From:	Arif, Syed
To:	Scearce, Lynn
Cc:	Koerner, Jeff; Linero, Alvaro; Read, David
Subject:	Georgia Pacific - Palatka ESP Replacement
Date:	Thursday, January 03, 2013 8:28:55 AM
Attachments:	Draft 1070005-078-AC - Written Notice Signed.pdf Draft 1070005-078-AC - Written Notice.docx Draft 1070005-078-AC - Public Notice.doc Draft 1070005-078-AC - TEPD.docx Draft 1070005-078-AC- Permit.docx

---

Lynn – Attached are documents for a minor AC modification at the above referenced facility. Please clerk and issue the project.

Jeff - This minor air construction permit revision will allow the replacement of the existing damaged ESP for the No. 4 combination boiler with the ESP previously used for the No. 5 power boiler at the Palatka Mill. The replacement is necessary because the original ESP was damaged by fire in November 2012. The power boiler ESP is nearly identical in size, design and configuration to the combination boiler ESP and should provide equivalent PM control efficiency. A 14-day comment period on the public notice is required for this project.

Thanks,
Syed