



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Bob Martinez, Governor

Dale Twachtman, Secretary

John Shearer, Assistant Secretary

January 4, 1991

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Harry Schindehette, P.E.
Director of Utilities
City of Fort Pierce
Post Office Box 3191
Fort Pierce, Florida 34948

Re: AC 56-185836 - Fort Pierce Utilities Authority
H. D. King Unit 9

Dear Mr. Schindehette:

We have reviewed your December 5, 1990 response to our letter of November 21, 1990 concerning the above referenced permit application. We have the following comments:

1. If you are willing to accept permit conditions allowing only the burning of natural gas in Units 6, 7, 8 and 9, we can deem your application complete as of December 5, 1990 and continue processing your permit application for Unit 9. However, we would like to have the 1990 NO_x compliance test.
2. If you want to have the authorization to burn fuel oil under emergency conditions in any unit (including Units 6, 7 and 8), then you must submit modeling of sulfur dioxide and particulate emissions for all short-term averaging times which includes all of the units you intend to burn fuel oil in. Please refer to C. H. Fancy's December 26, 1990 letter responding to your request for an emergency order for burning fuel oil in Units 6, 7 and 8. In addition, if you want to burn fuel oil in Units 8 or 9, you must also model for increment consumption.

Please advise us which option you want to choose. Please write to me at the address above or call Barry Andrews at 904-488-1344.

Sincerely,

C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/CH/plm

c: S. Day, P.E.
J. Miller
H. Lamb
I. Goldman