

Jeb Bush
Governor

Department of Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, Florida 32399-3000

David B. Struhs
Secretary

February 19, 2001

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Gary Lambert
CPV Atlantic, Ltd
45 Braintree Hill Office Park, Suite 107
Braintree, MA 02184

Re: DEP File No. 1110101-001-AC (PSD-FL-312)
CPV Atlantic Power Generating Facility
Combined Cycle Power Project


Dear Mr. Lambert:

Enclosed is one copy of the Draft Permit, Technical Evaluation and Preliminary Determination, and Draft BACT Determination, for the CPV Atlantic Power Generating Facility to be located near Port St. Lucie in St. Lucie County. The Department's Intent to Issue Air Construction Permit and the "PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT" are also included.

The "PUBLIC NOTICE" must be published one time only as soon as possible in a newspaper of general circulation in the area affected, pursuant to Chapter 50, Florida Statutes. Proof of publication, i.e., newspaper affidavit, must be provided to the Department's Bureau of Air Regulation office within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit.

Please submit any written comments you wish to have considered concerning the Department's proposed action to A. A. Linero, P.E., Administrator, New Source Review Section at the above letterhead address. If you have any questions, please call Ms. Teresa Heron at 850/921-9529 or Mr. Linero at 850/921-9523.

Sincerely,


C. H. Fancy, P.E., Chief,
Bureau of Air Regulation

CHF/al

Enclosures

In the Matter of an
Application for Permit by:

Mr. Gary Lambert
CPV Atlantic, Ltd.
35 Braintree Hill Office Park, Suite 107
Braintree, Massachusetts 02184

DEP File No. 1110101-001-AC and PSD-FL-312
Combined Cycle Facility
St. Lucie County

INTENT TO ISSUE AIR CONSTRUCTION PERMIT

The Department of Environmental Protection (Department) gives notice of its intent to issue an air construction permit (copy of DRAFT Permit attached) for the proposed project, detailed in the application specified above and the attached Technical Evaluation and Preliminary Determination, for the reasons stated below.

The applicant, CPV Atlantic, Ltd., applied on December 29, 2000 to the Department to construct a combined cycle electrical power generating plant consisting of a nominal 170 MW combustion turbine-electrical generator, an unfired heat recovery steam generator, a separate steam-electrical generator, a 200-foot stack, a mechanical draft cooling tower, a 1.0 million gallon fuel oil storage tank, and other ancillary equipment. The project will be located at a new site near Port St. Lucie in St. Lucie County.

The Department has permitting jurisdiction under the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4, 62-210, and 62-212 of the Florida Administrative Code (F.A.C.). The above actions are not exempt from permitting procedures. The Department has determined that an air construction permit is required to perform proposed work. The Department intends to issue this air construction permit based on the belief that the applicant has provided reasonable assurances to indicate that operation of these emission units will not adversely impact air quality, and the emission units will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297, F.A.C.

Pursuant to Section 403.815, F.S., and Rule 62-110.106(7)(a)1., F.A.C., you (the applicant) are required to publish at your own expense the enclosed Public Notice of Intent to Issue Air Construction Permit. The notice shall be published one time only in the legal advertisement section of a newspaper of general circulation in the area affected. Rule 62-110.106(7)(b), F.A.C., requires that the applicant cause the notice to be published as soon as possible after notification by the Department of its intended action. For the purpose of these rules, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. If you are uncertain that a newspaper meets these requirements, please contact the Department at the address or telephone number listed below. The applicant shall provide proof of publication to the Department's Bureau of Air Regulation, at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400 (Telephone: 850/488-0114 / Fax 850/ 922-6979). You must provide proof of publication within seven days of publication, pursuant to Rule 62-110.106(5), F.A.C. No permitting action for which published notice is required shall be granted until proof of publication of notice is made by furnishing a uniform affidavit in substantially the form prescribed in section 50.051, F.S. to the office of the Department issuing the permit. Failure to publish the notice and provide proof of publication may result in the denial of the permit pursuant to Rules 62-110.106(9) & (11), F.A.C.

The Department will issue the final permit with the attached conditions unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments and requests for public meetings concerning the proposed permit issuance action for a period of 30 (thirty) days from the date of publication of Public Notice of Intent to Issue Air Construction Permit. Written comments and requests for public meetings should be provided to the Department's Bureau of Air Regulation at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under Section 120.542 F.S. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Mediation is not available in this proceeding. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.


The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. The petition must specify the following information: (a) The name, address, and telephone number of the petitioner; (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any; (c) Each rule or

portion of a rule from which a variance or waiver is requested; (d) The citation to the statute underlying (implemented by) the rule identified in (c) above; (e) The type of action requested; (f) The specific facts that would justify a variance or waiver for the petitioner; (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in Section 120.542(2) F.S., and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

Executed in Tallahassee, Florida.


for C. H. Fancy, P.E., Chief
Bureau of Air Regulation


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this INTENT TO ISSUE AIR CONSTRUCTION PERMIT (including the PUBLIC NOTICE, Technical Evaluation and Preliminary Determination, and the DRAFT permit) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 2/20/01 to the person(s) listed:

Gary Lambert, CPV Atlantic, Ltd.*
Gregg Worley, EPA
John Bunyak, NPS
Isidore Goldman, DEP SED
Danna Civetti, DEP St. Lucie Branch
Chair, St. Lucie County BCC*
Mayor, Port St. Lucie*
Scott Sumner, P.E., TRC
Cathy Sellers, Esq., Moyle Flanagan

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.


(Clerk) 2/20/01 (Date)

PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

DEP File No. 1110101-001-AC and PSD-FL-312

CPV Atlantic Power Generating Facility
Combined Cycle Power Project

St. Lucie County

The Department of Environmental Protection (Department) gives notice of its intent to issue an air construction permit to CPV Atlantic Ltd. The permit is to construct a combined cycle electrical power generating plant near Port St. Lucie in St. Lucie County. A Best Available Control Technology (BACT) determination was required pursuant to Rule 62-212.400, F.A.C., Prevention of Significant Deterioration of Air Quality (PSD), for emissions of particulate matter (PM/PM₁₀), carbon monoxide (CO), sulfur dioxide (SO₂), sulfuric acid mist, and nitrogen oxides (NO_x). A maximum achievable control technology (MACT) determination for hazardous air pollutants was not required. The applicant's name and address are CPV Atlantic Ltd., 35 Braintree Hill Office Park, Suite 107, Braintree, Massachusetts 02184.

The project consists of: a nominal 170 megawatt General Electric 7FA combustion turbine-electrical generator, an unfired heat recovery steam generator, a separate steam-electrical generator, a 200-foot stack, a mechanical draft cooling tower, a 1.0 million gallon fuel oil storage tank, and other ancillary equipment. Back-up distillate fuel oil will be burned for a maximum of 720 hours per year.

NO_x emissions will be controlled by selective catalytic reduction (SCR) to achieve 3.5 parts per million by volume, dry, at 15 percent oxygen (ppmvd) while burning gas and 10 ppmvd while burning low sulfur distillate fuel oil. Emissions of CO will be controlled to 9 and 20 ppmvd while burning gas and fuel oil respectively. Emissions of PM/PM₁₀, SO₂, sulfuric acid mist, volatile organic compounds, and hazardous air pollutants (HAP) will be controlled to very low levels by good combustion and use of inherently clean pipeline quality natural gas and low sulfur (0.05 percent) distillate fuel oil. Ammonia emissions (NH₃) generated due to NO_x control will be limited to 5 ppmvd.

The following table summarizes the maximum emissions (in tons per year) of regulated air pollutants as a result of this project.

<u>Pollutants</u>	<u>Maximum Potential Emissions</u>	<u>PSD Significant Emission Rate</u>
PM/PM ₁₀	102	25/15
Sulfuric acid mist	12	7
SO ₂	76	40
NO _x	126	100
VOC	15	40
CO	222	100
NH ₃ (non-regulated)	52	NA
HAP	8	NA

An air quality impact analysis was conducted. Maximum impacts due to proposed emissions from the project are less than the applicable PSD Class II significant impact levels for all applicable pollutants. Therefore no increment consumption analysis was required. Emissions from the facility will not cause or contribute to a violation of any state or federal ambient air quality standards. The project has no significant impact on the PSD Class I Everglades National Park.

The Department will issue the FINAL permit with the attached conditions unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments and requests for a public meeting concerning the proposed permit issuance action for a period of thirty (30) days from the date of publication of "Public Notice of Intent to Issue Air Construction Permit." Written comments should be provided to the Department's Bureau of Air Regulation at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below. Mediation is not available in this proceeding.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station # 35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Dept. of Environmental Protection	Dept. of Environmental Protection	Dept. of Environmental Protection
Bureau of Air Regulation	Southeast District Office	Port St. Lucie Branch Office
111 S. Magnolia Drive, Suite 4	400 North Congress Avenue	1801 S.E. Hillmoor Dr., C 204
Tallahassee, Florida, 32301	W. Palm Beach, Florida 33416-5425	Port St. Lucie, Florida 34952
Telephone: 850/488-0114	Telephone: 561/681-6600	Telephone: 561/398-2806
Fax: 850/922-6979	Fax: 561/681-6755	Fax: 561/398-2815

The complete project file includes the application, technical evaluations, Draft Permit, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Administrator, New Resource Review Section at 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301, or call 850/488-0114, for additional information. The Department's technical evaluations and Draft Permit can be viewed at www.dep.state.fl.us/air/permitting.htm by clicking on Utility and Other Facility Permits.

TECHNICAL EVALUATION
AND
PRELIMINARY DETERMINATION

CPV Atlantic Power Generating Facility

Combined Cycle Unit

St. Lucie County

Facility I.D. No. 1110101-001-AC
PSD-FL-312

Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation

February 19, 2001

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

1. APPLICATION INFORMATION

1.1 Applicant Name and Address

CPV Atlantic, Ltd.
35 Braintree Office Park, Suite 107
Braintree, Massachusetts 02184

Authorized Representative: Mr. Gary Lambert

1.2 Reviewing and Process Schedule

12-29-00: Date of Receipt of Application
02-13-01 Application deemed complete
02-19-01: Intent to Issue PSD Permit

2. FACILITY INFORMATION

2.1 Facility Location

This new facility will occupy 10.5 acres of a 20-acre tract at LTC Ranch Industrial Park immediately Northwest of Glades Cut-off Road (SR 709) and East of I-95, near Port St. Lucie in St. Lucie County. This site is approximately 180 kilometers North-Northeast of the Everglades National Park, a Class I PSD Area. The UTM coordinates are Zone 17; 558.0 km E; 3025.9 km N.




Figure 1 – Location of Port St. Lucie




Figure 2 – I-95 and SR 709, Port St. Lucie

2.2 Standard Industrial Classification Codes (SIC)

Industry Group No.	49	Electric, Gas, and Sanitary Services
Industry No.	4911	Electric Services

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

2.3 Facility Category

This new facility will generate electric power from a combined cycle unit including an unfired heat recovery steam generator (HRSG). The combustion turbine will be fired primarily with natural gas as the primary fuel, with distillate fuel as backup.

The facility is classified as a Major or Title V Source of air pollution because emissions of at least one regulated air pollutant, such as particulate matter (PM/PM₁₀), sulfur dioxide (SO₂), nitrogen oxides (NO_x), carbon monoxide (CO), or volatile organic compounds (VOC) exceeds 100 TPY. The facility is within an industry included in the list of the 28 Major Facility Categories per Table 212.400-1, F.A.C. Because present emissions are greater than 100 TPY for CO and NO_x, the facility is also a Major Facility with respect to Rule 62-212.400, Prevention of Significant Deterioration (PSD).

As a Major Facility, project emissions greater than: Significant Emission Rates given in Table 212.400-2 (100 TPY of CO; 40 TPY of NO_x, SO₂, or VOC, 25/15 TPY of PM/PM₁₀) require review per the PSD rules and a determination of Best Available Control Technology (BACT). This facility is also subject to the Title IV Acid Rain Program, 40 CFR 72 and must apply for an Acid Rain Permit at least 24 months prior to start up.

3. PROJECT DESCRIPTION

This permit addresses the following emissions units:

EMISSION UNIT	SYSTEM	EMISSION UNIT DESCRIPTION
001	Power Generation	One 170-megawatt combustion turbine-electrical generator with unfired heat recovery steam generator
002	Water Cooling	Cooling tower
003	Fuel Storage	One 1-million gallon fuel oil storage tank

Competitive Power Ventures (CPV), Atlantic Ltd proposes to construct a cycle combustion turbine at their new site located near Port St. Lucie in St. Lucie County. The project includes: a nominal 170 megawatt (MW) General Electric 7FA combustion turbine-electrical generator, an un-fired heat recovery steam generator (HRSG), a separate steam-electrical generator, a 200-foot stack, a mechanical draft cooling tower, a 1-million gallon fuel oil storage tank, and other ancillary equipment.

The main fuel will be natural gas and the unit will operate up to 8760 hours per year, of which no more than 720 represent fuel oil operation (30 days). The turbine will have a nominal heat input rating of 1,700 million Btu per hour (mmBtu/hr), lower heating value (LHV), while firing natural gas and 1918 mmBtu/hr, LHV, while firing fuel oil at 25 °F while operating at 100% load.

The turbine will be equipped with Dry Low NO_x (DLN-2.6) combustors and Selective Catalytic Reduction (SCR) to control NO_x emissions to 3.5 parts per million by volume, dry, at 15% O₂ (ppmvd) while burning natural gas and 10 ppmvd while burning fuel oil.

Emission increases will occur for CO, SO₂, sulfuric acid mist (SAM), PM/PM₁₀, VOC, and NO_x.





Figure 3 - Internal and External Views of GE MS7001FA

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

4. PROCESS DESCRIPTION

Much of the following discussion is from a 1993 EPA document on Alternative Control Techniques for NO_x Emissions from Stationary Gas turbines. Project specific information is interspersed where appropriate.

A gas turbine is an internal combustion engine that operates with rotary rather than reciprocating motion. Ambient air is drawn into the 18-stage compressor of the GE 7FA (Figure 3) where it is compressed by a pressure ratio of about 15 times atmospheric pressure. The compressed air is then directed to the combustor section, where fuel is introduced, ignited, and burned. The combustion section consists of 14 separate can-annular combustors. Figure 4 is photograph from the GE website of a "7FA on the half-shell" as viewed from the compressor section.




Figure 4 – Internal View of GE 7FA. (GE Website)

Flame temperatures in a typical combustor section can reach 3600 degrees Fahrenheit (°F). Units such as the 7FA operate at lower flame temperatures, which minimize NO_x formation. The hot combustion gases are then diluted with additional cool air and directed to the turbine section at temperatures of approximately 2400 °F. Energy is recovered in the turbine section in the form of shaft horsepower, of which typically more than 50 percent is required to drive the internal compressor section. The balance of recovered shaft energy is available to drive the external load unit such as an electrical generator.

There are three basic operating cycles for gas turbines. These are simple, regenerative and combined cycles. In the CPV project, the unit will operate primarily in combined cycle mode, meaning that the gas turbine drives an electric generator while the exhausted gases are used to raise steam in a heat recovery steam generator (HRSG). The steam is then fed to a separate steam turbine, which also drives an electrical generator.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Figure 5 is a process flow diagram for a combined cycle unit basically similar to the proposed CPV project. CPV will also include fuel oil back-up, SCR, and power augmentation.

At high ambient temperature, the units cannot generate as much power because of lower compressor inlet air density. To partially compensate for the loss of output (which can be on the order of 20 MW compared to referenced temperatures), a chilling unit or evaporative inlet fogger may be installed ahead of the combustion turbine inlet to increase air density. Neither of these features is planned for the CPV project.

Other possibilities include placing a gas-fired duct burner between the combustion turbine and the HRSG, power augmentation and peaking. Power augmentation is accomplished by injecting some steam from the HRSG into the rotor (power) section of the combustion turbine. According to CPV, power augmentation will be employed in this project at temperatures above 59 °F "to make additional electrical output that is lost due to increasing temperature." Peaking is simply running the unit at greater than design fuel input.

The project includes highly automated controls, described as the GE Mark V Control System. The SPEEDTRONIC Mark V Gas Turbine Control System is designed to fulfill all of the gas turbine control requirements.

Additional process information related to the combustor design, and control measures to minimize NO_x formation are given in the draft BACT determination distributed with this evaluation.

5. RULE APPLICABILITY

The proposed project is subject to preconstruction review requirements under the provisions of 40 CFR 52.21, Chapter 403, Florida Statutes, and Chapters 62-4, 62-204, 62-210, 62-212, 62-214, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.).

This facility is located in St. Lucie County, an area designated as attainment for all criteria pollutants in accordance with Rule 62-204.360, F.A.C. The proposed project is subject to review under Rule 62-212.400., F.A.C., Prevention of Significant Deterioration (PSD), because the potential emission increases for PM/PM₁₀, CO, SO₂, SAM and NO_x exceed the significant emission rates given in Chapter 62-212, Table 62-212.400-2, F.A.C.

This PSD review consists of a determination of Best Available Control Technology (BACT) for PM/PM₁₀, SO₂, SAM, CO, and NO_x. An analysis of the air quality impact from proposed project upon soils, vegetation and visibility is required along with air quality impacts resulting from associated commercial, residential, and industrial growth.

The emission units affected by this PSD permit shall comply with all applicable provisions of the Florida Administrative Code (including applicable portions of the Code of Federal Regulations incorporated therein) and, specifically, the following Chapters and Rules:




Figure 5 - Process Flow Diagram of a Basic Combined Cycle Power Plant

(gas-only, without SCR, and no power augmentation)

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

5.1 State Regulations

Chapter 62-4	Permits.
Rule 62-204.220	Ambient Air Quality Protection
Rule 62-204.240	Ambient Air Quality Standards
Rule 62-204.260	Prevention of Significant Deterioration Increments
Rule 62-204.800	Federal Regulations Adopted by Reference
Rule 62-210.300	Permits Required
Rule 62-210.350	Public Notice and Comments
Rule 62-210.370	Reports
Rule 62-210.550	Stack Height Policy
Rule 62-210.650	Circumvention
Rule 62-210.700	Excess Emissions
Rule 62-210.900	Forms and Instructions
Rule 62-212.300	General Preconstruction Review Requirements
Rule 62-212.400	Prevention of Significant Deterioration
Rule 62-213	Operation Permits for Major Sources of Air Pollution
Rule 62-214	Requirements For Sources Subject To The Federal Acid Rain Program
Rule 62-296.320	General Pollutant Emission Limiting Standards
Rule 62-297.310	General Test Requirements
Rule 62-297.401	Compliance Test Methods
Rule 62-297.520	EPA Continuous Monitor Performance Specifications

5.2 Federal Rules

40 CFR 52.21	Prevention of Significant Deterioration
40 CFR 60	NSPS Subparts GG and Kb
40 CFR 60	Applicable sections of Subpart A, General Requirements
40 CFR 72	Acid Rain Permits (applicable sections)
40 CFR 73	Allowances (applicable sections)
40 CFR 75	Monitoring (applicable sections including applicable appendices)
40 CFR 77	Acid Rain Program-Excess Emissions (future applicable requirements)

6. SOURCE IMPACT ANALYSIS

6.1 Emission Limitations

The proposed project will emit the following PSD pollutants (Table 212.400-2): particulate matter, sulfur dioxide, nitrogen oxides, volatile organic compounds, sulfuric acid mist, carbon monoxide, and negligible quantities of, mercury and lead. The applicant's proposed annual emissions are summarized in the Table below and form the basis of the source impact review. The Department's proposed permitted allowable emissions for these Units are summarized in the Draft BACT document and Specific Conditions Nos. 12 through 17 of Draft Permit PSD-FL-312.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

6.2 Emission Summary

The emissions for all PSD pollutants as a result of the construction of this facility are presented below:

FACILITY EMISSIONS (TOTAL TPY) AND PSD APPLICABILITY

Pollutants	Gas Firing ¹	Oil Firing ³	Total ¹	PSD Significance	PSD REVIEW?
PM/PM ₁₀	88	19	102 ⁴	25	Yes
SO ₂	44	36	76	40	Yes
NO _x	106	29	126	40	Yes
CO	197	25	222	100	Yes
Ozone (VOC)	13	3	15	40	No
Sulfuric Acid Mist	8	4	12	7	Yes
Mercury	<<0.1	<<0.1	<0.1	0.1	No
Lead	<<0.6	<<0.6	<0.6	0.6	No
HAPs			8 ⁵	NA	NA

1. Based on 8760 hours of gas firing. Reference Temperature is 25 °F.
2. Based on 720 hours of fuel oil firing. Reference Temperature is 25 °F.
3. Based on 8040 hours of gas firing and 720 hours of fuel oil firing. Reference Temperature is 25 °F.
4. Includes 3.5 TPY of PM/PM₁₀ from the cooling tower.
5. Less than 10 TPY for any single HAP and less than 25 TPY for all HAPs. Case-by-case MACT does not apply.

6.3 Control Technology

Emissions control will be primarily accomplished by good combustion of inherently clean fuels. During gas operation, the combustors will operate in lean pre-mixed mode to minimize the flame temperature and nitrogen oxides formation potential. The DLN-2.6 combustors will control combustion turbine emissions of CO and NO_x to 9 ppmvd @15% O₂ between 50 and 100% of full load under normal operating conditions and during gas burning. Further control for NO_x will be achieved by SCR to 3.5 (gas) and 10 (oil) ppmvd @15% O₂. Emissions of CO during oil burning are expected not to exceed 20 ppmvd. A full discussion is given in the Draft Best Available Control Technology (BACT) Determination (see Permit Appendix BD). The Draft BACT is incorporated into this evaluation by reference.

6.4 Air Quality Analysis

6.4.1 Introduction

The proposed project will increase emissions of five pollutants at levels in excess of PSD significant amounts: PM/PM₁₀, CO, NO_x, SO₂, and SAM. PM₁₀, SO₂ and NO_x are criteria pollutants and have national and state ambient air quality standards (AAQS), PSD increments, and significant impact levels defined for them. CO is a criteria pollutant and has only AAQS and significant impact levels defined for it. There are no applicable PSD increments or AAQS for SAM.

The applicant's initial PM/PM₁₀, CO, NO_x and SO₂ air quality impact analyses for this project predicted no significant impacts; therefore, further applicable AAQS impact and PSD increment analyses for these pollutants were not required. Also, the maximum predicted impacts for all of

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

the pollutants listed above were below their respective *de minimis* ambient impact levels. Therefore, pre-construction monitoring at the proposed site was not required for this project.

No impacts on the Everglades National Park, the closest PSD Class I area, were calculated since the project is located 180 km north of this area and the projected impacts would be expected to be well below any PSD Class I significant impact levels.

Based on the preceding discussion, the air quality analyses required by the PSD regulations for this project were the following:

- A significant impact analysis for PM₁₀, CO, SO₂ and NO_x;
- An analysis of impacts on soils, vegetation, visibility, and of growth-related air quality modeling impacts.

Based on these required analyses, the Department has reasonable assurance that the proposed project, as described in this report and subject to the conditions of approval proposed herein, will not cause or significantly contribute to a violation of any AAQS or PSD increment. However, the following EPA-directed stack height language is included: "In approving this permit, the Department has determined that the application complies with the applicable provisions of the stack height regulations as revised by EPA on July 8, 1985 (50 FR 27892). Portions of the regulations have been remanded by a panel of the U.S. Court of Appeals for the D.C. Circuit in *NRDC v. Thomas*, 838 F. 2d 1224 (D.C. Cir. 1988). Consequently, this permit may be subject to modification if and when EPA revises the regulation in response to the court decision. This may result in revised emission limitations or may affect other actions taken by the source owners or operators." A more detailed discussion of the required analyses follows.

6.4.2 Models and Meteorological Data Used in the Air Quality Analysis

The EPA-approved Industrial Source Complex Short-Term (ISCST3) dispersion model was used to evaluate the pollutant emissions from the proposed project in the surrounding Class II Area. This model determines ground-level concentrations of inert gases or small particles emitted into the atmosphere by point, area, and volume sources. It incorporates elements for plume rise, transport by the mean wind, Gaussian dispersion, and pollutant removal mechanisms such as deposition. The ISCST3 model allows for the separation of sources, building wake downwash, and various other input and output features. A series of specific model features, recommended by the EPA, are referred to as the regulatory options. The applicant used the EPA recommended regulatory options. Direction-specific downwash parameters were used for all sources for which downwash was considered. The stacks associated with this project all satisfied the good engineering practice (GEP) stack height criteria.

Meteorological data used in the ISCST3 model consisted of a concurrent 5-year period of hourly surface weather observations and twice-daily upper air soundings from the National Weather Service (NWS) station at the West Palm Beach International Airport. The 5-year period of meteorological data was from 1987 through 1991. The station was selected for use in the study because it is the closest primary weather station to the study area and is most representative of the project site. The surface observations included wind direction, wind speed, temperature, cloud cover, and cloud ceiling.

6.4.3 Significant Impact Analysis

Typically, in order to conduct a significant impact analysis, the applicant conducts modeling using only the proposed project's emissions at worst load conditions. The highest predicted

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

short-term concentrations and highest predicted annual averages predicted by this modeling are compared to the appropriate significant impact levels. If this modeling at worst load conditions shows significant impacts, additional modeling that includes the emissions from surrounding facilities is required to determine the project's impacts on the existing air quality and any applicable AAQS or PSD increments. If no significant impacts are shown, the applicant does not have to conduct any further modeling. Nearly 800 receptors were placed along the facility's restricted property line and out to 20 km from the facility, which is located in a PSD Class II area.

MAXIMUM PROJECT AIR QUALITY IMPACTS FOR COMPARISON TO THE PSD CLASS II SIGNIFICANT IMPACT LEVELS IN THE VICINITY OF THE FACILITY

Pollutant	Averaging Time	Max Predicted Impact (ug/m ³)	Significant Impact Level (ug/m ³)	Significant Impact?
SO ₂	Annual	0.05	1	NO
	24-Hour	1	5	NO
	3-Hour	7	25	NO
PM ₁₀	Annual	0.1	1	NO
	24-Hour	2	5	NO
CO	8-Hour	4	500	NO
	1-Hour	20	2000	NO
NO ₂	Annual	0.05	1	NO

The results of the significant impact modeling show that there are no significant impacts predicted due to the emissions from this project; therefore, no further modeling was required.

6.4.4 Additional Impacts Analysis

Impact On Soils, Vegetation, And Wildlife

Very low emissions are expected from this natural gas-fired combustion turbine in comparison with conventional power plants generating equal power. Emissions of acid rain and ozone precursors will be very low. The maximum ground-level concentrations predicted to occur for PM₁₀, CO, NO_x and SO₂ as a result of the proposed project, including background concentrations and all other nearby sources, will be less than the respective ambient air quality standards (AAQS).

The project impacts are also less than the significant impact levels for PM₁₀, CO, NO_x and SO₂, which in-turn, are less than the applicable allowable increments for each pollutant. Because the AAQS are designed to protect both the public health and welfare, and the project impacts are less than significant, it is reasonable to assume the impacts on soils, vegetation, and wildlife will be minimal or insignificant.

Effects from sulfuric acid mist are expected to be minor. Ammonia emissions will result as a result of NO_x control. The impacts of ammonia on soils, vegetation, and wildlife will be in the same range as the effects of NO_x on the same media.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Impact On Visibility

Natural gas is a clean fuel and produces little particulate emissions. The low NO_x and SO₂ emissions will also minimize plume opacity. Due to the large distance between this source and the nearest PSD Class I Area, plus the type and amount of emissions from the source, the U.S. National Park Service believes that there is a low potential for visibility impacts. Therefore, a regional haze analysis was not required for this project.

The effects on visibility due to additional particulate matter from ammonia use are very difficult to quantify. These will be minimized by limiting ammonia emissions (slip) to 5 ppmvd.

Growth-Related Air Quality Impacts

There will be short-term increases in the labor force to construct the project. These temporary increases will not result in significant commercial and residential growth in the vicinity of the project. Operation of the combustion turbine will require few permanent employees, which will cause no significant impact on the local Area.

This project is a response to statewide and regional growth and also accommodates more growth. There are no adequate procedures under the PSD rules to fully assess these impacts. However, the type of project proposed has a small overall physical "footprint," and the lowest air emissions per unit of electric power generating capacity.

Hazardous Air Pollutants

The project is not a major source of hazardous air pollutants (HAPs) and is not subject to any maximum achievable control technology (MACT) requirements pursuant to Department rules or Section 112 of the Clean Air Act.

7. CONCLUSION

Based on the foregoing technical evaluation of the application and additional information submitted by the applicant, the Department has made a preliminary determination that the proposed project will comply with all applicable state and federal air pollution regulations.

A. A. Linero, P.E.

Cleve Holladay, Meteorologist

PERMITTEE:

CPV Atlantic, Ltd.
35 Braintree Hill Office Park, Suite 107
Braintree, Massachusetts 02184

File No.	1110101-001-AC
Permit No.	PSD-FL-312
SIC No.	4911
Expires:	March 31, 2004

Authorized Representative:

Gary Lambert, Executive Vice President

PROJECT AND LOCATION:

Air construction permit pursuant to the requirements for the Prevention of Significant Deterioration of Air Quality (PSD) for the construction of a nominal gas-fired combined cycle electrical power plant. No. 2 distillate fuel oil will be used as back-up fuel. The plant will be known as the CPV Atlantic Power Generating Facility.

The project will be located Northwest of Glades Cut-off Road (SR 709) and East of I-95, near Port St. Lucie in St. Lucie County. UTM coordinates are Zone 17; 558.0 km E; 3025.9 km N.

STATEMENT OF BASIS:

This permit is issued under the provisions of Chapter 403 of the Florida Statutes, and Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code. The above named permittee is authorized to modify the facility in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department of Environmental Protection (Department).

The attached Appendices are made a part of this permit:

Appendix GC Construction Permit General Conditions
Appendix BD BACT Determination
Appendix GG NSPS Subpart GG Requirements

Howard L. Rhodes, Director
Division of Air Resources Management

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION I - FACILITY INFORMATION

FACILITY DESCRIPTION

The proposed CPV facility is a combined cycle power plant. Key components include:

- One nominal 170 megawatt (MW) gas-fired combustion turbine-electrical generator with an un-fired heat recovery steam generator (HRSG) and 150-foot stack;
- A selective catalytic reduction unit located within the HRSG;
- A 1-million gallon storage tank for backup No. 2 distillate fuel oil;
- A separate steam-electrical generator;
- A five-cell mechanical draft cooling tower; and
- Ancillary facilities including miscellaneous equipment buildings, ammonium storage, demineralized water storage, fire water storage, diesel-fired fire water pump, and a 500 kW emergency generator.

EMISSION UNITS

This permit addresses the following emission units:

ARMS EMISSIONS UNIT NO.	SYSTEM	EMISSION UNIT DESCRIPTION
001	Power Generation	One 170-megawatt combustion turbine-electrical generator with unfired heat recovery steam generator
002	Water Cooling	One five-cell mechanical cooling tower
003	Fuel Storage	One 1-million gallon fuel oil storage tank

REGULATORY CLASSIFICATION

Title V: This facility is classified as a Major or Title V Source of air pollution because emissions of at least one regulated air pollutant, such as particulate matter (PM/PM₁₀), sulfur dioxide (SO₂), nitrogen oxides (NO_x), carbon monoxide (CO), or volatile organic compounds (VOC) exceeds 100 tons per year (TPY).

PSD: This facility is within an industry included in the list of the 28 Major Facility Categories per Table 62-212.400-1, F.A.C. Because emissions are greater than 100 TPY for at least one criteria pollutant, the facility is also a Major Facility with respect to Rule 62-212.400, Prevention of Significant Deterioration (PSD). With respect to Table 62-212.400-2, this facility modification results in emissions increases greater than 40 TPY of NO_x and SO₂, 25/15 TPY of PM/PM₁₀, 100 TPY of CO, and 7 TPY of sulfuric acid mist. These pollutants require PSD review and determinations of Best Available Control Technology (BACT) pursuant to Rule 62-212.400, F.A.C.

Title III: This facility is not a major source of hazardous air pollutants (HAPs). This facility is not subject to MACT applicability.

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION 1 - FACILITY INFORMATION

Title IV: The new combined cycle unit is subject to certain Acid Rain provisions of Title IV of the Clean Air Act.

NSPS: The new combined cycle gas turbine is subject to New Source Performance Standards 40 CFR 60, Subpart GG for Gas Turbines and the Storage Tank is subject to 40 CFR 60, Subpart Kb.

NESHAP: The permittee did not identify any emission unit as being subject to a National Emissions Standards for Hazardous Air Pollutants (NESHAP).

PERMIT SCHEDULE

- xx/xx/01 Air Construction Permit Issued
- xx/xx/01 Notice of Intent to Issue published in _____
- 02/19/01 Distributed Intent to Issue Permit
- 02/13/01 Application deemed complete
- 12/29/00 Received PSD Application

RELEVANT DOCUMENTS:

The documents listed below are the basis of the permit. They are specifically related to this permitting action, but are not incorporated into this permit. These documents are on file with the Department.

- Application received on December 29, 2000
- Comments from the Fish and Wildlife Service dated January 23, 2001
- Department letter to CPV dated January 26, 2001
- CPV letter regarding CPV Gulfcoast Project CO cost calculations dated January 26, 2001
- CPV responses dated February 13, 2001 and _____
- Department's Intent to Issue and Public Notice Package dated February 21, 2001.
- Letter from EPA Region IV dated _____
- Department's Final Determination and Best Available Control Technology Determination issued concurrently with this Final Permit.

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION II. COMMON SPECIFIC CONDITIONS

GENERAL AND ADMINISTRATIVE REQUIREMENTS

1. Permitting Authority: All documents related to applications for permits to construct, operate or modify an emissions unit should be submitted to the Bureau of Air Regulation (BAR), Florida Department of Environmental Protection (FDEP), at 2600 Blairstone Road, Tallahassee, Florida 32399-2400 and phone number (850)488-0114.
2. Compliance Authority: All documents related to reports, tests, and notifications should be submitted to the DEP Southeast District Office, 400 North Congress Avenue W, West Palm Beach, Florida, 33401 and phone number 561/681-6755, fax 561-681-6755. Copies shall be sent to the DEP Port St. Lucie Branch Office, 1801 S.E. Hillmoor Dr, C 204, Port St. Lucie, Florida 34952 and phone number 561/398-2806, fax 561/398-2815.
3. General Conditions: The owner and operator is subject to and shall operate under the attached General Permit Conditions G.1 through G.15 listed in Appendix GC of this permit. General Permit Conditions are binding and enforceable pursuant to Chapter 403 of the Florida Statutes. [Rule 62-4.160, F.A.C.]
4. Terminology: The terms used in this permit have specific meanings as defined in the corresponding chapters of the Florida Administrative Code.
5. Forms and Application Procedures: The permittee shall use the applicable forms listed in Rule 62-210.900, F.A.C. and follow the application procedures in Chapter 62-4, F.A.C. [Rule 62-210.900, F.A.C.]
6. Modifications: The permittee shall give written notification to the Department when there is any modification to this facility. This notice shall be submitted sufficiently in advance of any critical date involved to allow sufficient time for review, discussion, and revision of plans, if necessary. Such notice shall include, but not be limited to, information describing the precise nature of the change; modifications to any emission control system; production capacity of the facility before and after the change; and the anticipated completion date of the change. [Chapters 62-210 and 62-212, F.A.C.]
7. New or Additional Conditions: Pursuant to Rule 62-4.080, F.A.C., for good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
8. PSD Approval to Construct Expiration: Approval to construct shall become invalid if construction is not commenced within 18 months after receipt of such approval, or if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable time. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified. [40 CFR 52.21(r)(2)]
9. Completion of Construction: The permit expiration date is March 31, 2004. Physical construction shall be complete by December 31, 2003. The additional time provides for testing, submittal of results, and submittal of the Title V permit to the Department.

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION II. COMMON SPECIFIC CONDITIONS

10. Permit Expiration Date Extension: The permittee, for good cause, may request that this PSD permit be extended. Such a request shall be submitted to the Bureau of Air Regulation prior to 60 days before the expiration of the permit (Rule 62-4.080, F.A.C.).
11. BACT Determination: In conjunction with extension of the 18 month periods to commence or continue construction, the extension of the March 31, 2004 permit expiration date, or any increases in MW generated by steam, heat input limits, hours of operation, oil firing, low or baseload operation, short-term or annual emission limits, annual fuel heat input limits or similar changes; the permittee may be required to demonstrate the adequacy of any previous determination of best available control technology for the source. [40 CFR 52.21(j)(4); 40CFR 51.166(j) and Rule 62-4.070 F.A.C.]
12. Application for Title IV Permit: An application for a Title IV Acid Rain Permit must be submitted to the U.S. Environmental Protection Agency Region IV office in Atlanta, Georgia and a copy to the DEP's Bureau of Air Regulation in Tallahassee at least 24 months before the date on which the new unit begins serving an electrical generator greater than 25 MW. [40 CFR 72]
13. Application for Title V Permit: An application for a Title V operating permit, pursuant to Chapter 62-213, F.A.C., must be submitted to the DEP's Bureau of Air Regulation, and a copy to the Department's Southeast District Office. [Chapter 62-213, F.A.C.]

OPERATIONAL REQUIREMENTS

14. Plant Operation - Problems: If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify each Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations. [Rule 62-4.130, F.A.C.]
15. Operating Procedures: Operating procedures shall include good operating practices and proper training of all operators and supervisors. The good operating practices shall meet the guidelines and procedures as established by the equipment manufacturers. All operators (including supervisors) of air pollution control devices shall be properly trained in plant specific equipment. [Rule 62-4.070(3), F.A.C.]
16. Circumvention: The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without the applicable air control device operating properly. [Rule 62-210.650, F.A.C.]
17. Unconfined Particulate Matter Emissions: During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

SECTION II. COMMON SPECIFIC CONDITIONS

TESTING REQUIREMENTS

18. Test Notification: The permittee shall notify each Compliance Authority in writing at least 30 days prior to any initial NSPS performance tests and at least 15 days prior to any other required tests. Notification shall include the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and conducting the test. [Rule 62-297.310(7)(a)9., F.A.C. and 40 CFR 60.7, 60.8]
19. Calculation of Emission Rate: For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]
20. Applicable Test Procedures
- (a) *Required Sampling Time*. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. The minimum observation period for a visible emissions compliance test shall be sixty (60) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur. [Rule 62-297.310(4)(a)1. and 2., F.A.C.]
 - (b) *Minimum Sample Volume*. Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet. [Rule 62-297.310(4)(b), F.A.C.]
 - (c) *Calibration of Sampling Equipment*. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C. [Rule 62-297.310(4)(d), F.A.C.]
21. Determination of Process Variables
- (a) *Required Equipment*. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards. [Rule 62-297.310(5)(a), F.A.C.]
 - (b) *Accuracy of Equipment*. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value. [Rule 62-297.310(5)(b), F.A.C.]
22. Special Compliance Tests: When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION II. COMMON SPECIFIC CONDITIONS

emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]

23. Stack Testing Facilities: Stack sampling facilities shall be installed in accordance with Rule 62-297.310(6), F.A.C.
24. Operating Rate During Testing: Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rule 62-297.310(2)(b), F.A.C.]

RECORDS

25. Records Retention: All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request. [Rules 62-4.160(14) and 62-213.440(1)(b)2., F.A.C.]

REPORTS

26. Emissions Performance Test Results Reports: A report indicating the results of any required emissions performance test shall be submitted to each Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C. [Rule 62-297.310(8), F.A.C.].
27. Annual Operating Reports: Pursuant to Rule 62-210.370(2), F.A.C., Annual Operation Reports, the permittee is required to submit annual reports on the actual operating rates and emissions from this facility. Annual operating reports shall be sent to the DEP's Southeast District Office by March 1st of each year.

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

APPLICABLE STANDARDS AND REGULATIONS

1. Regulations: Unless otherwise indicated in this permit, the construction and operation of the subject emission units shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of Chapter 403, F.S. and Florida Administrative Code Chapters 62-4, 62-17, 62-204, 62-210, 62-212, 62-213, 62-214, 62-296, and 62-297; and the applicable requirements of the Code of Federal Regulations Section 40, Parts 52, 60, 72, 73, and 75.
2. Applicable Requirements: Issuance of a permit does not relieve the owner or operator of an emissions unit from complying with any applicable requirements, any emission limiting standards or other requirements of the air pollution rules of the Department or any other such requirements under federal, state, or local law, notwithstanding that these applicable requirements are not explicitly stated in this permit. In cases where there is an ambiguity or conflict in the specific conditions of this permit with any of the above-mentioned regulations, the more stringent local, state, or federal requirement applies.
[Rules 62-204.800 and Rules 62-210.300 and 62-4.070 (3) F.A.C.]
3. NSPS Requirements: The combined cycle gas turbine (Emissions Unit 001) shall comply with the applicable provisions of 40CFR60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted by reference in Rule 62-204.800(7)(b), F.A.C. The distillate oil storage tank (Emissions Unit 002) shall comply with all applicable provisions of 40CFR60, Subpart Kb, Standards of Performance for Volatile Organic Liquid Storage Vessels, adopted by reference in Rule 62-204.800, F.A.C. Emissions units subject to a specific NSPS subpart shall also comply with the applicable requirements of 40 CFR 60, Subpart A, General Provisions including:
 - 40CFR60.7, Notification and Recordkeeping
 - 40CFR60.8, Performance Tests
 - 40CFR60.11, Compliance with Standards and Maintenance Requirements
 - 40CFR60.12, Circumvention
 - 40CFR60.13, Monitoring Requirements
 - 40CFR60.19, General Notification and Reporting requirements

GENERAL OPERATION REQUIREMENTS

4. Authorized Fuels: The combined cycle gas turbine shall fire only pipeline-quality natural gas or No. 2 distillate oil (or a superior grade) containing no more than 0.05% sulfur by weight.
[Rules 62-210.200 (Definitions - Potential Emissions) and 62-212.400, F.A.C.]
5. Combustion Turbine Capacity: The maximum heat input to the combined cycle gas turbine shall not exceed 1,700 million Btu per hour (mmBtu/hr) when firing natural gas nor 1,918 mmBtu/hr when firing distillate fuel oil. The heat input limits are based on the lower heating value (LHV) of each fuel, 100% load, and ambient conditions of 25°F temperature, 60% relative humidity, and 14.7 psi pressure.

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

These maximum heat input rates will vary depending upon ambient conditions and the combustion turbine characteristics. Manufacturer's curves corrected for site conditions or equations for correction to other ambient conditions shall be provided to the Department within 45 days of completing the initial compliance testing. [Design, Rule 62-210.200, F.A.C. (Definitions - Potential Emissions)]

6. Hours of Operation: The combined cycle gas turbine may operate 8760 hours per year while firing natural gas. Distillate oil firing shall not exceed 720 hours during any consecutive 12 months. Power augmentation while firing gas is permitted 2000 hours per year and is not limited if oxidation catalyst is installed. The 2000 hour limit may be revised at the request of the applicant based upon review of actual performance and control equipment cost-effectiveness following proper public notice. [Applicant Request, Rule 62-210.200 (Definitions - Potential Emissions), F.A.C.]

CONTROL TECHNOLOGY

7. Automated Control System: The permittee shall install, calibrate, tune, operate, and maintain a SpeedtronicTM Mark VI automated gas turbine control system for the combined cycle unit. The system shall be designed and operated to monitor and control the gas turbine combustion process and operating parameters including, but not limited to: air/fuel distribution and staging, turbine speed, load conditions, temperatures, heat input, and fully automated startup/shutdown. [Design; 62-212.400(BACT), F.A.C.]
8. DLN Combustion Technology: The permittee shall install, tune, operate and maintain the General Electric dry low-NO_x combustion system (DLN 2.6 or better) to control NO_x emissions from the combined cycle gas turbine. Prior to the initial emissions performance tests for the gas turbine, the dry low-NO_x combustors and automated gas turbine control system shall be tuned to optimize the reduction of CO, NO_x, and VOC emissions. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations to minimize these pollutant emissions. The permittee shall provide at least 5 days advance notice prior to any tuning session. The permittee shall provide manufacturer's emissions performance versus load diagrams for the DLN and wet injection systems upon installation and completion of testing.
[Design; Rule 62-212.400(BACT), F.A.C.]
9. Wet Injection: A wet injection system shall be installed for use during distillate oil firing to reduce NO_x emissions from the combustion turbine exhaust entering the HRSG. [Design, Rule 62-212.400, F.A.C.]
10. Selective Catalytic Reduction (SCR) System: The permittee shall install, tune, operate and maintain an SCR system to control NO_x emissions from the combined cycle gas turbine. The SCR system consists of an ammonia injection grid, catalyst, anhydrous ammonia storage, monitoring and control system, electrical, piping and other support equipment. The SCR system shall be designed to control NO_x emissions to the permitted levels with an ammonia slip no greater than 5 ppmvd corrected to 15% oxygen. [Design, Rule 62-212.400, F.A.C.]

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

11. Drift Eliminators: Drift eliminators shall be installed on the cooling tower to reduce PM/PM₁₀ emissions.

EMISSION LIMITS AND STANDARDS

12. Nitrogen Oxides (NO_x) Emissions:

NO_x emissions are defined as oxides of nitrogen measured as NO₂.

a. **Performance Tests**:

When firing natural gas, NO_x emissions from the combined cycle gas turbine shall not exceed 3.5 ppmvd corrected to 15% oxygen nor 24.1 pounds per hour, based on a 24-hour average.

When firing distillate oil, NO_x emissions from the combined cycle gas turbine shall not exceed 10.0 ppmvd corrected to 15% oxygen nor 80.0 pounds per hour, based on a 24-hour average.

Compliance shall be determined in accordance with EPA Method 7E or Method 20 (40CFR60, Subpart GG).

b. **CEM System**:

When firing natural gas, NO_x emissions from the combined cycle gas turbine shall not exceed 3.5 ppmvd corrected to 15% oxygen, based on a 24-hour block average.

When firing distillate oil, NO_x emissions from the combined cycle gas turbine shall not exceed 10.0 ppmvd corrected to 15% oxygen, based on a 24-hour block average.

Compliance shall be determined by valid data from the required NO_x CEM system.

[Rule 62-212.400, F.A.C., BACT Determination]

13. Carbon Monoxide (CO) Emissions:

a. **Performance Tests**:

When firing natural gas (excluding operation in the Power Augmentation Mode), CO emissions from the combined cycle gas turbine shall not exceed 9.0 ppmvd corrected to 15% oxygen nor 26.0 pounds per hour, based on a 24-hour average.

When firing natural gas and operating in the Power Augmentation Mode, CO emissions from the combined cycle gas turbine shall not exceed 15.0 ppmvd corrected to 15% oxygen nor 49.0 pounds per hour, based on a 24-hour average.

When firing distillate oil, CO emissions from the combined cycle gas turbine shall not exceed 20.0 ppmvd corrected to 15% oxygen nor 70.0 pounds per hour, based on a 24-hour average.

Compliance shall be determined in accordance with EPA Method 10.

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

CEM System:

When firing natural gas, (excluding operation in the Power Augmentation Mode), CO emissions from the combined cycle gas turbine shall not exceed 9.0 ppmvd corrected to 15% oxygen, based on a 24-hour block average.

When firing natural gas and operating in the Power Augmentation Mode, CO emissions from the combined cycle gas turbine shall not exceed 15.0 ppmvd corrected to 15% oxygen, based on a 24-hour block average.

When firing distillate oil, CO emissions from the combined cycle gas turbine shall not exceed 20.0 ppmvd corrected to 15% oxygen, at 90-100 percent of full load. 22 ppmvd at 75-89 percent of full load nor 29 ppmvd @ 15% O₂ at 50-74 percent of full load based on a 24-hour block average.

Compliance shall be determined by valid data from the required CO CEM system.

[Rule 62-212.400, F.A.C, BACT Determination]

14. Volatile Organic Compounds (VOC) Emissions: The efficient combustion of clean fuels and good operating practices for the combined cycle gas turbine represent the Best Available Control Technology (BACT) requirements for VOC emissions.

{Permitting Note: VOC emissions are expected to be less than 3 pounds per hour (1.4 ppmvd corrected to 15% oxygen) when firing natural gas and less than 8 pounds per hour (3.6 ppmvd corrected to 15% oxygen) when firing distillate oil, as determined by EPA Method 25A measured and reported as methane.}

[Design; Rule 62-212.400(BACT), F.A.C.]

15. Sulfur Dioxide (SO₂) and Sulfuric Acid Mist Emissions (SAM): The fuel specifications listed Condition No. 4 of this section effectively limit the potential emissions of SO₂ and SAM. Compliance with the fuel sulfur limits shall be demonstrated by the fuel sampling, analysis, record keeping and reporting requirements of Condition No. 28 of this section. [Rule 62-212.400, F.A.C.; 40 CFR 60.333]

16. PM/PM₁₀ and Visible Emissions (VE): When firing either natural gas or distillate oil, visible emissions shall not exceed 10% opacity, based on a 6-minute average as determined by EPA Method 9. The fuel specifications in Conditions No. 4 and 28 of this section combined with the efficient combustion design and good operating practices for the combined cycle gas turbine represent the Best Available Control Technology (BACT) requirements for particulate matter.

{Permitting Note: Particulate matter emissions are expected to be less than 11 pounds per hour when firing natural gas and less than 36 pounds per hour when firing distillate oil, as determined by EPA Method 5, front-half catch only.}

[Rule 62-212.400(BACT), F.A.C.]

17. Ammonia Emissions: The concentration of ammonia in the stack exhaust gas shall not exceed 5 ppmvd corrected to 15% oxygen as determined by EPA Method CTM-027. [Rules 62-4.070 and 62-212.400(BACT), F.A.C.]

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

COMPLIANCE DETERMINATION

18. Test Methods: Required tests shall be performed in accordance with the following reference methods.

EPA Method	Description of Method and Comments
CTM-027	Procedure for Collection and Analysis of Ammonia in Stationary Source <ul style="list-style-type: none"> This is an EPA conditional test method. The minimum detection limit shall be 1 ppm.
5	Determination of Particulate Matter Emissions from Stationary Sources <ul style="list-style-type: none"> For gas firing, the minimum sampling time shall be two hours per run and the minimum sampling volume shall be 60 dscf per run. For oil firing, the minimum sampling time shall be one hour per run and the minimum sampling volume shall be 30 dscf per run.
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources <ul style="list-style-type: none"> The method shall be based on a continuous sampling train. The ascarite trap may be omitted or the interference trap of section 10.1 may be used in lieu of the silica gel and ascarite traps.
18	Measurement of Gaseous Organic Compound Emissions by Gas Chromatography <ul style="list-style-type: none"> EPA Method 18 may be used concurrently with EPA Method 25A to deduct emissions of methane and ethane from the measured VOC emissions.
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines
25A	Determination of Volatile Organic Concentrations

Except for Method CTM-027, the methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. Method CT-027 is published on EPA's Technology Transfer Network Web Site at "<http://www.epa.gov/ttn/emc/ctm.html>". No other methods may be used for compliance testing unless prior written approval is received from the administrator of the Department's Emissions Monitoring Section in accordance with an alternate sampling procedure pursuant to 62-297.620, F.A.C. [Rules 62-204.800 and 62-297.100, F.A.C.; 40 CFR 60, Appendix A]

19. Testing Modes of Operation: The permittee shall conduct all required tests for each mode of operation defined below:

- Standard Operation**: Separate tests shall be conducted when firing the combustion turbine with natural gas as well as low sulfur distillate oil.
- Alternate Mode of Operation**: Separate tests shall be conducted when firing the combustion turbine with natural gas and implementing the power augmentation mode with steam injection. Hourly rates of steam injection for power augmentation (pounds of steam) shall be restricted to the rates that demonstrated compliance during the test for this alternate mode of operation. The maximum steam injection rate (lb steam/hour) for power augmentation shall be established in the operation permit. Note: Alternate mode of operation is not allowed when firing low sulfur fuel oil. [Rule 62-4.070(3), F.A.C.]

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

20. Initial Compliance Tests: The combined cycle gas turbine shall be tested when firing each authorized fuel to demonstrate compliance with the emission standards for CO, NOx, visible emissions and ammonia slip. The tests must be conducted within 60 days after achieving at least 90% of the maximum permitted capacity, but not later than 180 days after initial operation of the combined cycle gas turbine.
- Tests for CO and NOx shall be conducted concurrently. Certified CEM system data may be used to demonstrate compliance with all CO and NOx standards. [Rule 62-297.310(7)(a)1., F.A.C.; 40 CFR 60.335]
21. Initial and Quarterly Ammonia Stack Compliance Tests: An initial and quarterly stack emissions test shall be conducted when firing natural gas and fuel oil to demonstrate compliance with the limit on ammonia slip. The initial and annual (one of the quarters) NOx and ammonia tests shall be conducted at four points within the operating range of the gas turbine. The test results for ammonia slip shall also report the ammonia injection rates and average NOx emissions during each test run. [Rules 62-4.070 (3) and 62-212.400(BACT), F.A.C.]
22. Annual Compliance Tests: During each federal fiscal year (October 1st to September 30th), the combined cycle gas turbine shall be tested when firing natural gas to demonstrate compliance with the emission standards for CO, NOx, ammonia slip and visible emissions. If the combined cycle gas turbine fires more than 200 hours of distillate oil during the federal fiscal year, it shall also be tested for visible emissions and ammonia slip when firing oil.
23. Tests After Substantial Modifications: All performance tests required for initial start up shall also be required by the Department after any substantial modifications (and shake down period not to exceed 100 days after re-starting the gas turbine) of air pollution control equipment such as installation of an oxidation catalyst or change of combustors. [Rule 62-4.070 (3) F.A.C.]
24. Compliance with the CO/NOx Emissions Limits: Continuous compliance with the applicable CO and NOx emissions standards shall be demonstrated with valid data collected by the required CEM systems during the required annual RATA at permitted capacity. Refer to Specific Conditions 18 and 22.
- [Rule 62-212.400(BACT) and 62-297.310(7)(a)4., F.A.C.]
25. Compliance with the VOC Emissions Limits: Compliance with the CO standards shall serve as surrogate standards for VOC emissions. [Rule 62-212.400 F.A.C. (BACT)]
26. Compliance with the Ammonia Emissions Limits: The permittee shall calculate and report the ppmvd ammonia slip @15% O₂ at the measured lb/hr emission rate as a means of compliance with the BACT standard. The compliance procedures are described in Specific Conditions 18 and 21. [Rule 62-212.400 F.A.C. (BACT)]
27. Compliance with the VE and PM/PM₁₀ Emissions Limits: Compliance with the VE limits shall be demonstrated by stack tests. Compliance with the fuel specifications, CO standards, and visible emissions standards of this section shall serve as surrogate standards for particulate matter. [Rule 62-212.400 F.A.C. (BACT)]

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

28. Compliance with the SO₂/H₂SO₄- Fuel Sulfur Limits: The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.

- a. Compliance with the fuel sulfur limit for *natural gas* shall be demonstrated by keeping reports obtained from the vendor indicating the sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be ASTM methods D4084-82, D3246-81 or more recent versions.
- b. Compliance with the *fuel oil* sulfur limit shall be demonstrated by taking a sample, analyzing the sample for fuel sulfur, and reporting the results to each Compliance Authority before initial startup. Sampling the fuel oil sulfur content shall be conducted in accordance with ASTM D4057-88, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, and one of the following test methods for sulfur in petroleum products: ASTM D129-91, ASTM D1552-90, ASTM D2622-94, or ASTM D4294-90. More recent versions of these methods may be used. For each subsequent fuel delivery, the permittee shall maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor. At the request of a Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content.

The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-4.160(15), F.A.C.]

EXCESS EMISSIONS

29. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction are prohibited. These emissions shall be included in the 24-hour compliance averages for NO_x and for CO emissions.
[Rule 62-210.700(4), F.A.C.]

30. Excess Emissions Defined: During startup, shutdown, and documented unavoidable malfunction of the combined cycle gas turbine, the following permit conditions allow excess emissions or the exclusion of monitoring data for specifically defined periods of operation. These conditions apply only if operators employ the best operational practices to minimize the amount and duration of excess emissions during such incidents.

- a. During startup and shutdown, visible emissions shall not exceed 10% opacity except for up to ten, 6-minute averaging periods during any calendar day, which shall not exceed 20% opacity. Data for each 6-minute averaging period shall be exclusive from other 6-minute averaging periods.
- b. Excluding startup and shutdown, operation below 50% base load is prohibited.
- c. In accordance with Condition No. 31 of this section, specific data collected by the CEM systems during startup, shutdown, malfunction, and tuning may be excluded from the CO and NO_x compliance averaging periods.

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

If a CEM system reports emissions in excess of a 24-hour block emissions standard, the permittee shall notify the Compliance Authority within (1) working day with a preliminary report of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.

[G.E. Combined Cycle Startup Curves Data and Rule 62-210.700, F.A.C.]

MONITORING REQUIREMENTS

31. Continuous Emission Monitoring System: The owner or operator shall install, calibrate, maintain, and operate a continuous emission monitoring (CEM) system in the exhaust stack of each emissions unit to measure and record the emissions of NO_x and CO from these emissions units in a manner sufficient to demonstrate compliance with the CEM emission standards of this permit. The oxygen content or the carbon dioxide (CO₂) content of the flue-gas shall also be monitored at the location where NO_x and CO are monitored to correct the measured CO and NO_x emissions rates to 15% oxygen. If a CO₂ monitor is installed, the oxygen content of the flue gas shall be calculated by the CEM system using F-factors that are appropriate for the fuel fired. The CEM system shall be used to demonstrate compliance with the CEM emission standards for NO_x and CO specified in this permit.
- a. *Data Collection*. Compliance with the CEM emission standards for NO_x and CO shall be based on a 24-hour block average starting at midnight of each operating day. The 24-hour block average shall be calculated from 24 consecutive hourly average emission rate values. If a unit operates less than 24 hours during the block, the 24-hour block average shall be the average of available valid hourly average emission rate values for the 24-hour block. Each hourly value shall be computed using at least one data point in each fifteen minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. Notwithstanding this requirement, an hourly value shall be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour). The owner or operator shall use all valid measurements or data points collected during an hour to calculate the hourly averages. All data points collected during an hour shall be, to the extent practicable, evenly spaced over the hour. If the CEM system measures concentration on a wet basis, the CEM system shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the owner or operator may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load for each allowable fuel, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Final results of the CEM system shall be expressed as ppmvd, corrected to 15% oxygen.
- b. *NO_x Certification*. The NO_x monitor shall be certified and operated in accordance with the following requirements. The NO_x monitor shall be certified pursuant to 40 CFR Part 75 and shall be operated and maintained in accordance with the applicable requirements of 40 CFR Part 75, Subparts B and C. For purposes of determining compliance with the

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

CEM emission standards of this permit, missing data shall not be substituted. Instead the block average shall be determined using the remaining hourly data in the 24-hour block. Record keeping and reporting shall be conducted pursuant to 40 CFR Part 75, Subparts F and G. The RATA tests required for the NO_x monitor shall be performed using EPA Method 20 or 7E, of Appendix A of 40 CFR 60. The NO_x monitor shall be a dual range monitor. The span for the lower range shall not be greater than 10 ppm, and the span for the upper range shall not be greater than 30 ppm, as corrected to 15% O₂.

- c. *CO, CO₂, and Oxygen Certification.* The CO monitor and CO₂ monitor shall be certified and operated in accordance with the following requirements. The CO monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4. The CO₂ monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 3. The oxygen monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 3. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of section 7 shall be made each calendar quarter, and reported semi-annually to each Compliance Authority. The RATA tests required for the CO monitor shall be performed using EPA Method 10, of Appendix A of 40 CFR 60. The Method 10 analysis shall be based on a continuous sampling train, and the ascarite trap may be omitted or the interference trap of section 10.1 may be used in lieu of the silica gel and ascarite traps. The CO monitor shall be a dual range monitor. The span for the lower range shall not be greater than 20 ppm, and the span for the upper range shall not be greater than 60 ppm, as corrected to 15% oxygen. The RATA tests required for the CO₂ monitor shall be performed using EPA Method 3B, of Appendix A of 40 CFR 60. The RATA tests required for the oxygen monitor shall be performed using EPA Method 3B, of Appendix A of 40 CFR 60.
- d. *Data Exclusion.* Emissions data for NO_x, CO and CO₂ (or oxygen content) shall be recorded by the CEM system during episodes of startup, shutdown and malfunction. NO_x and CO emissions data recorded during these episodes may be excluded from the block average calculated to demonstrate compliance with the CEM emission standards as provided in this paragraph.
 - (1) Periods of data excluded for a cold startup shall not exceed four hours in any block 24-hour period. A "cold startup" is defined as a startup to combined cycle operation following a complete shutdown lasting at least 48 hours.
 - (2) Periods of data excluded for a warm startup shall not exceed two hours in any block 24-hour period. A "warm startup" is defined as a startup to combined cycle operation following a complete shutdown lasting 8 hours or more, but less than 48 hours.
 - (3) Periods of data excluded for a hot startup shall not exceed one hour in any block 24-hour period. A "hot startup" is defined as a startup to combined cycle operation following a complete shutdown lasting less than 8 hours.

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

- (4) Periods of data excluded for a shutdown shall not exceed three hours in any block 24-hour period. A "*shutdown*" is the process of bringing a gas turbine off line and ending fuel combustion.
- (5) Periods of data excluded for a documented unavoidable malfunction shall not exceed two hours in any 24-hour block period. A "*documented unavoidable malfunction*" is a malfunction beyond the control of the operator that is documented within 24 hours of occurrence by contacting each Compliance Authority by telephone or facsimile transmittal.
- (6) If the permittee provides at least five days advance notice prior to a *tuning session*, data may be excluded from the block average calculated to demonstrate compliance with the CEM emission standards. Periods of data excluded for such episodes shall not exceed a total of three hours in any 24-hour block period. Tuning sessions must be performed in accordance with the manufacturer's recommendations. No more than two tuning sessions are expected during any year.

All periods of data excluded for any startup, shutdown or malfunction episode shall be consecutive for each episode. The permittee shall minimize the duration of data excluded for startup, shutdown and malfunctions, to the extent practicable. Data recorded during startup, shutdown or malfunction events shall not be excluded if the startup, shutdown or malfunction episode was caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented.

Best operational practices shall be used to minimize hourly emissions that occur during episodes of startup, shutdown and malfunction. Emissions of any quantity or duration that occur entirely or in part from poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented, shall be prohibited.

- e. *Data Exclusion Reports.* A summary report of duration of data excluded from the block average calculation, and all instances of missing data from monitor downtime, shall be reported semi-annually to each Compliance Authority. This report shall be consolidated with the report required pursuant to 40 CFR 60.7. For purposes of reporting "excess emissions" pursuant to the requirements of 40 CFR 60.7, excess emissions shall be defined as the hourly emissions which are recorded by the CEM system during periods of data excluded for episodes of startup, shutdown and malfunction, as allowed above. The duration of excess emissions shall be the duration of the periods of data excluded for such episodes. Reports required by this paragraph and by 40 CFR 60.7 shall be submitted no less than semi-annually, including semi-annual periods in which no data is excluded or no instances of missing data occur.
- f. *Data Conversion.* Upon request from the Department, the CEM systems emission rates shall be corrected to ISO conditions to demonstrate compliance with the applicable standards of 40 CFR 60.332.

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

- g. *Availability.* NOx and CO monitor availability shall not be less than 95% in any calendar quarter.

{Permitting Note: Compliance with these requirements will ensure compliance with the other applicable CEM system requirements such as: NSPS Subpart GG; Rule 62-297.520, F.A.C.; 40 CFR 60.7(a)(5) and 40 CFR 60.13; 40 CFR Part 51, Appendix P; 40 CFR 60, Appendix B - Performance Specifications; and 40 CFR 60, Appendix F - Quality Assurance Procedures.}

[Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]

32. Ammonia Monitoring Requirements: In accordance with the manufacturer's specifications, the permittee shall install, calibrate, maintain and operate, an ammonia flow meter to measure and record the ammonia injection rate to the SCR system. The permittee shall document the general range of ammonia flow rates required to meet emissions limitations over the range of combustion turbine load conditions allowed by this permit by comparing NOx emissions recorded by the NOx monitor with ammonia flow rates recorded using the ammonia flow meter. During NOx monitor downtimes or malfunctions, the permittee shall operate at the ammonia flow rate that is consistent with the documented flow rate for the combustion turbine load. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]
33. SCR Operational Requirements: The SCR shall operate at all times that the turbine is operating, except during turbine start-up and shutdown periods, as dictated by the manufacturer's guidelines and in accordance with this permit. During turbine start-up, permittee shall begin use of SCR (i.e., commence ammonia injection) as soon as possible and within two (2) hours of the initial turbine firing or when the temperature of the catalyst bed reaches a suitable predetermined temperature level, whichever occurs first. During turbine shutdown, permittee shall discontinue use of the SCR (i.e., discontinue ammonia injection) when the catalyst bed temperature drops below the predetermined temperature levels, but no more than one hour prior to the time at which the fuel feed to the turbine is discontinued.
- Suitable temperature for activation and deactivation of the SCR shall be established during performance testing. The permittee shall, whenever possible, operate the facility in a manner so as to optimize the effectiveness of the SCR unit while minimizing ammonia slip to below the emission limit. Design, Rule 62-212.400, F.A.C.]
34. Fuel Consumption Monitoring of Operations: To demonstrate compliance with the fuel consumption limits, the permittee shall monitor and record the rates of consumption of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D. To demonstrate compliance with the turbine capacity requirements, the permittee shall monitor and record the operating rate of the combined cycle gas turbine on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown and malfunction).

AIR CONSTRUCTION PERMIT 1110101-001-AC (PSD-FL-312)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

Such monitoring shall be made using a monitoring component of the CEM system required above, or by monitoring daily rates of consumption and heat content of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]

35. Fuel Consumption Rates Monthly Monitoring: By the fifth calendar day of each month, the permittee shall record the monthly fuel consumption and hours of operation for the gas turbine. The information shall be recorded in a written (or electronic log) and shall summarize the previous month of operation and the previous 12 months of operation. Information recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. [Rule 62-4.070(3), F.A.C.]

NOTIFICATION, REPORTING, AND RECORDKEEPING

36. Records: All measurements, records, and other data required to be maintained by CPV shall be recorded in a permanent form and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. These records shall be made available to DEP representatives upon request. [Rules 62-4.160 and 62-213.440, F.A.C.]
37. NSPS Notifications: All notifications and reports required by the 40CFR 60, Subpart A applicable requirements shall be submitted to Compliance Authority.
38. Semi-Annual Reports: Semi-annual excess emission reports, in accordance with 40 CFR 60.7 (a)(7)(c) (2000 version), shall be submitted to each Compliance Authority.

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

CPV Atlantic Power Generating Facility
PSD-FL-312 and 1110101-001-AC
St. Lucie County, Florida

BACKGROUND

The applicant, CPV Atlantic, Ltd, proposes to install a construct a combined cycle power plant at a new facility near Piney Point, St. Lucie County. The proposed project will result in "significant increases" with respect to Table 62-212.400-2, Florida Administrative Code (F.A.C.) of emissions of particulate matter (PM and PM₁₀), carbon monoxide (CO), sulfur dioxide (SO₂), sulfuric acid mist (SAM), and nitrogen oxides (NO_x). The project is therefore subject to review for the Prevention of Significant Deterioration (PSD) and a determination of Best Available Control Technology (BACT) in accordance with Rules 62-212.400, F.A.C.

The primary unit to be installed is a nominal 170 MW, General Electric 7FA combustion turbine-electrical generator, fired primarily with pipeline natural gas. The project includes an unfired heat recovery steam generator (HRSG) connected to a separate steam turbine-electrical generator. The project also includes a 1 million gallon storage tank for backup No. 2 fuel oil, cooling tower, a 200-foot stack, and a mechanical draft cooling tower and other ancillary equipment. Descriptions of the process, project, air quality effects, and rule applicability are given in the Technical Evaluation and Preliminary Determination dated February 19, 2001, accompanying the Department's Intent to Issue.

BACT APPLICATION:

The application was received on December 29, 2001 and included a proposed BACT proposal prepared by the applicant's consultant, TRC.

REVIEW GROUP MEMBERS:

Teresa Heron, Permit Engineer and A. A. Linero, P.E.

BACT REQUESTED BY THE APPLICANT:

POLLUTANT	CONTROL TECHNOLOGY	PROPOSED BACT LIMIT
Nitrogen Oxides	Selective Catalytic Reduction	3.5 ppmvd @15% O ₂ (gas) 10 ppmvd@15% O ₂ (oil)
Carbon Monoxide	Combustion Controls	9 ppmvd (gas) 20 ppmvd (oil)
Particulate Matter	Inherently Clean Fuels Combustion Controls	20 lb/hr (gas) 53 lb/hr (oil)
Sulfur Dioxide/Sulfuric Acid Mist	Low Sulfur Fuels	0.0065% sulfur (gas) 0.05% sulfur (oil)

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

BACT DETERMINATION PROCEDURE:

In accordance with Chapter 62-212, F.A.C., this BACT determination is based on the maximum degree of reduction of each pollutant emitted which the Department of Environmental Protection (Department), on a case by case basis, taking into account energy, environmental and economic impacts, and other costs, determines is achievable through application of production processes and available methods, systems, and techniques. In addition, the regulations state that, in making the BACT determination, the Department shall give consideration to:

- Any Environmental Protection Agency determination of BACT pursuant to Section 169, and any emission limitation contained in 40 CFR Part 60 - Standards of Performance for New Stationary Sources or 40 CFR Part 61 - National Emission Standards for Hazardous Air Pollutants.
- All scientific, engineering, and technical material and other information available to the Department.
- The emission limiting standards or BACT determination of any other state.
- The social and economic impact of the application of such technology.

The EPA currently stresses that BACT should be determined using the "top-down" approach. The first step in this approach is to determine, for the emission unit in question, the most stringent control available for a similar or identical emission unit or emission unit category. If it is shown that this level of control is technically or economically unfeasible for the emission unit in question, then the next most stringent level of control is determined and similarly evaluated. This process continues until the BACT level under consideration cannot be eliminated by any substantial or unique technical, environmental, or economic objections.

STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES:

The minimum basis for a BACT determination is 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines (NSPS). The Department adopted subpart GG by reference in Rule 62-204.800, F.A.C. The key emission limits required by Subpart GG are 75 ppmvd NO_x @ 15% O₂ (assuming 25 percent efficiency) and 150 ppmvd SO₂ @ 15% O₂ (or <0.8% sulfur in fuel). The BACT proposed by the CPV is consistent with the NSPS, which allows NO_x emissions in the range of 110 ppmvd for the high efficiency unit to be purchased by CPV. No National Emission Standard for Hazardous Air Pollutants exists for stationary gas turbines.

There is a National Emission Standard for Hazardous Air Pollutants (NESHAP) under development by EPA, but it is not applicable to this project. Because emissions of HAP are less than 10 tons per year, there is no requirement to conduct a case-by-case maximum achievable control technology determination.

DETERMINATIONS BY STATES:

The following table is a sample of information on some recent applications, proposals, and determinations in the Southeast for combined cycle projects. The CPV Atlantic Project is included for reference.

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

TABLE 1

RECENT NO_x EMISSION LIMIT PROPOSALS AND DETERMINATIONS FOR "F-CLASS"
 COMBINED CYCLE PROJECTS IN THE SOUTHEAST

Project Location	Capacity Megawatts	NO _x Limit ppmvd @ 15% O ₂ and Fuel	Technology	Comments
CPV Atlantic, FL	245	3.5 - NG 10 - FO	SCR	170 MW GE 7FA CT Under Review
CPV Gulfcoast, FL	245	3.5 - NG 10 - FO	SCR	170 MW GE 7FA CT Issued 2/2001
TECO Bayside, FL	1750	3.5 - NG 12 - FO	SCR	7x170 MW GE 7FA CTs Repowering Draft Issued 2/2001
FPC Hines II, FL		3.5 - NG 12 - FO	SCR	2x170 MW WH501F
Calpine Osprey, FL	527	3.5 - NG	SCR	2x170 MW WH501F Draft 5/00
Calpine Blue Heron, FL	1080	3.5 - NG	SCR	4x170 MW WH501F Draft 2/00
Santee Cooper, SC	~500	9 - NG	DLN	2x170 MW GE 7FA CTs ~ 4/00
Mobile Energy, AL	~250	~3.5 - NG ~11 - FO	SCR	178 MW GE 7FA CT 1/99
Alabama Power Barry	800	3.5 - NG	SCR	3x170 MW GE 7FA CTs 11/98
Alabama Power Theo	210	3.5 - NG	SCR	4x170 MW GE 7FA CTs 11/98
KUA Cane Island 3, FL	250	3.5 - NG (12 - simple cycle) 15 - FO	SCR	170 MW GE 7FA. 11/99 DLN on simple cycle
Lake Worth LLC, FL	250	9 or 3.5 - NG 9.4 or 3.5 - NG (CT&DB) 42 or 16.4 - FO	DLN or SCR DLN or SCR WI or SCR	170 MW GE 7FA. 11/99 Increase allowed for DB under DLN.
Miss Power Daniel	1000	3.5 - NG	SCR	4x170 MW GE 7FA CTs 11/98

DB = Duct Burner

NG = Natural Gas

FO = Fuel Oil

DLN = Dry Low NO_x Combustion

SCR = Selective Catalytic Reduction

WI = Water or Steam Injection

GE = General Electric

WH = Westinghouse

CT = Combustion Turbine

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

TABLE 2

RECENT CO, VOC, AND PM NO_x EMISSION LIMIT PROPOSALS AND
DETERMINATIONS FOR "F-CLASS" COMBINED CYCLE PROJECTS

Project Location	CO - ppmvd (or lb/mmBtu)	VOC - ppmv (or lb/mmBtu)	PM - lb/mmBtu (or gr/dscf or lb/hr)	Technology and Comments
CPV Atlantic, FL	9 - NG (50 - 100% load) 15 - NG (PA) 20 - FO	1.4 - NG 3.5 FO	11 lb/hr - NG (front) 36 lb/hr - FO (front) 5 ppmvd Ammonia Slip	Clean Fuels Good Combustion
CPV Gulfcoast, FL	9 - NG (50 - 100% load) 15 - NG (PA) 20 - FO	1.4 - NG 3.5 FO	11 lb/hr - NG (front) 36 lb/hr - FO (front) 5 ppmvd Ammonia Slip	Clean Fuels Good Combustion
TECO Bayside, FL	9 - NG () 20 - FO (24-hr CEMS)	1.3 - NG 3 - FO	12 lb/hr - NG 30 lb/hr - FO	Clean Fuels Good Combustion
FPC Hines II, FL	16 - NG (24-hr CEMS) 30 - FO (24-hr CEMS)	2 - NG 10 - FO	10% Opacity - NG 5/9 ammonia - NG/FO	Clean Fuels Good Combustion
Calpine Osprey, FL	10 - NG 17 - NG (DB&PA)	2.3 - NG 4.6 - NG (DB&PA)	24 lb/hr - NG (DB&PA) 10 percent Opacity 9 ppmvd Ammonia Slip	Clean Fuels Good Combustion
Calpine Blue Heron, FL	10 - NG (24-hr CEMS) 17 - NG (DB&PA)	1.2 - NG 6.6 - NG (DB&PA)	31.9 lb/hr - NG (DB&PA) 10 percent Opacity 5 ppmvd Ammonia Slip	Clean Fuels Good Combustion
Mobile Energy, AL	~18 - NG ~26 - FO	~5 - NG ~6 - FO	10% Opacity	Clean Fuels Good Combustion
Alabama Power Barry	~15 - NG(CT) ~25 - NG(DB & CT)	~8 - NG(CT) ~12 - NG(CT & DB)	0.010 lb/mmBtu - (CT) 0.011 lb/mmBtu -(CT/DB) 10% Opacity	Clean Fuels Good Combustion
Alabama Power Theo	~36 - CT & DB	~12.5 CT & DB		Clean Fuels Good Combustion
KUA Cane Island	10 - NG (CT) 20 - NG (CT&DB) 30 - FO	1.4 - NG (CT) 4 - NG (CT&DB) 10 - FO	10% Opacity	Clean Fuels Good Combustion
Lake Worth LLC, FL	9 - NG (CT) 15 - NG (CT & DB) 20 - F.O. (3-hr)	1.4 - NG (CT) 1.8 - NG (CT & DB) 3.5 - F.O.	10% Opacity	Clean Fuels Good Combustion
Miss Power Daniel	~15 - NG(CT) ~25 - NG(DB & CT)	~8 - NG(CT) ~12 - NG(CT & DB)	0.010 lb/mmBtu - (CT) 0.011 lb/mmBtu -(CT/DB) 10% Opacity	Clean Fuels Good Combustion

All of the projects listed above control SO₂ and sulfuric acid mist by limiting the sulfur content of the fuel. In every case, pipeline quality natural gas is used and has a sulfur content less than 2 grains per 100 cubic. In some cases, the limits are even lower or are expressed in different terms. However all ultimately rely on a fairly uniform gas distribution network and have very little flexibility in actually controlling sulfur content. Similarly, emissions of these two pollutants are controlled by using 0.05 percent sulfur distillate fuel oil.

Some of the projects listed above include front and back half catch for PM limits. Therefore comparison is not simple.

APPENDIX BD

BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

OTHER INFORMATION AVAILABLE TO THE DEPARTMENT:

Besides the initial information submitted by the applicant, the summary above, and the references at the end of this document, key information reviewed by the Department includes:

- Comments from the National Park Service dated January 23, 2001
- Comments from EPA Region IV (on CPV Gulfcoast) dated December 27, 2000
- Alternative Control Techniques Document - NO_x Emissions from Stationary Gas Turbines
- General Electric 39th Turbine State-of-the-Art Technology Seminar Proceedings
- GE Power Generation - Speedtronic™ Mark V Gas Turbine Control System
- GE Combined Cycle Startup Curves

REVIEW OF NITROGEN OXIDES CONTROL TECHNOLOGIES:

Some of the discussion in this section is based on a 1993 EPA document on Alternative Control Techniques for NO_x Emissions from Stationary Gas Turbines. Project-specific information is included where applicable.

Nitrogen Oxides Formation

Nitrogen oxides form in the gas turbine combustion process as a result of the dissociation of molecular nitrogen and oxygen to their atomic forms and subsequent recombination into seven different oxides of nitrogen. *Thermal NO_x* forms in the high temperature area of the gas turbine combustor. Thermal NO_x increases exponentially with increases in flame temperature and linearly with increases in residence time. Flame temperature is dependent upon the ratio of fuel burned in a flame to the amount of fuel that consumes all of the available oxygen.

By maintaining a low fuel ratio (lean combustion), the flame temperature will be lower, thus reducing the potential for NO_x formation. *Prompt NO_x* is formed in the proximity of the flame front as intermediate combustion products. The contribution of Prompt to overall NO_x is relatively small in near-stoichiometric combustors and increases for leaner fuel mixtures. This provides a practical limit for NO_x control by lean combustion.

In all but the most recent gas turbine combustor designs, the high temperature combustion gases are cooled to an acceptable temperature with dilution air prior to entering the turbine (expansion) section. The sooner this cooling occurs, the lower the thermal NO_x formation. Cooling is also required to protect the first stage nozzle. When this is accomplished by air-cooling, the air is injected into the component and is ejected into the combustion gas stream, causing a further drop in combustion gas temperature. This, in turn, lowers achievable thermal efficiency for the unit.

The relationship between flame temperature, firing temperature, unit efficiency, and NO_x formation can be appreciated from Figure 1 which is from a General Electric discussion on these principles.

Fuel NO_x is formed when fuels containing bound nitrogen are burned. This phenomenon is not important when combusting natural gas. Also, low sulfur fuel oil (which has more fuel-bound nitrogen than natural gas) is limited to no more than 30 days or 720 hours per year.

Gas Turbine - Hot Gas Path Parts




Figure 1 – Relation Between Flame Temperature and Firing Temperature







Figure 2 - DLN2.6 Fuel Nozzle Arrangement

APPENDIX BD

BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

Uncontrolled emissions range from about 100 to over 600 parts per million by volume, dry, corrected to 15 percent oxygen (ppmvd @15% O₂). The Department estimates uncontrolled emissions at approximately 200 ppmvd @15% O₂ for the turbine of the CPV Atlantic Project. The proposed NO_x controls will significantly reduce these emissions.

NO_x Control Techniques

Wet Injection

Injection of either water or steam directly into the combustor lowers the flame temperature and thereby reduces thermal NO_x formation. Typical emissions achieved by wet injection are in the range of 15–25 ppmvd when firing gas and 42 ppmvd when firing fuel oil in large combustion turbines. These values often form the basis, particularly in combined cycle turbines, for further reduction to BACT limits by other techniques. Carbon monoxide (CO) and hydrocarbon (HC) emissions are relatively low for most gas turbines. However steam and (more so) water injection may increase emissions of both of these pollutants.

Combustion Controls: Dry Low NO_x (DLN)

The excess air in lean combustion cools the flame and reduces the rate of thermal NO_x formation. Lean premixing of fuel and air prior to combustion can further reduce NO_x emissions. This is accomplished by minimizing localized fuel-rich pockets (and high temperatures) that can occur when trying to achieve lean mixing within the combustion zones.

The above principle is incorporated into the General Electric DLN-2.6 can-annular combustor shown in Figure 2. Each combustor includes six nozzles within which fuel and air have been fully pre-mixed. There are 16 small fuel passages around the circumference of each combustor can known as quaternary fuel peps. The six nozzles are sequentially ignited as load increases in a manner that maintains lean pre-mixed combustion and flame stability.

Design emission characteristics of the DLN-2.6 combustor while firing natural gas are given in Figure 3 for a unit tuned to meet a 15 ppmvd NO_x limit (by volume, dry corrected to at 15 percent oxygen) at JEA's Kennedy Station. The combustor can be tuned differently to achieve emissions as low as 9 ppmvd of NO_x.

The combustor emits NO_x at concentrations of 15 ppmvd at loads between 50 and 100 percent of capacity, but concentrations as high as 100 ppmvd may occur at less than 50 percent of capacity. Note that VOC comprises a very small amount of the "unburned hydrocarbons" which in turn is mostly non-VOC methane.

Following are the results of the new and clean tests conducted on a dual-fuel GE PG7241FA combustion turbine operating in combined cycle mode and burning natural gas at the City of Tallahassee Purdom Station Unit 8.¹ The DLN 2-6 combustors for this project were guaranteed to achieve 9 ppmvd of NO_x while burning natural gas although the permit limit is 12 ppmvd. The results are all superior to the emission characteristics given in Figure 3.




Figure 3 – Emissions Performance Curves for GE DLN-2.6 Combustor
Firing Natural Gas in a Dual Fuel GE 7FA Combustion Turbine
(Simple Cycle Intermittent Duty – If Tuned to 15 ppmvd NO_x)

APPENDIX BD

BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

Percent of Full Load	NO _x (ppmvd @15% O ₂)	CO (ppmvd)
70	7.2	
80	6.1	
90	6.6	
100	8.7	0.85
Limit	12	25

Following are the results of the new and clean tests conducted on a dual-fuel GE PG7241FA combustion turbine operating in simple cycle mode and burning natural gas at the Tampa Electric Polk Power Station.² The DLN 2-6 combustors for this project were guaranteed to achieve 9 ppmvd of NO_x while burning natural gas although the permit limit is 10.5 ppmvd. Again, the results are all superior to the emission characteristics given in Figure 3.

Percent of Full Load	NO _x (ppmvd @15% O ₂)	CO (ppmvd)	VOC (ppmvd)
50	5.3	1.6	0.5
70	6.3	0.5	0.4
85	6.2	0.4	0.2
100	7.6	0.3	0.1
Limit	10.5	15	7

Recent conversations with other operators indicate that the Low NO_x characteristics extend to operations less than 50 percent of full load, though such operation is not (yet) guaranteed by GE.³

Emissions characteristics by wet injection NO_x control while firing oil are shown in Figure 4 for the DLN-2.0, a predecessor of the DLN2-6. Operation on fuel oil is not in the premixed mode. Specialized premixed DLN burners for fuel oil operation were installed in a project in Israel⁴ where water is scarce, but the Department has no information on the results.

Mitsubishi (who also make a 501F) is also developing a dual-fuel premixed DLN. Optimization of premix fuel-air nozzle and performance was verified in high-pressure combustion tests. Commissioning tests on gas and oil burning were completed at an undesignated site.⁵ The details are not available in English.

An important consideration is that power and efficiency are sacrificed in the effort to achieve low NO_x by combustion technology. This limitation is seen in Figure 5 from an EPRI report.⁶ Basically developments such as single crystal blading, aircraft compressor design, high technology blade cooling have helped to greatly increase efficiency and lower capital costs. Further improvements are more difficult in large part because of the competing demands for air to support lean premix combustion and to provide blade cooling. New concepts are under development by GE and the other turbine manufacturers to meet the challenges implicit in Figure 5.




Figure 4 – Emissions Performance for DLN-2 Combustors
Firing Fuel Oil in Dual Fuel GE 7FA Turbine

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)




Figure 5 – Efficiency Increases in Combustion Turbines

Further NO_x reductions related to flame temperature control are possible such as closed loop steam cooling. This feature is available only in larger units (Westinghouse G or General Electric H Class technology) than the units planned by CPV. The fluid is circulated through the internal portion of the nozzle component or around the transition piece between the combustor and the nozzle and does not enter the exhaust stream. Instead it is normally sent back to a steam generator. The difference between flame temperature and firing temperature into the first stage is minimized and higher efficiency is attained.

Another important result of steam cooling is that a higher firing temperature can be attained with no increase in flame temperature. Flame temperatures and NO_x emissions can therefore be maintained at comparatively low levels even at high firing temperatures (refer back to figure 1). At the same time, thermal efficiency should be greater when employing steam cooling. A similar analysis applies to steam cooling around the transition piece between the combustor and first stage nozzle.

Catalytic Combustion: XONON™

Catalytic combustion involves using a catalytic bed to oxidize a lean air and fuel mixture within a combustor instead of burning with a flame as described in the DLN technology above. In a catalytic combustor the air and fuel mixture oxidizes at lower temperatures, producing less NO_x.⁷ In the past, the technology was not reliable because the catalyst would not last long enough to make the combustor economical.

There has been increased interest in catalytic combustion as a result of technological improvements and incentives to reduce NO_x emissions without the use of add-on control equipment and reagents. Westinghouse is working to replace the central pilot in its DLN technology with a catalytic pilot in a project with Precision Combustion Inc.

Catalytica has developed a system know as XONON™, which works by partially burning fuel in a low temperature pre-combustor and completing the combustion in a catalytic combustor. The overall result is low temperature partial combustion (and thus lower NO_x combustion) followed by flameless catalytic combustion to further attenuate NO_x formation.

APPENDIX BD

BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

In 1998, Catalytica announced the startup of a 1.5 MW Kawasaki gas turbine equipped with XONON™.⁸ The turbine is owned by Catalytica and is located at the Gianera Generating Station of Silicon Valley Power, a municipally owned utility serving the City of Santa Clara, California. Previously, this turbine and XONON™ system had successfully completed over 1,200 hours of extensive full-scale tests at a project development facility in Oklahoma, which documented XONON's ability to limit emissions of NO_x to less than 3 ppmvd.

Recently, Catalytica and GE announced that the XONON™ combustion system has been specified as the *preferred* emissions control system with GE 7FA turbines that have been ordered for Enron's proposed 750 MW Pastoria Energy Facility.⁹ The project will enter commercial operation by the summer of 2001. However actual installation of XONON on the Pastoria project is doubtful.

In principle, XONON™ will work on a combined cycle project. However, the Department does not have information regarding the status of the technology for fuel oil firing, cycling operations, or reasonable assurance that the technology is technically and economically feasible for a GE 7FA unit in an attainment area.

Selective Catalytic Reduction (SCR)

Selective catalytic reduction (SCR) is an add-on NO_x control technology that is employed in the exhaust stream following the gas turbine. SCR reduces NO_x emissions by injecting ammonia into the flue gas in the presence of a catalyst. Ammonia reacts with NO_x in the presence of a catalyst and excess oxygen yielding molecular nitrogen and water. The catalysts used in combined cycle, low temperature applications (conventional SCR), are usually vanadium or titanium oxide and account for almost all installations. For high temperature applications (Hot SCR up to 1100 °F), such as simple cycle turbines, zeolite catalysts are available but used in few applications to-date. SCR units are typically used in combination with wet injection or DLN combustion controls.

In the past, sulfur was found to poison the catalyst material. Sulfur-resistant catalyst materials are now becoming more available. Catalyst formulation improvements have proven effective in resisting sulfur-induced performance degradation with fuel oil in Europe and Japan, where conventional SCR catalyst life in excess of 4 to 6 years has been achieved, while 8 to 10 years catalyst life has been reported with natural gas.

As of early 1992, over 100 gas turbine installations already used SCR in the United States. Only one combustion turbine project in Florida (FPC Hines Power Block 1) employs SCR. The equipment was installed on a temporary basis because Westinghouse had not yet demonstrated emissions as low as 12 ppmvd by DLN technology at the time the units were to start up in 1998. Seminole Electric will install SCR on a previously permitted 501F unit at the Hardee Unit 3 project. The reasons are similar to those for the FPC Hines Power Block 1.

Kissimmee Utilities Authority (KUA) will install SCR at the Cane Island Unit 3 project as a result of insistence by EPA that DLN technology to achieve 9 ppmvd of NO_x was not BACT. The KUA project will meet a limit of 3.5 ppmvd with a combination of DLN and SCR. Since then, the Department has consistently advised prospective applicants that BACT is 3.5 ppmvd. Accordingly, FPC submitted an application for the Hines Power Block II project with a BACT NO_x proposal of 3.5 ppmvd by SCR. A permit was issued recently to CPV for its Gulfcoast Power Generating Facility in Manatee County that required SCR to achieve 3.5 ppmvd. CPV proposes the same for the present project by SCR. TECO proposes the same limit by SCR for its Bayside Repowering Project.

APPENDIX BD

BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

Figure 6 below is a diagram of a HRSG including an SCR reactor with honeycomb catalyst and the ammonia injection grid. The SCR system lies between low and high-pressure steam systems where the temperature requirements for conventional SCR can be met. Figure 8 is a photograph of FPC Hines Energy Complex. The external lines to the ammonia injection grid are easily visible. The magnitude of the installation can be appreciated from the relative size compared with nearby individuals and vehicles.




Figure 6 – SCR System within HRSG



Figure 7 – FPC Hines Power Block 1

Excessive ammonia use tends to increase emissions of at least ammonia (slip) and particulate matter (when sulfur-bearing fuels are used). Permit limits as low as 2 to 3.5 ppmvd NO_x have been specified using SCR on combined cycle F Class projects throughout the country. Such values are roughly equal to the inherent uncertainty in the sampling and analysis methods.

Selective Non-Catalytic Reduction (SNCR)

Selective non-catalytic reduction works on the same principle as SCR. The differences are that it is applicable to hotter streams than conventional or hot SCR, no catalyst is required, and urea can be used as a source of ammonia. No applications have been identified wherein SNCR was applied to a gas turbine because the exhaust temperature of 1100 °F is too low to support the NO_x removal mechanism.

The acceptable temperature for the removal reactions is between 1400 and 2000 °F. Temperatures on the order of 1800 °F can be achieved in supplementally-fired HRSGs with very large duct burners. An example is the Santa Rosa Energy Center, which incorporates a 585-mmBtu/hr duct burner. SNCR is not feasible for un-fired HRSG planned for the CPV project.

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

SCONO_xTM

SCONO_x is a catalytic add-on technology (and registered trademark) that achieves NO_x control by oxidizing and then absorbing the pollutant onto a honeycomb structure coated with potassium carbonate. The pollutant is then released as molecular nitrogen during a regeneration cycle that requires dilute hydrogen gas. The technology has been demonstrated on small units in California and has been purchased for a small source in Massachusetts.¹⁰

California regulators and industry sources have stated that the first 250 MW block to install SCONO_x will be at PG&E's La Paloma Plant near Bakersfield.¹¹ The overall project includes several more 250 MW blocks with SCR for control.¹² USEPA has identified an "achieved in practice" BACT value of 2.0 ppmvd over a three-hour rolling average based upon the recent performance of a Vernon, California natural gas-fired 32 MW combined cycle turbine equipped with SCONO_xTM.

SCONO_x technology (at 2.0 ppmvd) is considered to represent LAER in non-attainment areas where cost is not a factor in setting an emission limit. It competes with less-expensive ~~SCR in those areas~~, but has the advantages that it does not cause ammonia emissions in exchange for NO_x reduction. Advantages of the SCONO_x process include in addition to the reduction of NO_x, the elimination of ammonia and the control of VOC and CO emissions. SCONO_xTM has not been applied on any major sources in ozone attainment areas.

Recently EPA Region IX acknowledged that SCONO_x was demonstrated in practice to achieve 2.0 ppmv NO_x.¹³ Permitting authorities planning to issue permits for future combined cycle gas turbine systems firing exclusively on natural gas, and subject to LAER must recognize this limit which, in most cases, would result in a LAER determination of 2.0 ppmv. More recently, Goaline submitted information to EPA and states in support of its contention that the technology has achieved 1 ppmvd in practice.¹⁴

According to a recent press release, the Environmental Segment of ABB Alstom Power offers the technology (with performance guarantees) to "all owners and operators of natural gas-fired combined cycle combustion turbines, regardless of size."¹⁵ The technology was considered for one of the seven combined cycle units to be installed at the TECO Bayside Project (repowering of coal-fired Gannon Station Units 5 and 6). It was rejected on the basis of cost.

REVIEW OF SULFUR DIOXIDE (SO₂) AND SULFURIC ACID MIST (SAM)

SO₂ control processes can be classified into five categories: fuel/material sulfur content limitation, absorption by a solution, adsorption on a solid bed, direct conversion to sulfur, or direct conversion to sulfuric acid. A review of the BACT determinations for combustion turbines contained in the BACT Clearinghouse shows that the exclusive use of low sulfur fuels constitutes the top control option for SO₂.

For this project, the applicant has proposed as BACT the use of 0.05% sulfur oil and pipeline natural gas. The applicant estimated total emissions for the project at 76 TPY of SO₂ and 12 TPY of SAM. The Department expects that emissions will be lower because of the limited oil consumption and because typical natural gas distributed in Florida that contains less than the 0.0065% sulfur specification proposed as BACT.

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

REVIEW OF PARTICULATE MATTER (PM/PM₁₀) CONTROL TECHNOLOGIES:

Particulate matter is generated by various physical and chemical processes during combustion and will be affected by the design and operation of the NO_x controls. The particulate matter emitted from this unit will mainly be less than 10 microns in diameter (PM₁₀).

Natural gas and 0.05 percent sulfur No. 2 (or superior grade) distillate fuel oil will be the only fuels fired and are efficiently combusted in gas turbines. Such fuels are necessary to avoid damaging turbine blades and other components already exposed to very high temperature and pressure. Natural gas is an inherently clean fuel and contains no ash. The fuel oil to be combusted contains a minimal amount of ash and will be used for approximately 720 hours per year making any conceivable add-on control technique for PM/PM₁₀ either unnecessary or impractical.

A technology review indicated that the top control option for PM/PM₁₀ is a combination of good combustion practices, fuel quality, and filtration of inlet air. As previously mentioned, the NO_x control technology of SCR increases PM/PM₁₀ emissions due to formation of ammonium nitrates and ammonium sulfates. The problem is more significant when firing fuel oil (despite the low sulfur specification). This effect will be minimized by limiting fuel oil firing to less than 720 hours per year and limiting ammonia emissions (slip) to 5 ppmvd.

REVIEW OF CARBON MONOXIDE (CO) CONTROL TECHNOLOGIES

CO is emitted from combustion turbines due to incomplete fuel combustion. Most combustion turbines incorporate good combustion to minimize emissions of CO. There is a great deal of uncertainty regarding actual CO emissions from installed units. Despite the relatively high BACT limits typically proposed when using combustion controls, much lower emissions have actually been reported from several facilities without use of oxidation catalyst. For example, although Westinghouse does not offer a single digit CO guarantee on the 501F, the units installed at the FPC Hines Energy Complex achieved CO emissions in the range of 1-3 ppmvd on both gas and fuel oil.¹⁶ As previously discussed, GE 7FA units achieved similar results when firing gas at the City of Tallahassee Purdom Unit 8 and the TECO Polk Power Station Unit 2.

CO emissions *should* be low (at least at full load) because of the very high combustion temperatures characteristic of "F-Class" turbines. It appears that contract writing has not yet "caught up" with the field experience to consistently guarantee low CO emissions for F-Class units, at least at high loads.

One alternative is to complete the combustion by installation of an oxidation catalyst. Among the most recently permitted projects with oxidation catalyst requirements are the 500 MW Wyandotte Energy project in Michigan, the El Dorado project in Nevada, Ironwood in Pennsylvania, Millenium in Massachusetts, and Sutter Calpine in California. The permitted CO values of these units are between 3 and 5 ppmvd. Catalytic oxidation was recently installed at a cogeneration plant at Reedy Creek (Walt Disney World), Florida to avoid PSD review, which would have been required due to increased operation at low load. Seminole Electric will install oxidation catalyst to meet the permitted CO limit at its planned 244 MW Westinghouse 501FD combined cycle unit in Hardee County, Florida.¹⁷

The limit proposed by CPV when firing natural gas is 9 ppmvd at the entire operating range between 50 and 100 percent of full load. This is consistent with the description of the DLN-2.6 technology. A higher limit of 15 ppmvd is proposed during power augmentation. Under this mode, steam from the HRSG is re-injected into the combustors to boost power production. One consequence is that CO

APPENDIX BD

BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

emissions can increase. The emission limit of 20 ppmvd during limited fuel oil firing appears reasonable, although much lower values are likely to be achieved.

REVIEW OF VOLATILE ORGANIC COMPOUND (VOC) CONTROL TECHNOLOGIES

Volatile organic compound (VOC) emissions, like CO emissions, are formed due to incomplete combustion of fuel. The high flame temperature is very efficient at destroying VOC. The applicant has proposed good combustion practices to control VOC. The limits proposed by CPV for this project are 1.4 ppmvw for gas and 3.6 ppmvw for oil firing. According to GE, VOC emissions less than 1.4 ppm were achieved during recent tests of the DLN-2.6 technology when firing natural gas.¹⁸

Based on the chosen equipment, the Department believes that annual VOC emissions will be less than 40 TPY. Therefore a BACT determination is not required.

BACKGROUND ON SELECTED GAS TURBINE

CPV plans to the purchase a 170 MW (nominal) General Electric 7FA combined cycle gas turbine with an unfired heat recovery steam generator (HRSG). Per the discussion above, such units are capable of achieving and have achieved (with DLN and SCR technology) all of the emission limits proposed by CPV as BACT.

The GE SpeedtronicTM Mark V Gas Control System will be used. This control system is designed to fulfill all gas turbine control requirements. These include control of liquid, gas, or both fuels in accordance with the requirements of the speed, load control under part-load conditions, temperature control under maximum capability conditions, or during start-up conditions. The Mark V also monitors the DLN process and controls fuel staging and combustion modes to maintain the programmed NO_x values prior to the SCR unit.¹⁹

DEPARTMENT BACT DETERMINATION

Following are the BACT limits determined for the CPV project assuming full load. Values for NO_x, CO, and VOC are corrected to 15% O₂. The emission limits or their equivalents in terms of pounds per hour and NSPS units, as well as the applicable averaging times, are given in the permit Specific Conditions No. 16 through 21.

POLLUTANT	CONTROL TECHNOLOGY	PROPOSED BACT LIMIT
Nitrogen Oxides	Selective Catalytic Reduction	3.5 ppmvd @15% O ₂ (gas) 10 ppmvd@15% O ₂ (oil)
Carbon Monoxide	Combustion Controls	9 ppmvd (gas) 15 ppmvd (power augmentation) 20 ppmvd (oil)
Particulate Matter	Inherently Clean Fuels Combustion Controls Ammonia Slip < 5 ppmvd	11 lb/hr (gas) 36 lb/hr (oil) 10 percent Opacity
Sulfur Dioxide and Sulfuric Acid Mist	Low Sulfur Fuels	0.0065% sulfur (gas) 0.05% sulfur (oil)

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

RATIONALE FOR DEPARTMENT'S DETERMINATION

- The Lowest Achievable Emission Rate (LAER) for NO_x is approximately 2 ppmvd while firing natural gas. It has been achieved at the 32 MW Federal Merchant Plant in Los Angeles. The owner, Goal Line, has requested recognition of a 1.3 ppmvd NO_x value as *achieved in practice*.
- There are several projects for large turbines requiring SCR with a NO_x emission limit of 2 ppmvd.
- The "Top" technology in a top/down analysis will achieve 2 ppmvd by either SCONO_x or SCR.
- CPV chose SCR over SCONO_x for technical and economic reasons. The Department does not necessarily accept the technical rationale. The Department does not necessarily accept the economic figures submitted by CPV of \$2,835 and \$24,916 per ton of NO_x removed by SCR and SCONO_x respectively.
- If the costs submitted by CPV were *doubled* to \$5,600 per ton by SCR and *halved* to \$12,500 per ton by SCONO_x, the former control technology would still be more cost-effective than the latter. The difference of almost \$7,000 per ton of NO_x removed is sufficient reason to select SCR over SCONO_x for this project.
- CPV proposes a NO_x limit of 3.5 ppmvd while firing natural gas. This is equal to the lowest emission rate in Florida and nearby states to-date.
- Based on previous projects such as KUA Cane Island, the Department believes that the costs of NO_x control by SCR are on the order of \$6,000 per ton when ammonia emissions are held to 5 ppmvd.
- Uncertainties (and statistical variances) in NO_x emissions related to instrumentation, methodology, calibration and sampling errors; exhaust flow, ammonia slip bias, corrections to 15% O₂ and ambient conditions, etc., are approximately equal to "ultra low NO_x" limits (2.5-3.5 ppmvd).²⁰
- Although further reduction to 2 ppmvd is possible (though difficult to measure), the marginal costs escalate rapidly and ammonia emissions increase.
- The Department agrees with CPV that 3.5 ppmvd (with 5 ppmvd ammonia slip) while firing natural gas constitutes BACT. This value for the SCR option takes into consideration the uncertainties mentioned above and minimize the negative effects of ammonia emissions.
- The Department previously documented the environmental and cost impacts associated with the use of SCR to achieve 3.5 ppmvd of NO_x at the KUA Cane Island Project in comparison with DLN to achieve 9 ppmvd NO_x.
- EPA Region IV determined that there are no there were "no unusual site-specific conditions associated with the KUA project to indicate that the use of SCR to achieve NO_x emissions of 3.5 ppm would cause greater problems than experienced elsewhere at other similar facilities."
- In comparison with the KUA project, there are no obvious site-specific conditions that would make it unadvisable to use ammonia at the CPV project. It is noted that the site is adjacent to I-95. However, this at least minimizes transportation through densely populated areas.
- The conclusion is that the cost and environmental impacts of SCR for this project are acceptable in view of the NO_x reduction.

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

- The CO limits of 9 ppmvd while firing natural gas and 15 ppmvd under power augmentation are low and within the range of recent BACT determinations for combustion turbines in the Southeast. The CO limit during the limited hours of fuel oil firing will be set at 20 ppmvd (full load).
- The CO impact on ambient air quality is lower compared to other pollutants because the allowable concentrations of CO are much greater than for NO_x, SO₂, or PM₁₀.
- CPV initially estimated levelized costs for CO catalyst control at \$4,350 to reduce emissions from the 9-20 range to a 2-4 ppm range. EPA made several comments regarding cost estimation techniques used by CPV (for the Gulfcoast Project) that suggest the estimate is biased to the high side. Revised CPV estimates (see Final Determination of CPV Gulfcoast) range from \$3,050 to 3,870.
- In view of the performance of GE 7FA units cited in the discussion above (Tallahassee and TECO Polk Power data) without add-on control (~ 1 ppmvd), it appears to the Department that oxidation catalyst costs are substantially biased to the low side based on *actual* emissions.
- The measured CO values (~ 1 ppmvd) at Tallahassee and TECO Polk Power *without control* are less than the objective to be obtained by catalytic reduction (e.g. reducing CO from 20 to 4 ppm or from 9 to 2 ppm).
- The Department will set CO limits reflecting the "new and clean test" guarantees rather than actual performance because GE will not (yet) guarantee the lower values. The Department will gather more information and may substantially reduce CO limits in future projects if such performance is maintained at the new installations throughout the state. The Department will also limit the extent to which CPV can operate in power augmentation mode to 2000 hours unless CPV installs oxidation catalyst or proves that actual performance is much better than guaranteed (thus rendering control not cost effective).
- There is no benefit in penalizing the applicant with a lower limit at this time just because the performance at another site was far better than guaranteed or expected. There also appears to be no benefit in installing a catalytic oxidation system. The applicant will be among the first to install a continuous CO monitor. It is expected that data from continuous measurement will conclusively show that oxidation catalyst is not needed and is not cost effective for this project.
- The Department agrees that inlet air filtration, good combustion, and use of inherently clean fuels constitute BACT for PM/PM₁₀. Furthermore, the Department will set the ammonia limit at 5 ppmvd to minimize additional PM formation.
- PM₁₀ emissions will be very low and difficult to measure. The values of 11 and 36 lb/hr for natural gas and oil respectively will be included in the permit. These values include front-half catch only.
- The Department will set a visible emissions BACT limit at 10 percent. The Department will rely on VE observation as a surrogate for PM/PM₁₀ BACT compliance (after the initial PM/PM₁₀ test).

COMPLIANCE PROCEDURES

The following compliance procedures apply to this BACT determination. The precise details are given in the permit.

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

POLLUTANT	COMPLIANCE PROCEDURE
Visible Emissions (initial, annual)	Method 9
PM/PM ₁₀	Method 5 (Front-half catch)
VOC	Method 25A corrected by methane from Method 18
CTM-027(initial, quarterly, annual)	Procedure for Collection and Analysis of Ammonia in Stationary Sources
SO ₂ /SAM	Record keeping for the sulfur content of fuels delivered to the site
CO (initial, annual, CEMS)	Method 10; CO-CEMS (continuous 24-hr)
NO _x (continuous 24-hr)	NO _x CEMS, O ₂ or CO ₂ diluent monitor, and flow device as needed
NO _x (initial and annual)	Annual Method 20 (can use RATA if at capacity); Method 7E

BACT EXCESS EMISSIONS APPROVAL

Pursuant to the Rule 62-210.700 F.A.C., the Department through this BACT determination will allow excess emissions as follows: Valid hourly emission rates shall not include periods of startup, shutdown, or malfunction as defined in Rule 62-210.200 F.A.C., where emissions exceed the applicable NO_x standard. These excess emissions periods shall be reported as required in Specific Condition 24 of the Permit. A valid hourly emission rate shall be calculated for each hour in which at least two NO_x concentrations are obtained at least 15 minutes apart [Rules 62-4.070 F.A.C., 62-210.700 F.A.C. and applicant request].

Excess emissions may occur under the following startup scenarios:

Hot Start: One hour in simple cycle or following a shutdown less than or equal to 8 hours.

Warm Start: Two hours following a shutdown between 8 and 48 hours.

Cold Start: Four hours following a shutdown greater than or equal to 48 hours.

The starts are defined by the amount of time the HRSG has been shutdown, following the normal (hot) shutdown procedure described by General Electric, prior to the startup.²¹

DETAILS OF THE ANALYSIS MAY BE OBTAINED BY CONTACTING:

Teresa Heron, Review Engineer, New Source Review Section

A. A. Linero, P.E. Administrator, New Source Review Section

Bureau of Air Regulation

2600 Blair Stone Road

Tallahassee, Florida 32399-2400

Recommended By:

Approved By:

C. H. Fancy, P.E., Chief
Bureau of Air Regulation

Howard L. Rhodes, Director
Division of Air Resources Management

Date:

Date:

APPENDIX BD
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION (BACT)

REFERENCES

- ¹ Report. Cubix Corporation. "Exhaust Emissions from a GE PG7241FA Simple Cycle Power Turbine at TECO Polk Power Station." September 2000.
- ² Report. Cubix Corporation. "Exhaust Emissions from a GE PG7241FA Simple Cycle Power Turbine at TECO Polk Power Station." September 2000.
- ³ Telecom. Heron, T., FDEP and Gianazza, N. B., JEA. Additional Hours of Operation at JEA Kennedy Station. January 22, 2001.
- ⁴ Telecom. Linero, A.A., FDEP and Chalfin, J., GE. NO_x control technology for fuel oil.
- ⁵ Paper. Mandai, S., et. al., MHI. "Development of Low NO_x Combustor for Firing Dual Fuel." Mitsubishi Juko Giho, Vol.36 No.1 (1999).
- ⁶ Paper. Cohn, A. and Scheibel, J., EPRI. Current Gas Turbine Developments and Future Projects. October 1997.
- ⁷ Compliance Manual. California EPA, CARB Compliance Division. Gas Turbines. June 1996.
- ⁸ News Release. Catalytica. First Gas Turbine with Catalytica's XONON installed to Produce Electricity at a Utility. October 8, 1998.
- ⁹ News Release. Catalytica. XONONTM Specified With GE 7FA Gas Turbines For Enron Power Project. December 15, 1999.
- ¹⁰ News Release. Goal Line. Genetics Institute Buys SCONOX Clean Air System. August 20, 1999.
- ¹¹ Publication "Control Maker Strives to Sway Utility Skeptics." Air Daily. Volume 5, No. 199. October 14, 1998.
- ¹² Telecom. Linero, A.A., FDEP, and Beckham, D., U.S. Generating. Circa November 1998.
- ¹³ Letter. Haber, M., EPA Region IX to Danziger, R., GLET. SCONOX at Federal Cogeneration. March 23, 1998.
- ¹⁴ Letter. Bedwell, A.F., Goal Line to Linero, A.A., FDEP. Re: SCONOX 21000-Hour Report. September 29, 2000.
- ¹⁵ News Release. ABB Alstom Power, Environmental Segment. ABB Alstom Power to Supply Groundbreaking SCONOXTM Technology. December 1, 1999.
- ¹⁶ Reports. Cubix Corporation. "Initial Compliance Reports - Power Block I." February and May 1999.
- ¹⁷ Letter. Opalinski, M.P., SECI to Linero, A.A., FDEP. Turbines and Related Equipment at Hardee Unit 3. December 9, 1998.
- ¹⁸ Telecon. Vandervort, C., GE, and Linero, A.A., DEP. "VOC Emissions from FA Gas Turbines with DLN-2.6 Combustors."
- ¹⁹ Rowen, W.I. "General Electric SpeedtronicTM Mark V Gas Turbine Control System. 1994."
- ²⁰ Zachary, J, Joshi, S., and Kagolanu, R., Siemens. "Challenges Facing the Measurement and Monitoring of Very Low Emissions in Large Scale Gas Turbine Projects." Power-Gen Conference. Orlando, Florida. December 9-11, 1998.
- ²¹ General Electric. Combined Cycle Startup Curves. June 19, 1998.

APPENDIX GC
GENERAL PERMIT CONDITIONS [F.A.C. 62-4.160]

- G.1 The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
- G.2 This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings or exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
- G.3 As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey and vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
- G.4 This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- G.5 This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
- G.6 The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- G.7 The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
- a) Have access to and copy and records that must be kept under the conditions of the permit;
 - b) Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
 - c) Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.
- Reasonable time may depend on the nature of the concern being investigated.
- G.8 If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
- a) A description of and cause of non-compliance; and
 - b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

APPENDIX GC
GENERAL PERMIT CONDITIONS [F.A.C. 62-4.160]

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

- G.9 In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- G.10 The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
- G.11 This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- G.12 This permit or a copy thereof shall be kept at the work site of the permitted activity.
- G.13 This permit also constitutes:
- a) Determination of Best Available Control Technology (X)
 - b) Determination of Prevention of Significant Deterioration (X); and
 - c) Compliance with New Source Performance Standards (X).
- G.14 The permittee shall comply with the following:
- a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
 - b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
 - c) Records of monitoring information shall include:
 - 1. The date, exact place, and time of sampling or measurements;
 - 2. The person responsible for performing the sampling or measurements;
 - 3. The dates analyses were performed;
 - 4. The person responsible for performing the analyses;
 - 5. The analytical techniques or methods used; and
 - 6. The results of such analyses.
- G.15 When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

APPENDIX GG
40 CFR 60 NSPS REQUIREMENTS FOR GAS TURBINES

NSPS SUBPART GG REQUIREMENTS

[Note: Inapplicable provisions have been deleted in the following conditions, but the numbering of the original rules has been preserved for ease of reference to the original rules. The term "Administrator" when used in 40 CFR 60 shall mean the Department's Secretary or the Secretary's designee. Department notes and requirements related to the Subpart GG requirements are shown in **bold** immediately following the section to which they refer. The rule basis for the Department requirements specified below is Rule 62-4.070(3), F.A.C.]

11. Pursuant to 40 CFR 60.332 Standard for Nitrogen Oxides:

- (a) On and after the date of the performance test required by § 60.8 is completed, every owner or operator subject to the provisions of this subpart as specified in paragraph (b) section shall comply with:

- (1) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$\text{STD} = 0.0075 \frac{(14.4)}{Y} + F$$

where:

STD = allowable NOx emissions (percent by volume at 15 percent oxygen and on a dry basis).

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per-watt hour.

F = NOx emission allowance for fuel-bound nitrogen as de-fined in paragraph (a)(3) of this section.

- (3) F shall be defined according to the nitrogen content of the fuel as follows:

Fuel-bound nitrogen (percent by weight)	F (NOx percent by volume)
$N \leq 0.015$	0
$0.015 < N \leq 0.1$	$0.04(N)$
$0.1 < N \leq 0.25$	$0.004 + 0.0067(N - 0.1)$
$N > 0.25$	0.005

Where, N = the nitrogen content of the fuel (percent by weight).

Department requirement: While firing gas, the "F" value shall be assumed to be 0.

[Note: This is required by EPA's March 12, 1993 determination regarding the use of NOx CEMS. The "Y" values provided by the applicant are approximately 10.0 for natural gas and 10.6 for fuel oil. The equivalent emission standards are 108 and 102 ppmvd at 15% oxygen. The emissions standards of this permit is more stringent than this requirement.]

- (b) Electric utility stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired shall comply with the provisions of paragraph (a)(1) of this section.

12. Pursuant to 40 CFR 60.333 Standard for Sulfur Dioxide:

On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, every owner or operator subject to the provision of this subpart shall comply with:

- (b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains sulfur in excess of 0.8 percent by weight.

13. Pursuant to 40 CFR 60.334 Monitoring of Operations:

APPENDIX GG
40 CFR 60 NSPS REQUIREMENTS FOR GAS TURBINES

- (b) The owner or operator of any stationary gas turbine subject to the provisions of this subpart shall monitor sulfur content and nitrogen content of the fuel being fired in the turbine. The frequency of determination of these values shall be as follows:
- (1) If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source.

Department requirement: The owner or operator is allowed to use vendor analyses of the fuel as received to satisfy the sulfur content monitoring requirements of this rule for fuel oil. Alternatively, if the fuel oil storage tank is isolated from the combustion turbines while being filled, the owner or operator is allowed to determine the sulfur content of the tank after completion of filling of the tank, before it is placed back into service.

[Note: This is consistent with guidance from EPA Region 4 dated May 26, 2000 to Ronald W. Gore of the Alabama Department of Environmental Management.]

- (2) If the turbine is supplied its fuel without intermediate bulk storage the values shall be determined and recorded daily. Owners, operators or fuel vendors may develop custom schedules for determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with paragraph (b) of this section.

Department requirement: The requirement to monitor the nitrogen content of pipeline quality natural gas fired is waived. The requirement to monitor the nitrogen content of fuel oil fired is waived because a NOx CEMS shall be used to demonstrate compliance with the NOx limits of this permit. For purposes of complying with the sulfur content monitoring requirements of this rule, the owner or operator shall obtain a monthly report from the vendor indicating the sulfur content of the natural gas being supplied from the pipeline for each month of operation.

[Note: This is consistent with EPA's custom fuel monitoring policy and guidance from EPA Region 4.]

- (c) For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions that shall be reported are defined as follows:
- (1) *Nitrogen oxides.* Any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with 40 CFR 60.332 by the performance test required in § 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the performance test required in § 60.8. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under 40 CFR 60.335(a).

Department requirement: NOx emissions monitoring by CEM system shall substitute for the requirements of paragraph (c)(1) because a NOx monitor is required to demonstrate compliance with the standards of this permit. Data from the NOx monitor shall be used to determine "excess emissions" for purposes of 40 CFR 60.7 subject to the conditions of the permit.

[Note: As required by EPA's March 12, 1993 determination, the NOx monitor shall meet the applicable requirements of 40 CFR 60.13, Appendix B and Appendix F for certifying, maintaining, operating and assuring the quality of the system; shall be capable of calculating NOx emissions concentrations corrected to 15% oxygen; shall have no less than 95% monitor availability in any given calendar quarter; and shall provide a minimum of four data points for each hour and calculate an hourly average. The requirements for the CEMS specified by the specific conditions of this permit satisfy these requirements.]

APPENDIX GG
40 CFR 60 NSPS REQUIREMENTS FOR GAS TURBINES

- (2) *Sulfur dioxide*. Any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 percent.

14. Pursuant to 40 CFR 60.335 Test Methods and Procedures:

- (a) To compute the nitrogen oxides emissions, the owner or operator shall use analytical methods and procedures that are accurate to within 5 per-cent and are approved by the Administrator to determine the nitrogen content of the fuel being fired.
- (b) In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided for in 40 CFR 60.8(b). Acceptable alternative methods and procedures are given in paragraph (f) of this section.
- (c) The owner or operator shall determine compliance with the nitrogen oxides and sulfur dioxide standards in 40 CFR 60.332 and 60.333(a) as follows:
- (1) The nitrogen oxides emission rate (NO_x) shall be computed for each run using the following equation:

$$\text{NO}_x = (\text{NO}_{x0}) (\text{Pr}/\text{Po})^{0.5} e^{19(\text{Ho}-0.00633)} (288^\circ\text{K}/\text{Ta})^{1.53}$$

where:

- NO_x = emission rate of NO_x at 15 percent O₂ and ISO standard ambient conditions, volume percent.
- NO_{x0} = observed NO_x concentration, ppm by volume.
- Pr = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg.
- Po = observed combustor inlet absolute pressure at test, mm Hg.
- Ho = observed humidity of ambient air, g H₂O/g air.
- e = transcendental constant, 2.718.
- Ta = ambient temperature, °K.

Department requirement: The owner or operator is not required to have the NO_x monitor required by this permit continuously calculate NO_x emissions concentrations corrected to ISO conditions. However, the owner or operator shall keep records of the data needed to make the correction, and shall make the correction when required by the Department or Administrator.

[Note: This is consistent with guidance from EPA Region 4.]

- (2) The monitoring device of 40 CFR 60.334(a) shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with 40 CFR 60.332 at 30, 50, 75, and 100 percent of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer.

Department requirement: The owner or operator is allowed to conduct initial performance tests at a single load because a NO_x monitor shall be used to demonstrate compliance with the BACT NO_x limits of this permit.

[Note: This is consistent with guidance from EPA Region 4.]

- (3) Method 20 shall be used to determine the nitrogen oxides, sulfur dioxide, and oxygen concentrations. The span values shall be 300 ppm of nitrogen oxide and 21 percent oxygen. The NO_x emissions shall be determined at each of the load conditions specified in paragraph (c)(2) of this section.

Department requirement: The owner or operator is allowed to make the initial compliance demonstration for NO_x emissions using certified CEM system data, provided that compliance be based on a minimum of three test runs representing a total of at least three hours of data, and that the CEMS be calibrated in accordance with the procedure in section 6.2.3 of Method 20

APPENDIX GG
40 CFR 60 NSPS REQUIREMENTS FOR GAS TURBINES

following each run. Alternatively, initial compliance may be demonstrated using data collected during the initial relative accuracy test audit (RATA) performed on the NO_x monitor. The span value specified in the permit shall be used instead of that specified in paragraph (c)(3) above.

[Note: These initial compliance demonstration requirements are consistent with guidance from EPA Region 4. The span value is changed pursuant to Department authority and is consistent with guidance from EPA Region 4.]

- (d) The owner or operator shall determine compliance with the sulfur content standard in 40 CFR 60.333(b) as follows: ASTM D 2880-71 shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-80, D 3031-81, D 4084-82, or D 3246-81 shall be used for the sulfur content of gaseous fuels (incorporated by reference – see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator.

Department requirement: The permit specifies sulfur testing methods and allows the owner or operator to follow the requirements of 40 CFR 75 Appendix D to determine the sulfur content of liquid fuels.

[Note: This requirement establishes different methods than provided by paragraph (d) above, but the requirements are equally stringent and will ensure compliance with this rule.]

- (e) To meet the requirements of 40 CFR 60.334(b), the owner or operator shall use the methods specified in paragraphs (a) and (d) of this section to determine the nitrogen and sulfur contents of the fuel being burned. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.

[Note: The fuel analysis requirements of the permit meet or exceed the requirements of this rule and will ensure compliance with this rule]

7099 3400 0000 1449 2839

U.S. Postal Service CERTIFIED MAIL RECEIPT (Domestic Mail Only; No Insurance Coverage Provided)		
Article Sent To: Mr. Gary Lambert		
Postage	\$	CPV Atlantic
Certified Fee		Postmark here
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	
Name (Please Print Clearly) (to be completed by mailer) Mr. Gary Lambert		
Street, Apt. No., or PO Box No. 45 Braintree Hill Office Park-Suite 107		
City, State, ZIP+2 Braintree MA 02184		
PS Form 3800, July 1999 See Reverse for Instructions		

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. Gary Lambert
CPV Atlantic, Ltd
45 Braintree Hill Office Park
Suite 107
Braintree, MA 02184

COMPLETE THIS SECTION ON DELIVERY

A. Received by (Please Print Clearly) B. Date of Delivery

C. Signature

X *J. Le Blanc* ☐ Agent ☐ Addressee

D. Is delivery address different from item 1? ☐ Yes

If YES, enter delivery address below: ☐ No

3. Service Type

☒ Certified Mail ☐ Express Mail
☐ Registered ☐ Return Receipt for Merchandise
☐ Insured Mail ☒ 02184-9998

4. Restricted Delivery? (Extra Fee) ☐ Yes

2. Article Number (Copy from service label)

7099 3400 0000 1449 2839

Memorandum

Florida Department of Environmental Protection

TO: ~~Clair H. Fancy~~ *day for CRT*
FROM: A. A. Linero *A.A. Linero*
DATE: February 16, 2001
SUBJECT: CPV Atlantic Power Generating Facility
Combined Cycle Plant
DEP File No. 1110101-001-AC (PSD-FL-312)

Attached is the draft public notice package for construction of a Combined Cycle Plant at the CPV Atlantic Power Generating facility near Port St. Lucie, St. Lucie County.

The basic unit is a nominal 170-megawatt General Electric 7FA gas and oil-fired combustion turbine-generator. The project includes an un-fired HRSG and a separate steam-driven electrical generator. A selective catalytic reduction system including ammonia storage is included.

A 1.0 million gallon storage tank will be constructed for the back-up distillate fuel that will be used for no more than 720 hours per year. Power augmentation will be employed at high ambient temperature to partially compensate for loss of power output.

Nitrogen Oxides (NO_x) emissions from the gas turbine will be controlled by SCR to 3.5 ppmvd (gas) and 10 ppmvd (oil). The ammonia limit is proposed by the applicant at 5 ppmvd. This will reduce formation of ammoniated particulate species.

Emissions of carbon monoxide, volatile organic compounds, sulfur dioxide, sulfuric acid mist, and particulate matter (PM/PM₁₀) will be very low because of the inherently clean pipeline quality natural gas, limited fuel oil use and the design of the GE unit.

In early January, we provided portions of the application related to the steam cycle to the Power Plant Siting Office. I contacted them earlier this week. They found no reason to review the full application or our draft.

Day 74 is approximately March 11 so we are well ahead of schedule. I recommend your signature and approval of this Intent to Issue.

AAL/al

Attachments