

Adams, Patty

From: Mulkey, Cindy
Sent: Thursday, January 12, 2006 2:29 PM
To: Adams, Patty
Cc: Mulkey, Cindy
Subject: TCEC corrections to Draft Permit

Patty,

Please file this in the Treasure Coast Energy Center file.

This is to document phone conversations with FMPA (Susan Schumann) and Black & Veatch (Bob Holmes) regarding the TCEC project

No. 1110121-001-AC (PSD-FL-353). Some of the mass emission rates (lb/hr) listed in Condition 13, Emission Standards do not precisely coincide with the mass emission rates submitted by the applicant for the given concentration. This is due to the fact that I made independent calculations using an f-factor and the given heat input rate for each concentration.

The differences are less than $\pm 2\%$ and in most cases less than $\pm 1\%$. I have agreed to make the changes as corrections to the draft permit.

Modeling was based on the rates submitted in the application. The changes will not impact any determination made by the department.

Cindy

Cindy Mulkey
Engineering Specialist
Bureau of Air Regulation
Permitting South
(850) 921-8968
FAX (850)921-9533
SC 291-8968

**Treasure Coast Energy Center Draft PSD-FL-353
Explanation of proposed revisions submitted by FMPA**

Comment number	Corresponding page number in draft permit	Corresponding Condition in draft permit	Explanation of Revision / Comment
1	1	n/a	Expiration of permit should be extended to July 31, 2009, to allow for flexibility in construction schedule
2	1	n/a	Thomas W. Richards of FPUA will be the Authorized Representative for Treasure Coast Energy Center
3	2	n/a	Subpart KKKK applicability will be dependent upon the final rule wording; applicability may change from original proposed language
4	5	2.(d)	Correction for the date of the proposed NSPS standard
5	5	2.(d)	Subpart KKKK applicability will be dependent upon the final rule wording; applicability may change from the original proposed language
6	5	4.	Revision of maximum heat input rate from 565 MMBtu to 565.3 MMBtu, consistent with page 16 of the TCEC PSD application.
7	6	7.	Revision of reference from 40 CFR 60.130 (NSPS for brass and bronze production plants) to 40 CFR 68.130 (lists substances under Chemical Accident Prevention provisions)
8	6	8.	The Combustion Turbine has been purchased, and the final performance runs indicate the fuel oil heat input will be slightly higher, revised from 1,967MMBtu to 1,986MMBtu per hour.
9	6	9.	Revision of maximum heat input rate from 560 MMBtu to 565.3 MMBtu, as noted on page 16 of the TCEC PSD application
10	7	12.d.	Duct firing will not be limited to only natural gas firing of the combustion turbine. This is consistent with page TE-5 of the Technical Evaluation document, where FDEP recognizes that FMPA "requests unlimited use of duct burning...while firing either gas or oil in the combustion turbine."
11	8	13.	FMPA understands calendar 12-month-annual-average will be utilized as CEMS block average.
12	8	13.b.	Revision of language from "shall" to "may," consistent with 13.a
13	9	14.	Clarification of language to reflect proper training for maintenance procedures. Due to the complexity of the units, operators are not trained to "maintain" the units, but they will be trained to identify, troubleshoot, and coordinate maintenance items.
14	11	22.	Clarification of language to add "for good cause."
15	11	24.	Suggest removing sentence from permit. Condition 13 specifically indicates that short-term limits are based on stack tests.
16	14	30.b.	Clarification of language to reflect fuel sampling procedures to include permittee or vendor.
17	17	2.	Clarification of language to reflect commercial operation.
18	18	n/a	Engineer, Procure, Construct (EPC) final specification includes 750kw/1000hp generator – TCEC permit application estimated 765hp. FMPA is currently working with FDEP to address the revisions to the proposed safe shutdown generator.
19	18	n/a	Include language to accurately describe Emission Unit

PERMITTEE:

Florida Municipal Power Agency
8553 Commodity Circle
Orlando, Florida 32819

Treasure Coast Energy Center
DEP File No. FL10121-001-AC
Permit No. PSD-FL-353
SIC No. 4911
Expires: July 31, 2008

2509

1. Authorized Representative:

2. ~~Daniel Cassol, Director of Generation~~

Thomas W. Richards, FPUA
Director of Electric and Gas Systems

PROJECT AND LOCATION

This permit authorizes the construction of a nominal 300 MW gas-fired combined cycle electrical power plant. The project will include one 170 MW combustion turbine generator, one heat-recovery steam generator, a 130 MW steam turbine generator, a fuel oil storage tank, a mechanical draft cooling tower, and auxiliary equipment. The project will be located southwest of the city of Fort Pierce, East of Highway 95 in St. Lucie County.

STATEMENT OF BASIS

This construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.). The project was processed in accordance with the requirements of Rule 62-212.400, F.A.C., the preconstruction review program for the Prevention of Significant Deterioration (PSD) of Air Quality. Pursuant to Chapter 62-17, F.A.C. and Chapter 403 Part II, F.S., the project is also subject to Electrical Power Plant Siting. The permittee is authorized to install the proposed equipment in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department of Environmental Protection (Department).

The attached Appendices are made a part of this permit:

- Appendix A NSPS Subpart A. Identification of General Provisions
- Appendix BD Final BACT Determination and Emissions Standards
- Appendix Da NSPS Subpart Da Requirements
- Appendix GC Construction Permit General Conditions
- Appendix GG NSPS Subpart GG Requirements
- Appendix SC Standard Conditions

Michael G. Cooke, Director
Division of Air Resources Management

Date: _____

SECTION I - GENERAL INFORMATION

FACILITY DESCRIPTION

The proposed FMPA facility is a combined cycle power plant. The project is to install one combined cycle unit which will consist of one gas turbine (nominal 170 MW) and one heat recovery steam generator with supplementary duct firing, a steam turbine-electrical generator (nominal 130 MW), a mechanical draft cooling tower, and one 990,000 gallon fuel oil storage tank. Ancillary equipment includes a diesel engine driven fire pump with associated 500 gallon fuel oil tank, and a safe shutdown generator.

EMISSIONS UNITS

This permit authorizes construction and installation of the following new emissions unit:

EU ID NO.	EMISSION UNIT DESCRIPTION
001	Unit 1 consists of a General Electric PG7241 FA gas turbine electrical generator (nominal 170 MW) equipped with evaporative inlet air cooling, a heat recovery steam generator (HRSG) with supplemental duct firing, a HRSG stack, and a steam turbine electrical generator (nominal 130 MW).

REGULATORY CLASSIFICATION

Title III: The facility is not a "Major Source" of hazardous air pollutants (HAPs).

Title IV: The facility operates units subject to the Acid Rain provisions of the Clean Air Act.

Title V: The facility is a Title V or "Major Source" of air pollution in accordance with Chapter 62-213, F.A.C. because the potential emissions of at least one regulated pollutant exceed 100 tons per year. Regulated pollutants include pollutants such as carbon monoxide (CO), nitrogen oxides (NO_x), particulate matter (PM/PM₁₀), sulfur dioxide (SO₂), and volatile organic compounds (VOC).

PSD: The facility is located in an area that is designated as "attainment", "maintenance", or "unclassifiable" for each pollutant subject to a National Ambient Air Quality Standard. It is classified as a "fossil fuel-fired steam electric plant of more than 250 million BTU per hour of heat input", which is one of the 28 Prevention of Significant Deterioration (PSD) Major Facility Categories with the lower PSD applicability threshold of 100 tons per year. Potential emissions of at least one regulated pollutant exceed 100 tons per year, therefore the facility is classified as a major source of air pollution with respect to Rule 62-212.400 F.A.C., Prevention of Significant Deterioration of Air Quality.

NSPS: Unit 1 is subject to 40 CFR 60, Subparts GG (Standards of Performance for Stationary Gas Turbines) and Da (Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978). When the proposed NSPS Subpart KKKK (Standards of Performance for Stationary Combustion Turbines for Which Construction is Commenced After February 18, 2005) becomes final, the facility will be subject to Subpart KKKK, and may no longer be subject to subparts GG and Da. The distillate fuel oil tank has a capacity greater than or equal to 40,000 gallons (151 cubic meters) and is storing a liquid with a maximum true vapor pressure less than 3.5 kPa, and is therefore not subject to Subpart Kb.

NESHAP: The facility is not a "Major Source" of HAPs and Unit 1 is not subject to 40 CFR 63, Subpart YYYYY, National Emissions Standard for Hazardous Air Pollutants for Stationary Combustion Gas Turbines.

Siting: The facility is a steam electrical generating plant and is subject to the power plant siting provisions of Chapter 62-17, F.A.C.

SECTION I - GENERAL INFORMATION

PERMITTING AUTHORITY

All documents related to applications for permits to construct, operate or modify an emissions unit shall be submitted to the Bureau of Air Regulation of the Florida Department of Environmental Protection (DEP) at 2600 Blair Stone Road (MS #5505), Tallahassee, Florida 32399-2400. Copies of all such documents shall also be submitted to the Compliance Authority.

COMPLIANCE AUTHORITY

All documents related to compliance activities such as reports, tests, and notifications shall be submitted to the Department of Environmental Protection Southeast District, 400 North Congress Avenue, Suite 200, West Palm Beach, Florida 33401.

APPENDICES

The following Appendices are attached as part of this permit.

- Appendix A. NSPS Subpart A. Identification of General Provisions
- Appendix BD. Final BACT Determinations and Emissions Standards
- Appendix Da. NSPS Subpart Da Requirements for Duct Burners
- Appendix GC. General Conditions
- Appendix GG. NSPS Subpart GG Requirements for Gas Turbines
- Appendix SC. Standard Conditions

RELEVANT DOCUMENTS:

The documents listed below are the basis of the permit; however, they are specifically related to this permitting action and are on file with the Department.

- Application received on April 14, 2005
- Department's Determination of Sufficiency - Found Insufficient June, 6 2005
- FMPA Sufficiency responses dated July 28, 2005
- Department's Second Determination of Sufficiency - Found Sufficient August 29, 2005
- Department's Intent to Issue and Public Notice Package dated October 28, 2005
- Letter from EPA Region IV dated ___XXX___
- Final Certification by the Power Plant Siting Board on XXXX; and
- Department's Final Determination and Best Available Control Technology Determination issued concurrently with this Final Permit.

SECTION II. ADMINISTRATIVE REQUIREMENTS

1. General Conditions: The permittee shall operate under the attached General Conditions listed in Appendix GC of this permit. General Conditions are binding and enforceable pursuant to Chapter 403 of the Florida Statutes. [Rule 62-4.160, F.A.C.]
2. Applicable Regulations, Forms and Application Procedures: Unless otherwise indicated in this permit, the construction and operation of the subject emissions unit shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of: Chapter 403 of the Florida Statutes (F.S.); Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.); and the Title 40, Parts 51, 52, 60, 72, 73, and 75 of the Code of Federal Regulations (CFR), adopted by reference in Rule 62-204.800, F.A.C. The terms used in this permit have specific meanings as defined in the applicable chapters of the Florida Administrative Code. The permittee shall use the applicable forms listed in Rule 62-210.900, F.A.C. and follow the application procedures in Chapter 62-4, F.A.C. Issuance of this permit does not relieve the permittee from compliance with any applicable federal, state, or local permitting or regulations. [Rules 62-204.800, 62-210.300 and 62-210.900, F.A.C.]
3. Construction and Expiration: The permit expiration date includes sufficient time to complete construction, perform required testing, submit test reports, and submit an application for a Title V operation permit to the Department. Approval to construct shall become invalid for any of the following reasons: construction is not commenced within 18 months after issuance of this permit; construction is discontinued for a period of 18 months or more; or construction is not completed within a reasonable time. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified. In conjunction with an extension of the 18-month period to commence or continue construction (or to construct the project in phases), the Department may require the permittee to demonstrate the adequacy of any previous determination of Best Available Control Technology (BACT) for emissions units regulated by the project. For good cause, the permittee may request that this PSD air construction permit be extended. Such a request shall be submitted to the Department's Bureau of Air Regulation at least sixty (60) days prior to the expiration of this permit. [Rules 62-4.070(4), 62-4.080, 62-210.300(1), and 62-212.400(6)(b), F.A.C.]
4. New or Additional Conditions: For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
5. Modifications: No emissions unit or facility subject to this permit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning construction or modification. [Chapters 62-210 and 62-212, F.A.C.]
6. Application for Title IV Permit: At least 24 months before the date on which the new unit begins serving an electrical generator greater than 25 MW, the permittee shall submit an application for a Title IV Acid Rain Permit to the Department's Bureau of Air Regulation in Tallahassee and a copy to the Region 4 Office of the U.S. Environmental Protection Agency in Atlanta, Georgia. [40 CFR 72]
7. Title V Permit: This permit authorizes construction of the permitted emissions unit and initial operation to determine compliance with Department rules. A Title V operation permit is required for regular operation of the permitted emission units. The permittee shall apply for and obtain a Title V operation permit in accordance with Rule 62-213.420, F.A.C. To apply for a Title V operation permit, the applicant shall submit the appropriate application form, compliance test results, and such additional information as the Department may by law require. The application shall be submitted to the Department's Bureau of Air Regulation and a copy to the Compliance Authority. [Rules 62-4.030, 62-4.050, 62-4.220, and Chapter 62-213, F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

This section of the permit addresses the following emissions unit.

E.U. ID	Emission Unit Description
001	Unit 1 consists of a General Electric PG7241 FA gas turbine electrical generator (nominal 170 MW) equipped with evaporative inlet air cooling, a heat recovery steam generator (HRSG) with supplemental duct firing, a HRSG stack, and a steam turbine electrical generator (nominal 130 MW).

APPLICABLE STANDARDS AND REGULATIONS

- BACT Determinations:** The emission unit addressed in this section is subject to a Best Available Control Technology (BACT) determination for carbon monoxide (CO), nitrogen oxides (NO_x), particulate matter (PM/PM₁₀), sulfuric acid mist (SAM), and sulfur dioxide (SO₂). [Rule 62-212.400, F.A.C.]
- NSPS Requirements:** The combustion turbine shall comply with all applicable requirements of 40 CFR 60, listed below, adopted by reference in Rule 62-204.800(7)(b), F.A.C. The Department determines that compliance with the BACT emissions performance requirements also assures compliance with the New Source Performance Standards for Subpart Da, Subpart GG, and Subpart KKKK (as proposed). Some separate reporting and monitoring may be required by the individual subparts.

(a) **Subpart A, General Provisions,** including:

- 40 CFR 60.7, Notification and Record Keeping
- 40 CFR 60.8, Performance Tests
- 40 CFR 60.11, Compliance with Standards and Maintenance Requirements
- 40 CFR 60.12, Circumvention
- 40 CFR 60.13, Monitoring Requirements
- 40 CFR 60.19, General Notification and Reporting Requirements

(b) **Subpart Da, Standards of Performance for Electric Utility Steam Generating Units** These provisions include standards for duct burners.

(c) **Subpart GG, Standards of Performance for Stationary Gas Turbines:** These provisions include a requirement to correct test data to ISO conditions; however, such correction is not used for compliance determinations with the BACT standards.

(d) **Subpart KKKK, Standards of Performance for Stationary Gas Turbines:** These provisions were published February 18, 2004 as a proposed new NSPS standard. The final rule will be applicable to Unit 1 at the time of publication in the Federal Register. When the rule becomes final, Unit 1 may no longer be subject to NSPS Subparts Da and GG.

4, 5

EQUIPMENT

- Gas Turbine:** The permittee is authorized to install, tune, operate, and maintain one General Electric Model PG7241FA gas turbine-electrical generator set with a nominal generating capacity of 170 MW. The gas turbine will be equipped with DLN combustors, and an inlet air filtration system with evaporative coolers. The unit shall include the Speedtronic™ Mark VI automated gas turbine control system, and will have dual-fuel capability. [Application; Design]
- HRSG:** The permittee is authorized to install, operate, and maintain one heat recovery steam generator (HRSG) with a HRSG exhaust stack. The HRSG shall be designed to recover heat energy from the gas turbine and deliver steam to the steam turbine electrical generator. The HRSG may be equipped with supplemental gas-fired duct burners having a maximum heat input rate of 565 MMBtu per hour (HHV).

6

565.3

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

The duct burners shall be designed in accordance with the following specifications: 0.04 lb CO/MMBtu and 0.08 lb NO_x/MMBtu. [Application; Design]

CONTROL TECHNOLOGY

5. DLN Combustion: The permittee shall operate and maintain the General Electric DLN 2.6 combustion system (or better) to control NO_x emissions from the gas turbine when firing natural gas. Prior to the initial emissions performance tests required for the gas turbine, the DLN combustors and automated gas turbine control system shall be tuned to achieve the permitted levels for CO and sufficiently low NO_x values to meet the NO_x limits with the additional SCR control technology described below. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations.
6. Water Injection: The permittee shall install, operate, and maintain a water injection system to reduce NO_x emissions from the gas turbine when firing distillate fuel oil. Prior to the initial emissions performance tests required for the gas turbine, the water injection system shall be tuned to achieve the permitted levels for CO and sufficiently low NO_x values to meet the NO_x limits with the additional SCR control technology described below. Thereafter, the system shall be maintained and tuned in accordance with the manufacturer's recommendations.
7. Selective Catalytic Reduction (SCR) System: The permittee shall install, tune, operate, and maintain an SCR system to control NO_x emissions from the gas turbine when firing either natural gas or distillate fuel oil. The SCR system consists of an ammonia (NH₃) injection grid, catalyst, ammonia storage, monitoring and control system, electrical, piping and other ancillary equipment. The SCR system shall be designed, constructed and operated to achieve the permitted levels for NO_x and NH₃ emissions.

7. | Ammonia Storage: In accordance with 40 CFR 60.130, the storage of ammonia shall comply with all applicable requirements of the Chemical Accident Prevention Provisions in 40 CFR 68.

[Design; Rule 62-212.400(BACT), F.A.C.]

PERFORMANCE RESTRICTIONS

8. | Permitted Capacity - Gas Turbine: The maximum heat input rate to the gas turbine is 1,787 MMBtu per hour when firing natural gas and 1,967 MMBtu per hour when firing distillate fuel oil (based on a compressor inlet air temperature of 59° F, the higher heating value (HHV) of each fuel, and 100% load). Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternate methods of operation, and evaporative cooling. The permittee shall provide manufacturer's performance curves (or equations) that correct for site conditions to the Permitting and Compliance Authorities within 45 days of completing the initial compliance testing. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department. [Rule 62-210.200(PTE), F.A.C.]
9. | Permitted Capacity - HRSG Duct Burners: The total maximum heat input rate to the duct burners for the HRSG is 560 MMBtu per hour based on the higher heating value (HHV) of natural gas. Only natural gas shall be fired in the duct burners. [Rule 62-210.200(PTE), F.A.C.]
10. | Hours of Operation: The gas turbine may operate throughout the year (8760 hours per year). Restrictions on individual methods of operation are specified in separate conditions. [Rules 62-210.200(PTE) and 62-212.400 (BACT), F.A.C.]
11. | Authorized Fuels: The gas turbine shall fire natural gas as the primary fuel, which shall contain no more than 2.0 grains of sulfur per 100 standard cubic feet of natural gas. As a restricted alternate fuel, the gas turbine may fire ultra low sulfur distillate fuel oil containing no more than 0.0015% sulfur by weight. The

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

gas turbine shall fire no more than 500 hours of fuel oil, regardless of mode, during any calendar year.
[Rules 62-210.200(PTE) and 62-212.400 (BACT), F.A.C.]

12. Methods of Operation: Subject to the restrictions and requirements of this permit, the gas turbine may operate under the following methods of operation.

- a. *Combined Cycle Operation:* The gas turbine/HRSG system may operate to produce direct, shaft-driven electrical power and steam-generated electrical power from the steam turbine-electrical generator as a combined cycle unit subject to the restrictions of this permit. In accordance with the specifications of the SCR and HRSG manufacturers, the SCR system shall be on line and functioning properly during combined cycle operation or when the HRSG is producing steam.
- b. *Pseudo Simple Cycle Operation:* The gas turbine/HRSG system may operate in a pseudo simple cycle mode where steam from the HRSG bypasses the steam turbine electrical generator and is dumped directly to the condenser. This is not considered a separate mode of operation with respect to emission limits (i.e. emission limits of combined cycle operation still apply).
- c. *Inlet Fogging:* In accordance with the manufacturer's recommendations and appropriate ambient conditions, the evaporative cooling system may be operated to reduce the compressor inlet air temperature and provide additional direct, shaft-driven electrical power. This method of operation is commonly referred to as "fogging."
- d. *Duct Firing:* ~~When firing natural gas,~~ the HRSG system may fire natural gas in the duct burners to provide additional steam-generated electrical power.

[Application; Rules 62-210.200(PTE) and 62-212.400 (BACT), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

EMISSIONS STANDARDS

13. Emission Standards: Emissions from the turbine/HRSG system shall not exceed the following standards.

Pollutant	Fuel	Method of Operation	Stack Test, 3-Run Average		CEMS Block Average
			ppmvd @ 15% O ₂	lb/hr ^f	ppmvd @ 15% O ₂
CO ^a	Oil	Combustion Turbine (CT)	8.0	37.1	8.0, 24-hr
	Gas	CT, Normal	4.1	16.4	
		CT & Duct Burner (DB)	7.6	39.7	
	Oil/Gas	All Modes	NA	NA	6.0, 12-month
NO _x ^b	Oil	CT	8.0	61.0	8.0, 24-hr
	Gas	CT, Normal	2.0	13.2	2.0, 24-hr
		CT & DB	2.0	17.1	
PM/PM ₁₀ ^c	Oil/Gas	All Modes	0.0015% sulfur fuel oil, 2 gr S/100 SCF of gas Visible emissions shall not exceed 10% opacity for each 6-minute block average.		
SAM/SO ₂ ^d	Oil/Gas	All Modes	0.0015% sulfur fuel oil, 2 gr S/100 SCF of gas		
Ammonia ^e	Oil/Gas	CT, All Modes	5.0	NA	NA

- a. Continuous compliance with the 24-hour and 12-month CO standards shall be demonstrated based on data collected by the required CEMS. The initial and annual EPA Method 10 tests associated with the certification and quality assurance of the CEMS instruments may also be used to demonstrate compliance with the individual standards for natural gas, fuel oil, and basic duct burner mode.
- b. Continuous compliance with the 24-hr NO_x standards shall be demonstrated based on data collected by the required CEMS. The initial and annual EPA Method 7E or Method 20 tests associated with demonstration of compliance with 40 CFR 60, Subpart GG or certification and quality assurance of the CEMS instruments shall also be used to demonstrate compliance with the individual standards for natural gas, fuel oil, and duct burner modes during the time of those tests. NO_x mass emission rates are defined as oxides of nitrogen expressed as NO₂.
- c. The fuel sulfur specifications, established in Condition No. 11 of this section, combined with the efficient combustion design and operation of the gas turbine represents (BACT) for PM/PM₁₀ emissions. Compliance with the fuel specifications, CO standards, and visible emissions standards shall serve as indicators of good combustion. Compliance with the fuel specifications shall be determined by the requirements in Condition No. 30 of this section. Compliance with the visible emissions standard shall be demonstrated by conducting tests in accordance with EPA Method 9.
- d. The fuel sulfur specifications, established in Condition No. 11 this section, effectively limit the potential emissions of SAM and SO₂ from the gas turbine and represent BACT for these pollutants. Compliance with the fuel sulfur specifications shall be determined by the requirements in Condition No. 30 of this section.
- e. The SCR system shall be designed and operated for an ammonia slip limit of no more than 5 ppmvd corrected to 15% O₂ based on the average of three test runs.
- f. The mass emission rate standards are based on a turbine inlet condition of 59°F, evaporative cooling on, and using the HHV of the fuel. Mass emission rate may be adjusted from actual test conditions in accordance with the performance curves and/or equations on file with the Department.

[Rule 62-212.400 (BACT), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

EXCESS EMISSIONS

{Permitting Note: The following conditions apply only to the SIP-based emissions standards specified in Condition No. 13 of this section. Rule 62-210.700, F.A.C. (Excess Emissions) cannot vary or supersede any federal provision of the NSPS, or Acid Rain programs.}

13. | 14. Operating Procedures: The Best Available Control Technology (BACT) determinations established by this permit rely on "good operating practices" to reduce emissions. Therefore, all operators and supervisors shall be properly trained to operate and maintain the gas turbine, HRSG, and pollution control systems in accordance with the guidelines and procedures established by each manufacturer. The training shall include good operating practices as well as methods for minimizing excess emissions. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]

15. Definitions

- a. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions. [Rule 62-210.200(245), F.A.C.]
- b. *Shutdown* is the cessation of the operation of an emissions unit for any purpose. [Rule 62-210.200(230), F.A.C.]
- c. *Malfunction* is defined as any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner. [Rule 62-210.200(159), F.A.C.]

16. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C.]

17. Alternate Visible Emissions Standard: Visible emissions due to startups, shutdowns, and malfunctions shall not exceed 10% opacity except for up to ten, 6-minute averaging periods during a calendar day, which shall not exceed 20% opacity. [Rule 62-212.400(BACT), F.A.C.]

18. Excess Emissions Allowed: Excess emissions resulting from startup, shutdown, and documented malfunctions shall be permitted, provided that operators employ the best operational practices to minimize the amount and duration of emissions during such incidents. For the gas turbine/HRSG system, excess emissions resulting from startup, shutdown, or documented malfunctions shall not exceed two hours in any 24-hour period except for the following specific cases. A "documented malfunction" means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic mail.

- a. *Steam Turbine/HRSG System Cold Startup*: For cold startup of the steam turbine/HRSG system, excess emissions from the gas turbine/HRSG system shall not exceed six hours in any 24-hour period. A "cold startup of the steam turbine/HRSG system" is defined as startup of the combined cycle system following a shutdown of the steam turbine lasting at least 48 hours.

{Permitting Note: During a cold startup of the steam turbine system, the gas turbine/HRSG system is brought on line at low load to gradually increase the temperature of the steam-electrical turbine and prevent thermal metal fatigue.}

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

- b. *Steam Turbine/HRSG System Warm Startup*: For warm startup of the steam turbine/HRSG system, excess emissions shall not exceed four hours in any 24-hour period. A "warm startup of the steam turbine/HRSG system" is defined as a startup of the combined cycle system following a shutdown of the steam turbine lasting at least 8 hours and less than 48 hours.
- c. *Shutdown*: For shutdown of the combined cycle operation, excess emissions from the gas turbine/HRSG system shall not exceed three hours in any 24-hour period.
- d. *Fuel Switching*: Excess emissions due to oil-to-gas fuel switching shall not exceed 1 hour in any 24-hour period.
19. *Ammonia Injection*: Ammonia injection shall begin as soon as operation of the gas turbine/HRSG system achieves the operating parameters specified by the manufacturer. As authorized by Rule 62-210.700(5), F.A.C., the above condition allows excess emissions only for specifically defined periods of startup, shutdown, fuel switching, and documented malfunction of the gas turbine/HRSG system including the pollution control equipment. [Design; Rules 62-212.400(BACT) and 62-210.700, F.A.C.]
20. *DLN Tuning*: CEMS data collected during initial or other major DLN tuning sessions shall be excluded from the CEMS compliance demonstration provided the tuning session is performed in accordance with the manufacturer's specifications. A "major tuning session" would occur after completion of initial construction, a combustor change-out, a major repair or maintenance to a combustor, or other similar circumstances. Prior to performing any major tuning session, the permittee shall provide the Compliance Authority with an advance notice of at least 14 days that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [Design; Rule 62-4.070(3), F.A.C.]

EMISSIONS PERFORMANCE TESTING

21. *Test Methods*: Required tests shall be performed in accordance with the following reference methods.

Method	Description of Method and Comments
CTM-027	Procedure for Collection and Analysis of Ammonia in Stationary Source <ul style="list-style-type: none">This is an EPA conditional test method.The minimum detection limit shall be 1 ppm.
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources <ul style="list-style-type: none">The method shall be based on a continuous sampling train.The ascarite trap may be omitted or the interference trap of section 10.1 may be used in lieu of the silica gel and ascarite traps.
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines

Method CTM-027 is published on EPA's Technology Transfer Network Web Site at "<http://www.epa.gov/ttn/emc/ctm.html>". The other methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used for compliance testing unless prior written approval is received from the administrator of the Department's Emissions Monitoring Section in accordance with an alternate sampling procedure pursuant to 62-297.620, F.A.C. [Rules 62-204.800 and 62-297.100, F.A.C.; 40 CFR 60, Appendix A]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

14. 22. Initial Compliance Determinations: The gas turbine shall be stack tested to demonstrate initial compliance with the emission standards for CO, NO_x, visible emissions, and ammonia slip. The tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the initial startup. The unit shall be tested when firing natural gas, when using the duct burners and when firing distillate fuel oil. For each run during tests for visible emissions and ammonia slip, emissions of CO and NO_x recorded by the CEMS shall also be reported. NO_x and CO emissions data collected during the required continuous monitor Relative Accuracy Test Audits (RATAs) may be used to demonstrate initial compliance with the CO and NO_x standards. With appropriate flow measurements (or fuel measurements and approved F-factors), CEMS data may be used to demonstrate compliance with the CO and NO_x mass rate emissions standards. The Department may require the permittee to conduct additional tests after major replacement or major repair of any air pollution control equipment, such as the SCR catalyst, DLN combustors, etc. [Rule 62-297.310(7)(a)1, F.A.C. and 40 CFR 60.8] for good cause

23. Annual Compliance Tests: During each federal fiscal year (October 1st, to September 30th), the gas turbine shall be tested to demonstrate compliance with the emission standard for visible emissions. NO_x and CO emissions data collected during the required continuous monitor Relative Accuracy Test Audits (RATAs) may be used to demonstrate compliance with the CO and NO_x standards. Annual testing to determine the ammonia slip shall be conducted while firing the primary fuel. NO_x emissions recorded by the CEMS shall be reported for each ammonia slip test run. CO emissions recorded by the CEMS shall be reported for the visible emissions observation period. [Rules 62-212.400 (BACT) and 62-297.310(7)(a)4, F.A.C.]

15. 24. Continuous Compliance: The permittee shall demonstrate continuous compliance with the 24-hour CO and NO_x emissions standards based on data collected by the certified CEMS. Within 45 days of conducting any Relative Accuracy Test Assessments (RATA) on a CEMS, the permittee shall submit a report to the Compliance Authority summarizing results of the RATA. Compliance with the CO emission standards also serves as an indicator of efficient fuel combustion, which reduces emissions of particulate matter. The Department also reserves the right to use data from the continuous monitoring record and from annual RATA tests to determine compliance with the short-term CO and NO_x limits for each method of operation given in Condition 12 above. [Rule 62-212.400 (BACT), F.A.C.]

CONTINUOUS MONITORING REQUIREMENTS

25. CEM Systems: The permittee shall install, calibrate, maintain, and operate continuous emission monitoring systems (CEMS) to measure and record the emissions of CO and NO_x from the combined cycle gas turbine in a manner sufficient to demonstrate continuous compliance with the CEMS emission standards of this section. Each monitoring system shall be installed, calibrated, and properly functioning prior to the initial performance tests. Within one working day of discovering emissions in excess of a CO or NO_x standard (and subject to the specified averaging period), the permittee shall notify the Compliance Authority.

a. CO Monitor: The CO monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of Section 7 shall be made each calendar quarter, and reported semiannually to the Compliance Authority. The RATA tests required for the CO monitor shall be performed using EPA Method 10 in Appendix A of 40 CFR 60 and shall be based on a continuous sampling train. The CO monitor span values shall be set appropriately, considering the allowable methods of operation and corresponding emission standards.

b. NO_x Monitor: Each NO_x monitor shall be certified, operated, and maintained in accordance with the requirements of 40 CFR 75. Record keeping and reporting shall be conducted

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

pursuant to Subparts F and G in 40 CFR 75. The RATA tests required for the NO_x monitor shall be performed using EPA Method 20 or 7E in Appendix A of 40 CFR 60.

- c. *Diluent Monitor:* The oxygen (O₂) or carbon dioxide (CO₂) content of the flue gas shall be monitored at the location where CO and NO_x are monitored to correct the measured emissions rates to 15% oxygen. If a CO₂ monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.

26. CEMS Data Requirements:

- a. *Data Collection:* Emissions shall be monitored and recorded at all times including startup, operation, shutdown, and malfunction except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments. The CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over an hour. If the CEMS measures concentration on a wet basis, the CEM system shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the owner or operator may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load for each allowable fuel, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Final results of the CEMS shall be expressed as ppmvd corrected to 15% oxygen. The CEMS shall be used to demonstrate compliance with the CEMS emission standards for CO and NO_x as specified in this permit. For purposes of determining compliance with the CEMS emissions standards of this permit, missing (or excluded) data shall not be substituted. Upon request by the Department, the CEMS emission rates shall be corrected to ISO conditions to demonstrate compliance with the applicable standards of 40 CFR 60.332.
- b. *Valid Hour:* Hourly average values shall begin at the top of each hour. Each hourly average value shall be computed using at least one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. Notwithstanding this requirement, an hourly value shall be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour). If less than two such data points are available, the hourly average value is not valid. An hour in which any oil is fired is attributed towards compliance with the permit standards for oil firing. The permittee shall use all valid measurements or data points collected during an hour to calculate the hourly average values.
- c. *24-hour Block Averages:* A 24-hour block shall begin at midnight of each operating day and shall be calculated from 24 consecutive hourly average emission rate values. If a unit operates less than 24 hours during the block, the 24-hour block average shall be the average of all available valid hourly average emission rate values for the 24-hour block. For purposes of determining compliance with the 24-hour CEMS standards, the missing data substitution methodology of 40 CFR part 75, subpart D, shall not be utilized. Instead, the 24-hour block average shall be determined using the remaining hourly data in the 24-hour block. [Rule 62-212.400(BACT), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

{Permitting Note: There may be more than one 24-hour compliance demonstration required for CO and NO_x emissions depending on the use of alternate methods of operation}

- d. **Data Exclusion:** Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction, fuel switches and DLN tuning. Some of the CEMS emissions data recorded during these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of Condition Nos. 18 and 20 of this section. All periods of data excluded shall be consecutive for each such episode and only data obtained during the described episodes (startup, shutdown, malfunction, fuel switches, DLN tuning) may be used for the appropriate exclusion periods. The permittee shall minimize the duration of data excluded for such episodes to the extent practicable. Data recorded during such episodes shall not be excluded if the episode was caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented. Best operational practices shall be used to minimize hourly emissions that occur during such episodes. Emissions of any quantity or duration that occur entirely or in part from poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented, shall be prohibited.
- e. **Availability:** Monitor availability for the CEMS shall be 95% or greater in any calendar quarter. The quarterly excess emissions report shall be used to demonstrate monitor availability. In the event 95% availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving 95% availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department's Compliance Authority.

[NSPS Subparts Da and GG; Rule 62-297.520, F.A.C.; 40 CFR 60.7(a)(5) and 40 CFR 60.13; 40 CFR Part 51, Appendix P; 40 CFR 60, Appendix B; Performance Specifications; 40 CFR 60, Appendix F - Quality Assurance Procedures; and Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]

27. **Ammonia Monitoring Requirements:** In accordance with the manufacturer's specifications, the permittee shall install, calibrate, operate and maintain an ammonia flow meter to measure and record the ammonia injection rate to the SCR system prior to the initial compliance tests. The permittee shall document and periodically update the general range of ammonia flow rates required to meet permitted emissions levels over the range of load conditions allowed by this permit by comparing NO_x emissions recorded by the CEM system with ammonia flow rates recorded using the ammonia flow meter. During NO_x monitor downtimes or malfunctions, the permittee shall operate at the ammonia flow rate and, as applicable for fuel oil firing, the water-to-fuel ratio, that are consistent with the documented flow rate for the combustion turbine load condition. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]

RECORDS AND REPORTS

28. **Monitoring of Capacity:** The permittee shall monitor and record the operating rate of the gas turbine and HRSG duct burner system on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown, malfunction, and fuel switching). Such monitoring shall be made using a monitoring component of the CEM system required above, or by monitoring daily rates of consumption and heat content of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

29. **Monthly Operations Summary:** By the fifth calendar day of each month, the permittee shall record the following for each fuel in a written or electronic log for the gas turbine for the previous month of operation: fuel consumption, hours of operation, hours of duct firing, and the updated 12-month rolling totals for each. Information recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. The fuel consumption shall be monitored in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.]

30. **Fuel Sulfur Records:** The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.

a. Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be ASTM methods D4084-82, D4468-85, D5504-01, D6228-98 and D6667-01, D3246-81 or more recent versions.

16. | b. Compliance with the distillate fuel oil sulfur limit shall be demonstrated by taking a sample, analyzing the sample for fuel sulfur, and reporting the results to the Compliance Authority before initial startup. Sampling the fuel oil sulfur content shall be conducted in accordance with ASTM D4057-88, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, and one of the following test methods for sulfur in petroleum products: ASTM methods D5453-00, D129-91, D1552-90, D2622-94, or D4294-90. More recent versions of these methods may be used. For each subsequent fuel delivery, the permittee shall maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor. At the request of a Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content.

The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-4.160(15), F.A.C.]

31. **Emissions Performance Test Reports:** A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C. and in Appendix SC of this permit. [Rule 62-297.310(8), F.A.C.]

32. **Excess Emissions Reporting:**

a. **Malfunction Notification:** If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.

b. **SIP Quarterly Report:** Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of CO and NOx emissions in excess of the BACT permit standards following the NSPS format in 40 CFR 60.7(c), Subpart A. Periods of startup, shutdown and malfunction, shall be monitored, recorded and reported as excess emissions when emission levels exceed the standards specified in this permit. In addition, the report shall summarize the CEMS systems monitor availability for the previous quarter.

c. **NSPS Semi-Annual Reports:** For purposes of reporting emissions in excess of NSPS Subpart GG, excess emissions from the gas turbine are defined as: any operating hour in which the CEMS 4-hr

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. Unit 1 Combined Cycle Gas Turbine (EU 001)

rolling average NO_x concentration exceeds the NSPS NO_x emissions standard identified in Appendix GG; and any monitoring period during which the sulfur content of the fuel being fired in the gas turbine exceeds the NSPS standard identified in Appendix GG. For purposes of reporting emissions in excess of NSPS Subpart Da, excess emissions from duct firing are defined as: NO_x or PM emissions in excess of the NSPS standards except during periods of startup, shutdown, or malfunction; and SO₂ emissions in excess of the NSPS standards except during startup or shutdown. Within thirty (30) days following each calendar semi-annual period, the permittee shall submit a report on any periods of excess emissions that occurred during the previous semi-annual period to the Compliance Authority. This also includes reporting any periods of excess emissions as applicable and defined by NSPS Subpart KKKK when the rule is finalized.

{Note: If there are no periods of excess emissions as defined in NSPS Subparts GG, Da, or KKKK, a statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}

[Rules 62-4.130, 62-204.800, 62-210.700(6), F.A.C., and 40 CFR 60.7, and 60.332(j)(1)]

33. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating hours and emissions from this facility. The permittee shall also keep records sufficient to determine the annual throughput of distillate fuel oil for the fuel oil storage tank for use in the Annual Operating Report. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

C. Fuel Oil Storage Tank (EU 002)

ID	Emission Unit Description
002	One distillate fuel oil storage tank for Unit 1 combustion turbine (approximately 1 million gallons).

NSPS APPLICABILITY

1. **NSPS Subpart Kb Applicability:** Subpart Kb does not apply to storage vessels with a capacity greater than or equal to 151 cubic meters storing a liquid with a maximum true vapor pressure less than 3.5 kilopascals (kPa) or with a capacity greater than or equal to 75 cubic meters but less than 151 cubic meters storing a liquid with a maximum true vapor pressure less than 15.0 kPa. Tanks with a capacity greater than or equal to 40,000 gallons (151 cubic meters) storing a liquid with a maximum true vapor pressure less than 5.2 kPa and greater than 3.5 kPa, are exempt from the General Provisions (40 CFR 60, Subpart A) and from the provisions of NSPS Subpart Kb, except for the monitoring requirements. Tanks with a capacity greater than or equal to 40,000 gallons (151 cubic meters) storing a liquid with a maximum true vapor pressure less than 3.5 kPa, are exempt from the General Provisions (40 CFR 60, Subpart A) and from the provisions of NSPS Subpart Kb. The fuel oil storage tank (EU 002) has a capacity greater than 151 cubic meters and the vapor pressure of the ultra low sulfur fuel oil is less than 3.5 kPa, therefore NSPS Kb, including the monitoring requirements, does not apply to this unit. [40 CFR 60.110b(a) and (b), and 60.116b(c); Rule 62-204.800(7)(b), F.A.C.]

EQUIPMENT SPECIFICATIONS

2. **Equipment:** The permittee is authorized to install, operate, and maintain one 990,000 gallon distillate fuel oil storage tank designed to provide ultra low sulfur fuel oil to the Unit 1 gas turbine. [Applicant Request; Rule 62-210.200(PTE), F.A.C.]

PERFORMANCE REQUIREMENTS

3. **Hours of Operation:** The hours of operation are not restricted (8760 hours per year). [Applicant Request; Rule 62-210.200(PTE), F.A.C.]

NOTIFICATION, REPORTING, AND RECORDS

4. **Oil Tank Records:** The permittee shall keep readily accessible records showing the dimension of each storage vessel and an analysis showing the capacity of each storage tank. Records shall be retained for the life of the facility. The permittee shall also keep records sufficient to determine the annual throughput of distillate fuel oil for use in the Annual Operating Report. [Rule 62-204.800(7)(b)16, F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

C. Cooling Tower (EU 003)

This section of the permit addresses the following new emissions unit.

ID	Emission Unit Description
003	One 8-cell mechanical draft cooling tower.

EQUIPMENT

1. Cooling Tower: The permittee is authorized to install one 8-cell mechanical draft cooling tower with the following nominal design characteristics: a circulating water flow rate of 111,130 gpm; a design air flow rate of 1,000,000 acfm per cell; drift eliminators; a drift rate of no more than 0.0005 percent of the circulating water flow. [Application; Design]

EMISSIONS AND PERFORMANCE REQUIREMENTS

v7.

2. Drift Rate: Within 60 days of commencing ^{operation} ~~construction~~, the permittee shall certify that the cooling tower was constructed to achieve the specified drift rate of no more than 0.0005 percent of the circulating water flow rate. [Rule 62-212.400(BACT), F.A.C.]

(Permitting Note: This work practice standard is established as BACT₂ for PM/PM₁₀ emissions from the cooling tower. Based on this design criteria, potential emissions are expected to be less than 10 tons of PM per year and less than 2 tons of PM₁₀ per year. Actual emissions are expected to be lower than these rates.)

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

D. Safe Shutdown Generator (EU 004)

This section of the permit addresses the following emissions unit.

ID	Emission Unit Description
004	One safe shutdown generator (approximately 765 hp) with associated 1000 gallon fuel oil storage tank.

18,19

NESHAPS APPLICABILITY

NESHAPS Subpart ZZZZ Applicability: The facility is not a "Major Source" of hazardous air pollutants (HAPs); therefore the generator is not subject to Subpart ZZZZ.

EQUIPMENT SPECIFICATIONS

1. Safe Shutdown Generator: The permittee is authorized to install, operate, and maintain one safe shutdown generator. The safe shutdown generator may operate when the transmission connection is lost and the plant shuts down, and during occasional testing to ensure operability. The safe shutdown generator will fire ULS fuel oil. [Application; Design]

EMISSIONS AND PERFORMANCE REQUIREMENTS

2. Hours of Operation: The safe shutdown generator may operate 200 hours per year. [Applicant Request; Rule 62-210.200(PTE), F.A.C.]

{Permitting Note: Emissions from the safe shutdown generator are included in the potential to emit for the project.}

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

E. Diesel Fire Pump (EU 005)

This section of the permit addresses the following emissions unit.

ID	Emission Unit Description
005	One diesel engine fire pump (approximately 300 hp) with associated 500 gallon fuel oil storage tank.

NESHAPS APPLICABILITY

NESHAPS Subpart ZZZZ Applicability: The facility is not a "Major Source" of hazardous air pollutants (HAPs), therefore the generator is not subject to Subpart ZZZZ.

EQUIPMENT SPECIFICATIONS

1. Fire Pump: The permittee is authorized to install, operate, and maintain one diesel engine driven fire pump (approximately 300 hp) with associated 500 gallon fuel oil storage tank. The diesel engine fire pump will fire ULS fuel oil. [Application: Design]

EMISSIONS AND PERFORMANCE REQUIREMENTS

Hours of Operation: The fire pump may operate 200 hours per year.
[Applicant Request; Rule 62-210.200(PTE), F.A.C.]

{Permitting Note: The fire pump is considered emergency equipment, therefore exempt from permitting, however its emissions are included in the potential to emit for the project.}