

MAY 22 1980

REF: 4AH-AF

RECEIVED

MAY 27 1980

Office of the Secretary

Mr. Gus Schaefer
Florida Power Corporation
3201 Thirty-fourth Street South
P. O. Box 14042
St. Petersburg, FL 33733

Re: PSD-FL-014

Dear Mr. Schaefer:

This is in response to your April 16, 1980 letter requesting that PSD condition 3(b), for Florida Power Corporation's Suwannee River Peaking Units, be amended.

It has been determined by this Division that based upon the figures presented in your recent submittal, which will become an amendment to your application, condition 3(b) as stated in the Final Determination dated July 9, 1979 is hereby deleted and the following amendment should be inserted in its place to read:

The applicant shall record weekly, the sulfur content, nitrogen content, and lower heating value of the fuel being fired in the gas turbine.

This letter should be attached and made a part of your current PSD Conditions for Approval of Florida Power Corporation's proposed Suwannee River Peaking Units, and will become effective on the date of this letter.

If you have any questions concerning this matter, please contact Bill Wagner of my staff at 404/881-4552.


Sincerely yours,

151
Tommie A. Gibbs
Chief
Air Facilities Branch

cc: FL DER
TRW

UNITED STATES
ENVIRONMENTAL PROTECTION AGENCY
REGION IV
345 COURTLAND STREET
ATLANTA, GEORGIA 30308

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300



Mr. Steve Smallwood, Chief
Bureau of Air Quality Management
Florida Department of Environmental Regulation
Twin Towers Office Building
2600 Blairstone Road
Tallahassee, Florida 32301