

RECEIVED

NOV 12 2009

BUREAU OF ARR REGULATION

November 10, 2009

Trina Vielhauer, Chief Bureau of Air Regulation FDEP Division of Air Resources 2600 Blair Stone Road, MS #5505 Tallahassee, Florida 32399-2400

RE:

FPL Sanford Power Plant - Title V Air Operating Permit 1270009-020-AX

Project No: 1270009-021-AC

Combustion Turbine 4C

Excess Emissions Request for Rotor/Blade Change-out

Dear Ms. Vielhauer:

Florida Power & Light is requesting an extended excess emissions period for the Sanford Plant Unit 4C combustion turbine following an anticipated rotor/blade change out during a currently scheduled outage. In accordance with manufacturer's specifications, it has been identified that a Full Speed No Load (FSNL) operation and extended tuning period is necessary should the rotor/blade change out be necessary. The extended start-up period is scheduled to occur during the period of December 07, 2009 through December 23, 2009. The Department granted a similar request following the replacement of the Unit 4D rotor/blade change out in October 2009.

If you have any questions or require additional information, please contact me at (386) 575-5211 or Randy Hopkins at (386) 575-5385.

Sincerely,

Gary Køwalczyk

Plant General Manager

FPL Sanford Plant

Attachment

Cc:

Ms. Caroline Shine, Program Administrator

Air Resource Management FDEP Central Florida District 3313 Maguire Blvd., Suite 232 Orlando, Florida 32803-3767

Ms. Mary Archer – FPL/JES FPL Sanford Plant File