



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET, N.E.
ATLANTA, GEORGIA 30365

4APT-AEB

NOV 18 1991

RECEIVED

NOV 21 1991

Division of Air
Resources Management

Mr. Clair H. Fancy, P.E., Chief
Bureau of Air Regulation
Florida Department of Environmental
Regulation
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400


RE: Florida Power Corporation/DeBary Plant (PSD-FL-167)

Dear Mr. Fancy:

This is to acknowledge receipt of your final determination and Prevention of Significant Deterioration (PSD) permit for the above referenced facility's proposed construction, by your letter dated October 18, 1991. The facility will consist of six simple-cycle combustion peaking units, each rated 92.9 MW, fired with No. 2 distillate fuel oil. Your determination proposes to limit NO_x emissions through wet injection, to limit SO₂ and H₂SO₄ mist emissions through limiting the sulfur content of the fuel oil, to limit PM and PM₁₀ through combustion design and the use of clean fuel, to limit CO through combustion design, and to limit Hg, Be, and As emissions through the specifications on No. 2 distillate fuel oil.

We have reviewed the package as submitted and have no adverse comments. Thank you for the opportunity to review and comment on this package. If you have any questions or comments, please contact Mr. Scott Davis of my staff at (404) 347-5014.

Sincerely yours,


Jewell A. Harper, Chief
Air Enforcement Branch
Air, Pesticides, and Toxics
Management Division

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY -- REGION IV
 AIR, PESTICIDES & TOXICS MANAGEMENT DIVISION
 345 Courtland Street, N. E.
 Atlanta, Georgia 30365
 Fax Number: FTS 257-5207 or 404/347-5207

FACSIMILE TRANSMISSION SHEET

DATE: NOV 18 1991 NUMBER OF PAGES (including this sheet) 2
 (Preparer must number all pages)

TO: Clay H. Jones PHONE: 904-488-1344

ADDRESS: FDEE FAX NUMBER: 904-922-6979

FROM: Jessie A. Hooper PHONE: 404-347-2404

If the following pages are received poorly, please call Ed Davis
 at FTS 257-5014 or 404/347-5014.

SPECIAL INSTRUCTIONS FOR RECEIVER: _____

