



United States Department of the Interior  
FISH AND WILDLIFE SERVICE



IN REPLY REFER TO:

MAILING ADDRESS:  
Post Office Box 25486  
Denver Federal Center  
Denver, Colorado 80225

STREET LOCATION:  
134 Union Blvd.  
Lakewood, Colorado 80228

RW Air Quality  
Mail Stop 60130

RECEIVED  
OCT 2 1989  
29 SEP 1989  
DER-BAQM

Mr. C.H. Fancy, P.E., Deputy Chief  
Bureau of Air Quality Management  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Dear Mr. Fancy:

We have reviewed the information you forwarded to us regarding Orlando Utilities Commission's request to increase the permitted particulate matter rate for the new gas turbines at their Indian River plant. The Indian River plant is located approximately 175 km east of Chassahowitzka National Wildlife Refuge (NWR), a class I area administered by the U.S. Fish and Wildlife Service. We appreciate your continued cooperation in notifying us of projects that have the potential to impact the air quality or air quality related values of our class I lands.

Results of initial performance tests indicate that particulate matter emissions from turbine CT-A ranged from 12.65 to 19.4 lb/hr (average of 15.3 lb/hr) and particulate matter emissions from turbine CT-B ranged from 17.83 to 24.93 lb/hr (average of 21.9 lb/hr) when burning oil. Based on the performance tests results, Orlando Utilities requests that you increase the permitted limit for the turbines from the current 10 lb/hr rate to 30 lb/hr.

Considering the relatively long distance from the Indian River plant to the Chassahowitzka NWR, we do not expect that the proposed increase in particulate matter emissions would significantly impact resources at the refuge. However, in order to minimize local impacts from the turbine emissions we offer the following comments for your consideration. First, since particulate matter, nitrogen oxides, and sulfur dioxide emissions from the turbines would be much less when burning gas as compared to oil, and the turbines are capable of burning both gas and oil, we recommend that you encourage Orlando Utilities to fire the turbines with gas rather than oil. Also, because turbines CT-A & B are identical, we would expect that the emissions from the turbines would be similar. However, during the performance tests the particulate matter emissions from turbine CT-B averaged over 43% higher than those from turbine CT-A. Unless Orlando Utilities can explain the discrepancy in the test results, and provide



further justification for the proposed 30 lb/hr emission rate, we recommend that the revised particulate matter rate be closer to the test results for turbine CT-A (i.e., 15-16 lb/hr).

If you have any questions regarding this matter, please contact John Bunyak of our Air Quality Office at (303) 969-2071.

Sincerely,



Ralph F. Fries  
Acting Assistant Regional Director  
Refuges and Wildlife, Region 6

*copied:* P. Kaval  
B. Andrews  
D. Rogers  
C. Collins, c Dist.  
CHF/BT



ORLANDO UTILITIES COMMISSION

500 SOUTH ORANGE AVENUE • P. O. BOX 3193 • ORLANDO, FLORIDA 32802 • 407/423-9100

September 18, 1989

Mr. Pradeep Raval  
Bureau of Air Quality Management  
Florida Department of  
Environmental Regulation  
2600 Blainstone Road  
Tallahassee, FL 32399-2400

RECEIVED

SEP 19 1989

DER-BAQM

Re: PSD-FL-130 Modification to Permit

Dear Mr. Raval:

Per your request, I had Black & Veatch develop correction factors to be applied to compensate for the location of the ports. Attached is this estimate as supplied to me by Black & Veatch in their letter of September 14, 1989.

If the Department concurs with this estimate and uses it to establish maximum emissions per unit, I request that the calculation be made a part of the permit.

We appreciate your cooperation and understanding in this matter. If you have any questions, please call me at 407/423-9141, Steve Day (B&V) at 913/339-2880 or Al Ferguson (B&V) at 913/339-2199.

Sincerely,

J. S. Crall  
Director  
Environmental Division

JSC/cs  
Attachment

xc: S. M. Day (B&V)

*cc: Patrick Anderson  
Mack  
Nancy Anderson, EPA  
Steve Shaw, DOE  
Chuck Collins & Bill  
ET  
Jim Pennington*



USE THIS AIRBILL FOR DOMESTIC SHIPMENTS WITHIN THE CONTINENTAL U.S.A., ALASKA AND HAWAII.  
USE THE INTERNATIONAL AIRWAYBILL FOR SHIPMENTS TO PUERTO RICO.  
QUESTIONS? CALL 800-230-5355/TOLL FREE.

AIRBILL  
PACKAGE  
TRACKING NUMBER

4379864134

9214M

4379864134

RECIPIENT'S COPY

From (Your Name) Please Print <b>IR FORWARDING SYSTEMS</b>		Your Phone Number (Very Important) <b>(407) 859-1802</b>		To (Recipient's Name) Please Print <b>Priscilla Raus</b>		Recipient's Phone Number (Very Important) <b>(904) 455-154</b>			
Company <b>IR FORWARDING SYSTEMS</b>		Department/Floor No. <b>FL Dept. of Environmental Reg.</b>		Company <b>FL Dept. of Environmental Reg.</b>		Department/Floor No. <b>3600 Blystone Rd</b>			
Street Address <b>317 EAST LAND STREET RD</b>		Exact Street Address (We Cannot Deliver to P.O. Boxes or P.O. Zip Codes) <b>3600 Blystone Rd</b>		City <b>Tallahassee</b>		State <b>FL</b>			
City <b>ORLANDO</b>		State <b>FL</b>		ZIP Required <b>32824</b>		ZIP Required <b>32399</b>			
YOUR BILLING REFERENCE INFORMATION (First 24 characters will appear on invoice) <b>INC 20217</b>				IF HOLD FOR PICK-UP, Print FEDEX Address Here Street Address City State ZIP Required					
PAYMENT <input checked="" type="checkbox"/> Bill Sender <input type="checkbox"/> Bill Recipient's FedEx Acct. No. <input type="checkbox"/> Bill 3rd Party FedEx Acct. No. <input type="checkbox"/> Bill Credit Card <input type="checkbox"/> Cash									
<b>SERVICES</b> (Check only one box)		<b>DELIVERY AND SPECIAL HANDLING</b>		<b>PACKAGES</b>		<b>WEIGHT</b> In Pounds Only			
Priority Overnight Service (Delivery by next business morning) <input type="checkbox"/> YOUR PACKAGING 51 <input type="checkbox"/> FEDEX LETTER * 56 <input type="checkbox"/> FEDEX PAK * 52 <input type="checkbox"/> FEDEX BOX 53 <input type="checkbox"/> FEDEX TUBE 54 Standard Overnight Service (Delivery by next business afternoon) <input checked="" type="checkbox"/> FEDEX LETTER * 56 <input type="checkbox"/> FEDEX PAK * 52 <input type="checkbox"/> FEDEX BOX 53 <input type="checkbox"/> FEDEX TUBE 54 Economy Service (formerly Standard Air) (Delivery by second business day†) <input type="checkbox"/> ECONOMY SERVICE 30 Heavyweight Service (for Extra Large or any package over 150 lbs.) <input type="checkbox"/> HEAVYWEIGHT ** 70 <input type="checkbox"/> DEFERRED HEAVYWEIGHT ** 80		1 <input type="checkbox"/> HOLD FOR PICK-UP (if in box #1) 2 <input checked="" type="checkbox"/> DELIVER WEEKDAY 3 <input type="checkbox"/> DELIVER SATURDAY (Extra charge) 4 <input type="checkbox"/> DANGEROUS GOODS (Extra charge) 5 <input type="checkbox"/> CONSTANT SURVEILLANCE SVC. (CSS) (Extra charge) (Release Signature Not Applicable) 6 <input type="checkbox"/> DRY ICE Lbs. 7 <input type="checkbox"/> OTHER SPECIAL SERVICE 8 <input type="checkbox"/> DIM SHIPMENT (Heavyweight Services Only) 9 <input type="checkbox"/> SATURDAY PICK-UP (Extra charge) 10 <input type="checkbox"/> 11 <input type="checkbox"/> 12 <input type="checkbox"/> HOLIDAY DELIVERY (Extra charge)		Total Total Total DIM SHIPMENT (Heavyweight Services Only) <input type="checkbox"/> lbs. Received At: <input type="checkbox"/> Regular Stop <input type="checkbox"/> On-Call Stop <input checked="" type="checkbox"/> Drop Box <input type="checkbox"/> B & C Station		Emp. No. Date <input type="checkbox"/> Cash Received <input type="checkbox"/> Return Shipment <input type="checkbox"/> Third Party <input type="checkbox"/> Chg. To Del <input type="checkbox"/> Chg. To Hold Street Address City State Zip Received By <input checked="" type="checkbox"/> Date/Time Received FedEx Employee Number Release Signature Date/Time		Federal Express Use Base Charges Declared Value Charge Other 1 Other 2 Total Charges REVISION DATE 8/89 PART #119501 FXE M 7/89 FORMAT #014 <b>014</b> © 1989 F.E.C. PRINTED IN U.S.A.	

**BLACK & VEATCH**

ENGINEERS-ARCHITECTS

TEL. (913) 339-2000

1500 MEADOW LAKE PARKWAY  
MAILING ADDRESS P.O. BOX NO. 8405  
KANSAS CITY, MISSOURI 64114**RECEIVED**Orlando Utilities Commission  
Indian River Plant, CT Project  
TSP Measurements

SEP 18 89

B&V Project 14137  
B&V File 32.0404  
September 14, 1989**OUC-ENVD**Orlando Utilities Commission  
500 South Orange Avenue  
Orlando, Florida 32802Attention: Mr. James S. Crall  
Director, Environmental Division

Gentlemen:

The measurement of particulate emissions from Combustion Turbine Units A and B were conducted in an expanding section of the duct. This location is immediately adjacent to turns and bends in the flue gas duct and does not meet the requirement for proper stack sampling. GE located the sampling ports there because no duct or stack locations were available which met the criteria for sampling. To achieve a proper sampling port location within the existing duct, the silencer would have had to be removed to perform the sampling.

The test measurements include a measurement of the gas flow rate. However the measured gas flow rate is much higher than the gas flow rate that Black & Veatch has calculated to have occurred during the test using the F-factor method. We believe that the F-factor method for estimating the gas flow rate is more accurate than the value obtained during the measurement due to the location of the sampling ports. In view of this, the application of a correction factor to the measured data is appropriate.

The high measurement of gas flow rate indicates turbulent gas flow in the duct at the point of measurement. The concentration of large particles of particulate matter will vary across a flue gas duct in an environment of turbulent gas flow making estimates of the appropriate correction factor difficult. However very small particles of particulate will retain a uniform concentration in a turbulent flow acting much the same as the gas itself. Since the particulate emissions in a combustion turbine are mostly fine particles, the correction factor can be approximated as the ratio of the actual (calculated) flue gas flow rate to the measured flue gas flow rate.

The enclosed calculations provide the estimated correction factors to be applied to the measured particulate emission rates. With these correction factors applied, the estimated average particulate emission rate from Unit A becomes 9.6 pounds per hour and for Unit B it becomes 15.4 pounds per hour.

BLACK & VEATCH

Orlando Utilities Commission  
Mr. James S. Crall,

2

B&V Project 14137  
September 14, 1989

If you have any questions regarding these estimates of correction factors,  
please call me at 913-339-2880 or Al Ferguson at 913-339-2199.

Very truly yours,

BLACK & VEATCH

  
Steven M. Day

Enclosure



Owner Ocala Utilities  
 Plant Indian River Unit CTA-CTB  
 Project No. 12125 File No. \_\_\_\_\_  
 Title Estimate Particulate Emissions



AW Ferguson  
 Date 9/12 1989  
 Checked By \_\_\_\_\_  
 Date \_\_\_\_\_ 19\_\_\_\_  
 Page 1 of 4

DO NOT WRITE IN THIS SPACE

Purpose: The purpose of these calculations is to estimate the particulate emissions from CTA and CTB using the measured data from the emissions tests. The test ports were in a very turbulent area which resulted in measurement of gas flow which was higher than should exist at that point.  
 Ref. TSA Test Report CTA and CTB

Measured gas flow during particulate runs

- CTA
- Run 1 7/26/89 - 854,407 acfm - 295,450 dscfm
  - Run 2 7/27/89 - 853,157 acfm - 295,743 dscfm
  - Run 3 7/27/89 - 857,662 acfm - 283,445 dscfm

RECEIVED  
 SEP 15 89  
 OUC-ENVD

Calculate gas flow using "F" factors

"F" factor for fuel oil =  $F_d = 9190$  dscf/MBtu  
 $F_w = 10320$  scf/MBtu  
 $F_c = 1420$  scf/MBtu

Fuel oil flow rate					Btu/lb	
Run 1	7/26/89	17:30 - 18:57	pm	6.05	lb/sec	19,533
Run 2	7/27/89	07:05 - 08:21	am	6.26	lb/sec	19,533
Run 3	7/27/89	08:43 - 10:02	am	6.13	lb/sec	19,533

RGN-172A





Flue Gas Flow Rate CTA

Adjustment for  
excess air from  
"F" factor

$$\text{Run 1} - \frac{9190 \text{ dsct}}{\text{MBtu}} \times \frac{0.019533 \text{ MBtu}}{\text{lb fuel}} \times \frac{6.05 \text{ lb fuel}}{\text{sec}} \times \frac{60 \text{ sec}}{\text{min}} \times \frac{20.9}{(20.9 - 13.5)}$$

= 184,037 dsctfm

$$\text{Run 2} - \frac{9190 \text{ dsct}}{\text{MBtu}} \times \frac{0.019533 \text{ MBtu}}{\text{lb fuel}} \times \frac{6.26 \text{ lb fuel}}{\text{sec}} \times \frac{60 \text{ sec}}{\text{min}} \times \frac{20.9}{(20.9 - 13.5)}$$

= 189,147 dsctfm

$$\text{Run 3} - \frac{9190 \text{ dsct}}{\text{MBtu}} \times \frac{0.019533 \text{ MBtu}}{\text{lb fuel}} \times \frac{6.13 \text{ lb fuel}}{\text{sec}} \times \frac{60 \text{ sec}}{\text{min}} \times \frac{20.9}{(20.9 - 13.6)}$$

= 189,025 dsctfm

Particulate Emissions

The measured flow rate is higher than the calculated flow rate as would be expected for flow not perpendicular to the pitot tube. This also means that the measured concentration is equal to or higher than actual because of super-isokinetic sampling. This is because the expected particle size distribution is low for this source. That is all the particles are expected to be small, these small particles will follow the gas streamlines and be relatively evenly distributed across the combustion turbine duct. Sampling above isokinetic as was done at this location would result in an abnormally high weight of these particles being trapped on the filter and weighed. This would not be true if all the particles were large. In that instance the particles would cross the streamlines. If we assume that the measured particulate concentration is correct we will either estimate emissions which are too high or correct. This is the approach which will be used.

DO NOT WRITE IN THIS SPACE

RGN-172A



Owner Orlando Utilities

Plant Indian River

Unit CTA-CTB

Computed By A.W. Ferguson

Date 9/12 19 89

Project No. 12105

File No. \_\_\_\_\_

Checked By \_\_\_\_\_

Title Estimate Particulate Emissions

Date \_\_\_\_\_ 19 \_\_\_\_\_

Page 3 of 4

CTA Estimated Emissions

Run 1

Concentration from TSA report

$$184,037 \frac{\text{dscf}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{2.13 \times 10^{-7} \text{ lb}}{\text{dscf}} = 2.87 \text{ lb/hr}$$

Run 2

$$189,147 \frac{\text{dscf}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{1.09 \times 10^{-6} \text{ lb}}{\text{dscf}} = 12.4 \text{ lb/hr}$$

Run 3

$$189,025 \frac{\text{dscf}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{8.21 \times 10^{-7} \text{ lb}}{\text{dscf}} = 9.31 \text{ lb/hr}$$

Avg. 9.86 lb/hr

CTB Estimated Emissions

Fuel Oil Flow Rate CTB

Run	Date	Time	O <sub>2</sub>	Part W/dscf	Fuel Oil Flow
Run 4	7/28/89	09:25 - 10:42	13.5	$1.25 \times 10^{-6}$	6.32 lb/sec
Run 5	7/28/89	11:00 - 12:16	14.5	$1.00 \times 10^{-6}$	6.22 lb/sec
Run 6	7/28/89	12:30 - 13:44	14.5	$1.14 \times 10^{-6}$	6.15 lb/sec

Flue Gas Flow Rate CTB

$$\text{Run 4 } 9190 \frac{\text{dscf}}{\text{MBtu}} \times 0.019537 \frac{\text{MBtu}}{\text{lb fuel}} \times \frac{6.32 \text{ lb fuel}}{\text{sec}} \times \frac{60 \text{ sec}}{\text{min}} \times \frac{20.9}{(20.9-13.5)} = 192,290 \text{ dscf/min}$$

$$\text{Run 5 } 9190 \frac{\text{dscf}}{\text{MBtu}} \times 0.019537 \frac{\text{MBtu}}{\text{lb fuel}} \times \frac{6.22 \text{ lb fuel}}{\text{sec}} \times \frac{60 \text{ sec}}{\text{min}} \times \frac{20.9}{(20.9-14.5)} = 218,817 \text{ dscf/min}$$

$$\text{Run 6 } 9190 \frac{\text{dscf}}{\text{MBtu}} \times 0.019537 \frac{\text{MBtu}}{\text{lb fuel}} \times \frac{6.15 \text{ lb fuel}}{\text{sec}} \times \frac{60 \text{ sec}}{\text{min}} \times \frac{20.9}{(20.9-14.5)} = 216,354 \text{ dscf/min}$$

DO NOT WRITE IN THIS SPACE

DO NOT WRITE IN THIS SPACE

PGN-172A



CTB Estimated Emissions

$$\text{Run 4} \quad 192,290 \frac{\text{dscf}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times 1.25 \times 10^{-6} \frac{\text{lb}}{\text{dscf}} = 14.4 \text{ lb/hr}$$

$$\text{Run 5} \quad 218,817 \frac{\text{dscf}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times 1.00 \times 10^{-6} \frac{\text{lb}}{\text{dscf}} = 13.1 \text{ lb/hr}$$

$$\text{Run 6} \quad 216,354 \frac{\text{dscf}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times 1.44 \times 10^{-6} \frac{\text{lb}}{\text{dscf}} = 18.7 \text{ lb/hr}$$

$$\text{Avg} \quad 15.4 \text{ lb/hr}$$

This correction should be repeated for any future particulate sampling which occurs at this site. The following values should be determined for the new tests.

Fuel Flow Rate - lb/sec

Heat Value of the Fuel - Btu/lb

Particulate concentration - lb/dscf

O<sub>2</sub> at sample site - %

With these new values ~~and~~ the other values, the equations shown above can be used for future particulate emission estimates.

DO NOT WRITE IN THIS SPACE

RGN-172A