

Department of Environmental Protection

Jeb Bush Governor Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 32399-2400

David B. Struhs Secretary

NOTICE OF FINAL PERMIT

In the Matter of an Application for Permit by:

Ms. Denise M. Scarlett Director of Environmental Affairs Orlando Utilities Commission 500 South Orange Avenue P.O. Box 3193 Orlando, Florida 32802 FINAL Permit No.: 0090008-001-AV

Indian River Plant

Enclosed is FINAL Permit Number 0090008-001-AV for the operation of the Indian River Plant located at US 1 & Kings Highway, Brevard County, issued pursuant to Chapter 403, Florida Statutes (F.S.).

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the permitting authority in the Legal Office; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the permitting authority.

Executed in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

C. H. Fancy, I

Chief

Bureau of Air Regulation

FINAL Permit No.: 0090008-001-AV

12/2/99 cc - Cindy Phillips Reading File

Page 2 of 2

CERTIFICATE OF SERVICE

Bob Hicks
Fred F. Haddad, Jr.
Len Kozlov, FDEP Central District Office
Ms. Elizabeth Bartlett, USEPA, Region 4 (INTERNET E-mail Memorandum)

Clerk.Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is

hereby acknowledged.

Clerk)

(Date)

US Postal Service
Receipt for Certified Mail
No Insurance Coverage Provided.
Do not use for International Mail (See reverse)
Sent to
Yels. Denise M. Scarlett
Street & Number
500 South Orange Avenue
Post Office State, & ZIP Code
Or Lando, Florida 32802
Postage

Special Delivery Fee

Special Delivery Fee

Restricted Delivery Fee
Return Receipt Showing to
Whom & Date Delivered
Return Receipt Showing to
That Postage & Fees
Final Permit No.:0090008-00120
OUC - Indian River Plant

n the reverse side?	SENDER: Complete items 1 and/or 2 for additional services. Complete items 3, 4a, and 4b. Print your name and address on the reverse of this form so that we card to you. Attach this form to the front of the mailpiece, or on the back if space permit. Write "Return Receipt Requested" on the mailpiece below the article arther Return Receipt will show to whom the article was delivered and delivered.	I also wish to receive the following services (for an extra fee): 1. Addressee's Address 2. Restricted Delivery Consult postmaster for fee.		sipt Service.	
ADDRESS completed on	Article Addressed to: MS. Denise M. Scarlett Director of Environmental Affairs Orlando Utilities Commission 500 South Orange Avenue P.O. Box 3193 Orlando, Florida 32802	4a. Article N Z 094 4b. Service ☐ Register ☐ Express ☐ Return Rec 7. Date of D	XX Certified Insured COD	u for using Return Rece	
is your net unit	5. Received By: (Print Name) 6. Signature: (Addressed or Agent) X PS Forth 3811, December 1994	8. Addresse and fee is	e's Address (Only paid)	<u> </u>	Thank yo

Florida Department of **Environmental Protection**

BAR RECEIVED

NOV 3 0 1999

TO:

Howard Rhodes

BUREAU OF AIR REGULATION

THROUGH: Clair Fancy

THROUGH: Scott Sheplak

FROM:

Cindy Phillips C

DATE:

November 10, 1999

SUBJECT:

FINAL Permit No. 0090008-001-AV

Orlando Utilities Commission

Indian River Plant

The Indian River Plant consists of three boilers, four combustion turbines, and a lime storage silo.

Although EPA objections/comments were received on the PROPOSED permit, all questions and issues have been resolved. Therefore, I recommend your signature.

Attachment

STATEMENT OF BASIS

Orlando Utilities Commission Indian River Plant Facility ID No.: 0090008 Brevard County

Initial Title V Air Operation Permit Permit No.: 0090008-001-AV

This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility described in the application, approved drawings, plans, and other documents attached hereto or on file with the Department, in accordance with the terms and conditions of this permit.

This facility consists of three boilers, four combustion turbines, and a lime storage silo.

Emissions units -001, -002, and -003 consist of three Combustion Engineering Steam Generators. The boilers may burn a variable combination of natural gas, propane, No. 6 and No. 2 fuel oils, and on-specification used oil from Orlando Utilities Commission (OUC) operations. Emissions units -001 and -002 share a common stack, with a height of 300 feet. Emissions unit -003 has a separate 300 foot stack. Unit -001 began operation February 1, 1960; Unit -002 September 1, 1964, and Unit -003 February 1, 1974.

The Department has determined that the appropriate particulate matter testing frequency for the fossil fuel steam generators is annually whenever fuel oil is used for more than 400 hours in the preceding year. This frequency is justified because the units 001, 002, and 003 are uncontrolled and have documented low emissions in previous emissions tests while firing fuel oil. The applicant has presented historical PM test results which show that the steady-state and soot blowing average results are well below the applicable standards of 0.1 lb/mmBtu and 0.3 lb/mmBtu, respectively. The five-year average test results for 1994-1998 for these units are as follows:

W
TU)
.080
.131
.103

Emissions units -004 and -007 (Turbines A and B) consist of simple cycle GE Frame 6 combustion turbines, each with a 35 MW rating. Although the turbines will primarily fire natural gas, distillate oil may be fired during periods of curtailed or uneconomical natural gas supply. Nitrogen oxide emissions are reduced by using water injection. Both turbines began commercial operation August 1, 1990.

Emissions units -005 and -006 (Turbines C and D) consist of simple cycle Westinghouse Model Number 501-D5 combustion turbines, each with a 129 MW rating. The turbines will primarily fire natural gas. Distillate oil will be fired during periods of curtailed or uneconomical natural gas supply. Nitrogen oxide emissions will be controlled by water injection. Both turbines began commercial operation November 1, 1991.

Emissions unit -008 is a lime storage silo filling system. The silo is equipped with a fabric filter baghouse made by General Resource Corporation, Model 13204.8. The baghouse is approximately 99 percent efficient to control particulate emissions. This source is located at the water treatment building. The silo began operation February 25, 1993.

Also included in this permit are miscellaneous unregulated and exempt emissions units and activities. Based on the initial Title V permit application received June 12, 1996, this facility is a major source of hazardous air pollutants (HAPs).



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET

ATLANTA, GEORGIA 30303-8960

NOV 3 1999

NOV 00 1999

DIVISION OF AIR RESOURCES MANAGEMEN

4APT-ARB

Howard L. Rhodes, Director Department of Environmental Protection Division of Air Resources Management Division Mail Station 5500 2600 Blair Stone Road Tallahassee, Florida 32399-2400

SUBJ: Proposed Title V Permit for Orlando Utilities Commission - Indian River Plant Permit Number 0090008-001-AV

Dear Mr. Rhodes:

cc:

The purpose of this letter is to acknowledge the receipt of the State of Florida's proposed changes to the Orlando Utilities Commission - Indian River Plant proposed title V permit, dated October 28, 1999, which was the subject of a U.S. Environmental Protection Agency (EPA) title V objection on August 5, 1999. EPA Region 4 has completed its review of the proposed changes to the permit and believes that the State has adequately addressed each of the issues enumerated in the objection. Therefore, EPA considers the objection to be resolved. Once the State's proposed changes are incorporated into the permit, the State may proceed with permit issuance.

We commend the efforts of your staff for facilitating the resolution of the permit issues. If you have any questions about this letter, please contact Mr. Gregg Worley, Chief, Operating Source Section at (404) 562-9141.

Sincerely,

Winston A. Smith

Director

Air, Pesticides and Toxics Management Division

Mr. Robert F. Hicks, Orlando Utilities Commission

Orlando Utilities Commission Indian River Plant Facility ID No. 0090008 Brevard County

Initial Title V Air Operation Permit **FINAL Permit No.** 0090008-001-AV

Permitting Authority:
State of Florida
Department of Environmental Protection
Division of Air Resources Management

Bureau of Air Resources Manageme Bureau of Air Regulation Title V Section

Mail Station #5505 2600 Blair Stone Road Tallahassee, Florida 32399-2400 Telephone: 850/488-0114

Fax: 850/922-6979

Compliance Authority:

Department of Environmental Protection Central District Office 3319 Maguire Boulevard, Suite 232 Orlando, Florida 32803-3767

Telephone: 407/894-7555 Fax: 407/897-2996

Initial Title V Air Operation Permit **FINAL Permit No.** 0090008-001-AV

TABLE OF CONTENTS

Section	Page
Placard Page	1
I. Facility Information	2
A. Facility Description	2
B. Summary of Emissions Unit ID Nos. and Brief Description	
C. Relevant Documents	2
II. Facility-wide Conditions	3
III. Emissions Unit Conditions	5
A. Fossil Fuel Steam Boilers	5
B. Combustion Turbines A & B	14
C. Combustion Turbines C & D	
D. Common Conditions I (Combustion Turbines)	20
E. Common Conditions II (Boilers and Combustion Turbines)	33
F. Lime Storage Silo	36
IV. Acid Rain Part, Phase II	39



Department of Environmental Protection

Jeb Bush Governor Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 32399-2400

David B. Struhs Secretary

Permittee:

Orlando Utilities Commission 500 South Orange Avenue P.O. Box 3193 Orlando, Florida 32802 FINAL Permit No. 0090008-001-AV SIC Nos. 49, 4911 Project: Initial Title V. Air Operation P.

Project: Initial Title V Air Operation Permit

This permit is for the operation of the Indian River Plant. This facility is located at US 1 & Kings Highway, Titusville, Brevard County, 32780; UTM Coordinates: Zone 17, 521.5 km East and 3151.6 km North; Latitude: 28° 29' 32" North and Longitude: 80° 46' 59" West.

STATEMENT OF BASIS: This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.) and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named Permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawings, plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

Appendix U-1, List of Unregulated Emissions Units and Activities

Appendix I-1, List of Insignificant Emissions Units and Activities

APPENDIX TV-3, TITLE V CONDITIONS (version dated 4/30/99)

APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)

TABLE 297.310-1, CALIBRATION SCHEDULE (version dated 10/07/96)

Figure 1 - SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND

MONITORING SYSTEM REPORT (version dated 7/96)

Phase II Acid Rain Permit Application dated 12/15/95

Alternate Sampling Procedures: ASP Number 97-B-01 and ASP 92-0-01

Attachment A: Operating Curve for Combustion Turbines A and B

Attachment B: Westinghouse Electric Corp. letter dated 04/11/95 Re: Heat Input Curve for

OUC Indian River, Units C and D, Base Load Operation.

Effective Date: January 1, 2000

Renewal Application Due Date: July 5, 2004

Expiration Date: December 31, 2004

Howard L. Rhodes, Director

Division of Air Resources

Management

HLR/clp

Section I. Facility Information

Subsection A. Facility Description

This facility consists of three boilers, four combustion turbines, and a lime storage silo. Also included in this permit are miscellaneous unregulated and insignificant emissions units and activities. {Permitting Note: PSD-FL-130 was initially issued for all four combustion turbines. PSD-FL-173 was subsequently issued for combustion turbines C and D.}

Based on the initial Title V permit application received June 17, 1996, this facility is a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID Nos. and Brief Descriptions

<u>E.U. ID</u>	
No. Brief Description	
001	87 MW Unit No.1 Boiler (EPA ID # 1)
002	188 MW Unit No.2 Boiler (EPA ID # 2)
003	328 MW Unit No.3 Boiler (EPA ID # 3)
004	35 MW Simple Cycle Combustion Turbine A
005	129 MW Simple Cycle Combustion Turbine C (EPA ID # C)
006	129 MW Simple Cycle Combustion Turbine D (EPA ID # D)
007	35 MW Simple Cycle Combustion Turbine B
800	Lime Storage Silo
009	Unregulated Emissions Units and Activities.

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit ID Nos. on all test report submittals, applications, and other correspondence.

Subsection C. Relevant Documents

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action.

These documents are provided to the Permittee for information purposes only:

Table 1-1, Summary of Air Pollutant Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

Appendix H-1, Permit History/ID Number Transfers

These documents are on file with the permitting authority:

Initial Title V Permit Application received June 17, 1996

Orlando Utilities Commission Indian River Plant Page 3 of 40

Section II. Facility-wide Conditions The following conditions apply facility-wide:

- 1. APPENDIX TV-3, TITLE V CONDITIONS (version dated 04/30/99), is a part of this permit. {Permitting note: APPENDIX TV-3, TITLE V CONDITIONS, is distributed to the Permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}
- 2. Not Federally Enforceable. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.

 [Rule 62-296.320(2), F.A.C.]
- 3. General Particulate Emission Limiting Standards. General Visible Emissions Standard.

Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. [Rule 62-296.320(4)(b)1. & 4., F.A.C.]

<u>{Permitting Note:</u> Although the Permittee is <u>not</u> required to perform a visible emissions compliance test to demonstrate compliance with the facility-wide limitations annually or before renewal, if the Department believes that the general visible emissions standard is being violated, the Department may require that the owner or operator perform a visible emissions compliance test per Chapter 62-297.310(7)(b), Special Compliance Tests. In addition, Department personnel who are certified to perform visible emissions tests may determine compliance with the general visible emissions standard.}

- 4. Prevention of Accidental Releases (Section 112(r) of CAA).
- a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable; and
- **b.** The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C. [40 CFR 68]
- 5. <u>Unregulated Emissions Units and Activities.</u> Appendix U-1, List of Unregulated Emissions Units and Activities, is a part of this permit. [Rule 62-213.440(1), F.A.C.]
- 6. <u>Insignificant Emissions Units and Activities.</u> Appendix I-1, List of Insignificant Emissions Units and Activities, is a part of this permit. [Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]
- 7. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or

Orlando Utilities Commission Indian River Plant Page 4 of 40

organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. [Rule 62-296.320(1)(a), F.A.C.]

- **8.** When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one. [Rule 62-213.440. F.A.C.]
- 9. Not federally enforceable. The Permittee shall take reasonable precautions to prevent emissions of unconfined particulate matter at this facility. These precautions include receiving delivery of fuel oil by barge rather than trucks, and using paved roads for the fuel trucks which deliver vehicle fuel. Additionally, watering will be used as needed to prevent emissions from unpaved areas. [Rule 62-296.320(4)(c)2., F.A.C.]
- 10. The Permittee shall submit all compliance, annual operating reports and other correspondence required of this permit to:

Department of Environmental Protection Central District Office 3319 Maguire Boulevard Suite 232 Orlando, Florida 32803-3767 Telephone: 407/894-7555 Fax: 407/897-2996

11. Any reports, data, notification, certifications, and requests required to be sent to the United States Environmental Protection Agency should be sent to:

United States Environmental Protection Agency

Region 4

Air, Pesticides, & Toxics Management Division Air and EPCRA Enforcement Branch, Air Enforcement Section

61 Forsyth Street Atlanta, Georgia 30303 Telephone: 404/562-9155 Fax: 404/562-9163

{Permitting note: Condition no. 51 of Appendix TV-3, lists the necessary elements of a compliance certification required under 40 C.F.R. 70.6(c)(5)(iii).}

Orlando Utilities Commission Indian River Plant Page 5 of 40

Section III. Emissions Unit Conditions

Subsection A. Fossil Fuel Steam Boilers

E.U. ID

<u>No.</u>	Brief Description			
001	87 MW Unit No.1 Boiler (EPA ID # 1)			
002	188 MW Unit No.2 Boiler (EPA ID # 2)			
003	328 MW Unit No.3 Boiler (EPA ID # 3)			

Emissions units 001, 002, and 003 consist of three Combustion Engineering Steam Generators. The boilers may burn a variable combination of natural gas, propane, No.6 and No.2 fuel oils, and onspecification used oil. Emissions units 001 and 002 share a common stack, with a height of 300 feet. Emissions unit 003 has a separate 300 foot stack. Unit 001 began operation February 1, 1960; Unit 002 September 1, 1964, and Unit 003 February 1, 1974.

{Permitting note: The emissions units are regulated under Acid Rain-Phase II, and Fossil Fuel Steam Generators with more than 250 million Btu per Hour Heat Input - Rule 62-296.405, F.A.C. and AO05-183384}

The following conditions apply to the emissions units listed above: Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum operating heat input rate is as follows:

<u>Unit No.</u>	<u>Fuel Type</u>	<u>MMBtu/Hour</u>		
1	Natural Gas	865.5		
1	Oil	832.2		
2	Natural Gas	2248.7		
2	Oil	2016.5		
3	Natural Gas	3208.5		
3	Oil	3048.8		

Additionally, on-specification used oil may be fired at the rate of the lesser of:

- a. Up to 1.5 million gallons per year; or
- b. the equivalent heat input of 10 percent or less of the permitted heat input of No. 6 Fuel Oil while combusting either No. 6 Fuel Oil or Natural Gas.

{Permitting note: See condition A.27.}

[Rules 62-4.160(2), 62-210.200 (PTE), and 62-296.405, F.A.C.]

- **A.2.** Emissions Unit Operating Rate Limitation After Testing. See specific condition A.18. [Rule 62-297.310(2), F.A.C.]
- A.3. Methods of Operation Fuels. The only fuels allowed to be burned are No.2 fuel oil, No.6 residual oil, natural gas, propane, and on-specification used oil. The used oil shall comply with the limits given in specific condition A.27. Off-specification used oil shall not be burned. [Rules 62-4.160(2), 62-210.200, 62-213.440(1), F.A.C., and AO05-183384]
- **A.4.** Hours of Operation. These emissions units may operate 8,400 hours per year. The facility is required to keep daily records of the operating hours and associated fuel use. [Rules 62-210.200 and 62-213.440(1)(b)1.b., F.A.C., (PTE)]

Orlando Utilities Commission Indian River Plant Page 6 of 40

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.5. <u>Visible Emissions - Steady State</u>. Visible emissions shall not exceed 40 percent opacity. Emissions units governed by this visible emissions standard shall compliance test for particulate matter emissions annually.

[Rule 62-296.405(1)(a), F.A.C. and Order OGC File Nos. 88-1257, 88-1258, and 88-1259 dated March 13, 1989.]

A.6. <u>Visible Emissions - Soot Blowing and Load Change</u>. Visible emissions shall not exceed 60 percent opacity during the 3 hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.

Visible emissions above 60 percent opacity shall be allowed for not more than four, six-minute periods, during the three-hour period of excess emissions allowed by this subparagraph, for boiler cleaning and load changes, at units which have installed and are operating, or have committed to install or operate, continuous opacity monitors.

[Rule 62-210.700(3), F.A.C.]

A.7. Particulate Matter - Steady State. Particulate matter emissions shall not exceed 0.1 pound per million Btu heat input, as measured by applicable compliance methods. {Permitting note: The averaging time shall correspond to the cumulative sample time, as specified in the reference test method.}

[Rule 62-296.405(1)(b), F.A.C.]

A.8. Particulate Matter - Soot Blowing and Load Change. Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change. {Permitting note: The averaging time shall correspond to the cumulative sample time, as specified in the reference test method.}

[Rule 62-210.700(3), F.A.C.]

- A.9. <u>Sulfur Dioxide</u>. Sulfur dioxide emissions when burning liquid fuel shall not exceed 2.75 pounds per million Btu heat input, as measured by applicable compliance methods. [Rule 62-296.405(1)(c)1.j., F.A.C.]
- A.10. <u>Sulfur Dioxide Sulfur Content.</u> The as-fired sulfur content of the fuel(s) shall not exceed 2.5 percent, by weight. See conditions A.11., A.16., and A.17. [Rule 62-296.405(1)(e)3., F.A.C.]

Orlando Utilities Commission Indian River Plant Page 7 of 40

Monitoring Requirements

A.11. <u>Sulfur Dioxide</u>. The permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit. OUC will perform a daily sulfur content analysis of the as-fired fuel. See condition A.22. for recordkeeping requirements. This protocol is allowed since the emissions unit has no operating flue gas desulfurization device. See specific conditions A.16., and A.17. [Rule 62-296.405(1)(f)1.b., F.A.C.]

A.12. Determination of Process Variables.

- (a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- (b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.13. <u>Visible Emissions</u>. The test method for visible emissions shall be DEP Method 9, incorporated in Chapter 62-297, F.A.C. A transmissometer may be used and calibrated according to Rule 62-297.520, F.A.C. See specific condition A.14.

[Rule 62-296.405(1)(e)1., F.A.C.]

- **A.14.** <u>DEP Method 9</u>. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:
- 1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.
- 2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:
 - a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.

Orlando Utilities Commission Indian River Plant Page 8 of 40

b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value. [Rule 62-297.401, F.A.C.]

- **A.15.** Particulate Matter. The test method for particulate emissions shall be EPA Method 17 incorporated by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet. For EPA Method 17, stack temperature shall be less than 375 degrees Fahrenheit. OUC may use EPA Method 5 to demonstrate compliance. EPA Method 3 or 3A with Orsat analysis shall be used when the oxygen based F-factor, computed according to EPA Method 19, is used in lieu of heat input. Acetone wash shall be used with EPA Method 17. [Rule 62-296.405(1)(e)2., F.A.C.]
- A.16. <u>Sulfur Dioxide</u>. The test methods for sulfur dioxide emissions shall be EPA Methods 6, 6A, 6B, or 6C, incorporated by reference in Chapter 62-297, F.A.C. Fuel sampling and analysis may be used as an alternate sampling procedure if such a procedure is incorporated into the operation permit for the emissions unit. If the emissions unit obtains an alternate procedure under the provisions of Rule 62-297.620, F.A.C., the procedure shall become a condition of the emissions unit's permit. The Department will retain the authority to require EPA Method 6 or 6C if it has reason to believe that exceedances of the sulfur dioxide emissions limiting standard are occurring. Results of an approved fuel sampling and analysis program shall have the same effect as EPA Method 6 test results for purposes of demonstrating compliance or noncompliance with sulfur dioxide standards. The permittee may use the EPA test methods referenced above to demonstrate compliance; however, the permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit. OUC will perform a daily analysis of the as-fired fuel. See specific condition A.17. [Rules 62-296.405(1)(e)3., 62-297.620, F.A.C.]
- **A.17.** The following fuel sampling and analysis protocol shall be used as an alternate sampling procedure:
 - a. Determine and record the **as-fired** fuel sulfur content, percent by weight, for liquid fuels using either ASTM D2622-94, ASTM D4294-90 (95), ASTM D1552-95, ASTM D1266-91, or both ASTM D4057-88 and ASTM D129-95 (or latest editions).
 - b. Record daily the amount of each fuel fired, the density of each fuel, and the percent sulfur content by weight of the as-fired fuel.
 - c. Utilize the information in a. and b., above, to calculate the SO₂ emission rate to ensure compliance at all times.

[Rules 62-297.440, and 62-297.620(2)(d), F.A.C.]

A.18. Operating Rate During Testing. Testing of emissions shall be conducted with each emissions unit operating at permitted capacity, which is defined as 90 to 100 percent of the maximum operation

Orlando Utilities Commission Indian River Plant Page 9 of 40

rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rules 62-297.310(2) & (2)(b), F.A.C.]

- **A.19.** The particulate matter and visible emissions test shall be conducted concurrently. [Rule 62-4.070(3), F.A.C., and AO05-183384]
- **A.20.** Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities. (See attachment.) [Rule 62-297.310(6), F.A.C.]
- **A.21.** Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

 (a) General Compliance Testing.
 - 1. (Not applicable)
 - 2. For excess emission limitations for particulate matter specified in Rule 62-210.700,
- F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid fuel for more than 400 hours other than during startup.
 - 3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of ssion compliance test results for any emissions unit that, during the year prior to renewal:
 - a. Did not operate; or
 - b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.
- 4. During each federal fiscal year (October 1 September 30), a formal compliance test shall be conducted for:
 - a. Visible emissions;
 - b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
 - c. Each NESHAP pollutant, if there is an applicable emission standard.
 - 5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid fuel, other than during startup, for a total of more than 400 hours.
 - 6. (Not applicable)

Orlando Utilities Commission Indian River Plant Page 10 of 40

- 7. (Not applicable)
- 8. (Not applicable)
- 9. (See Specific Condition A.26.)
- 10. An annual compliance test conducted for visible emissions shall not be required for units exempted from permitting at Rule 62-210.300(3)(a), F.A.C., or units permitted under the General Permit provisions at Rule 62-210.300(4), F.A.C.

[Rule 62-297.310(7)(a)2., 3., 4., 5., 9., 10., F.A.C.; SIP approved]

Reporting and Recordkeeping Requirements

- **A.22.** On a quarterly basis, OUC shall submit a report showing the types of fuels burned. Also, state the sulfur content of the as-fired fuel, recorded from the daily analysis required of specific condition A.16. The records shall be maintained for a minimum of five years and shall be made available to the Department upon request. The permittee shall submit a copy of the fuel oil analysis for the fuel oil burned during each compliance test with the results from the test. [Rule 62-4.070(3), F.A.C., and AO05-183384]
- **A.23.** <u>Malfunction Reporting</u>. In the case of excess emissions resulting from malfunctions, the permittee shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]
- A.24. Quarterly Excess Emissions Reporting Requirements. Submit to the Department a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the permittee of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years.

 [Rule 62-296.405(1)(g), F.A.C.]

A.25. Test Reports - General Requirements.

- (a) The owner or operator an emissions unit for which a compliance test is required shall file a report with the Department's Central District Office on the results of each such test.
- (b) The required test report shall be filed with the Department's Central District Office as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
 - 1. The type, location, and designation of the emissions unit tested.
 - 2. The facility at which the emissions unit is located.
 - 3. The owner or operator of the emissions unit.
- 4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
- 5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.

Orlando Utilities Commission Indian River Plant Page 11 of 40

- 6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
- 7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
 - 8. The date, starting time and duration of each sampling run.
- 9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
 - 10. The number of points sampled and configuration and location of the sampling plane.
- 11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
 - 12. The type, manufacturer and configuration of the sampling equipment used.
 - 13. Data related to the required calibration of the test equipment.
 - 14. Data on the identification, processing and weights of all filters used.
 - 15. Data on the types and amounts of any chemical solutions used.
- 16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
- 17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
- 18. All measured and calculated data required to be determined by each applicable test procedure for each run.
- 19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
- 20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
- 21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge. [Rule 62-297.310(8), F.A.C.]
- **A.26.** Notification. OUC shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted. [Rule 62-297.310(7)(a)9., F.A.C.]

Miscellaneous Conditions

- A.27. <u>Used Oil</u>. Burning of on-specification used oil is allowed by these emissions units in accordance with all other conditions of this permit and the following conditions:
 - a. On-specification Used Oil Emissions Limitations: This emissions unit is permitted to burn only on-specification used oil, which contains a PCB concentration of less than 50 ppm. "On-specification" used oil is defined as used oil that meets the specifications of 40 CFR

Orlando Utilities Commission Indian River Plant Page 12 of 40

279.11, Table 1, Standards for the Management of Used Oil, as listed below. "Off-specification" used oil shall not be burned. Used oil which exceeds any of the allowable levels of the constituents and properties in the following table is considered off-specification used oil.

CONSTITUENT/PROPERTY	ALLOWABLE LEVEL
Arsenic	5 ppm maximum
Cadmium	2 ppm maximum
Chromium	10 ppm maximum
Lead	100 ppm maximum
Total Halogens ·	1000 ppm maximum
Flash point	100 degrees F minimum

- b. Quantity Limitation: No more than 1.5 million gallons of on-specification used oil may be burned during any federal fiscal year.
- c. <u>PCB Limitation</u>: Used oil containing a PCB concentration of 50 or more ppm shall not be burned at this facility. Used oil shall not be blended to meet this requirement.
- d. Operational Requirements: On-specification used oil with a PCB concentration of greater than or equal to 2, and less than 50 ppm shall be burned only at normal source operating temperatures. Used oil with a PCB concentration of greater than or equal to 2 ppm shall not be burned during periods of startup or shutdown.
- e. <u>Testing Requirements</u>: For used oil generated on-site, OUC shall sample and analyze each batch of used oil to be burned for the following parameters:

Arsenic, cadmium, chromium, lead, total halogens, flash point and PCBs.

Testing (sampling, extraction and analysis) shall be performed using approved methods specified in EPA Publication SW-846 (Test Methods for Evaluating Solid Waste, Physical/Chemical Methods).

For used oil obtained off-site, OUC shall receive from the marketer, for each load of used oil received, a certification that the used oil meets the criteria for on-specification used oil and contains a PCB concentration of no greater than 49 ppm. This certification shall also describe the basis for the certification, such as analytical results. Any claim that used oil does not contain quantifiable levels of PCBs (that is, the used oil contains less than 2 ppm of PCBs) must be documented by testing or other information. The first person making that claim is responsible for furnishing the documentation. The documentation can be tests, personal or special knowledge of the source and composition of the used oil, or a certification from the person generating the used oil claiming that it contains no detectable PCBs. If OUC does not receive certification from the marketer as described above, they must sample and test each load of used oil as outlined above for on-site testing. If OUC relies on the certification from the marketer, OUC shall, at a minimum, each calendar quarter, test one load of the used oil received, selected at random, for the above parameters. If the analytical results show that the used oil does not meet the "on-specification" criteria, or that it contains PCB's of 50 ppm or greater, OUC shall immediately notify and provide these results to the Department's Central District Office and immediately stop burning the used oil.

- f. <u>Record Keeping Requirements</u>: OUC shall obtain, make, and keep the following records for used oil in a form suitable for inspection by the Department:
 - (1) The gallons of on-specification used oil generated and burned each month. (This record shall be completed no later than the fifteenth day of the succeeding month.)
 - (2) The total gallons of on-specification used oil burned in the preceding consecutive 12-month period. (This record shall be completed no later than the fifteenth day of the succeeding month.)
 - (3) The name and address of all marketers delivering used oil to the facility.
 - (4) Copies of the marketer certifications and any supporting information.
 - (5) Documentation that the used oil contains less than 2 ppm PCBs, if claimed, including the name and address of the person making the claim.
 - (6) Results of the analyses required above.
 - (7) A copy of the notice to EPA and a copy of the one-time written notice provided to each marketer.
 - (8) Total lead emissions as a result of burning on-specification used oil on a monthly basis.
- g. <u>Reporting Requirements</u>: OUC shall submit to the Department, within thirty days of the end of each calendar quarter, the analytical results and the total amount of on-specification used oil generated and burned during the quarter.

OUC shall submit, with the Annual Operation Report form, the analytical results and the total amount of on-specification used oil burned during the previous calendar year.

[Rule 62-4.070(3), F.A.C., and 40 CFR 279 and 40 CFR 761]

A.28. The specific conditions in Subsection E (Common Conditions II) apply to these emissions units.

Orlando Utilities Commission Indian River Plant Page 14 of 40

Subsection B. Combustion Turbines A & B

E.U. ID

No. Brief Description

35 MW Simple Cycle Combustion Turbine A

007 35 MW Simple Cycle Combustion Turbine B

Emissions units 004 and 007 (Turbines A and B) consist of simple cycle GE Frame 6 combustion turbines, each with a 35 MW rating. Although the turbines will primarily fire natural gas, distillate oil may be fired during periods of curtailed or uneconomical natural gas supply. Nitrogen oxide emissions are reduced by using water injection. Both turbines began commercial operation August 1, 1990.

{Permitting notes: These emissions units are regulated under Rule 62-210.300, F.A.C., Permits Required; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(7)(b)38., F.A.C.; NSPS 40 CFR 60 Subpart A; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration; PSD-FL-130; and AC05-144482 and AC05-146749.}

The following conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

B.1. <u>Permitted Capacity.</u> The maximum heat input (lower heating value) to each turbine shall not exceed 445 MMBtu/hour, at sea level and 59°F. See Attachment A for a plot of heat input versus temperature.

[Rules 62-4.160(2), 62-210.200 (PTE), and 62-212.400, F.A.C., AO05-176351]

- **B.2.** Methods of Operation Fuels. The only fuels allowed to be burned are No.2 fuel oil and natural gas. To comply with the sulfur emission limits, the sulfur content of the as-fired fuels shall not exceed 0.3 percent, by weight. See condition D.3 (Common Conditions I). [Rule 62-4.160(2), 62-210.200, 62-213.440(1), F.A.C., AC05-144482 and AC05-146749]
- **B.3.** Hours of Operation. This emissions units may operate continuously (8,760 hours per year). The facility is required to keep daily records of the operating hours and associated fuel use. [Rules 62-210.200 and 62-213.440(1)(b)1.b., F.A.C., (PTE)]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

Orlando Utilities Commission Indian River Plant Page 15 of 40

B.4. The maximum allowable emissions from the turbines in accordance with the BACT determination, shall not exceed the following, at sea level and 59°F:

Pollutant	Fuel	ppm @ 15% O ₂	lb per hr/Unit	TPY per Unit	TPY per 2 Units
NOx	Gas	42	75.1	328.9	658
NOx	Oil	65	118.3	518.2	1036.5
SO ₂	Gas	n/a	0.34	1.5	3
SO ₂	Oil	n/a	142.7	625.0	1250

{Permitting note: The averaging time shall correspond to the cumulative sample time, as specified in the reference test method.}

[PSD-FL-130 and AC05-144482 and AC05-146749]

B.5. <u>Visible emissions.</u> Visible emissions shall not exceed 5% opacity while burning natural gas or 10% opacity while burning distillate oil, except as provided in Rule 62-210.700, F.A.C., Excess Emissions. EPA Method 9 shall be used annually to show compliance. [PSD-FL-130, and AC05-144482 and AC05-146749]

B.6. The following emissions are tabulated for PSD and inventory purposes:

Pollutant	Fuel	lb per hr/Unit	TPY per Unit	TPY per 2 Units
CO	Gas	10.0	43.8	87.5
CO	Oil	10.0	44.2	88.5
Total Particulates	Gas	2.5	11.0	22
Total Particulates	Oil	20.0	87.6	175
PM10	Gas	2.5	11.0	22
PM10	Oil	10.0	43.8	87.5
VOC	Gas	4.0	17.5	35
VOC	Oil	4.0	17.5	35
Beryllium	Oil	0.0001	0.0005	0.0009
SO ₂ Mist	Oil	10.0	44.0	88

[PSD-FL-130 and AO05-176351]

Operating Parameters

B.7. Water Injection. Water injection shall be used for NOx control. The combustion turbines (CT) shall operate at the minimum water-to-fuel ratios measured for the most recent (satisfactory) compliance demonstration. The compliance test report shall document the required water-to-fuel ratios.

[PSD-FL-130]

B.8. Both start and black start capability shall be provided by a No.2 fuel oil fired 800 HP internal combustion diesel engine (for each turbine), projected to run for approximately 10 minutes per start. These diesels are expected to emit minimal air emissions (15 lbs SO₂/yr./unit). [PSD-FL-130, and AC05-144482, AC05-146749, and AO05-176351]

Excess Emissions, Monitoring, Testing, and Recordkeeping Requirements

Orlando Utilities Commission Indian River Plant Page 16 of 40

B.9. Subsection D (Common Conditions I) and Subsection E (Common Conditions II) apply to these emissions units.

Orlando Utilities Commission Indian River Plant Page 17 of 40

Subsection C. Combustion Turbines C & D

E.U. ID

No. Brief Description

129 MW Simple Cycle Combustion Turbine C (EPA ID # C)

129 MW Simple Cycle Combustion Turbine D (EPA ID # D)

Emissions units 005 and 006 (Turbines C and D) consist of simple cycle Westinghouse Model Number 501-D5 combustion turbines, each with a 129 MW rating. The turbines will primarily fire natural gas. Distillate oil will be fired during periods of curtailed or uneconomical natural gas supply. Nitrogen oxide emissions will be controlled by water injection. Both turbines began commercial operation November 1, 1991.

{Permitting notes: This emissions unit is regulated under Acid Rain-Phase II, Rule 62-210.300, F.A.C., Permits Required; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(7)(b)38., F.A.C.; NSPS 40 CFR 60 Subpart A; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration; PSD-FL-173; and AC05-193720.}

The following conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

- C.1. <u>Permitted Capacity.</u> For each emissions unit, the maximum heat input (lower heating value) (MMBtu/hr) shall not exceed 1,354 MMBtu/hr while firing natural gas or 1,346 MMBtu/hr while firing distillate oil. See Attachment B for a plot of heat input versus temperature. [Rules 62-4.160(2), 62-210.200 (PTE), and 62-212.400, F.A.C., PSD-FL-173]
- C.2. Methods of Operation Fuels. For each CT, natural gas shall be the primary fuel and No. 2 fuel oil shall be the secondary fuel. For each CT usage rates shall not exceed the following:
 - a. Maximum No. 2 fuel oil consumption shall not exceed either of the following limitations: 10,282 gals per hour; 22,517,580 gallons per year.
 - b. Maximum annual firing using No. 2 fuel oil shall not exceed 2,190 hours per year.
 - c. Maximum sulfur content in the oil shall not exceed 0.3 percent by weight.
 - d. Maximum annual firing on any fuel combination shall not exceed 4,380 hours per year.

To determine compliance with the capacity factor limitations, each CT's fuel consumption shall be continuously measured and recorded. The permittee shall maintain daily records of this fuel usage and the operating hours. All records shall be maintained for a minimum of five years after the date of each record and shall be made available to authorized representatives of the Department upon request.

To comply with the sulfur emission limits, the sulfur content of the as-fired fuels shall not exceed 0.3 percent, by weight; see condition D.3 (Common Conditions I).

Any request to a change in the method of operation, equipment or operating hours which would result in an increase in emissions shall be submitted to the DEP's Bureau of Air Regulation. [PSD-FL-173 and Rules 62-4.160(2), 62-210.200, 62-213.440(1), F.A.C.,]

C.3. <u>Hours of Operation.</u> Each source is allowed to operate at full load for a maximum of 4,380 hours per year. The facility is required to keep daily records of the operating hours. [PSD FL-173, Rules 62-210.200 (PTE) and 62-213.440(1)(b)1.b., F.A.C.]

Orlando Utilities Commission Indian River Plant Page 18 of 40

C.4. Any request to change the method of operation, equipment or operating hours which would result in an increase in emissions shall be submitted to the DEP's Bureau of Air Regulation and Central District offices for prior approval.

[PSD-FL-173 and AC05-193720]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

C.5. The maximum allowable emissions from *each* turbine in accordance with the BACT determination, shall not exceed any of the following limitations, at sea level and 59°F:

Pollutant	Firing Natural Gas	TPY* Firing Gas	Lbs/hour Firing Gas**	Firing No. 2 Fuel Oil	TPY* Firing No.2 Fuel Oil	Lbs/hour Firing No.2 Fuel Oil**	Basis
NOx	25 ppm @ 15% O ₂ (dry basis)	295.75	135.0	42ppmv @15% O ₂ (dry basis)	253	231.1	BACT
SO ₂	0.3% by weight	1.05	0.5	0.3% by weight	476.5	435.2	BACT
PM/PM10	0.003 lb/MMBtu	9.75	4.5	0.08 lb/MMBtu	118.5	108.2	Perf. Data
VOC	5 ppmvd	18.5	8.4	15 ppmvd	56	51.1	Perf. Data
CO	25 ppmvđ	156.5	71.5	25 ppmvd	79.5	72.6	Perf. Data
SO ₂ Mist	Natural gas as fuel	0.035	0.02	Low sulfur oil	14.25	13.0	Perf. Data

^{*} Emission rates for each 129 MW turbine are based on a 50 percent capacity factor with a maximum of 25 percent attributed to oil firing.

Since the pollutants mercury, lead, and beryllium are an inherent constituent in distillate fuel oil, they will be regulated by specifying that only No.2 fuel oil be fired at this facility in addition to natural gas.

{Permitting note: The averaging time shall correspond to the cumulative sample time, as specified in the reference test method.}

[AC05-193720, AO05-229084, and applicant request.]

C.6. <u>Visible Emissions</u>. Visible emissions shall never exceed 20 percent opacity and shall not exceed 10 percent opacity during full load, except as provided in Rule 62-210.700, F.A.C., Excess Emissions. EPA Method 9 shall be used to demonstrate compliance. [AC05-193720]

C.7. Compliance with the total volatile organic compound emission limits will be assumed, provided the CO allowable emission rate is achieved; specific VOC compliance testing is not required.

[PSD-FL-173]

Excess Emissions, Monitoring, Testing, and Recordkeeping Requirements

C.8. Emissions Testing. Testing of emissions shall be conducted with the turbines operating at capacity (maximum heat input rate for the inlet air temperature of the CT during the test). Capacity

^{**} Requested by applicant.

Orlando Utilities Commission Indian River Plant Page 19 of 40

is defined as 95-100 percent of the manufacturer's rated heat input achievable for the average ambient (or conditioned inlet) air temperature during the test. If it is impracticable to test at capacity, then the combustion turbine may be tested at less than capacity. In such case, the entire heat input versus inlet temperature curve (reference Attachment B) will be adjusted down by the increment equal to the difference between the design heat input value and 105 percent of the value reached during the test. Data, curves, and calculations necessary to demonstrate the heat input rate correction at both design and test conditions shall be submitted to the Department with the compliance test report. Test results will be the average of three valid one-hour runs. [AC05-193720 and PSD-FL-173]

C.9. Carbon Monoxide. EPA Method 10 shall be used to show compliance with the CO emission limits on an annual basis.

[PSD-FL-173 and OGC File No. #94-3376-C-05]

C.10. Water Injection. Water injection shall be used for NO_x control. OUC shall report the water-to-fuel ratios used during testing to demonstrate compliance with the permitted emission rate. Additionally, the water meters shall be calibrated semi-annually (once every six months). If, after two years [of initial use], the meters show less than two percent error, the calibration frequency shall be changed to annually.

[PSD-FL-173 and OGC File No. #94-3376-C-05]

C.11. The permittee will conduct its operation of combustion turbines C and D using the Department-approved "Air Pollution Prevention and Operator's Best Management Practice Training Plan".

[OGC File No. #94-3376-C-05]

C.12. <u>Training.</u> All watch engineers, Control Center I's, plant operators, and apprentice operators, directly involved with the operation of Combustion C and D and/or the related monitoring systems shall be trained annually on the approved final plan referenced in specific condition C.11., above. The OUC shall keep documentation of the employee training in the plan on file in the facility records. All watch engineers, Control Center I's, plant operators, and apprentice operators, directly involved with the operation of Combustion C and D and/or the related monitoring systems shall be trained of these plans prior to their initial operation of Combustion Turbines C and D. This training shall be documented and filed as provided above.

[OGC File No. #94-3376-C-05]

C.13. Subsection D (Common Conditions I) and Subsection E (Common Conditions II) apply to these emissions units.

Orlando Utilities Commission Indian River Plant Page 20 of 40

Subsection D. Common Conditions I (Combustion Turbines)

The following conditions apply only to the *combustion turbines* listed in Subsections B. and C., Section III., of this permit.

Emission Limitations and Standards

- **D.1.** Oxides of Nitrogen. In addition to the specific NOx emission limits specified for each turbine, NOx emissions shall not exceed any of the following limits:
- a. Nitrogen oxides emissions, expressed as NO_x, shall not exceed:

$$STD = 0.0075 (14.4)/Y + F$$

where:

STD = allowable NOx emissions (percent by volume at 15 percent oxygen and on a dry basis).

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour.

F = NOx emission allowance for fuel-bound nitrogen as defined in 40 CFR 60.332(a)(3).

F shall be defined according to the nitrogen content of the fuel as follows:

Fuel-bound nitrogen (% by we	ight) F (NO _X % by volume)	
N≤0.015	0	•
0.015 <n<u><0.1</n<u>	0.04(N)	•
0.1 <n≤0.25< td=""><td>0.004+0.0067(N-0.1)</td><td></td></n≤0.25<>	0.004+0.0067(N-0.1)	
N>0.25	0.005	•

where:

N = the nitrogen content of the fuel (percent by weight)

{Permitting Note: Fuel-bound nitrogen is used to increase the NSPS limit to account for nitrogen in the fuel. The lowest NOx limit that can be achieved with this equation is 0.0075% NO_x by volume (at 15 percent oxygen and on a dry basis.) Combustion Turbines A, B, C, and D are all BACT turbines and have much lower NO_x limits without regard for the fuel-bound nitrogen. } [40 CFR 60.332]

Monitoring Requirements

- **D.2.** CMS Requirements. For the simple cycle unit, the permittee shall install, operate, and maintain a continuous monitoring system (CMS) to monitor and record the fuel consumption, the ratio of water to fuel being fired in the turbine, and the electrical output in MW. The system shall be accurate to within ±5.0 percent and shall be approved by the Department.

 [40 CFR 60.334(a)]
- **D.3.** <u>Critical Fuel Parameters</u>. OUC shall monitor sulfur content, nitrogen content, and the lower heating value of the fuel being fired in the turbine. The frequency of determination of these values shall be as follows:
- a. If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source.

Orlando Utilities Commission Indian River Plant Page 21 of 40

b. If the turbine is supplied its fuel without intermediate bulk storage, the values shall be determined and recorded daily. Owners, operators or fuel vendors may develop custom schedules for determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Bureau of Air Regulation before they can be used to show compliance. See condition D.10. below.

[40 CFR 60.334(b)]

- **D.4.** Excess Emissions Defined. For the purpose of reports required under 40 CFR 60.7(c) (see specific condition C.24.), periods of excess emissions that shall be reported are defined as follows:
- a. Nitrogen oxides. Any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with 40 CFR 60.332 by the performance test required in 40 CFR 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the performance test required in 40 CFR 60.8. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under 40 CFR 60.335(a).
- b. Sulfur dioxide. Any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.3 percent.

[40 CFR 60.334(c)(1)&(c)(2), PSD-FL-130 and PSD-FL-173]

Test Methods & Procedures

Testing of emissions shall be conducted with the source operating at capacity. Capacity is defined as 95 to 100 percent of the manufacturer's rated heat input achievable for the average ambient (or conditioned) air temperature during the test. If it is impracticable to test at capacity, then sources may be tested at less than capacity. In such cases, the entire heat input versus inlet temperature curve will be adjusted by the increment equal to the difference between the design heat input value and 105 percent of the value reached during the test. Data, curves, and calculations necessary to demonstrate the heat input rate correction at both design and test conditions shall be submitted to the Department with the compliance test report.

To demonstrate compliance with federal new source performance standard Subpart GG - Standards of performance Stationary Gas Turbines, the initial test shall be conducted at four load points and corrected to ISO conditions for comparison to the NSPS allowable. Subsequent annual compliance tests conducted to establish compliance with NOx limits that are more stringent than the NSPS standard shall not require an ISO correction or testing at four load points; rather, the testing shall be done at capacity, as defined above. However, when testing shows that NOx emissions exceed the standard when operating at capacity, the company shall recalibrate the NOx emission control system using emission testing at four loads as required in Subpart GG.

[Rule 62-4.070(3), F.A.C.]

- **D.5.** The Permittee shall conduct a compliance test for each combustion turbine on an *annual basis* for the following pollutants. Each compliance test shall be conducted in accordance with 40 CFR 60, Appendix A, using the method indicated.
 - a) Oxides of Nitrogen (NOx) EPA Method 20.
 - b) Carbon Monoxide (CO) EPA Method 10 (CT Units C&D only).
 - c) Visible Emissions EPA Method 9.

Orlando Utilities Commission Indian River Plant Page 22 of 40

[Rule 62-297.310(7)(a)4., F.A.C.]

- **D.6.** The Permittee shall conduct a compliance test for each of the following pollutants *prior to obtaining a renewed operation permit.* Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy this requirement. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of compliance test results for any emissions unit that, during the year prior to renewal; a) did not operate; or b) in the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours. Each compliance test shall be conducted in accordance with 40 CFR 60 Appendix A, using the method indicated.
 - a) Sulfur Dioxide (SO₂) ASTM Method for sulfur in fuel. (See specific condition D.12.)
 - b) Oxides of Nitrogen (NOx) EPA Method 20.
 - c) Carbon Monoxide (CO) EPA Method 10 (CT Units C&D only).
 - d) Visible Emissions EPA Method 9.

[Rule 62-297.310(7)(a)3., F.A.C.]

D.7. NOx Compliance. Annual NOx compliance tests shall be performed with each fuel used for more than 170 hours per unit for CT-A and CT-B in the preceding 12 month period, and for more than 400 hours per unit for CT-C and CT-D in the preceding 12 month period. Testing of emissions shall be conducted at 95-100% of the manufacturer's rated heat input based on the average ambient air temperature during the test. To compute the nitrogen oxides emissions, OUC shall use analytical methods and procedures that are accurate to within ±5 percent and are approved by the Department to determine the nitrogen content of the fuel being fired.

[40 CFR 60.335(a), PSD-FL-130 and PSD-FL-173]

D.8. In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of 40 CFR 60 or other methods and procedures as specified in this permit, except as provided for in 40 CFR 60.8(b). Acceptable alternative methods and procedures are given in paragraph 40 CFR 60.335(f). [40 CFR 60.335(b)]

D.9. NOx Emission Rate. OUC shall determine compliance with the NOx standards in 40 CFR 60.332 (condition D.1) as follows:

a. The NO_x emission rate shall be computed for each run using the following equation:

 $NO_X = (NO_{XO}) (Pr/Po)^{0.5} e^{19(Ho-0.00633)} (288^{\circ}K/Ta)^{1.53}$

where:

 NO_X = emission rate of NO_X at 15 percent O_2 and ISO standard ambient conditions, volume percent.

 NO_{XO} = observed NO_X concentration, ppm by volume.

 P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg.

P_O = observed combustor inlet absolute pressure at test, mm Hg.

 H_0 = observed humidity of ambient air, g H_2O/g air.

e = transcendental constant, 2.718.

 $T_a = ambient temperature, °K.$

[40 CFR 60.335(c)(1)]

Orlando Utilities Commission Indian River Plant Page 23 of 40

- **D.10.** The monitoring device of 40 CFR 60.334(a) (specific condition D.2.) shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with 40 CFR 60.332 (specific condition D.1.) at 30, 50, 75, and 100 percent of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer. However, annual compliance tests conducted to establish compliance with NOx limits that are more stringent than the NSPS standard shall not require an ISO correction or testing at four load points; rather, the testing shall be done at capacity, as defined earlier. [40 CFR 60.335(c)(2)]
- **D.11.** Emissions Concentrations. U.S. EPA. Method 20 (40 CFR 60, Appendix A) shall be used to determine nitrogen oxides, sulfur dioxide and oxygen concentrations. The span values shall be 300 ppm of nitrogen oxide and 21 percent oxygen. The NO_X emissions shall be determined at each of the load conditions specified in 40 CFR 60.335(c)(2), (condition D.7). [40 CFR 60.335(c)(3)]
- **D.12.** Sulfur Content. OUC shall determine compliance with the sulfur content standard in 40 CFR 60.333(b) as follows: ASTM D 2880-96, or more recent version, shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-90(94)E-1, D 3031-81(86), D 4084-94, or D 3246-92, or more recent versions, shall be used for the sulfur content of gaseous fuels (incorporated by reference-see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Department. [40 CFR 60.335(d)]
- **D.13.** The owner or operator may use the following as an alternative to the reference methods and procedures specified in 40 CFR 60.335:

Instead of using the equation in paragraph 40 CFR 60.335(c)(1), manufacturers may develop ambient condition correction factors to adjust the nitrogen oxides emission level measured by the performance test as provided in 40 CFR 60.8 to ISO standard day conditions. These factors are developed for each gas turbine model they manufacture in terms of combustion inlet pressure, ambient air pressure, ambient air humidity, and ambient air temperature. They shall be substantiated with data and must be approved for use by the Department before the initial performance test required by 40 CFR 60.8. Notices of approval of custom ambient condition correction factors will be published in the Federal Register.

[40 CFR 60.335(f)(1)]

- **D.14.** Except as provided by ASP 92-0-01, OUC shall provide, or cause to be provided, performance testing facilities as follows:
- 1. Sampling ports adequate for test methods applicable to such facility. This includes (a) constructing the air pollution control system such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and procedures and (b) providing a stack or duct free of cyclonic flow during performance tests, as demonstrated by applicable test methods and procedures.
 - 2. Safe sampling platform(s).
 - 3. Safe access to sampling platform(s).
 - 4. Utilities for sampling and testing equipment.

Orlando Utilities Commission Indian River Plant Page 24 of 40

[40 CFR 60.7(e)]

Reporting and Recordkeeping Requirements

D.15. Excess Emissions Report. The permittee shall record the occurrence and duration of any startup, shutdown, or malfunctions of the turbine and any malfunction of the air pollution control equipment or CMS. Additionally, the permittee shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C., and 40 CFR 60.7(b)]

- **D.16.** Quarterly Report. OUC shall submit a quarterly excess emissions and monitoring systems performance report. All reports shall be postmarked by the 30th day following the end of each quarter. Written reports of excess emissions shall include the following information:
- 1. The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.
- 2. Specific identification of each period of excess emissions that occurs during startups, shutdowns and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.
- 3. The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
- 4. When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

 [40 CFR 60.7(c)]
- **D.17.** Summary Report. The summary report form shall contain the information and be in the format shown in Figure 1 of 40 CFR 60.7(d) unless otherwise specified by the Department. One summary report form shall be submitted for each pollutant monitored.
- 1. If the total duration of excess emissions for the reporting period is less than one percent of the operating time for the reporting period and CMS downtime for the reporting period is less than five percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Department.
- 2. If the total duration of excess emissions for the reporting period is one percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is five percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

 [40 CFR 60.7(d)]
- **D.18.** Reporting Frequency. (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), a permittee who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:
- (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;

Orlando Utilities Commission Indian River Plant Page 25 of 40

- (ii) OUC continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and
- (iii) The Department does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).
- (2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after OUC notifies the Department in writing of his or her intention to make such a change and the Department does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Department may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an OUC's conformance with operation and maintenance requirements. Such information may be used by the Department to make a judgment about the source's potential for noncompliance in the future. If the Department disapproves the OUC's request to reduce the frequency of reporting, the Department will notify the permittee in writing within 45 days after receiving notice of OUC's intention. The notification from the Department to the permittee will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.
- (3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the permittee shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the permittee may again request approval from the Department to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

 [40 CFR 60.7(e)]
- **D.19.** OUC shall file a report with the Department's Central District Office for any required compliance tests within forty-five days of the last sampling run. All reports shall be in a format consistent with and shall include the information in accordance with Rule 62-297.310 (8), F.A.C. [Rule 62-297.310(8)(a)&(b), F.A.C.]
- **D.20.** Records Retention. The permittee shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least 5 (five) years following the date of such measurements, maintenance, reports, and records.

[40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

D.21. 15 Day Notification. OUC shall provide to the Department's Central District office at least 15 days prior notice of any compliance or performance test, except as specified under other subparts, to afford the Central District office the opportunity to have an observer present. Test results shall be submitted to the Central District office no later than 45 days after completion of the test. [Rule 62-297.310(7)(a)9., F.A.C.]

Orlando Utilities Commission Indian River Plant Page 26 of 40

Additional General Provisions - 40 CFR 60 Subpart A

- **D.22.** Performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in each applicable subpart unless the Department (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology, (2) waives the requirement for performance tests because the owner or operator of a source has demonstrated by other means to the Department's satisfaction that the affected facility is in compliance with the standard, or (3) approves shorter sampling times and smaller sample volumes when necessitated by process variables or other factors. Nothing in 40 CFR 60.8 shall be construed to abrogate the Department's authority to require testing under section 114 of the Act. [40 CFR 60.8(b)(1), (4) & (5)]
- **D.23.** Performance tests shall be conducted under such conditions as the Department shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Department such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

 [40 CFR 60.8(c)].
- **D.24.** OUC shall provide, or cause to be provided, performance testing facilities as follows:
- 1. Sampling ports adequate for test methods applicable to such facility. This includes (a) constructing the air pollution control system such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and procedures and (b) providing a stack or duct free of cyclonic flow during performance tests, as demonstrated by applicable test methods and procedures.
 - 2. Safe sampling platform(s).
 - 3. Safe access to sampling platform(s).
 - 4. Utilities for sampling and testing equipment.

[40 CFR 60.8(e)]

- **D.25.** Each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For the purpose of determining compliance with an applicable standard, the arithmetic means of results of the three runs shall apply. In the event that a sample is accidentally lost or conditions occur in which one of the three runs must be discontinued because of forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances, beyond the owner or operator's control, compliance may, upon the Department's approval, be determined using the arithmetic mean of the results of the two other runs. [40 CFR 60.8(f)].
- **D.26.** <u>Department Notification</u>. OUC shall give written notification to the Department when there is any modification to this facility. This notice shall be submitted timely and in advance of any critical date involved to allow sufficient time for review, discussion, and revision of plans, if necessary.

Orlando Utilities Commission Indian River Plant Page 27 of 40

Such notice shall include, but not be limited to, information describing the precise nature of the change; modifications to any emission control system; production capacity of the facility before and after the change; and, the anticipated completion date of the change.

[40 CFR 60.8(d) and PSD-FL-130 and PSD-FL-173]

Compliance with Standards and Maintenance Requirements

- **D.27.** Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in appendix A of 40 CFR 60, any alternative method that is approved by the Department, or as provided in 40 CFR 60.11(e)(5). For purposes of determining initial compliance, the minimum total time of observations shall be 3 hours (30 6-minute averages) for the performance test or other set of observations (meaning those fugitive-type emission sources subject only to an opacity standard). [40 CFR 60.11(b)].
- **D.28.** The Permittee shall follow the manufacturer's instructions during periods of start-up, shutdown, malfunction, or load change to ensure that the best operational practices to minimize emissions will be adhered to and the duration of any excess emissions will be minimized. The instructions shall be kept on file at the plant site and made available for inspection upon request by the Department.

[40 CFR 60.11(d)]

- **D.29.** Credible Evidence. For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any standard in 40 CFR 60, nothing in 40 CFR 60 shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed. [40 CFR 60.11(g)].
- **D.30.** Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

 [40 CFR 60.12]

Monitoring Requirements

- **D.31.** (a) For the purposes of this section, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of this section upon promulgation of performance specifications for continuous monitoring systems under appendix B of 40 CFR 60 and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, appendix F to 40 CFR 60, unless otherwise specified in an applicable subpart or by the Department. Appendix F is applicable December 4, 1987.
- (b) All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests under 40 CFR 60.8. Verification of operational status shall,

Orlando Utilities Commission Indian River Plant Page 28 of 40

as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device.

- (c) If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under 40 CFR 60.11(e)(5), he/she shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, appendix B, of 40 CFR 60 before the performance test required under 40 CFR 60.8 is conducted. Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of the COMS or continuous emission monitoring system (CEMS) during any performance test required under 40 CFR 60.8 or within 30 days thereafter in accordance with the applicable performance specification in appendix B of 40 CFR 60. The owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Department under section 114 of the Act.
- (1) The owner or operator of an affected facility using a COMS to determine opacity compliance during any performance test required under 40 CFR 60.8 and as described in 40 CFR 60.11(e)(5), shall furnish the Department two or, upon request, more copies of a written report of the results of the COMS performance evaluation described in 40 CFR 60.13(c) at least 10 days before the performance test required under 40 CFR 60.8 is conducted.
- (2) Except as provided in 40 CFR 60.13(c)(1), the owner or operator of an affected facility shall furnish the Department within 60 days of completion two or, upon request, more copies of a written report of the results of the performance evaluation.
- (d)(1) Permittee's of all continuous emission monitoring systems installed in accordance with the provisions of 40 CFR 60 shall check the zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span shall, as a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications in appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified, whenever specified. For continuous monitoring systems measuring opacity of emissions, the optical surfaces exposed to the effluent gases shall be cleaned prior to performing the zero and span drift adjustments except that for systems using automatic zero adjustments. The optical surfaces shall be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.
- (3) Unless otherwise approved by the Department, the following procedures shall be followed for continuous monitoring systems measuring opacity of emissions. Minimum procedures shall include a method for producing a simulated zero opacity condition and upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photo detector assembly. (e) Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:
- (1) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.
- (2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

Orlando Utilities Commission Indian River Plant Page 29 of 40

- (f) All continuous monitoring systems or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of appendix B of 40 CFR 60 shall be used.
- (g) When the effluents from a single affected facility or two or more affected facilities subject to the same emission standards are combined before being released to the atmosphere, the owner or operator may install applicable continuous monitoring systems on each effluent or on the combined effluent. When the affected facilities are not subject to the same emission standards, separate continuous monitoring systems shall be installed on each effluent. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless the installation of fewer systems is approved by the Department. When more than one continuous monitoring system is used to measure the emissions from one affected facility (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required from each continuous monitoring system.
- (h) Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period. For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorder during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non reduced form (e.g., PPM pollutant and percent O2 or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).

[Rule 62-296.800, F.A.C.; 40 CFR 60.13(a)-(h)].

- **D.32.** After receipt and consideration of written application, the Department may approve alternatives to any monitoring procedures or requirements of 40 CFR 60 including, but not limited to the following:
- (1) Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by 40 CFR 60 would not provide accurate measurements due to liquid water or other interferences caused by substances with the effluent gases.
 - (2) Alternative monitoring requirements when the affected facility is infrequently operated.
- (3) Alternative monitoring requirements to accommodate continuous monitoring systems that require additional measurements to correct for stack moisture conditions.
- (4) Alternative locations for installing continuous monitoring systems or monitoring devices when the owner or operator can demonstrate that installation at alternate locations will enable accurate and representative measurements.
- (5) Alternative methods of converting pollutant concentration measurements to units of the standards.
- (6) Alternative procedures for performing daily checks of zero and span drift that do not involve use of span gases or test cells.

Orlando Utilities Commission Indian River Plant Page 30 of 40

- (7) Alternatives to the ASTM test methods or sampling procedures specified by any subpart.
- (8) Alternative continuous monitoring systems that do not meet the design or performance requirements in Performance Specification 1, appendix B, but adequately demonstrate a definite and consistent relationship between its measurements and the measurements of opacity by a system complying with the requirements in Performance Specification 1. The Department may require that such demonstration be performed for each affected facility.
- (9) Alternative monitoring requirements when the effluent from a single affected facility or the combined effluent from two or more affected facilities are released to the atmosphere through more than one point.

[Rule 62-296.800, F.A.C.; 40 CFR 60.13(i)].

- **D.33.** An alternative to the relative accuracy test specified in Performance Specification 2 of 40 CFR 60 Appendix B, may be requested as follows:
- (1) An alternative to the reference method tests for determining relative accuracy is available for sources with emission rates demonstrated to be less than 50 percent of the applicable standard. A source owner or operator may petition the Department to waive the relative accuracy test in section 7 of Performance Specification 2 and substitute the procedures in section 10 if the results of a performance test conducted according to the requirements in 40 CFR 60.8 of this subpart or other tests performed following the criteria in 40 CFR 60.8 demonstrate that the emission rate of the pollutant of interest in the units of the applicable standard is less than 50 percent of the applicable standard. For sources subject to standards expressed as control efficiency levels, a source owner or operator may petition the Department to waive the relative accuracy test and substitute the procedures in section 10 of Performance Specification 2 if the control device exhaust emission rate is less than 50 percent of the level needed to meet the control efficiency requirement. The alternative procedures do not apply if the continuous emission monitoring system is used to determine compliance continuously with the applicable standard. The petition to waive the relative accuracy test shall include a detailed description of the procedures to be applied. Included shall be location and procedure for conducting the alternative, the concentration or response levels of the alternative RA materials, and the other equipment checks included in the alternative procedure. The Department will review the petition for completeness and applicability. The determination to grant a waiver will depend on the intended use of the CEMS data (e.g., data collection purposes other than NSPS) and may require specifications more stringent than in Performance Specification 2 (e.g., the applicable emission limit is more stringent than NSPS).
- (2) The waiver of a CEMS relative accuracy test will be reviewed and may be rescinded at such time following successful completion of the alternative RA procedure that the CEMS data indicate the source emissions approaching the level of the applicable standard. The criterion for reviewing the waiver is the collection of CEMS data showing that emissions have exceeded 70 percent of the applicable standard for seven, consecutive, averaging periods as specified by the applicable regulation(s). For sources subject to standards expressed as control efficiency levels, the criterion for reviewing the waiver is the collection of CEMS data showing that exhaust emissions have exceeded 70 percent of the level needed to meet the control efficiency requirement for seven, consecutive, averaging periods as specified by the applicable regulation(s) [e.g., 40 CFR 60.45(g)(2) and 40 CFR 60.45(g)(3), 40 CFR 60.73(e), and 40 CFR 60.84(e)]. It is the responsibility of the source operator to maintain records and determine the level of emissions relative to the criterion on the waiver of relative accuracy testing. If this criterion is exceeded, the owner or operator must notify the Department within 10 days of such occurrence and include a

Orlando Utilities Commission Indian River Plant Page 31 of 40

description of the nature and cause of the increasing emissions. The Department will review the notification and may rescind the waiver and require the owner or operator to conduct a relative accuracy test of the CEMS as specified in section 7 of Performance Specification 2. [Rule 62-296.800, F.A.C.; 40 CFR 60.13(j)].

Modifications

D.34. Except as provided under 40 CFR 60.14(e) and 40 CFR 60.14(f), any physical or operational change to an existing facility which results in an increase in the emission rate to the atmosphere of any pollutant to which a standard applies shall be considered a modification within the meaning of section 111 of the Act. Upon modification, an existing facility shall become an affected facility for each pollutant to which a standard applies and for which there is an increase in the emission rate to the atmosphere.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(a)].

- **D.35.** Emission rate shall be expressed as kg/hr (lbs./hour) of any pollutant discharged into the atmosphere for which a standard is applicable. The Department shall use the following to determine emission rate:
- (1) Emission factors as specified in the latest issue of "Compilation of Air Pollutant Emission Factors", EPA Publication No. AP-42, or other emission factors determined by the Department to be superior to AP-42 emission factors, in cases where utilization of emission factors demonstrate that the emission level resulting from the physical or operational change will either clearly increase or clearly not increase.
- (2) Material balances, continuous monitor data, or manual emission tests in cases where utilization of emission factors as referenced in 40 CFR 60.14(b)(1) does not demonstrate to the Department's satisfaction whether the emission level resulting from the physical or operational change will either clearly increase or clearly not increase, or where an owner or operator demonstrates to the Department's satisfaction that there are reasonable grounds to dispute the result obtained by the Department utilizing emission factors as referenced in 40 CFR 60.14(b)(1). When the emission rate is based on results from manual emission tests or continuous monitoring systems, the procedures specified in 40 CFR 60 appendix C of 40 CFR 60 shall be used to determine whether an increase in emission rate has occurred. Tests shall be conducted under such conditions as the Department shall specify to the owner or operator based on representative performance of the facility. At least three valid test runs must be conducted before and at least three after the physical or operational change. All operating parameters which may affect emissions must be held constant to the maximum feasible degree for all test runs.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(b)].

D.36. The addition of an affected facility to a stationary source as an expansion to that source or as a replacement for an existing facility shall not by itself bring within the applicability of 40 CFR 60 any other facility within that source.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(c)].

- **D.37.** The following shall not, by themselves, be considered modifications under 40 CFR 60:
- (1) Maintenance, repair, and replacement which the Department determines to be routine for a source category, subject to the provisions of 40 CFR 60.14(c) and 40 CFR 60.15.
- (2) An increase in production rate of an existing facility, if that increase can be accomplished without a capital expenditure on that facility.

Orlando Utilities Commission Indian River Plant Page 32 of 40

- (3) An increase in the hours of operation.
- (4) Use of an alternative fuel or raw material if, prior to the date any standard under 40 CFR 60 becomes applicable to that source type, as provided by 40 CFR 60.1, the existing facility was designed to accommodate that alternative use. A facility shall be considered to be designed to accommodate an alternative fuel or raw material if that use could be accomplished under the facility's construction specifications as amended prior to the change. Conversion to coal required for energy considerations, as specified in section 111(a)(8) of the Act, shall not be considered a modification.
- (5) The addition or use of any system or device whose primary function is the reduction of air pollutants, except when an emission control system is removed or is replaced by a system which the Department determines to be less environmentally beneficial.
- (6) The relocation or change in ownership of an existing facility. [Rule 62-296.800, F.A.C.; 40 CFR 60.14(e)].
- **D.38.** Special provisions set forth under an applicable subpart of 40 CFR 60 shall supersede any conflicting provisions of this section. [Rule 62-296.800, F.A.C.; 40 CFR 60.14(f)].
- **D.39.** Within 180 days of the completion of any physical or operational change subject to the control measures specified in 40 CFR 60.14(a), compliance with all applicable standards must be achieved.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(g)].

Orlando Utilities Commission Indian River Plant Page 33 of 40

Subsection E. Common Conditions II (Boilers and Combustion Turbines)

E.1. This subsection applies to the boilers and combustion turbines, Units 001 through 007.

Excess Emissions

E.2. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

E.3. Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.

[Rule 62-210.700(2), F.A.C.]

E.4. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

Test Methods and Procedures

- **E.5.** The Permittee shall conduct a compliance test on an *annual basis* for each of the following pollutants. Each compliance test shall be conducted in accordance with 40 CFR 60, Appendix A, using the method indicated.
 - a) Oxides of Nitrogen (NOx) EPA Method 20.
 - b) Carbon Monoxide (CO) EPA Method 10.
 - c) Beryllium (Be) EPA Method 104.
 - d) Particulate Matter (PM/PM₁₀) EPA Method 5.

An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

[Rule 62-297.310(7)(a)4. & 5., F.A.C.]

- **E.6.** The Permittee shall conduct a compliance test for each of the following pollutants *prior to obtaining a renewed operation permit.* Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy this requirement. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of compliance test results for any emissions unit that, during the year prior to renewal: a) did not operate; or b) in the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours. Each compliance test shall be conducted in accordance with 40 CFR 60 Appendix A, using the method indicated.
 - a) Sulfur Dioxide (SO₂) EPA Method 6 or ASTM D 2880-71 for sulfur in oil.
 - b) Particulate Matter (PM/PM₁₀) EPA Method 5.
 - c) Volatile Organic Compounds (VOC) EPA Method 25.

1.0

Orlando Utilities Commission Indian River Plant Page 34.of 40

[Rule 62-297.310(7)(a)3., F.A.C.]

E.7. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of OUC, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

E.8. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]

E.9. Applicable Test Procedures.

- (a) Required Sampling Time.
- 1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.
 - 2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:
 - a. (not applicable)
 - b. (not applicable)
 - c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.
- (b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.
- (c) <u>Required Flow Rate Range</u>. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

Orlando Utilities Commission Indian River Plant Page 35 of 40

- (d) <u>Calibration of Sampling Equipment</u>. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1. (See attachment.)
- (e) <u>Allowed Modification to EPA Method 5</u>. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]
- **E.10.** Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require OUC to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

 [Rule 62-297.310(7)(b), F.A.C., SIP approved]
- **E.11.** Waiver of Compliance Test Requirements. If OUC is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7)(c), F.A.C., SIP approved]

E.12. COMS for Periodic Monitoring. OUC shall install continuous opacity monitoring systems (COMS) pursuant to 40 CFR Part 75. OUC shall maintain and operate the COMS and shall make and maintain records of opacity measured by the COMS, for purposes of periodic monitoring. [Rule 62-213.440, F.A.C., and applicant requested]

Orlando Utilities Commission Indian River Plant Page 36 of 40

Subsection F. Lime Storage Silo

E.U. ID

No. Brief Description
United Storage Silo

Emissions unit 008 is a lime storage silo filling system. The silo is equipped with a fabric filter baghouse made by General Resource Corporation, Model 13204.8. The baghouse is approximately 99 percent efficient to control particulate emissions. This source is located at the water treatment building. The silo began operation February 25, 1993.

Essential Potential to Emit (PTE) Parameters

F.1. Capacity.

- (a) This silo is permitted to be loaded 14 hours per week.
- (b) The maximum permitted loading rate is ten (10) tons per hour.
- (c) The facility is required to keep records of the operating hours and loading rate. [Rules 62-4.160(2), 62-210.200 (PTE), 62-213.440(1)(b)1.b., F.A.C., and AO05-229996]

Emission Limitations and Standards

- **F.2.** (a) No owner or operator of an emissions unit source governed by Rule 62-296.711, F.A.C., shall cause, permit, or allow any visible emissions (five percent opacity) from such emissions unit.
- (b) If, in order to comply with the requirements of paragraph (a) above, it is necessary to totally or partially enclose an operation and exhaust particulate laden gases through a vent or stack, emissions of particulate from such vent or stack shall not exceed 0.03 gr/dscf.
- (c) An owner or operator may request the Department to determine that the emission standards of Rule 62-296.711(2)(a) and (b), F.A.C., do not constitute RACT for a facility. If the Department finds that the emission standards do not represent RACT, the Department shall make a determination of RACT for that facility.

[Rule 62-296.711, F.A.C.]

- **F.3.** <u>Unconfined Emissions.</u> Particulate matter emissions from plant grounds, including the transfer point at which materials are loaded into trucks shall be subject to the following:
- a) Area must be watered down should unconfined emissions occur.
- b) The loading operation shall be maintained and properly operated.

[Rule 62-296.320(4)(c), F.A.C., and AO05-229996]

Test Methods and Procedures

- **F.4.** (a) An annual test method for visible emissions shall be performed. The test method shall be EPA Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C.
- (b) A visible emissions test indicating no visible emissions (5 percent opacity)may be submitted in lieu of a particulate stack test for materials handling emissions units subject to this rule, where the emissions unit is equipped with a baghouse.
- (c) The permittee must perform and record the results of a qualitative observation of opacity (40 C.F.R. Part 60, Method 22) at least once on each day while the loading operations are taking place. The records of these observations should indicate whether or not any abnormal visible emissions are detected and include color, duration, and density of the plume, as well as the cause and

Orlando Utilities Commission Indian River Plant Page 37 of 40

corrective action taken for any abnormal visible emissions. If an abnormal visible emission is detected, a Method 9 survey shall be conducted during lime loading operations, within 24 hours of the qualitative survey. If lime filling does not occur within 24 hours of the detected visible emission, a Method 9 survey shall occur at the next time the silo is loaded.

- (d) Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C. [Rules 62-213.440(1)(b)1.b. and 62-297, F.A.C.]
- **F.5.** <u>DEP Method 9</u>. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:
- 1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.
- 2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:
 - a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
 - b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value. [Rule 62-297.401, F.A.C.]

F.6. Operating Rate During Testing. Unless otherwise stated in the applicable emission limiting standard rule, testing of emissions shall be conducted with the emissions unit operating at 90 to 100 percent of the maximum operation rate allowed by permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rule 62-297.310(2), F.A.C.]

F.7. Required Sampling Time.

Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per

Orlando Utilities Commission Indian River Plant Page 38 of 40

year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows: For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time. [Rule 62-297.310(4)(a)(2)a., F.A.C.]

F.8. During compliance testing, the silo must be operated at the highest pressure and filling rate ever intended to be used. The process rate achieved during the compliance test must be recorded on the visible emission test report.

[Rule 62-4.070(3), F.A.C., and AO05-229996]

Reporting and Recordkeeping

- **F.9.** OUC shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for OUC. [Rule 62-297.310(7)(a)9., F.A.C.,]
- **F.10.** The required test report shall be filed with this office as soon as practical but no later than 45 days after the last sampling run of each test is completed.

Each calendar year on or before March 1, submit an Annual Operations Report DEP Form 62-210.900(4) for the preceding calendar year. [Rule 62-297.310(8)(b), F.A.C, and AO05-229996]

F.11. OUC shall keep records of the operating hours and process loading rate of the lime storage silo to encontinuous compliance with the limits in specific condition F.1. [Rules 62-4.160(2), 62-210.200 (PTE), and 62-4.070(3), F.A.C.]

Qualitative Opacity Monitoring

F.12. OUC shall perform and record the results of a qualitative observation of opacity (40 CFR 60, Method 22) a least once on each day while the loading operations are taking place. The records of these observations should indicate whether or not any visible emissions are detected and include color, duration and density of the plume, a well as the cause and corrective action taken for any visible emissions. If a visible emission is detected, correctiv action should be taken and a Method 9 observation shall be conducted during lime loading operations, within 24 hours of the qualitative survey. If lime loading does not occur within 24 hours of the detected visible emission a Method 9 observation shall be conducted the next time the silo is loaded. {Permitting note: It is presumed that t threshold of visibility for opacity is equal to 5%.}

[Rules 62-213.440 and 62-4.070(3), F.A.C.]

Orlando Utilities Commission Indian River Plant Page 39 of 40

IV. Acid Rain Part

Indian River Plant

Operated by: Orlando Utilities Commission

ORIS code: 683

The emissions units listed below are regulated under Acid Rain Part, Phase II.

E.U.

<u>ID No.</u>	<u>Description</u>
001	87 MW Unit No.1 Boiler [EPA ID #: 1]
002	188 MW Unit No.2 Boiler [EPA ID #: 2]
003	328 MW Unit No.3 Boiler [EPA ID #: 3]
005	129 MW Simple Cycle Combustion Turbine C [EPA ID #: C]
006	129 MW Simple Cycle Combustion Turbine D [EPA ID #: D]

- 1. The Acid Rain Part application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these acid rain units must comply with the standard requirements and special provisions set forth in the application listed below:
- a. DEP Form No.62-210.900(1)(a), version 07/01/95, received June 17, 1996. [Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

2. Sulfur dioxide (SO₂) allowance allocations for each Acid Rain unit:

E.U. ID No.	EPA ID#	Year	2000	2001	2002	2003	2004
001	1	SO2 allowances, under Table 2 of 40 CFR 73	1180*	1180*	1180*	1180*	1180*
002	2	SO2 allowances, under Table 2 of 40 CFR 73	1555*	1555*	1555*	1555*	1555*
003	3	SO2 allowances, under Table 2 of 40 CFR 73	3612*	3612*	3612*	3612*	3612*
005	С	SO2 allowances, under Table 2 of 40 CFR 73	0*.	0*	0*	0*	0*
.006	D	SO2 allowances, under Table 3 of 40 CFR 73	634*	634*	634*	634*	634*

^{*}The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the US EPA under Table 2 or 3 of 40 CFR 73.

- 3. Comments, notes, and justifications: Phase II Permit Application received 1/2/96.
- 4. <u>Emission Allowances</u>. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain

Orlando Utilities Commission Indian River Plant Page 40 of 40

Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
- b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
- c. Allowances shall be accounted for under the Federal Acid Rain Program. [Rule 62-213.440(1)(c)1., 2. & 3., F.A.C.]
- 5. <u>Statement of Compliance</u>. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year. {See condition No.51., Appendix TV-3, Title V Conditions.} [Rule 62-214.420(11), F.A.C.]
- 6. Where an applicable requirement of the Act is more stringent than applicable regulations promulgated under Title IV of the Act, both provisions shall be incorporated into the permit and shall be enforceable by the Administrator.

[40 CFR 70.6(a)(1)(ii); and, Rule 62-210.200, F.A.C., Definitions – Applicable Requirements.]

Appendix H-1, Permit History/ID Number Changes

Orlando Utility Commission Indian River Plant FINAL Permit No. 0090008-001-AV Facility ID No. 0090008

Permit History: E.U.						
ID No	Description	Permit No.	<u>Issue</u>	Expiration	Extended	Revised Dates
			Date	<u>Date</u>	Date ¹	
001, 002, & 003	Boiler Units No. 1, 2, & 3	OGC FILE NO.	03/13/89		-	
		88-1257, 88-1258, & 88-1259				
		AO05-183384	04/26/91	04/15/96	08/14/96	
004 & 007	35 MW Combustion Turbines A & B	AC05-144482, AC05-146749	09/01/88	01/31/92		12/18/89
		PSD-FL-130	09/01/88			12/18/89
		AO05-176351	07/30/90	07/25/95	08/14/96	
005 & 006	129 MW Combustion Turbines C & D	AC05-146750, AC05-146751	09/01/88	01/31/92		12/18/89, 11/05/91
		PSD-FL-130	09/01/88			12/18/89, 11/05/91
		AC05-193720	11/05/91	06/30/93		05/10/94, 08/24/95
		PSD-FL-173	11/05/91			05/10/94, 08/24/95
		ASP 92-0-01	12/16/92			
		AO05-229084	09/21/93	08/30/98		
		OGC FILE NO.	05/22/96			
		94-3376-C-05				
008	Lime Storage Silo	AO05-229996	06/03/93	05/30/98		

ID Number Changes:

From: Facility ID No. 30ORL050008

To: Facility ID No. 0090008

Notes: 1 - AO permits automatic extensions in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.

{Rule 62-213.420(1)(b)2., F.A.C., allows Title V Sources to operate under existing valid permits that were in effect at the time of application until the Title V permit becomes effective.}

Table 1-1, Summary of Air Pollutant Standards and Terms

Orlando Utilities Commission

Indian River Plant

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 001, 002, 003

Boilers 1, 2, and 3

			Allowabl	e Emissions		Equivalent Emissions*			See Permit
Pollutant/Parameter	Fuel	Hours/Year	Standards	lbs./hour	TPY	lbs./hour	TPY	Regulatory Citations	Condition
SO2	All	8,400	2.75 lbs/MMBtu					Rule 62-296.405(1)(c)1.j	III. A.9
РМ	All		0.1 lbs/MMBtu 0.3 lbs/MMBtu for 3hr. per 24 hours (sootblowing)		·			Rule 62-296.405(1)(b) Rule 62-210.700(3)	III: A.7 III. A.8
VE	All		20%; 40%@ 2min/hr. 60% for 3hr./24 hours (sootblowing)				n/a	Rule 62-296 405(1)(a) Rule 62-210 700(3)	III. A.5 III. A.6
			·						

^{** --} Annual emissions (TPY) based on 3 hours per day at 0.3 lb/mmBtu and 21 hours per day at 0.1lb/MMBtu.

^{* --} Equivalent Emissions provided for information only.

Table 1-1, Summary of Air Pollutant Standards and Terms

Orlando Utilities Commission

Indian River Plant

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 004, 007

Combustion Turbines A and B

			Allowab	le Emissions		Equivalent	Emissions*	•	See Permit
Pollutant/Parameter	Fuel	Hours/Year	lbs/hour/unit	TPY/unit	TPY/2 units	lbs./hour	TPY	Regulatory Citations	Condition
SO2	Gas	8,760	0.34	1.5	3			PSD-FL-130	III. B.4
•	Oil		143	625	1250	285.4	1250		
NOx	Gas		75	329	658			PSD-FL-130	III. B.4
	Oil		118	518	1037	237	1037		
VE	Gas		5% opacity				n/a	PSD-FL-130	III. B.5
	Oil		10% opacity						

^{** --} Annual émissions (TPY) based on 3 hours per day at 0.3 lb/mmBtu and 21 hours per day at 0.1 lb/MMBtu.

^{* --} Equivalent Emissions provided for information only.

Table 1-1, Summary of Air Pollutant Standards and Terms

Orlando Utilities Commission Indian River Plant

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 005, 006

Combustion Turbines C and D

				Allowable Emiss	•		See Permit	
Pollutant/Parameter	Fuel	Hours/Year	Standard	TPY/unit	TPY/2 units	lbs./hour / unit	Regulatory Citations	Condition
SO2	Gas	4,380	0.3% Sulfur Fuel	1.05	2.10	0.5	PSD-FL-173	III.C.5
	Oil		0.3% Sulfur Fuel	476.5	953	217.6		
NOx	Gas		25 ppm@15% O2	295.75	591.5	135.0	PSD-FL-173	III.C.5
	Oil		42 ppm@15% O2	253	506	115.5		
							•	
			400/				4.005.400500	
VE	Gas		10% opacity				AC05-193720	III.C.6
	Oil		10% opacity					
PM/PM10	Gas		0.003 lb/MMBtu	9.75		4.5		
FIVITEIVITO	Oil		0.003 lb/MMBtu	118.5		54.1		
·	Oii		U.OU ID/IVIIVID (U	110.5		54.1		
со	Gas		25 ppmvd	156.5		71.5		
	Oil		25 ppmvd	79.5		36.3		
			••					
voc	Gas		5 ppmvd	18.5		8.4		
	Oil		15 ppmvd	56		25.6		
						,		
Sulfurc Acid Mist	Gas			0.035		0.02		
	Oil			14.25		6.5		
						.		

Table 1-1, Summary of Air Pollutant Standards and Terms

Orlando Utilities Commission

FINAL Permit # 0090008-001-AV Facility ID # 0090008

Indian River Plant

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 008

Lime Storage Silo

		Allowable Emissions	Equivalent Emissions			See Permit
Pollutant	Process Rate		lbs./hour	TPY	Regulatory Citations	Condition
Particulate Matter	10 tons per hour	0.03 gr/dscf	n/a	n/a	Rule 62-296.711	III.F.2.
Visible Emissions	10 tons per hour	5% Opacity	n/a	n/a	Rule 62-296.711	III.F.2.
					·	
Notes:						

Table 2-1, Summary of Compliance Requirements

Orlando Utilities Commission Indian River Plant

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 001, 002, 003

Boilers 1, 2, and 3

			Frequency	Frequency	Min. Compliance		
Pollutant/		Compliance	of	Base ·	Test		. Permit
Parameter	Fuel	Method	Sampling	Date *	Duration	CMS**	Condition
SO2	All Fuels	Fuel sampling & analysis	Daily sampling of as-fired fuel	1-Oct			III. A.16
PM	All Fuels	EPA Method 5 or 17	annual	001: 1-Oct 002 & -003: 23-Aug			III. A.15
VE	All Fuels	DEP Method 9	annuạl	001: 1-Oct 002 & -003: 23-Aug	1 hour		III. A.13

^{*}Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

^{**}CMS = continuous monitoring system

Table 2-1, Summary of Compliance Requirements

Orlando Indian River Plant FINAL Permit # 0870003-001-AV Facility ID # 0870003

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 004, 007

Combustion Turbines A and B

			Frequency	Frequency	Min. Compliance		
Pollutant/		Compliance	of	Base	Test	-	Permit
Parameter	Fuel	Method	Sampling	Date *	Duration	CMS**	Condition
SO2	#2 oil	Fuel sampling & analysis	Daily sampling of as-fired fuel	Per 40 CFR 60.334(b)			III.D.3, D.8 & D.12
	gas						III.D.8
VE	#2 oil	EPA Method 9	annual	20-Jan			III.B.5
NOx	#2 oil	EPA Method 20	annual	20-Jan			III.D.8, D.11
	gas						

^{*}Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

^{**}CMS = continuous monitoring system

Table 2-1, Summary of Compliance Requirements

Orlando Indian River Plant FINAL Permit # 0870003-001-AV Facility ID # 0870003

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 005, 006

Combustion Turbines C and D

		·					1
			Frequency	Frequency	Min. Compliance		
Pollutant/		Compliance	of	Base	Test		Permit
Parameter	Fuel	Method	Sampling	Date *	Duration	CMS	Condition
SO2	#2 oil	Fuel sampling & analysis	After each fuel oil shipment	Per 40 CFR 60.335			III.D.3, D.8 & D.12
	gas		-				III.D.8
VE	#2 oil gas	EPA Method 9	annual	20-Jan			III.C.6
со	#2 oil gas	EPA Method 10	annual	20-Jan			III.C.9.
NOx	#2 oil gas	EPA Method 20**	annual	20-Jan			III.D.8, D.11.
PM/PM10	#2 oil gas	none					
voc		***					III.C.7.

^{*}Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

^{**}With ASP for revised Method 1

^{***} Compliance with total VOC emission limits will be assumed, provided the CO allowable emission rate is achieved. PSD-FL-173

Table 2-1, Summary of Compliance Requirements

Orlando Utilities Commission Indian River Plant

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 008

Lime Storage Silo

Pollutant/ Parameter	Material	Compliance Method	Frequency of Sampling	Frequency Base Date*	Min. Compliance Test Duration	CMS**	Permit Condition
PM VE	Lime Lime	VE Test in lieu of PM test since source has baghouse DEP Method 9	annual	1-Mar 1-Mar	30 minutes or one batch cycle 30 minutes or one batch cycle	n/a	III.F.4. III.F.4.
			·				

^{*}Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

^{**}CMS = continuous monitoring system

APPENDIX TV-3, TITLE V CONDITIONS (version dated 04/30/99)

[Note: This attachment includes "canned conditions" developed from the "Title V Core List."]

{Permitting note: APPENDIX TV-3, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}

Chapter 62-4. F.A.C.

1. Not federally enforceable. General Prohibition. Any stationary installation which will reasonably be expected to be a source of pollution shall not be operated, maintained, or modified without the appropriate and valid permits issued by the Department, unless the source is exempted by Department rule. The Department may issue a permit only after it receives reasonable assurance that the installation will not cause pollution in violation of any of the provisions of Chapter 403, F.S., or the rules promulgated thereunder. A permitted installation may only be operated, maintained, constructed, expanded or modified in a manner that is consistent with the terms of the permit.

[Rule 62-4.030, Florida Administrative Code (F.A.C.); Section 403.087, Florida Statute (F.S.)]

- 2. Not federally enforceable. Procedure to Obtain Permits: Application.
- (1) Any person desiring to obtain a permit from the Department shall apply on forms prescribed by the Department and shall submit such additional information as the Department by law may require.
- (2) All applications and supporting documents shall be filed in quadruplicate with the Department.
- (3) To ensure protection of public health, safety, and welfare, any construction, modification, or operation of an installation which may be a source of pollution shall be in accordance with sound professional engineering practices pursuant to Chapter 471, F.S. All applications for a Department permit shall be certified by a professional engineer registered in the State of Florida except when the application is for renewal of an air pollution operation permit at a minor facility as defined in Rule 62-210.200, F.A.C., or where professional engineering is not required by Chapter 471, F.S. Where required by Chapter 471 or 492, F.S., applicable portions of permit applications and supporting documents which are submitted to the Department for public record shall be signed and sealed by the professional(s) who prepared or approved them.
- (4) Processing fees for air construction permits shall be in accordance with Rule 62-4.050(4), F.A.C.
- (5)(a) To be considered by the Department, each application must be accompanied by the proper processing fee. The fee shall be paid by check, payable to the Department of Environmental Protection. The fee is non-refundable except as provided in Section 120.60, F.S., and in this section.
 - (c) Upon receipt of the proper application fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin.
 - (d) If the applicant does not submit the required fee within ten days of receipt of written notification, the Department shall either return the unprocessed application or arrange with the applicant for the pick up of the application.
 - (e) If an applicant submits an application fee in excess of the required fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin upon receipt, and the Department shall refund to the applicant the amount received in excess of the required fee.
- (6) Any substantial modification to a complete application shall require an additional processing fee determined pursuant to the schedule set forth in Rule 62-4.050, F.A.C., and shall restart the time requirements of Sections 120.60 and 403.0876, F.S. For purposes of this Subsection, the term "substantial modification" shall mean a modification which is reasonably expected to lead to substantially different environmental impacts which require a detailed review.
- (7) Modifications to existing permits proposed by the permittee which require substantial changes in the existing permit or require substantial evaluation by the Department of potential impacts of the proposed modifications shall require the same fee as a new application.

[Rule 62-4.050, F.A.C.]

3. <u>Standards for Issuing or Denving Permits</u>. Except as provided at Rule 62-213.460, F.A.C., the issuance of a permit does not relieve any person from complying with the requirements of Chapter 403, F.S., or Department rules. [Rule 62-4.070(7), F.A.C.]

4. Modification of Permit Conditions.

- (1) For good cause and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions and on application of the permittee the Department may grant additional time. For the purpose of this section, good cause shall include, but not be limited to, any of the following: (also, see Condition No. 38)
 - (a) A showing that an improvement in effluent or emission quality or quantity can be accomplished because of technological advances without unreasonable hardship.
 - (b) A showing that a higher degree of treatment is necessary to effect the intent and purpose of Chapter 403, F.S.
 - (c) A showing of any change in the environment or surrounding conditions that requires a modification to conform to applicable air or water quality standards.
 - (e) Adoption or revision of Florida Statutes, rules, or standards which require the modification of a permit condition for compliance.
- (2) A permittee may request a modification of a permit by applying to the Department.
- (3) A permittee may request that a permit be extended as a modification of the permit. Such a request must be submitted to the Department in writing before the expiration of the permit. Upon timely submittal of a request for extension, unless the permit automatically expires by statute or rule, the permit will remain in effect until final agency action is taken on the request. For construction permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that, upon completion, the extended permit will comply with the standards and conditions required by applicable regulation. For all other permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that the extended permit will comply with the standards and conditions applicable to the original permit. A permit for which the permit application fee was prorated in accordance with Rule 62-4.050(4)(1), F.A.C., shall not be extended. In no event shall a permit be extended or remain in effect longer than the time limits established by statute or rule.

[Rule 62-4.080, F.A.C.]

5. Renewals. Prior to one hundred eighty (180) days before the expiration of a permit issued pursuant to Chapter 62-213, F.A.C., the permittee shall apply for a renewal of a permit using forms incorporated by reference in the specific rule chapter for that kind of permit. A renewal application shall be timely and sufficient. If the application is submitted prior to 180 days before expiration of the permit, it will be considered timely and sufficient. If the renewal application is submitted at a later date, it will not be considered timely and sufficient unless it is submitted and made complete prior to the expiration of the operation permit. When the application for renewal is timely and sufficient, the existing permit shall remain in effect until the renewal application has been finally acted upon by the Department or, if there is court review of the Department's final agency action, until a later date is required by Section 120.60, F.S., provided that, for renewal of a permit issued pursuant to Chapter 62-213, F.A.C., the applicant complies with the requirements of Rules 62-213.420(1)(b)3. and 4., F.A.C. [Rule 62-4.090(1), F.A.C.]

6. Suspension and Revocation.

- (1) Permits shall be effective until suspended, revoked, surrendered, or expired and shall be subject to the provisions of Chapter 403, F.S., and rules of the Department.
- (2) Failure to comply with pollution control laws and rules shall be grounds for suspension or revocation.
- (3) A permit issued pursuant to Chapter 62-4, F.A.C., shall not become a vested property right in the permittee. The Department may revoke any permit issued by it if it finds that the permit holder or the permit holder's agent:
 - (a) Submitted false or inaccurate information in application or operational reports.
 - (b) Has violated law, Department orders, rules or permit conditions.
 - (c) Has failed to submit operational reports or other information required by Department rules.
 - (d) Has refused lawful inspection under Section 403.091, F.S.

[Rule 62-4.100, F.A.C.]

7. Not federally enforceable. <u>Financial Responsibility</u>. The Department may require an applicant to submit proof of financial responsibility and may require the applicant to post an appropriate bond to guarantee compliance with the law and Department rules. [Rule 62-4.110, F.A.C.]

8. Transfer of Permits.

- (1) Within 30 days after the sale or legal transfer of a permitted facility, an "Application for Transfer of Permit" (DEP Form 62-1.201(1)) must be submitted to the Department. This form must be completed with the notarized signatures of both the permittee and the proposed new permittee.
- (2) The Department shall approve the transfer of a permit unless it determines that the proposed new permittee cannot provide reasonable assurances that conditions of the permit will be met. The determination shall be limited solely to the ability of the new permittee to comply with the conditions of the existing permit, and it shall not concern the adequacy of these permit conditions. If the Department proposes to deny the transfer, it shall provide both the permittee and the proposed new permittee a written objection to such transfer together with notice of a right to request a Chapter 120, F.S., proceeding on such determination.
- (3) Within 30 days of receiving a properly completed Application for Transfer of Permit form, the Department shall issue a final determination. The Department may toll the time for making a determination on the transfer by notifying both the permittee and the proposed new permittee that additional information is required to adequately review the transfer request. Such notification shall be served within 30 days of receipt of an Application for Transfer of Permit form, completed pursuant to Rule 62-1.120(1), F.A.C. If the Department fails to take action to approve or deny the transfer within 30 days of receipt of the completed Application for Transfer of Permit form, or within 30 days of receipt of the last item of timely requested additional information, the transfer shall be deemed approved.
- (4) The permittee is encouraged to apply for a permit transfer prior to the sale or legal transfer of a permitted facility. However, the transfer shall not be effective prior to the sale or legal transfer.
- (5) Until this transfer is approved by the Department, the permittee and any other person constructing, operating, or maintaining the permitted facility shall be liable for compliance with the terms of the permit. The permittee transferring the permit shall remain liable for corrective actions that may be required as a result of any violations occurring prior to the sale or legal transfer of the facility.

[Rule 62-4.120, F.A.C.]

9. Plant Operation-Problems. If the permittee is temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by hazard of fire, wind or by other cause, the permittee shall immediately notify the Department. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules. (also, see Condition No. 10)

[Rule 62-4.130, F.A.C.]

- 10. For purposes of notification to the Department pursuant to Condition No. 9, Condition No. 12(8), and Rule 62-4.130, F.A.C., Plant Operation-Problems, "immediately" shall mean the same day, if during a workday (i.e., 8:00 a.m. 5:00 p.m.), or the first business day after the incident, excluding weekends and holidays; and, for purposes of 40 CFR 70.6(a)(3)(iii)(B), "prompt" shall have the same meaning as "immediately". [also, see Conditions Nos. 9 and 12(8)] [40 CFR 70.6(a)(3)(iii)(B)]
- 11. Not federally enforceable. Review. Failure to request a hearing within 14 days of receipt of notice of proposed or final agency action on a permit application or as otherwise required in Chapter 62-103, F.A.C., shall be deemed a waiver of the right to an administrative hearing.

[Rule 62-4.150, F.A.C.]

- 12. Permit Conditions. All permits issued by the Department shall include the following general conditions:
- (1) The terms, conditions, requirements, limitations and restrictions set forth in this permit, are "permit conditions" and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861. F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
- (2) This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
- (3) As provided in subsections 403.087(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.

- (4) This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- (5) This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of F.S. and Department rules, unless specifically authorized by an order from the Department.
- (6) The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- (7) The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
 - (a) Have access to and copy any records that must be kept under conditions of the permit;
 - (b) Inspect the facility, equipment, practices, or operations regulated or required under this permit; and,
 - (c) Sample or monitor any substances or parameters at any location reasonable necessary to assure compliance with this permit or Department rules. Reasonable time may depend on the nature of the concern being investigated.
- (8) If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information: (also, see Condition No. 10)
 - (a) A description of and cause of noncompliance; and,
 - (b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.
- (9) In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the F.S. or Department rules, except where such use is prescribed by Sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- (10) The permittee agrees to comply with changes in Department rules and F.S. after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by F.S. or Department rules.
- (11) This permit is transferable only upon Department approval in accordance with Rule 62-4.120, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- (12) This permit or a copy thereof shall be kept at the work site of the permitted activity.
- (14) The permittee shall comply with the following:
 - (a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
 - (b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least five (5) years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
 - (c) Records of monitoring information shall include:
 - 1. the date, exact place, and time of sampling or measurements;
 - 2. the person responsible for performing the sampling or measurements;
 - 3. the dates analyses were performed:
 - 4. the person responsible for performing the analyses;
 - 5. the analytical techniques or methods used: and.
 - 6. the results of such analyses.
- (15) When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly. [Rules 62-4.160 and 62-213.440(1)(b), F.A.C.]

13. Construction Permits.

- (1) No person shall construct any installation or facility which will reasonably be expected to be a source of air or water pollution without first applying for and receiving a construction permit from the Department unless exempted by statute or Department rule. In addition to the requirements of Chapter 62-4, F.A.C., applicants for a Department Construction Permit shall submit the following as applicable:
 - (a) A completed application on forms furnished by the Department.
 - (b) An engineering report covering:
 - I. plant description and operations.
 - 2. types and quantities of all waste material to be generated whether liquid, gaseous or solid,
 - 3. proposed waste control facilities.
 - 4. the treatment objectives,
 - 5. the design criteria on which the control facilities are based, and,
 - 6. other information deemed relevant.

Design criteria submitted pursuant to Rule 62-4.210(1)(b)5., F.A.C., shall be based on the results of laboratory and pilot-plant scale studies whenever such studies are warranted. The design efficiencies of the proposed waste treatment facilities and the quantities and types of pollutants in the treated effluents or emissions shall be indicated. Work of this nature shall be subject to the requirements of Chapter 471, F.S. Where confidential records are involved, certain information may be kept confidential pursuant to Section 403.111, F.S.

- (c) The owners' written guarantee to meet the design criteria as accepted by the Department and to abide by Chapter 403, F.S. and the rules of the Department as to the quantities and types of materials to be discharged from the installation. The owner may be required to post an appropriate bond or other equivalent evidence of financial responsibility to guarantee compliance with such conditions in instances where the owner's financial resources are inadequate or proposed control facilities are experimental in nature.
- (2) The construction permit may contain conditions and an expiration date as determined by the Secretary or the Secretary's designee.
- (3) When the Department issues a permit to construct, the permittee shall be allowed a period of time, specified in the permit, to construct, and to operate and test to determine compliance with Chapter 403, F.S., and the rules of the Department and, where applicable, to apply for and receive an operation permit. The Department may require tests and evaluations of the treatment facilities by the permittee at his/her expense.

 [Rule 62-4.210, F.A.C.]
- 14. Not federally enforceable. Operation Permit for New Sources. To properly apply for an operation permit for new sources, the applicant shall submit certification that construction was completed noting any deviations from the conditions in the construction permit and test results where appropriate.

 [Rule 62-4.220, F.A.C.]

Chapters 28-106 and 62-110. F.A.C.

- 15. <u>Public Notice. Public Participation.</u> and <u>Proposed Agency Action</u>. The permittee shall comply with all of the requirements for public notice, public participation, and proposed agency action pursuant to Rule 62-110.106 and Rule 62-210.350, F.A.C. [Rules 62-110.106, 62-210.350 and 62-213.430(1)(b), F.A.C.]
- 16. <u>Administrative Hearing</u>. The permittee shall comply with all of the requirements for a petition for administrative hearing or waiver of right to administrative proceeding pursuant to Rules 28-106.201, 28-106.301 and 62-110.106, F.A.C. [Rules 28-106.201, 28-106.301 and 62-110.106, , F.A.C.]

Chapter 62-204. F.A.C.

17. <u>Asbestos.</u> This permit does not authorize any demolition or renovation of the facility or its parts or components which involves asbestos removal. This permit does not constitute a waiver of any of the requirements of Chapter 62-257, F.A.C., and 40 CFR Part 61. Subpart M. National Emission Standard for Asbestos, adopted and incorporated by reference in Rule 62-204,800, F.A.C. Compliance with Chapter 62-257, F.A.C., and 40 CFR 61. Subpart M. Section 61.145, is required for any asbestos demolition or renovation at the source.

[40 CFR 61: Rule 62-204.800, F.A.C.; and, Chapter 62-257, F.A.C.]

Chapter 62-210, F.A.C.

- 18. Permits Required. The owner or operator of any emissions unit which emits or can reasonably be expected to emit any air pollutant shall obtain an appropriate permit from the Department prior to beginning construction, modification, or initial or continued operation of the emissions unit unless exempted pursuant to Department rule or statute. All emissions limitations, controls, and other requirements imposed by such permits shall be at least as stringent as any applicable limitations and requirements contained in or enforceable under the State Implementation Plan (SIP) or that are otherwise federally enforceable. Except as provided at Rule 62-213.460, F.A.C., issuance of a permit does not relieve the owner or operator of an emissions unit from complying with any applicable requirements, any emission limiting standards or other requirements of the air pollution rules of the Department or any other such requirements under federal, state, or local law.
- (1) Air Construction Permits.
 (a) Unless exempt from permitting pursuant to Rule 62-210.300(3)(a) or (b), F.A.C., or Rule 62-4.040, F.A.C., an air construction permit shall be obtained by the owner or operator of any proposed new or modified facility or emissions unit prior to the beginning of construction or modification, in accordance with all applicable provisions of this chapter, Chapter 62-212, F.A.C., and Chapter 62-4, F.A.C. Except as provided under Rule 62-213.415, F.A.C., the owner or operator of any facility seeking to create or change an air emissions bubble shall obtain an air construction permit in accordance with all the applicable provisions of this chapter, Chapter 62-212, F.A.C., and Chapter 62-4, F.A.C. The construction permit shall be issued for a period of time sufficient to allow construction or modification of the facility or emissions unit and operation while the new or modified facility or emissions unit is conducting tests or otherwise demonstrating initial compliance with the conditions of the construction permit.
 - (b) Notwithstanding the expiration of an air construction permit, all limitations and requirements of such permit that are applicable to the design and operation of the permitted facility or emissions unit shall remain in effect until the facility or emissions unit is permanently shut down, except for any such limitation or requirement that is obsolete by its nature (such as a requirement for initial compliance testing) or any such limitation or requirement that is changed in accordance with the provisions of Rule 62-210.300(1)(b)1., F.A.C. Either the applicant or the Department can propose that certain conditions be considered obsolete. Any conditions or language in an air construction permit that are included for informational purposes only, if they are transferred to the air operation permit, shall be transferred for informational purposes only and shall not become enforceable conditions unless voluntarily agreed to by the permittee or otherwise required under Department rules.
 - 1. Except for those limitations or requirements that are obsolete, all limitations and requirements of an air construction permit shall be included and identified in any air operation permit for the facility or emissions unit. The limitations and requirements included in the air operation permit can be changed, and thereby superseded, through the issuance of an air construction permit, federally enforceable state air operation permit, federally enforceable air general permit, or Title V air operation permit; provided, however, that:
 - a. Any change that would constitute an administrative correction may be made pursuant to Rule 62-210.360, F.A.C.;
 - b. Any change that would constitute a modification, as defined at Rule 62-210.200, F.A.C., shall be accomplished only through the issuance of an air construction permit; and
 - c. Any change in a permit limitation or requirement that originates from a permit issued pursuant to 40 CFR 52.21, Rule 62-204.800(10)(d)2., F.A.C., Rule 62-212.400, F.A.C., Rule 62-212.500, F.A.C., or any former codification of Rule 62-212.400 or 62-212.500, F.A.C., shall be accomplished only through the issuance of a new or revised air construction permit under Rule 62-204.800(10)(d)2., F.A.C., 62-212.400 or 62-212.500, F.A.C., as appropriate.
 - 2. The force and effect of any change in a permit limitation or requirement made in accordance with the provisions of Rule 62-210.300(1)(b)1. F.A.C., shall be the same as if such change were made to the original air construction permit.
 - 3. Nothing in Rule 62-210.300(1)(b), F.A.C., shall be construed as to allow operation of a facility or emissions unit without a valid air operation permit.
- (2) Air Operation Permits. Upon expiration of the air operation permit for any existing facility or emissions unit, subsequent to construction or modification and demonstration of initial compliance with the conditions of the construction permit for any new or modified facility or emissions unit, or as otherwise provided in Chapter 62-210 or Chapter 62-213, the owner or operator of such facility or emissions unit shall obtain a renewal air operation permit, an initial air operation permit, or an administrative correction or revision of an existing air operation permit, whichever is appropriate, in accordance with all applicable provisions of Chapter 62-210, Chapter 62-213, and Chapter 62-4, F.A.C.
 - (a) Minimum Requirements for All Air Operation Permits. At a minimum, a permit issued pursuant to this subsection shall:
 - 1. Specify the manner, nature, volume and frequency of the emissions permitted, and the applicable emission limiting standards or performance standards, if any;
 - 2. Require proper operation and maintenance of any pollution control equipment by qualified personnel, where applicable in accordance with the provisions of any operation and maintenance plan required by the air pollution rules of the Department.

- 3. Contain an effective date stated in the permit which shall not be earlier than the date final action is taken on the application and be issued for a period, beginning on the effective date, as provided below.
 - a. The operation permit for an emissions unit which is in compliance with all applicable rules and in operational condition, and which the owner or operator intends to continue operating, shall be issued or renewed for a five-year period, except that, for Title V sources subject to Rule 62-213.420(1)(a)1., F.A.C., operation permits shall be extended until 60 days after the due date for submittal of the facility's Title V permit application as specified in Rule 62-213.420(1)(a)1., F.A.C.
 - b. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for six months or more prior to the expiration date of the current operation permit, shall be renewed for a period not to exceed five years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided:
 - (i) the owner or operator of the emissions unit demonstrates to the Department that the emissions unit may need to be reactivated and used, or that it is the owner's or operator's intent to apply to the Department for a permit to construct a new emissions unit at the facility before the end of the extension period; and.
 - (ii) the owner or operator of the emissions unit agrees to and is legally prohibited from providing the allowable emission permitted by the renewed permit as an emissions offset to any other person under Rule 62-212.500, F.A.C.; and,
 - (iii) the emissions unit was operating in compliance with all applicable rules as of the time the source was shut down.
 - c. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for five years or more prior to the expiration date of the current operation permit shall be renewed for a maximum period not to exceed ten years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided the conditions given in Rule 62-210.300(2)(a)3.b., F.A.C., are met and the owner or operator demonstrates to the Department that failure to renew the permit would constitute a hardship, which may include economic hardship.
 - d. The operation permit for an electric utility generating unit on cold standby or long-term reserve shutdown shall be renewed for a five-year period, and additional five-year periods, even if the unit is not maintained in operational condition, provided the conditions given in Rules 62-210.300(2)(a)3.b.(i) through (iii), F.A.C., are met.
- 4. In the case of an emissions unit permitted pursuant to Rules 62-210.300(2)(a)3.b., c., and d., F.A.C., include reasonable notification and compliance testing requirements for reactivation of such emissions unit and provide that the owner or operator demonstrate to the Department prior to reactivation that such reactivation would not constitute reconstruction pursuant to Rule 62-204.800(7), F.A.C.

[Rules 62-210.300(1) & (2), F.A.C.]

- 19. Not federally enforceable. Notification of Startup. The owner or operator of any emissions unit or facility which has a valid air operation permit and which has been shut down more than one (1) year, shall notify the Department in writing of the intent to start up such emissions unit or facility, a minimum of sixty (60) days prior to the intended startup date.
 - (a) The notification shall include the planned startup date, anticipated emission rates or pollutants released, changes to processes or control devices which will result in changes to emission rates, and any other conditions which may differ from the valid outstanding operation permit.
 - (b) If, due to an emergency, a startup date is not known 60 days prior thereto, the owner shall notify the Department as soon as possible after the date of such startup is ascertained.

[Rule 62-210.300(5), F.A.C.]

20. Emissions Unit Reclassification.

(a) Any emissions unit whose operation permit has been revoked as provided for in Chapter 62-4, F.A.C., shall be deemed permanently shut down for purposes of Rule 62-212.500. F.A.C. Any emissions unit whose permit to operate has expired without timely renewal or transfer may be deemed permanently shut down, provided, however, that no such emissions unit shall be deemed permanently shut down if, within 20 days after receipt of written notice from the Department, the emissions unit owner or operator demonstrates that the permit expiration resulted from inadvertent failure to comply with the requirements of Rule 62-4.090, F.A.C., and that the owner or operator intends to continue the emissions unit in operation, and either submits an application for an air operation permit or complies with permit transfer requirements, if applicable.

(b) If the owner or operator of an emissions unit which is so permanently shut down, applies to the Department for a permit to reactivate or operate such emissions unit, the emissions unit will be reviewed and permitted as a new emissions unit. [Rule 62-210.300(6), F.A.C.]

21. Public Notice and Comment.

- (1) Public Notice of Proposed Agency Action.
 - (a) A notice of proposed agency action on permit application, where the proposed agency action is to issue the permit, shall be published by any applicant for:
 - 1. An air construction permit;
 - 2. An air operation permit, permit renewal or permit revision subject to Rule 62-210.300(2)(b), F.A.C., (i.e., a FESOP), except as provided in Rule 62-210.300(2)(b)1.b., F.A.C.; or
 - 3. An air operation permit, permit renewal, or permit revision subject to Chapter 62-213, F.A.C., except those permit revisions meeting the requirements of Rule 62-213.412(1), F.A.C.
 - (b) The notice required by Rule 62-210.350(1)(a), F.A.C., shall be published in accordance with all otherwise applicable provisions of Rule 62-110.106, F.A.C. A public notice under Rule 62-210.350(1)(a)1., F.A.C., for an air construction permit may be combined with any required public notice under Rule 62-210.350(1)(a)2. or 3., F.A.C., for air operation permits. If such notices are combined, the public notice must comply with the requirements for both notices.
 - (c) Except as otherwise provided at Rules 62-210.350(2) and (5), F.A.C., each notice of intent to issue an air construction permit shall provide a 14-day period for submittal of public comments.
- (2) Additional Public Notice Requirements for Emissions Units Subject to Prevention of Significant Deterioration or Nonattainment Area Preconstruction Review.
 - (a) Before taking final agency action on a construction permit application for any proposed new or modified facility or emissions unit subject to the preconstruction review requirements of Rule 62-212.400 or 62-212.500, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:
 - 1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S., and the Department's analysis of the effect of the proposed construction or modification on ambient air quality, including the Department's preliminary determination of whether the permit should be approved or disapproved;
 - 2. A 30-day period for submittal of public comments; and,
 - 3. A notice, by advertisement in a newspaper of general circulation in the county affected, specifying the nature and location of the proposed facility or emissions unit, whether BACT or LAER has been determined, the degree of PSD increment consumption expected, if applicable, and the location of the information specified in paragraph 1. above; and notifying the public of the opportunity for submitting comments and requesting a public hearing.
 - (b) The notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action.
 - (c) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall also be sent by the Department to the Regional Office of the U. S. Environmental Protection Agency and to all other state and local officials or agencies having cognizance over the location of such new or modified facility or emissions unit, including local air pollution control agencies, chief executives of city or county government, regional land use planning agencies, and any other state, Federal Land Manager, or Indian Governing Body whose lands may be affected by emissions from the new or modified facility or emissions unit.
 - (d) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be displayed in the appropriate district, branch and local program offices.
 - (e) An opportunity for public hearing shall be provided in accordance with Chapter 120, F.S., and Rule 62-110,106, F.A.C.
 - (f) Any public comments received shall be made available for public inspection in the location where the information specified in Rule 62-210.350(2)(a)1.. F.A.C., is available and shall be considered by the Department in making a final determination to approve or deny the permit.
 - (g) The final determination shall be made available for public inspection at the same location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., was made available.

- (h) For a proposed new or modified emissions unit which would be located within 100 kilometers of any Federal Class I area or whose emissions may affect any Federal Class I area, and which would be subject to the preconstruction review requirements of Rule 62-212.400, F.A.C., or Rule 62-212.500, F.A.C.:
 - 1. The Department shall mail or transmit to the Administrator a copy of the initial application for an air construction permit and notice of every action related to the consideration of the permit application.
 - 2. The Department shall mail or transmit to the Federal Land Manager of each affected Class I area a copy of any written notice of intent to apply for an air construction permit; the initial application for an air construction permit, including all required analyses and demonstrations; any subsequently submitted information related to the application; the preliminary determination and notice of proposed agency action on the permit application; and any petition for an administrative hearing regarding the application or the Department's proposed action. Each such document shall be mailed or transmitted to the Federal Land Manager within fourteen (14) days after its receipt by the Department.
- (3) Additional Public Notice Requirements for Facilities Subject to Operation Permits for Title V Sources.
 - (a) Before taking final agency action to issue a new, renewed, or revised air operation permit subject to Chapter 62-213, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:
 - 1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S.; and,
 - 2. A 30-day period for submittal of public comments.
 - (b) The notice provided for in Rule 62-210.350(3)(a), F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action.
 - (c) The notice shall identify:
 - 1. The facility:
 - 2. The name and address of the office at which processing of the permit occurs;
 - 3. The activity or activities involved in the permit action;
 - 4. The emissions change involved in any permit revision;
 - 5. The name, address, and telephone number of a Department representative from whom interested persons may obtain additional information, including copies of the permit draft, the application, and all relevant supporting materials, including any permit application, compliance plan, permit, monitoring report, and compliance statement required pursuant to Chapter 62-213, F.A.C. (except for information entitled to confidential treatment pursuant to Section 403.111, F.S.), and all other materials available to the Department that are relevant to the permit decision;
 - 6. A brief description of the comment procedures required by Rule 62-210.350(3), F.A.C.;
 - 7. The time and place of any hearing that may be held, including a statement of procedure to request a hearing (unless a hearing has already been scheduled); and,
 - 8. The procedures by which persons may petition the Administrator to object to the issuance of the proposed permit after expiration of the Administrator's 45-day review period.

[Rule 62-210.350, F.A.C.]

22. Administrative Permit Corrections.

- (1) A facility owner shall notify the Department by letter of minor corrections to information contained in a permit. Such notifications shall include:
 - (a) Typographical errors noted in the permit;
 - (b) Name, address or phone number change from that in the permit;
 - (c) A change requiring more frequent monitoring or reporting by the permittee;
 - (d) Changes listed at 40 CFR 72.83(a)(1), (2), (6), (9) and (10), hereby adopted and incorporated by reference, to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-76510;
 - (e) Changes listed at 40 CFR 72.83(a)(11), hereby adopted and incorporated by reference, to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-76510, provided the notification is accompanied by a copy of any EPA determination concerning the similarity of the change to those listed at Rule 62-210.360(1)(d), F.A.C.; and
 - (f) Any other similar minor administrative change at the source.
- (2) Upon receipt of any such notification the Department shall within 60 days correct the permit and provide a corrected copy to the owner.
- (3) After first notifying the owner, the Department shall correct any permit in which it discovers errors of the types listed at Rule 62-210.360(1)(a) and (b), F.A.C., and provide a corrected copy to the owner.
- (4) For Title V source permits, other than general permits, a copy of the corrected permit shall be provided to EPA and any approved local air program in the county where the facility or any part of the facility is located.

(5) The Department shall incorporate requirements resulting from issuance of a new or revised construction permit into an existing Title V source permit, if the construction permit or permit revision incorporates requirements of federally enforceable preconstruction review, and if the applicant requests at the time of application that all of the requirements of Rule 62-213.430(1), F.A.C., be complied with in conjunction with the processing of the construction permit application. [Rule 62-210.360, F.A.C.]

23. Reports.

- (3) Annual Operating Report for Air Pollutant Emitting Facility.
 - (a) The Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) shall be completed each year.
 - (c) The annual operating report shall be submitted to the appropriate Department District or Department approved local air pollution control program office by March 1 of the following year unless otherwise indicated by permit condition or Department request.

[Rule 62-210.370(3), F.A.C.]

- 24. <u>Circumvention</u>. No person shall circumvent any air pollution control device, or allow the emission of air pollutants without the applicable air pollution control device operating properly. [Rule 62-210.650, F.A.C.]
- 25. Forms and Instructions. The forms used by the Department in the stationary source control program are adopted and incorporated by reference in this section. The forms are listed by rule number, which is also the form number, with the subject, title and effective date. Forms 62-210.900(1),(3),(4) and (5), F.A.C., including instructions, are available from the Department as hard-copy documents or executable files on computer diskettes. Copies of forms (hard-copy or diskette) may be obtained by writing to the Department of Environmental Protection, Division of Air Resources Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400. Notwithstanding the requirement of Rule 62-4.050(2), F.A.C., to file application forms in quadruplicate, if an air permit application is submitted using the Department's electronic application form, only one copy of the diskette and signature pages is required to be submitted.
- (1) Application for Air Permit Title V Source, Form and Instructions (Effective 2-11-99).
 - (a) Acid Rain Part (Phase II), Form and Instructions (Effective 7-1-95).
 - 1. Repowering Extension Plan, Form and Instructions (Effective 7-1-95).
 - 2. New Unit Exemption, Form and Instructions (Effective 7-1-95).
 - 3. Retired Unit Exemption, Form and Instructions (Effective 7-1-95).
 - 4. Phase II NOx Compliance Plan, Form and Instructions (Effective 1-6-98).
 - 5. Phase II NOx Averaging Plan, Form (Effective 1-6-98).
 - (b) Reserved.
- (5) Annual Operating Report for Air Pollutant Emitting Facility, Form and Instructions (Effective 2-11-99). [Rule 62-210.900, F.A.C.]

Chapter 62-213, F.A.C.

26. <u>Annual Emissions Fee.</u> Each Title V source permitted to operate in Florida must pay between January 15 and March 1 of each year, upon written notice from the Department, an annual emissions fee in accordance with Rule 62-213.205, F.A.C., and the appropriate form and associated instructions.

[Rules 62-213.205 and 62-213.900(1), F.A.C.]

27. <u>Annual Emissions Fee</u>. Failure to pay timely any required annual emissions fee, penalty, or interest constitutes grounds for permit revocation pursuant to Rule 62-4.100, F.A.C.

[Rule 62-213.205(1)(g), F.A.C.]

28. <u>Annual Emissions Fee</u>. Any documentation of actual hours of operation, actual material or heat input, actual production amount, or actual emissions used to calculate the annual emissions fee shall be retained by the owner for a minimum of five (5) years and shall be made available to the Department upon request.

[Rule 62-213.205(1)(j), F.A.C.]

29. Annual Emissions Fee. A completed DEP Form 62-213.900(1), F.A.C., "Major Air Pollution Source Annual Emissions Fee Form", must be submitted by the responsible official with the annual emissions fee. [Rule 62-213.205(1)(k), F.A.C.]

30. <u>Air Operation Permit Fees</u>. After December 31, 1992, no permit application processing fee, renewal fee, modification fee or amendment fee is required for an operation permit for a Title V source.

[Rule 62-213.205(4), F.A.C.]

- 31. Permits and Permit Revisions Required. All Title V sources are subject to the permit requirements of Chapter 62-213, F.A.C.
- (1) No Title V source may operate except in compliance with Chapter 62-213, F.A.C.
- (2) Except as provided in Rule 62-213.410, F.A.C., no source with a permit issued under the provisions of this chapter shall make any changes in its operation without first applying for and receiving a permit revision if the change meets any of the following:
 - (a) Constitutes a modification;
 - (b) Violates any applicable requirement;
 - (c) Exceeds the allowable emissions of any air pollutant from any unit within the source;
 - (d) Contravenes any permit term or condition for monitoring, testing, recordkeeping, reporting or of a compliance certification requirement:
 - (e) Requires a case-by-case determination of an emission limitation or other standard or a source specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapters 62-212 or 62-296, F.A.C.;
 - (f) Violates a permit term or condition which the source has assumed for which there is no corresponding underlying applicable requirement to which the source would otherwise be subject;
 - (g) Results in the trading of emissions among units within a source except as specifically authorized pursuant to Rule 62-213.415, F.A.C.
 - (h) Results in the change of location of any relocatable facility identified as a Title V source pursuant to paragraph (a)-(e), (g) or (h) of the definition of "major source of air pollution" at Rule 62-210.200, F.A.C
 - (i) Constitutes a change at an Acid Rain Source under the provisions of 40 CFR 72.81(a)(1),(2),or (3),(b)(1) or (b)(3), hereby incorporated by reference;
 - (j) Constitutes a change in a repowering plan, nitrogen oxides averaging plan, or nitrogen oxides compliance deadline extension at an Acid Rain Source.
- (k) Is a request for exemption pursuant to Rule 62-214.340, F.A.C.

[Rule 62-213.400(1) & (2), F.A.C.]

- 32. <u>Changes Without Permit Revision</u>. Title V sources having a valid permit issued pursuant to Chapter 62-213, F.A.C., may make the following changes without permit revision, provided that sources shall maintain source logs or records to verify periods of operation in each alternative method of operation:
- (1) Permitted sources may change among those alternative methods of operation allowed by the source's permit as provided by the terms of the permit;
- (2) Permitted sources may implement the terms or conditions of a new or revised construction permit if;
 - (a) The application for construction permit complied with the requirements of Rule 62-213.420(3) and (4), F.A.C.;
 - (b) The terms or conditions were subject to federally enforceable preconstruction review pursuant to Chapter 62-212, F.A.C.; and,
 - (c) The new or revised construction permit was issued after the Department and the applicant complied with all the requirements of Rule 62-213.430(1), F.A.C.;
- (3) A permitted source may implement operating changes after the source submits any forms required by any applicable requirement and provides the Department and EPA with at least 7 days written notice prior to implementation. The source and the Department shall attach each notice to the relevant permit;
 - (a) The written notice shall include the date on which the change will occur, and a description of the change within the permitted source, the pollutants emitted and any change in emissions, and any term or condition becoming applicable or no longer applicable as a result of the change;
 - (b) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes;
- (4) Permitted sources may implement changes involving modes of operation only in accordance with Rule 62-213.415, F.A.C. [Rule 62-213.410, F.A.C.]
- 33. Immediate Implementation Pending Revision Process.
- (1) Those permitted Title V sources making any change that constitutes a modification pursuant to the definition of modification at Rule 62-210.200, F.A.C., but which would not constitute a modification pursuant to 42 USC 7412(a) or to 40 CFR 52.01, 60.2, or 61.15, adopted and incorporated by reference at Rule 62-204.800, F.A.C., may implement such change prior to final issuance of a permit revision in accordance with this section, provided the change:
 - (a) Does not violate any applicable requirement:
 - (b) Does not contravene any permit term or condition for monitoring, testing, recordkeeping or reporting, or any compliance certification requirement;

- (c) Does not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapter 62-212 or 62-296, F.A.C.;
- (d) Does not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject including any federally enforceable emissions cap or federally enforceable alternative emissions limit.
- (2) A Title V source may immediately implement such changes after they have been incorporated into the terms and conditions of a new or revised construction permit issued pursuant to Chapter 62-212. F.A.C., and after the source provides to EPA, the Department, each affected state and any approved local air program having geographic jurisdiction over the source, a copy of the source's application for operation permit revision. The Title V source may conform its application for construction permit to include all information required by Rule 62-213.420, F.A.C., in lieu of submitting separate application forms.
- (3) The Department shall process the application for operation permit revision in accordance with the provisions of Chapter 62-213, F.A.C., except that the Department shall issue a draft permit revision or a determination to deny the revision within 60 days of receipt of a complete application for operation permit revision or, if the Title V source has submitted a construction permit application conforming to the requirements of Rule 62-213.420, F.A.C., the Department shall issue a draft permit or a determination to deny the revision at the same time the Department issues its determination on issuance or denial of the construction permit application. The Department shall not take final action until all the requirements of Rule 62-213.430(1)(a), (c), (d), and (e), F.A.C., have been complied with.
- (4) Pending final action on the operation permit revision application, the source shall implement the changes in accordance with the terms and conditions of the source's new or revised construction permit.
- (5) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes until after the Department takes final action to issue the operation permit revision.
- (6) If the Department denies the source's application for operation permit revision, the source shall cease implementation of the proposed changes.

[Rule 62-213.412, F.A.C.]

34. Permit Applications.

- (1) Duty to Apply. For each Title V source, the owner or operator shall submit a timely and complete permit application in compliance with the requirements of Rules 62-213.420, 62-4.050(1) & (2), and 62-210.900, F.A.C.
 - (a) Timely Application.
 - 3. For purposes of permit renewal, a timely application is one that is submitted in accordance with Rule 62-4.090, F.A.C.
 - (b) Complete Application.
 - 1. Any applicant for a Title V permit, permit revision or permit renewal must submit an application on DEP Form No. 62-210.900(1), which must include all the information specified by Rule 62-213.420(3), F.A.C., except that an application for permit revision must contain only that information related to the proposed change. The applicant shall include information concerning fugitive emissions and stack emissions in the application. Each application for permit, permit revision or permit renewal shall be certified by a responsible official in accordance with Rule 62-213.420(4), F.A.C.
 - 2. For those applicants submitting initial permit applications pursuant to Rule 62-213.420(1)(a)1., F.A.C., a complete application shall be an application that substantially addresses all the information required by the application form number 62-210.900(1), and such applications shall be deemed complete within sixty days of receipt of a signed and certified application unless the Department notifies the applicant of incompleteness within that time. For all other applicants, the applications shall be deemed complete sixty days after receipt, unless the Department, within sixty days after receipt of a signed application for permit, permit revision or permit renewal, requests additional documentation or information needed to process the application. An applicant making timely and complete application for permit, or timely application for permit renewal as described by Rule 62-4.090(1), F.A.C., shall continue to operate the source under the authority and provisions of any existing valid permit or Florida Electrical Power Plant Siting Certification, provided the applicant complies with all the provisions of Rules 62-213.420(1)(b)3, and 4. F.A.C. Failure of the Department to request additional information within sixty days of receipt of a properly signed application shall not impair the Department's ability to request additional information pursuant to Rules 62-213.420(1)(b)3, and 4. F.A.C.

- 3. For those permit applications submitted pursuant to the provisions of Rule 62-213.420(1)(a)1., F.A.C., the Department shall notify the applicant if the Department becomes aware at any time during processing of the application that the application contains incorrect or incomplete information. The applicant shall submit the corrected or supplementary information to the Department within ninety days unless the applicant has requested and been granted additional time to submit the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days or such additional time as requested and granted shall render the application incomplete.
- 4. For all applications other than those addressed at Rule 62-213.420(1)(b)3., F.A.C., should the Department become aware, during processing of any application that the application contains incorrect information, or should the Department become aware, as a result of comment from an affected State, an approved local air program, EPA, or the public that additional information is needed to evaluate the application, the Department shall notify the applicant within 30 days. When an applicant becomes aware that an application contains incorrect or incomplete information, the applicant shall submit the corrected or supplementary information to the Department. If the Department notifies an applicant that corrected or supplementary information is necessary to process the permit, and requests a response, the applicant shall provide the information to the Department within ninety days of the Department request unless the applicant has requested and been granted additional time to submit the information or, the applicant shall, within ninety days, submit a written request that the Department process the application without the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days, or such additional time as requested and granted, or to demand in writing within ninety days that the application be processed without the information shall render the application incomplete. Nothing in this section shall limit any other remedies available to the Department.

[Rules 62-213.420(1)(a)3. and 62-213.420(1)(b)1., 2., 3. & 4., F.A.C.]

- 35. Confidential Information. Whenever an applicant submits information under a claim of confidentiality pursuant to Section 403.111, F.S., the applicant shall also submit a copy of all such information and claim directly to EPA. (also, see Condition No. 50.) [Rule 62-213.420(2), F.A.C.]
- 36. Standard Application Form and Required Information. Applications shall be submitted under Chapter 62-213, F.A.C., on forms provided by the Department and adopted by reference in Rule 62-210.900(1), F.A.C. The information as described in Rule 62-210.900(1), F.A.C., shall be included for the Title V source and each emissions unit. An application must include information sufficient to determine all applicable requirements for the Title V source and each emissions unit and to evaluate a fee amount pursuant to Rule 62-213.205, F.A.C. [Rule 62-213.420(3), F.A.C.]
- 37. <u>Certification by Responsible Official (RO)</u>. In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. [Rule 62-213.420(4), F.A.C.]
- 38. a. Permit Renewal and Expiration. Permits being renewed are subject to the same requirements that apply to permit issuance at the time of application for renewal. Permit renewal applications shall contain that information identified in Rules 62-210.900(1) and 62-213.420(3), F.A.C. Unless a Title V source submits a timely application for permit renewal in accordance with the requirements of Rule 62-4.090(1), F.A.C., the existing permit shall expire and the source's right to operate shall terminate.

- b. <u>Permit Revision Procedures.</u> Permit revisions shall meet all requirements of Chapter 62-213, F.A.C., including those for content of applications, public participation, review by approved local programs and affected states, and review by EPA, as they apply to permit issuance and renewal, except that permit revisions for those activities implemented pursuant to Rule 62-213.412, F.A.C., need not meet the requirements of Rule 62-213.430(1)(b), F.A.C. The Department shall require permit revision in accordance with the provisions of Rule 62-4.080, F.A.C., and 40 CFR 70.7(f), whenever any source becomes subject to any condition listed at 40 CFR 70.7(f)(1), hereby adopted and incorporated by reference. The below requirements from 40 CFR 70.7(f) are adopted and incorporated by reference in Rule 62-213.430(4), F.A.C.:
- (1) This section contains provisions from 40 CFR 70.7(f) that specify the conditions under which a Title V permit shall be reopened prior to the expiration of the permit. A Title V permit shall be reopened and revised under any of the following circumstances:
 - (i) Additional applicable requirements under the Act become applicable to a major Part 70 source with a remaining permit term of 3 or more years. Such a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii).
 - (ii) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approved by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
 - (iii) The permitting authority or EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
 - (iv) The Administrator or the permitting authority determines that the permit must be revised or revoked to assure compliance with the applicable requirements.
- (2) Proceedings to reopen and issue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable.
- (3) Reopenings under 40 CFR 70.7(f)(1) shall not be initiated before a notice of such intent is provided to the Part 70 source by the permitting authority at least 30 days in advance of the date that the permit is to be reopened, except that the permitting authority may provide a shorter time period in the case of an emergency.

[Rules 62-213.430(3) & (4), F.A.C.; and, 40 CFR 70.7(f)]

39. Insignificant Emissions Units or Pollutant-Emitting Activities.

- (a) All requests for determination of insignificant emissions units or activities made pursuant to Rule 62-213.420(3)(m), F.A.C., shall be processed in conjunction with the permit, permit renewal or permit revision application submitted pursuant to Chapter 62-213, F.A.C. Insignificant emissions units or activities shall be approved by the Department consistent with the provisions of Rule 62-4.040(1)(b), F.A.C. Emissions units or activities which are added to a Title V source after issuance of a permit under Chapter 62-213, F.A.C., shall be incorporated into the permit at its next renewal, provided such emissions units or activities have been exempted from the requirement to obtain an air construction permit and also qualify as insignificant pursuant to Rule 62-213.430(6), F.A.C.
- (b) An emissions unit or activity shall be considered insignificant if:

o 40 CFR 70.7(f): Reopening for Cause. (also, see Condition No. 4)

- 1. Such unit or activity would be subject to no unit-specific applicable requirement;
- 2. Such unit or activity, in combination with other units or activities proposed as insignificant, would not cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s); and
- 3. Such unit or activity would not emit or have the potential to emit:
 - a. 500 pounds per year or more of lead and lead compounds expressed as lead;
 - b. 1,000 pounds per year or more of any hazardous air pollutant;
 - c. 2,500 pounds per year or more of total hazardous air pollutants; or
 - d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C.]

40. <u>Permit Duration</u>. Operation permits for Title V sources may not be extended as provided in Rule 62-4.080(3), F.A.C., if such extension will result in a permit term greater than five (5) years. [Rule 62-213.440(1)(a), F.A.C.]

- 41. <u>Monitoring Information</u>. All records of monitoring information shall specify the date, place, and time of sampling or measurement and the operating conditions at the time of sampling or measurement, the date(s) analyses were performed, the company or entity that performed the analyses, the analytical techniques or methods used, and the results of such analyses. [Rule 62-213.440(1)(b)2.a., F.A.C.]
- 42. Retention of Records. Retention of records of all monitoring data and support information shall be for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

[Rule 62-213.440(1)(b)2.b., F.A.C.]

- 43. Monitoring Reports. The permittee shall submit reports of any required monitoring at least every six (6) months. All instances of deviations from permit requirements must be clearly identified in such reports.

 [Rule 62-213.440(1)(b)3.a., F.A.C.]
- 44. <u>Deviation from Permit Requirements Reports</u>. The permittee shall report in accordance with the requirements of Rules 62-210.700(6) and 62-4.130, F.A.C., any deviations from permit requirements, including those attributable to upset conditions as defined in the permit. Reports shall include the probable cause of such deviations, and any corrective actions or preventive measures taken.

[Rule 62-213.440(1)(b)3.b., F.A.C.]

- 45. Reports. All reports shall be accompanied by a certification by a responsible official, pursuant to Rule 62-213.420(4), F.A.C. [Rule 62-213.440(1)(b)3.c, F.A.C.]
- 46. If any portion of the final permit is invalidated, the remainder of the permit shall remain in effect. [Rule 62-213.440(1)(d)1., F.A.C.]
- 47. It shall not be a defense for a permittee in an enforcement action that maintaining compliance with any permit condition would necessitate halting of or reduction of the source activity.

 [Rule 62-213.440(1)(d)3., F.A.C.]
- 48. A Title V source shall comply with all the terms and conditions of the existing permit until the Department has taken final action on any permit renewal or any requested permit revision, except as provided at Rule 62-213.412(2), F.A.C. [Rule 62-213.440(1)(d)4., F.A.C.]
- 49. A situation arising from sudden and unforeseeable events beyond the control of the source which causes an exceedance of a technology-based emissions limitation because of unavoidable increases in emissions attributable to the situation and which requires immediate corrective action to restore normal operation, shall be an affirmative defense to an enforcement action in accordance with the provisions and requirements of 40 CFR 70.6(g)(2) and (3), hereby adopted and incorporated by reference. [Rule 62-213.440(1)(d)5., F.A.C.]
- 50. <u>Confidentiality Claims.</u> Any permittee may claim confidentiality of any data or other information by complying with Rule 62-213.420(2), F.A.C. (also, see Condition No. 35.) [Rule 62-213.440(1)(d)6., F.A.C.]

- 51. Statement of Compliance. The permittee shall submit a statement of compliance with all terms and conditions of the permit. Such statements shall be submitted to the Department and EPA annually, or more frequently if specified by Rule 62-213.440(2), F.A.C., or by any other applicable requirement. Such statements shall be accompanied by a certification in accordance with Rule 62-213.420(4), F.A.C. The statement of compliance shall include all the provisions of 40 CFR 70.6(c)(5)(iii), incorporated by reference at Rule 62-204.800, F.A.C.
- o 40 CFR 70.6(c)(5)(iii). The compliance certification shall include all of the following (provided that the identification of applicable information may cross-reference the permit or previous reports, as applicable):
 - (A) The identification of each term or condition of the permit that is the basis of the certification;
 - (B) The identification of the method(s) or other means used by the owner or operator for determining the compliance status with each term and condition during the certification period, and whether such methods or other means provide continuous or intermittent data. Such methods and other means shall include, at a minimum, the methods and means required under 40 CFR 70.6(a)(3). If necessary, the owner or operator also shall identify any other material information that must be included in the certification to comply with section 113(c)(2) of the Act, which prohibits knowingly making a false certification or omitting material information;
 - (C) The status of compliance with the terms and conditions of the permit for the period covered by the certification, based on the method or means designated in paragraph (c)(5)(iii)(B) of this section. The certification shall identify each deviation and take it into account in the compliance certification. The certification shall also identify as possible exceptions to compliance any periods during which compliance is required and in which an excursion or exceedance as defined under part 64 of this chapter occurred; and
- (D) Such other facts as the permitting authority may require to determine the compliance status of the source. The statement shall be accompanied by a certification by a responsible official, in accordance with Rule 62-213.420(4), F.A.C. The responsible official may treat compliance with all other applicable requirements as a surrogate for compliance with Rule 62-296.320(2), Objectionable Odor Prohibited.

[Rule 62-213.440(3), F.A.C.]

52. <u>Permit Shield.</u> Except as provided in Chapter 62-213, F.A.C., compliance with the terms and conditions of a permit issued pursuant to Chapter 62-213, F.A.C., shall be deemed compliance with any applicable requirements in effect as of the date of permit issuance, provided that the source included such applicable requirements in the permit application. Nothing in Rule 62-213.460, F.A.C., or in any permit shall alter or affect the ability of EPA or the Department to deal with an emergency, the liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance, or the requirements of the Federal Acid Rain Program.

{Permitting note: The permit shield is not in effect until the effective date of the permit.} [Rule 62-213.460, F.A.C.]

- 53. Forms and Instructions. The forms used by the Department in the Title V source operation program are adopted and incorporated by reference in Rule 62-213.900, F.A.C. The form is listed by rule number, which is also the form number, and with the subject, title, and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resources Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, or by contacting the appropriate permitting authority.
- (1) Major Air Pollution Source Annual Emissions Fee (AEF) Form. [Rule 62-213.900(1), F.A.C.]

Chapter 62-256. F.A.C.

54. Not federally enforceable. Open Burning. This permit does not authorize any open burning nor does it constitute any waiver of the requirements of Chapter 62-256, F.A.C. Source shall comply with Chapter 62-256, F.A.C., for any open burning at the source. [Chapter 62-256, F.A.C.]

Chapter 62-281, F.A.C.

- 55. <u>Refrigerant Requirements</u>. Any facility having refrigeration equipment, including air conditioning equipment, which uses a Class I or II substance (listed at 40 CFR 82. Subpart A. Appendices A and B), and any facility which maintains, services, or repairs motor vehicles using a Class I or Class II substance as refrigerant must comply with all requirements of 40 CFR 82, Subparts B and F, and with Rule 62-281.100, F.A.C. Those requirements include the following restrictions:
- (1) Any facility having any refrigeration equipment normally containing 50 (fifty) pounds of refrigerant, or more, must keep servicing records documenting the date and type of all service and the quantity of any refrigerant added pursuant to 40 CFR 82.166;

- (2) No person repairing or servicing a motor vehicle may perform any service on a motor vehicle air conditioner (MVAC) involving the refrigerant for such air conditioner unless the person has been properly trained and certified as provided at 40 CFR 82.34 and 40 CFR 82.40, and properly uses equipment approved pursuant to 40 CFR 82.36 and 40 CFR 82.38, and complies with 40 CFR 82.42;
- (3) No person may sell or distribute, or offer for sale or distribution, any substance listed as a Class I or Class II substance at 40 CFR 82, Subpart A. Appendices A and B, except in compliance with Rule 62-281.100, F.A.C., and 40 CFR 82.34(b), 40 CFR 82.42, and/or 40 CFR 82.166;
- (4) No person maintaining, servicing, repairing, or disposing of appliances may knowingly vent or otherwise release into the atmosphere any Class I or Class II substance used as a refrigerant in such equipment and no other person may open appliances (except MVACs as defined at 40 CFR 82.152) for service, maintenance or repair unless the person has been properly trained and certified pursuant to 40 CFR 82.161 and unless the person uses equipment certified for that type of appliance pursuant to 40 CFR 82.158 and unless the person observes the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
- (5) No person may dispose of appliances (except small appliances, as defined at 40 CFR 82.152) without using equipment certified for that type of appliance pursuant to 40 CFR 82.158 and without observing the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
- (6) No person may recover refrigerant from small appliances, MVACs and MVAC-like appliances (as defined at 40 CFR 82.152), except in compliance with the requirements of 40 CFR 82, Subpart F.

[40 CFR 82; and, Chapter 62-281, F.A.C. (Chapter 62-281, F.A.C., is not federally enforceable)]

Chapter 62-296, F.A.C.

- 56. <u>Industrial. Commercial. and Municipal Open Burning Prohibited</u>. Open burning in connection with industrial, commercial, or municipal operations is prohibited, except when:
 - (a) Open burning is determined by the Department to be the only feasible method of operation and is authorized by an air permit issued pursuant to Chapter 62-210 or 62-213, F.A.C.; or
 - (b) An emergency exists which requires immediate action to protect human health and safety; or
 - (c) A county or municipality would use a portable air curtain incinerator to burn yard trash generated by a hurricane, tornado, fire or other disaster and the air curtain incinerator would otherwise be operated in accordance with the permitting exemption criteria of Rule 62-210.300(3), F.A.C.

[Rule 62-296.320(3), F.A.C.]

57. Unconfined Emissions of Particulate Matter.

(4)(c)1. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any emissions unit whatsoever, including, but not limited to, vehicular movement, transportation of materials, construction, alteration, demolition or wrecking, or industrially related activities such as loading, unloading, storing or handling, without taking reasonable precautions to prevent such emission.

- 3. Reasonable precautions may include, but shall not be limited to the following:
 - a. Paving and maintenance of roads, parking areas and yards.
 - b. Application of water or chemicals to control emissions from such activities as demolition of buildings, grading roads, construction, and land clearing.
 - c. Application of asphalt, water, oil, chemicals or other dust suppressants to unpaved roads, yards, open stock piles and similar emissions units.
 - d. Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the emissions unit to prevent reentrainment, and from buildings or work areas to prevent particulate from becoming airborne.
 - e. Landscaping or planting of vegetation.
 - f. Use of hoods, fans, filters, and similar equipment to contain, capture and/or vent particulate matter.
 - g. Confining abrasive blasting where possible.
 - h. Enclosure or covering of conveyor systems.
- 4. In determining what constitutes reasonable precautions for a particular facility, the Department shall consider the cost of the control technique or work practice, the environmental impacts of the technique or practice, and the degree of reduction of emissions expected from a particular technique or practice.

[Rules 62-296.320(4)(c)1., 3., & 4. F.A.C.]

[electronic file name: rv-3.doc]

APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)

Stack Sampling Facilities Provided by the Owner of an Emissions Unit. This section describes the minimum requirements for stack sampling facilities that are necessary to sample point emissions units. Sampling facilities include sampling ports, work platforms, access to work platforms, electrical power, and sampling equipment support. Emissions units must provide these facilities at their expense. All stack sampling facilities must meet any Occupational Safety and Health Administration (OSHA) Safety and Health Standards described in 29 CFR Part 1910, Subparts D and E.

(a) Permanent Test Facilities. The owner or operator of an emissions unit for which a compliance test, other than a visible emissions test, is required on at least an annual basis,

shall install and maintain permanent stack sampling facilities.

(b) Temporary Test Facilities. The owner or operator of an emissions unit that is not required to conduct a compliance test on at least an annual basis may use permanent or temporary stack sampling facilities. If the owner chooses to use temporary sampling facilities on an emissions unit, and the Department elects to test the unit, such temporary facilities shall be installed on the emissions unit within 5 days of a request by the Department and remain on the emissions unit until the test is completed.

(c) Sampling Ports.

1. All sampling ports shall have a minimum inside diameter of 3 inches.

2. The ports shall be capable of being sealed when not in use.

3. The sampling ports shall be located in the stack at least 2 stack diameters or equivalent diameters downstream and at least 0.5 stack diameter or equivalent diameter.

upstream from any fan, bend, constriction or other flow disturbance.

- 4. For emissions units for which a complete application to construct has been filed prior to December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 15 feet or less. For stacks with a larger diameter, four sampling ports, each 90 degrees apart, shall be installed. For emissions units for which a complete application to construct is filed on or after December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 10 feet or less. For stacks with larger diameters, four sampling ports, each 90 degrees apart, shall be installed. On horizontal circular ducts, the ports shall be located so that the probe can enter the stack vertically, horizontally or at a 45 degree angle.
- 5. On rectangular ducts, the cross sectional area shall be divided into the number of equal areas in accordance with EPA Method 1. Sampling ports shall be provided which allow access to each sampling point. The ports shall be located so that the probe can be inserted perpendicular to the gas flow.

(d) Work Platforms.

- 1. Minimum size of the working platform shall be 24 square feet in area. Platforms shall be at least 3 feet wide.
- 2. On circular stacks with 2 sampling ports, the platform shall extend at least 110 degrees around the stack.

3. On circular stacks with more than two sampling ports, the work platform shall

extend 360 degrees around the stack.

4. All platforms shall be equipped with an adequate safety rail (ropes are not acceptable), toeboard, and hinged floor-opening cover if ladder access is used to reach the platform. The safety rail directly in line with the sampling ports shall be removable so that no obstruction exists in an area 14 inches below each sample port and 6 inches on either side of the sampling port.

(e) Access to Work Platform.

APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96) (continued)

1. Ladders to the work platform exceeding 15 feet in length shall have safety cages or fall arresters with a minimum of 3 compatible safety belts available for use by sampling personnel.

2. Walkways over free-fall areas shall be equipped with safety rails and toeboards.

(f) Electrical Power.

1. A minimum of two 120-volt AC, 20-amp outlets shall be provided at the sampling

platform within 20 feet of each sampling port.

2. If extension cords are used to provide the electrical power, they shall be kept on the plant's property and be available immediately upon request by sampling personnel.

(g) Sampling Equipment Support.

1. A three-quarter inch eyebolt and an angle bracket shall be attached directly above each port on vertical stacks and above each row of sampling ports on the sides of

horizontal ducts.

a. The bracket shall be a standard 3 inch x 3 inch x one-quarter inch equal-legs bracket which is 1 and one-half inches wide. A hole that is one-half inch in diameter shall be drilled through the exact center of the horizontal portion of the bracket. The horizontal portion of the bracket shall be located 14 inches above the centerline of the sampling port.

b. A three-eighth inch bolt which protrudes 2 inches from the stack may be substituted for the required bracket. The bolt shall be located 15 and one-half inches

above the centerline of the sampling port.

- c. The three-quarter inch eyebolt shall be capable of supporting a 500 pound working load. For stacks that are less than 12 feet in diameter, the eyebolt shall be located 48 inches above the horizontal portion of the angle bracket. For stacks that are greater than or equal to 12 feet in diameter, the eyebolt shall be located 60 inches above the horizontal portion of the angle bracket. If the eyebolt is more than 120 inches above the platform, a length of chain shall be attached to it to bring the free end of the chain to within safe reach from the platform.
- 2. A complete monorail or dualrail arrangement may be substituted for the eyebolt and bracket.
- 3. When the sample ports are located in the top of a horizontal duct, a frame shall be provided above the port to allow the sample probe to be secured during the test. [Rule 62-297.310(6), F.A.C.]

TABLE 297.310-1 CALIBRATION SCHEDULE

ITEM	MINIMUM CALIBRATION FREQUENCY	REFERENCE INSTRUMENT	TOLERANCE
Liquid in glass thermometer	Annually	ASTM Hg in glass ref. thermometer or equivalent, or thermometric points	+/-2%
Bimetallic thermometer	Quarterly	Calib. liq. in glass thermometer	5 degrees F
Thermocouple	Annually	ASTM Hg in glass ref. thermometer, NBS calibrated reference and potentiometer	5 degrees F
Barometer	Monthly	Hg barometer or NOAA station	+/-1% scale
Pitot Tube	When required or when damaged	By construction or measurements in wind tunnel D greater than 16" and standard pitot tube	See EPA Method 2, Fig. 2-2 & 2-3
Probe Nozzles	Before each test or when nicked, dented, or corroded	Micrometer .	+/-0.001" mean of at least three readings Max. deviation between readings .004"
Dry Gas Meter and Orifice Meter	1. Full Scale: When received, When 5% change observed, Annually 2. One Point: Semiannually 3. Check after	Spirometer or calibrated wet test or dry gas test meter Comparison check	2% 5%
·	each test series	Comparison encek	J / U

FIGURE 1--SUMMARY REPORT--GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE (version dated 7/96)

[Note: This form is referenced in 40 CFR 60.7, Subpart A-General Provisions	5]
Pollutant (Circle One): SO ₂ NO _X TRS H ₂ S	CO Opacity
Reporting period dates: From	to
Company:	
Emission Limitation:	
Address:	
Monitor Manufacturer:	
Model No.:	
Date of Latest CMS Certification or Audit:	·
Process Unit(s) Description:	
Total source operating time in reporting period ¹ :	<u> </u>
Emission data summary 1	CMS performance summary 1
1. Duration of excess emissions in reporting period due to:	CMS downtime in reporting period due to:
a. Startup/shutdown	a. Monitor equipment malfunctions
b. Control equipment problems	b. Non-Monitor equipment malfunctions
c. Process problems	c. Quality assurance calibration
d. Other known causes	d. Other known causes
e. Unknown causes	e. Unknown causes
Total duration of excess emissions	2. Total CMS Downtime
3. Total duration of excess emissions x (100) / [Total	3. [Total CMS Downtime] x (100) / [Total source
1	
1 For opacity, record all times in minutes. For gases, record are total CMS downtime is 5 percent or greater of the total excess emission report described in 40 CFR 60.7(c) shall	missions is 1 percent or greater of the total operating time or all operating time, both the summary report form and the
Note: On a separate page, describe any changes since last que	arter in CMS, process or controls.
I <u>certify</u> that the information contained in this report is true, acc	curate, and complete.
Name:	
# V	
Signature:	
Title:	·
[electronic file name: figure1.doc]	·

Appendix U-1, List of Unregulated Emissions Units and Activities

Orlando Utilities Commission Indian River Plant FINAL Permit No. 0090008-001-AV

<u>Unregulated Emissions Units and Activities</u>. An emissions unit which emits no "emissions-limited pollutant" and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and activities are neither 'regulated emissions units' nor 'exempt emissions units'.

E.U.

ID No. Brief Description of Emissions Units and Activities

009

Three No. 6 Fuel Oil Storage Tanks (two with 3.67 million gallon capacity, one with 7.5 million gallon capacity)

Two No. 2 Fuel Oil Storage Tanks (one with 150,000 gallon capacity, one with 34,500 gallon capacity)

One Gasoline Fuel Storage "day" Tank (500 gallon capacity)

Fuel loading and unloading activities

[electronic file name: 0090008u.doc]

Appendix U-1, List of Unregulated Emissions Units and Activities

Orlando Utilities Commission Indian River Plant FINAL Permit No. 0090008-001-AV

<u>Unregulated Emissions Units and Activities</u>. An emissions unit which emits no "emissions-limited pollutant" and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and activities are neither 'regulated emissions units' nor 'exempt emissions units'.

<u>E.U.</u>

ID No. Brief Description of Emissions Units and Activities

009

Three No. 6 Fuel Oil Storage Tanks (two with 3.67 million gallon capacity, one with 7.5 million gallon capacity)

Two No. 2 Fuel Oil Storage Tanks (one with 150,000 gallon capacity) one with 34,500 gallon capacity)

One Gasoline Fuel Storage "day" Tank (500 gallon capacity)

Fuel loading and unloading activities

[electronic file name: 0090008u.doc]

Appendix I-1, List of Insignificant Emissions Units and Activities

Orlando Utilities Commission Indian River Plant Page 1 of 2 FINAL Permit No. 0090008-001-AV

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., <u>Categorical Exemptions</u>, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62.210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and Activities

- 1. Internal combustion engines in boats, aircraft and vehicles used for transportation of passengers or freight.
- 2. Cold storage refrigeration equipment, except for any such equipment located at a Title V source using an ozone-depleting substance regulated under 40 CFR Part 82.
- 3. Vacuum pumps in laboratory operations.
- 4. Equipment used for steam cleaning.
- 5. Belt or drum sanders having a total sanding surface of five square feet or less and other equipment used exclusively on wood or plastics or their products having a density of 20 pounds per cubic foot or more.
- 6. Equipment used exclusively for space heating, other than boilers.
- 7. Laboratory equipment used exclusively for chemical or physical analyses.
- 8. Brazing, soldering or welding equipment.
- 9. One or more emergency generators located within a single facility provided:
 - a. None of the emergency generators is subject to the Federal Acid Rain Program; and
 - b. Total fuel consumption by all such emergency generators within the facility is limited to 32,000 gallons per year of diesel fuel, 4,000 gallons per year of gasoline, 4.4 million standard cubic feet per year of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.
- 10. One or more heating units and general purpose internal combustion engines located within a single facility provided:
 - a. None of the heating units or general purpose internal combustion engines is subject to the Federal Acid Rain Program; and
 - b. Total fuel consumption by all such heating units and general purpose internal combustion engines within the facility is limited to 32,000 gallons per year of diesel

Appendix I-1, List of Insignificant Emissions Units and/or Activities

Orlando Utilities Commission FINAL Permit No. 0090008-001-AV Indian River Plant
Page 2 of 2

fuel, 4,000 gallons per year of gasoline, 4.4 million standard cubic feet per year of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.

- 11. Fire and safety equipment.
- 12. Surface coating operations within a single facility if the total quantity of coatings containing greater than 5.0 percent VOCs, by volume, used is 6.0 gallons per day or less, averaged monthly, provided:
 - a. Such operations are not subject to a volatile organic compound Reasonably Available Control Technology (RACT) requirement of Chapter 62-296, F.A.C.; and
 - b. The amount of coatings used shall include any solvents and thinners used in the process including those used for cleanup.
- 13. Surface coating operations utilizing only coatings containing 5.0 percent or less VOCs, by volume.
- 14. Degreasing units using heavier-than-air vapors exclusively, except any such unit using or emitting any substance classified as a hazardous air pollutant.

Note: No exemption shall be granted to any emissions unit or activity if:

- 1. Such unit or activity would be subject to any unit-specific applicable requirement;
- 2. Such unit or activity, in combination with other units and activities proposed for exemption, would cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s); or
- 3. Such unit or activity would emit or have the potential to emit:
- a. 500 pounds per year or more of lead and lead compounds expressed as lead;
- b. 1,000 pounds per year or more of any hazardous air pollutant;
- c. 2,500 pounds per year or more of total hazardous air pollutants; or
- d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C]

[electronic file name: 0090008i.doc]

Appendix H-1, Permit History/ID Number Changes

Orlando Utility Commission Indian River Plant FINAL Permit No. 0090008-001-AV Facility ID No. 0090008

Permit History: E.U.						
ID No	Description	Permit No.	<u>Issue</u>	Expiration	Extended	Revised Dates
			Date	<u>Date</u>	<u>Date¹</u>	
001, 002, & 003	Boiler Units No. 1, 2, & 3	OGC FILE NO.	03/13/89			
		88-1257, 88-1258, & 88-1259				
		AO05-183384	04/26/91	04/15/96	08/14/96	
004 & 007	35 MW Combustion Turbines A & B	AC05-144482, AC05-146749	09/01/88	01/31/92		12/18/89
		PSD-FL-130	09/01/88			12/18/89
		AO05-176351	07/30/90	07/25/95	08/14/96	
005 & 006	129 MW Combustion Turbines C & D	AC05-146750, AC05-146751	09/01/88	01/31/92	•	12/18/89, 11/05/9
		PSD-FL-130	09/01/88			12/18/89, 11/05/9
	•	AC05-193720	11/05/91	06/30/93		05/10/94, 08/24/9
		PSD-FL-173	11/05/91			05/10/94, 08/24/9
		ASP 92-0-01	12/16/92			
		AO05-229084	09/21/93	08/30/98		
		OGC FILE NO.	05/22/96			
		94-3376-C-05				
008	Lime Storage Silo	AO05-229996	06/03/93	05/30/98		

ID Number Changes:

From: Facility ID No. 30ORL050008

To: Facility ID No. 0090008

Notes: 1 - AO permits automatic extensions in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.

{Rule 62-213.420(1)(b)2., F.A.C., allows Title V Sources to operate under existing valid permits that were in effect at the time of application until the Title V permit becomes effective.}

Table 1-1, Summary of Air Pollutant Standards and Terms

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 001, 002, 003

Boilers 1, 2, and 3

			Allowabl	e Emissions		Equivalent Emissions*			See Permit
Pollutant/Parameter	Fuel	Hours/Year	Standards	lbs./hour	TPY	lbs /hour	TPY	Regulatory Citations	Condition
SO2	All	8,400	2.75 lbs/MMBtu					Rule 62-296.405(1)(c)1.j	III. A.9
РМ	AII		0.1 lbs/MMBtu 0.3 lbs/MMBtu for 3hr. per 24 hours (sootblowing)			·		Rule 62-296.405(1)(b) Rule 62-210.700(3)	III. A.7 III. A.8
VE	Ali		20%; 40%@ 2min/hr. 60% for 3hr./24 hours (sootblowing)		,		n/a	Rule 62-296.405(1)(a) Rule 62-210.700(3)	III. A.5 III. A.6
									·
						·			

^{** --} Annual emissions (TPY) based on 3 hours per day at 0.3 lb/mmBtu and 21 hours per day at 0.1lb/MMBtu.

^{* --} Equivalent Emissions provided for information only.

Table 1-1, Summary of Air Pollutant Standards and Terms

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 004, 007

Combustion Turbines A and B

			Allowab	le Emissions		Equivalent	Emissions*		See Permit
Pollutant/Parameter	Fuel	Hours/Year	lbs/hour/unit	TPY/unit	TPY/2 units	lbs./hour	TPY	Regulatory Citations	Condition
SO2	Gas	8,76 0	0.34	1.5	3-			PSD-FL-130	III. B.4
•	Oil		143	625	1250	285.4	1250		
		•							
NOx	Gas		75	329	658			PSD-FL-130	III. B.4
	Oil		118	518	1037	237	1037		
-									
VE	Gas		5% opacity				n/a	PSD-FL-130	III. B.5
\ \ \	Oil		10% opacity				11/4	1 00-1 2-100	III. B.3
	, O.,		, o to op actify						
,									
						4.			
					•				

^{** --} Annual emissions (TPY) based on 3 hours per day at 0.3 lb/mmBtu and 21 hours per day at 0.1 lb/MMBtu.

^{* --} Equivalent Emissions provided for information only.

Table 1-1, Summary of Air Pollutant Standards and Terms

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 005, 006

Combustion Turbines C and D

				Allowable Emissi			See Permit	
Pollutant/Parameter	Fuel	Hours/Year	Standard	TPY/unit	TPY/2 units	lbs./hour / unit	Regulatory Citations	Condition
SO2	Gas Oil	4,380	0.3% Sulfur Fuel 0.3% Sulfur Fuel	1.05 476.5	2.10 953	0.5 217.6	PSD-FL-173	III.C.5
NOx	Gas Oil		25 ppm@15% O2 42 ppm@15% O2	295.75 253	591.5 506	135.0 115.5	PSD-FL-173	III.C.5
VE	Gas Oil		10% opacity 10% opacity				AC05-193720	III.C.6
PM/PM10	Gas Oil		0.003 lb/MMBtu 0.08 lb/MMBtu	9.75 118.5		4.5 54.1		
со	Gas Oil		25 ppmvd 25 ppmvd	156.5 79.5		71.5 36.3		
VOC	Gas Oil		5 ppmvd 15 ppmvd	18.5 56		8.4 25.6		
Sulfurc Acid Mist	Gas Oil			0.035 14.25		0.02 6.5		

Table 1-1, Summary of Air Pollutant Standards and Terms

FINAL Permit # 0090008-001-AV

Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 008 Lime Storage Silo

		Allowable Emissions	Equivalent Emissions			See Permit
Pollutant	Process Rate		lbs./hour	TPY	Regulatory Citations	Condition
Particulate Matter	10 tons per hour	0.03 gr/dscf	n/a	n/a	Rule 62-296.711	III.F.2.
Visible Emissions	10 tons per hour	5% Opacity	n/a	· n/a	Rule 62-296.711	III.F.2.
					·	

Table 2-1, Summary of Compliance Requirements

Orlando Utilities Commission Indian River Plant

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 001, 002, 003

Boilers 1, 2, and 3

	_		Frequency	Frequency	Min. Compliance		
Pollutant/		Compliance	of	Base ·	Test		Permit
Parameter	Fuel	Method	Sampling	Date *	Duration	CMS**	Condition
SO2	All Fuels	Fuel sampling & analysis	Daily sampling of as-fired fuel	1-Oct			III. A.16
PM	All Fuels	EPA Method 5 or 17	annual	001: 1-Oct 002 & -003: 23-Aug			III. A.15
VE	All Fuels	DEP Method 9	annual	001: 1-Oct 002 & -003: 23-Aug	1 hour		III. A.13
					·		

^{*}Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

^{**}CMS = continuous monitoring system

Table 2-1, Summary of Compliance Requirements

Orlando Indian River Plant FINAL Permit # 0870003-001-AV Facility ID # 0870003

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 004, 007

Combustion Turbines A and B

	_		Frequency	Frequency	Min. Compliance		
Pollutant/		Compliance	of	Base	Test	-	Permit
Parameter	Fuel	Method	Sampling	Date *	Duration	CMS**	Condition
SO2	#2 oil	Fuel sampling & analysis	Daily sampling of as-fired fuel	Per 40 CFR 60.334(b)			III.D.3, D.8 & D.12
	gas						III.D.8
VE	#2 oil	EPA Method 9	annual	20-Jan			III.B.5
NOx	#2 oil	EPA Method 20	annual	20-Jan			III.D.8, D.11
	gas						
						'	

^{*}Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

^{**}CMS = continuous monitoring system

Table 2-1, Summary of Compliance Requirements

Orlando Indian River Plant FINAL Permit # 0870003-001-AV Facility ID # 0870003

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 005, 006

Combustion Turbines C and D

	_		Frequency	Frequency	Min. Compliance		
Pollutant/		Compliance	of	Base	Test		Permit
Parameter	Fuel	Method	Sampling	Date *	Duration	CMS	Condition
SO2	#2 oil	Fuel sampling & analysis	After each fuel oil shipment	Per 40 CFR 60.335			III.D.3, D.8 & D.12
	gas			•			III.D.8
VE	#2 oil gas	EPA Method 9	annual	20-Jan			III.C.6
со	#2 oil gas	EPA Method 10	annual	20-Jan			III.C.9.
NOx	#2 oil gas	EPA Method 20**	annual	20-Jan			III.D.8, D.11.
PM/PM10	#2 oil gas	none					
VOC		***					III.C.7.

^{*}Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

^{**}With ASP for revised Method 1

^{***} Compliance with total VOC emission limits will be assumed, provided the CO allowable emission rate is achieved. PSD-FL-173

Table 2-1, Summary of Compliance Requirements

Orlando Utilities Commission Indian River Plant

FINAL Permit # 0090008-001-AV Facility ID # 0090008

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

E.U. 008

Lime Storage Silo

			Frequency	Frequency	Min. Compliance		
Pollutant/		Compliance	of	Base	Test		Permit
Parameter	Material	Method	Sampling	Date*	Duration	CMS**	Condition
	`				·.		
РМ	Lime	VE Test in lieu of PM test since source has baghouse	annual	1-Mar	30 minutes or one batch cycle	n/a	III.F.4.
VE	Lime	DEP Method 9	annual	1-Mar	30 minutes or one batch cycle	n/a	III.F.4.
<u> </u>		·					

^{*}Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

^{**}CMS = continuous monitoring system

Appendix I-1, List of Insignificant Emissions Units and/or Activities

Orlando Utilities Commission Indian River Plant Page 2 of 2 **FINAL Permit No.** 0090008-001-AV

fuel, 4,000 gallons per year of gasoline, 4.4 million standard cubic feet per year of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.

- 11. Fire and safety equipment.
- 12. Surface coating operations within a single facility if the total quantity of coatings containing greater than 5.0 percent VOCs, by volume, used is 6.0 gallons per day or less, averaged monthly, provided:
 - a. Such operations are not subject to a volatile organic compound Reasonably Available Control Technology (RACT) requirement of Chapter 62-296, F.A.C.; and
 - b. The amount of coatings used shall include any solvents and thinners used in the process including those used for cleanup.
- 13. Surface coating operations utilizing only coatings containing 5.0 percent or less VOCs, by volume.
- 14. Degreasing units using heavier-than-air vapors exclusively, except any such unit using or emitting any substance classified as a hazardous air pollutant.

Note: No exemption shall be granted to any emissions unit or activity if:

- 1. Such unit or activity would be subject to any unit-specific applicable requirement;
- 2. Such unit or activity, in combination with other units and activities proposed for exemption, would cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s); or
- 3. Such unit or activity would emit or have the potential to emit:
- a. 500 pounds per year or more of lead and lead compounds expressed as lead;
- b. 1,000 pounds per year or more of any hazardous air pollutant;
- c. 2,500 pounds per year or more of total hazardous air pollutants; or
- d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C]

[electronic file name: 0090008i.doc]

Appendix I-1, List of Insignificant Emissions Units and Activities

Orlando Utilities Commission Indian River Plant Page 1 of 2 FINAL Permit No. 0090008-001-AV

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62.210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and Activities

- 1. Internal combustion engines in boats, aircraft and vehicles used for transportation of passengers or freight.
- 2. Cold storage refrigeration equipment, except for any such equipment located at a Title V source using an ozone-depleting substance regulated under 40 CFR Part 82.
- 3. Vacuum pumps in laboratory operations.
- 4. Equipment used for steam cleaning.
- 5. Belt or drum sanders having a total sanding surface of five square feet or less and other equipment used exclusively on wood or plastics or their products having a density of 20 pounds per cubic foot or more.
- 6. Equipment used exclusively for space heating, other than boilers.
- 7. Laboratory equipment used exclusively for chemical or physical analyses.
- 8. Brazing, soldering or welding equipment.
- 9. One or more emergency generators located within a single facility provided:
 - a. None of the emergency generators is subject to the Federal Acid Rain Program; and
 - b. Total fuel consumption by all such emergency generators within the facility is limited to 32,000 gallons per year of diesel fuel, 4,000 gallons per year of gasoline, 4.4 million standard cubic feet per year of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.
- 10. One or more heating units and general purpose internal combustion engines located within a single facility provided:
 - a. None of the heating units or general purpose internal combustion engines is subject to the Federal Acid Rain Program; and
 - b. Total fuel consumption by all such heating units and general purpose internal combustion engines within the facility is limited to 32,000 gallons per year of diesel

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

In the matter of:)	•
Florida Electric Power Coordinating Group, Inc.,)	ASP No. 97-B-01
Petitioner.)	•

ORDER ON REQUEST FOR ALTERNATE PROCEDURES AND REQUIREMENTS

Pursuant to Rule 62-297.620, Florida Administrative Code (F.A.C.), the Florida Electric Coordinating Group, Incorporated, (FCG) petitioned for approval to: (1) Exempt fossil fuel steam generators which burn liquid and/or solid fuel for less than 400 hours during the federal fiscal year from the requirement to conduct an annual particulate matter compliance test; and, (2) Exempt fossil fuel steam generators which burn liquid and/or solid fuel for less than 400 hours during the federal fiscal year from the requirement to conduct an annual particulate matter compliance test during the year prior to renewal of an operation permit. This Order is intended to clarify particulate testing requirements for those fossil fuel steam generators which primarily burn gaseous fuels including, but not necessarily limited to natural gas.

Having considered the provisions of Rule 62-296.405(1), F.A.C., Rule 62-297.310(7), F.A.C., and all supporting documentation, the following Findings of Fact, Conclusions of Law, and Order are entered:

FINDINGS OF FACT

- 1. The Fiorida Electric Power Coordinating Group, Incorporated, petitioned the Department to exempt those fossil fuel steam generators which have a heat input of more than 250 million Etu per hour and burn solid and/or liquid fuel less than 400 hours during the year from the requirement to conduct an annual particulate matter compliance test. [Exhibit 1]
- 2. Rule 62-296.405(1)(a), F.A.C., applies to those fossil fuel steam generators that are not subject to the federal standards of performance for new stationary sources (NSPS) in 40 CFR 60 and which have a heat input of more than 250 million Etu per hour.
- 3. Rule 62-296.405(1)(a), F.A.C., limits visible emissions from affected fossil fuel steam generators to, "20 percent opacity except for either one six-minute period per hour during which

not exceed 40 percent. The option selected shall be specified in the emissions unit's construction and operation permits. Emissions units governed by this visible emission limit shall test for particulate emission compliance annually and as otherwise required by Rule 62-297, F.A.C."

- 4. Rule 62-296.405(1)(a), F.A.C., further states, "Emissions units electing to test for particulate matter emission compliance quarterly shall be allowed visible emissions of 40 percent opacity. The results of such tests shall be submitted to the Department. Upon demonstration that the particulate standard has been regularly complied with, the Secretary, upon petition by the applicant, shall reduce the frequency of particulate testing to no less than once annually.
- 5. Rule 297.310(7)(a)1., F.A.C., states, "The owner or operator of a new or modified emissions unit that is subject to an emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining an operation permit for such emissions unit."
- 6. Rule 297.310(7)(a)?., F.A.C., states, "The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision.
- 7. Rule 297.310(7)/2)3., F.A.C., further states, "In renewing an air operation permit pursuant to Rule 62-210.360(2)(2)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal: a. Did not operate; or, b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours."
- 8. Rule 297.310(7)(a)4., F.A.C., states, "During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for: a. Visible emissions, if there is an applicable standard; b. Each of the following pollutants, if there is an applicable standard; and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of any other regulated air pollutant..."
- 9. Rule 297.310(7)(a)5., F.A.C., states. "An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours."
- 10. Rule 297,310(7)(4)6., F.A.C., states, "For fossil fuel steam gener, tors on a semi-annual particulate matter emission compliance testing schedule, a compliance test shall not be

required for any six-month period in which liquid and/or solid fuel is not burned for more than 200 hours other than during startup."

- 11. Rule 297.310(7)(a)7., F.A.C., states, "For emissions units electing to conduct particulate matter emission compliance testing quarterly pursuant to Rule 62-296.405(2)(a), F.A.C., a compliance test shall not be required for any quarter in which liquid and/or solid fuel is not burned for more than 100 hours other than during startup." [Note: The reference should be to Rule 62-296.405(1)(a), F.A.C., rather than Rule 62-296.405(2)(a), F.A.C.]
- 12. The fifth edition of the U. S. Environmental Protection Agency's <u>Compilation of Air Pollutant Emission Factors</u>. AP-42, that emissions of filterable particulate from gas-fired fossil fuel steam generators with a heat input of more than about 10 million Btu per hour may be expected to range from 0.001 to 0.006 pound per million Etu. [Exhibit 2]
- 13. Rule 62-296.405(1)(b), F.A.C. and the federal standards of performance for new stationary sources in 40 CFR 60.42, Subpart D, limit particulate emissions from uncontrolled fossil fuel fired steam generators with a heat input of more than 250 million Btu to 0.1 pound per million Btu.

CONCLUSIONS OF LAW

- 1. The Department has jurisdiction to consider the matter pursuant to Section 403.061, Florida Statutes (F.S.), and Rule 62-297.620, F.A.C.
- 2. Pursuant to Rule 62-297.310(7), F.A.C., the Department may require Petitioner to conduct compliance tests that identify the nature and quantity of pollutant emissions, if, after investigation, it is believed that any applicable emission standard or condition of the applicable permits is being violated.
- 3. There is reason to believe that a fossil fuel steam generator which does not burn liquid and/or solid fuel (other than during startup) for a total of more than 400 hours in a federal fiscal year and complies with all other applicable limits and permit conditions is in compliance with the applicable particulate mass emission limiting standard.

OFDER

Having considered the requirements of Rule 62-296.405, F.A.C., Rule 62-297.310, F.A.C., and supporting documentation, it is hereby ordered that:

1. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours;

- 2. For fossil fuel steam generators on a semi-annual particulate matter emission compliance testing schedule, a compliance test shall not be required for any six-month period in which liquid and/or solid fuel is not burned for more than 200 hours other than during startup;
- 3. For emissions units electing to conduct particulate matter emission compliance testing quarterly pursuant to Rule 62-296.405(1)(a), F.A.C., a compliance test shall not be required for any quarter in which liquid and/or solid fuel is not burned for more than 100 hours other than during startup;
- 4. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of particulate matter emission compliance test results for any fossil fuel steam generator emissions unit that burned liquid and/or solid fuel for a total of no more than 400 hours during the year prior to renewal.
- 5. Pursuant to Rule 62-297.310(7), F.A.C., owners of affected fossil fuel steam generators may be required to conduct compliance tests that identify the nature and quantity of pollutant emissions, if, after investigation, it is believed that any applicable emission standard or condition of the applicable permits is being violated.
- 6. Pursuant to Rule 62-297.310(8), F.A.C., owners of affected fossil fuel steam generators shall submit the compliance test report to the District Director of the Department district office having jurisdiction over the emissions unit and, where applicable, the Air Program Administrator of the appropriate Department-approved local air program within 45 days of completion of the test.

PETITION FOR ADMINISTRATIVE REVIEW

The Department will take the action described in this Order unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 of the Florida Statutes, or a party requests mediation as an alternative remedy under section 120.573 before the deadline for filing a petition. Choosing mediation will not adversely affect the right to a hearing if mediation does not result in a settlement. The procedures for petitioning for a hearing are set forth below, followed by the procedures for requesting mediation.

A person whose substantial interests are affected by the Department's proposed decision may petition for an administrative hearing in accordance with sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. Petitions must be filed within 21 days of receipt of this Order. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition (or a request for mediation, as discussed below) within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 of

the Florida Statutes, or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-5.207 of the Florida Administrative Code.

A petition must contain the following information:

- (a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department File Number, and the county in which the project is proposed;
- (b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
 - (d) A statement of the material facts disputed by each petitioner, if any;
- (e) A statement of facts that the petitioner contends warrant reversal or modification of the Department's action or proposed action;
- (f) A statement identifying the rules or statutes each petitioner contends require reversal or modification of the Department's action or proposed action; and,
- (g) A statement of the relief sought by each petitioner, stating precisely the action each petitioner wants the Department to take with respect to the Department's action or proposed action in the notice of intent.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this Order. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A person whose substantial interests are affected by the Department's proposed decision, may elect to pursue mediation by asking all panies to the proceeding to agree to such mediation and by filing with the Department a request for mediation and the written agreement of all such parties to mediate the dispute. The request and agreement must be filed in (received by) the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Fiorica 32399-3000, by the same deadline as set forth above for the filing of a petition.

A request for mediation must contain the following information:

- (a) The name, address, and telephone number of the person requesting mediation and that person's representative, if any;
 - (b) A statement of the preliminary agency action;
 - (r) A statement of the relief sought; and
 - (a) Either in explanation of how the requester's substantial interests will be affected by the action or proposed action addressed in this notice of intent or a statement clearly identifying the petition for hearing that the requester has already filed, and incorporating it by reference.

The agreement to mediate must include the following:

- (2) The names, addresses, and telephone numbers of any persons who may attend the mediation:
- (a) The name, address, and telephone number of the mediator selected by the parties, or a provision for selecting a mediator within a specified time;
 - (c) The agreed allocation of the costs and fees associated with the mediation;
- (i) The agreement of the parties on the confidentiality of discussions and documents introduced during mediation;
- (e) The date, time, and place of the first mediation session, or a deadline for holding the first session, if no mediator has yet been chosen;
- (f) The name of each party's representative who shall have authority to settle or recommend settlement; and
 - (g) The signatures of all parties or their authorized representatives.

As provided in section 120.573 of the Fiorida Statutes, the timely agreement of all parties to mediate will tall the time limitations imposed by sections 120.569 and 120.57 for requesting and holding an administrative hearing. Unless otherwise agreed by the parties, the mediation must be concluded within sixty days of the execution of the agreement. If mediation results in settlement of the auministrative dispute, the Department must enter a final order incorporating the greement of the parties. Persons whose substantial interests will be affected by such a modified final decision of the Department have a right to petition for a hearing only in accordance with the requirements for such petitions set forth above. If mediation terminates without settlement of the dispute, the Department shall notify all parties in writing that the administrative hearing processes under sections 120.669 and 120.57 remain available for disposition of the dispute, and the notice will

specify the deadlines that then will apply for challenging the agency action and electing remedies under those two statutes.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under section 120.542 of the Florida Statutes. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

The petition must specify the following information:

- (a) The name, address, and telephone number of the petitioner;
- (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;
 - (c) Each rule or portion of a rule from which a variance or waiver is requested;
 - (d) The citation to the statute underlying (implemented by) the rule identified in (c) above;
 - (e) The type of action requested;
 - (f) The specific facts that would justify a variance or waiver for the petitioner;
- (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and
- (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver, when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner. Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully

each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner. Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

This Order constitutes final agency action unless a petition is filed in accordance with the above paragraphs. Upon timely filing of a petition, this Order will not be effective until further Order of the Department.

RIGHT TO APPEAL

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Notice of Agency Action is filed with the Clerk of the Department.

DONE AND ORDERED this 17 day of March. 1997 in Tallahassee, Fiorida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

HOWARD L. RHODES, Director

Division of Air Resources Management

Twin Towers Office Euilding

2600 Elair Stone Road

Tallahassee, Florida 32399-2400

(904) 488-0114

CERTIFICATE OF SERVICE

The undersigned duly designated deputy clerk hereby certifies that a copy of the foregoing was mailed to Rich Piper, Chair, Florida Power Coordinating, Group, Inc., 405 Reo Street, Suite 100, Tampa, Florida 33609-1004, on this KFK day of March 1997.

. Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby zaknowledged.

LORIDA ELECTRIC POWER COORDINATING GROUP, INC. (FCG)
DS REG STREET, SUITE 100 • (\$13) 269-5644 • FAX (\$13) 269-5646
KMPA FLORIDA 33609-1004

January 28, 1997



Clair H. Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Department of Environmental Protection
2600 Elair Stone Road, MS 5505
Tallahassee, FL 32301

RECEIVED

JAN 28 1997

EUREAU OF

AIR REGULATION

RE: Comments Regarding Draft Title V Permits

Dear Mr. Fancy:

The Florida Electric Power Coordinating Group, Inc. (FCG), which is made up of 36 utilities owned by investors, municipalities, and cooperatives, has been following the implementation of Title V in Florida and recently submitted comments to you on draft Title V permit conditions by letter dated December 4, 1996. As indicated in that letter, representatives from the FCG would like to meet with you and other members of your air permitting staff to discuss some significant concerns that FCG member companies have regarding conditions that may be included in Title V permits issued by your office. While we will be discussing these issues with you and your staff in greater detail at that meeting, we would like to explain some of our concerns in this letter.

Primarily, the FCG members are concerned that the Title V permits may contain conditions that are much different in important respects than those conditions currently included in existing air permits. During the rulemaking workshops and seminars conducted by the Department to discuss the rules implementing the Title V permitting program, representations were made on several occasions that industry could expect to see permit conditions that were substantively similar to existing permit conditions and that primarily the format was changing. Representations were also made to industry that Title V did not impose additional substantive requirements beyond what was already required under the Department's rules. Based on the first draft Title V permit that we have reviewed, we are concerned that there may be some attempt to change the substantive requirements on existing facilities through the Title V permitting process, and we would like to discuss this with you at the meeting we have scheduled for January 30, 1997.

1. Federal Enforceability--The FCG has long been concerned about the designation of non-federally enforceable permit terms and conditions. We are concerned about this issue because the Department's first draft Title V permits have included language stating that all terms and conditions would become federally enforceable once the permit is issued. This approach is consistent with the Department's guidance memorandum dated September 13, 1995 (DAPM-PERVV-18), but we understand that the Department may now intend to remove all references to

Clair H. Fancy, P.E. Chief, Bureau of Air Regulation Florida Department of Environmental Protection January 28, 1997 Page 2

the federal enforceability of permit terms and conditions. We are also concerned about this approach because a Title V permit is generally federally enforceable and, without any designation of non-federally enforceable terms and conditions, the entire permit could be interpreted to be federally enforceable. As we stated in the December 4 letter as well as our letter dated October 11, 1996, all terms and conditions in a Title V permit do not become enforceable by the U.S. Environmental Protection Agency and citizens under the Clean Air Act simply by inclusion in a Title V permit. To make it clear which provisions in a Title V permit are not federally enforceable (which are being included because of state or local requirements only), it is very important to specifically designate those conditions as having no federally enforceable basis. Such a designation is actually required under the federal Title V rules, which provide that permitting agencies are to "specifically designate as not being federally enforceable under the Act any terms and conditions included in the permit that are not recuired under the Act or under any of its applicable requirements." 40 CFR § 70.6(b). We would like to discuss with you our concerns about this issue and to again specifically request that when Title V permiss are issued by the Department, conditions having no federally enforceable basis clearly be identified as such.

- 2. PM Testing on Gar-The FCG understands that the Department may attempt to require annual particulate matter compliance testing while firing natural gas to determine compliance with the 0.1 lb/mmEtu emission limit established under Rule 62-296.495(1)(1). F.A.C. The FCG member companies feel strongly that compliance testing for particulate maner should not be required while firing natural gas. The Department has not historically required particulate maner compliance testing while firing natural gas, it is not required under the current permits for these units, and it should not be necessary since natural gat is such a clean field Typically only de minimis amounts of particulate matter would be expected from the firing of natural gas, so compliance testing would not provide meaningful information to the Department, and the expense to conduct such tests is not justified. We understand that Department representatives suggested that industry could pursue an alternative test procedure under Rule 62-297.620, F.A.C., to allow a visible emissions test to be used in lier of a stack test for determining compliance with the particulate matter limit. While certainly a visible emissions test would be preferable over a stack test, neither of these tests should be needed to demonstrate compliance with the particulate matter limit of 0.1 lb/mmBtt while burning natural gas. The FCG strongly urges that the Department reconsider its position on this issue and clarify that compliance testing for particulate matter while firing natural gas is not required.
- 3. Excess Emissions--By letter dated December 5, 1995, the U.S. Environmental Protection Agency (EPA) submitted a letter commenting on a draft Title V permit that had been issued by the Department and indicated some concern regarding excess similaring included in conditions that were quoted from Rule 63-210.700, F.A.C. Because the permit conditions cited simply quote the applicable provisions of the Department's rules regarding

Clair H. Fancy, P.E.
Chief, Eureau of Air Regulation
Florida Department of Environmental Protection
January 28, 1997
Page 3

excess emissions and because these rules have been approved as part of Florida's State Implementation Plan, the permit conditions are appropriate to be included in the permit. We understand that the Department intends to include as applicable requirements in Title V permit conditions the provisions of Rule 62-210.700, F.A.C. If the Department receives any further adverse comments regarding the excess emissions rule under 62-210.700, F.A.C., we would appreciate your contacting us. Because this issue is so important to us, we would like to discuss it with you in greater detail at our meeting on January 30.

- Compliance Testing for Combustion Turbines-While the Department's November 22, 1995, guidance regarding the compliance testing requirements for combustion ti roines clearly states that the use of heat input curves based on ambient temperatures and humidities is to be included as a permit condition only if requested by a permittee, we understand that the Department may intend to include this requirement in Title V remnits for all combustion rurbines. As we are sure you recall, the FCG worked over a period of several months with the Department on the development of the guidance memorandum and it was clearly understood by FCG members that the heat input curves would not be mandated but would remain voluntary for any existing combustion turbine. It was also understood by FCG members that the requirement to conduct testing at 95 to 100 percent of capacity would be required only if the permit applicant requested the use of heat input curves. We understand that the Department may be interpreting the requirement to use heat input curves and to test at 95 to 100 percent of permitted capacity to be mandatory for all combustion turbines. We would like to clarify this with you during our meeting. Also, we would like to confirm that, regardless of whether a combustion turbine uses heat input curves or tests at 95 to 100 percent of permined capacity, it is necessary to test at four load points and correct to ISO only to determine compliance with the nitrogen oxides (NOx) standard under New Source Performance Standard Subpart GG under 40 CFR § 60.332 and not annually thereafter.
- 5. Test Methods--The FCG is concerned about the possibility of the Department requiring a full permit revision to authorize the use of an approved test method not specifically identified in a Title V permit, even though the Department may have separately approved the use of the particular test method for a unit (i.e., through a compliance test protocol). It is the FCG's position that language should be included in all Title V permits indicating that other test methods approved by the Department may be used. Further, a full permit revision (including public notice) should not be necessary when a test method not previously identified in the permit is approved for use by a unit. The Department's subsequent approval of test methods should simply be included in the next permit renewal cycle. The FCG understands that the Department planned to confirm this approach with the U.S. Environmental Protection Agency Region IV, and we would like to discuss this issue with you at the January 30 meeting to learn of the agency's response.

Clair H. Fancy, P.E. Chief, Bureau of Air Regulation Florida Department of Environmental Protection January 28, 1997 Page 4

- 6. Quarterly Reports--The FCG understands that the Department may be interpreting the quarterly reporting requirements under Rule 62-296.405(1)(g), F.A.C., to apply regardless of whether continuous emissions monitors were required under the preceding Rule 62-296.405(1)(f), F.A.C. It is the FCG's position that quarterly reports are required under Rule 62-296.405(1)(g) only when continuous emissions monitors are required under the preceding paragraph (f). While this may not be entirely clear from the language of the rules, paragraphs (f) and (g) were originally included in a separate rule on "continuous emission monitoring requirements" where it was very clear that the requirements of paragraph (g) applied only if continuous emission monitoring was required under paragraph (f). Research indicates that Rule 17-2.710, F.A.C. (copy attached), where these provisions were originally located, was first transferred to Rule 17-297.500, F.A.C. (which later became Rule 62-296.405(1)(f) and (g), F.A.C. To the extent that an emissions unit is not subject to Rule 62-296.405(1)(f) and is not required to install and operate continuous emissions monitors (e.g., 60-and gus-fired units), the quarterly reporting requirements of paragraph (g) should not apply.
- Trivial Activities—As you may recall, in Way of 1996, the FCG submitted to the Department a list of small, de minimis emissions units and activities that it considered to be "trivial," consistent with the list developed by EPA as part of the Title V "White Paper" and incorporated by reference by the Department in its March 15, 1996, guidance memorandum (DAPM-PERV-15-Revised). We never received a response from the Department and now understand that the Department may not have made a determination as to whether any of the emission units or activities on the list should qualify as "trivial." This is an important issue to the FCG because only "trivial" activities can be omitted from the Title V permit application and permit, and ultimately omitted from emission estimates in the annual air operation reports under Rule 62-210.370(3), F.A.C. The FCG remains hopeful that the Department will consider its request to determine that most, if not all, of the emission units and activities on the May, 1994, list to be "trivial." We would like to discuss a possible resciution of this issue with you and your staff at the January 30 meeting.
- 8. Permit Shield-The FCG continues to be concerned about the language in Conditions 5 and 20 of Appendix TV-1, Title V Conditions, which circumvents the permit shield provisions under Section 403.0872(15), Fiorida Statutes, and Rule 62-213.460, F.A.C. The FCG believes that these conditions should be deleted in their entirety. To the extent that the Department attempt to cavest the applicability of those conditions, the FCG believes that it is important to cite to not only the regulatory situation for the permit shield but the statutory citation as well.

Thank you again for considering the FCG's comments on the drift Title V permits. We very much appreciate the cooperation we have received from the Γ -partment throughout the

Clair H. Fancy, P.E. Chief, Bureau of Air Regulation Florida Department of Environmental Protection January 28, 1997 Page 5

Title V implementation process, and we look forward to our meeting later this week. If you have any questions in the meantime, please call me at 561-525-7661.

Sincerely,

Rich Piper, Chair A

Enclosures

Howard L. Rhodes, DEP cc: John Brown, DEP Pat Comer, DEF OGC Scott M. Sheplak, DEP Edward Svec. DEP FCG Air Subcomminee Angela Morrison, HGSS

10852

AP-42 FIFTH EDITION JANUARY 1995

COMPILATION OF AIR POLLUTANT EMISSION FACTORS

VOLUME I: STATIONARY POINT AND AREA SOURCES

Office Of Air Quality Flanning And Standards
Office Of Air And Redistion
U. S. Environmental Protection Agency
Research Triangle Park, NC 27711

1.4 Natural Gas Combustion

1.4.1 General¹⁻²

Natural gar is one of the major fuels used throughout the country. It is used mainly for industrial process steam and heat production; for residential and commercial space heating; and for electric power generation. Natural gas consists of a high percentage of methane (generally above 80 percent) and varying amounts of ethane, propane, butane, and inerts (typically nitrogen, carbon district, and helium). Gas processing plants are required for the recovery of liquefiable constituents and removal of hydrogen sulfide before the gas is used (see Section 5.3, Natural Gas Processing). The average gross heating value of natural gas is approximately 8900 kilocalories per standard cubic meter (1000 British thermal units per standard cubic foot), usually varying from 8000 to \$401 km (900 to 1100 Bru/sof).

1.4.2 Endwichs And Controls3-5

Fren though natural gas is considered to be a relatively clean-burning fuel, some emissions can result from combustion. For example, improper operating conditions, including poor air/fuel mixing, insufficient sit, etc., may cause large amounts of smoke, curbon monoxide (CO), and organic compliant emissions. Moreover, because a sulfur-containing mercaptan is added to natural gas to permit leak detection, small amounts of sulfur oxides will be produced in the combustion process.

Nitrogen exides (NO₂) are the major pollutants of concern when burning natural gas.

Nitrogen exides emissions depend primarily on the peak temperature within the combustion chamber at well as the turnace-zone exygen concentration, nitrogen concentration, and time of exposure at peak temperatures. Emission levels vary considerably with the type and size of combustor and with operating conditions (particularly combustion air temperature, load, and excess air level in boilers).

Currently, the two most prevalent NO_x control techniques being applied to natural gas-fired botters (which result in characteristic changes in emission rates) are low NO_x burners and five gas red to late. Low NO_x burners reduce NO_x by accomplishing the combustion process in stages. Sugging probably delays the combustion process, resulting in a cooler fiame which suppresses NO_x formation. The three most common types of low NO_x burners being applied to natural gas-fired patient to estaged air burners, staged fuel burners, and radiant fiber burners. Nitrogen oxide emission reductions of 40 to 85 percent (relative to uncontrolled emission levels) have been observed with low NO_x burners. Other combustion staging techniques which have been applied to natural gas-fired boilers include low excess air, reduced air preheat, and staged combustion (e.g., burners-out-si-service and overfire air). The degree of staging is a key operating parameter influencing NO_x mission rates for these systems.

In a fine gar recirculation (FGR) system, a portion of the fine gas is recycled from the small the burner windhox. Upon entering the windbox, the gas is mixed with combustion air prior to sing fed to the burner. The FGR system reduces NO, emissions by two mechanisms. The recycled was gas—mule up of combustion products which art as inerts during combustion of the fuel/sir limite. This additional mass is heated in the combustion zone, thereby lowering the peak fiame my tratter and reducing the amount of NO, formed. To a lesser extent, FGR also reduce; NO, trutted in by lowering the oxygen concentration in the primary fiame zone. The amount of five gas piroulated is a key operating parameter influencing NO, emission rates for these systems. Five gas

recirculation is normally used in combination with low NO, burners. When used in combination, -thuse techniques are capable of reducing uncontrolled NO, emissions by 60 to 90 percent.

Two post-combustion technologies that may be applied to natural gas-fired boilers to reduce NO, emissions by further amounts are selective noncatalytic reduction and selective catalytic reduction. These systems inject ammonia (or urea) into combustion five gase: to reduce inlet NO, emission rates by 40 to 70 percent.

Although not measured, all particulate matter (PM) from natural gas combustion has been estimated to be less than 1 micrometer in size. Particulate matter is composed of filterable and condensable fractions, based on the EPA sampling method. Filterable and condensable emission rates are of the same order of magnitude for boilers; for residential furnaces, most of the PM is in the form of condensable material.

'The rates of CO and trace organic emissions from boilers and furnaces depend on the efficiency of natural gas combustion. These emissions are minimized by combustion practices that promote high combustion temperatures, long residence times at those temperatures, and turbulent mixing of fuel and combustion air. In some cases, the addition of NO, control systems such as FGR and low NO, butters reduces combustion efficiency (due to lower combustion temperatures), resulting it higher CO and organic emissions relative to uncontrolled boilers.

Emission factors for natural gas combustion in bollers and furnates are presented in Tables 1.41, 1.42, and 1.45.6. For the purposes of developing emission factors, natural gas combustors have been organized into four general categories: utility/large industrial bollers, small industrial bollers, commercial bollers, and residential furnates. Bollers and furnaces within these categories share the same general design and operating characteristics and hence have similar emission characteristics when combusting natural gas. The primary factor used to demarcate the individual combustor categories is heat input.

Combustor Type	Filterable PM ⁶			Condensable PM ^d		
(Strc, 10 ⁶ Btu/br Heat Input) (SCC) ^b	kg/10 ⁶ in ³	jivto _e u _a	RATING	kg/106 m ³	11/10 ₆ U ₃	RATING
Utility/large industrial boilers (> 100) (1-01-006-01, 1-01-006-04)	16 - 80	1 - 5	· n	ND .	ND .	λИ
Small industrial boilers (10 - 100) (1:02-006-02)	. 99 ;		n	120	7.5	D
Commercial boilers (0.1 - < 10) (1:03:006:03)	72	. 1.4.5		120	7.5	C
Residential furnaces (<0.3) (No SCC)	2.11	. 0.18	.c	180	П	D

^{*} References 9-14. All factors represent uncontrolled emissions." Units are kg of pollutant/10⁶ cubic meters natural gas fired and the of pollutant/10⁶ cubic feet natural gas fired. Based on an average hatural gas higher heating value of 8270 kcal/m³ (1000 Btu/scf). The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. ND = no data. NA = not applicable.

SCC = Source Classification Code.

Elliterable PM is that particulate matter collected on or prior to the filter of an EPA Method 5 (or equivalent) sampling train.

d Condensable PM is that particulate matter collected using EPA Method 202, (or equivalent). Total PM is the sum of the filterable PM and condensable PM. All PM emissions can be assumed to be less than 10 micrometers in aerodynamic equivalent diameter (PM-10).

. Table 1.4-2 (Metric And English Units). EMISSION FACTORS FOR SULFUR DIOXIDE (SO₂), NITROGEN OXIDES (NO_x), AND CARBON MONOXIDE (CO) FROM NATURAL GAS COMBUSTION.

	•			· . · . · . ·				·	
Combustor Type	****	so ₁ °			NOx"	.		CO.	
(Size, 10 ⁶ Atu/hr Heat Input) (SCC) ^h	1:g/10 ⁶ m ¹	Pritog UT	יתאדווום'	kg/106 m ³	16/10 ⁶ 0 ³	מודגת	tg/106 m ³	IPALO _R U ₃	RATINO
Utility/large Industrial Boilers (> 100) (1-01-006-01, 1-01-006-04)		•			1:				
Uncontrolled	9.6	0.6	· · · · · · ·	8800 *	.sso ^r	λ	640	40	Τ
Controlled - Low MO _x hurners	ე.ი	0.6	. · · λ · ·	:1300	81°	<u>D</u>	तास	du	ИХ
Controlled - Flue gas recirculation	9.6	0.6	.	850	. 23 _t	 D	аи	ИD	. N A
Small Industrial Builers (10 - 100) (1-02-006-02)			· · · · ·					:	•
Uncontrolled	9.6	0.6	٨	2240	140	, Y	. 200	.35	λ
Controlled - Low 10_{x}	9.6	ሰ.ለ	٠ ٨	1100	81	מ	980	61	D
Controlled - Flue gas recirculation	9.6	ი. ი	, ,	480	• 30 .:: ::	·	590 •	"ה.	С
Commercial Doilers (0.3 - < 10) (1-03-006-03)	- 1		•		. :			•	
Uncontrolled	9.6	0.6	٠ ۲ :	1600	100	n	. 330	21	C
Controlled - Low NO _x burners	9,6	n.a _.	Λ.	270 .	17	C.	425	. 27	С
Controlled - Flue gas	2.6	በ.6	٨	580 .	16	. מ	, ND +	ND	λи
Residential Furnnees (<0.3) (No SCC)			•			•	٠		
Uncontrolled	9.6	0.6	: χ	1500	94	73	640	• 10	В

Units are kg of pollutant/10⁶ cubic meters natural gas fired and lb of pollutant/10⁶ cubic feet natural gas fired. Based on an average natural gas fired higher heating value of 8270 keal/m³ (1000 Btu/scf). The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. ND = no data. NA = not applicable.

b SCC = Source Classification Code.

⁶ Reference 7. Based on average sulfur content of natural gas, 4600 g/106 Nm¹ (2000 gr/106 scf).

a % Table 1.4-2 (cont.).

References 10,15-19. Expressed as NO₂. For tangentially fired units, use 4400 kg/10⁶ m³ (275 lb/10⁶ ft³). At reduced loads, multiply factor by load reduction coefficient in Figure 1.4-1: Note that NO_x emissions from controlled boilers will be reduced at low load

1 Emission factors apply to packaged boilers only.

Table 1.4-2 greate And English Units). EMISSION FACTORS FOR CARDON DIOXIDE (CO₂) AND TOTAL ORGANIC COMPOUNDS (f'OC) FROM NATURAL GAS COMPUSTION.

	., :	• :			•	
Combustor Type	CO ₂ c		TOC			
(Size, 10 ⁶ Blu/hr Heat Input) (SCC) ^h	kg/Ĭ0 ⁶ m ³	1P\10 _e U ₃	RATING	kg/10 ⁶ m ³	11710e U3	RATING
Utility/large industrial boilers (> 100) (1-01-006-01, 1-01-006-04)	ND¢	. CIN		281	1.7	С
Small industrial boilers (10 - 100) (1-02-006-02)	1.9 E+06	1.2 E+05	D	928	5.88	С
Commercial hoilers (0.3 - < 10) (1-03-006-03)	1.9 E+06	1.2 1: 1-05	С	128 ^h	8.01	C ·
Residential furnaces (No SCC)	2.0 15 1-06	1.3 E+05	מ	180h	11"	. D

All factors represent uncontrolled emissions. Units are kg of pollutant/10⁶ cubic meters and lb of pollutant/10⁶ cubic feet. Based on an average natural gas higher heating value of 8270 kcal/m³ (1000 Btu/scf). The emission factors in this table may be converted to other natural gas heating values by multiplying the given factor by the ratio of the specified heating value to this average heating value. NA = not applicable.

h SCC = Source Classification Code.

c References 10,22-23.

d References 9-10, 18.

^{&#}x27; ND = no daia.

Reference R: methane comprises 17% of organic compounds.

Reference R: methane comprises 52% of organic compounds.

h Reference B: methane comprises 34% of organic compounds.




Figure 1.4-1. Load reduction coefficient as a function of boiler load. (Úsed to decermine NO_x reductions at reduced loads in large boilers.)

- Reference: For Section 1.4 ...
- Exhaust Gases From Combustion and Industrial Processes, EPA Contract No. EESD 71-36, Engineering Science, Inc., Wighington, DC, Omober 1971. 2.
- Cremical Engineers' Hardocoit, Fourth Edition, J. H. Ferry, Editor, McGraw-Hill Ecok Company, New York, NY, 1963. the property of the property o
- Eccigrowe Information Document For Industrial Eollers, EFA-450/3-82-9068, U. S. Environmental Protection Agency, Research Triangle Park, NC, March 1982.
 - Eachground Information Document For Small Steam Generating Units, EPA-450/3-87-900, U. S. Esvironmental Protection Agency, Research Triangle Park, NC, 1987.
 - Fine Famiculate Emissions From Stationary and Miscellaneous Sources in the South Coast Air Eastin, California Air Resources Eoard Contract No. A6-191-30, KVE, Inc., Tustin, CA, February 1979.
 - Emission Feder Documentation for APIAN Section 1.4 Natural Gas Combustion (Draft), Technical Support Division, Office of Air Quality Planning and Standards, U. S. Environmental Protection Agency, Research Triangle Park, NC, April 1993.
- Systematic Field Study of NO Emission Control Methods For Utility Eollers, APTD-1163, U. S. Environmental F. Mection Agency, Recentch Triangle Park, NC, December 1971.
- Compilerion of Air Follission Emission Fedore, Fourth Edition, AF-42, U.S. Environments Protection Agency, Research Triangle Park, NC. September 1985.

- 9. J. L. Muhlbaier, "Particulate and Gaseous Emissions From Natural Gas Furnaces and Water Heaters", Journal of the Air Pollution Control Association, December 1981.
- Field Investigation of Emissions From Combustion Equipment for Space Heading, EPA-F2-73-084s, U. S. Environmental Protection Agency, Research Triangle Park, NC, June 1973.
- 11. N. F. Suprenant, et al., Emissions Assessment of Conventional Stationary Combustion Systems, Volume 1: Gas and Oil Fired Residential Hearing Sources, EPA-600/7-79-0296, U. S. Environmental Protection Agency, Washington, DC, May 1979.
- 12. C. C. Shih, et al., Emissions Assessment of Conventional Stationary Combustion Systems, Volume III: External Combustion Sources for Electricity Generation, EPA Contract No. 68-02-2197, TRW, Inc., Redondo Beach, CA, November 1980.
- 13. N. F. Suprenant, et al., Emissions Assessment of Conversional Stationary Combustion Systems, Volume IV: Commercial/Institutional Combustion Sources, EPA Contract No. 68-02-2197, GCA Corporation, Bedford, MA, October 1980.
- 14. N. F.: Suprenant, et al., Emissions Assessment of Conventional Stationary Combustion Systems, Volume V: Industrial Combustion Sources, EPA Contract No. 68-02-2197, GCA Corporation, Bedford, MA, October 1980.
- 15. Emissions Test on 200 HP Boller at Kaiser Hospital in Woodland Hills, Energy Systems Associates, Tustin, CA, June 1986.
- Results From Performance Tests: California Milk Producers Boller No. 5, Energy Systems

 Associates, Tustin, CA, November 1984.
- 17. Source Test For Measurement of Nitrogen Oxides and Carbon Monoxide Emission: From Eolier Exhaust at GAF Euliding Materials, Padific Environmental Services, Inc., Baldwin Park; CA, May 1991.
- S. J. P. Kesselring and W. V. Krill. "A Low-NO, Eurner For Gar-First Firetible Bollers", Froceedings: 1985 Symposium on Stationary Combustion NO, Control. Volume 2, EPRI CS-4360, Electric Power Research Institute, Paio Alto, CA, January 1986.
 - NO₂ Emission Control Technology Update, EPA Contract No. 68-01-6558, Rudian Corporation, Research Triangle Park, NC, January 1984.
 - Eachground Information Document For Small Steam Generating Unit: EX 4,450 (7,457,000). U. S. Environmental Protection Agency, Research Triangle Park, NC, 1987.
 - Evaluation of the Pollutant Emissions From Gas-Fired Forced Air Furnation Research Report No. 1503, American Gas Association Laboratories, Cleveland, OH, May 1975.
 - Thirty-day Field Tests of Industrial Bollers: Site 5 Gas-fired Low-NO, Eurnes, EPA-600/7-81-695a, U. S. Environmental Protection Agency, Research Triangle Park, NC, May 1981.
 - Private communication from Him Black (Industrial Combustion) to Reich Hards (NCR) | Independent Third Famy Source Tests, February 7, 1991

ORIDA

Best Available Copy

Department of

Environmental Protection

Lawton Chiles Governor Twin Towers Office Building 2600 Blair Scone Road Tallahassee, Fiorida 32399-2400

Virginia B. Wetherell Secretary

July 9, 1997

Certified Mail - Return Receipt Requested

Mr. Rich Piper, Chair Florida Power Coordinating Group, Inc. 405, Reo Street, Suite 100 Tampa, Florida 33609-1004

Dear Mr. Piper:

Enclosed is a copy of a Scrivener's Order correcting an error in the Order concerning particulate matter testing of natural gas fired boilers.

If you have any questions concerning the above, please call Yogesh Manocha at 904/488-6140, or write to me.

Sincerely,

M. D. Hariey, P.E., DEE

P.E. Administrator

Emissions Monitoring Section Bureau of Air Monitoring and

Mobile Sources

MDH:ym

ca: Dotty Diltz, FDEP Pat Comer, FDEP

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

In the matter of:	
Fiorida Electric Power Coordinating Group, Inc.,	ASP No. 97-B-01
Petitioner.	3

ORDER CORRECTING SCRIVENER'S ERROR

The Order which authorizes owners of natural gas fired fossil fuel steam generators to forgo particulate matter compliance testing on an annual basis and prior to renewal of an operation permit entered on the 17th day of March, 1997, is hereby corrected on page 4, paragraph number 4, by deleting the words "pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C.":

4. In renewing an air operation permit pursuant to Rule 62 210.300(2)(a)3.b., e., or d., F.A.C., the Department shall not require submission of particulate matter emission compliance test results for any fossil fuel steam generator emissions unit that burned liquid and/or solid fuel for a total of no more than 400 hours during the year prior to renewal.

DONE AND ORDERED this 2 day of July 1997 in Tallahassee, Fiorida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

HOWARD L. RHODES, Director

Division of Air Resources Management

Twin Towers Office Euilding

2600 Blair Stone Road

Tallahassee, Florida 32399-2400

(904) 488-0114

CERTIFICATE OF SERVICE

The undersigned duly designated deputy clerk hereby certifies that a copy of the foregoing was mailed to Rich Piper, Chair, Florida Power Coordinating Group, Inc., 405 Rep Street, Suite 100, Tampa, Florida 33609-1004, on this $10^{\frac{1}{10}}$ day of July 1997.

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to \$120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Mas The De 11/1/2/2 9/10/97

Clerk Date

PHASE II PERMIT APPLICATION

Page 1

For more information, see instructions and refer to 40 CFR 72.30 and 72.31 and Chapter 214, F.A.C.

This submission is:

X New

Revised

Step 1
Identify the source by
plant name, State, and
ORIS code from NADE

Indian River Plant	FI	683
Plant Name	State	ORIS Code

Step 2

Enter the boiler ID# from NADB for each affected unit, and indicate whether a repowering plan is being submitted for the unit by entering "yes" or "no" at column c. For new units, enter the requested information in columns d and e

	Comp	oliance Plan	_	
а	l b	С	l d	е
Boiler ID#	Unit Will	Repowering	New Units	New Units
	Hold Allow-	Plan		•
	ances in			
	Accordance		Commence	Monitor
	with 40 CFR		Operation Date	Certification
	72.9(c)(1)			Deadline

1	Yes	No		
2	Yes	No		
3	Yes	No		
С	Yes	No	01 Sep 1992	01 Jan 1995
D	Yes	No	01 Oct 1992	01 Jan 1995
	Yes			
_	Yes			

STEP 3 Check the box if the response in column c of Step 2 is "yes" for any unit

For each unit that will be repowered, the Repowering Extension Plan form is included and the Repowering Technology Petition form has been submitted or will be submitted by <u>June 1, 1997.</u>

DEP Form No. 62-610 900(1)(a) - Form Effective: 7-1-95

Indian River Plant

Step 4

Read the standard requirements and certification, enter the name of the designated representative, and sign and date

Standard Requirements

Permit Requirements:

- The designated representative of each Acid Rain source and each Acid Rain unit at the source shall: (i) Submit a complete Acid Rain part application (including a compliance plan) under 40 CFR part 72, Rules 62-214.320 and 330, F.A.C.; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary to review an Acid Rain part application and issue or deny an Acid Rain permit;
- The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain part application or a superseding Acid Rain part issued by the permitting authority; and (ii) Have an Acid Rain Part.

Monitoring Requirements:

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75, and Rule 62-214.420, F.A.C.
- The emissions measured recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor the emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements:

- The owners and operators of each source and each Acid Rain unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certificationunder 40 CFR part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1)(i) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements: The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements;

- The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall: (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77,

Recordkeeping and Reporting Requirements;

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5
- years, in writing by the Administrator or permitting authority:

 (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certification of representation changing the designated representative:
 - (ii) All emissions monitoring information, in accordance with 40 CFR part 75;
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

Indian River Plant

Recordkeeping and Reporting Requirements (cont.)

- (iv) Copies of all documents used to complete an Acid Rain part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability:

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain part application, an Acid Rain part, or written exemption under 40 CFR 72.7 or 72.8, including any requirement for payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 including 40 CFR 75.16, 75.17, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40CFR parts 72, 73, 75, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities: No provision of the Acid Rain Program, an Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any provision of the Act, including the provisions of title I of the Act relating to applicable National Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudent review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalities for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	Fred F. Haddad, Jr.
Signature AMM	Date 12/15/85

Indian River Plant

Step 5 (optional) Enter the source AIRS

and FINDS identification numbers, If known

AIRS	30-ORL-05-0008	
FINDS		

ATTACHMENT:

Acid Rain Phase II Permit Application Compilance Plan

Indian River Plant
Unit 1, Unit 2, Unit 3, CT-C, and CT-D


ORIS 683


The Orlando Utilities Commission (OUC) will hold SO2 allowances in each unit's compliance subaccount not less than the total annual emissions of sulfur dioxide emitted from each respective unit. Should additional allowances, beyond those allocated to OUC, be required, the Commission will purchase a sufficient number of allowances on the open market.

The Orlando Utilities Commission will comply with the applicable nitrogen oxide emissions limitation established by regulation.


		•	•	
•				
•			•	
	ATTACH	MENT A		
-				
•				
		•		
•		•		

OUC IRP COMBUSTION TURBINES A&B





OUC IRP COMBUSTION TURBINES A&B



ATTACHMENT B

Best Available Copy

APR | 2 |995

Westinghouse Electric Corporation Power Generation Business Unit Power Generation Projects Division

The Quadrangle 4400 Alafaya Trail Orlando Florida 32826-2399

CM/OPTMS/95-027

April 11, 1995

Mr. Bob Hicks Environmental Division Orlando Utilities Commission 500 South Orange Avenue P. O. Box 3193 Orlando, Florida 32802

FAX: (407) 236-9616

Re: Heat Input Curve for OUC Indian River, Units C and D, Base Load Operation

Dear Mr. Hicks:

Per your request to Mr. Joseph Macak, attached is the base load heat input (million Btu/hr, LHV) curve vs. ambient temperature applicable to OUC Indian River Units C and D, while operating on natural gas and distillate oil fuels. The curve reflects expected heat input with 60% relative humidity and is not to be construed as a commercial offering. Be advised that these values will vary slightly based on changes in meteorology and fuel quality. The plot points for typical fuel are as follows:

Base Load Heat Input (million Btu/nr, LHV)				
e Oil				
2				
2				
)				
5				
7				
0				

Should you have any further questions, please contact Ms. Lisa Beeson at (407) 281-5519.

Sincerely,

Thomas B. Czapleski

Manager, Operating Plant Technical and Materials Support

JJM:TBC

att.

OUC Indian River Units C and D
Base Load Heat Input (million Btu/hr, LHV) vs. Ambient Temperature

