# Sun-Sentinel

12/9/97

Attn: Vito Giarrusso

The following affidavit was mailed to Mr. Scott Sheplak. We received the letter back in our office on today. No other information is given other than a copy of the affidavit was also forwarded to you. I'm taking the liberty of forwarding the affidavit to you.

Thank you

Dedrie/Legal Dept

RECEIVED

NFC 19 1997

BUREAU OF AIR REGULATION

THE ISSUES OF

C / 10/02, 1 X

AFFIANT FURTHER SAYS THAT THE SAID SUN-SENTINEL IS

NEWSPAPEP PUBLISHED IN SAID BROWARD/PALM EEACH/DADE

SEEN CONTINUOUSLY PUBLISHED IN SAID BROWARD/PALM EEACH/DADE

GEEN CONTINUOUSLY PUBLISHED IN SAID BROWARD/PALM EEACH/DADE

SEEN CONTINUOUSLY PUBLISHED IN SAID BROWARD/PALM EEACH/DADE

SEEN CONTINUOUSLY PUBLISHED IN SAID BROWARD/PALM EEACH/DADE

COUNTY, FLORIDA, AND THAT THE SAID NEWSPAFER HAS HER PROPOSED.

COUNTY, FLORIDA, EACH DAY, AND HAS BEEN ENTERED AS

CLASS MATTER AT THE POST CFFICE IN FORT LAUDERDALE.

CLASS MATTER AT THE POST CFFICE IN FORT LAUDERDALE.

CLASS MATTER AT THE POST CFFICE IN FORT LAUDERDALE.

CREATER AT THE POST CFFICE IN FORT LAUDERDALE.

FORT LAUBERDALE, BROWARD COUNTY, FLORIDA

BCCA RATON, PALM BEACH COUNTY, FLORIDA

MIAMI, DADE COUNTY, FLORIDA

STATE OF FLORIDA

COUNTY OF BROWARD/PALM BEACH/DADE

BEFORE THE UNOTESIGNED AUTHORITY PERSONALLY APPEARE

CLASSIFIED DEPARTMENT OF THE SUM-SENTINEL, DAILY

NEMSPARE IS A DULK AUTHORITED REPRESENTATIVE OF THE

CLASSIFIED DEPARTMENT OF THE SUM-SENTINEL, DAILY

NEMSPARE PUBLISHED IN BRCWARD/PALM BEACH/DADE

IN THE MATTER OF

TITLE V DRAFT

IN THE CIRCUIT CCURT, WAS PUBLISHED IN SAID NEWSPAPE

AFFIANT FURTHER SAYS THAT THE SAID SUN-SENTINEL IS

AFFIANT FURTHER SAYS THAT THE SAID SUN-SENTINEL IS

AFFIANT FURTHER SAYS THAT THE SAID SUN-SENTINEL IS

NEWSPAPEP PUBLISHED IN SAID BROWARD/PALM BEACH/DADE

AFFIANT FURTHER SAYS THAT THE SAID SUN-SENTINEL IS

NEWSPAPEP PUBLISHED IN SAID BROWARD/PALM BEACH/DADE

(a) The point flore product from the floring through a time to the production of the sound of the

Broward County Departmetection
Air Quality Division
218 Southwest First Aven
Ft. Lauderdale, Ft. 33301
Telephone: 954/519-1493
The complete project file

rax: 954/519-1493 The complete project file includes the DRAFT Permit, the application, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, FS. Interested persons may contact Scott M. Sheplak, P.E., at the above acdress, or call 850/488-1344, for additional information.

### Memorandum

To: Vito Giarrusso, FPL

Sent Via Fax: 561/691-7070

From: Joe Kahn, DEP, Title V Section

**Date:** October 21, 1997

Re: FPL Port Everglades Draft Permit Comments

Draft Permit No. 0110036-001-AV

Per our teleconference October 15, 1997 and your comment letter dated October 14, 1997, following are the changes we propose to address your comments. Please look these over and call me with your comments.

The stack height for emissions units 001, 002, 003, and 004 will be changed from 343 ft. to 344 ft throughout the permit.

For emissions unit 005 the total rated capacity will be corrected to 504 MW.

For Facility-wide condition 10 electronic mail has been added as an option for submitting applicable correspondence. It has been noted that the Continuous Emission Monitoring data reported under the Acid Rain section is to be submitted to the Acid Rain Division in Washington.

10. <u>Submittals</u>. All reports, tests, notifications or other submittals required by this permit shall be submitted to the Broward County Department of Natural Resource Protection, Air Quality Division, and copies of those submittals shall be sent to the Department of Environmental Protection, Southeast District Office, Air Section. Certain correspondence may be submitted via electronic mail as appropriate. Certain Acid Rain Reports may be submitted to EPA's Acid Rain Division in Washington. Addresses and telephone numbers are:

On pages 7 and 11, the description of emissions units 001, 002, 003 and 004 will not include a reference to ash reinjection once we have received the revised permit application pages.

Conditions A.14 and B.14 have been changed to the following:

**A.14./B.14.** Operating Conditions During Testing - PM and VE. Compliance testing during sootblowing and steady-state operation for particulate matter and visible emissions shall be conducted at least once annually, if liquid fuel is fired for more than 400 hours. A visible emissions test shall be conducted during one run of each particulate matter test. The owner or operator shall conduct testing while operating under one of the following methods of operation (representative of normal operation to achieve the facility's target SO<sub>2</sub> emission rate of 1.1 lb/mmBtu):

a. When Burning 100% Fuel Oil. Particulate matter and visible emissions tests during sootblowing and steady-state operation shall be performed on such emissions unit while firing solely fuel oil of approximately 1% sulfur by weight (stoichiometrically representative

Memo to Vito Giarrusso, FPL October 21, 1997 Page 2 of 2

- of sulfur dioxide emissions of the target SO<sub>2</sub> emission rate of 1.1 lb/mmBtu), except that such test shall not be required to be performed during any year that testing is performed in accordance with specific condition **A.14.b/B.14.b**.
- b. When Burning Fuel Oil While Co-firing With Natural Gas. Particulate matter and visible emissions tests during sootblowing and steady-state operation shall be performed on such emissions unit while co-firing oil with the appropriate proportion of natural gas required to maintain SO<sub>2</sub> emissions between 90 to 100% of the target SO<sub>2</sub> emission rate of 1.1 lb/mmBtu heat input (corresponding to 1.0 and 1.1 lb/mmBtu heat input).

<u>Test Required if Target SO<sub>2</sub> Emission Rate Increased</u>. If the owner or operator target increases the target SO<sub>2</sub> emission rate above 1.1 lb/mmBtu, testing while operating under one of the above methods of operation that is representative of the new target SO<sub>2</sub> emission rate shall be conducted within 60 days of increasing the target rate.

{Note: The facility is operated under an informal agreement with Broward County to limit visible emissions to less than 20% opacity, to the extent possible. To achieve this, the facility voluntarily limits sulfur dioxide emissions to 1.1 lb/mmBtu by either firing fuel oil with up to 1% sulfur content, or by co-firing fuel oil and natural gas in a ratio to limit sulfur dioxide emissions to 1.1 lb/mmBtu.}

[Rules 62-4.070(3), 62-213.440, 62-296.405(1)(c)3. and 62-297.310(7)(a)9., F.A.C.]

In condition D.6 the wording "5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile" has been removed.

- **D.6.** <u>Frequency of Compliance Tests</u>. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.
- 4. During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:
  - a. Visible emissions, if there is an applicable standard;
- b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 100 tons per year or more of any other regulated air pollutant; and
  - c. Each NESHAP pollutant, if there is an applicable emission standard

The description of "turbine, Unit 5" in Condition D.9 will be changed to "bank of twelve combustion turbines."

Other comments from us that we addressed in the teleconference include the following:

On page S1 of Table 1-1 the equivalent emissions for PM<sub>SB</sub> should be 377.8 tons per year and has been changed.

On page S3 of Table 1-1 the equivalent emissions for PM<sub>SB</sub> should be 657 tons per year and has been changed.



Florida Power & Light Company, Environmental Services Dept., P.O. Box 14000, Juno Beach, FL 33408

October 16, 1997

Mr. Joseph Kahn, P.E.
State of Florida
Department of Environmental Protection
Division of Air Resources Management
Title V Section
Mail Station #5505
2600 Blair Stone Road
Tallahassee, FL 32399-2400

Re: Draft Permit No. 0110036-001-AV

FPL Port Everglades Plant Initial Title V Air

Operation Permit Comments

Dear Mr. Kahn:

Per your telephone conversation with Kathryn Pascale and Vito Giarrusso on 10/15/1997, attached are the revised permit pages, Section B. General Emission Unit Information page 2. for boiler units 1 thru 4.

Very truly yours,

J. Stanton

Plant General Manager

Florida Power & Light Company

RECEIVED

OCT 28 1997

BUREAU OF AIR REGULATION

Emission Unit Information	<b>Section</b>	of
---------------------------	----------------	----

# B. GENERAL EMISSIONS UNIT INFORMATION (Regulated and Unregulated Emissions Units)

# Emissions Unit Description and Status

1. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Port Everglades Boiler Unit 1
2. Emissions Unit Identification Number: 001 (No Corresponding ID or Unknown)
3. Emission Unit Status Code: (A or C): A
4. Acid Rain Unit? (Y/N): Y
5. Emissions Unit Major Group SIC Code: 49
6. Emissions Unit Comment (limit to 500 characters):  The generator nameplate rating given reflects information provided to the Florida Public Service Commission (PSC) in the 10-Year Site Plan. Actual generator output may exceed the stated value, and may var seasonally, or with changes in unit efficiency, and with fluctuations in system load demand.

## Emissions Unit Control Equipment

- A. Control Equipment #: 1
  - Description (limit to 200 characters):
     Multiple Cyclone with Fly Ash Reinjection
  - 2. Control Device or Method Code: Multiple Cyclone

Emission Unit Information Section	01	
-----------------------------------	----	--

# B. GENERAL EMISSIONS UNIT INFORMATION (Regulated and Unregulated Emissions Units)

# Emissions Unit Description and Status

1. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Port Everglades Boiler Unit 2	
2. Emissions Unit Identification Number: 002 (No Corresponding ID or Unknown)	
3. Emission Unit Status Code: (A or C): A	
4. Acid Rain Unit? (Y/N): Y	
5. Emissions Unit Major Group SIC Code: 49	
6. Emissions Unit Comment (limit to 500 characters):  The generator nameplate rating given reflects information provided to the Florida Public Service Commission (PSC) in the 10-Year Site Plan. Actual generator output may exceed the stated value, and may versesonally, or with changes in unit efficiency, and with fluctuations in system load demand.	/ary

# Emissions Unit Control Equipment

- A. Control Equipment #: 1
  - Description (limit to 200 characters):
     Multiple Cyclone with Fly Ash Reinjection
  - 2. Control Device or Method Code: Multiple Cyclone

Porto Effective: 3/21/96

Emission	Unit It	formation	Section	of
----------	---------	-----------	---------	----

# B. GENERAL EMISSIONS UNIT INFORMATION (Regulated and Unregulated Emissions Units)

# **Emissions Unit Description and Status**

1. Description of Emissions Unit Addressed in This Section (limit to Port Everglades Boiler Unit 3	60 characters):
Emissions Unit Identification Number: 003     (No Corresponding ID or Unknown)	
3. Emission Unit Status Code: (A or C): A	· · · · ·
4. Acid Rain Unit? (Y/N): Y	
5. Emissions Unit Major Group SIC Code: 49	•
6. Emissions Unit Comment (limit to 500 characters):  The generator nameplate rating given reflects information provided to the Flo Commission (PSC) in the 10-Year Site Plan. Actual generator output may exceed the seasonally, or with changes in unit efficiency, and with fluctuations in system load.	ne stated value, and may vary

# Emissions Unit Control Equipment A. Control Equipment #: 1

- - 1. Description (limit to 200 characters): Multiple Cyclone with Fly Ash Reinjection
  - 2. Control Device or Method Code: Multiple Cyclone

Emission Unit Information S	Section	of
-----------------------------	---------	----

# B. GENERAL EMISSIONS UNIT INFORMATION (Regulated and Unregulated Emissions Units)

### Emissions Unit Description and Status

1.	Description of Emissions Unit Addressed in This Section (limit to 60 characters):  Port Everglades Boiler Unit 4
2.	Emissions Unit Identification Number: 004 (No Corresponding ID or Unknown)
3.	. Emission Unit Status Code: (A or C): A
4,	. Acid Rain Unit? (Y/N): Y

6. Emissions Unit Comment (limit to 500 characters):


5. Emissions Unit Major Group SIC Code: 49

The generator nameplate rating given reflects information provided to the Florida Public Service Commission (PSC) in the 10-Year Site Plan. Actual generator output may exceed the stated value, and may vary seasonally, or with changes in unit efficiency, and with fluctuations in system load demand.

# **Emissions Unit Control Equipment**

- A. Control Equipment #:1
  - 1. Description (limit to 200 characters):
    Multiple Cyclone with Fly Ash Reinjection
  - 2. Control Device or Method Code: Multiple Cyclone

10/15/97 PT. EVERGLADES VITO GIARUSSON, FR. PAOUL -, AL JOE KAMIN, SUSAN DEVOLE DEP FPL COMMENTS - STACK Hr. SHOULD BE 344 FT. MW CAPACITY SHOULD BE 504 MW NEED REVISED PARES TO REMOVE ASH RETWEETAN - E-MAIL TO BE ADDED FRE 60%: 415, 40% OIL OR 1% 5 OIL TYPICALLY TO VOCUNTARICY CIMIT SO, EMISSIAN TO 1.1 18 SOZ/MMBTY DEP TO DRAFF REVISED LANGUAGE - D.6 DEL LED ACHLONITERE. D.9 CHANGE DESCRIPTION - P. 15 CAPACITY SHOULD BE SOY MIN - FUEL: NO. 2 SHOULD BE & TO LT. DISTURTE DESCH., C1, C3 DER COMMENTS P. SI # 8 , TABLE 1-1 PM JB EQUIV. EMISS SHOULD BE 377.8 TRY 1.53 or 8 PMSB EDVIV. EMISS STONED BE 657 THY PUBLISHED and 10/8/97.



# FPL ENVIRONMENTAL SERVICES DEPARTMENT PO BOX 14000 JUNO BEACH, FLORIDA 33408

DATE:	October 14,1997	
SEND TO:	Joe Kahn	
COMPAI	NY: FDEP	
FAX N	UMBER: 850 922 6979	
PHONE	NUMBER:	
	RICH PIPER	· · · · · · · · · · · · · · · · · · ·
PHONE NUMB	MBER: (561) 691- 7058 BER: (561) 691- 7070	
NUMBER O	F PAGES (INCLUDING COVER SHEET):	<u> </u>
	Everalades Comments	
uty/=4vek(tiker)dati);	To proper the second se	- 41



Florida Power & Light Company, Environmental Services Dept., P.O. Box 14000, Juno Beach, FL 33408

いだり

October 14, 1997

Mr. Scott Scheplak, P.E.
State of Florida
Department of Environmental Protection
Division of Air Resources Management
Title V Section
Mail Station #5505
2600 Blair Stone Road
Tallahassee, FL 32399-2400

Re: Draft Permit No. 00110036-001-AV

FPL Port Everglades Plant Initial Title V Air Operation Permit

#### Dear Mr. Sheplak:

After reviewing the subject draft Title V permit. FPL has identified several issues which need to be addressed. We plan to call you at 2 pm on Wednesday 10/15/97 to discuss them. Listed below are suggested changes to the language in the draft permit.

#### Section I. Facility Information

#### Page 2 - Subsection B. Summary of Emissions Unit No(s), and Brief Description(s).:

E.U. ID\_No's 001, 002, 003, and 004, stack height should be 344 ft. (Pg. 7 Section III, Subsection A., para. 2)

E.U. ID No. 005, the total capacity rated should be 504 MW. (Pg. 15 Section III, Subjection C, para. 1)

### Section II. Facility-wide Conditions

Page 5 - No. 10. <u>Submittals</u>: We propose adding an electronic mail as an additional option for applicable correspondence. Also note that Continuous Emission Monitoring data reported under the Acid Rain section is submitted to the Acid Rain Division in Washington.

### Section III. Emissions Unit(s) and Conditions

Pages 7 and 11 Description of Emission Units 001, 002, 003 and 004 - Each emission unit description includes a reference to ash reinjection. These references should be removed.

- MYTANGET あんななから、ノーリインリサイがLiveMin

YW.

W

Page 10 and 14 - A.14. and B.14. Operating Conditions During Testing - PM and VE: The Port Everglades facility currently operates their units under an informal agreement with Broward County in which visible emissions are controlled to less than 20% opacity, to the extent possible. In order to facilitate this, the plant generally fires low-sulfur oil (containing less than or equal to 1% sulfur) when firing 100% oil; and when cofiring oil with gas, they cofire with oil containing up to 2.5% sulfur and maintain their SO2 emissions at about 1.1 lb / mmBtu. In view of this situation, under condition A.14.a., the facility would end up particulate testing in a non-representative firing mode (e.g. if they only cofire with 2.5% oil, under the current language they would have to demonstrate compliance firing "solely" 100% 2.5% sulfur oil, a situation which never occurred during the previous 12 months). We therefore suggest that paragraph A.14.a. and B.14.a. be changed as follows:

<u>A.14. Operating Conditions During Testing - PM and VE.</u> Compliance testing during sootblowing and steady-state operation for particulate matter and visible emissions shall be conducted at least once annually, if liquid fuel is fired for more than 400 hours. A visible emissions test shall be conducted during one run of each particulate matter test. Testing shall be conducted under conditions representative of actual unit operation during the previous 12 month period as follows:

a. When Burning: Fuel Oil Up to 2.5% Sulfur. When only fuel oil containing less than or equal to 2.5% sulfur, by weight, is fired, (or co-fired with natural gas) in an emissions unit, particulate matter and visible emissions tests during sootblowing and steady-state operation shall be performed on such emissions unit while firing solely fuel oil containing at least 90% of the average sulfur content of the fuel oils fired in the previous 12 month period, except that the test may be performed while cofiring such oil with natural gas if it can be demonstrated that testing while cofiring is more representative of actual unit operation during the previous 12 month period. except that a Such test shall not be required to be performed during any year that testing is performed in accordance with specific condition A.14.b.

#### **Subsection D - Common Conditions**

· リリナン人ははおおんないが、ノイノ、リイダンはない。

Page 18 - <u>D.6. Frequency of Compliance Tests (a) 4. b.</u>; We request removing the wording "5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile;". The maximum potential to emit lead would be under the following unit conditions, burning 100% oil, at full load and for 8,760 hours resulting in 0.59 tons per year, all units included. Acrylonitrile is not emitted from these units.

Page 19 - <u>D.9. Visible Emissions - Turbines:</u> The description "turbine, Unit 5" should be changed to "bank of twelve combustion turbines".

V.

Thank you for your prompt attention to the issues raised in this correspondence. Please do not hesitate to contact me at (561) 691-7061 if I may be of further assistance.

Very truly yours,

Vito Giarrusão.

Sr. Environmental Specialist Florida Power & Light Company

VII.

البلاي