



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawson Chiles, Governor

Carol M. Browner, Secretary

PSD-112

~~South~~
North

October 4, 1991

XC
T. Porter
J. WEIGNER
P. CLAERBOUT
T. Kelly
C. Falter
T. KIRK
EMS - original

Eric N. Selya
Wheelabrator North Broward, Inc.
2600 N.W. 48th Street
Pompano Beach, Florida 33703

Re: North Broward RRF, PA 86-22

Dear Mr. Selya:

In accordance with Condition of Certification XIV.A.1.e., the Florida Department of Environmental Regulation approves alternate stack sampling procedures for the North Broward Resource Recovery Facility as outlined in your letter of September 16, 1991. The approval of the revised sampling protocol includes the following methods from 40CFR60, Appendix A:

~~PS. D. FL~~
~~#05~~
012119

1. Arsenic - Method 108.
2. V.E., Lime Silo - Method 9.
3. Flyash conditioning dust collector Methods 5 and 9.
4. NO_x, SO₂, and CO - Methods 7E, 6C and 10 (instrumental)

If you have any questions concerning this please let me know.

Sincerely,

Hamilton S. Owen

Hamilton S. Owen, P.E.
Administrator
Siting Coordination Office
Division of Air Resources
Management

HSO/

cc: Tom Tittle
A. L. Linero