

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
NOTICE OF FINAL PERMIT MODIFICATION

In the Matter of an  
Application for Permit Modification


Mr. Thomas D. Kirk, Plant Manager  
Wheelabrator North Broward, Inc.  
2600 Northwest 48th Street  
Pompano Beach, Florida 33073

DEP File No. PSD-FL-112  
North Broward Resource Recovery Facility

Enclosed is a letter that modifies Permit Number PSD-FL-112 to allow the use of EPA Method 29 in lieu of Method 101A for Mercury, Method 12 for lead, Method 104 for beryllium and Method 108 for arsenic for annual compliance stack testing. This permit modification is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.

  
C.H. Fancy, P.E., Chief  
Bureau of Air Regulation


**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF FINAL PERMIT MODIFICATION (including the FINAL permit Modification) was sent by certified mail (\*) and copies were mailed by U.S. Mail before the close of business on 5-22-97 to the person(s) listed:

Mr. Thomas D. Kirk, Wheelabrator North Broward Inc.\*  
Mr. Brian Beals, EPA  
Mr. John Bunyak, NPS  
Ms. Terri Hillard, SED  
Ms. Daniela Banu, Broward County

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date,  
pursuant to §120.52(7), Florida Statutes, with the designated  
Department Clerk, receipt of which is hereby acknowledged.

  
(Clerk) 5-22-97  
(Date)

Fold at line over top of envelope to

Is your RETURN ADDRESS completed on the reverse side?

**SENDER:**

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

- Addressee's Address
- Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to: Thomas D. Kirk, Plant Mgr. Wheelabrator N. Broward 2600 NW 48th Street Pompano Beach, FL 33073	4a. Article Number P 265 659 186
5. Received By: (Print Name) Rudler Pearce	4b. Service Type <input type="checkbox"/> Registered <input checked="" type="checkbox"/> Certified <input type="checkbox"/> Express Mail <input type="checkbox"/> Insured <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> COD
6. Signature: (Addressee or Agent) X	7. Date of Delivery 5/27
	8. Addressee's Address (Only if requested and fee is paid)

Thank you for using Return Receipt Service.

PS Form 3811, December 1994 Domestic Return Receipt

P 265 659 186

US Postal Service  
**Receipt for Certified Mail**

No Insurance Coverage Provided.  
Do not use for International Mail (See reverse)

Sent to	Thomas Kirk
Street & Number	Wheelabrator North B.
Post Office, State, & ZIP Code	Pompano Bch, FL
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, & Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	5-22-97
	PSD-FI-112

PS Form 3800 April 1995

*Test Method Change***Wheelabrator North Broward Inc.**

A Wheelabrator Technologies Company  
2600 N.W. 48th Street  
Pompano Beach, FL 33073

Phone 954.971.8701  
Fax 954.971.8703

February 24, 1997

**CERTIFIED MAIL #Z 784 818 809  
RETURN RECEIPT REQUESTED**

Al Linero  
Florida Department of Environmental Protection  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

Re: **Wheelabrator North Broward  
Use of EPA 29**

*PSD-FI-112*

Dear Mr. Linero:

Wheelabrator North Broward is requesting to utilize EPA Method 29 in lieu of Method 101A for mercury, Method 12 for lead, Method 104 for beryllium and Method 108 for arsenic during the upcoming annual compliance stack testing. At present, stack testing is scheduled for March 21-23, 1997.

EPA Method 29 has been approved by the EPA and is incorporated in 40 CFR subpart Eb.

If the Department finds the use of Method 29 acceptable, please contact me at (954) 971-8701, extension 210, or in my absence, Chuck Faller at extension 250.

Very truly yours,

Thomas D. Kirk  
Plant Manager

970224.TDK

cc: **Tim Porter  
Chuck Faller  
Frank Ferraro  
Terri Hilliard, FDEP, West Palm Beach \* Certified Mail # Z 784 818 810  
Don Markley**