



Wheelabrator North Broward Inc.

A Waste Management Company

2600 N.W. 48th Street
Pompano Beach, FL 33073
(954) 971-8701
(954) 971-8703 Fax

RECEIVED

APR 24 2009

BUREAU OF AIR REGULATION

April 23, 2009

UPS # 1Z26X1500191677200

Mr. Lennon Anderson
Air Program Administrator
Florida Department of Environmental Protection
Southeast District
400 North Congress Ave., Suite 200
West Palm Beach, FL 33401

Re: Wheelabrator North Broward
2009 Annual Compliance Stack Test and RATA Reports

Dear Mr. Anderson:

Please find enclosed a copy of the final compliance stack test report and the continuous emissions monitoring system certification RATA report for testing conducted on March 10-12 of this year by Clean Air Engineering, Inc.

I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this submittal. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements and information in this document are true, accurate and complete.

If there are any questions, please contact this office at (954) 971-8701.

Sincerely,

Scott McIlvaine
Plant Manager

cc: USEPA, Region IV, Pesticides and Toxics Management Division, Air & EPCRA Enforcement Branch, Air Enforcement Section (with) UPS# 1Z26X1500191930417

FDEP, Tallahassee, Bureau of Air Regulation, New Source Review Section,
(with) UPS# 1Z26X1500193275024

Broward County Department of Planning and Environmental Protection, Air Quality Division
(with) UPS# 1Z26X1500191787038

Chuck Faller (with)
Ram Tewari – BCWRS (without)
Tim Porter (without)
Rob French – MPI (with)





Wheelabrator North Broward, Inc.
2600 NW 48th Street
Pompano Beach, FL 33073


REPORT ON COMPLIANCE TESTING

Performed for:
**WHEELABRATOR NORTH BROWARD, INC.
ASH HANDLING SYSTEM, LIME SILO VENTS,
UNITS 1, 2 AND 3 SDA INLETS, FF OUTLETS AND STACKS
POMPAÑO BEACH, FL
VOLUME I OF II**

CleanAir Project No: 10735-2
Revision 0: April 22, 2009

To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the actual emissions during the test program.

Submitted by,



Scott Brown
Project Manager
sbrown@cleanair.com
(800) 627-0033 ext. 4544

Reviewed by,



Mark Roach, P.E.
Engineering Group Technical Leader
mroach@cleanair.com
(800) 627-0033 ext. 4599

REVISION HISTORY

REPORT ON COMPLIANCE TESTING

DRAFT REPORT REVISION HISTORY

Revision:	Date	Pages	Comments
DOa	04/15/09	All	Draft version of original document.

FINAL REPORT REVISION HISTORY

Revision:	Date	Pages	Comments
0	04/22/09	All	Final version of original document.

CONTENTS

1	PROJECT OVERVIEW	1-1
	INTRODUCTION	1-1
	Key Project Participants	1-1
	Test Program Parameters	1-2
	TEST PROGRAM SYNOPSIS.....	1-3
	Test Schedule	1-3
	Table 1-1: Schedule of Activities	1-3
	Results Summary	1-4
	Table 1-2: Summary of Test Results	1-4
	Table 1-3: Subpart Cb Required Operating Data	1-5
	Table 1-4: Opacity and Fugitive Emission Test Results.....	1-5
	Discussion of Test Program	1-5
2	RESULTS	2-1
	Table 2-1: Unit 1 FF Outlet – Particulate, Metals and Mercury	2-1
	Table 2-2: Unit 1 FF Outlet - Fluorides.....	2-2
	Table 2-3: Unit 1 FF Outlet - PCDDs/PCDFs	2-3
	Table 2-4: Unit 1 FF Outlet and SDA Inlet - Hydrogen Chloride	2-4
	Table 2-5: Unit 2 FF Outlet – Particulate, Metals and Mercury	2-5
	Table 2-6: Unit 2 FF Outlet - Fluorides.....	2-6
	Table 2-7: Unit 2 FF Outlet and SDA Inlet - Hydrogen Chloride	2-7
	Table 2-8: Unit 3 FF Outlet – Particulate, Metals and Mercury	2-8
	Table 2-9: Unit 3 FF Outlet - Fluorides.....	2-9
	Table 2-10: Unit 3 FF Outlet and SDA Inlet - Hydrogen Chloride	2-10
	Table 2-11: Units 1, 2 and 3 FF Outlets – Opacity by COMS.....	2-11
	Table 2-12: Ash Handling System - Fugitive Emissions.....	2-12
	Table 2-13: Lime Silo Fabric Filter Outlet - Visible Emissions	2-12
	Table 2-14: Air Flow Summary.....	2-13
	Table 2-15: Quality Control and Quality Assurance PCDD/PCDF - Extraction Standard Percent Recoveries.....	2-14
	Table 2-16: Quality Control and Quality Assurance PCDD/PCDF – CS/SS Percent Recoveries	2-14
	Table 2-17: Quality Control and Quality Assurance - Metals	2-15
	Table 2-19: Quality Control and Quality Assurance - Method and Field Blanks	2-17
	Table 2-20: Quality Control and Quality Assurance - Miscellaneous	2-18

CONTENTS

3 DESCRIPTION OF INSTALLATION..... 3-1
PROCESS DESCRIPTION..... 3-1
 Figure 3-1: General Process Schematic 3-1
 Figure 3-2: Process Schematic 3-2
 Table 3-1: Unit 1 Compliance Test Process Data 3-3
 Table 3-2: Unit 2 Compliance Test Process Data 3-4
 Table 3-3: Unit 3 Compliance Test Process Data 3-5
DESCRIPTION OF SAMPLING LOCATIONS..... 3-6
 Table 3-4: Sampling Points 3-6
 Figure 3-3: SDA Inlets - Sampling Point Determination (HCl Sampling) 3-7
 Figure 3-4: FF Outlets - Sampling Point Determination 3-8

4 METHODOLOGY 4-1
 Table 4-1: Summary of Sampling Procedures 4-1

5 APPENDIX..... 5-1
TEST METHOD SPECIFICATIONS..... A
SAMPLE CALCULATIONS..... B
PLANT DATA..... C
PARAMETERS D
QA/QC DATA..... E
FIELD DATA F
FIELD DATA PRINTOUTS G
LABORATORY DATA..... H
PERTINENT CERTIFICATIONS I
CORRESPONDENCE AND CLARIFICATIONS J

PROJECT OVERVIEW

1-1

INTRODUCTION

Wheelabrator North Broward, Inc. operates a Refuse to Energy facility, located in Pompano Beach, Florida. The facility's emission levels are regulated by the Florida Department of Environmental Protection (FDEP). Wheelabrator North Broward, Inc. contracted Clean Air Engineering (CleanAir) to perform a compliance test program. The lime silo fabric filter vent was observed for visual emissions (VEs) and the ash handling system was observed for fugitive emissions.

The VEs were determined by the facility's continuous opacity monitor system (COMS) data, as allowed under Title V Conditions A.36 (6), A.53 and A.54. The lime silo fabric filter vent was observed for VEs and the ash handling system was observed for fugitive emissions. Testing was conducted in accordance with the Wheelabrator North and South Broward Protocol on Compliance, dated February 5, 2009, 40 CFR 60 Subpart Cb, and applicable sections of the facility's Title V Permit number 0112120-009-AV.

All testing was conducted in accordance with the regulations set-forth by the United States Environmental Protection Agency (EPA) and the FDEP.

Key Project Participants

Individuals responsible for coordinating and conducting the test program were:

C. Faller – Wheelabrator North Broward
S. Brown – CleanAir

Patty Tampas of the FDEP was present for portions of the test program.

The CleanAir test crew consisted of the following individuals:

B. Wiltse
R. Vicere
P. Bihun
C. Slimp
P. Collins
S. Joint

PROJECT OVERVIEW

1-2

Test Program Parameters

The sampling was conducted at the Units 1, 2 and 3 Spray Dry Absorption (SDA) Inlet and Fabric Filter (FF) Outlets from March 10 through 12, 2009, and included the following emissions measurements:

- beryllium;
- cadmium;
- lead;
- mercury;
- PCDDs and PCDFs (Unit 1 only);
- total suspended particulate (TSP);
- hydrogen chloride;
- fluoride;
- visual emissions;
- fugitive emissions.

PROJECT OVERVIEW

TEST PROGRAM SYNOPSIS

Test Schedule

The on-site schedule followed during the test program is outlined in Table 1-1.

**Table 1-1:
Schedule of Activities**

Run	Location	Method	Analyte	Date	Start Time	End Time
1	Unit 1 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/10/09	06:48	09:03
1	Unit 2 SDA Inlet/FF Outlet	USEPA Mod. Method 26A	HCl	03/10/09	06:51	08:03
1	Unit 3 FF Outlet	USEPA Method 13B	Total Fluorides	03/10/09	08:17	10:32
2	Unit 2 SDA Inlet/FF Outlet	USEPA Method 26A	HCl	03/10/09	08:38	09:38
2	Unit 1 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/10/09	09:25	11:37
3	Unit 2 SDA Inlet/FF Outlet	USEPA Method 26A	HCl	03/10/09	10:04	11:04
1	Unit 1 FF Outlet	USEPA Method 23	PCDD/F	03/10/09	10:08	14:30
2	Unit 3 FF Outlet	USEPA Method 13B	Total Fluorides	03/10/09	11:31	12:49
3	Unit 1 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/10/09	11:59	14:13
3	Unit 3 FF Outlet	USEPA Method 13B	Total Fluorides	03/10/09	13:16	14:30
2	Unit 1 FF Outlet	USEPA Method 23	PCDD/F	03/11/09	06:26	11:05
1	Unit 3 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/11/09	06:46	08:58
1	Unit 3 SDA Inlet/FF Outlet	USEPA Method 26A	HCl	03/11/09	06:57	07:57
1	Unit 2 FF Outlet	USEPA Method 13B	Total Fluorides	03/11/09	07:30	08:48
2	Unit 3 SDA Inlet/FF Outlet	USEPA Method 26A	HCl	03/11/09	08:29	09:29
2	Unit 3 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/11/09	09:24	11:38
3	Unit 3 SDA Inlet/FF Outlet	USEPA Method 26A	HCl	03/11/09	10:02	11:02
3	Unit 1 FF Outlet	USEPA Method 23	PCDD/F	03/11/09	11:26	15:45
2	Unit 2 FF Outlet	USEPA Method 13B	Total Fluorides	03/11/09	11:28	12:46
3	Unit 3 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/11/09	11:58	14:10
3	Unit 2 FF Outlet	USEPA Method 13B	Total Fluorides	03/11/09	13:12	14:24
1	Unit 2 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/12/09	06:29	08:40
1	Unit 1 SDA Inlet/FF Outlet	USEPA Method 26A	HCl	03/12/09	06:36	07:36
4	Unit 1 FF Outlet	USEPA Method 23	PCDD/F	03/12/09	06:42	11:13
1	Lime Silo FF Outlet	USEPA Method 9	Opacity	03/12/09	08:16	10:12
2	Unit 1 SDA Inlet/FF Outlet	USEPA Method 26A	HCl	03/12/09	08:25	09:25
2	Unit 2 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/12/09	08:58	11:20
3	Unit 1 SDA Inlet/FF Outlet	USEPA Method 26A	HCl	03/12/09	10:10	11:10
3	Unit 2 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/12/09	11:39	13:49
1	Unit 1 FF Outlet	USEPA Method 13B	Total Fluorides	03/12/09	11:47	12:59
1	Ash handling System	USEPA Method 22	Fugitive Emissions	03/12/09	12:48	16:28
2	Unit 1 FF Outlet	USEPA Method 13B	Total Fluorides	03/12/09	13:09	14:19
3	Unit 1 FF Outlet	USEPA Method 13B	Total Fluorides	03/12/09	14:33	15:43

PROJECT OVERVIEW

TEST PROGRAM SYNOPSIS (CONTINUED)

1-4

Results Summary

Table 1-2 summarizes the results of the test program. A more detailed presentation of the test conditions and results of analysis are shown in Tables 2-1 through 2-20 on pages 2-1 through 2-18. Subpart Cb required operating data is summarized in Table 1-3, and opacity and fugitive emission results are presented in Table 1-4, both on page 1-5.

**Table 1-2:
Summary of Test Results**

<u>Source</u>	<u>Average Unit 1</u>	<u>Average Unit 2</u>	<u>Average Unit 3</u>	<u>Permit Limit¹</u>
Constituent				
Particulate (mg/dscm @7% O ₂)	<0.63	0.63	1.1	27/25
Visual Emissions (% by COMS) ²	0	0	0	10
Fluoride (lb/MMBtu as HF) ³	<0.000024	<0.000023	<0.000027	0.0040
Total PCCD/PCDF (ng/dscm @ 7% O ₂)	0.62	NA	NA	30
Hydrogen Chloride (ppmdv @ 7% O ₂) <u>or</u>	17	16	8	29
Hydrogen Chloride Removal (%) ⁴	97%	96%	98%	>95
Beryllium (mg/dscm @ 7% O ₂)	<0.000028	<0.000030	<0.000028	0.001
Cadmium (mg/dscm @ 7% O ₂)	<0.00020	<0.00012	<0.00013	0.040/0.035
Lead (mg/dscm @ 7% O ₂)	0.00047	0.00039	0.00045	0.44/0.40
Mercury (µg/dscm @ 7% O ₂)	8.0	12	5.0	70/50
Average Steam Flow (Klbs/hr) ⁵	183.9	184.1	184.0	186
Average FF Inlet Temperature (°F) ⁵	320	321	320	NA

¹Limits obtained from facilities Title V Permit 0112119-009-AV. If a second limit is shown that limit is being implemented by the EPA as of April 28, 2009.

²Visual Emissions (opacity) was obtained from the facilities COMS data as allowed under Title V Conditions B.53(6), B.76 and B.8.1.

³lb/MMBtu calculations used Fd of 9,570 for MSW as per Method 19.

⁴Removal for hydrogen chloride calculated in the unit of its standard (ppmdv @ 7% O₂). The hydrogen chloride limit is 29 ppmdv @ 7% O₂ or 95% removal, whichever is less stringent.

⁵From all compliance test runs.

PROJECT OVERVIEW

1-5

**Table 1-3:
Subpart Cb Required Operating Data**

Process Condition

Unit 1 Maximum Demonstrated Combustor Load (Klbs/hr) ¹	184.5
Unit 2 Maximum Demonstrated Combustor Load (Klbs/hr) ¹	183.9 ²
Unit 3 Maximum Demonstrated Combustor Load (Klbs/hr) ¹	184.1 ³
Unit 1 Maximum Particulate Control Device Inlet Temperature (°F) ⁴	322
Unit 2 Maximum Particulate Control Device Inlet Temperature (°F) ⁴	325 ²
Unit 3 Maximum Particulate Control Device Inlet Temperature (°F) ⁴	325 ³

¹ From 40CFR60.58b (i) (8) the maximum demonstrated load during PCDD/PCDF testing, four hour average.

² From CleanAir Cb test report dated April 19, 2007.

³ From CleanAir Cb test report dated April 30, 2008.

⁴ From 40CFR60.58b (i) (9) the highest four hour average during PCDD/PCDF testing.

**Table 1-4:
Opacity and Fugitive Emission Test Results**

<u>Source</u>	<u>Constituent</u>	<u>Sampling Method</u>	<u>Results</u>	<u>Permit Limit¹</u>
<u>Ash Handling System²</u>				
	Fugitive Emissions (% of obseravtion time)	EPA M22	0	5%
	Fugitive Emissions (minutes)		0	9 minutes
<u>Lime Silo³</u>				
	Visual Emisssions (%)	EPA M9	0	5%

¹ Limits obtained from 40 Code of Federal Register part 60 Subpart Cb - Emission Guidelines and Compliance Times for Large Municipal Waste Combustors That Are Constructed on or Before September 20, 1994 published in Federal Register as 62 FR 45 123 on December 19, 1995 as modified on August 25, 1997, Florida's Rule 62-296.416, F.A.C. and PSD-FL-105.

² The Ash Handling System was observed at various locations for a total of 3 hours.

³ The Lime Silo was observed for one complete truck unloading.

Discussion of Test Program

All test methods were done in triplicate. All data that is reported in the units of lb/MMBTU utilized the Fd of 9,570 as per EPA Method 19.

All equipment utilized for compliance testing was manufactured by Clean Air Engineering, except for the Servomex O₂/CO₂ analyzer utilized for all of the integrated gas sample bag analysis.

PROJECT OVERVIEW

During compliance testing, all three (3) boilers were operated within 10% of the 186,000 lb/hr maximum steam flow rating. The result tables present each boiler's steam output for every test run.

Shawn Joint performed the fugitive emission readings (per EPA Method 22) on the ash handling system. Ben Wiltse conducted the VE readings (per EPA Method 9) on the Lime Silo during one (1) entire truck unloading. Mr. Wiltse's VE evaluation certificate is presented in Appendix I.

Any fractions of the mercury analysis that were reported as not detected were summed as zero, if there was at least one (1) fraction detected in that run. The beryllium, cadmium and lead front- and back-half fractions were combined proportionately for analysis per EPA Method 29, Section 5.4.

Field blanks were collected for the Method 23 and 29 testing by assembling a used set of glassware, taking the complete train to the outlet location and performing a leak check. These samples were treated exactly as the other samples. The results for the Method and Field Blanks are presented in Table 2-19 on page 2-17, as well as Appendix H. The results of the Method 29 reagent blank analysis were used to correct any data, as outlined in Method 29.

All Method 23 samples were analyzed with the DB-5S column with modified calibration and additional quality assurance procedures as a direct substitute for the DB-5 and DB-225 columns. Confirmation of the 2,3,7,8 TCDF and TCDD 2,3,7,8 isomers was performed on the DB-5S column. The DB-5S column and modified calibration procedures meets the column separation requirement and can be used as a direct substitute for the DB-5 and DB-225 columns, in accordance with Method 23 as approved by the EPA. All QA/QC data (spikes and recoveries) for Method 23, as well as the EPA Audit Sample results, are presented in Appendix H.

The Method 23 results for Runs 3 and 4 each contained at least one (1) estimated maximum possible concentration (EMPC) value. EMPC results do not meet all the identification criteria required by Method 23 to be positively identified as a dioxin or furan. Specifically, the integrated ion abundance ratios were not within 15% of the theoretical value limits specified in Method 23 Section 5.3.2.5, Table 4. The laboratory reports EMPC results as zero and, for this reason, all EMPC results are enclosed in brackets and are considered zero when calculating total dioxin/furans.

PROJECT OVERVIEW

1-7

Chuck Faller of Wheelabrator North Broward, Inc. provided the process (operating) data. This data is presented in its entirety in Appendix C. All process data and CleanAir run times are based on facility CEM and Bailey Computer Time, which is 60 minutes earlier than actual Eastern Standard Time (EST). The Lime Silo opacity start and stop times are based on EST, since the initial and final truck weights were recorded using “real” time.

Integrated gas samples (IGS) were collected in a vinyl sample bag from every sample train. The contents of the bag were then analyzed for O₂ and CO₂ concentrations using an O₂/CO₂ continuous monitoring analyzer calibrated with EPA Protocol gases. A linearity and bias check was performed on the analyzers before each set of bags was analyzed, and then a post bias check was performed after each set of bags was analyzed. All data was recorded using CleanAir’s data acquisition system. The results of the IGS bag analyses are presented in Appendix G.

Metals and particulate matter sampling were combined during this test program per the Method 29 Section 1.2 Principle, “This method may be used to determine particulate emissions in addition to the metals emissions if the prescribed procedures and precautions are followed”.

Sixty-minute Method 26A sample trains at the SDA Inlets and FF Outlets were utilized to exhibit compliance with each unit’s HCl limit(s). The Method 26A was modified to a single-point constant sampling rate at all test locations.

The FDEP supplied audit samples for PCDD/PCDF, metals, HF and HCl to CleanAir. The analytical results of these samples are presented in Appendix H, along with each respective lab report.

During recovery of Run 2 of the Method 23 (PCCD/PCDF) XAD, the sample trap accidentally broke and the XAD sorbent was compromised. The test run was invalidated and two (2) additional test runs, labeled Runs 3 and 4, were performed.

End of Section 1 – Project Overview

RESULTS

2-1

**Table 2-1:
Unit 1 FF Outlet – Particulate, Metals and Mercury**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:48	09:25	11:59	
Stop Time (approx.)	09:03	11:37	14:13	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	185.4	183.9	183.7	184.3
P ₁ Fabric Filter Inlet Temperature (°F)	320	320	320	320
Gas Conditions				
O ₂ Oxygen (dry volume %)	7.6	8.3	8.4	8.1
CO ₂ Carbon dioxide (dry volume %)	11.7	11.4	11.3	11.5
T _s Sample temperature (°F)	307	307	307	307
B _w Actual water vapor in gas (% by volume)	22.7	22.3	21.3	22.1
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	164,030	172,929	171,587	169,515
Q _{std} Volumetric flow rate, dry standard (dscfm)	86,185	91,330	91,825	89,780
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	65.91	69.19	67.92	67.68
%I Isokinetic sampling (%)	100.0	99.1	96.7	98.6
Particulate Laboratory Data				
m _n Net matter collected (g)	0.0029	<0.00020	<0.00020	
Filterable Particulate Results				
C _{sd} Particulate Concentration (mg/dscm)	1.6	<0.10	<0.10	<0.59
C _{sd7} Particulate Concentration @7% O ₂ (mg/dscm)	1.6	<0.11	<0.12	<0.63
Mercury Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	12.8947	13.9374	15.6810	
Mercury Results - Total				
C _{sd} Concentration (µg/dscm)	6.9	7.1	8.2	7.4
C _{sd7} Concentration @7% O ₂ (µg/dscm)	7.2	7.8	9.1	8.0
Beryllium Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total				
C _{sd} Concentration (mg/dscm)	<0.000027	<0.000026	<0.000026	<0.000026
C _{sd7} Concentration @7% O ₂ (mg/dscm)	<0.000028	<0.000028	<0.000029	<0.000028
Cadmium Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.6369	<0.2009	<0.2000	
Cadmium Results - Total				
C _{sd} Concentration (mg/dscm)	0.00034	<0.00010	<0.00010	<0.00018
C _{sd7} Concentration @7% O ₂ (mg/dscm)	0.00036	<0.00011	<0.00012	<0.00020
Lead Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.8752	0.9408	0.6833	
Lead Results - Total				
C _{sd} Concentration (mg/dscm)	0.00047	0.00048	0.00036	0.00043
C _{sd7} Concentration @7% O ₂ (mg/dscm)	0.00049	0.00053	0.00039	0.00047

RESULTS**Table 2-2:
Unit 1 FF Outlet - Fluorides**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	11:47	13:09	14:33	
Stop Time (approx.)	12:59	14:19	15:43	
Process Conditions				
R _P Steam Production Rate (Klbs/hr)	184.6	184.1	183.7	184.1
P ₁ Fabric Filter Inlet Temperature (°F)	319	320	320	320
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.5	8.6	8.6	8.6
CO ₂ Carbon dioxide (dry volume %)	11.4	11.5	11.2	11.3
T _s Sample temperature (°F)	304	305	306	305
B _w Actual water vapor in gas (% by volume)	21.3	21.4	21.0	21.2
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	179,476	174,385	189,647	181,169
Q _{std} Volumetric flow rate, dry standard (dscfm)	96,200	93,195	101,746	97,047
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	38.08	37.50	39.55	38.38
%I Isokinetic sampling (%)	100.5	102.2	98.7	100.5
Laboratory Data				
m _n Total HF collected (mg)	<0.02453	<0.02590	<0.02801	
Hydrogen Fluoride (HF) Results				
C _{sd} HF Concentration (ppmdv)	<0.027	<0.029	<0.030	<0.029
C _{sd7} HF Concentration @7% O ₂ (ppmdv)	<0.031	<0.033	<0.034	<0.033
C _{sd} HF Concentration (mg/dscm)	<0.023	<0.024	<0.025	<0.024
C _{sd7} HF Concentration @7% O ₂ (mg/dscm)	<0.025	<0.027	<0.028	<0.027
E _{lb/hr} HF Rate (lb/hr)	<0.0082	<0.0085	<0.0095	<0.0087
E _{Fd} HF Rate - Fd-based (lb/MMBtu)	<0.000023	<0.000025	<0.000025	<0.000024

RESULTS

2-3

**Table 2-3:
Unit 1 FF Outlet - PCDDs/PCDFs**

Run No.		1	2	3	4	Average
Date (2009)		Mar 10	Mar 11	Mar 11	Mar 12	
Start Time (approx.)		10:08	06:26	11:26	06:42	
Stop Time (approx.)		14:30	11:05	15:45	11:13	
Process Conditions						
R _p	Steam Production Rate (Klbs/hr)	184.0	184.5	183.6	183.9	184.0
P ₁	Fabric Filter Inlet Temperature (°F)	320	322	320	319	320
Gas Conditions						
O ₂	Oxygen (dry volume %)	8.6	8.9	9.3	8.7	8.9
CO ₂	Carbon dioxide (dry volume %)	11.3	11.0	10.6	11.2	11.0
T _s	Sample temperature (°F)	307	307	305	306	306
B _w	Actual water vapor in gas (% by volume)	21.6	20.7	21.0	20.1	20.9
Gas Flow Rate						
Q _a	Volumetric flow rate, actual (acfm)	172,759	178,893	175,038	176,461	175,788
Q _{std}	Volumetric flow rate, dry standard (dscfm)	92,098	96,002	93,905	95,725	94,433
Sampling Data						
V _{msid}	Volume metered, standard (dscf)	138.68	146.02	142.06	141.32	142.02
%I	Isokinetic sampling (%)	99.9	101.0	100.4	98.0	99.8
Results (ND and EMPC = 0)						
Laboratory Data from USEPA Method 23						
m _n	Total PCDDs & PCDFs (ng)	2.2000		2.4100	1.7600	
m _{n,TEQ}	Total TEQ PCDDs & PCDFs (ng)	0.0236		0.0237	0.0184	
Total PCDD/F Results (TEF=1)						
C _{sd}	PCDD/F Concentration (ng/dscm)	0.56		0.60	0.44	0.53
C _{sd7}	PCDD/F Concentration @7% O ₂ (ng/dscm)	0.63		0.72	0.50	0.62
E _{lb/hr}	PCDD/F Rate (lb/hr)	1.933E-07		2.108E-07	1.577E-07	1.873E-07
E _{Fd}	PCDD/F Rate - F _d -based (lb/MMBtu)	5.665E-10		6.467E-10	4.484E-10	5.538E-10
Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)						
C _{sdTEQ}	TEQ Concentration (ng/dscm)	0.0060		0.0059	0.0046	0.0055
C _{sd7TEQ}	TEQ Concentration @7% O ₂ (ng/dscm)	0.0068		0.0071	0.0052	0.0064
E _{lb/hrTEQ}	TEQ Rate (lb/hr)	2.074E-09		2.073E-09	1.649E-09	1.932E-09
E _{FdTEQ}	TEQ Rate - F _d -based (lb/MMBtu)	6.077E-12		6.359E-12	4.688E-12	5.708E-12
Results (ND and EMPC = actual value)						
Laboratory Data from USEPA Method 23, including NDs and EMPCs						
m _n	Total PCDDs & PCDFs (ng)	2.2600		2.5500	1.8900	
m _{n,TEQ}	Total TEQ PCDDs & PCDFs (ng)	0.0242		0.0272	0.0199	
Total PCDD/F Results (TEF=1)						
C _{sd}	PCDD/F Concentration (ng/dscm)	0.58		0.63	0.47	0.56
C _{sd7}	PCDD/F Concentration @7% O ₂ (ng/dscm)	0.65		0.76	0.54	0.65
E _{lb/hr}	PCDD/F Rate (lb/hr)	1.986E-07		2.230E-07	1.694E-07	1.970E-07
E _{Fd}	PCDD/F Rate - F _d -based (lb/MMBtu)	5.820E-10		6.842E-10	4.815E-10	5.826E-10
Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)						
C _{sdTEQ}	TEQ Concentration (ng/dscm)	0.0062		0.0068	0.0050	0.0060
C _{sd7TEQ}	TEQ Concentration @7% O ₂ (ng/dscm)	0.0069		0.0081	0.0056	0.0069
E _{lb/hrTEQ}	TEQ Rate (lb/hr)	2.126E-09		2.379E-09	1.783E-09	2.096E-09
E _{FdTEQ}	TEQ Rate - F _d -based (lb/MMBtu)	6.232E-12		7.298E-12	5.070E-12	6.200E-12

Run 2 XAD trap broke during recovery. Run 2 is not included in any averages.

RESULTS

**Table 2-4:
Unit 1 FF Outlet and SDA Inlet - Hydrogen Chloride**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:36	08:25	10:10	
Stop Time (approx.)	07:36	09:25	11:10	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	184.0	183.6	183.8	183.8
P ₁ Fabric Filter Inlet Temperature (°F)	320	317	320	319
SDA Inlet Gas Conditions				
O ₂ Oxygen (dry volume %)	7.8	8.1	8.2	8.0
CO ₂ Carbon dioxide (dry volume %)	11.7	11.4	11.6	11.6
T _s Sample temperature (°F)	496	499	498	498
B _w Actual water vapor in gas (% by volume)	16.9	16.5	16.6	16.7
SDA Inlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	32.25	33.48	34.50	33.41
SDA Inlet Laboratory Data				
m _n Total HCl collected (mg)	711.8015	610.9163	602.0750	
SDA Inlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	514	425	407	449
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	545	463	445	484
FF Outlet Gas Conditions				
O ₂ Oxygen (dry volume %)	8.9	9.1	8.9	9.0
CO ₂ Carbon dioxide (dry volume %)	10.7	10.5	11.0	10.7
T _s Sample temperature (°F)	307	304	306	306
B _w Actual water vapor in gas (% by volume)	20.9	20.9	20.6	20.8
FF Outlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	40.30	41.43	41.91	41.21
FF Outlet Laboratory Data				
m _n Total HCl collected (mg)	33.4232	21.9550	19.7170	
FF Outlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	19	12	11	14
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	22	15	13	17
RE Reduction Efficiency (% Removal)	96%	97%	97%	97%

RESULTS

2-5

**Table 2-5:
Unit 2 FF Outlet – Particulate, Metals and Mercury**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:29	08:58	11:39	
Stop Time (approx.)	08:40	11:20	13:49	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	184.6	183.7	184.3	184.2
P ₁ Fabric Filter Inlet Temperature (°F)	321	320	320	320
Gas Conditions				
O ₂ Oxygen (dry volume %)	9.0	10.0	8.3	9.1
CO ₂ Carbon dioxide (dry volume %)	10.6	9.7	11.7	10.7
T _s Sample temperature (°F)	311	311	311	311
B _w Actual water vapor in gas (% by volume)	21.6	21.9	21.9	21.8
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	175,746	170,351	171,635	172,577
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,746	89,558	90,177	90,827
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.57	67.68	68.02	69.09
%I Isokinetic sampling (%)	100.9	98.8	98.6	99.5
Laboratory Data				
m _n Net matter collected (g)	0.00099	0.00135	0.00075	
Filterable Particulate Results				
C _{sd} Particulate Concentration (mg/dscm)	0.49	0.70	0.39	0.53
C _{sd7} Particulate Concentration @7% O ₂ (mg/dscm)	0.57	0.90	0.43	0.63
Mercury Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	22.3002	16.7306	18.6602	
Mercury Results - Total				
C _{sd} Concentration (µg/dscm)	11	8.7	9.7	9.8
C _{sd7} Concentration @7% O ₂ (µg/dscm)	13	11	11	12
Beryllium Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total				
C _{sd} Concentration (mg/dscm)	<0.000025	<0.000026	<0.000026	<0.000026
C _{sd7} Concentration @7% O ₂ (mg/dscm)	<0.000029	<0.000033	<0.000029	<0.000030
Cadmium Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	<0.2000	0.2028	<0.2000	
Cadmium Results - Total				
C _{sd} Concentration (mg/dscm)	<0.000099	0.00011	<0.00010	<0.00010
C _{sd7} Concentration @7% O ₂ (mg/dscm)	<0.00012	0.00014	<0.00011	<0.00012
Lead Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.5592	0.8264	0.5117	
Lead Results - Total				
C _{sd} Concentration (mg/dscm)	0.00028	0.00043	0.00027	0.00032
C _{sd7} Concentration @7% O ₂ (mg/dscm)	0.00032	0.00055	0.00029	0.00039

RESULTS**Table 2-6:
Unit 2 FF Outlet - Fluorides**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	07:30	11:28	13:12	
Stop Time (approx.)	08:48	12:46	14:24	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	184.4	184.0	183.5	184.0
P ₁ Fabric Filter Inlet Temperature (°F)	330	320	320	323
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.4	9.2	9.1	8.9
CO ₂ Carbon dioxide (dry volume %)	10.8	10.7	10.8	10.8
T _s Sample temperature (°F)	318	312	314	314
B _w Actual water vapor in gas (% by volume)	22.7	22.0	22.5	22.4
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	188,918	183,861	193,864	188,881
Q _{std} Volumetric flow rate, dry standard (dscfm)	97,759	96,793	101,143	98,565
Sampling Data				
V _{metd} Volume metered, standard (dscf)	38.04	36.84	38.97	37.95
%I Isokinetic sampling (%)	98.8	96.6	97.8	97.8
Laboratory Data				
m _n Total HF collected (mg)	<0.02464	<0.02346	<0.02420	
Hydrogen Fluoride (HF) Results				
C _{sd} HF Concentration (ppmdv)	<0.028	<0.027	<0.026	<0.027
C _{sd7} HF Concentration @7% O ₂ (ppmdv)	<0.031	<0.032	<0.031	<0.031
C _{sd} HF Concentration (mg/dscm)	<0.023	<0.022	<0.022	<0.022
C _{sd7} HF Concentration @7% O ₂ (mg/dscm)	<0.025	<0.027	<0.026	<0.026
E _{lb/hr} HF Rate (lb/hr)	<0.0084	<0.0082	<0.0083	<0.0083
E _{Fd} HF Rate - Fd-based (lb/MMBtu)	<0.000023	<0.000024	<0.000023	<0.000023

RESULTS

2-7

**Table 2-7:
Unit 2 FF Outlet and SDA Inlet - Hydrogen Chloride**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:51	08:38	10:04	
Stop Time (approx.)	08:03	09:38	11:04	
Process Conditions				
R _P Steam Production Rate (Klbs/hr)	184.6	183.8	184.1	184.2
P ₁ Fabric Filter Inlet Temperature (°F)	319	322	320	320
SDA Inlet Gas Conditions				
O ₂ Oxygen (dry volume %)	7.2	9.2	8.4	8.2
CO ₂ Carbon dioxide (dry volume %)	12.1	10.5	11.3	11.3
T _s Sample temperature (°F)	503	508	508	507
B _w Actual water vapor in gas (% by volume)	19.5	17.3	17.9	18.2
SDA Inlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	34.56	33.65	32.35	33.52
SDA Inlet Laboratory Data				
m _n Total HCl collected (mg)	510.8082	510.6186	584.4054	
SDA Inlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	345	354	421	373
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	349	418	467	412
FF Outlet Gas Conditions				
O ₂ Oxygen (dry volume %)	8.8	9.6	9.0	9.1
CO ₂ Carbon dioxide (dry volume %)	10.7	10.1	10.7	10.5
T _s Sample temperature (°F)	312	313	313	312
B _w Actual water vapor in gas (% by volume)	23.1	21.4	22.0	22.2
FF Outlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	40.20	39.64	39.47	39.77
FF Outlet Laboratory Data				
m _n Total HCl collected (mg)	30.4028	20.3235	17.7085	
FF Outlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	17.6	12.0	10.5	13.3
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	20.2	14.6	12.2	15.7
RE Reduction Efficiency (% Removal)	94%	97%	97%	96%

RESULTS**Table 2-8:
Unit 3 FF Outlet – Particulate, Metals and Mercury**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	184.0	184.1	184.0	184.0
P ₁ Fabric Filter Inlet Temperature (°F)	321	320	320	320
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.8	9.0	8.8	8.8
CO ₂ Carbon dioxide (dry volume %)	10.6	10.9	11.1	10.8
T _s Sample temperature (°F)	308	308	310	309
B _w Actual water vapor in gas (% by volume)	20.0	20.0	20.6	20.2
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	170,082	175,333	170,440	171,952
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,068	94,920	91,224	92,737
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.64	74.94	71.27	72.62
%I Isokinetic sampling (%)	101.8	103.2	102.2	102.4
Particulate Laboratory Data				
m _n Net matter collected (g)	0.0037	0.0012	0.0011	
Filterable Particulate Results				
C _{sd} Particulate Concentration (mg/dscm)	1.8	0.56	0.55	1.0
C _{sd7} Particulate Concentration @7% O ₂ (mg/dscm)	2.1	0.66	0.63	1.1
Mercury Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	11.5809	8.1043	6.8887	
Mercury Results - Total				
C _{sd} Concentration (µg/dscm)	5.7	3.8	3.4	4.3
C _{sd7} Concentration @7% O ₂ (µg/dscm)	6.5	4.5	3.9	5.0
Beryllium Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total				
C _{sd} Concentration (mg/dscm)	<0.000025	<0.000024	<0.000025	<0.000024
C _{sd7} Concentration @7% O ₂ (mg/dscm)	<0.000028	<0.000027	<0.000028	<0.000028
Cadmium Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.2826	<0.2000	0.2161	
Cadmium Results - Total				
C _{sd} Concentration (mg/dscm)	0.00014	<0.000094	0.00011	<0.00011
C _{sd7} Concentration @7% O ₂ (mg/dscm)	0.00016	<0.00011	0.00012	<0.00013
Lead Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	1.4108	0.4894	0.4760	
Lead Results - Total				
C _{sd} Concentration (mg/dscm)	0.00070	0.00023	0.00024	0.00039
C _{sd7} Concentration @7% O ₂ (mg/dscm)	0.00080	0.00027	0.00027	0.00045

RESULTS

2-9

**Table 2-9:
Unit 3 FF Outlet - Fluorides**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	08:17	11:31	13:16	
Stop Time (approx.)	10:32	12:49	14:30	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	184.8	184.6	183.9	184.4
P ₁ Fabric Filter Inlet Temperature (°F)	320	320	320	320
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.9	8.8	8.9	8.8
CO ₂ Carbon dioxide (dry volume %)	10.7	11.0	10.9	10.9
T _s Sample temperature (°F)	310	309	313	311
B _w Actual water vapor in gas (% by volume)	23.0	22.8	21.1	22.3
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	183,084	172,115	164,821	173,340
Q _{std} Volumetric flow rate, dry standard (dscfm)	95,013	90,201	87,724	90,980
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	38.01	35.74	33.65	35.80
%I Isokinetic sampling (%)	101.6	100.6	97.4	99.9
Laboratory Data				
m _n Total HF collected (mg)	<0.02798	<0.02675	<0.02341	
Hydrogen Fluoride (HF) Results				
C _{sd} HF Concentration (ppmdv)	<0.031	<0.032	<0.030	<0.031
C _{sd7} HF Concentration @7% O ₂ (ppmdv)	<0.036	<0.036	<0.034	<0.036
C _{sd} HF Concentration (mg/dscm)	<0.026	<0.026	<0.025	<0.026
C _{sd7} HF Concentration @7% O ₂ (mg/dscm)	<0.030	<0.030	<0.029	<0.030
E _{lb/hr} HF Rate (lb/hr)	<0.0093	<0.0089	<0.0081	<0.0088
E _{Fd} HF Rate - Fd-based (lb/MMBtu)	<0.000027	<0.000027	<0.000026	<0.000027

RESULTS

**Table 2-10:
Unit 3 FF Outlet and SDA Inlet - Hydrogen Chloride**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:57	08:29	10:02	
Stop Time (approx.)	07:57	09:29	11:02	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	184	183	184	184
P ₁ Fabric Filter Inlet Temperature (°F)	321	321	320	321
SDA Inlet Gas Conditions				
O ₂ Oxygen (dry volume %)	8.2	8.2	8.2	8.2
CO ₂ Carbon dioxide (dry volume %)	11.1	11.3	11.6	11.3
T _s Sample temperature (°F)	487	495	496	493
B _w Actual water vapor in gas (% by volume)	16.3	16.4	15.8	16.2
SDA Inlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	32.51	32.23	33.40	32.71
SDA Inlet Laboratory Data				
m _n Total HCl collected (mg)	698.7197	595.7498	572.4612	
SDA Inlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	501	431	400	444
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	549	472	438	486
FF Outlet Gas Conditions				
O ₂ Oxygen (dry volume %)	9.2	9.2	9.0	9.1
CO ₂ Carbon dioxide (dry volume %)	10.0	10.3	10.8	10.4
T _s Sample temperature (°F)	309	311	309	310
B _w Actual water vapor in gas (% by volume)	19.9	20.7	20.1	20.2
FF Outlet Sampling Data				
V _{mstd} Volume metered, standard (dscf)	39.84	40.04	39.66	39.85
FF Outlet Laboratory Data				
m _n Total HCl collected (mg)	7.9377	13.6807	13.2000	
FF Outlet Hydrogen Chloride (HCl) Results				
C _{sd} HCl Concentration (ppmdv)	4.6	8.0	7.8	6.8
C _{sd7} HCl Concentration @7% O ₂ (ppmdv)	5.5	9.4	9.1	8.0
RE Reduction Efficiency (% Removal)	99%	98%	98%	98%

RESULTS

2-11

**Table 2-11:
Units 1, 2 and 3 FF Outlets – Opacity by COMS**

Run No.	1	2	3	Average
Unit 1				
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:48	09:25	11:59	
Stop Time (approx.)	09:03	11:37	14:13	
Visible Emissions (%)¹				
Average Opacity	0	0	0	0
Maximum Reading	0	0	0	0
Minimum Reading	0	0	0	0
Unit 2				
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:29	08:58	11:39	
Stop Time (approx.)	08:40	11:20	13:49	
Visible Emissions (%)¹				
Average Opacity	0	0	0	0
Maximum Reading	0	0	0	0
Minimum Reading	0	0	0	0
Unit 3				
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	
Visible Emissions (%)¹				
Average Opacity	0	0	0	0
Maximum Reading	0	0	0	0
Minimum Reading	0	0	0	0

¹ Reading obtained from facility's continuous opacity monitoring system (COMS) as provided under 40 CFR 60.11(e) and Title V Conditions A.36(6), A.53 and A.54 and coincide with Method 5/29 test run

RESULTS

**Table 2-12:
Ash Handling System - Fugitive Emissions**

<u>Source</u> Constituent	<u>Date</u> (2009)	<u>Start Time</u> (approx.)	<u>Stop Time</u> (approx.)	<u>Observation</u> Duration (minutes)	<u>Accumulated</u> Emission Duration (seconds)	
<u>Ash Conveyor/Doors to Baghouse</u>						
Visual Opacity (%)	March 12	12:48	13:58	60	0	
<u>Ash Unloading/Conveyor</u>						
Visual Opacity (%)	March 12	14:03	15:13	60	0	
<u>Rolling Door/Door to Baghouse</u>						
Visual Opacity (%)	March 12	15:18	16:28	60	0	<u>Permit Limit</u>
				Total (% of observation time) = 0	< 5% of observation Time	
				Total (minutes) = 0	< 9 minutes	

**Table 2-13:
Lime Silo Fabric Filter Outlet - Visible Emissions**

Run No.	1
Date (2009)	Mar 12
Start Time (approx.)	08:16
Stop Time (approx.)	10:12
<u>Process Conditions</u>	
Total lime unloaded (tons)	25.81
Rate of unloading (tons/hr)	13.5
<u>Visible Emissions</u>	
Average (percent opacity)	0
Maximum reading (percent opacity)	0

RESULTS

**Table 2-14:
Air Flow Summary**

Run Number	Run Date	Run Time	Steam Flow Klbs/hour	Flue Gas Temp Deg F	Air Flow ACFM	O ₂ %	CO ₂ %	Air Flow, DSCFM	Air Flow, DSCFM@ 7%O ₂
1-O-M5/29-1	3/10/2009	06:48-09:03	185.4	307	164,030	7.6	11.7	86,185	82,526
1-O-M5/29-2	3/10/2009	09:25-11:37	183.9	307	172,929	8.3	11.4	91,330	82,789
1-O-M5/29-3	3/10/2009	11:59-14:13	183.7	307	171,587	8.4	11.3	91,825	82,576
1-O-M13B-1	3/12/2009	11:47-12:59	184.6	304	179,476	8.5	11.4	96,200	85,888
1-O-M13B-2	3/12/2009	13:09-14:19	184.1	305	174,385	8.6	11.5	93,195	82,669
1-O-M13B-3	3/12/2009	14:33-15:43	183.7	306	189,647	8.6	11.2	101,746	89,961
1-O-M23-1	3/10/2009	10:08-14:30	184.0	307	172,759	8.6	11.3	92,098	81,828
1-O-M23-2	3/11/2009	06:26-11:05	184.5	307	178,893	8.9	11.0	96,002	83,017
1-O-M23-3	3/11/2009	11:26-15:45	183.6	305	175,038	9.3	10.6	93,905	78,164
1-O-M23-4	3/12/2009	06:42-11:13	183.9	306	176,461	8.7	11.2	95,725	84,362
		Average	184.1	306	175,520	8.5	11.2	93,821	83,378
2-O-M5/29-1	3/12/2009	06:29-0840	184.6	311	175,746	9.0	10.6	92,746	79,468
2-O-M5/29-2	3/12/2009	0858-11:20	183.7	311	170,351	10.0	9.7	89,558	70,164
2-O-M5/29-3	3/12/2009	11:39-13:49	184.3	311	171,635	8.3	11.7	90,177	82,003
2-O-M13B-1	3/11/2009	07:30-08:48	184.4	318	188,918	8.4	10.8	97,759	87,983
2-O-M13B-2	3/11/2009	11:28-12:46	184.0	312	183,861	9.2	10.7	96,793	81,473
2-O-M13B-3	3/11/2009	13:12-14:24	183.5	314	193,864	9.1	10.8	101,143	86,227
		Average	184.1	313	180,729	9.0	10.7	94,696	81,220
3-O-M5/29-1	3/11/2009	06:46-08:58	184.0	308	170,082	8.8	10.6	92,068	80,410
3-O-M5/29-2	3/11/2009	09:24-11:38	184.1	308	175,333	9.0	10.9	94,920	81,331
3-O-M5/29-3	3/11/2009	11:58-14:10	184.0	310	170,440	8.8	11.1	91,224	79,739
3-O-M13B-1	3/10/2009	08:17-09:32	184.8	310	183,084	8.9	10.7	95,013	82,368
3-O-M13B-2	3/10/2009	11:31-12:49	184.6	309	172,115	8.8	11.0	90,201	78,845
3-O-M13B-3	3/10/2009	13:16-14:30	183.9	313	164,821	8.9	10.9	87,724	75,480
		Average	184.2	310	172,646	8.8	10.9	91,859	79,696
Facility Average			184.2	309	176,298	8.8	10.9	93,459	81,431

RESULTS

**Table 2-15:
Quality Control and Quality Assurance
PCDD/PCDF - Extraction Standard Percent Recoveries**

Sample Number	Extraction Standard Percent Recoveries, %						
	¹³ C-TCDD	¹³ C-PeCDD	¹³ C-HxCDD	¹³ C-HxCDD	¹³ C-HxCDD	¹³ C-HpCDD	¹³ C-OCDD
0_6673_MB001	83.1	77.2	94.6	86.1	92.1	82.7	74.4
Field Blank	89.7	85.1	86.4	84.1	87.7	83.5	72.4
Run 1-Unit 1 FF Outlet	89.1	84.4	84.2	81.8	85.3	82.1	73.5
Run 3-Unit 1 FF Outlet	88.2	83.5	87.9	82.1	90	84	72.4
Run 4-Unit 1 FF Outlet	87.3	82.3	87.1	83.9	86.3	79.5	66.8
Average	87	83	88	84	88	82	72
SD	3	3	4	2	3	2	3
Min	83.1	77.2	84.2	81.8	85.3	79.5	66.8
Max	89.7	85.1	94.6	86.1	92.1	84	74.4
Within M23 QC	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE

Sample Number	Extraction Standard Percent Recoveries, %									
	¹³ C-TCDF	¹³ C-PeCDF	¹³ C-PeCDF	¹³ C-HxCDF	¹³ C-HxCDF	¹³ C-HxCDF	¹³ C-HxCDF	¹³ C-HpCDF	¹³ C-HpCDF	¹³ C-OCDF
0_6673_MB001	87.9	81.6	78.2	93.1	93.6	90.9	77.7	86.2	84.1	75.4
Field Blank	92.5	83.5	86.6	86.8	85.4	86.4	76	83.6	82.2	73.9
Run 1-Unit 1 FF Outlet	87.9	83.2	80.8	85.9	82.8	84.3	74.6	79.8	80.6	74.4
Run 3-Unit 1 FF Outlet	89.2	83.4	82.4	87.8	83.3	87.3	76.3	82.4	83.6	75.2
Run 4-Unit 1 FF Outlet	87.2	81.4	81.6	91.7	90.6	92.2	76.8	81.8	80.6	68.7
Average	89	83	82	89	87	88	76	83	82	74
SD	2	1	3	3	5	3	1	2	2	3
Min	87.2	81.4	78.2	85.9	82.8	84.3	74.6	79.8	80.6	68.7
Max	92.5	83.5	86.6	93.1	93.6	92.2	77.7	86.2	84.1	75.4
Within M23 QC	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE

**Table 2-16:
Quality Control and Quality Assurance
PCDD/PCDF – CS/SS Percent Recoveries**

Sample Number	CS/SS Percent Recoveries, %				
	³⁷ Cl-TCDD	¹³ C-PeCDD	¹³ C-PeCDF	¹³ C-HxCDF	¹³ C-HpCDF
0_6673_MB001	97.6	106	96.2	93.5	95.9
Field Blank	96.3	95.4	95.6	98.2	96.6
Run 1-Unit 1 FF Outlet	95.8	94.4	91	96.7	96.5
Run 3-Unit 1 FF Outlet	95.6	95.7	89.4	98.7	95.9
Run 4-Unit 1 FF Outlet	99.5	96.8	94.2	97.7	98
Average	97	98	93	97	97
SD	2	5	3	2	1
Min	95.6	94.4	89.4	93.5	95.9
Max	99.5	106	96.2	98.7	98
Min within M23 QC	TRUE	TRUE	TRUE	TRUE	TRUE

RESULTS

2-15

**Table 2-17:
Quality Control and Quality Assurance - Metals**

Run Number	RPD RESULTS				
	FH Front Half	BH H ₂ O ₂ /HNO ₄	A Empty Impinger	B KMnO ₄	C HCl
U1 FF Outlet R1	NA	0.1%	5.9%	NA	NA
U1 FF Outlet R2	NA	0.2%	NA	NA	NA
U1 FF Outlet R3	NA	0.4%	NA	NA	NA
U2 FF Outlet R1	NA	0.2%	0.7%	NA	NA
U2 FF Outlet R2	NA	0.2%	NA	NA	NA
U2 FF Outlet R3	NA	0.4%	0.6%	NA	NA
U3 FF Outlet R1	NA	1.1%	NA	NA	NA
U3 FF Outlet R2	NA	0.0%	NA	NA	NA
U3 FF Outlet R3	NA	0.7%	NA	NA	NA
Field Blank	NA	NA	NA	NA	NA
Reagent Blank	NA	NA	NA	NA	NA

Element	Duplicate Analysis RPD		
	U1 FF O R2 RPD	U2 FF O R2 RPD	U3 FF O R2 RPD
	12198-2	12198-5	12198-8
Beryllium	NA	NA	NA
Cadmium	NA	2.2%	NA
Lead	2.1%	2.3%	3.7%

RESULTS

Table 2-18:
Quality Control and Quality Assurance - Metals (Continued)
Sample Spike and Recovery

Run Number		FH Front Half	BH H ₂ O ₂ /HNO ₄	A Empty Impinger	B KMnO ₄	C HCl
U1 FF Outlet R3	#1	102%	100%	101%	103%	94%
	#2	105%	100%	100%	102%	94%
U2 FF Outlet R3	#1	101%	90%	101%	103%	91%
	#2	103%	89%	102%	104%	92%
U3 FF Outlet R3	#1	98%	94%	102%	93%	93%
	#2	100%	97%	100%	93%	94%

Element	U1 FF O R3 Recovery	U2 FF O R3 Recovery	U3 FF O R3 Recovery
	12198-3	12198-6	12198-9
Beryllium	95%	90%	97%
Cadmium	106%	105%	108%
Lead	114%	116%	113%

Second Source Calibration Verification					
Element	.25 ppb	1 ppb	50 ppb	100 ppb	250 ppb
	QC Std 8	QC Std 2	QC Std 5	QC Std 4	QC Std 3
Beryllium	119%	107%	106%	95%	101%
Cadmium		108%	101%	94%	99%
Lead		115%	116%	99%	98%

RESULTS

2-17

**Table 2-19:
Quality Control and Quality Assurance - Method and Field Blanks**

Method 29		Average Total Catch ug	FH Front Half	BH H ₂ O ₂ /HNO ₄	A Empty Impinger	B KMnO ₄	C HCl
Field Blank	#1	< 0.5	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
Reagent Blank	#1	< 0.5	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.2	< 0.2	< 0.5	< 0.4

Element	Field Blank Total µg	Reagent Blank Total µg
	12198-10	12198-11
Beryllium	< 0.05	< 0.05
Cadmium	< 0.2	< 0.2
Lead	0.900	0.364

Method 23	0_6673_MB001	Field Blank
	pg	pg
Totals		
TCDDs	0	3.34
PeCDDs	0	0
HxCDDs	0	8.23
HpCDDs	0	5.05
OCDD	0	10.5
TCDFs	0	0.955
PeCDFs	0	0
HxCDFs	0	4.23
HpCDFs	0	2.17
OCDF	0	1.12
Total PCDD/Fs (ND=0; EMPC=0)	0.00	35.6
Total PCDD/Fs (ND=0; EMPC=EMPC)	0.00	51.4
Total PCDD/Fs (2378-X ND=DL; EMPC=EMPC)	38.2	64.6
Total 2378s (ND=0; EMPC=0)	0.00	10.5
Total 2378s (ND=0.5; EMPC=0)	19.1	34.6
Total 2378s (ND=1; EMPC=0)	38.2	58.7
Total 2378s (ND=0; EMPC=1)	0.00	10.5
Total 2378s (ND=0.5; EMPC=1)	19.1	34.6
Total 2378s (ND=1; EMPC=1)	38.2	58.7

RESULTS

2-18

**Table 2-20:
Quality Control and Quality Assurance - Miscellaneous**

Blanks	Result	
Acetone (g)	<0.0001	
HCl DI H ₂ O (mg/l)	<0.008	
HCl 0.1 N H ₂ SO ₄ (mg/l)	<0.008	
HF DI H ₂ O (mg/l)	<0.026	
Meters - Post Cal	Result	Limit
61-6	-0.9%	≤ ± 5%
61-7	3.6%	≤ ± 5%
61-8	-3.4%	≤ ± 5%
66-6	-1.7%	≤ ± 5%
66-7	2.3%	≤ ± 5%
66-11	-0.9%	≤ ± 5%
66-22	-1.1%	≤ ± 5%

End of Section 2 – Results

DESCRIPTION OF INSTALLATION

3-1

PROCESS DESCRIPTION

The North Broward Resource Recovery facility operates three (3) 750-tons-per-day municipal refuse-fired, water-wall boiler trains. The trains were manufactured by Babcock and Wilcox to produce electricity for sale to a local utility company. The boilers are rated at a maximum steam flow of 186,000 lbs/hr. Each boiler is equipped with an SDA for acid gas removal, followed by an FF baghouse for the control of particulate emissions and selective non-catalytic reduction for NO_x control. The control equipment is manufactured by Wheelabrator Air Pollution Control, Inc. Each FF baghouse is followed by an induced draft fan that directs the flue gas to a dedicated flue in a common stack.

Figure 3-1 shows a general schematic of the facility. The general sampling locations for the Units 1, 2 and 3 SDA Inlets and FF Outlets are shown in Figure 3-2 on page 3-2.




Figure 3-1: General Process Schematic

DESCRIPTION OF INSTALLATION

3-2




Figure 3-2: Process Schematic

DESCRIPTION OF INSTALLATION

**Table 3-1:
Unit 1 Compliance Test Process Data**

PLANT NAME: NORTH BROWARD 2009				Data from DCS Printouts								Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCI	1	1	3/12/2009	0636	0736	184.0	319.9	6.3	522.9	38.7	31.9	6.8	15.8	1.098	1.028	420.7	All times based on CEMS time Bailey time = CEMS time
		2	3/12/2009	0825	0925	183.6	317.0	6.2	525.7	39.8	33.0	6.8	23.2	1.098	1.028	422.0	
		3	3/12/2009	1010	1110	183.8	320.1	6.3	527.3	40.1	31.4	8.7	25.0	1.098	1.028	538.0	
		Avg				183.8	319.0	6.3	525.3	39.5	32.1	7.5	21.3	1.098	1.028	460.2	
M-29/5 Metals PM	1	1	3/10/2009	0648	0903	185.4	319.6	6.3	521.2	36.5	29.3	7.2	16.3	1.102	1.070	461.6	All times based on CEMS time Bailey time = CEMS time
		2	3/10/2009	0925	1137	183.9	320.1	6.3	527.7	38.7	31.7	7.0	15.5	1.102	1.070	448.8	
		3	3/10/2009	1159	1413	183.7	320.1	6.2	531.4	39.4	32.0	7.4	15.4	1.101	1.060	470.6	
		Avg				184.3	319.9	6.3	526.8	38.2	31.0	7.2	15.7	1.102	1.067	460.3	
M-23 dioxins	1	1	3/10/2009	1008	1430	184.0	319.9	6.2	530.3	39.0	31.8	7.3	15.5	1.101	1.060	461.7	All times based on CEMS time Bailey time = CEMS time Run 2 excluded due to broken XAD-trap during sample recovery
		2	3/11/2009	0626	1105	184.5	321.7	6.3	521.9	38.5	29.6	8.9	16.1	1.098	1.028	547.8	
		3	3/11/2009	1126	1545	183.6	320.1	6.3	528.9	40.5	32.6	7.9	15.4	1.097	1.017	481.6	
		4	3/12/2009	0642	1113	183.9	319.0	6.3	525.3	39.4	32.2	7.2	20.9	1.098	1.028	442.3	
Avg				184.0	320.2	6.3	526.6	39.4	31.6	7.8	16.9	1.099	1.033	483.4			
M-13B HF	1	1	3/12/2009	1147	1259	184.6	319.4	6.2	522.6	37.2	31.2	6.0	15.7	1.099	1.039	374.7	All times based on CEMS time Bailey time = CEMS time
		2	3/12/2009	1309	1419	184.1	320.4	6.4	523.4	37.2	30.5	6.7	15.8	1.099	1.039	418.3	
		3	3/12/2009	1433	1543	183.7	320.4	6.3	530.0	39.6	32.8	6.8	15.0	1.097	1.017	418.1	
		Avg				184.1	320.1	6.3	525.3	38.0	31.5	6.5	15.5	1.098	1.032	403.7	

DESCRIPTION OF INSTALLATION

3-4

CleanAir

**Table 3-2:
Unit 2 Compliance Test Process Data**

PLANT NAME: NORTH BROWARD 2009						Data From DCS Printouts						Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCI	2	1	3/10/2009	0651	0803	184.6	319.4	6.4	498.8	35.6	32.4	3.2	16.9	1.102	1.070	202.2	All times based on CEMS time
		2	3/10/2009	0838	0938	183.8	321.5	6.5	511.2	40.0	34.4	5.6	16.3	1.102	1.070	361.4	Bailey time = CEMS time
		3	3/10/2009	1004	1104	184.1	319.6	6.4	511.4	38.9	34.3	4.7	18.5	1.102	1.070	299.8	
					Avg		184.2	320.1	6.4	507.2	38.2	33.7	4.5	17.2	1.102	1.070	287.8
M-29/5 Metals PM	2	1	3/12/2009	0629	0840	184.6	320.0	6.5	501.8	36.6	32.2	4.4	20.1	1.098	1.028	269.6	All times based on CEMS time
		2	3/12/2009	0858	1120	183.7	319.8	6.5	503.3	35.7	31.6	4.1	18.0	1.098	1.028	252.3	Bailey time = CEMS time
		3	3/12/2009	1139	1349	184.3	320.1	6.5	508.5	36.8	32.9	3.9	17.0	1.099	1.039	241.9	
					Avg		184.2	320.0	6.5	504.5	36.4	32.3	4.1	18.4	1.098	1.032	254.6
M-13B HF	2	1	3/11/2009	0730	0848	184.4	329.8	6.5	500.0	34.6	24.9	9.8	24.7	1.098	1.028	602.1	All times based on CEMS time
		2	3/11/2009	1128	1246	184.0	319.8	6.4	512.4	38.8	32.8	6.0	19.0	1.097	1.017	366.8	Bailey time = CEMS time
		3	3/11/2009	1312	1424	183.5	320.2	6.6	516.9	40.6	32.9	7.7	18.4	1.097	1.017	468.8	
					Avg		184.0	323.3	6.5	509.8	38.0	30.2	7.8	20.7	1.097	1.021	479.2

DESCRIPTION OF INSTALLATION

3-5

CleanAir

**Table 3-3:
Unit 3 Compliance Test Process Data**

PLANT NAME: NORTH BROWARD 2009					Data From DCS Printouts							Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCl	3	1	3/11/2009	0657	0757	184.2	321.4	6.3	510.0	33.0	23.1	10.0	20.1	1.098	1.028	614.5	All times based on CEMS time
		2	3/11/2009	0829	0929	182.9	320.6	6.0	518.1	36.1	30.1	6.0	15.6	1.098	1.028	371.4	Bailey time = CEMS time
		3	3/11/2009	1002	1102	183.9	319.7	5.7	520.3	36.7	32.1	4.6	15.6	1.098	1.028	284.4	
		Avg				183.7	320.6	6.0	516.1	35.3	28.4	6.9	17.1	1.098	1.028	423.4	
M-29/5 Metals PM	3	1	3/11/2009	0646	0858	184.0	320.9	6.2	511.5	33.9	25.6	8.3	18.6	1.098	1.028	510.8	All times based on CEMS time
		2	3/11/2009	0924	1138	184.1	319.8	6.0	520.4	36.6	31.9	4.7	15.9	1.098	1.028	288.7	Bailey time = CEMS time
		3	3/11/2009	1158	1410	184.0	320.2	6.1	515.1	34.4	28.6	5.8	18.1	1.097	1.017	354.0	
		Avg				184.0	320.3	6.1	515.7	34.9	28.7	6.3	17.5	1.098	1.025	384.5	
M-13B HF	3	1	3/10/2009	0817	0932	184.8	319.9	6.0	524.1	37.2	31.6	5.6	16.5	1.102	1.070	361.4	All times based on CEMS time
		2	3/10/2009	1131	1249	184.6	319.8	6.0	518.6	34.5	28.6	5.9	17.4	1.101	1.060	377.8	Bailey time = CEMS time
		3	3/10/2009	1316	1430	183.9	320.1	6.1	518.2	34.0	26.5	7.5	17.5	1.101	1.060	477.0	
		Avg				184.4	319.9	6.0	520.3	35.2	28.9	6.4	17.1	1.101	1.063	405.4	

DESCRIPTION OF INSTALLATION

DESCRIPTION OF SAMPLING LOCATIONS

Sampling point locations were determined according to EPA Method 1.

Table 3-4 outlines the sampling point configurations. Figures 3-3 and 3-4 on pages 3-7 and 3-8 illustrate the sampling points and orientation of sampling ports for each of the sources that were tested in the program.

**Table 3-4:
Sampling Points**

Location	Constituent	Method	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
<u>Units 1,2 and 3 SDA Inlets</u>								
	Hydrogen Chloride	26A ¹	1-3	1	1	60	60	3-3
<u>Units 1,2 and 3 FF Outlets</u>								
	Particulate, Be, Cd, Pb and Hg	5/29 ²	1-3	5	5	5	125	3-4
	Hydrogen Chloride	26A ¹	1-3	1	1	60	60	NA
	Fluorides	13B	1-3	5	5	2.5	62.5	3-4
	PCDDs/PCDFs (Unit 3 only)	23	1-3	5	5	10	250	3-4

¹ Hydrogen chloride inlet testing utilized a modification of EPA Method 26A (single point constant sampling rate).

² Metals testing was done in conjunction with EPA Method 5 particulate sampling.

DESCRIPTION OF INSTALLATION
DESCRIPTION OF SAMPLING LOCATIONS (CONTINUED)

3-7





Figure 3-3: SDA Inlets - Sampling Point Determination (HCl Sampling)
(Units 1, 2 and 3 are identical)

DESCRIPTION OF INSTALLATION
DESCRIPTION OF SAMPLING LOCATIONS (CONTINUED)



<u>Sampling Point</u>	<u>Port to Point Distance (in.)</u>
1	86.4
2	67.2
3	48.0
4	28.8
5	9.6

Equivalent diameters to upstream disturbance: 2.0 Limit: 2.0
Equivalent diameters to downstream disturbance: 0.5 Limit: 0.5

Figure 3-4: FF Outlets - Sampling Point Determination
(Units 1, 2 and 3 are identical)

End of Section 3 – Description of Installation

METHODOLOGY

Clean Air Engineering followed procedures as detailed in EPA Methods 1, 2, 3, 3A, 3B, 4, 5, 9, 13B, 22, 23, mod. 26A and 29. The following table summarizes the methods and their respective sources.

**Table 4-1:
Summary of Sampling Procedures**

Title 40 CFR Part 60 Appendix A

Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
Method 3	"Gas Analysis for the Determination of Dry Molecular Weight"
Method 3A	"Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)"
Method 3B	"Gas Analysis for the Determination of Emission Rate Correction Factor or Excess Air"
Method 5	"Determination of Particulate Matter Emissions from Stationary Sources"
Method 9	"Visual Determination of the Opacity of Emissions from Stationary Sources"
Method 13B	"Determination of Total Fluoride Emissions from Stationary Sources (Specific Ion Electrode Method)"
Method 23	"Determination of Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans from Municipal Waste Conductors"
Method 22	"Visual Determination of Fugitive Emissions from Material Sources and Smoke Emissions from Flares"
Mod.Method 26A ¹	"Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources Isokinetic Method"
Method 29	"Determination of Metals Emissions from Stationary Sources"

¹ Method 26A was modified at the inlet using single point constant sampling rate and at the outlet it was done in conjunction with Method 5.

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and on the World Wide Web at <http://www.cleanair.com>.

Diagrams of the sampling apparatus and major specifications of the sampling, recovery and analytical procedures are summarized for each method in Appendix A.

CleanAir followed specific quality assurance and quality control (QA/QC) procedures as outlined in the individual methods and in EPA "Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III Stationary Source-Specific Methods", EPA/600/R-94/038C. Additional QA/QC methods, as prescribed in CleanAir's internal Quality Manual, were also followed. Results of all QA/QC activities performed by CleanAir are summarized in Appendix E.

End of Section 4 – Methodology

APPENDIX

5-1

TEST METHOD SPECIFICATIONS	A
SAMPLE CALCULATIONS	B
PLANT DATA	C
PARAMETERS	D
QA/QC DATA	E
FIELD DATA	F
FIELD DATA PRINTOUTS	G
LABORATORY DATA	H
PERTINENT CERTIFICATIONS	I
CORRESPONDENCE AND CLARIFICATIONS	J

TEST METHOD SPECIFICATIONS

A

This Page Intentionally Left Blank

Specification Sheet for

EPA Method 5/29

Source Location Name(s) Units 1, 2 and 3 FF Outlets
 Pollutant(s) to be Determined Particulate Matter (PM) and Trace Metals (including Mercury)
 Other Parameters to be Determined from Train Gas Density, Moisture, Flow Rate


	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
Pollutant Sampling Information		
Duration of Run	N/A	125 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	5 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
Sampling Probe		
Nozzle Material	Borosilicate or Quartz Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
Velocity Measuring Equipment		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.812
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
Metering System Console		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
Filter Description		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Teflon (or other non-metallic material)	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Quartz or Fiberglass Fiber	Quartz Fiber
Other Components		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

Specification Sheet for

EPA Method 5/29

	Standard Method Specification	Actual Specification Used
Impinger Train Description		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	7	7
Impinger Stem Types		
Impinger 1	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 2	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 3	Greenburg-Smith	Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 6	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 7	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 8	Modified Greenburg-Smith	Modified Greenburg-Smith
Gas Density Determination		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	CEM
Sample Recovery Information		
Probe Brush Material	Non-metallic swab or bristle	Teflon Mat
Probe Rinse Reagent	Acetone/0.1N Nitric Acid	Acetone/0.1N. Nitric Acid
Probe Rinse Wash Bottle Material	Glass or Teflon	Teflon
Probe Rinse Storage Container	See Method 29 Recovery Flow Chart	See Recovery Flow Chart
Filter Recovered?	Yes	Yes
Filter Storage Container	Petri Dish - Glass or Polystyrene	Glass
Impinger Contents Recovered?	Yes	Yes
Impinger Rinse Reagent	See Method 29 Recovery Flow Chart	See Recovery Flow Chart
Impinger Wash Bottle	Glass or Teflon	Teflon
Impinger Storage Container	See Recovery Flow Chart	See Recovery Flow Chart
Analytical Information		
Method 4 H ₂ O Determination by	Volumetric or Gravimetric	Gravimetric and Volumetric
Filter Preparation Conditions	See Method 29 Analytical Flow Chart	For Metals Analysis
Front-Half Rinse Preparation	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Back-Half Analysis	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Additional Analysis	Gravimetric (EPA Method 5)	Gravimetric (EPA Method 5)


EPA Method 5/29 Sampling Train Configuration



Impinger Contents


Impinger 1	Empty
Impinger 2	100 ml 5% HNO ₃ / 10% H ₂ O ₂
Impinger 3	100 ml 5% HNO ₃ / 10% H ₂ O ₂
Impinger 4	Empty
Impinger 5	100 ml 4% KMnO ₄ / 10% H ₂ SO ₄
Impinger 6	100 ml 4% KMnO ₄ / 10% H ₂ SO ₄
Impinger 7	Silica Gel

EPA Method 29 Glassware Preparation Procedures




EPA Method 29
Sample Recovery Flowchart
 (includes Mercury and Particulate Matter)

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)
- Collect one complete blank set per field test



EPA Method 29
Analytical Flowchart
 (includes Mercury and Particulate Matter)



Specification Sheet for EPA Method 13B

Source Location Name(s) Units 1 ,2 and 3 FF Outlets
 Pollutant(s) to be Determined Total Fluoride (F)
 Other Parameters to be Determined from Trai Gas Density, Moisture, Flow Rate


	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
Pollutant Sampling Information		
Duration of Run	N/A	62.5 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	2.5 minutes
Sampling Rate	Isokinetic (90-110%) 1 cfm maximum	Isokinetic (90-110%) 1 cfm maximum
Sampling Probe		
Nozzle Material	Stainless Steel or Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Stainless Steel or Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F (optional)	248°F±25°F
Velocity Measuring Equipment		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.825
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
Metering System Console		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
Filter Description		
Filter Location	Exit of Probe or Between 3rd and 4th impingers	Exit of Probe
Filter Holder Material	Borosilicate Glass or Stainless Steel	Borosilicate Glass
Filter Support Material	Stainless Steel if filter at probe exit; Glass Frit if filter after 3rd impinger	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F if after probe, unheated if after 3rd imp.	248°F±25°F
Filter Material	Low F Quartz or Fiberglass if after probe, Whatman No. 1 if after 3rd impinger	Whatman No. 1 (Ashless)
Other Components		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

Specification Sheet for

EPA Method 13B

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
Impinger Train Description		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	4	4
Impinger Stem Types		
Impinger 1	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 2	Greenburg-Smith	Greenburg-Smith
Impinger 3	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5		
Impinger 6		
Impinger 7		
Impinger 8		
Gas Density Determination		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	CEM
Sample Recovery Information		
Probe Brush Material	Nylon Bristle	Nylon Bristle
Probe Rinse Reagent	Deionized distilled water	Deionized Distilled Water
Probe Rinse Wash Bottle Material	Glass or Polyethylene	Teflon
Probe Rinse Storage Container	Polyethylene	Polyethylene
Filter Recovered?	Yes	Yes
Filter Storage Container	Polyethylene	Polyethylene
Impinger Contents Recovered?	Yes	Yes
Impinger Rinse Reagent	Deionized Distilled Water	Deionized Distilled Water
Impinger Wash Bottle	Glass or Polyethylene	Teflon
Impinger Storage Container	Polyethylene	Polyethylene
Analytical Information		
Method 4 H ₂ O Determination by	Volumetric or Gravimetric	Gravimetric and Volumetric
Filter Preparation Conditions	See analytical flow chart	See Analytical Flow Chart
Front-Half Rinse Preparation	See analytical flow chart	See Analytical Flow Chart
Back-Half Analysis	Ion Specific Electrode	Ion Chromatography
Additional Analysis	N/A	None


EPA Method 13B Sampling Train Configuration



Impinger Contents


Impinger 1	100 ml DI H ₂ O
Impinger 2	100 ml DI H ₂ O
Impinger 3	Empty
Impinger 4	Silica Gel

EPA Method 13B Glassware Preparation Procedures




EPA Method 13B Sample Recovery Flowchart

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)



EPA Method 13B Analytical Flowchart



Specification Sheet for

EPA Method 23

Source Location Name(s)

Unit 1 FF Outlet

Pollutant(s) to be Determined

Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans (PCDD/PCDF)

Other Parameters to be Determined from Train

Gas Density, Moisture, Flow Rate


	Standard Method Specification	Actual Specification Used
Pollutant Sampling Information		
Duration of Run	N/A	250 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	10 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
Sampling Probe		
Nozzle Material	Nickel, Quartz, Stainless Steel or Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
Velocity Measuring Equipment		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.833
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
Metering System Console		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
Filter Description		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Glass Frit	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Glass Fiber - Toluene Extracted	Glass Fiber - Toluene Extracted
Other Components		
Adsorbent Module	XAD-2 Trap	XAD-II Adsorbent Trap
Location	After filter and condenser	After filter and condenser
Operating Temperature	< 68°F	<68°F

Specification Sheet for

EPA Method 23

	Standard Method Specification	Actual Specification Used
Impinger Train Description		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	5	5
Impinger Stem Types		
Impinger 1	Modified Greenburg-Smith	Shortened Stem (open tip)
Impinger 2	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 3	Greenburg-Smith	Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 6		
Impinger 7		
Impinger 8		
Gas Density Determination		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	CEM
Sample Recovery Information		
Probe Brush Material	Inert Bristle	Teflon Mat
Probe Rinse Reagent	Acetone/Methylene Chloride/Toluene	Acetone/Toluene (see Appendix J)
Probe Rinse Wash Bottle Material	Glass or Teflon	Teflon
Probe Rinse Storage Container	Glass	Glass
Filter Recovered?	Yes	Yes
Filter Storage Container	Petri Dish - Glass or Polystyrene	Glass
Impinger Contents Recovered?	No	Archived
Impinger Rinse Reagent	N/A	HPLC Water
Impinger Wash Bottle	N/A	Teflon
Impinger Storage Container	N/A	Polyethylene
Analytical Information		
Method 4 H ₂ O Determination by	Volumetric or Gravimetric	Gravimetric
Filter Preparation Conditions	See Method 23 Analytical Flow Chart	For Organic Analysis
Front-Half Rinse Preparation	See Method 23 Analytical Flow Chart	Organic Analysis
Back-Half Analysis	N/A	Archive
Additional Analysis	None	None


EPA Method 23 Sampling Train Configuration



Impinger Contents


Impinger 1	Empty
Impinger 2	100 ml HPLC H ₂ O
Impinger 3	100 ml HPLC H ₂ O
Impinger 4	Empty
Impinger 5	Silica Gel

EPA Method 23 Glassware Preparation Procedures




EPA Method 23 Sample Recovery Flowchart

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)



EPA Method 23 Analytical Flowchart

- Log each sample in shipment and verify against chain-of-custody sheet
- Note liquid levels in the sample containers and confirm on the chain-of-custody sheet condition
- All samples must be extracted within 30 days of collection
- All samples must be analyzed within 45 days of extraction
- All laboratory glassware must be cleaned as described in Section 3A of the "Manual of Analytical Methods for the Analysis of Pesticides"



Specification Sheet for

EPA Method 26A (modified)

Note: Modification includes the use of full-size impingers instead of midget impingers.

Source Location Name(s) Units 1-3 SDA Inlets and Units 1-3 FF Outlets
 Pollutant(s) to be Determined Hydrogen Chloride (HCl)
 Other Parameters to be Determined from Train Gas Density, Moisture

Pollutant Sampling Information

	Standard Method Specification	Actual Specification Used
Duration of Run	N/A	60 minutes
No. of Sample Traverse Points	N/A	1
Sample Time per Point	N/A	60 minutes
Sampling Rate	Constant Rate (±10%)	Constant Rate (±10%)

Sampling Probe

Nozzle Material	N/A	None
Nozzle Design	N/A	N/A
Probe Liner Material	Borosilicate Glass	Borosilicate Glass
Effective Probe Length	N/A	5 feet
Probe Temperature Set-Point	>248°F	350°F @ Inlet, Stack Temp @ FF Outlet

Velocity Measuring Equipment

Pitot Tube Design	None	None
Pitot Tube Coefficient	N/A	N/A
Pitot Tube Calibration by	N/A	N/A
Pitot Tube Attachment	N/A	N/A

Metering System Console

Meter Type	Dry Gas Meter or Critical Orifice	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	2 liters/minute	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter	Wet Test Meter
Pump Type	Diaphragm or equivalent	Rotary Vane
Temperature Measurements	Dial Thermometer or equivalent	Type K Thermocouple/Pyrometer
Temperature Resolution	2°F-5.4°F	1.0°F
ΔP Differential Pressure Gauge	N/A	N/A
ΔH Differential Pressure Gauge	N/A	Inclined Manometer
Barometer	Mercury, aneroid or other.	Digital Barometer calibrated w/Mercury Aneroid

Filter Description

Filter Location	After Probe	Exit of Probe
Filter Holder Material	Teflon or Quartz	Borosilicate Glass
Filter Support Material	Teflon Frit	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	>248°F	350°F @ Inlet, Stack Temp @ FF Outlet
Filter Material	Teflon/Glass Mat (Quartz, Optional High Temp>410F)	Quartz Fiber @ Inlet, Teflon on Glass @ Outlet

Other Components


Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

Specification Sheet for

EPA Method 26A (modified)

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
Impinger Train Description		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	5 or 6 (Midget Impingers)	5
Impinger Stem Types		
Impinger 1	Midget Shortened Stem	Shortened Stem (open tip)
Impinger 2	Midget Bubbler	Greenburg-Smith
Impinger 3	Midget Bubbler	Greenburg-Smith
Impinger 4	Midget Bubbler	Modified Greenburg-Smith
Impinger 5	Midget Bubbler	Modified Greenburg-Smith
Impinger 6	Mae West	
Impinger 7		
Impinger 8		
Gas Density Determination		
Sample Collection	N/A	Single Point Integrated
Sample Collection Medium	N/A	Vinyl Bag
Sample Analysis	N/A	CEM
Sample Recovery Information		
Probe Brush Material	N/A	N/A
Probe Rinse Reagent	N/A	N/A
Probe Rinse Wash Bottle Material	N/A	N/A
Probe Rinse Storage Container	N/A	N/A
Filter Recovered?	No	No
Filter Storage Container	N/A	N/A
Impinger Contents Recovered?	Yes	Yes
Impinger Rinse Reagent	Deionized Distilled Water	Deionized Distilled Water
Impinger Wash Bottle	Polyethylene or glass	Polyethylene
Impinger Storage Container	Polyethylene	Polyethylene
Analytical Information		
Method 4 H ₂ O Determination by	N/A	Gravimetric
Filter Preparation Conditions	N/A	N/A
Front-Half Rinse Preparation	N/A	N/A
Back-Half Analysis	Ion Chromatography	Ion Chromatography
Additional Analysis	None	None


Modified EPA Method 26A Sampling Train Configuration



Impinger Contents


Impinger 1	50 ml 0.1 N H ₂ SO ₄
Impinger 2	100 ml 0.1 N H ₂ SO ₄
Impinger 3	100 ml 0.1 N H ₂ SO ₄
Impinger 4	Empty
Impinger 5	Silica Gel

EPA Method 26A Glassware Preparation Procedures




EPA Method 26
Sample Recovery Flowchart
(without Cl2)
(Modified)

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)



**EPA Method 26
Analytical Flowchart
(without Cl2)
(Modified)**

- Log each sample in shipment and verify against chain-of-custody sheet
- Note liquid levels in the sample containers and confirm on the chain-of-custody sheet condition



SAMPLE CALCULATIONS

B

This Page Intentionally Left Blank

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 111627
N

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

V_{lc}	= total volume of liquid collected in impingers and silica gel (ml)	=	412.4	ml
0.04706	= ideal gas conversion factor (ft ³ water vapor/ml or gm)	=	0.04706	ft ³ /ml
V_{wstd}	= volume of water vapor collected at standard conditions (ft ³)	=	19.41	ft ³

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left(P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.25	in. Hg
T_m	= average dry gas meter temperature (°F)	=	68.40	°F
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	65.67	dcf
Y_d	= gas meter correction factor (dimensionless)	=	0.9916	
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	0.97	in. H ₂ O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	65.915	dscf
------------	---	---	--------	------

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left(\frac{P_g}{13.6} \right)$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.25	in. Hg
P_g	= sample gas static pressure (in. H ₂ O)	=	-9.40	in. H ₂ O
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg

P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
-------	---	---	-------	--------

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left(\frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

T_s	= average sample gas temperature (°F)	=	306.96	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
P_v	= vapor pressure, actual (in. Hg)	=	29.56	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.56	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	65.915	dscf
V_{wstd}	= volume of water collected at standard conditions (scf)	=	19.41	scf
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2275	
		=	22.75	%

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.56	in. Hg
B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2275	
B_w	= actual water vapor in gas	=	0.2275	
		=	22.75	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.7	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	7.6	%
100	= conversion factor (%)	=	100	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.72	%

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = \left(M_{CO_2} \right) \frac{(CO_2)}{(100)} + \left(M_{O_2} \right) \frac{(O_2)}{(100)} + \left(M_{N_2+CO} \right) \frac{(N_2 + CO)}{(100)}$$

Where:

M_{CO_2}	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
M_{O_2}	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
M_{N_2+CO}	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.7	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	7.6	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.7	%
100	= conversion factor (%)	=	100	%
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.17	lb/lb-mole

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2275	
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.17	lb/lb-mole
M_{H_2O}	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
M_s	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.40	lb/lb-mole

12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left(\sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

K_p	= velocity pressure constant	=	85.49	
C_p	= pitot tube coefficient	=	0.81	
M_s	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.40	lb/lb-mole
P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
T_s	= average sample gas temperature (°F)	=	306.96	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H ₂ O)	=	0.632	$\sqrt{\text{in. H}_2\text{O}}$
460	= °F to °R conversion constant	=	460	
V_s	= sample gas velocity (ft/sec)	=	42.72	ft/sec

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

A_s	= cross sectional area of sampling location (ft ²)	=	64.00	ft ²
V_s	= sample gas velocity (ft/sec)	=	42.72	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
Q_a	= volumetric flow rate at actual conditions (acfm)	=	164,030	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left(\frac{P_s}{29.92} \right) \left(\frac{68 + 460}{T_s + 460} \right)$$

Where:

Q_a	= volumetric flow rate at actual conditions (acfm)	=	164,030	acfm
P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
T_s	= average sample gas temperature (°F)	=	307.0	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	111,560	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2275	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	111,560	scfm
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm

16. Dry flow of sample gas corrected to 7%O₂ (dscfm)

$$Q_{std7} = (Q_{std}) \left(\frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
O_2	= proportion of oxygen in the gas stream by volume (%)	=	7.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
Q_{std7}	= volumetric flow rate at STP and 7%O ₂ , dry basis (dscfm)	=	82,526	dscfm

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

17. Hourly time basis conversion of volumetric flow rate (Q_{std} example)

$$Q_{std-hr} = (Q_{std-min})(60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft ³ /min)	=	86,185	dscfm
60	= conversion factor (min/hr)	=	60	min/hr

Q_{std-hr}	= volumetric flow rate, hourly basis (dscf/hr)	=	5,171,079	dscf/hr
--------------	--	---	-----------	---------

18. Metric Conversion of Gas Volumes (Q_{std} example)

$$Q_{std-metric} = (Q_{std-english}) \left(\frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft ³ /min)	=	86,185	dscfm
35.31	= conversion factor (ft ³ /m ³)	=	35.31	ft ³ /m ³
60	= conversion factor (min/hr)	=	60	min/hr

$Q_{std-metric}$	= volumetric flow rate, metric units (m ³ /hr)	=	146,448	dry std m ³ /hr
------------------	---	---	---------	----------------------------

19. Standard to Normal Conversion of Gas Volumes (Q_{std} example)

$$Q_{Normal} = (Q_{std-metric}) \left(\frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m ³ /hr)	=	146,448	dry std m ³ /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	

Q_{Normal}	= volumetric flow rate, metric units (dry Nm ³ /hr)	=	136,463	dry Nm ³ /hr
--------------	--	---	---------	-------------------------

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\bar{T}_s + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n^2(\pi)}{(144)(4)}\right)(\theta)(1 - B_w)}$$

Where:

D_n	= diameter of nozzle (in)	=	0.268	in.
B_w	= proportion of water vapor in the gas stream by volume	=	0.2275	
P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
T_s	= average sample gas temperature (°F)	=	307.0	°F
V_{mstd}	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	65.915	dscf
V_s	= sample gas velocity (ft/sec)	=	42.72	ft/sec
θ	= total sampling time (min)	=	125	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
I	= percent of isokinetic sampling (%)	=	100.02	%

21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{\theta})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

θ	= total sampling time (min)	=	125	min
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	65.67	dcf
T_m	= average dry gas meter temperature (°F)	=	68.40	°F
ΔH_{θ}	= dry gas meter orifice coefficient	=	1.8053	
P_{bar}	= barometric pressure (in. Hg)	=	30.25	in. Hg
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	0.967	in. H ₂ O
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.17	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	0.979	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
Y_{qa}	= alternative Method 5 post-test meter calibration factor	=	1.0130	

**USEPA Method 5/29
 Filterable Particulate Gravimetric Analysis Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042209 081728
 K

1. Total residue from gravimetric analysis of filters (g)

$$m_{fr} = \sum_{i=1}^n m_{fi}$$

Where:

m_{f1}	= residual mass of filter "1" from gravimetric analysis (g)	= 0.00090 g
m_{f2}	= residual mass of filter "2" from gravimetric analysis (g)	= 0.00000 g
m_{f3}	= residual mass of filter "3" from gravimetric analysis (g)	= 0.00000 g
m_{f4}	= residual mass of filter "4" from gravimetric analysis (g)	= 0.00000 g
m_{fr}	= total filter residue from gravimetric analysis (g)	= 0.00090 g

2. Total particulate collected on filters (g)

$$m_{filter} = m_{fr} \text{ if } m_{fr} \geq 0$$

$$m_{filter} = 0 \text{ if } m_{fr} < 0$$

Where:

m_{fr}	= total filter residue from gravimetric analysis (g)	= 0.00090 g
m_{filter}	= total particulate collected on filters (g)	= 0.00090 g

3. Solvent rinse - sample residue mass (g)

$$r_{si} = r_{ai} \left(\frac{v_{si}}{v_{ai}} \right)$$

Where:

r_{ai}	= aliquot residue mass for solvent "i" (g)	= 0.00280 g	Acetone
v_{si}	= sample liquid volume for solvent rinse "i" (ml)	= 96.0 ml	
v_{ai}	= aliquot liquid volume for solvent rinse "i" (ml)	= 96.0 ml	
r_{si}	= solvent rinse "i" - sample residue mass (g)	= 0.00280 g	

4. Solvent rinse - blank residue (g)

$$m_{i-blank} = r_{ai-blank} \text{ if } r_{ai-blank} \geq 0$$

$$m_{i-blank} = 0 \text{ if } r_{ai-blank} < 0$$

Where:

$r_{ai-blank}$	= blank residue for solvent "i" from gravimetric analysis (g)	= 0.00120 g	Acetone
$m_{i-blank}$	= solvent rinse - blank residue (g)	= 0.00120 g	

5. Solvent rinse - maximum allowable blank correction (g)

$$m_{bi} = \text{MINIMUM} \left[\left(\frac{(m_{i-blank})(v_{si})}{v_{ai-blank}} \right) \text{ or } (0.00001)(\rho_i)(v_{si}) \text{ or } (r_{si}) \right] \text{ if } r_{si} \geq 0$$

$$m_{bi} = 0 \quad \text{if } r_{si} < 0$$

Where:

		Acetone
$m_{i-blank}$	= solvent rinse - blank residue (g)	= 0.00120 g
v_{si}	= sample liquid volume for solvent rinse "i" (ml)	= 96.0 ml
$v_{ai-blank}$	= blank liquid volume for solvent rinse "i" (ml)	= 100.0 ml
0.00001	= EPA M5 fraction of total rinse that can be subtracted (g)	= 0.00001 g
ρ_i	= density of solvent rinse "i" (g/ml)	= 0.7845 g/ml
r_{si}	= solvent rinse "i" - sample residue mass (g)	= 0.00280 g
m_{bi}	= solvent rinse "i" - maximum allowable blank correction (g)	= 0.00075 g

6. Solvent rinse - net residue (g)

$$m_i = (r_{si} - m_{bi}) \text{ if } r_{si} \geq m_{bi}$$

$$m_i = 0 \quad \text{if } r_{si} < m_{bi}$$

Where:

		Acetone
r_{si}	= solvent rinse "i" - sample residue mass (g)	= 0.00280 g
m_{bi}	= solvent rinse "i" - maximum allowable blank correction (g)	= 0.00075 g
m_i	= solvent rinse "i" - net residue (g)	= 0.00205 g

7. Total solvent residue - (g)

$$m_s = \sum_{i=1}^n m_i$$

Where:

m_1	= solvent rinse "1" - net residue (g)	= 0.00205 g
m_2	= solvent rinse "2" - net residue (g)	= N/A g
m_3	= solvent rinse "3" - net residue (g)	= N/A g
m_s	= total solvent residue (g)	= 0.00205 g

8. Total gravimetric result (g)

$$m_T = m_{filter} + m_s$$

Where:

m_{filter}	= total particulate collected on filters (g)	= 0.00090 g
m_s	= total solvent residue (g)	= 0.00205 g
m_T	= total gravimetric result (g)	= 0.00295 g

9. Total gravimetric detection limit (g)

$$m_D = (MDL_{filter})(n_f) + (MDL_{rinse})(n_r)$$

Where:

MDL_{filter}	= minimum detection limit for single filter analysis (g)	= 0.00010 g
n_f	= number of filters in analysis	= 1
MDL_{rinse}	= minimum detection limit for single rinse analysis (g)	= 0.00010 g
n_r	= number of rinses in analysis	= 1
m_D	= total gravimetric detection limit (g)	= 0.00020 g

10. Total particulate matter (g)

$$m_n = \text{MAXIMUM}[m_T \text{ or } < m_D]$$

Where:

m_T	= total gravimetric result (g)	= 0.00295 g
m_D	= total gravimetric detection limit (g)	= 0.00020 g
m_n	= total particulate matter (g)	= 0.00295 g

**USEPA Method 5/29
 Filterable Particulate Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

042209 081728
 N_K

1. Particulate concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3})$$

Where:

m_n	= total particulate matter (g)	=	0.00295	g
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
C_{sd}	= particulate concentration (lb/dscf)	=	9.8580E-08	lb/dscf

2. Particulate concentration (gr/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (15.43)$$

Where:

m_n	= total particulate matter (g)	=	0.00295	g
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
15.43	= conversion factor (gr/g)	=	15.43	gr/g
C_{sd}	= particulate concentration (gr/dscf)	=	0.00069	gr/dscf

3. Particulate concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (1000)(35.31)$$

Where:

m_n	= total particulate matter (g)	=	0.00295	g
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
1,000	= conversion factor (mg/g)	=	1,000	mg/g
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
C_{sd}	= particulate concentration (mg/dscm)	=	1.57861	mg/dscm

4. Particulate concentration (mg/Nm³ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (1000)(35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= total particulate matter (g)	= 0.00295	g
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
1,000	= conversion factor (mg/g)	= 1,000	mg/g
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature (°F)	= 68	°F
32	= normal temperature (°F)	= 32	°F
460	= °F to °R conversion constant	= 460	

C_{sd}	= particulate concentration (mg/Nm ³ dry)	= 1.69412	mg/Nm ³ dry
----------	--	-----------	------------------------

5. Particulate concentration corrected to x% O₂ (gr/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= particulate concentration (gr/dscf)	= 0.00069	gr/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
O ₂	= proportion of oxygen in the gas stream by volume (%)	= 7.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

C_{sdx}	= particulate concentration corrected to x%O ₂ (gr/dscf)	= 0.00072	gr/dscf @ x%O ₂
-----------	---	-----------	----------------------------

6. Particulate concentration corrected to y% CO₂ (gr/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= particulate concentration (gr/dscf)	= 0.00069	gr/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
CO ₂	= proportion of carbon dioxide in the gas stream by volume (%)	= 11.7	%

C_{sdy}	= particulate concentration corrected to y%CO ₂ (gr/dscf)	= 0.00071	gr/dscf @ y%CO ₂
-----------	--	-----------	-----------------------------

7. Particulate concentration at actual gas conditions (gr/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= particulate concentration (gr/dscf)	= 0.00069	gr/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 86,185	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	= 164,030	acfm

C_a	= particulate concentration at actual gas conditions (gr/acf)	= 0.00036	gr/acf
-------	---	-----------	--------

8. Particulate rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (Q_{std}) (60)$$

Where:

m_n	= total particulate matter (g)	=	0.00295	g
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
$E_{lb/hr}$	= particulate rate (lb/hr)	=	0.5098	lb/hr

9. Particulate rate (kg/hr)

$$E_{kg/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{(Q_{std})(60)}{1000} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00295	g
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
1,000	= conversion factor (g/kg)	=	1,000	g/kg
$E_{kg/hr}$	= particulate rate (kg/hr)	=	0.2312	kg/hr

10. Particulate rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (Q_{std}) (60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00295	g
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Cap	= capacity factor for process (hours operated/year)	=	8,760	hours/yr
2,000	= conversion factor (lb/Ton)	=	2,000	lb/Ton
$E_{T/yr}$	= particulate rate (Ton/yr)	=	2.2328	Ton/yr

11. Particulate rate - F_d -based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00295	g
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	=	7.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
E_{Fd}	= particulate rate - F_d - based (lb/MMBtu)	=	0.00148	lb/MMBtu

12. Particulate rate - F_c -based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00295	g
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	=	11.7	%
100	= conversion factor	=	100	
E_{Fc}	= particulate rate - F_c - based (lb/MMBtu)	=	0.00153	lb/MMBtu

13. Particulate rate - Heat Input-based (lb/MMBtu)

$$E_{Hi} = \left(\frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) \left(\frac{Q_{std} (60)}{H_i} \right)$$

Where:

m_n	= total particulate matter (g)	=	0.00295	g
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
H_i	= actual heat input (MMBtu/hr)	=		MMBtu/hr
E_{Hi}	= particulate rate - Heat based (lb/MMBtu)	=	N/A	lb/MMBtu

LOGIC FOR TREATING DETECTION LIMITS (mercury only)

1. Logic for Determining Total Blank ($m_{Total-B}$) from 5 Fractions

	CASE 1	CASE 2	CASE 3
	All 5 fractions are D.	1 to 4 fractions are ND	All 5 fractions are ND
Rule			
$ND = 0$	$m_{Total-B} = \text{Sum D, 1-5}$	$m_{Total-B} = \text{Sum D}$	$m_{Total-B} = < \text{Sum ND}$
$ND = 1x$	$m_{Total-B} = \text{Sum D, 1-5}$	$m_{Total-B} = \text{Sum D}$	$m_{Total-B} = < \text{Sum ND}$
$ND = 0.5x$	$m_{Total-B} = \text{Sum D, 1-5}$	$m_{Total-B} = \text{Sum D}$	$m_{Total-B} = < 0.5 \text{ Sum ND}$

2. Logic for Determining Total Sample ($m_{Total-S}$) from 5 Fractions

	CASE 1	CASE 2	CASE 3
	All 5 fractions are D.	1 to 4 fractions are ND	All 5 fractions are ND
Rule			
$ND = 0$	$m_{Total-S} = \text{Sum D, 1-5}$	$m_{Total-S} = \text{Sum D}$	$m_{Total-S} = < \text{Sum ND}$
$ND = 1x$	$m_{Total-S} = \text{Sum D, 1-5}$	$m_{Total-S} = < [\text{Sum D} + \text{Sum ND}]$	$m_{Total-S} = < \text{Sum ND}$
$ND = 0.5x$	$m_{Total-S} = \text{Sum D, 1-5}$	$m_{Total-S} = < [\text{Sum D} + 0.5 \text{ Sum ND}]$	$m_{Total-S} = < 0.5 \text{ Sum ND}$

3. Logic for Determining Maximum Allowable Blank Correction ($m_{T-B-allow}$)

	CASE 1	CASE 2	CASE 3	CASE 4
	All 5 fractions are D.	1 to 4 sample fractions are ND	All 5 fractions are ND	Any type of fractions
	$m_{Total-B} = D$	$m_{Total-B} = D$	$m_{Total-B} = D$	$m_{Total-B} = ND$
Rule				
$ND = 0$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = \text{M29 Rule}^*$	$m_{T-B-allow} = 0$	$m_{T-B-allow} = 0$
$ND = 1x$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = \text{M29 Rule}^*$	$m_{T-B-allow} = 0$	$m_{T-B-allow} = 0$
$ND = 0.5x$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = \text{M29 Rule}^*$	$m_{T-B-allow} = 0$	$m_{T-B-allow} = 0$

* M29 rule using only detected sample quantities for logical comparisons.

4. Logic for Determining Blank-Corrected Sample Amount (m_n)

	CASE 1	CASE 2	CASE 3	CASE 4
	All 5 fractions are D.	1 to 4 sample fractions are ND	All 5 fractions are ND	Any type of fractions
	$m_{Total-S} - m_{T-B-allow} \geq \text{MIN}(\text{MDL})$	$m_{Total-S} - m_{T-B-allow} \geq \text{MIN}(\text{MDL})$	$m_{Total-S}$ and $m_{T-B-allow}$ anything	$m_{Total-S} - m_{T-B-allow} < \text{MIN}(\text{MDL})$
Rule				
$ND = 0$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = < m_{Total-S}$	$m_n = < \text{MIN}[\text{MDL}]$
$ND = 1x$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = < [m_{Total-S} - m_{T-B-allow}]$	$m_n = < m_{Total-S}$	$m_n = < \text{MIN}[\text{MDL}]$
$ND = 0.5x$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = < [m_{Total-S} - m_{T-B-allow}]$	$m_n = < m_{Total-S}$	$m_n = < \text{MIN}[\text{MDL}]$

Definitions and Notes

The term "Rule" refers to the rule being implemented for handling non-detectable quantities in summations.

MDL = minimum detection limit.

D = Detectable quantity reported as D.

ND = Non-Detectable quantity reported at a value of ND.

MIN[MDL] = lowest quantity of all detection limits for 5 fractions.

LOGIC FOR TREATING DETECTION LIMITS

(all metals except mercury)

1. Logic for Determining Maximum Allowable Front-Half Blank Correction ($m_{FB-allow}$)

	CASE 1	CASE 2
	$m_{FB} = D$	$m_{FB} = ND$
Rule		
$ND = 0$	$m_{FB-allow} = M29 \text{ Rule}$	$m_{FB-allow} = 0$
$ND = 1x$	$m_{FB-allow} = M29 \text{ Rule}$	$m_{FB-allow} = 0$
$ND = 0.5x$	$m_{FB-allow} = M29 \text{ Rule}$	$m_{FB-allow} = 0$

2. Logic for Determining Blank-Corrected Front-Half Sample Amount (m_F)

	CASE 1	CASE 2
	$m_{FS} - m_{FB-allow} \geq MDL$	$m_{FS} - m_{FB-allow} < MDL$
Rule		
$ND = 0$	$m_F = m_{FS} - m_{FB-allow}$	$m_F = < MDL$
$ND = 1x$	$m_F = m_{FS} - m_{FB-allow}$	$m_F = < MDL$
$ND = 0.5x$	$m_F = m_{FS} - m_{FB-allow}$	$m_F = < MDL$

3. Logic for Determining Maximum Allowable Back-Half Blank Correction ($m_{BB-allow}$)

	CASE 1	CASE 2
	$m_{BB} = D$	$m_{BB} = ND$
Rule		
$ND = 0$	$m_{BB-allow} = M29 \text{ Rule}$	$m_{BB-allow} = 0$
$ND = 1x$	$m_{BB-allow} = M29 \text{ Rule}$	$m_{BB-allow} = 0$
$ND = 0.5x$	$m_{BB-allow} = M29 \text{ Rule}$	$m_{BB-allow} = 0$

4. Logic for Determining Blank-Corrected Back-Half Sample Amount (m_B)

	CASE 1	CASE 2
	$m_{BS} - m_{BB-allow} \geq MDL$	$m_{BS} - m_{BB-allow} < MDL$
Rule		
$ND = 0$	$m_B = m_{BS} - m_{BB-allow}$	$m_B = < MDL$
$ND = 1x$	$m_B = m_{BS} - m_{BB-allow}$	$m_B = < MDL$
$ND = 0.5x$	$m_B = m_{BS} - m_{BB-allow}$	$m_B = < MDL$

5. Logic for Adding Front and Back-Half Corrected Samples (m_n)

	CASE 1	CASE 2	CASE 3
	Both are D	One is D, other is ND	Both are ND
Rule			
$ND = 0$	$m_n = m_F + m_B$	$m_n = D$	$m_n = < \text{Sum ND}$
$ND = 1x$	$m_n = m_F + m_B$	$m_n = < [D + ND]$	$m_n = < \text{Sum ND}$
$ND = 0.5x$	$m_n = m_F + m_B$	$m_n = < [D + 0.5ND]$	$m_n = < 0.5 \text{ Sum ND}$

Definitions and Notes

The term "Rule" refers to the rule being implemented for handling non-detectable quantities in summations

MDL = minimum detection limit.

D = Detectable quantity reported as D.

ND = Non-Detectable quantity reported at a value of ND.

If Front and Back-Half fractions are combined, then only Items 1 and 2 are used.

**USEPA Method 5/29
 Mercury Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

041409 111827
 6

1. Total blank amount (µg)

$$m_{total-B} = \sum_{i=1}^n m_{i-B}$$

Where:

m_{1b-B}	= mercury amount in blank for Fraction 1b	=	<0.1000	µg
m_{2b-B}	= mercury amount in blank for Fraction 2b	=	<0.2000	µg
m_{3a-B}	= mercury amount in blank for Fraction 3a	=	<0.2000	µg
m_{3b-B}	= mercury amount in blank for Fraction 3b	=	<0.5000	µg
m_{3c-B}	= mercury amount in blank for Fraction 3c	=	<0.4000	µg
$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg

2. Total sample amount (µg)

$$m_{total-S} = \sum_{i=1}^n m_{i-S}$$

Where:

m_{1b-S}	= mercury amount in sample for Fraction 1b	=	<0.1000	µg
m_{2b-S}	= mercury amount in sample for Fraction 2b	=	18.9954	µg
m_{3a-S}	= mercury amount in sample for Fraction 3a	=	0.2294	µg
m_{3b-S}	= mercury amount in sample for Fraction 3b	=	<0.5000	µg
m_{3c-S}	= mercury amount in sample for Fraction 3c	=	<0.4000	µg
$m_{total-S}$	= total amount of mercury in sample	=	19.2248	µg

3. Allowable blank correction (µg)

$$m_{T-B-allow} = m_{total-B} \text{ if } m_{total-B} \leq 0.6$$

$$m_{T-B-allow} = \text{MAX} [0.6, \text{MIN} (m_{total-B}, 0.05 \times m_{total-S})] \text{ if } m_{total-B} > 0.6$$

Where:

$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg
$m_{total-S}$	= total amount of mercury in sample	=	19.2248	µg
$0.05 \times m_{total-S}$	= 5% of $m_{total-S}$	=	0.9612	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
$m_{T-B-allow}$	= total allowable blank correction	=	0.0000	µg

NOTE: In this case, the second criteria applies.

4. Sample corrected for allowable blank - Total (μg)

$$m_n = m_{\text{total-S}} - m_{\text{T-B-allow}}$$

Where:

$m_{\text{total-S}}$	= total amount of mercury in sample	= 19.2248	μg
$m_{\text{T-B-allow}}$	= total allowable blank correction	= 0.0000	μg
m_n	= total mercury in sample corrected for allowable blank	= 19.2248	μg

5. Sample corrected for allowable blank - Prorated for each fraction (μg)

$$m_{n-i} = \left(\frac{m_{i-S}}{m_{\text{total-S}}} \right) (m_n)$$

Where:

m_n	= total mercury in sample corrected for allowable blank	= 19.2248	μg
m_{1b-S}	= mercury amount in sample for Fraction 1b	= <0.1000	μg
m_{2b-S}	= mercury amount in sample for Fraction 2b	= 18.9954	μg
m_{3a-S}	= mercury amount in sample for Fraction 3a	= 0.2294	μg
m_{3b-S}	= mercury amount in sample for Fraction 3b	= <0.5000	μg
m_{3c-S}	= mercury amount in sample for Fraction 3c	= <0.4000	μg
$m_{\text{total-S}}$	= total amount of mercury in sample	= 19.2248	μg
m_{n-1b}	= mercury corrected for blank - prorated for Fraction 1b	= <0.1000	μg
m_{n-2b}	= mercury corrected for blank - prorated for Fraction 2b	= 18.9954	μg
m_{n-3a}	= mercury corrected for blank - prorated for Fraction 3a	= 0.2294	μg
m_{n-3b}	= mercury corrected for blank - prorated for Fraction 3b	= <0.5000	μg
m_{n-3c}	= mercury corrected for blank - prorated for Fraction 3c	= <0.4000	μg

**USEPA Method 5/29
 Mercury Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 111627
 N_G

1. Mercury concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 19.2248	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
C_{sd}	= mercury concentration (lb/dscf)	= 6.4311E-10	lb/dscf

2. Mercury concentration ($\mu\text{g/dscm}$)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= mercury collected in sample (total μg)	= 19.2248	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
C_{sd}	= mercury concentration ($\mu\text{g/dscm}$)	= 1.0299E+01	$\mu\text{g/dscm}$

3. Mercury concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{35.31}{1000} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 19.2248	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
1000	= conversion factor ($\mu\text{g/mg}$)	= 1000	$\mu\text{g/mg}$
C_{sd}	= mercury concentration (mg/dscm)	= 1.0299E-02	mg/dscm

4. Mercury concentration ($\mu\text{g}/\text{Nm}^3$ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 19.2248	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ($^{\circ}\text{F}$)	= 68	$^{\circ}\text{F}$
32	= normal temperature ($^{\circ}\text{F}$)	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	

C_{sd} = mercury concentration ($\mu\text{g}/\text{Nm}^3$ dry) = 1.1052E+01 $\mu\text{g}/\text{Nm}^3$ dry

5. Mercury concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= mercury concentration (lb/dscf)	= 6.4311E-10	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	= 7.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

C_{sdx} = mercury concentration corrected to x% oxygen (lb/dscf) = 6.7162E-10 lb/dscf @ x% O_2

6. Mercury concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= mercury concentration (lb/dscf)	= 6.4311E-10	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	= 11.7	%

C_{sdy} = mercury conc. corrected to y% carbon dioxide (lb/dscf) = 6.6017E-10 lb/dscf @ y% CO_2

7. Mercury concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= mercury concentration (lb/dscf)	= 6.4311E-10	lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 86,185	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	= 164,030	acfm

C_a = mercury concentration at actual gas conditions (lb/acf) = 3.3790E-10 lb/acf

8. Mercury emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60)$$

Where:

m_n	= mercury collected in sample (total μg)	= 19.2248 μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150 dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03 lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06 $\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 86,185 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
$E_{lb/hr}$	= mercury emission rate (lb/hr)	= 3.3256E-03 lb/hr

9. Mercury emission rate (g/s)

$$E_{g/s} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 19.2248 μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150 dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 86,185 dscfm
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06 $\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60 sec/min
$E_{g/s}$	= mercury emission rate (g/s)	= 4.1894E-04 g/s

10. Mercury emission rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 19.2248 μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150 dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03 lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06 $\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 86,185 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760 hours/yr
2000	= conversion factor (lb/Ton)	= 2000 lb/Ton
$E_{T/yr}$	= mercury emission rate (Ton/yr)	= 1.4566E-02 Ton/yr

11. Mercury emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 19.2248	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 7.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
E_{Fd}	= mercury emission rate - Fd-based (lb/MMBtu)	= 9.6642E-06	lb/MMBtu

12. Mercury emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= mercury collected in sample (total μg)	= 19.2248	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	= 11.7	%
100	= conversion factor	= 100	
E_{Fc}	= mercury emission rate - Fc-based (lb/MMBtu)	= 1.0013E-05	lb/MMBtu

**USEPA Method 5/29
 Beryllium Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

041409 111627
 K

1. Maximum front-half blank correction criteria (μg)

$$A = (1.4) \left(\frac{3.141593}{4} \right) \left(\frac{D}{2.54} \right)^2$$

Where:

D	= diameter of filter used in sample apparatus	=	8.2	cm
1.4	= allowable blank per square inch of filter area	=	1.4	$\mu\text{g}/\text{in}^2$
2.54	= conversion constant	=	2.54	cm/in
4	= conversion constant	=	4	
3.141593	= conversion constant (π)	=	3.141593	
A	= maximum front-half blank correction criteria	=	12.46	μg

2. Allowable blank correction - combined front and back-half sample fractions (μg)

$$m_{FB-allow} = m_{FB} \text{ if } m_{FB} \leq A + 1$$

$$m_{FB-allow} = \text{MAX} [A + 1, \text{MIN} (m_{FB}, 0.05 \times m_{FS})] \text{ if } m_{FB} > A + 1$$

Where:

m_{FB}	= beryllium amount in combined front- and back-half blank	=	<0.0500	μg
m_{FS}	= beryllium amount in combined front- and back-half sample	=	<0.0500	μg
A+1	= max combined front- & back-half blank correction criteria	=	12.46	μg
$0.05 \times m_{FS}$	= 5% of combined front- and back-half sample amount	=	<0.0025	μg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			

$m_{FB-allow}$	= allowable combined Beryllium blank correction	=	0.0000	μg
----------------	---	---	--------	---------------

NOTE: In this case, the first criteria applies.

3. Combined front- and back-half sample corrected for allowable blank (μg)

$$m_n = m_{FS} - m_{FB-allow}$$

Where:

m_{FS}	= beryllium amount in combined front- and back-half sample	=	<0.0500	μg
$m_{FB-allow}$	= allowable combined beryllium blank correction	=	0.0000	μg
m_n	= blank-corrected beryllium in combined sample	=	<0.0500	μg

**USEPA Method 5/29
 Beryllium Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 111627
 N_K

1. Beryllium concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	= <0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
C_{sd}	= beryllium concentration (lb/dscf)	= <1.6726E-12	lb/dscf

2. Beryllium concentration ($\mu\text{g/dscm}$)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= beryllium collected in sample (total μg)	= <0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
C_{sd}	= beryllium concentration ($\mu\text{g/dscm}$)	= <2.6785E-02	$\mu\text{g/dscm}$

3. Beryllium concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{35.31}{1000} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	= <0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
1000	= conversion factor ($\mu\text{g/mg}$)	= 1000	$\mu\text{g/mg}$
C_{sd}	= beryllium concentration (mg/dscm)	= <2.6785E-05	mg/dscm

4. Beryllium concentration ($\mu\text{g}/\text{Nm}^3$ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	\pm	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature ($^{\circ}\text{F}$)	=	68	$^{\circ}\text{F}$
32	= normal temperature ($^{\circ}\text{F}$)	=	32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	=	460	

C_{sd} = beryllium concentration ($\mu\text{g}/\text{Nm}^3$ dry) = <2.8744E-02 $\mu\text{g}/\text{Nm}^3$ dry

5. Beryllium concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= beryllium concentration (lb/dscf)	=	<1.6726E-12	lb/dscf
x	= oxygen content of corrected gas (%)	=	7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	7.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%

C_{sdx} = beryllium concentration corrected to x% oxygen (lb/dscf) = <1.7468E-12 lb/dscf @ x% O_2

6. Beryllium concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= beryllium concentration (lb/dscf)	=	<1.6726E-12	lb/dscf
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.7	%

C_{sdy} = beryllium conc. corrected to y% carbon dioxide (lb/dscf) = <1.7170E-12 lb/dscf @ y% CO_2

7. Beryllium concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= beryllium concentration (lb/dscf)	=	<1.6726E-12	lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	=	164,030	acfm

C_a = beryllium concentration at actual gas conditions (lb/acf) = <8.7882E-13 lb/acf

8. Beryllium emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

m_n	= beryllium collected in sample (total μg)	=	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
$E_{lb/hr}$	= beryllium emission rate (lb/hr)	=	<8.6492E-06	lb/hr

9. Beryllium emission rate (g/s)

$$E_{g/s} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	=	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	=	60	sec/min
$E_{g/s}$	= beryllium emission rate (g/s)	=	<1.0896E-06	g/s

10. Beryllium emission rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	=	<0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Cap	= capacity factor for process (hours operated/year)	=	8,760	hours/yr
2000	= conversion factor (lb/Ton)	=	2000	lb/Ton
$E_{Ton/yr}$	= beryllium emission rate (Ton/yr)	=	<3.7883E-05	Ton/yr

11. Beryllium emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	= <0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 7.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
E_{Fd}	= beryllium emission rate - Fd-based (lb/MMBtu)	= <2.5135E-08	lb/MMBtu

12. Beryllium emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= beryllium collected in sample (total μg)	= <0.0500	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	= 11.7	%
100	= conversion factor	= 100	
E_{Fc}	= beryllium emission rate - Fc-based (lb/MMBtu)	= <2.6041E-08	lb/MMBtu

**USEPA Method 5/29
 Cadmium Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

041508 081402
 K

1. Maximum front-half blank correction criteria (µg)

$$A = (1.4) \left(\frac{3.141593}{4} \right) \left(\frac{D}{2.54} \right)^2$$

Where:

D	= diameter of filter used in sample apparatus	=	8.2	cm
1.4	= allowable blank per square inch of filter area	=	1.4	µg/in ²
2.54	= conversion constant	=	2.54	cm/in
4	= conversion constant	=	4	
3.141593	= conversion constant (pi)	=	3.141593	
A	= maximum front-half blank correction criteria	=	12.46	µg

2. Allowable blank correction - combined front and back-half sample fractions (µg)

$$m_{FB-allow} = m_{FB} \text{ if } m_{FB} \leq A + 1$$

$$m_{FB-allow} = \text{MAX} [A + 1, \text{MIN} (m_{FB}, 0.05 \times m_{FS})] \text{ if } m_{FB} > A + 1$$

Where:

m _{FB}	= cadmium amount in combined front- and back-half blank	=	<0.2000	µg
m _{FS}	= cadmium amount in combined front- and back-half sample	=	0.6369	µg
A+1	= max combined front- & back-half blank correction criteria	=	12.46	µg
0.05 x m _{FS}	= 5% of combined front- and back-half sample amount	=	0.0318	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			

m _{FB-allow}	= allowable combined Cadmium blank correction	=	0.0000	µg
-----------------------	---	---	--------	----

NOTE: In this case, the first criteria applies.

3. Combined front- and back-half sample corrected for allowable blank (µg)

$$m_n = m_{FS} - m_{FB-allow}$$

Where:

m _{FS}	= cadmium amount in combined front- and back-half sample	=	0.6369	µg
m _{FB-allow}	= allowable combined cadmium blank correction	=	0.0000	µg
m _n	= blank-corrected cadmium in combined sample	=	0.6369	µg

**USEPA Method 5/29
 Cadmium Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041509 091402
 N_K

1. Cadmium concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	= 0.6369 μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150 dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03 lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06 $\mu\text{g/g}$
C_{sd}	= cadmium concentration (lb/dscf)	= 2.1304E-11 lb/dscf

2. Cadmium concentration ($\mu\text{g/dscm}$)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= cadmium collected in sample (total μg)	= 0.6369 μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm
C_{sd}	= cadmium concentration ($\mu\text{g/dscm}$)	= 3.4116E-01 $\mu\text{g/dscm}$

3. Cadmium concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{35.31}{1000} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	= 0.6369 μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm
1000	= conversion factor ($\mu\text{g/mg}$)	= 1000 $\mu\text{g/mg}$
C_{sd}	= cadmium concentration (mg/dscm)	= 3.4116E-04 mg/dscm

4. Cadmium concentration ($\mu\text{g}/\text{Nm}^3$ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	= 0.6369	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ($^{\circ}\text{F}$)	= 68	$^{\circ}\text{F}$
32	= normal temperature ($^{\circ}\text{F}$)	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	

C_{sd}	= cadmium concentration ($\mu\text{g}/\text{Nm}^3$ dry)	= 3.6612E-01	$\mu\text{g}/\text{Nm}^3$ dry
----------	--	--------------	-------------------------------

5. Cadmium concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= cadmium concentration (lb/dscf)	= 2.1304E-11	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	= 7.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

C_{sdx}	= cadmium concentration corrected to x% oxygen (lb/dscf)	= 2.2249E-11	lb/dscf @ x% O_2
-----------	--	--------------	--------------------

6. Cadmium concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= cadmium concentration (lb/dscf)	= 2.1304E-11	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	= 11.7	%

C_{sdy}	= cadmium conc. corrected to y% carbon dioxide (lb/dscf)	= 2.1869E-11	lb/dscf @ y% CO_2
-----------	--	--------------	---------------------

7. Cadmium concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= cadmium concentration (lb/dscf)	= 2.1304E-11	lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 86,185	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	= 164,030	acfm

C_a	= cadmium concentration at actual gas conditions (lb/acf)	= 1.1194E-11	lb/acf
-------	---	--------------	--------

8. Cadmium emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

m_n	= cadmium collected in sample (total μg)	=	0.6369	μg
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
$E_{lb/hr}$	= cadmium emission rate (lb/hr)	=	1.1017E-04	lb/hr

9. Cadmium emission rate (g/s)

$$E_{g/s} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	=	0.6369	μg
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	=	60	sec/min
$E_{g/s}$	= cadmium emission rate (g/s)	=	1.3878E-05	g/s

10. Cadmium emission rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	=	0.6369	μg
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	=	1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Cap	= capacity factor for process (hours operated/year)	=	8,760	hours/yr
2000	= conversion factor (lb/Ton)	=	2000	lb/Ton
$E_{Ton/yr}$	= cadmium emission rate (Ton/yr)	=	4.8252E-04	Ton/yr

11. Cadmium emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	= 0.6369	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 7.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
E_{Fd}	= cadmium emission rate - Fd-based (lb/MMBtu)	= 3.2014E-07	lb/MMBtu

12. Cadmium emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= cadmium collected in sample (total μg)	= 0.6369	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	= 11.7	%
100	= conversion factor	= 100	
E_{Fc}	= cadmium emission rate - Fc-based (lb/MMBtu)	= 3.3168E-07	lb/MMBtu

**USEPA Method 5/29
 Lead Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

041509 091537
 K

1. Maximum front-half blank correction criteria (µg)

$$A = (1.4) \left(\frac{3.141593}{4} \right) \left(\frac{D}{2.54} \right)^2$$

Where:

D	= diameter of filter used in sample apparatus	=	8.2	cm
1.4	= allowable blank per square inch of filter area	=	1.4	µg/in ²
2.54	= conversion constant	=	2.54	cm/in
4	= conversion constant	=	4	
3.141593	= conversion constant (pi)	=	3.141593	
A	= maximum front-half blank correction criteria	=	12.46	µg

2. Allowable blank correction - combined front and back-half sample fractions (µg)

$$m_{FB-allow} = m_{FB} \text{ if } m_{FB} \leq A + 1$$

$$m_{FB-allow} = \text{MAX} [A + 1, \text{MIN} (m_{FB}, 0.05 \times m_{FS})] \text{ if } m_{FB} > A + 1$$

Where:

m _{FB}	= lead amount in combined front- and back-half blank	=	0.3640	µg
m _{FS}	= lead amount in combined front- and back-half sample	=	1.2392	µg
A+1	= max combined front- & back-half blank correction criteria	=	12.46	µg
0.05 x m _{FS}	= 5% of combined front- and back-half sample amount	=	0.0620	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
m _{FB-allow}	= allowable combined Lead blank correction	=	0.3640	µg

NOTE: In this case, the first criteria applies.

3. Combined front- and back-half sample corrected for allowable blank (µg)

$$m_n = m_{FS} - m_{FB-allow}$$

Where:

m _{FS}	= lead amount in combined front- and back-half sample	=	1.2392	µg
m _{FB-allow}	= allowable combined lead blank correction	=	0.3640	µg
m _n	= blank-corrected lead in combined sample	=	0.8752	µg

**USEPA Method 5/29
 Lead Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041509 091537
 N_K

1. Lead concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.8752	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
C_{sd}	= lead concentration (lb/dscf)	= 2.9277E-11	lb/dscf

2. Lead concentration ($\mu\text{g/dscm}$)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.8752	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
C_{sd}	= lead concentration ($\mu\text{g/dscm}$)	= 4.6884E-01	$\mu\text{g/dscm}$

3. Lead concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{35.31}{1000} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.8752	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
1000	= conversion factor ($\mu\text{g/mg}$)	= 1000	$\mu\text{g/mg}$
C_{sd}	= lead concentration (mg/dscm)	= 4.6884E-04	mg/dscm

4. Lead concentration ($\mu\text{g}/\text{Nm}^3$ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= lead collected in sample (total μg)	=	0.8752	μg
V_{mstd}	= volume metered, standard (dscf)	=	65.9150	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature ($^{\circ}\text{F}$)	=	68	$^{\circ}\text{F}$
32	= normal temperature ($^{\circ}\text{F}$)	=	32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	=	460	

C_{sd} = lead concentration ($\mu\text{g}/\text{Nm}^3$ dry) = 5.0314E-01 $\mu\text{g}/\text{Nm}^3$ dry

5. Lead concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= lead concentration (lb/dscf)	=	2.9277E-11	lb/dscf
x	= oxygen content of corrected gas (%)	=	7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	7.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%

C_{sdx} = lead concentration corrected to x% oxygen (lb/dscf) = 3.0575E-11 lb/dscf @ x% O_2

6. Lead concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= lead concentration (lb/dscf)	=	2.9277E-11	lb/dscf
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.7	%

C_{sdy} = lead conc. corrected to y% carbon dioxide (lb/dscf) = 3.0054E-11 lb/dscf @ y% CO_2

7. Lead concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= lead concentration (lb/dscf)	=	2.9277E-11	lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	86,185	dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	=	164,030	acfm

C_a = lead concentration at actual gas conditions (lb/acf) = 1.5383E-11 lb/acf

8. Lead emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.8752	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 86,185	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$E_{lb/hr}$	= lead emission rate (lb/hr)	= 1.5140E-04	lb/hr

9. Lead emission rate (g/s)

$$E_{g/s} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.8752	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 86,185	dscfm
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60	sec/min
$E_{g/s}$	= lead emission rate (g/s)	= 1.9072E-05	g/s

10. Lead emission rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.8752	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 86,185	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2000	lb/Ton
$E_{Ton/yr}$	= lead emission rate (Ton/yr)	= 6.6311E-04	Ton/yr

11. Lead emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.8752	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 7.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

E_{Fd} = lead emission rate - Fd-based (lb/MMBtu) = 4.3996E-07 lb/MMBtu

12. Lead emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= lead collected in sample (total μg)	= 0.8752	μg
V_{mstd}	= volume metered, standard (dscf)	= 65.9150	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
10^6	= conversion factor ($\mu\text{g/g}$)	= 1.0E+06	$\mu\text{g/g}$
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	= 11.7	%
100	= conversion factor	= 100	

E_{Fc} = lead emission rate - Fc-based (lb/MMBtu) = 4.5582E-07 lb/MMBtu

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

**USEPA Method 13B (Total Fluorides)
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 115318
K

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

V_{lc}	= total volume of liquid collected in impingers and silica gel (ml)	=	219.1	ml
0.04706	= ideal gas conversion factor (ft ³ water vapor/ml or gm)	=	0.04706	ft ³ /ml
V_{wstd}	= volume of water vapor collected at standard conditions (ft ³)	=	10.31	ft ³

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left(P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.20	in. Hg
T_m	= average dry gas meter temperature (°F)	=	79.60	°F
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	38.78	dcf
Y_d	= gas meter correction factor (dimensionless)	=	0.9916	
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.28	in. H ₂ O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	38.083	dscf
------------	---	---	--------	------

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left(\frac{P_g}{13.6} \right)$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.20	in. Hg
P_g	= sample gas static pressure (in. H ₂ O)	=	-9.70	in. H ₂ O
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg

P_s	= absolute sample gas pressure (in. Hg)	=	29.49	in. Hg
-------	---	---	-------	--------

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left(\frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

T_s	= average sample gas temperature (°F)	=	303.96	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
P_v	= vapor pressure, actual (in. Hg)	=	29.49	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.49	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.49	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	38.083	dscf
V_{wstd}	= volume of water collected at standard conditions (scf)	=	10.31	scf
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2131	
		=	21.31	%

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.49	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.49	in. Hg
B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2131	
B_w	= actual water vapor in gas	=	0.2131	
		=	21.31	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.4	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	8.5	%
100	= conversion factor (%)	=	100	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.14	%

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \left(\frac{CO_2}{100} \right) + (M_{O_2}) \left(\frac{O_2}{100} \right) + (M_{N_2+CO}) \left(\frac{N_2+CO}{100} \right)$$

Where:

M_{CO_2}	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
M_{O_2}	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
M_{N_2+CO}	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.4	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	8.5	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.1	%
100	= conversion factor (%)	=	100	%
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.16	lb/lb-mole

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2131	
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.16	lb/lb-mole
M_{H_2O}	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
M_s	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.57	lb/lb-mole

12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p) \left(\sqrt{\Delta P} \right) \left(\sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

K_p	= velocity pressure constant	=	85.49	
C_p	= pitot tube coefficient	=	0.83	
M_s	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.57	lb/lb-mole
P_s	= absolute sample gas pressure (in. Hg)	=	29.49	in. Hg
T_s	= average sample gas temperature (°F)	=	303.96	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H ₂ O)	=	0.684	√in. H ₂ O
460	= °F to °R conversion constant	=	460	
V_s	= sample gas velocity (ft/sec)	=	46.74	ft/sec

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

A_s	= cross sectional area of sampling location (ft ²)	=	64.00	ft ²
V_s	= sample gas velocity (ft/sec)	=	46.74	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
Q_a	= volumetric flow rate at actual conditions (acfm)	=	179,476	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left(\frac{P_s}{29.92} \right) \left(\frac{68 + 460}{T_s + 460} \right)$$

Where:

Q_a	= volumetric flow rate at actual conditions (acfm)	=	179,476	acfm
P_s	= absolute sample gas pressure (in. Hg)	=	29.92	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
T_s	= average sample gas temperature (°F)	=	304.0	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	122,246	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2131	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	122,246	scfm
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	96,200	dscfm

16. Dry flow of sample gas corrected to 7%O₂ (dscfm)

$$Q_{std7} = (Q_{std}) \left(\frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	96,200	dscfm
O_2	= proportion of oxygen in the gas stream by volume (%)	=	8.5	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
Q_{std7}	= volumetric flow rate at STP and 7%O ₂ , dry basis (dscfm)	=	85,888	dscfm

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

17. Hourly time basis conversion of volumetric flow rate (Q_{std} example)

$$Q_{std-hr} = (Q_{std-min})(60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft ³ /min)	=	96,200	dscfm
60	= conversion factor (min/hr)	=	60	min/hr

Q_{std-hr}	= volumetric flow rate, hourly basis (dscf/hr)	=	5,771,996	dscf/hr
--------------	--	---	-----------	---------

18. Metric Conversion of Gas Volumes (Q_{std} example)

$$Q_{std-metric} = (Q_{std-english}) \left(\frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft ³ /min)	=	96,200	dscfm
35.31	= conversion factor (ft ³ /m ³)	=	35.31	ft ³ /m ³
60	= conversion factor (min/hr)	=	60	min/hr

$Q_{std-metric}$	= volumetric flow rate, metric units (m ³ /hr)	=	163,466	dry std m ³ /hr
------------------	---	---	---------	----------------------------

19. Standard to Normal Conversion of Gas Volumes (Q_{std} example)

$$Q_{Normal} = (Q_{std-metric}) \left(\frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m ³ /hr)	=	163,466	dry std m ³ /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	

Q_{Normal}	= volumetric flow rate, metric units (dry Nm ³ /hr)	=	152,321	dry Nm ³ /hr
--------------	--	---	---------	-------------------------

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

20. Percent isokinetic (%)

$$I = \frac{(0.09450)(T_s + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n^2(\pi)}{(144)(4)}\right)(\Theta)(1 - B_w)}$$

Where:

D_n	= diameter of nozzle (in)	=	0.272	in.
B_w	= proportion of water vapor in the gas stream by volume	=	0.2131	
P_s	= absolute sample gas pressure (in. Hg)	=	29.49	in. Hg
T_s	= average sample gas temperature (°F)	=	304.0	°F
V_{mstd}	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	38.083	dscf
V_s	= sample gas velocity (ft/sec)	=	46.74	ft/sec
θ	= total sampling time (min)	=	63	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
I	= percent of isokinetic sampling (%)	=	100.52	%

21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\Theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{@})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

θ	= total sampling time (min)	=	63	min
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	38.78	dcf
T_m	= average dry gas meter temperature (°F)	=	79.60	°F
$\Delta H_{@}$	= dry gas meter orifice coefficient	=	1.8053	
P_{bar}	= barometric pressure (in. Hg)	=	30.20	in. Hg
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.280	in. H ₂ O
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.16	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.129	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
Y_{qa}	= alternative Method 5 post-test meter calibration factor	=	1.0006	

**USEPA Method 13B
 HF Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041408 115318
 J

1. Fluoride to HF conversion factor

$$K_{HF} = \frac{MW_{HF}}{n \times MW_{F^-}}$$

Where:

MW_{HF}	= molecular weight of HF (mg/mg-mole)	=	20.006	mg/mg-mole
MW_{F^-}	= molecular weight of fluoride ion (mg/mg-mole)	=	18.998	mg/mg-mole
n	= molar ratio of fluoride to HF	=	1.0	mole F/mole HF
K_{HF}	= conversion factor to convert mass F ⁻ to mass HF	=	1.053	

2. Total HF collected (mg)

$$m_{HF} = K_{HF} \times \frac{(S_{F-1}v_1 + S_{F-2}v_2)}{1000}$$

Where:

K_{HF}	= conversion factor to convert mass F ⁻ to mass HF	=	1.053	
S_{F-1}	= fluoride concentration of sample fraction 1 (mg/liter)	=	<0.0260	mg/liter
v_1	= liquid volume of sample fraction 1 (ml)	=	896.0	ml
S_{F-2}	= fluoride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v_2	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m_{HF}	= total HF collected in sample (mg)	=	<0.0245	mg

Note: Non-detects are treated as zero in summations.

DEFINITION

Fraction 1 = entire sample except last impinger containing applicable absorbing reagent.
 Fraction 2 = last impinger containing applicable absorbing reagent, analyzed separately to evaluate collection efficiency.
 If entire sample is analyzed as a single fraction, then data is included as Fraction 1 (Fraction 2 = 0).

3. Allowable blank subtraction (mg)

$$m_b = K_{HF} \times B_F \times \frac{(v_1 + v_2)}{1000}$$

$$m_b = 0 \text{ if } B_F < MDL$$

Where:

K_{HF}	= conversion factor to convert mass F ⁻ to mass HF	=	1.053	
B_F	= fluoride concentration of blank (mg/liter)	=	<0.0260	mg/liter
v_1	= liquid volume of sample fraction 1 (ml)	=	896.0	ml
v_2	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m_b	= allowable blank subtraction (mg)	=	0.0000	mg

4. Total HF collected, corrected for blank (mg)

$$m_{nb} = m_{HF} - m_b$$

Where:

m_{HF}	= total HF collected in sample (mg)	=	<0.0245	mg
m_b	= allowable blank subtraction (mg)	=	0.0000	mg
m_{nb}	= total HF collected, corrected for blank (mg)	=	<0.0245	mg

5. Minimum detectable HF (mg)

$$m_{MDL} = K_{HF} \times MDL \times \frac{(v_1 + v_2)}{1000}$$

Where:

K_{HF}	= conversion factor to convert mass F to mass HF	=	1.053	
MDL	= minimum detectable fluoride concentration	=	0.005	mg/liter
v_1	= liquid volume of sample fraction 1 (ml)	=	896.0	ml
v_2	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m_{MDL}	= minimum detectable HF (mg)	=	0.0047	mg

6. Total HF value used in emission calculations (mg)

$$m_n = \text{MAXIMUM} [m_{nb} \text{ or } < m_{MDL}]$$

Where:

m_{nb}	= total HF collected, corrected for blank (mg)	=	<0.0245	mg
m_{MDL}	= minimum detectable HF (mg)	=	0.0047	mg
m_n	= total HF value used in emission calculations (mg)	=	<0.0245	mg

7. Collection QC check (% mass collected in second fraction)

$$EFF = 100 \times \frac{K_{HF} \times S_{F-2} \times \frac{v_2}{1000}}{m_{HF}}$$

Where:

K_{HF}	= conversion factor to convert mass F to mass HF	=	1.053	
S_{F-2}	= fluoride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v_2	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
m_{HF}	= total HF collected in sample (mg)	=	<0.0245	mg
1000	= conversion factor (ml/liter)	=	1000	ml/liter
100	= conversion factor	=	100	%
EFF	= Collection QC check (% mass collected in second fraction)	=	0.00	%

**USEPA Method 13B
 HF Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 115318
 K,J

1. HF concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0245	mg
V_{mstd}	= volume metered, standard (dscf)	=	38.0828	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
C_{sd}	= HF concentration (lb/dscf)	=	<1.4203E-09	lb/dscf

2. HF concentration (ppmdv)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{0.850}{1000} \right) \left(\frac{10^6}{MW} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0245	mg
V_{mstd}	= volume metered, standard (dscf)	=	38.0828	dscf
MW	= molecular weight of HF (g/g-mole)	=	20.006	g/g-mole
0.850	= conversion factor (dscf/g-mole)	=	0.850	dscf/g-mole
1000	= conversion factor (mg/g)	=	1,000	mg/g
10^6	= conversion factor (ppm)	=	10^6	ppm
C_{sd}	= HF concentration (ppmdv)	=	<0.0274	ppmdv

3. HF concentration (ppmwv)

$$C_w = C_{sd} \left(1 - \frac{B_w}{100} \right)$$

Where:

C_{sd}	= HF concentration (ppmdv)	=	<0.0274	ppmdv
B_w	= actual water vapor in gas (% v/v)	=	21.3062	% v/v
100	= conversion factor (%)	=	100	%
C_w	= HF concentration (ppmwv)	=	<0.0215	ppmwv

4. HF concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0245	mg
V_{mstd}	= volume metered, standard (dscf)	=	38.0828	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
C_{sd}	= HF concentration (mg/dscm)	=	<0.0227	mg/dscm

5. HF concentration (mg/Nm³ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0245	mg
V_{mstd}	= volume metered, standard (dscf)	=	38.0828	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature (°F)	=	68	°F
32	= normal temperature (°F)	=	32	°F
460	= °F to °R conversion constant	=	460	
C_{sd}	= HF concentration (mg/Nm ³ dry)	=	<0.0244	mg/Nm ³ dry

6. HF concentration corrected to x% O₂ (ppmdv example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= HF concentration (ppmdv)	=	<0.0274	ppmdv
x	= oxygen content of corrected gas (%)	=	7.0	%
O ₂	= proportion of oxygen in the gas stream by volume (%)	=	8.5	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
C_{sdx}	= HF concentration corrected to x%O ₂ (ppmdv)	=	<0.0307	ppmdv @ x%O ₂

7. HF concentration corrected to y% CO₂ (ppmdv example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= HF concentration (ppmdv)	=	<0.0274	ppmdv
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
CO ₂	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.4	%
C_{sdy}	= HF concentration corrected to y%CO ₂ (ppmdv)	=	<0.0289	ppmdv @ y%CO ₂

8. HF concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$$

Where:

C_{sd}	= HF concentration (lb/dscf)	= <1.4203E-09 lb/dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 96,200 dscfm
Q_a	= volumetric flow rate at actual conditions (acfm)	= 179,476 acfm
C_a	= HF concentration at actual gas conditions (lb/acf)	= <7.6130E-10 lb/acf

9. HF rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (Q_{std})(60)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	= <0.0245 mg
V_{mstd}	= volume metered, standard (dscf)	= 38.0828 dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03 lb/g
1000	= conversion factor (mg/g)	= 1,000 mg/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 96,200 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
$E_{lb/hr}$	= HF rate (lb/hr)	= <0.0082 lb/hr

10. HF rate (kg/hr)

$$E_{kg/hr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{(Q_{std})(60)}{10^6} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	= <0.0245 mg
V_{mstd}	= volume metered, standard (dscf)	= 38.0828 dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 96,200 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
10^6	= conversion factor (mg/kg)	= 10^6 g/kg
$E_{kg/hr}$	= HF rate (kg/hr)	= <0.0037 kg/hr

11. HF rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (Q_{std})(60) \left(\frac{Cap}{2000} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	= <0.0245 mg
V_{mstd}	= volume metered, standard (dscf)	= 38.0828 dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03 lb/g
1000	= conversion factor (mg/g)	= 1,000 mg/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 96,200 dscfm
60	= conversion factor (min/hr)	= 60 min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760 hours/yr
2000	= conversion factor (lb/Ton)	= 2,000 lb/Ton
$E_{T/yr}$	= HF rate (Ton/yr)	= <0.0359 Ton/yr

12. HF rate - F_d -based (lb/MMBtu)

$$E_{F_d} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0245	mg
V_{mstd}	= volume metered, standard (dscf)	=	38.0828	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	=	8.5	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
E_{F_d}	= HF rate (lb/MMBtu)	=	<2.2892E-05	lb/MMBtu

13. HF rate - F_c -based (lb/MMBtu)

$$E_{F_c} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= total HF collected, corrected for applicable blank (mg)	=	<0.0245	mg
V_{mstd}	= volume metered, standard (dscf)	=	38.0828	dscf
2.205×10^{-3}	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	=	11.4	%
100	= conversion factor	=	100	
E_{F_c}	= HF rate (lb/MMBtu)	=	<2.2735E-05	lb/MMBtu

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

**USEPA Method 23 (PCDD/F)
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 115425
J

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

V_{lc}	= total volume of liquid collected in impingers and silica gel (ml)	=	812.3	ml
0.04706	= ideal gas conversion factor (ft ³ water vapor/ml or gm)	=	0.04706	ft ³ /ml
V_{wstd}	= volume of water vapor collected at standard conditions (ft ³)	=	38.23	ft ³

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left(P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.25	in. Hg
T_m	= average dry gas meter temperature (°F)	=	87.88	°F
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	142.94	dcf
Y_d	= gas meter correction factor (dimensionless)	=	0.9937	
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.01	in. H ₂ O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	138.679	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left(\frac{P_g}{13.6} \right)$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.25	in. Hg
P_g	= sample gas static pressure (in. H ₂ O)	=	-9.40	in. H ₂ O
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left(\frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

T_s	= average sample gas temperature (°F)	=	307.04	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
P_v	= vapor pressure, actual (in. Hg)	=	29.56	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.56	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	138.679	dscf
V_{wstd}	= volume of water collected at standard conditions (scf)	=	38.23	scf
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2161	
		=	21.61	%

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

P_s = absolute sample gas pressure (in. Hg) = 29.56 in. Hg

P_v = water vapor pressure, actual (in. Hg) = 29.56 in. Hg

B_{ws} = proportion of water vapor in the gas stream by volume at saturated conditions = 1.0000 = 100.00 %

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

B_{ws} = proportion of water vapor in the gas stream by volume at saturated conditions = 1.0000

B_{wo} = proportion of water measured in the gas stream by volume = 0.2161

B_w = actual water vapor in gas = 0.2161 = 21.61 %

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

CO_2 = proportion of carbon dioxide in the gas stream by volume (%) = 11.3 %

O_2 = proportion of oxygen in the gas stream by volume (%) = 8.6 %

100 = conversion factor (%) = 100 %

N_2+CO = proportion of nitrogen and CO in the gas stream by volume (%) = 80.15 %

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

10. Molecular weight of dry gas stream (lb/lb·mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2+CO)}{(100)}$$

Where:

M_{CO_2}	= molecular weight of carbon dioxide (lb/lb·mole)	=	44.00	lb/lb·mole
M_{O_2}	= molecular weight of oxygen (lb/lb·mole)	=	32.00	lb/lb·mole
M_{N_2+CO}	= molecular weight of nitrogen and carbon monoxide (lb/lb·mole)	=	28.00	lb/lb·mole
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.3	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	8.6	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.2	%
100	= conversion factor (%)	=	100	%
M_d	= dry molecular weight of sample gas (lb/lb·mole)	=	30.15	lb/lb·mole

11. Molecular weight of sample gas (lb/lb·mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2161	
M_d	= dry molecular weight of sample gas (lb/lb·mole)	=	30.15	lb/lb·mole
M_{H_2O}	= molecular weight of water (lb/lb·mole)	=	18.00	lb/lb·mole
M_s	= molecular weight of sample gas, wet basis (lb/lb·mole)	=	27.52	lb/lb·mole

12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left(\sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

K_p	= velocity pressure constant	=	85.49	
C_p	= pitot tube coefficient	=	0.83	
M_s	= wet molecular weight of sample gas, wet basis (lb/lb·mole)	=	27.52	lb/lb·mole
P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
T_s	= average sample gas temperature (°F)	=	307.04	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H ₂ O)	=	0.651	$\sqrt{\text{in. H}_2\text{O}}$
460	= °F to °R conversion constant	=	460	
V_s	= sample gas velocity (ft/sec)	=	44.99	ft/sec

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

A_s	= cross sectional area of sampling location (ft ²)	=	64.00	ft ²
V_s	= sample gas velocity (ft/sec)	=	44.99	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
Q_a	= volumetric flow rate at actual conditions (acfm)	=	172,759	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left(\frac{P_s}{29.92} \right) \left(\frac{68 + 460}{T_s + 460} \right)$$

Where:

Q_a	= volumetric flow rate at actual conditions (acfm)	=	172,759	acfm
P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
T_s	= average sample gas temperature (°F)	=	307.0	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	117,485	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2161	
Q_s	= volumetric flow rate at standard conditions, wet basis (scfm)	=	117,485	scfm
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	92,098	dscfm

16. Dry flow of sample gas corrected to 7%O₂ (dscfm)

$$Q_{std7} = (Q_{std}) \left(\frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	92,098	dscfm
O_2	= proportion of oxygen in the gas stream by volume (%)	=	8.6	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
Q_{std7}	= volumetric flow rate at STP and 7%O ₂ , dry basis (dscfm)	=	81,828	dscfm

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

17. Hourly time basis conversion of volumetric flow rate (Q_{std} example)

$$Q_{std-hr} = (Q_{std-min})(60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft^3/min)	=	92,098	dscfm
60	= conversion factor (min/hr)	=	60	min/hr

Q_{std-hr}	= volumetric flow rate, hourly basis (dscf/hr)	=	5,525,886	dscf/hr
--------------	--	---	-----------	---------

18. Metric Conversion of Gas Volumes (Q_{std} example)

$$Q_{std-metric} = (Q_{std-english}) \left(\frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft^3/min)	=	92,098	dscfm
35.31	= conversion factor (ft^3/m^3)	=	35.31	ft^3/m^3
60	= conversion factor (min/hr)	=	60	min/hr

$Q_{std-metric}$	= volumetric flow rate, metric units (m^3/hr)	=	156,496	dry std m^3/hr
------------------	---	---	---------	------------------

19. Standard to Normal Conversion of Gas Volumes (Q_{std} example)

$$Q_{Normal} = (Q_{std-metric}) \left(\frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m^3/hr)	=	156,496	dry std m^3/hr
32	= normal temperature ($^{\circ}F$)	=	32	$^{\circ}F$
68	= standard temperature ($^{\circ}F$)	=	68	$^{\circ}F$
460	= standard temperature in Rankine (68 $^{\circ}F$)	=	460	

Q_{Normal}	= volumetric flow rate, metric units (dry Nm^3/hr)	=	145,826	dry Nm^3/hr
--------------	---	---	---------	---------------

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

20. Percent isokinetic (%)

$$I = \frac{(0.09450)(T_s + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n}{1.44}\right)^2(\theta)(1 - B_w)}$$

Where:

D_n	= diameter of nozzle (in)	=	0.266	in.
B_w	= proportion of water vapor in the gas stream by volume	=	0.2161	
P_s	= absolute sample gas pressure (in. Hg)	=	29.56	in. Hg
T_s	= average sample gas temperature (°F)	=	307.0	°F
V_{mstd}	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	138.679	dscf
V_s	= sample gas velocity (ft/sec)	=	44.99	ft/sec
θ	= total sampling time (min)	=	250	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
I	= percent of isokinetic sampling (%)	=	99.95	%

21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{\theta})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

θ	= total sampling time (min)	=	250	min
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	142.94	dcf
T_m	= average dry gas meter temperature (°F)	=	87.88	°F
ΔH_{θ}	= dry gas meter orifice coefficient	=	1.7498	
P_{bar}	= barometric pressure (in. Hg)	=	30.25	in. Hg
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.008	in. H ₂ O
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.15	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.000	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in.H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
Y_{qa}	= alternative Method 5 post-test meter calibration factor	=	0.9836	

**USEPA Method 23
 PCDD/PCDF Emissions Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: PCDD/F results may be presented in two formats - normally expected levels and the maximum possible levels. In the normal case, data classified as ND (non-detect) or EMPC (estimated maximum possible concentration) are not counted. In the maximum possible emissions case, NDs and EMPCs are fully counted.

041409 115425
 J_M

	Normal Case (ND & EMPC = 0)	Maximum Case (ND & EMPC fully counted)
1. TEQ concentration (ng/dscm)		
$C_{sd} = \left(\frac{m_{n-TEQ}}{V_{msd}} \right) \times 35.31$		
Where:		
m_{n-TEQ} = total TEQ mass for PCDDs and PCDFs (ng)	= 2.3600E-02 ng	2.4200E-02 ng
V_{msd} = volume metered, standard (dscf)	= 138.6788 dscf	138.6788 dscf
35.31 = conversion factor (dscf/dscm)	= 35.31 dscf/dscm	35.31 dscf/dscm
C_{sd} = PCDD/F TEQ concentration (ng/dscm)	= 6.0090E-03 ng/dscm	6.1617E-03 ng/dscm

2. TEQ concentration (ng/Nm3 dry)		
$C_{sd} = \left(\frac{m_{n-TEQ}}{V_{msd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$		
Where:		
m_{n-TEQ} = total TEQ mass for PCDDs and PCDFs (ng)	= 2.3600E-02 ng	2.4200E-02 ng
V_{msd} = volume metered, standard (dscf)	= 138.6788 dscf	138.6788 dscf
35.31 = conversion factor (dscf/dscm)	= 35.31 dscf/dscm	35.31 dscf/dscm
68 = standard temperature (°F)	= 68 °F	68 °F
32 = normal temperature (°F)	= 32 °F	32 °F
460 = °F to °R conversion constant	= 460	480
C_{sd} = PCDD/F TEQ concentration (ng/Nm3 dry)	= 6.4486E-03 ng/Nm3 dry	6.6128E-03 ng/Nm3 dry

3. TEQ concentration at actual gas conditions (ng/acm example)		
$C_a = C_{sd} \left(\frac{Q_{std}}{Q_a} \right)$		
Where:		
C_{sd} = PCDD/F TEQ concentration (ng/dscm)	= 6.0090E-03 ng/dscm	6.1617E-03 ng/dscm
Q_{std} = volumetric flow rate at standard conditions, dry basis (dscm/h)	= 156,496 dry std m ³ /hr	156,496 dry std m ³ /hr
Q_a = volumetric flow rate at actual conditions (acm/h)	= 293,558 actual m ³ /hr	293,558 actual m ³ /hr
C_a = PCDD/F TEQ concentration at actual gas conditions (ng/acm)	= 3.2034E-03 ng/acm	3.2848E-03 ng/acm

4. TEQ concentration corrected to x% O2 (ng/dscm example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= PCDD/F TEQ concentration (ng/dscm)	= 6.0090E-03	ng/dscm	6.1617E-03	ng/dscm
x	= oxygen content of corrected gas (%)	= 7.0	%	7.0	%
O_2	= proportion of oxygen in the gas stream by volume (%)	= 8.6	%	8.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%	20.9	%
C_{sdx}	= PCDD/F TEQ concentration (ng/dscm corrected to x% O ₂)	= 6.7631E-03	ng/dscm @ x% O ₂	6.9351E-03	ng/dscm @ x% O ₂

5. TEQ concentration corrected to y% CO2 (ng/dscm example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= PCDD/F TEQ concentration (ng/dscm)	= 6.0090E-03	ng/dscm	6.1617E-03	ng/dscm
y	= carbon dioxide content of corrected gas (%)	= 12.0	%	12.0	%
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	= 11.3	%	11.3	%
C_{sdy}	= PCDD/F TEQ concentration (ng/dscm corrected to y% CO ₂)	= 6.3812E-03	ng/dscm @ y% CO ₂	6.5434E-03	ng/dscm @ y% CO ₂

6. TEQ Emission rate (lb/hr)

$$E_{lb/hr} = \left(\frac{m_{n-TEQ}}{V_{mstd}} \right) (2.205 \times 10^{-3}) (Q_{std}) \left(\frac{60}{10^9} \right)$$

Where:

m_{n-TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 2.3600E-02	ng	2.4200E-02	ng
V_{mstd}	= volume metered, standard (dscf)	= 138.6788	dscf	138.6788	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g	2.205E-03	lb/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 92,098	dscfm	92,098	dscfm
60	= conversion factor (min/hr)	= 60	min/hr	60	min/hr
10^9	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
$E_{lb/hr}$	= PCDDF TEQ Emission rate (lb/hr)	= 2.0735E-09	lb/hr	2.1263E-09	lb/hr

7. TEQ Emission rate (g/sec)

$$E_{g/sec} = \left(\frac{m_{n-TEQ}}{V_{mstd}} \right) \left(\frac{Q_{std}}{60 \times 10^9} \right)$$

Where:

m_{n-TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 2.3600E-02	ng	2.4200E-02	ng
V_{mstd}	= volume metered, standard (dscf)	= 138.6788	dscf	138.6788	dscf
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 92,098	dscfm	92,098	dscfm
60	= conversion factor (sec/min)	= 60	sec/min	60	sec/min
10^9	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
$E_{g/sec}$	= PCDDF TEQ Emission rate (g/sec)	= 2.6122E-10	g/sec	2.6786E-10	g/sec

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

USEPA Method 23 PCDD/PCDF Emissions Calculations

8. TEQ emission rate (Ton/yr)

$$E_{T/yr} = \left(\frac{m_{n_TEQ}}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^9} \right) (Q_{std}) (60) \left(\frac{Cap}{2000} \right)$$

Where:

m_{n_TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 2.3600E-02	ng	2.4200E-02	ng
V_{mstd}	= volume metered, standard (dscf)	= 138.6788	dscf	138.6788	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g	2.205E-03	lb/g
Q_{std}	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 92,098	dscfm	92,098	dscfm
60	= conversion factor (min/hr)	= 60	min/hr	60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr	8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2,000	lb/Ton	2,000	lb/Ton
10^9	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
$E_{T/yr}$	= PCDDF TEQ Emission rate (Ton/yr)	= 9.0821E-09	Ton/yr	9.3130E-09	Ton/yr

9. TEQ emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_{n_TEQ}}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^9} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_{n_TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 2.3600E-02	ng	2.4200E-02	ng
V_{mstd}	= volume metered, standard (dscf)	= 138.6788	dscf	138.6788	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g	2.205E-03	lb/g
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu	9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 8.6	%	8.6	%
20.9	= oxygen content of ambient air (%)	= 20.9	%	20.9	%
10^9	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
E_{Fd}	= PCDDF TEQ Emission rate (lb/MMBtu)	= 6.0772E-12	lb/MMBtu	6.2317E-12	lb/MMBtu

10. TEQ emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_{n_TEQ}}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{10^9} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_{n_TEQ}	= total TEQ mass for PCDDs and PCDFs (ng)	= 2.3600E-02	ng	2.4200E-02	ng
V_{mstd}	= volume metered, standard (dscf)	= 138.6788	dscf	138.6788	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g	2.205E-03	lb/g
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu	1,820	dscf/MMBtu
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	= 11.3	%	11.3	%
100	= conversion factor	= 100		100	
10^9	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
E_{Fc}	= PCDDF TEQ Emission rate (lb/MMBtu)	= 6.0437E-12	lb/MMBtu	6.1974E-12	lb/MMBtu

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 SDA Inlet

**USEPA Method 26A (HCl)
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 115716
K

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

V_{lc}	= total volume of liquid collected in impingers and silica gel (ml)	=	139.5	ml
0.04706	= ideal gas conversion factor (ft ³ water vapor/ml or gm)	=	0.04706	ft ³ /ml
V_{wstd}	= volume of water vapor collected at standard conditions (ft ³)	=	6.56	ft ³

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left(P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.20	in. Hg
T_m	= average dry gas meter temperature (°F)	=	73.50	°F
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	32.13	dcf
Y_d	= gas meter correction factor (dimensionless)	=	1.0028	
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.02	in. H ₂ O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	
V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	32.253	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left(\frac{P_g}{13.6} \right)$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.20	in. Hg
P_g	= sample gas static pressure (in. H ₂ O)	=	-2.20	in. H ₂ O
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
P_s	= absolute sample gas pressure (in. Hg)	=	30.04	in. Hg

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 SDA Inlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left(\frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

T_s	= average sample gas temperature (°F)	=	495.67	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
P_v	= vapor pressure, actual (in. Hg)	=	30.04	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	30.04	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	30.04	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	32.253	dscf
V_{wstd}	= volume of water collected at standard conditions (scf)	=	6.56	scf
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.1691	
		=	16.91	%

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 SDA Inlet

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	30.04	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	30.04	in. Hg
B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.1691	
B_w	= actual water vapor in gas	=	0.1691	
		=	16.91	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.7	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	7.8	%
100	= conversion factor (%)	=	100	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.53	%

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 SDA Inlet

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2+CO)}{(100)}$$

Where:

M_{CO_2}	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
M_{O_2}	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
M_{N_2+CO}	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.7	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	7.8	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.5	%
100	= conversion factor (%)	=	100	%
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.18	lb/lb-mole

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.1691	
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.18	lb/lb-mole
M_{H_2O}	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
M_s	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	28.12	lb/lb-mole

**USEPA Method 26A
 HCl Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

D41409 115716

1. Chloride to HCl conversion factor

$$K_{HCl} = \frac{MW_{HCl}}{n \times MW_{Cl^-}}$$

Where:

MW _{HCl}	= molecular weight of HCl (mg/mg-mole)	=	36.461	mg/mg-mole
MW _{Cl⁻}	= molecular weight of chloride ion (mg/mg-mole)	=	35.453	mg/mg-mole
n	= molar ratio of chloride to HCl	=	1.0	mole Cl ⁻ /mole HCl
K _{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	=	1.028	

2. Total HCl collected (mg)

$$m_{HCl} = K_{HCl} \times \frac{(S_{Cl-1}v_1 + S_{Cl-2}v_2)}{1000}$$

Where:

K _{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	=	1.028	
S _{Cl-1}	= chloride concentration of sample fraction 1 (mg/liter)	=	874.2600	mg/liter
v ₁	= liquid volume of sample fraction 1 (ml)	=	792.0	ml
S _{Cl-2}	= chloride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v ₂	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m _{HCl}	= total HCl collected in sample (mg)	=	711.8015	mg

Note: Non-detects are treated as zero in summations.

DEFINITION

Fraction 1 = entire sample except last impinger containing applicable absorbing reagent.
 Fraction 2 = last impinger containing applicable absorbing reagent, analyzed separately to evaluate collection efficiency.
 If entire sample is analyzed as a single fraction, then data is included as Fraction 1 (Fraction 2 = 0).

3. Allowable blank subtraction (mg)

$$m_b = K_{HCl} \times B_{Cl} \times \frac{(v_1 + v_2)}{1000}$$

$$m_b = 0 \text{ if } B_{Cl} < MDL$$

Where:

K _{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	=	1.0280	
B _{Cl}	= chloride concentration of blank (mg/liter)	=	<0.0	mg/liter
v ₁	= liquid volume of sample fraction 1 (ml)	=	792.0	ml
v ₂	= liquid volume of sample fraction 2 (ml)	=	0	ml
1000	= conversion factor (ml/liter)	=	1000.0000	ml/liter
m _b	= allowable blank subtraction (mg)	=	0.0000	mg

4. Total HCl collected, corrected for blank (mg)

$$m_{nb} = m_{HCl} - m_b$$

Where:

m_{HCl}	= total HCl collected in sample (mg)	= 711.8015	mg
m_b	= allowable blank subtraction (mg)	= 0.0000	mg
m_{nb}	= total HCl collected, corrected for blank (mg)	= 711.8015098	mg

5. Minimum detectable HCl (mg)

$$m_{MDL} = K_{HCl} \times MDL \times \frac{(v_1 + v_2)}{1000}$$

Where:

K_{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	= 1.028	
MDL	= minimum detectable chloride concentration	= 0.0	mg/liter
v_1	= liquid volume of sample fraction 1 (ml)	= 792.0	ml
v_2	= liquid volume of sample fraction 2 (ml)	= 0	ml
1000	= conversion factor (ml/liter)	= 1000	ml/liter
m_{MDL}	= minimum detectable HCl (mg)	= 0.001628352	mg

6. Total HCl value used in emission calculations (mg)

$$m_n = \text{MAXIMUM} [m_{nb} \text{ or } < m_{MDL}]$$

Where:

m_{nb}	= total HCl collected, corrected for blank (mg)	= 711.8015	mg
m_{MDL}	= minimum detectable HCl (mg)	= 0.001628352	mg
m_n	= total HCl value used in emission calculations (mg)	= 711.8015098	mg

7. Collection QC check (% mass collected in second fraction)

$$EFF = 100 \times \frac{K_{HCl} \times S_{Cl-2} \times \frac{v_2}{1000}}{m_{HCl}}$$

Where:

K_{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	= 1.0280	
S_{Cl-2}	= chloride concentration of sample fraction 2 (mg/liter)	= 0.0	mg/liter
v_2	= liquid volume of sample fraction 2 (ml)	= 0.0000	ml
m_{HCl}	= total HCl collected in sample (mg)	= 712	mg
1000	= conversion factor (ml/liter)	= 1000	ml/liter
100	= conversion factor	= 100	%
EFF	= Collection QC check (% mass collected in second fraction)	= 0	%

**USEPA Method 26A
 HCl Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 115718
 K_@

1. HCl concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 711.8015	mg
V_{mstd}	= volume metered, standard (dscf)	= 32.2532	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
C_{sd}	= HCl concentration (lb/dscf)	= 4.8663E-05	lb/dscf

2. HCl concentration (ppmdv)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{0.850}{1000} \right) \left(\frac{10^6}{MW} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 711.8015	mg
V_{mstd}	= volume metered, standard (dscf)	= 32.2532	dscf
MW	= molecular weight of HCl (g/g-mole)	= 36.461	g/g-mole
0.850	= conversion factor (dscf/g-mole)	= 0.850	dscf/g-mole
1000	= conversion factor (mg/g)	= 1,000	mg/g
10^6	= conversion factor (ppm)	= 10^6	ppm
C_{sd}	= HCl concentration (ppmdv)	= 514.4898	ppmdv

3. HCl concentration (ppmwv)

$$C_w = C_{sd} \left(1 - \frac{B_w}{100} \right)$$

Where:

C_{sd}	= HCl concentration (ppmdv)	= 514.4898	ppmdv
B_w	= actual water vapor in gas (% v/v)	= 16.9119	% v/v
100	= conversion factor (%)	= 100	%
C_w	= HCl concentration (ppmwv)	= 427.4798	ppmwv

4. HCl concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 711.8015	mg
V_{mstd}	= volume metered, standard (dscf)	= 32.2532	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
C_{sd}	= HCl concentration (mg/dscm)	= 779.2632	mg/dscm

5. HCl concentration (mg/Nm³ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 711.8015	mg
V_{mstd}	= volume metered, standard (dscf)	= 32.2532	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature (°F)	= 68	°F
32	= normal temperature (°F)	= 32	°F
460	= °F to °R conversion constant	= 460	
C_{sd}	= HCl concentration (mg/Nm ³ dry)	= 836.2824	mg/Nm ³ dry

6. HCl concentration corrected to x% O₂ (ppmdv example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= HCl concentration (ppmdv)	= 514.4898	ppmdv
x	= oxygen content of corrected gas (%)	= 7.0	%
O ₂	= proportion of oxygen in the gas stream by volume (%)	= 7.8	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
C_{sdx}	= HCl concentration corrected to x%O ₂ (ppmdv)	= 545.4926	ppmdv @ x%O ₂

7. HCl concentration corrected to y% CO₂ (ppmdv example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= HCl concentration (ppmdv)	= 514.4898	ppmdv
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
CO ₂	= proportion of carbon dioxide in the gas stream by volume (%)	= 11.7	%
C_{sdy}	= HCl concentration corrected to y%CO ₂ (ppmdv)	= 528.5854	ppmdv @ y%CO ₂

8. HCl rate - F_d -based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 711.8015	mg
V_{mstd}	= volume metered, standard (dscf)	= 32.2532	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 7.8	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
E_{Fd}	= HCl rate (lb/MMBtu)	= 7.4242E-01	lb/MMBtu

9. HCl rate - F_c -based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 711.8015	mg
V_{mstd}	= volume metered, standard (dscf)	= 32.2532	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	= 11.7	%
100	= conversion factor	= 100	
E_{Fc}	= HCl rate (lb/MMBtu)	= 7.5827E-01	lb/MMBtu

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

**USEPA Modified Method 26A (HCl)
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 115818

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

V_{lc}	= total volume of liquid collected in impingers and silica gel (ml)	=	226.9	ml
0.04706	= ideal gas conversion factor (ft ³ water vapor/ml or gm)	=	0.04706	ft ³ /ml
V_{wstd}	= volume of water vapor collected at standard conditions (ft ³)	=	10.68	ft ³

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left(P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.20	in. Hg
T_m	= average dry gas meter temperature (°F)	=	72.33	°F
V_m	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	40.47	dcf
Y_d	= gas meter correction factor (dimensionless)	=	0.9916	
ΔH	= average pressure drop across meter box orifice (in. H ₂ O)	=	1.50	in. H ₂ O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg
460	= °F to °R conversion constant	=	460	

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	40.301	dscf
------------	---	---	--------	------

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left(\frac{P_g}{13.6} \right)$$

Where:

P_{bar}	= barometric pressure (in. Hg)	=	30.20	in. Hg
P_g	= sample gas static pressure (in. H ₂ O)	=	-9.70	in. H ₂ O
13.6	= conversion factor (in. H ₂ O/in. Hg)	=	13.6	in. H ₂ O/in. Hg

P_s	= absolute sample gas pressure (in. Hg)	=	29.49	in. Hg
-------	---	---	-------	--------

Wheelabrator North Broward, Inc.
Clean Air Project No: 10735
Unit 1 FF Outlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left(\frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

T_s	= average sample gas temperature (°F)	=	307.25	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
P_v	= vapor pressure, actual (in. Hg)	=	29.49	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.49	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.49	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

V_{mstd}	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	40.301	dscf
V_{wstd}	= volume of water collected at standard conditions (scf)	=	10.68	scf
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2095	
		=	20.95	%

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

P_s	= absolute sample gas pressure (in. Hg)	=	29.49	in. Hg
P_v	= water vapor pressure, actual (in. Hg)	=	29.49	in. Hg
B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	100.00 %

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

B_{ws}	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
B_{wo}	= proportion of water measured in the gas stream by volume	=	0.2095	
B_w	= actual water vapor in gas	=	0.2095	20.95 %

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.7	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	8.9	%
100	= conversion factor (%)	=	100	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.37	%

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2+CO)}{(100)}$$

Where:

M_{CO_2}	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
M_{O_2}	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
M_{N_2+CO}	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
CO_2	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.7	%
O_2	= proportion of oxygen in the gas stream by volume (%)	=	8.9	%
N_2+CO	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.4	%
100	= conversion factor (%)	=	100	%
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.07	lb/lb-mole

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

B_w	= proportion of water vapor in the gas stream by volume	=	0.2095	
M_d	= dry molecular weight of sample gas (lb/lb-mole)	=	30.07	lb/lb-mole
M_{H_2O}	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
M_s	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.54	lb/lb-mole

**USEPA Modified Method 26A
 HCl Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 115818

1. Chloride to HCl conversion factor

$$K_{HCl} = \frac{MW_{HCl}}{n \times MW_{Cl^-}}$$

Where:

MW _{HCl}	= molecular weight of HCl (mg/mg-mole)	=	36.461	mg/mg-mole
MW _{Cl⁻}	= molecular weight of chloride ion (mg/mg-mole)	=	35.453	mg/mg-mole
n	= molar ratio of chloride to HCl	=	1.0	mole Cl/mole HCl
K _{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	=	1.028	

2. Total HCl collected (mg)

$$m_{HCl} = K_{HCl} \times \frac{(S_{Cl-1}v_1 + S_{Cl-2}v_2)}{1000}$$

Where:

K _{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	=	1.028	
S _{Cl-1}	= chloride concentration of sample fraction 1 (mg/liter)	=	37.2000	mg/liter
v ₁	= liquid volume of sample fraction 1 (ml)	=	874.0	ml
S _{Cl-2}	= chloride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v ₂	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m _{HCl}	= total HCl collected in sample (mg)	=	33.4232	mg

Note: Non-detects are treated as zero in summations.

DEFINITION

Fraction 1 = entire sample except last impinger containing applicable absorbing reagent.
 Fraction 2 = last impinger containing applicable absorbing reagent, analyzed separately to evaluate collection efficiency.
 If entire sample is analyzed as a single fraction, then data is included as Fraction 1 (Fraction 2 = 0).

3. Allowable blank subtraction (mg)

$$m_b = K_{HCl} \times B_{Cl} \times \frac{(v_1 + v_2)}{1000}$$

$$m_b = 0 \text{ if } B_{Cl} < MDL$$

Where:

K _{HCl}	= conversion factor to convert mass Cl ⁻ to mass HCl	=	1.0280	
B _{Cl}	= chloride concentration of blank (mg/liter)	=	<0.0	mg/liter
v ₁	= liquid volume of sample fraction 1 (ml)	=	874.0	ml
v ₂	= liquid volume of sample fraction 2 (ml)	=	0	ml
1000	= conversion factor (ml/liter)	=	1000.0000	ml/liter
m _b	= allowable blank subtraction (mg)	=	0.0000	mg

4. Total HCl collected, corrected for blank (mg)

$$m_{nb} = m_{HCl} - m_b$$

Where:

m_{HCl}	= total HCl collected in sample (mg)	=	33.4232	mg
m_b	= allowable blank subtraction (mg)	=	0.0000	mg
m_{nb}	= total HCl collected, corrected for blank (mg)	=	33.4231584	mg

5. Minimum detectable HCl (mg)

$$m_{MDL} = K_{HCl} \times MDL \times \frac{(v_1 + v_2)}{1000}$$

Where:

K_{HCl}	= conversion factor to convert mass Cl^- to mass HCl	=	1.028	
MDL	= minimum detectable chloride concentration	=	0.0	mg/liter
v_1	= liquid volume of sample fraction 1 (ml)	=	874.0	ml
v_2	= liquid volume of sample fraction 2 (ml)	=	0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m_{MDL}	= minimum detectable HCl (mg)	=	0.001796944	mg

6. Total HCl value used in emission calculations (mg)

$$m_n = \text{MAXIMUM} [m_{nb} \text{ or } < m_{MDL}]$$

Where:

m_{nb}	= total HCl collected, corrected for blank (mg)	=	33.4232	mg
m_{MDL}	= minimum detectable HCl (mg)	=	0.001796944	mg
m_n	= total HCl value used in emission calculations (mg)	=	33.4231584	mg

7. Collection QC check (% mass collected in second fraction)

$$EFF = 100 \times \frac{K_{HCl} \times S_{Cl-2} \times \frac{v_2}{1000}}{m_{HCl}}$$

Where:

K_{HCl}	= conversion factor to convert mass Cl^- to mass HCl	=	1.0280	
S_{Cl-2}	= chloride concentration of sample fraction 2 (mg/liter)	=	0.0	mg/liter
v_2	= liquid volume of sample fraction 2 (ml)	=	0.0000	ml
m_{HCl}	= total HCl collected in sample (mg)	=	33	mg
1000	= conversion factor (ml/liter)	=	1000	ml/liter
100	= conversion factor	=	100	%
EFF	= Collection QC check (% mass collected in second fraction)	=	0	%

**USEPA Modified Method 26A
 HCl Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041409 115818
 O_@

1. HCl concentration (lb/dscf)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 33.4232	mg
V_{mstd}	= volume metered, standard (dscf)	= 40.3015	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
C_{sd}	= HCl concentration (lb/dscf)	= 1.8287E-06	lb/dscf

2. HCl concentration (ppmdv)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{0.850}{1000} \right) \left(\frac{10^6}{MW} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 33.4232	mg
V_{mstd}	= volume metered, standard (dscf)	= 40.3015	dscf
MW	= molecular weight of HCl (g/g-mole)	= 36.461	g/g-mole
0.850	= conversion factor (dscf/g-mole)	= 0.850	dscf/g-mole
1000	= conversion factor (mg/g)	= 1,000	mg/g
10^6	= conversion factor (ppm)	= 10^6	ppm
C_{sd}	= HCl concentration (ppmdv)	= 19.3338	ppmdv

3. HCl concentration (ppmwv)

$$C_w = C_{sd} \left(1 - \frac{B_w}{100} \right)$$

Where:

C_{sd}	= HCl concentration (ppmdv)	= 19.3338	ppmdv
B_w	= actual water vapor in gas (% v/v)	= 20.9455	% v/v
100	= conversion factor (%)	= 100	%
C_w	= HCl concentration (ppmwv)	= 15.2842	ppmwv

4. HCl concentration (mg/dscm)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	=	33.4232	mg
V_{mstd}	= volume metered, standard (dscf)	=	40.3015	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
C_{sd}	= HCl concentration (mg/dscm)	=	29.2836	mg/dscm

5. HCl concentration (mg/Nm³ dry)

$$C_{sd} = \left(\frac{m_n}{V_{mstd}} \right) (35.31) \left(\frac{68 + 460}{32 + 460} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	=	33.4232	mg
V_{mstd}	= volume metered, standard (dscf)	=	40.3015	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature (°F)	=	68	°F
32	= normal temperature (°F)	=	32	°F
460	= °F to °R conversion constant	=	460	
C_{sd}	= HCl concentration (mg/Nm ³ dry)	=	31.4263	mg/Nm ³ dry

6. HCl concentration corrected to x% O₂ (ppmdv example)

$$C_{sdx} = C_{sd} \left(\frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

C_{sd}	= HCl concentration (ppmdv)	=	19.3338	ppmdv
x	= oxygen content of corrected gas (%)	=	7.0	%
O ₂	= proportion of oxygen in the gas stream by volume (%)	=	8.9	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
C_{sdx}	= HCl concentration corrected to x%O ₂ (ppmdv)	=	22.3950	ppmdv @ x%O ₂

7. HCl concentration corrected to y% CO₂ (ppmdv example)

$$C_{sdy} = C_{sd} \left(\frac{y}{CO_2} \right)$$

Where:

C_{sd}	= HCl concentration (ppmdv)	=	19.3338	ppmdv
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
CO ₂	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.7	%
C_{sdy}	= HCl concentration corrected to y%CO ₂ (ppmdv)	=	21.6221	ppmdv @ y%CO ₂

8. HCl rate - F_d -based (lb/MMBtu)

$$E_{Fd} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_d) \left(\frac{20.9}{20.9 - O_2} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 33.4232	mg
V_{mstd}	= volume metered, standard (dscf)	= 40.3015	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
F_d	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
O_2	= proportion of oxygen in the gas stream by volume (%)	= 8.9	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
E_{Fd}	= HCl rate (lb/MMBtu)	= 3.0480E-02	lb/MMBtu

9. HCl rate - F_c -based (lb/MMBtu)

$$E_{Fc} = \left(\frac{m_n}{V_{mstd}} \right) \left(\frac{2.205 \times 10^{-3}}{1000} \right) (F_c) \left(\frac{100}{CO_2} \right)$$

Where:

m_n	= total HCl collected, corrected for applicable blank (mg)	= 33.4232	mg
V_{mstd}	= volume metered, standard (dscf)	= 40.3015	dscf
2.205×10^{-3}	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
F_c	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
CO_2	= proportion of oxygen in the gas stream by volume (%)	= 10.7	%
100	= conversion factor	= 100	
E_{Fc}	= HCl rate (lb/MMBtu)	= 3.1017E-02	lb/MMBtu

WHEELABRATOR NORTH BROWARD, INC.
POMPANO BEACH, FL

CleanAir Project No: 10735-2

PLANT DATA

C

This Page Intentionally Left Blank

**WHEELABRATOR NORTH BROWARD
TONS OF REFUSE PROCESSED PER STACK TEST RUN LOG (2009)**

UNIT #1						
Date	Material	Value	Run	Steam (lb/hr)	Run Length (min)	Trash Processed (Tons)
3/12/2009	HCl	26A	1	184.0	1.00	32.9
3/12/2009	HCl	26A	2	183.6	1.00	32.8
3/12/2009	HCl	26A	3	183.8	1.00	32.8
3/10/2009	Particulate/Metals	5/29	1	185.4	2.25	74.5
3/10/2009	Particulate/Metals	5/29	2	183.9	2.20	72.2
3/10/2009	Particulate/Metals	5/29	3	183.7	2.23	73.1
3/12/2009	Fluorides	13B	1	184.6	1.20	39.6
3/12/2009	Fluorides	13B	2	184.1	1.17	38.5
3/12/2009	Fluorides	13B	3	183.7	1.17	38.4
3/10/2009	Dioxins/Furans	23	1	184.0	4.37	143.6
3/11/2009	Dioxins/Furans	23	2	184.5	4.48	147.6
3/11/2009	Dioxins/Furans	23	3	183.6	4.32	141.7
3/12/2009	Dioxins/Furans	23	4	183.9	4.52	148.4

UNIT #2						
Date	Material	Value	Run	Steam (lb/hr)	Run Length (min)	Trash Processed (Tons)
3/10/2009	HCl	26A	1	184.6	1.20	39.6
3/10/2009	HCl	26A	2	183.8	1.00	32.8
3/10/2009	HCl	26A	3	184.1	1.00	32.9
3/12/2009	Particulate/Metals	5/29	1	184.6	2.18	71.8
3/12/2009	Particulate/Metals	5/29	2	183.7	2.37	77.7
3/12/2009	Particulate/Metals	5/29	3	184.3	2.17	71.4
3/11/2009	Fluorides	13B	1	184.4	1.20	39.5
3/11/2009	Fluorides	13B	2	184.0	1.30	42.7
3/11/2009	Fluorides	13B	3	183.5	1.20	39.3
n/a	Dioxins/Furans	23	1	n/a	n/a	n/a
n/a	Dioxins/Furans	23	2	n/a	n/a	n/a
n/a	Dioxins/Furans	23	3	n/a	n/a	n/a

UNIT #3						
Date	Material	Value	Run	Steam (lb/hr)	Run Length (min)	Trash Processed (Tons)
3/11/2009	HCl	26A	1	184.2	1.00	32.9
3/11/2009	HCl	26A	2	182.9	1.00	32.7
3/11/2009	HCl	26A	3	183.9	1.00	32.8
3/11/2009	Particulate/Metals	5/29	1	184.0	2.20	72.3
3/11/2009	Particulate/Metals	5/29	2	184.1	2.23	73.3
3/11/2009	Particulate/Metals	5/29	3	184.0	2.20	72.3
3/10/2009	Fluorides	13B	1	184.8	1.25	41.3
3/10/2009	Fluorides	13B	2	184.6	1.30	42.9
3/10/2009	Fluorides	13B	3	183.9	1.23	40.4
n/a	Dioxins/Furans	23	1	n/a	n/a	n/a
n/a	Dioxins/Furans	23	2	n/a	n/a	n/a
n/a	Dioxins/Furans	23	3	n/a	n/a	n/a

Metals: Cd (cadmium) Hg (mercury) Be (beryllium) Pb (lead)

Stack Test Process Data

PLANT NAME: NORTH BROWARD 2009						Data from DCS Printouts						Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCI	1	1	3/12/2009	0636	0736	184.0	319.9	6.3	522.9	38.7	31.9	6.8	15.8	1.098	1.028	420.7	All times based on CEMS time Bailey time = CEMS time
		2	3/12/2009	0825	0925	183.6	317.0	6.2	525.7	39.8	33.0	6.8	23.2	1.098	1.028	422.0	
		3	3/12/2009	1010	1110	183.8	320.1	6.3	527.3	40.1	31.4	8.7	25.0	1.098	1.028	538.0	
		Avg				183.8	319.0	6.3	525.3	39.5	32.1	7.5	21.3	1.098	1.028	460.2	
M-29/5 Metals PM	1	1	3/10/2009	0648	0903	185.4	319.6	6.3	521.2	36.5	29.3	7.2	16.3	1.102	1.070	461.6	All times based on CEMS time Bailey time = CEMS time
		2	3/10/2009	0925	1137	183.9	320.1	6.3	527.7	38.7	31.7	7.0	15.5	1.102	1.070	448.8	
		3	3/10/2009	1159	1413	183.7	320.1	6.2	531.4	39.4	32.0	7.4	15.4	1.101	1.060	470.6	
		Avg				184.3	319.9	6.3	526.8	38.2	31.0	7.2	15.7	1.102	1.067	460.3	
M-23 dioxins	1	1	3/10/2009	1008	1430	184.0	319.9	6.2	530.3	39.0	31.8	7.3	15.5	1.101	1.060	461.7	All times based on CEMS time Bailey time = CEMS time Run 2 excluded due to broken XAD-trap during sample recovery
		2	3/11/2009	0626	1105	184.5	321.7	6.3	521.9	38.5	29.6	8.9	16.1	1.098	1.028	547.8	
		3	3/11/2009	1126	1545	183.6	320.1	6.3	528.9	40.5	32.6	7.9	15.4	1.097	1.017	481.6	
		4	3/12/2009	0642	1113	183.9	319.0	6.3	525.3	39.4	32.2	7.2	20.9	1.098	1.028	442.3	
Avg				184.0	320.2	6.3	526.6	39.4	31.6	7.8	16.9	1.099	1.033	483.4			
M-13B HF	1	1	3/12/2009	1147	1259	184.6	319.4	6.2	522.6	37.2	31.2	6.0	15.7	1.099	1.039	374.7	All times based on CEMS time Bailey time = CEMS time
		2	3/12/2009	1309	1419	184.1	320.4	6.4	523.4	37.2	30.5	6.7	15.8	1.099	1.039	418.3	
		3	3/12/2009	1433	1543	183.7	320.4	6.3	530.0	39.6	32.8	6.8	15.0	1.097	1.017	418.1	
		Avg				184.1	320.1	6.3	525.3	38.0	31.5	6.5	15.5	1.098	1.032	403.7	

C-4

Stack Test Process Data

PLANT NAME: NORTH BROWARD 2009						Data From DCS Printouts						Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCl	2	1	3/10/2009	0651	0803	184.6	319.4	6.4	498.8	35.6	32.4	3.2	16.9	1.102	1.070	202.2	All times based on CEMS time Bailey time = CEMS time
		2	3/10/2009	0838	0938	183.8	321.5	6.5	511.2	40.0	34.4	5.6	16.3	1.102	1.070	361.4	
		3	3/10/2009	1004	1104	184.1	319.6	6.4	511.4	38.9	34.3	4.7	18.5	1.102	1.070	299.8	
		Avg				184.2	320.1	6.4	507.2	38.2	33.7	4.5	17.2	1.102	1.070	287.8	
M-29/5 Metals PM	2	1	3/12/2009	0629	0840	184.6	320.0	6.5	501.8	36.6	32.2	4.4	20.1	1.098	1.028	269.6	All times based on CEMS time Bailey time = CEMS time
		2	3/12/2009	0858	1120	183.7	319.8	6.5	503.3	35.7	31.6	4.1	18.0	1.098	1.028	252.3	
		3	3/12/2009	1139	1349	184.3	320.1	6.5	508.5	36.8	32.9	3.9	17.0	1.099	1.039	241.9	
		Avg				184.2	320.0	6.5	504.5	36.4	32.3	4.1	18.4	1.098	1.032	254.6	
M-13B HF	2	1	3/11/2009	0730	0848	184.4	329.8	6.5	500.0	34.6	24.9	9.8	24.7	1.098	1.028	602.1	All times based on CEMS time Bailey time = CEMS time
		2	3/11/2009	1128	1246	184.0	319.8	6.4	512.4	38.8	32.8	6.0	19.0	1.097	1.017	366.8	
		3	3/11/2009	1312	1424	183.5	320.2	6.6	516.9	40.6	32.9	7.7	18.4	1.097	1.017	468.8	
		Avg				184.0	323.3	6.5	509.8	38.0	30.2	7.8	20.7	1.097	1.021	479.2	

G-C

Stack Test Process Data

PLANT NAME: NORTH BROWARD 2009						Data From DCS Printouts						Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCI	3	1	3/11/2009	0657	0757	184.2	321.4	6.3	510.0	33.0	23.1	10.0	20.1	1.098	1.028	614.5	All times based on CEMS time Bailey time = CEMS time
		2	3/11/2009	0829	0929	182.9	320.6	6.0	518.1	36.1	30.1	6.0	15.6	1.098	1.028	371.4	
		3	3/11/2009	1002	1102	183.9	319.7	5.7	520.3	36.7	32.1	4.6	15.6	1.098	1.028	284.4	
		Avg				183.7	320.6	6.0	516.1	35.3	28.4	6.9	17.1	1.098	1.028	423.4	
M-29/5 Metals PM	3	1	3/11/2009	0646	0858	184.0	320.9	6.2	511.5	33.9	25.6	8.3	18.6	1.098	1.028	510.8	All times based on CEMS time Bailey time = CEMS time
		2	3/11/2009	0924	1138	184.1	319.8	6.0	520.4	36.6	31.9	4.7	15.9	1.098	1.028	288.7	
		3	3/11/2009	1158	1410	184.0	320.2	6.1	515.1	34.4	28.6	5.8	18.1	1.097	1.017	354.0	
		Avg				184.0	320.3	6.1	515.7	34.9	28.7	6.3	17.5	1.098	1.025	384.5	
M-13B HF	3	1	3/10/2009	0817	0932	184.8	319.9	6.0	524.1	37.2	31.6	5.6	16.5	1.102	1.070	361.4	All times based on CEMS time Bailey time = CEMS time
		2	3/10/2009	1131	1249	184.6	319.8	6.0	518.6	34.5	28.6	5.9	17.4	1.101	1.060	377.8	
		3	3/10/2009	1316	1430	183.9	320.1	6.1	518.2	34.0	26.5	7.5	17.5	1.101	1.060	477.0	
		Avg				184.4	319.9	6.0	520.3	35.2	28.9	6.4	17.1	1.101	1.063	405.4	

C - 6

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/10/09
 Start Time: 6:48
 End Time: 9:03

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1 5/29 run 1	521.16	319.59	36.49	29.30	7.19	16.29	306.07	6.26	-9.41
Unit 2	501.61	320.12	36.69	32.51	4.18	17.55	0.00	6.42	-11.31
Unit 3	523.03	320.18	36.48	31.51	4.97	16.28	309.02	6.13	-8.27

C-7

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	187.31	896.13	831.99	79.02	-0.09	273.32	1211.89	2.85	185.38
Unit 2	186.77	893.27	829.24	78.24	-0.10	273.72	1207.92	4.44	184.60
Unit 3	189.70	897.60	825.68	80.48	-0.09	280.03	1093.80	8.26	184.17

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/10/09
Start Time: 9:25
End Time: 11:37

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

		DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	5/29 run 2	527.74	320.11	38.69	31.70	6.99	15.53	306.33	6.26	-9.43
Unit 2		512.08	319.97	39.41	34.58	4.83	17.38	0.00	6.39	-11.37
Unit 3		521.88	319.90	35.48	28.40	7.08	16.85	308.08	6.02	-7.96

C-8

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	186.02	894.37	831.61	80.87	-0.10	273.27	1208.11	2.54	183.89
Unit 2	185.06	891.72	829.77	81.68	-0.10	273.67	1201.04	5.39	182.62
Unit 3	191.05	896.83	832.92	80.12	-0.09	279.97	1096.62	7.83	184.21

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/10/09
 Start Time: 11:59
 End Time: 14:13

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

		DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	5/29 run 3	531.36	320.08	39.39	31.99	7.40	15.36	306.24	6.23	-9.36
Unit 2		507.83	319.95	35.84	30.74	5.10	20.08	0.00	6.43	-11.04
Unit 3		517.87	319.93	33.99	27.48	6.51	17.59	308.16	6.03	-7.69

C - 9

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.19	894.32	829.03	83.29	-0.10	273.50	1216.49	2.53	183.68
Unit 2	186.66	891.37	828.95	76.80	-0.11	273.89	1212.81	3.24	184.45
Unit 3	190.30	896.04	828.34	78.30	-0.08	280.15	1095.99	8.94	184.17

Reporting Period: 03/10/2009 to 03/10/2009

Site Name: UNIT1
Data Averaging Type: 6m

Time of Report: 03/10/09 15:03
Rolling Average Interval: 1

Date	Time	OPACITY1 (PERCENT)
03/10/09	06:48	0
	06:54	0
	07:00	0
	07:06	0
	07:12	0
	07:18	0
	07:24	0
	07:30	0
	07:36	0
	07:42	0
	07:48	0
	07:54	0
	08:00	0
	08:06	0
	08:12	0
	08:18	0
	08:24	0
	08:30	0
	08:36	0
	08:42	0
	08:48	0
	08:54	0
	09:00	0

Average = 0
Geometric Avg. =
Maximum = 0
Minimum = 0
Possible Values = 23
Included Values = 23
Total = 0

* - excluded values (missing, OOC, invalid, suspect)
< - missing
T - out-of-control
I - invalid
S - suspect
H - exceedance
F - stack not operating
B - invalid (PADER)
U - missing data substituted
-999 - missing value
-888 - value could not be calculated

Reporting Period: 03/10/2009 to 03/10/2009

Site Name: UNIT1
Data Averaging Type: 6m

Time of Report: 03/10/09 15:03
Rolling Average Interval: 1

Date	Time	OPACITY1 (PERCENT)
03/10/09	09:24	0
	09:30	0
	09:36	0
	09:42	0
	09:48	0
	09:54	0
	10:00	0
	10:06	0
	10:12	0
	10:18	0
	10:24	0
	10:30	0
	10:36	0
	10:42	0
	10:48	0
	10:54	0
	11:00	0
	11:06	0
	11:12	0
	11:18	0
	11:24	0
	11:30	0
	11:36	0

Average = 0
Geometric Avg. =
Maximum = 0
Minimum = 0
Possible Values = 23
Included Values = 23
Total = 0

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

Reporting Period: 03/10/2009 to 03/10/2009

Site Name: UNIT1
Data Averaging Type: 6m

Time of Report: 03/10/09 15:03
Rolling Average Interval: 1

Date	Time	OPACITY1 (PERCENT)
03/10/09	11:54	0
	12:00	0
	12:06	0
	12:12	0
	12:18	0
	12:24	0
	12:30	0
	12:36	0
	12:42	0
	12:48	0
	12:54	0
	13:00	0
	13:06	0
	13:12	0
	13:18	0
	13:24	0
	13:30	0
	13:36	0
	13:42	0
	13:48	0
	13:54	0
	14:00	0
	14:06	0
	14:12	0

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	24
Included Values =	24
Total =	0

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/12/09
Start Time: 11:47
End Time: 12:59

SDA INLET TEMP	SDA OUTLET 0:00	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1 13B run 1	522.56	319.39	37.17	31.16	6.00	15.67	303.68	6.22	-9.33
Unit 2	508.79	320.27	37.32	33.62	3.71	16.72	0.00	6.50	-11.18
Unit 3	524.38	319.92	37.63	28.69	8.95	16.58	308.54	6.04	-8.46

C-13

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	186.13	894.52	828.20	78.21	-0.10	273.20	1237.49	2.54	184.62
Unit 2	186.12	891.35	827.90	78.18	-0.10	273.66	1209.83	5.08	183.92
Unit 3	190.27	895.92	823.86	84.40	-0.11	279.83	1155.80	3.07	183.54

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/12/09
Start Time: 13:09
End Time: 14:19

SDA INLET TEMP	SDA OUTLET 0:00	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

		DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	13B run 2	523.37	320.41	37.21	30.50	6.71	15.81	304.35	6.40	-9.45
Unit 2		512.23	320.75	38.17	33.13	5.03	16.54	0.00	6.51	-11.24
Unit 3		531.05	320.16	39.71	34.56	5.15	15.84	309.21	6.15	-8.64

C - 14

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.77	894.09	827.63	79.68	-0.10	273.31	1244.23	2.53	184.11
Unit 2	186.99	891.24	827.61	75.94	-0.08	273.67	1212.46	6.81	184.34
Unit 3	189.70	895.54	820.70	86.29	-0.10	279.84	1163.02	4.88	183.41

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/12/09
Start Time: 14:33
End Time: 15:43

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF-OUT TEMP	FF DP	SID INLET PRESS
-------------------	--------------------	----------------------	-------------------	---------------	--------------	----------------	----------	--------------------

		DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	13B run 3	530.02	320.36	39.62	32.77	6.85	14.96	305.53	6.27	-9.48
Unit 2		519.82	320.61	41.45	35.05	6.40	14.93	0.00	6.57	-11.51
Unit 3		525.48	319.66	37.03	31.31	5.72	16.71	308.60	5.97	-8.24

C - 15

FEED H2O FLOW	SH-OUT STM PRESS	FINAL-STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT-TEMP	SH-ROLL AVG	SNGR CHEM-FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	185.98	894.44	828.40	82.75	-0.09	273.57	1248.14	2.53	183.69
Unit 2	186.53	891.09	827.53	77.44	-0.09	273.91	1214.52	3.53	183.53
Unit 3	192.94	896.13	825.66	81.80	-0.09	280.04	1173.57	6.40	185.10

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/10/09
 Start Time: 10:08
 End Time: 14:30

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
----------------	-----------------	-------------------	----------------	------------	-----------	-------------	-------	----------------

		DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	23 run 1	530.28	319.85	39.04	31.78	7.26	15.46	306.11	6.23	-9.35
Unit 2		510.00	319.82	37.24	32.23	5.01	19.36	0.00	6.42	-11.17
Unit 3		519.80	319.95	34.62	28.15	6.48	17.27	308.22	6.02	-7.77

C-16

FEED H2O FLOW	SH OUT SIFM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
---------------	-------------------	----------------	--------------	---------------	----------------	-------------	----------------	------------

		KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1		185.63	894.42	829.20	82.30	-0.10	273.47	1215.35	2.53	183.98
Unit 2		187.31	891.72	830.74	78.54	-0.10	273.86	1211.30	4.31	184.39
Unit 3		190.53	896.38	830.23	78.98	-0.09	280.14	1095.97	8.75	184.20

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/11/09
Start Time: 6:26
End Time: 11:05

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONG	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

		DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	23 run 2	521.92	321.72	38.52	29.64	8.88	16.06	307.50	6.29	-9.64
Unit 2		501.19	323.53	35.90	27.71	8.19	21.63	0.00	6.48	-11.09
Unit 3		515.97	320.45	35.43	28.65	6.78	17.07	307.64	6.02	-9.23

C - 17

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	185.48	895.08	828.11	83.13	-0.10	272.95	1174.83	2.55	184.48
Unit 2	186.88	892.26	829.02	78.49	-0.09	273.44	1199.69	3.90	183.93
Unit 3	190.23	897.22	830.13	79.93	-0.10	279.59	1126.33	3.49	183.80

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/11/09
 Start Time: 11:26
 End Time: 15:45

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1 23 run 3	528.89	320.12	40.52	32.63	7.89	15.38	305.52	6.30	-9.62
Unit 2	514.40	319.93	39.32	32.26	7.06	19.04	0.00	6.49	-11.19
Unit 3	515.56	320.00	34.66	28.68	5.98	17.98	307.39	6.05	-8.90

C-18

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.07	893.98	828.94	85.69	-0.10	273.11	1189.12	2.52	183.64
Unit 2	187.05	890.92	828.91	80.09	-0.10	273.55	1210.10	4.62	183.89
Unit 3	190.89	895.87	828.07	77.14	-0.10	279.75	1135.27	5.63	184.24

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/12/09
Start Time: 6:42
End Time: 11:13

	SDA INLET TEMP	SDA OUTLET 0:00	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1 23 run 4	525.32	319.04	39.38	32.21	7.18	20.86	304.31	6.29	-9.78
Unit 2	502.93	319.99	36.32	32.10	4.22	18.98	0.00	6.46	-11.13
Unit 3	515.37	320.23	34.09	27.82	6.26	18.04	307.72	6.11	-8.43

C - 19

	FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.41	894.35	829.16	81.82	-0.10	273.14	1221.07	2.52	183.90
Unit 2	186.62	891.76	830.09	77.53	-0.10	273.61	1204.56	3.94	184.09
Unit 3	190.19	896.28	825.49	79.46	-0.10	279.75	1129.39	3.47	183.62

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/12/09
Start Time: 6:36
End Time: 7:36

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1 26A run 1	522.89	319.94	38.70	31.88	6.81	15.80	305.28	6.29	-9.84
Unit 2	502.43	319.49	37.06	32.71	4.35	19.76	0.00	6.46	-11.28
Unit 3	507.49	320.21	31.99	25.92	6.07	19.16	307.26	6.16	-8.42

C - 20

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	185.44	894.72	827.79	81.48	-0.09	273.25	1222.09	2.51	184.02
Unit 2	186.64	892.02	827.62	80.29	-0.08	273.81	1196.15	5.06	184.25
Unit 3	190.58	896.92	829.21	75.84	-0.11	279.84	1116.49	3.49	183.78

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/12/09
Start Time: 8:25
End Time: 9:25

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FE DP	ID INLET PRESS
	0.00							

		DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	26A run 2	525.67	317.00	39.84	33.00	6.84	23.16	302.81	6.19	-9.71
Unit 2		505.26	319.99	37.61	33.32	4.30	19.63	0.00	6.41	-11.18
Unit 3		516.41	320.22	34.39	29.61	4.78	17.81	307.97	6.05	-8.41

C-21

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	184.53	893.89	826.54	82.03	-0.11	273.08	1222.96	2.53	183.62
Unit 2	187.26	891.55	831.41	75.74	-0.10	273.54	1198.73	3.68	184.39
Unit 3	189.34	896.00	825.91	79.89	-0.10	279.69	1124.10	4.07	183.43

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/12/09
 Start Time: 10:10
 End Time: 11:10

SDA INLET TEMP	SDA-OUTLET 0:00	TOTAL SLURRY FLOW	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	----------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1 26A run 3	527.28	320.10	40.07	31.35	8.72	25.04	304.66	6.31	-9.78
Unit 2	503.90	320.34	35.66	31.76	3.90	17.27	0.00	6.55	-11.14
Unit 3	522.79	320.55	36.26	27.84	8.42	16.98	307.84	5.99	-8.40

C - 22

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.41	894.12	829.11	82.45	-0.10	273.14	1221.75	2.52	183.78
Unit 2	185.92	891.36	829.60	77.96	-0.09	273.56	1205.72	3.71	183.53
Unit 3	189.26	895.66	821.39	83.32	-0.10	279.80	1142.41	2.70	183.03

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/12/09
Start Time: 6:29
End Time: 8:40

SDA INLET TEMP	SDA OUTLET 0:00	TOTAL SLURRY FL	DIE WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	522.97	318.99	38.78	32.59	6.19	17.11	304.81	6.27	-9.78
Unit 2 5/29 run 1	501.82	320.02	36.60	32.23	4.37	20.08	0.00	6.45	-11.20
Unit 3	509.35	320.10	32.44	26.95	5.49	18.89	307.29	6.20	-8.44

C-23

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.48	894.77	829.53	81.21	-0.10	273.27	1221.67	2.52	184.10
Unit 2	186.72	892.12	828.99	78.60	-0.09	273.79	1204.19	4.29	184.56
Unit 3	190.81	896.80	826.90	76.63	-0.10	279.85	1123.56	3.85	184.01

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/12/09
Start Time: 8:58
End Time: 11:20

SDA INLET TEMP	SDA OUTLET 0:00	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	527.58	319.71	39.88	31.91	7.98	23.27	304.27	6.31	-9.79
Unit 2 5/29 run 2	503.31	319.80	35.72	31.63	4.09	17.98	0.00	6.45	-11.02
Unit 3	520.08	320.23	35.41	27.73	7.68	17.40	307.98	6.10	-8.45

C - 24

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.27	894.14	829.38	82.49	-0.10	272.99	1218.68	2.52	183.71
Unit 2	186.46	891.53	831.48	77.13	-0.10	273.42	1202.98	3.75	183.70
Unit 3	190.09	895.93	823.29	81.53	-0.10	279.62	1137.34	3.11	183.56

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/12/09
Start Time: 11:39
End Time: 13:49

SDA INLET TEMP	SDA OUTLET	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME GONG	FF OUT TEMP	FF DP	ID INLET PRESS
----------------	------------	-----------------	----------------	------------	-----------	-------------	-------	----------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	522.60	319.54	36.96	31.08	5.88	15.80	303.78	6.27	-9.34
Unit 2	508.46	320.07	36.81	32.93	3.88	17.02	0.00	6.46	-11.08
Unit 3	526.98	320.13	38.52	30.76	7.76	16.26	308.82	6.11	-8.58

C-25

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
---------------	------------------	----------------	--------------	---------------	----------------	-------------	----------------	------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	186.22	894.45	828.76	78.02	-0.10	273.23	1238.89	2.54	184.59
Unit 2	186.97	891.47	829.03	77.02	-0.10	273.64	1210.42	5.51	184.26
Unit 3	189.80	895.75	822.09	85.33	-0.10	279.83	1156.31	3.51	183.28

Site Name: UNIT2
Data Averaging Type: 6m

Reporting Period: 03/12/2009 to 03/12/2009

Time of Report: 03/12/09 14:28
Rolling Average Interval: 1

Date	Time	OPACITY2 (PERCENT)
03/12/09	06:24	0
	06:30	0
	06:36	0
	06:42	0
	06:48	0
	06:54	0
	07:00	0
	07:06	0
	07:12	0
	07:18	0
	07:24	0
	07:30	0
	07:36	0
	07:42	0
	07:48	0
	07:54	0
	08:00	0
	08:06	0
	08:12	0
	08:18	0
	08:24	0
	08:30	0
	08:36	0

Average = 0
Geometric Avg. =
Maximum = 0
Minimum = 0
Possible Values = 23
Included Values = 23
Total = 0

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

General Average Report

Reporting Period: 03/12/2009 to 03/12/2009

Site Name: UNIT2

Data Averaging Type: 6m

Time of Report: 03/12/09 14:28

Rolling Average Interval: 1

Date	Time	OPACITY2 (PERCENT)
03/12/09	08:54	0
	09:00	0
	09:06	0
	09:12	0
	09:18	0
	09:24	0
	09:30	0
	09:36	0
	09:42	0
	09:48	0
	09:54	0
	10:00	0
	10:06	0
	10:12	0
	10:18	0
	10:24	0
	10:30	0
	10:36	0
	10:42	0
	10:48	0
	10:54	0
	11:00	0
	11:06	0
	11:12	0
	11:18	0

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	25
Included Values =	25
Total =	0

* - excluded values (missing, OOC, invalid, suspect)
 < - missing
 T - out-of-control
 I - invalid
 S - suspect
 H - exceedance
 F - stack not operating
 B - invalid (PADER)
 U - missing data substituted
 -999 - missing value
 -888 - value could not be calculated

Plant Name: NBWD
General Average Report

Reporting Period: 03/12/2009 to 03/12/2009

Site Name: UNIT2
Data Averaging Type: 6m

Time of Report: 03/12/09 14:29
Rolling Average Interval: 1

Date	Time	OPACITY2 (PERCENT)
03/12/09	11:36	0
	11:42	0
	11:48	0
	11:54	0
	12:00	0
	12:06	0
	12:12	0
	12:18	0
	12:24	0
	12:30	0
	12:36	0
	12:42	0
	12:48	0
	12:54	0
	13:00	0
	13:06	0
	13:12	0
	13:18	0
	13:24	0
	13:30	0
	13:36	0
	13:42	0
	13:48	0

Average = 0
Geometric Avg. =
Maximum = 0
Minimum = 0
Possible Values = 23
Included Values = 23
Total = 0

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/11/09
Start Time: 7:30
End Time: 8:48

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	520.47	319.86	38.22	29.29	8.93	15.81	306.98	6.25	-9.58
Unit 2 13B run 1	499.97	329.77	34.64	24.88	9.76	24.72	0.00	6.52	-11.22
Unit 3	511.76	320.14	34.13	27.36	6.77	17.41	307.46	6.11	-9.23

C - 29

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	186.42	896.10	833.40	82.20	-0.10	273.21	1168.80	2.56	184.84
Unit 2	187.69	893.23	833.00	78.17	-0.10	273.72	1204.68	3.52	184.37
Unit 3	190.08	897.87	829.41	78.01	-0.10	279.79	1123.72	3.17	183.97

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/11/09
Start Time: 11:28
End Time: 12:46

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	524.51	320.11	39.00	30.28	8.71	15.75	304.83	6.40	-9.62
Unit 2 13B run 2	512.42	319.80	38.82	32.81	6.01	19.02	0.00	6.40	-10.85
Unit 3	512.39	319.69	33.08	27.64	5.45	18.59	307.16	6.06	-8.91

C-30

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	186.02	894.68	832.61	84.53	-0.09	273.55	1176.27	2.53	184.21
Unit 2	187.34	891.83	830.67	79.90	-0.10	273.99	1205.64	5.26	184.02
Unit 3	191.82	896.92	829.77	75.45	-0.10	280.25	1139.91	6.96	185.33

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/11/09
 Start Time: 13:12
 End Time: 14:24

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	----------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	529.05	319.94	40.37	33.00	7.37	15.44	305.54	6.29	-9.60
Unit 2 13B run 3	516.91	320.22	40.62	32.94	7.68	18.39	0.00	6.58	-11.50
Unit 3	517.35	320.11	35.52	29.93	5.60	17.54	307.52	6.06	-8.92

C-31

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	184.84	893.42	828.18	85.43	-0.09	272.37	1192.83	2.52	183.48
Unit 2	186.62	890.25	828.91	81.35	-0.10	272.82	1202.93	4.54	183.51
Unit 3	190.13	895.34	829.42	78.17	-0.10	278.96	1127.78	5.30	183.53

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/10/09
 Start Time: 6:51
 End Time: 8:03

SDA INLET TEMP	SDA-OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF-OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	521.32	319.54	37.11	29.60	7.52	15.98	306.32	6.20	-9.40
Unit 2 26A run 1	498.83	319.37	35.59	32.44	3.15	16.93	0.00	6.38	-11.17
Unit 3	521.25	320.30	35.65	30.37	5.29	16.65	309.14	6.12	-8.20

C - 32

FEED H2O FLOW	SH-OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH-ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	187.14	896.36	832.60	81.43	-0.08	273.21	1216.71	2.92	185.26
Unit 2	187.32	893.53	832.63	76.21	-0.09	273.58	1211.54	4.72	184.58
Unit 3	189.45	897.73	826.31	80.20	-0.09	279.90	1088.42	7.52	183.98

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/10/09
Start Time: 8:38
End Time: 9:38

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	522.01	320.25	36.26	29.41	6.85	16.40	305.80	6.42	-9.52
Unit 2 26A run 2	511.24	321.46	40.01	34.38	5.63	16.25	0.00	6.45	-11.54
Unit 3	522.78	319.50	36.64	30.42	6.23	16.22	308.20	6.00	-8.11

C-33

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	186.74	895.39	831.52	77.12	-0.10	273.47	1205.27	2.59	184.76
Unit 2	186.27	892.86	829.41	83.23	-0.11	273.93	1207.63	4.06	183.81
Unit 3	190.94	897.60	827.77	79.87	-0.10	280.18	1103.43	9.36	185.13

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/10/09
Start Time: 10:04
End Time: 11:04

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONG	FF OUT TEMP	FF DP	ID INLET PRESS
	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	529.06	319.58	39.08	32.02	7.05	15.39	306.29	6.16	-9.32
Unit 2 26A run 3	511.40	319.60	38.93	34.26	4.67	18.47	0.00	6.40	-11.33
Unit 3	522.49	319.76	35.54	28.72	6.82	16.84	308.10	5.88	-7.82

C - 34

	FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	186.73	894.39	829.52	80.04	-0.10	273.36	1211.30	2.56	184.36
Unit 2	187.24	892.08	830.28	80.69	-0.10	273.72	1201.32	5.67	184.11
Unit 3	190.57	896.82	831.46	80.20	-0.09	280.03	1091.70	7.32	184.25

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/11/09
 Start Time: 6:46
 End Time: 8:58

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONG	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	520.77	321.90	38.17	29.21	8.96	16.19	308.61	6.32	-9.70
Unit 2	498.63	327.32	34.79	25.79	9.00	23.66	0.00	6.46	-11.16
Unit 3 5/29 run 1	511.50	320.91	33.89	25.61	8.28	18.60	307.50	6.15	-9.26

C - 35

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.90	895.75	832.18	82.96	-0.10	272.90	1166.75	2.56	184.43
Unit 2	186.93	892.63	829.44	78.30	-0.09	273.42	1200.05	3.48	184.26
Unit 3	190.19	897.57	829.00	77.94	-0.10	279.52	1122.81	3.26	184.00

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/11/09
 Start Time: 9:24
 End Time: 11:38

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	523.65	319.98	39.14	31.12	8.02	15.52	305.38	6.26	-9.55
Unit 2	507.43	320.27	38.14	30.97	7.16	19.16	0.00	6.61	-11.07
Unit 3 5/29 run 2	520.38	319.79	36.56	31.88	4.68	15.90	307.65	6.03	-9.20

C - 36

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	184.52	894.23	825.56	84.25	-0.10	273.01	1192.00	2.54	183.98
Unit 2	186.56	891.83	829.81	79.67	-0.09	273.40	1200.73	4.90	183.51
Unit 3	190.67	896.82	830.14	81.27	-0.10	279.66	1134.36	4.42	184.10

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/11/09
Start Time: 11:58
End Time: 14:10

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	527.42	320.09	39.94	31.29	8.65	15.59	305.27	6.34	-9.62
Unit 2	514.64	320.22	39.70	33.23	6.48	18.83	0.00	6.51	-11.32
Unit 3	515.08	320.15	34.37	28.57	5.80	18.13	307.42	6.05	-8.86

C-37

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	185.29	893.70	828.91	85.20	-0.10	272.90	1183.75	2.52	183.81
Unit 2	186.69	890.66	828.02	80.53	-0.09	273.37	1203.83	5.03	183.72
Unit 3	190.41	895.66	827.78	77.25	-0.10	279.56	1136.47	5.05	183.95

Reporting Period: 03/11/2009 to 03/11/2009

Site Name: UNIT3
Data Averaging Type: 6m

Time of Report: 03/12/09 05:34
Rolling Average Interval: 1

Date	Time	OPACITY3 (PERCENT)
03/11/09	06:42	0
	06:48	0
	06:54	0
	07:00	0
	07:06	0
	07:12	0
	07:18	0
	07:24	0
	07:30	0
	07:36	0
	07:42	0
	07:48	0
	07:54	0
	08:00	0
	08:06	0
	08:12	0
	08:18	0
	08:24	0
	08:30	0
	08:36	0
	08:42	0
	08:48	0
	08:54	0

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	23
Included Values =	23
Total =	0

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (FADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

Reporting Period: 03/11/2009 to 03/11/2009

Site Name: UNIT3
Data Averaging Type: 6m

Time of Report: 03/12/09 05:34
Rolling Average Interval: 1

Date	Time	OPACITY3 (PERCENT)
03/11/09	09:24	0
	09:30	0
	09:36	0
	09:42	0
	09:48	0
	09:54	0
	10:00	0
	10:06	0
	10:12	0
	10:18	0
	10:24	0
	10:30	0
	10:36	0
	10:42	0
	10:48	0
	10:54	0
	11:00	0
	11:06	0
	11:12	0
	11:18	0
	11:24	0
	11:30	0
	11:36	0

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	23
Included Values =	23
Total =	0

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

Reporting Period: 03/11/2009 to 03/11/2009

Site Name: UNIT3
Data Averaging Type: 6m

Time of Report: 03/12/09 05:35
Rolling Average Interval: 1

Date	Time	OPACITY3 (PERCENT)
03/11/09	11:54	0
	12:00	0
	12:06	0
	12:12	0
	12:18	0
	12:24	0
	12:30	0
	12:36	0
	12:42	0
	12:48	0
	12:54	0
	13:00	0
	13:06	0
	13:12	0
	13:18	0
	13:24	0
	13:30	0
	13:36	0
	13:42	0
	13:48	0
	13:54	0
	14:00	0
	14:06	0

Average = 0
Geometric Avg. =
Maximum = 0
Minimum = 0
Possible Values = 23
Included Values = 23
Total = 0

- * - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/10/09
Start Time: 8:17
End Time: 9:32

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SEURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	521.50	320.10	36.00	29.21	6.78	16.51	305.76	6.37	-9.46
Unit 2	509.50	321.90	39.40	33.87	5.53	17.02	0.00	6.46	-11.56
Unit 3 13B run 1	524.10	319.85	37.20	31.57	5.64	15.96	308.56	6.03	-8.19

C-41

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	186.92	895.54	830.41	76.60	-0.10	273.45	1206.21	2.66	185.13
Unit 2	185.96	892.96	827.86	82.73	-0.11	273.90	1205.64	4.11	184.36
Unit 3	190.51	897.54	826.56	80.42	-0.10	280.17	1102.14	9.27	184.80

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/10/09
 Start Time: 11:31
 End Time: 12:49

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	TOTAL LIME	LIME CONC	FEED OUT TEMP	FEED DP	ID INLET PRESS
-------------------	--------------------	----------------------	-------------------	---------------	--------------	------------------	------------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	529.43	320.04	38.90	31.38	7.51	15.56	306.08	6.20	-9.31
Unit 2	509.61	319.23	36.97	31.92	5.05	19.54	0.00	6.46	-11.16
Unit 3 13B run 2	518.57	319.81	34.50	28.56	5.94	17.38	308.40	5.96	-7.65

C - 42

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH RO AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	--------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.86	894.46	827.72	82.31	-0.11	273.59	1211.57	2.54	184.11
Unit 2	187.60	891.91	831.69	77.75	-0.11	273.98	1214.43	4.19	184.70
Unit 3	191.10	896.59	830.80	78.44	-0.09	280.24	1098.08	10.16	184.60

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/10/09
Start Time: 13:16
End Time: 14:30

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	532.91	319.77	39.57	32.68	6.89	15.23	306.10	6.21	-9.33
Unit 2	509.99	320.72	36.68	31.54	5.14	19.52	0.00	6.47	-11.20
Unit 3 13B run 3	518.24	320.06	33.97	26.47	7.50	17.51	308.18	6.13	-7.80

C-43

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	184.83	894.42	831.34	83.55	-0.11	273.30	1222.37	2.53	183.69
Unit 2	185.40	890.95	827.77	78.76	-0.09	273.68	1209.06	3.15	183.86
Unit 3	189.43	895.58	825.01	78.38	-0.08	279.95	1098.40	8.26	183.91

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/11/09
Start Time: 6:57
End Time: 7:57

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIC WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	520.73	321.57	38.82	28.44	10.39	15.80	309.79	6.33	-9.76
Unit 2	496.70	330.94	32.27	25.31	6.96	28.26	0.00	6.42	-11.22
Unit 3 26A run 1	510.01	321.36	33.01	23.05	9.96	20.14	307.43	6.29	-9.37

C - 44

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	185.64	895.67	833.92	84.33	-0.10	272.56	1168.46	2.55	183.99
Unit 2	186.27	892.24	828.81	78.82	-0.11	273.05	1196.72	3.34	183.61
Unit 3	189.98	897.34	827.07	77.57	-0.10	279.17	1116.67	3.23	184.19

**Wheelabrator
NORTH BROWARD
Emission Test Log**

Date: 03/11/09
Start Time: 8:29
End Time: 9:29

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FEEDOUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	-----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	522.35	320.23	38.91	31.81	7.10	15.41	306.09	6.27	-9.63
Unit 2	501.27	320.34	36.43	25.74	10.69	19.78	0.00	6.56	-10.89
Unit 3 26A run 2	518.10	320.63	36.07	30.05	6.02	15.59	308.03	6.03	-9.33

C - 45

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	185.44	895.08	826.17	81.92	-0.10	273.35	1167.32	2.58	184.59
Unit 2	187.26	892.74	829.65	77.01	-0.10	273.90	1205.37	3.18	184.52
Unit 3	189.54	897.50	834.06	80.90	-0.10	279.97	1128.27	3.76	182.94

Wheelabrator NORTH BROWARD Emission Test Log

Date: 03/11/09
Start Time: 10:02
End Time: 11:02

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	523.00	319.84	38.81	30.52	8.29	15.69	305.32	6.31	-9.56
Unit 2	506.27	319.95	37.05	32.44	4.61	19.74	0.00	6.50	-11.01
Unit 3 26A run 3	520.27	319.68	36.74	32.13	4.61	15.61	307.66	5.69	-8.85

FEED H2O FLOW	SH:OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGONO OUT TEMP	SH:ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	184.08	894.05	822.27	84.10	-0.11	273.14	1197.10	2.54	184.13
Unit 2	186.87	891.78	828.57	78.81	-0.10	273.47	1198.77	4.32	183.66
Unit 3	189.80	896.61	828.11	81.82	-0.10	279.78	1136.22	3.34	183.92

C - 46

Wheelabrator - N. Broward

2600 N.W. 48th Street
 Pompano Beach, FL 33073
 Tel: (954) 971-8701 Fax: (954) 971-8703

Ticket 274039

3/12/2009

In 7:43:59AM

Out 10:08:56AM

Account 623030
Customer Chemical Lime
 Chemical Lime
 PO Box 7247-8945
 Philadelphia. PA

Decal # LIME1
Vehicle # LIME1
Auto ID 0
Other 2357416
Product 9020 Lime
Qty 25.81 Ton
Origin Wheelabrator No
Operator Olivia Smith

Price/Ton	0.00
Fees	0.00
Other	0.00
Total	0.00

	<u>Pounds</u>	<u>Tons</u>
Gross	78840	39.42
Tare	27220	13.61
Net	51620	25.81

Wheelabrator - N. Broward

2600 N.W. 48th Street
 Pompano Beach, FL 33073
 Tel: (954) 971-8701 Fax: (954) 971-8703

Ticket 274039

3/12/2009

In 7:43:59AM

Out 10:08:56AM

Account 623030
Customer Chemical Lime
 Chemical Lime
 PO Box 7247-8945
 Philadelphia. PA

Decal # LIME1
Vehicle # LIME1
Auto ID 0
Other 2357416
Product 9020
Qty 25.81 Ton
Origin Wheelabrator No
Operator Olivia Smith

Price/Ton	0.00
Fees	0.00
Other	0.00
Total	0.00

	<u>Pounds</u>	<u>Tons</u>
Gross	78840	39.42
Tare	27220	13.61
Net	51620	25.81

This Page Intentionally Left Blank

WHEELABRATOR NORTH BROWARD, INC.
POMPANO BEACH, FL

CleanAir Project No: 10735-2

PARAMETERS

D

This Page Intentionally Left Blank

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:48	09:25	11:59	
Stop Time (approx.)	09:03	11:37	14:13	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9916	0.9916	0.9916	
C _p Pitot tube coefficient	0.8120	0.8120	0.8120	
P _g Static pressure (in. H ₂ O)	-9.4000	-9.4000	-9.4000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.25	30.25	30.25	30.2500
D _n Nozzle diameter (in.)	0.2680	0.2680	0.2680	
O ₂ Oxygen (dry volume %)	7.5900	8.3000	8.4000	8.0967
CO ₂ Carbon dioxide (dry volume %)	11.6900	11.4000	11.2800	11.4567
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.7200	80.3000	80.3200	80.4467
V _{lc} Total Liquid collected (ml)	412.40	421.90	390.80	
V _m Volume metered, meter conditions (ft ³)	65.6700	70.3650	70.0350	
T _m Dry gas meter temperature (°F)	68.4000	79.5000	86.9600	
T _s Sample temperature (°F)	306.9600	307.4400	307.0400	307.1467
ΔH Meter box orifice pressure drop (in. H ₂ O)	0.9668	1.0440	1.0388	
θ Total sampling time (min)	125.0	125.0	125.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	19.4075	19.8546	18.3910	19.2177
V _{mstd} Volume metered, standard (dscf)	65.9150	69.1873	67.9228	67.6750
P _s Sample gas pressure, absolute (in. Hg)	29.5588	29.5588	29.5588	29.5588
P _v Vapor pressure, actual (in. Hg)	29.5588	29.5588	29.5588	29.5588
B _{wv} Moisture measured in sample (% by volume)	22.7461	22.2981	21.3072	22.1171
B _{wvs} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	22.7461	22.2981	21.3072	22.1171
√ΔP Velocity head (√in. H ₂ O)	0.6324	0.6670	0.6633	0.6542
M _d MW of sample gas, dry (lb/lb-mole)	30.1740	30.1560	30.1408	30.1569
M _w MW of sample gas, wet (lb/lb-mole)	27.4049	27.4454	27.5539	27.4681
V _s Velocity of sample (ft/sec)	42.7161	45.0336	44.6840	44.1446
%I Isokinetic sampling (%)	100.0190	99.0695	96.7350	98.6078
Q _a Volumetric flow rate, actual (acfm)	164,030	172,929	171,587	169,515
Q _s Volumetric flow rate, standard (scfm)	111,560	117,539	116,688	115,262
Q _{std} Volumetric flow rate, dry standard (dscfm)	86,185	91,330	91,825	89,780
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	82,526	82,789	82,576	82,630
Q _a Volumetric flow rate, actual (acf/hr)	9,841,788	10,375,743	10,295,196	10,170,909
Q _s Volumetric flow rate, standard (scf/hr)	6,693,616	7,052,357	7,001,258	6,915,744
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,171,079	5,479,818	5,509,487	5,386,795
Q _a Volumetric flow rate, actual (m ³ /hr)	278,725	293,847	291,566	288,046
Q _s Volumetric flow rate, standard (m ³ /hr)	189,567	199,727	198,280	195,858
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	146,448	155,192	156,032	152,557
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	140,232	140,677	140,316	140,409
Q _n Volumetric flow rate, normal (Nm ³ /hr)	176,642	186,109	184,761	182,504
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	136,463	144,610	145,393	142,156
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	130,671	131,086	130,749	130,835

Comments:

Average includes 3 runs.

D41409 120109
 N O K @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 5/29
 Filterable Particulate Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:48	09:25	11:59	
Stop Time (approx.)	09:03	11:37	14:13	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	185.4	183.9	183.7	184.3
P ₁ Fabric Filter Inlet Temperature (°F)	320	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	7.5900	8.3000	8.4000	8.0967
CO ₂ Carbon dioxide (dry volume %)	11.6900	11.4000	11.2800	11.4567
T _s Sample temperature (°F)	306.9600	307.4400	307.0400	307.1467
B _w Actual water vapor in gas (% by volume)	22.7461	22.2981	21.3072	22.1171
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	164,030	172,929	171,587	169,515
Q _s Volumetric flow rate, standard (scfm)	111,560	117,539	116,688	115,262
Q _{std} Volumetric flow rate, dry standard (dscfm)	86,185	91,330	91,825	89,780
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	82,526	82,789	82,576	82,630
Q _a Volumetric flow rate, actual (acf/hr)	9,841,788	10,375,743	10,295,196	10,170,909
Q _s Volumetric flow rate, standard (scf/hr)	6,693,616	7,052,357	7,001,258	6,915,744
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,171,079	5,479,818	5,509,487	5,386,795
Q _a Volumetric flow rate, actual (m ³ /hr)	278,725	293,847	291,566	288,046
Q _s Volumetric flow rate, standard (m ³ /hr)	189,567	199,727	198,280	195,858
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	146,448	155,192	156,032	152,557
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	140,232	140,677	140,316	140,409
Q _s Volumetric flow rate, normal (Nm ³ /hr)	176,642	186,109	184,761	182,504
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	136,463	144,610	145,393	142,156
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	130,671	131,086	130,749	130,835
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	65.9150	69.1873	67.9228	67.6750
%I Isokinetic sampling (%)	100.0190	99.0695	96.7350	98.6078
Laboratory Data				
m _{filter} Matter collected on filter(s) (g)	0.00090	0.00010	0.00010	
m _s Matter collected in solvent rinse(s) (g)	0.00205	0.00003	0.00006	
m _n Total particulate matter collected (g)	0.00295	<0.00020	<0.00020	
Filterable Particulate Results				
C _{sd} Particulate Concentration (lb/dscf)	9.8580E-08	<6.3740E-09	<6.4927E-09	<3.7149E-08
C _{sd7} Particulate Concentration @7% O ₂ (lb/dscf)	1.0295E-07	<7.0316E-09	<7.2198E-09	<3.9067E-08
C _{sd12} Particulate Concentration @12% CO ₂ (lb/dscf)	1.0119E-07	<6.7095E-09	<6.9071E-09	<3.8270E-08
C _a Particulate Concentration (lb/acf)	5.1796E-08	<3.3663E-09	<3.4746E-09	<1.9546E-08
C _{sd} Particulate Concentration (gr/dscf)	0.0007	<0.0000	<0.0000	<0.0003
C _{sd7} Particulate Concentration @7% O ₂ (gr/dscf)	0.0007	<0.0000	<0.0001	<0.0003
C _{sd12} Particulate Concentration @12% CO ₂ (gr/dscf)	0.0007	<0.0000	<0.0000	<0.0003
C _a Particulate Concentration (gr/acf)	0.0004	<0.0000	<0.0000	<0.0001
C _{sd} Particulate Concentration (mg/dscm)	1.5786	<0.1021	<0.1040	<0.5949
C _{sd7} Particulate Concentration @7% O ₂ (mg/dscm)	1.6486	<0.1126	<0.1156	<0.6256
C _{sd12} Particulate Concentration @12% CO ₂ (mg/dscm)	1.6205	<0.1074	<0.1106	<0.6128
C _a Particulate Concentration (mg/m ³ (actual,wet))	0.8294	<0.0539	<0.0556	<0.3130
C _{sd} Particulate Concentration (mg/Nm ³ dry)	1.6941	<0.1095	<0.1116	<0.6384
C _{sd7} Particulate Concentration @7% O ₂ (mg/Nm ³ dry)	1.7692	<0.1208	<0.1241	<0.6714
C _{sd12} Particulate Concentration @12% CO ₂ (mg/Nm ³ dry)	1.7390	<0.1153	<0.1187	<0.6577
E _{lb/hr} Particulate Rate (lb/hr)	0.5098	<0.0349	<0.0358	<0.1935
E _{kg/hr} Particulate Rate (kg/hr)	0.2312	<0.0158	<0.0162	<0.0877
E _{T/yr} Particulate Rate (Ton/yr)	2.2328	<0.1530	<0.1567	<0.8475
E _{Fd} Particulate Rate - F _d -based (lb/MMBtu)	0.0015	<0.00010	<0.00010	<0.00056
E _{Fc} Particulate Rate - F _c -based (lb/MMBtu)	0.0015	<0.00010	<0.00010	<0.00058

Comments:

Average includes 3 runs.

042209 081728
 NOK@X

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 10	Mar 10	Mar 10	
Start Time (approx.)		06:48	09:25	11:59	
Stop Time (approx.)		09:03	11:37	14:13	
Process Conditions					
R _p	Steam Production Rate (Kibs/hour)	185.4	183.9	183.7	184.3
P ₁	Fabric Filter Inlet Temperature (°F)	320	320	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	7.5900	8.3000	8.4000	8.0967
CO ₂	Carbon dioxide (dry volume %)	11.6900	11.4000	11.2800	11.4567
T _s	Sample temperature (°F)	306.9600	307.4400	307.0400	307.1467
B _w	Actual water vapor in gas (% by volume)	22.7461	22.2981	21.3072	22.1171
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	164,030	172,929	171,587	169,515
Q _s	Volumetric flow rate, standard (scfm)	111,560	117,539	116,688	115,262
Q _{std}	Volumetric flow rate, dry standard (dscfm)	86,185	91,330	91,825	89,780
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	82,526	82,789	82,576	82,630
Q _a	Volumetric flow rate, actual (acf/hr)	9,841,788	10,375,743	10,295,196	10,170,909
Q _s	Volumetric flow rate, standard (scf/hr)	6,693,616	7,052,357	7,001,258	6,915,744
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,171,079	5,479,818	5,509,487	5,386,795
Q _a	Volumetric flow rate, actual (m ³ /hr)	278,725	293,847	291,566	288,046
Q _s	Volumetric flow rate, standard (m ³ /hr)	189,567	199,727	198,280	195,858
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	146,448	155,192	156,032	152,557
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	140,232	140,677	140,316	140,409
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	176,642	186,109	184,761	182,504
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	136,463	144,610	145,393	142,156
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	130,671	131,086	130,749	130,835
Sampling Data					
V _{std}	Volume metered, standard (dscf)	65.9150	69.1873	67.9228	67.6750
%I	Isokinetic sampling (%)	100.0190	99.0695	96.7350	98.6078
Laboratory Data					
m _{n-1b}	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	
m _{n-2b}	Fraction 2B (µg)	12.6653	13.9374	15.6810	
m _{n-3a}	Fraction 3A (µg)	0.2294	<0.2000	<0.2000	
m _{n-3b}	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m _{n-3c}	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	
m _n	Total matter corrected for allowable blanks (µg)	12.8947	13.9374	15.6810	
Mercury Results - Total					
C _{sd}	Concentration (lb/dscf)	4.3136E-10	4.4418E-10	5.0906E-10	4.6153E-10
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	4.5048E-10	4.9001E-10	5.6607E-10	5.0219E-10
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	4.4279E-10	4.6756E-10	5.4155E-10	4.8397E-10
C _a	Concentration (lb/acf)	2.2664E-10	2.3459E-10	2.7242E-10	2.4455E-10
C _{sd}	Concentration (µg/dscm)	6.9076E+00	7.1130E+00	8.1518E+00	7.3908E+00
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	7.2138E+00	7.8469E+00	9.0649E+00	8.0418E+00
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	7.0907E+00	7.4874E+00	8.6722E+00	7.7501E+00
C _{sd}	Concentration (mg/dscm)	6.9076E-03	7.1130E-03	8.1518E-03	7.3908E-03
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	7.2138E-03	7.8469E-03	9.0649E-03	8.0418E-03
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	7.0907E-03	7.4874E-03	8.6722E-03	7.7501E-03
C _a	Concentration (µg/m ³ (actual,wet))	3.6294E+00	3.7566E+00	4.3625E+00	3.9162E+00
C _{sd}	Concentration (µg/Nm ³ dry)	7.4130E+00	7.6335E+00	8.7483E+00	7.9316E+00
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	7.7416E+00	8.4210E+00	9.7281E+00	8.6303E+00
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	7.6096E+00	8.0352E+00	9.3067E+00	8.3172E+00
E _{lb/hr}	Rate (lb/hr)	2.2306E-03	2.4340E-03	2.8046E-03	2.4898E-03
E _{g/s}	Rate (g/s)	2.8100E-04	3.0663E-04	3.5332E-04	3.1365E-04
E _{T/yr}	Rate (Ton/yr)	9.7699E-03	1.0661E-02	1.2284E-02	1.0905E-02
E _{Fd}	Rate - Fd-based (lb/MMBtu)	6.4821E-06	7.0510E-06	8.1455E-06	7.2262E-06
E _{Fc}	Rate - Fc-based (lb/MMBtu)	6.7157E-06	7.0914E-06	8.2135E-06	7.3402E-06

041000 085227
 HOK E M

Prepared by Clean Air Engineering Proprietary Software
 SS Metals-1 Version 2005-12a

Copyright © 2008 Clean Air Engineering Inc.

QA/QC _____
 Date _____

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Front Half Results**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:48	09:25	11:59	
Stop Time (approx.)	09:03	11:37	14:13	

Mercury Results - Front Half

C _{sd}	Concentration (lb/dscf)	<3.3452E-12	<3.1870E-12	<3.2463E-12	<3.2595E-12
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<3.4935E-12	<3.5158E-12	<3.6099E-12	<3.5397E-12
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<3.4339E-12	<3.3547E-12	<3.4535E-12	<3.4141E-12
C _a	Concentration (lb/acf)	<1.7576E-12	<1.6832E-12	<1.7373E-12	<1.7260E-12
C _{sd}	Concentration (µg/dscm)	<5.3569E-02	<5.1035E-02	<5.1986E-02	<5.2197E-02
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<5.5944E-02	<5.6301E-02	<5.7808E-02	<5.6684E-02
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<5.4990E-02	<5.3721E-02	<5.5304E-02	<5.4672E-02
C _{sd}	Concentration (mg/dscm)	<5.3569E-05	<5.1035E-05	<5.1986E-05	<5.2197E-05
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<5.5944E-05	<5.6301E-05	<5.7808E-05	<5.6684E-05
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<5.4990E-05	<5.3721E-05	<5.5304E-05	<5.4672E-05
C _a	Concentration (µg/m ³ (actual,wet))	<2.8146E-02	<2.6954E-02	<2.7820E-02	<2.7640E-02
C _{sd}	Concentration (µg/Nm ³ dry)	<5.7489E-02	<5.4770E-02	<5.5789E-02	<5.6016E-02
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<6.0037E-02	<6.0421E-02	<6.2038E-02	<6.0832E-02
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<5.9013E-02	<5.7652E-02	<5.9350E-02	<5.8672E-02
E _{lb/hr}	Rate (lb/hr)	<1.7298E-05	<1.7464E-05	<1.7886E-05	<1.7549E-05
E _{g/s}	Rate (g/s)	<2.1792E-06	<2.2001E-06	<2.2532E-06	<2.2108E-06
E _{T/yr}	Rate (Ton/yr)	<7.5767E-05	<7.6493E-05	<7.8339E-05	<7.6866E-05
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<5.0270E-08	<5.0591E-08	<5.1945E-08	<5.0935E-08
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<5.2081E-08	<5.0880E-08	<5.2379E-08	<5.1780E-08

041509 088227
 NOK@_N

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:48	09:25	11:59	
Stop Time (approx.)	09:03	11:37	14:13	

Mercury Results - Impingers 1-3 Solution

C_{sd}	Concentration (lb/dscf)	4.2368E-10	4.4418E-10	5.0906E-10	4.5898E-10
C_{sd7}	Concentration @7% O ₂ (lb/dscf)	4.4246E-10	4.9001E-10	5.6607E-10	4.9952E-10
C_{sd12}	Concentration @12% CO ₂ (lb/dscf)	4.3492E-10	4.6756E-10	5.4155E-10	4.8134E-10
C_a	Concentration (lb/acf)	2.2261E-10	2.3459E-10	2.7242E-10	2.4321E-10
C_{sd}	Concentration (µg/dscm)	6.7847E+00	7.1130E+00	8.1518E+00	7.3498E+00
C_{sd7}	Concentration @7% O ₂ (µg/dscm)	7.0854E+00	7.8469E+00	9.0649E+00	7.9991E+00
C_{sd12}	Concentration @12% CO ₂ (µg/dscm)	6.9646E+00	7.4874E+00	8.6722E+00	7.7081E+00
C_{sd}	Concentration (mg/dscm)	6.7847E-03	7.1130E-03	8.1518E-03	7.3498E-03
C_{sd7}	Concentration @7% O ₂ (mg/dscm)	7.0854E-03	7.8469E-03	9.0649E-03	7.9991E-03
C_{sd12}	Concentration @12% CO ₂ (mg/dscm)	6.9646E-03	7.4874E-03	8.6722E-03	7.7081E-03
C_a	Concentration (µg/m ³ (actual,wet))	3.5648E+00	3.7566E+00	4.3625E+00	3.8946E+00
C_{sd}	Concentration (µg/Nm ³ dry)	7.2811E+00	7.6335E+00	8.7483E+00	7.8876E+00
C_{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	7.6039E+00	8.4210E+00	9.7281E+00	8.5844E+00
C_{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	7.4742E+00	8.0352E+00	9.3067E+00	8.2721E+00
$E_{lb/hr}$	Rate (lb/hr)	2.1909E-03	2.4340E-03	2.8046E-03	2.4765E-03
$E_{g/s}$	Rate (g/s)	2.7600E-04	3.0663E-04	3.5332E-04	3.1198E-04
$E_{T/yr}$	Rate (Ton/yr)	9.5961E-03	1.0661E-02	1.2284E-02	1.0847E-02
E_{Fd}	Rate - Fd-based (lb/MMBtu)	6.3668E-06	7.0510E-06	8.1455E-06	7.1878E-06
E_{Fc}	Rate - Fc-based (lb/MMBtu)	6.5963E-06	7.0914E-06	8.2135E-06	7.3004E-06

041809 088227
 N O K @ _ N

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Impinger 4 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:48	09:25	11:59	
Stop Time (approx.)	09:03	11:37	14:13	

Mercury Results - Impinger 4 Solution

C _{sd}	Concentration (lb/dscf)	7.6724E-12	<6.3740E-12	<6.4927E-12	<6.8464E-12
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	8.0125E-12	<7.0316E-12	<7.2198E-12	<7.4213E-12
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	7.8759E-12	<6.7095E-12	<6.9071E-12	<7.1642E-12
C _a	Concentration (lb/acf)	4.0313E-12	<3.3663E-12	<3.4746E-12	<3.6241E-12
C _{sd}	Concentration (µg/dscm)	1.2286E-01	<1.0207E-01	<1.0397E-01	<1.0964E-01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	1.2831E-01	<1.1260E-01	<1.1562E-01	<1.1884E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	1.2612E-01	<1.0744E-01	<1.1061E-01	<1.1472E-01
C _{sd}	Concentration (mg/dscm)	1.2286E-04	<1.0207E-04	<1.0397E-04	<1.0964E-04
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	1.2831E-04	<1.1260E-04	<1.1562E-04	<1.1884E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	1.2612E-04	<1.0744E-04	<1.1061E-04	<1.1472E-04
C _a	Concentration (µg/m ³ (actual,wet))	6.4555E-02	<5.3907E-02	<5.5640E-02	<5.8034E-02
C _{sd}	Concentration (µg/Nm ³ dry)	1.3185E-01	<1.0954E-01	<1.1158E-01	<1.1766E-01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	1.3770E-01	<1.2084E-01	<1.2408E-01	<1.2754E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	1.3535E-01	<1.1530E-01	<1.1870E-01	<1.2312E-01
E _{lb/hr}	Rate (lb/hr)	3.9675E-05	<3.4928E-05	<3.5771E-05	<3.6791E-05
E _{g/s}	Rate (g/s)	4.9981E-06	<4.4001E-06	<4.5063E-06	<4.6349E-06
E _{T/yr}	Rate (Ton/yr)	1.7378E-04	<1.5299E-04	<1.5668E-04	<1.6115E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	1.1530E-07	<1.0118E-07	<1.0389E-07	<1.0679E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	1.1945E-07	<1.0176E-07	<1.0476E-07	<1.0866E-07

041508 085227
 N O K @ _ N

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:48	09:25	11:59	
Stop Time (approx.)	09:03	11:37	14:13	

Mercury Results - Filtered Permanganate Solution

C _{sd}	Concentration (lb/dscf)	<1.6726E-11	<1.5935E-11	<1.6232E-11	<1.6298E-11
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<1.7468E-11	<1.7579E-11	<1.8050E-11	<1.7699E-11
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<1.7170E-11	<1.6774E-11	<1.7268E-11	<1.7070E-11
C _a	Concentration (lb/acf)	<8.7882E-12	<8.4159E-12	<8.6864E-12	<8.6302E-12
C _{sd}	Concentration (µg/dscm)	<2.6785E-01	<2.5518E-01	<2.5993E-01	<2.6098E-01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<2.7972E-01	<2.8150E-01	<2.8904E-01	<2.8342E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<2.7495E-01	<2.6861E-01	<2.7652E-01	<2.7336E-01
C _{sd}	Concentration (mg/dscm)	<2.6785E-04	<2.5518E-04	<2.5993E-04	<2.6098E-04
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<2.7972E-04	<2.8150E-04	<2.8904E-04	<2.8342E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<2.7495E-04	<2.6861E-04	<2.7652E-04	<2.7336E-04
C _a	Concentration (µg/m ³ (actual,wet))	<1.4073E-01	<1.3477E-01	<1.3910E-01	<1.3820E-01
C _{sd}	Concentration (µg/Nm ³ dry)	<2.8744E-01	<2.7385E-01	<2.7895E-01	<2.8008E-01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<3.0019E-01	<3.0210E-01	<3.1019E-01	<3.0416E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<2.9507E-01	<2.8826E-01	<2.9675E-01	<2.9336E-01
E _{lb/hr}	Rate (lb/hr)	<8.6492E-05	<8.7321E-05	<8.9428E-05	<8.7747E-05
E _{g/s}	Rate (g/s)	<1.0896E-05	<1.1000E-05	<1.1266E-05	<1.1054E-05
E _{T/yr}	Rate (Ton/yr)	<3.7883E-04	<3.8247E-04	<3.9170E-04	<3.8433E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<2.5135E-07	<2.5295E-07	<2.5972E-07	<2.5467E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<2.6041E-07	<2.5440E-07	<2.6189E-07	<2.5890E-07

Mercury Results - HCl Rinse + HCl/MnO2 Precipitate

C _{sd}	Concentration (lb/dscf)	<1.3381E-11	<1.2748E-11	<1.2985E-11	<1.3038E-11
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<1.3974E-11	<1.4063E-11	<1.4440E-11	<1.4159E-11
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<1.3736E-11	<1.3419E-11	<1.3814E-11	<1.3656E-11
C _a	Concentration (lb/acf)	<7.0306E-12	<6.7327E-12	<6.9491E-12	<6.9041E-12
C _{sd}	Concentration (µg/dscm)	<2.1428E-01	<2.0414E-01	<2.0794E-01	<2.0879E-01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<2.2377E-01	<2.2520E-01	<2.3123E-01	<2.2674E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<2.1996E-01	<2.1489E-01	<2.2122E-01	<2.1869E-01
C _{sd}	Concentration (mg/dscm)	<2.1428E-04	<2.0414E-04	<2.0794E-04	<2.0879E-04
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<2.2377E-04	<2.2520E-04	<2.3123E-04	<2.2674E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<2.1996E-04	<2.1489E-04	<2.2122E-04	<2.1869E-04
C _a	Concentration (µg/m ³ (actual,wet))	<1.1259E-01	<1.0781E-01	<1.1128E-01	<1.1056E-01
C _{sd}	Concentration (µg/Nm ³ dry)	<2.2995E-01	<2.1908E-01	<2.2316E-01	<2.2406E-01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<2.4015E-01	<2.4168E-01	<2.4815E-01	<2.4333E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<2.3605E-01	<2.3061E-01	<2.3740E-01	<2.3469E-01
E _{lb/hr}	Rate (lb/hr)	<6.9194E-05	<6.9857E-05	<7.1543E-05	<7.0198E-05
E _{g/s}	Rate (g/s)	<8.7168E-06	<8.8003E-06	<9.0127E-06	<8.8432E-06
E _{T/yr}	Rate (Ton/yr)	<3.0307E-04	<3.0597E-04	<3.1336E-04	<3.0747E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<2.0108E-07	<2.0236E-07	<2.0778E-07	<2.0374E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<2.0832E-07	<2.0352E-07	<2.0952E-07	<2.0712E-07

041509 085227
 N O K B_N

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

USEPA Method 5/29 Beryllium (Be) Emission Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 10	Mar 10	Mar 10	
Start Time (approx.)		06:48	09:25	11:59	
Stop Time (approx.)		09:03	11:37	14:13	
Process Conditions					
R _p	Steam Production Rate (Klbs/hr)	185.4	183.9	183.7	184.3
P ₁	Fabric Filter Inlet Temperature (°F)	320	320	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	7.5900	8.3000	8.4000	8.0967
CO ₂	Carbon dioxide (dry volume %)	11.6900	11.4000	11.2800	11.4567
T _a	Sample temperature (°F)	306.9600	307.4400	307.0400	307.1467
B _w	Actual water vapor in gas (% by volume)	22.7461	22.2981	21.3072	22.1171
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	164,030	172,929	171,587	169,515
Q _s	Volumetric flow rate, standard (scfm)	111,560	117,539	116,688	115,262
Q _{std}	Volumetric flow rate, dry standard (dscfm)	86,185	91,330	91,825	89,780
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	82,526	82,789	82,576	82,630
Q _a	Volumetric flow rate, actual (acf/hr)	9,841,788	10,375,743	10,295,196	10,170,909
Q _s	Volumetric flow rate, standard (scf/hr)	6,693,616	7,052,357	7,001,258	6,915,744
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,171,079	5,479,818	5,509,487	5,386,795
Q _a	Volumetric flow rate, actual (m ³ /hr)	278,725	293,847	291,566	288,046
Q _s	Volumetric flow rate, standard (m ³ /hr)	189,567	199,727	198,280	195,858
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	146,448	155,192	156,032	152,557
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	140,232	140,677	140,316	140,409
Q _a	Volumetric flow rate, normal (Nm ³ /hr)	176,642	186,109	184,761	182,504
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	136,463	144,610	145,393	142,156
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	130,671	131,086	130,749	130,835
Sampling Data					
V _{metd}	Volume metered, standard (dscf)	65.9150	69.1873	67.9228	67.6750
%I	Isokinetic sampling (%)	100.0190	99.0695	96.7350	98.6078
Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total					
C _{sd}	Concentration (lb/dscf)	<1.6726E-12	<1.5935E-12	<1.6232E-12	<1.6298E-12
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<1.7468E-12	<1.7579E-12	<1.8050E-12	<1.7699E-12
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<1.7170E-12	<1.6774E-12	<1.7268E-12	<1.7070E-12
C _a	Concentration (lb/acf)	<8.7882E-13	<8.4159E-13	<8.6864E-13	<8.6302E-13
C _{sd}	Concentration (µg/dscm)	<2.6785E-02	<2.5518E-02	<2.5993E-02	<2.6098E-02
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<2.7972E-02	<2.8150E-02	<2.8904E-02	<2.8342E-02
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<2.7495E-02	<2.6861E-02	<2.7652E-02	<2.7336E-02
C _{sd}	Concentration (mg/dscm)	<2.6785E-05	<2.5518E-05	<2.5993E-05	<2.6098E-05
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<2.7972E-05	<2.8150E-05	<2.8904E-05	<2.8342E-05
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<2.7495E-05	<2.6861E-05	<2.7652E-05	<2.7336E-05
C _a	Concentration (µg/m ³ (actual,wet))	<1.4073E-02	<1.3477E-02	<1.3910E-02	<1.3820E-02
C _{sd}	Concentration (µg/Nm ³ dry)	<2.8744E-02	<2.7385E-02	<2.7895E-02	<2.8008E-02
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<3.0019E-02	<3.0210E-02	<3.1019E-02	<3.0416E-02
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<2.9507E-02	<2.8826E-02	<2.9675E-02	<2.9336E-02
E _{lb/hr}	Rate (lb/hr)	<8.6492E-06	<8.7321E-06	<8.9428E-06	<8.7747E-06
E _{g/s}	Rate (g/s)	<1.0896E-06	<1.1000E-06	<1.1266E-06	<1.1054E-06
E _{7/yr}	Rate (Ton/yr)	<3.7883E-05	<3.8247E-05	<3.9170E-05	<3.8433E-05
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<2.5135E-08	<2.5295E-08	<2.5972E-08	<2.5467E-08
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<2.6041E-08	<2.5440E-08	<2.6189E-08	<2.5890E-08

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 5/29
 Cadmium (Cd) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:48	09:25	11:59	
Stop Time (approx.)	09:03	11:37	14:13	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	185.4	183.9	183.7	184.3
P ₁ Fabric Filter Inlet Temperature (°F)	320	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	7.5900	8.3000	8.4000	8.0967
CO ₂ Carbon dioxide (dry volume %)	11.6900	11.4000	11.2800	11.4567
T _s Sample temperature (°F)	306.9600	307.4400	307.0400	307.1467
B _w Actual water vapor in gas (% by volume)	22.7461	22.2981	21.3072	22.1171
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	164,030	172,929	171,587	169,515
Q _s Volumetric flow rate, standard (scfm)	111,560	117,539	116,688	115,262
Q _{std} Volumetric flow rate, dry standard (dscfm)	86,185	91,330	91,825	89,780
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	82,526	82,789	82,576	82,630
Q _a Volumetric flow rate, actual (acf/hr)	9,841,788	10,375,743	10,295,196	10,170,909
Q _s Volumetric flow rate, standard (scf/hr)	6,693,616	7,052,357	7,001,258	6,915,744
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,171,079	5,479,818	5,509,487	5,386,795
Q _a Volumetric flow rate, actual (m ³ /hr)	278,725	293,847	291,566	288,046
Q _s Volumetric flow rate, standard (m ³ /hr)	189,567	199,727	198,280	195,858
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	146,448	155,192	156,032	152,557
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	140,232	140,677	140,316	140,409
Q _n Volumetric flow rate, normal (Nm ³ /hr)	176,642	186,109	184,761	182,504
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	136,463	144,610	145,393	142,156
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	130,671	131,086	130,749	130,835
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	65.9150	69.1873	67.9228	67.6750
%I Isokinetic sampling (%)	100.0190	99.0695	96.7350	98.6078
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.6369	<0.2009	<0.2000	
Cadmium Results - Total				
C _{ed} Concentration (lb/dscf)	2.1304E-11	<6.4041E-12	<6.4927E-12	<1.1400E-11
C _{ed7} Concentration @7% O ₂ (lb/dscf)	2.2249E-11	<7.0649E-12	<7.2198E-12	<1.2178E-11
C _{ed12} Concentration @12% CO ₂ (lb/dscf)	2.1869E-11	<6.7412E-12	<6.9071E-12	<1.1839E-11
C _a Concentration (lb/acf)	1.1194E-11	<3.3823E-12	<3.4746E-12	<6.0168E-12
C _{sd} Concentration (µg/dscm)	3.4116E-01	<1.0255E-01	<1.0397E-01	<1.8256E-01
C _{sd7} Concentration @7% O ₂ (µg/dscm)	3.5628E-01	<1.1313E-01	<1.1562E-01	<1.9501E-01
C _{sd12} Concentration @12% CO ₂ (µg/dscm)	3.5020E-01	<1.0795E-01	<1.1061E-01	<1.8959E-01
C _{sd} Concentration (mg/dscm)	3.4116E-04	<1.0255E-04	<1.0397E-04	<1.8256E-04
C _{sd7} Concentration @7% O ₂ (mg/dscm)	3.5628E-04	<1.1313E-04	<1.1562E-04	<1.9501E-04
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	3.5020E-04	<1.0795E-04	<1.1061E-04	<1.8959E-04
C _a Concentration (µg/m ³ (actual,wet))	1.7925E-01	<5.4162E-02	<5.5640E-02	<9.6351E-02
C _{sd} Concentration (µg/Nm ³ dry)	3.6612E-01	<1.1006E-01	<1.1158E-01	<1.9592E-01
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	3.8235E-01	<1.2141E-01	<1.2408E-01	<2.0928E-01
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	3.7583E-01	<1.1585E-01	<1.1870E-01	<2.0346E-01
E _{lb/hr} Rate (lb/hr)	1.1017E-04	<3.5093E-05	<3.5771E-05	<6.0343E-05
E _{g/s} Rate (g/s)	1.3878E-05	<4.4209E-06	<4.5063E-06	<7.6018E-06
E _{T/yr} Rate (Ton/yr)	4.8252E-04	<1.5371E-04	<1.5668E-04	<2.6430E-04
E _{Fd} Rate - Fd-based (lb/MMBtu)	3.2014E-07	<1.0166E-07	<1.0389E-07	<1.7523E-07
E _{Fc} Rate - Fc-based (lb/MMBtu)	3.3168E-07	<1.0224E-07	<1.0476E-07	<1.7956E-07

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

USEPA Method 5/29 Lead (Pb) Emission Parameters

Run No.	1	2	3	Average	
Date (2009)	Mar 10	Mar 10	Mar 10		
Start Time (approx.)	06:48	09:25	11:59		
Stop Time (approx.)	09:03	11:37	14:13		
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	185.4	183.9	183.7	184.3
P ₁	Fabric Filter Inlet Temperature (°F)	320	320	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	7.5900	8.3000	8.4000	8.0967
CO ₂	Carbon dioxide (dry volume %)	11.6900	11.4000	11.2800	11.4567
T _s	Sample temperature (°F)	306.9600	307.4400	307.0400	307.1467
B _w	Actual water vapor in gas (% by volume)	22.7461	22.2981	21.3072	22.1171
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	164,030	172,929	171,587	169,515
Q _s	Volumetric flow rate, standard (scfm)	111,560	117,539	116,688	115,262
Q _{std}	Volumetric flow rate, dry standard (dscfm)	86,185	91,330	91,825	89,780
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	82,526	82,789	82,576	82,630
Q _a	Volumetric flow rate, actual (acf/hr)	9,841,788	10,375,743	10,295,196	10,170,909
Q _s	Volumetric flow rate, standard (scf/hr)	6,693,616	7,052,357	7,001,258	6,915,744
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,171,079	5,479,818	5,509,487	5,386,795
Q _a	Volumetric flow rate, actual (m ³ /hr)	278,725	293,847	291,566	288,046
Q _s	Volumetric flow rate, standard (m ³ /hr)	189,567	199,727	198,280	195,858
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	146,448	155,192	156,032	152,557
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	140,232	140,677	140,316	140,409
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	176,642	186,109	184,761	182,504
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	136,463	144,610	145,393	142,156
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	130,671	131,086	130,749	130,835
Sampling Data					
V _{std}	Volume metered, standard (dscf)	65.9150	69.1873	67.9228	67.6750
%I	Isokinetic sampling (%)	100.0190	99.0695	96.7350	98.6078
Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	0.8752	0.9408	0.6833	
Lead Results - Total					
C _{std}	Concentration (lb/dscf)	2.9277E-11	2.9982E-11	2.2181E-11	2.7147E-11
C _{std7}	Concentration @7% O ₂ (lb/dscf)	3.0575E-11	3.3076E-11	2.4665E-11	2.9439E-11
C _{std12}	Concentration @12% CO ₂ (lb/dscf)	3.0054E-11	3.1560E-11	2.3597E-11	2.8404E-11
C _a	Concentration (lb/acf)	1.5383E-11	1.5835E-11	1.1870E-11	1.4363E-11
C _{std}	Concentration (µg/dscm)	4.6884E-01	4.8012E-01	3.5520E-01	4.3472E-01
C _{std7}	Concentration @7% O ₂ (µg/dscm)	4.8962E-01	5.2966E-01	3.9498E-01	4.7142E-01
C _{std12}	Concentration @12% CO ₂ (µg/dscm)	4.8127E-01	5.0539E-01	3.7787E-01	4.5484E-01
C _{std}	Concentration (mg/dscm)	4.6884E-04	4.8012E-04	3.5520E-04	4.3472E-04
C _{std7}	Concentration @7% O ₂ (mg/dscm)	4.8962E-04	5.2966E-04	3.9498E-04	4.7142E-04
C _{std12}	Concentration @12% CO ₂ (mg/dscm)	4.8127E-04	5.0539E-04	3.7787E-04	4.5484E-04
C _a	Concentration (µg/m ³ (actual,wet))	2.4634E-01	2.5357E-01	1.9008E-01	2.3000E-01
C _{std}	Concentration (µg/Nm ³ dry)	5.0314E-01	5.1525E-01	3.8119E-01	4.6653E-01
C _{std7}	Concentration @7% O ₂ (µg/Nm ³ dry)	5.2545E-01	5.6842E-01	4.2388E-01	5.0591E-01
C _{std12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	5.1648E-01	5.4237E-01	4.0552E-01	4.8813E-01
E _{lb/hr}	Rate (lb/hr)	1.5140E-04	1.6430E-04	1.2221E-04	1.4597E-04
E _{g/s}	Rate (g/s)	1.9072E-05	2.0698E-05	1.5395E-05	1.8388E-05
E _{T/yr}	Rate (Ton/yr)	6.6311E-04	7.1962E-04	5.3526E-04	6.3933E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	4.3996E-07	4.7594E-07	3.5492E-07	4.2361E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	4.5582E-07	4.7866E-07	3.5788E-07	4.3079E-07

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 13B (Total Fluorides)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	11:47	13:09	14:33	
Stop Time (approx.)	12:59	14:19	15:43	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9916	0.9916	0.9916	
C _p Pitot tube coefficient	0.8250	0.8250	0.8250	
P _g Static pressure (in. H ₂ O)	-9.7000	-9.7000	-9.7000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.20	30.20	30.20	30.2000
D _n Nozzle diameter (in.)	0.2720	0.2720	0.2720	
O ₂ Oxygen (dry volume %)	8.4900	8.5700	8.6100	8.5567
CO ₂ Carbon dioxide (dry volume %)	11.3700	11.4700	11.1800	11.3400
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.1400	79.9600	80.2100	80.1033
V _{lc} Total Liquid collected (ml)	219.10	216.90	223.80	
V _m Volume metered, meter conditions (ft ³)	38.7800	38.5250	40.5050	
T _m Dry gas meter temperature (°F)	79.6000	84.2000	82.7800	
T _s Sample temperature (°F)	303.9600	305.3600	305.9600	305.0933
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.2800	1.1576	1.3960	
θ Total sampling time (min)	62.5	62.5	62.5	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	10.3108	10.2073	10.5320	10.3501
V _{mstd} Volume metered, standard (dscf)	38.0828	37.5015	39.5549	38.3797
P _s Sample gas pressure, absolute (in. Hg)	29.4868	29.4868	29.4868	29.4868
P _v Vapor pressure, actual (in. Hg)	29.4868	29.4868	29.4868	29.4868
B _{wo} Moisture measured in sample (% by volume)	21.3062	21.3950	21.0275	21.2429
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	21.3062	21.3950	21.0275	21.2429
√ΔP Velocity head (√in. H ₂ O)	0.6836	0.6636	0.7216	0.6896
M _d MW of sample gas, dry (lb/lb-mole)	30.1588	30.1780	30.1332	30.1567
M _s MW of sample gas, wet (lb/lb-mole)	27.5682	27.5725	27.5819	27.5742
V _s Velocity of sample (ft/sec)	46.7384	45.4129	49.3873	47.1795
%I Isokinetic sampling (%)	100.5182	102.1751	98.7132	100.4688
Q _a Volumetric flow rate, actual (acfm)	179,476	174,385	189,647	181,169
Q _s Volumetric flow rate, standard (scfm)	122,246	118,562	128,837	123,215
Q _{std} Volumetric flow rate, dry standard (dscfm)	96,200	93,195	101,746	97,047
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	85,888	82,669	89,961	86,172
Q _a Volumetric flow rate, actual (acf/hr)	10,768,533	10,463,122	11,378,824	10,870,160
Q _s Volumetric flow rate, standard (scf/hr)	7,334,751	7,113,691	7,730,200	7,392,881
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,771,996	5,591,714	6,104,733	5,822,814
Q _a Volumetric flow rate, actual (m ³ /hr)	304,971	296,322	322,255	307,849
Q _s Volumetric flow rate, standard (m ³ /hr)	207,724	201,464	218,924	209,371
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	163,466	158,361	172,890	164,906
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	145,944	140,474	152,864	146,427
Q _s Volumetric flow rate, normal (Nm ³ /hr)	193,561	187,728	203,997	195,095
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	152,321	147,563	161,102	153,662
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	135,993	130,896	142,442	136,444

Comments:

Average includes 3 runs.

041409 120328
 K Q O @

**USEPA Method 13B
 HF Parameters**

Run No.	1	2	3	Average	
Date (2009)	Mar 12	Mar 12	Mar 12		
Start Time (approx.)	11:47	13:09	14:33		
Stop Time (approx.)	12:59	14:19	15:43		
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	184.6	184.1	183.7	184.1
P ₁	Fabric Filter Inlet Temperature (°F)	319	320	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.4900	8.5700	8.6100	8.5567
CO ₂	Carbon dioxide (dry volume %)	11.3700	11.4700	11.1800	11.3400
T _a	Sample temperature (°F)	303.9600	305.3600	305.9600	305.0933
B _w	Actual water vapor in gas (% by volume)	21.3062	21.3950	21.0275	21.2429
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	179,476	174,385	189,647	181,169
Q _s	Volumetric flow rate, standard (scfm)	122,246	118,562	128,837	123,215
Q _{std}	Volumetric flow rate, dry standard (dscfm)	96,200	93,195	101,746	97,047
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	85,888	82,669	89,961	86,172
Q _a	Volumetric flow rate, actual (acf/hr)	10,768,533	10,463,122	11,378,824	10,870,160
Q _s	Volumetric flow rate, standard (scf/hr)	7,334,751	7,113,691	7,730,200	7,392,881
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,771,996	5,591,714	6,104,733	5,822,814
Q _a	Volumetric flow rate, actual (m ³ /hr)	304,971	296,322	322,255	307,849
Q _s	Volumetric flow rate, standard (m ³ /hr)	207,724	201,464	218,924	209,371
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	163,466	158,361	172,890	164,906
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	145,944	140,474	152,864	146,427
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	193,561	187,728	203,997	195,095
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	152,321	147,563	161,102	153,662
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	135,993	130,896	142,442	136,444
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	38.0828	37.5015	39.5549	38.3797
%I	Isokinetic sampling (%)	100.5182	102.1751	98.7132	100.4688
Laboratory Data					
m _n	Total HF collected (mg)	<0.0245	<0.0259	<0.0280	
Hydrogen Fluoride (HF) Results					
C _{sd}	HF Concentration (lb/dscf)	<1.4203E-09	<1.5228E-09	<1.5613E-09	<1.5015E-09
C _{sd7}	HF Concentration @7% O ₂ (lb/dscf)	<1.5909E-09	<1.7167E-09	<1.7658E-09	<1.6911E-09
C _{sd12}	HF Concentration @12% CO ₂ (lb/dscf)	<1.4990E-09	<1.5932E-09	<1.6758E-09	<1.5893E-09
C _a	HF Concentration (lb/acf)	<7.6130E-10	<8.1384E-10	<8.3763E-10	<8.0426E-10
C _{sd}	HF Concentration (ppmdv)	<0.0274	<0.0293	<0.0301	<0.0289
C _{sd7}	HF Concentration @7% O ₂ (ppmdv)	<0.0307	<0.0331	<0.0340	<0.0326
C _{sd12}	HF Concentration @12% CO ₂ (ppmdv)	<0.0289	<0.0307	<0.0323	<0.0306
C _w	HF Concentration (ppmwv)	<0.0215	<0.0231	<0.0238	<0.0228
C _{sd}	HF Concentration (mg/dscm)	<0.0227	<0.0244	<0.0250	<0.0240
C _{sd7}	HF Concentration @7% O ₂ (mg/dscm)	<0.0255	<0.0275	<0.0283	<0.0271
C _{sd12}	HF Concentration @12% CO ₂ (mg/dscm)	<0.0240	<0.0255	<0.0268	<0.0255
C _a	HF Concentration (mg/m ³ (actual,wet))	<0.0122	<0.0130	<0.0134	<0.0129
C _{sd}	HF Concentration (mg/Nm ³ dry)	<0.0244	<0.0262	<0.0268	<0.0258
C _{sd7}	HF Concentration @7% O ₂ (mg/Nm ³ dry)	<0.0273	<0.0295	<0.0303	<0.0291
C _{sd12}	HF Concentration @12% CO ₂ (mg/Nm ³ dry)	<0.0258	<0.0274	<0.0288	<0.0273
E _{lb/hr}	HF Rate (lb/hr)	<0.0082	<0.0085	<0.0095	<0.0087
E _{kg/hr}	HF Rate (kg/hr)	<0.0037	<0.0039	<0.0043	<0.0040
E _{T/yr}	HF Rate (Ton/yr)	<0.0359	<0.0373	<0.0417	<0.0383
E _{Fd}	HF Rate - Fd-based (lb/MMBtu)	<0.000023	<0.000025	<0.000025	<0.000024
E _{Fc}	HF Rate - Fc-based (lb/MMBtu)	<0.000023	<0.000024	<0.000025	<0.000024

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

USEPA Method 23 (PCDD/F) Sampling, Velocity and Moisture Parameters

Run No.	1	2*	3	4	Average
Date (2009)	Mar 10	Mar 11	Mar 11	Mar 12	
Start Time (approx.)	10:08	06:26	11:26	06:42	
Stop Time (approx.)	14:30	11:05	15:45	11:13	
Sampling Conditions					
Y _d Dry gas meter correction factor	0.9937	0.9937	0.9937	0.9875	
C _p Pitot tube coefficient	0.8330	0.8330	0.8330	0.8330	
P _g Static pressure (in. H ₂ O)	-9.4000	-10.5000	-10.4000	-9.7000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.25	30.20	30.20	30.20	30.2167
D _n Nozzle diameter (in.)	0.2660	0.2660	0.2660	0.2660	
O ₂ Oxygen (dry volume %)	8.5500	8.8800	9.3300	8.6500	8.8433
CO ₂ Carbon dioxide (dry volume %)	11.3000	10.9700	10.5500	11.1500	11.0000
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.1500	80.1500	80.1200	80.2000	80.1567
V _{lc} Total Liquid collected (ml)	812.30	811.90	800.60	757.70	
V _m Volume metered, meter conditions (ft ³)	142.9400	146.9950	146.2800	146.3950	
T _m Dry gas meter temperature (°F)	87.8800	74.3000	86.4800	86.3500	
T _s Sample temperature (°F)	307.0400	307.0200	305.2800	305.9600	306.0933
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.0076	1.0856	1.0458	1.0452	
θ Total sampling time (min)	250.0	250.0	250.0	250.0	
Flow Results					
V _{wstd} Volume of water collected (ft ³)	38.2268	38.2080	37.6762	35.6574	37.1868
V _{mstd} Volume metered, standard (dscf)	138.6788	146.0241	142.0613	141.3194	140.6865
P _s Sample gas pressure, absolute (in. Hg)	29.5588	29.4279	29.4353	29.4868	29.4936
P _v Vapor pressure, actual (in. Hg)	29.5588	29.4279	29.4353	29.4868	29.4936
B _{wo} Moisture measured in sample (% by volume)	21.6086	20.7391	20.9618	20.1481	20.9062
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	21.6086	20.7391	20.9618	20.1481	20.9062
√ΔP Velocity head (√in. H ₂ O)	0.6506	0.6732	0.6587	0.6662	0.6585
M _d MW of sample gas, dry (lb/lb-mole)	30.1500	30.1104	30.0612	30.1300	30.1137
M _s MW of sample gas, wet (lb/lb-mole)	27.5246	27.5988	27.5330	27.6860	27.5812
V _s Velocity of sample (ft/sec)	44.9893	46.5867	45.5828	45.9533	45.5085
%I Isokinetic sampling (%)	99.9457	100.9604	100.4132	97.9896	99.4495
Q _a Volumetric flow rate, actual (acfm)	172,759	178,893	175,038	176,461	174,753
Q _s Volumetric flow rate, standard (scfm)	117,485	121,121	118,810	119,878	118,724
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,098	96,002	93,905	95,725	93,910
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	81,828	83,017	78,164	84,362	81,452
Q _a Volumetric flow rate, actual (acf/hr)	10,365,543	10,733,581	10,502,280	10,587,630	10,485,151
Q _s Volumetric flow rate, standard (scf/hr)	7,049,098	7,267,251	7,128,595	7,192,703	7,123,465
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,525,886	5,760,091	5,634,313	5,743,514	5,634,571
Q _a Volumetric flow rate, actual (m ³ /hr)	293,558	303,981	297,431	299,848	296,946
Q _s Volumetric flow rate, standard (m ³ /hr)	199,635	205,813	201,886	203,702	201,741
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	156,496	163,129	159,567	162,660	159,574
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	139,045	141,066	132,819	143,351	138,405
Q _s Volumetric flow rate, normal (Nm ³ /hr)	186,023	191,780	188,121	189,813	187,986
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	145,826	152,007	148,687	151,569	148,694
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	129,565	131,448	123,764	133,577	128,969

Comments:

Average includes 3 runs. * indicates that the run is not included in the average.

041409 120930
 JKMP

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 23 Parameters (NDs & EMPCs counted as Zero)
 Total Tetra- through Octa-PCDD/F Results (using USEPA/INTL 1989 TEFs)**

Run No.	1	2	3	4	Average	
Date (2009)	Mar 10	Mar 11	Mar 11	Mar 12		
Start Time (approx.)	10:08	06:26	11:26	06:42		
Stop Time (approx.)	14:30	11:05	15:45	11:13		
Process Conditions						
R _p	Steam Production Rate (Klbs/hour)	184.0	184.5	183.6	184	184.0
P ₁	Fabric Filter Inlet Temperature (°F)	320	322	320	319	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760	8,760
Gas Conditions						
O ₂	Oxygen (dry volume %)	8.5500	8.8800	9.3300	8.6500	8.8525
CO ₂	Carbon dioxide (dry volume %)	11.3000	10.9700	10.5500	11.1500	10.9925
T _s	Sample temperature (°F)	307.0	307.0	305.3	306.0	306.3
B _w	Actual water vapor in gas (% by volume)	21.6086	20.7391	20.9618	20.1481	20.8644
Gas Flow Rate						
Q _a	Volumetric flow rate, actual (acfm)	172,759	178,893	175,038	176,461	175,788
Q _s	Volumetric flow rate, standard (scfm)	117,485	121,121	118,810	119,878	119,324
Q _{std}	Volumetric flow rate, dry standard (dscfm)	92,098	96,002	93,905	95,725	94,433
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	81,828	83,017	78,164	84,362	81,843
Q _a	Volumetric flow rate, actual (acf/hr)	10,365,543	10,733,581	10,502,280	10,587,630	10,547,259
Q _s	Volumetric flow rate, standard (scf/hr)	7,049,098	7,267,251	7,128,595	7,192,703	7,159,412
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,525,886	5,760,091	5,634,313	5,743,514	5,665,951
Q _a	Volumetric flow rate, actual (m ³ /hr)	293,558	303,981	297,431	299,848	298,705
Q _s	Volumetric flow rate, standard (m ³ /hr)	199,635	205,813	201,886	203,702	202,759
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	156,496	163,129	159,567	162,660	160,463
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	139,045	141,066	132,819	143,351	139,070
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	186,023	191,780	188,121	189,813	188,934
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	145,826	152,007	148,687	151,569	149,522
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	129,565	131,448	123,764	133,577	129,588
Sampling Data						
V _{std}	Volume metered, standard (dscf)	138.6788	146.0241	142.0613	141.3194	142.0209
%I	Isokinetic sampling (%)	99.9457	100.9604	100.4132	97.9896	99.8272
Laboratory Data from USEPA Method 23						
	Total PCDDs (ng)	1.29100		1.29600	1.04200	
	Total PCDFs (ng)	0.91205		1.11340	0.71810	
m _s	Total PCDDs & PCDFs (ng)	2.20000		2.41000	1.76000	
m _{s,TEQ}	Total TEQ PCDDs & PCDFs (ng)	0.02360		0.02370	0.01840	
Total PCDD/F Results (TEF=1)						
C _{std}	PCDD/F Concentration (ng/dscm)	5.6016E-01	5.9902E-01	4.3975E-01	5.3298E-01	
C _{std7}	PCDD/F Concentration @7% O ₂ (ng/dscm)	6.3046E-01	7.1965E-01	4.9898E-01	6.1636E-01	
C _{std12}	PCDD/F Concentration @12% CO ₂ (ng/dscm)	5.9486E-01	6.8135E-01	4.7328E-01	5.8316E-01	
C _{std}	PCDD/F Concentration (ng/Nm ³ dry)	6.0115E-01	6.4285E-01	4.7193E-01	5.7197E-01	
C _{std7}	PCDD/F Concentration @7% O ₂ (ng/Nm ³ dry)	6.7659E-01	7.7231E-01	5.3550E-01	6.6146E-01	
C _{std12}	PCDD/F Concentration @12% CO ₂ (ng/Nm ³ dry)	6.3838E-01	7.3120E-01	5.0791E-01	6.2583E-01	
E _{lb/hr}	PCDD/F Rate (lb/hr)	1.9330E-07	2.1076E-07	1.5772E-07	1.8726E-07	
E _{g/s}	PCDD/F Rate (g/s)	2.4351E-08	2.6551E-08	1.9869E-08	2.3590E-08	
E _{Ton/yr}	PCDD/F Rate (Ton/yr)	8.4664E-07	9.2313E-07	6.9083E-07	8.2020E-07	
E _{Fd}	PCDD/F Rate - F _d -based (lb/MMBtu)	5.6652E-10	6.4666E-10	4.4838E-10	5.5385E-10	
E _{Fc}	PCDD/F Rate - F _c -based (lb/MMBtu)	5.6340E-10	6.4531E-10	4.4825E-10	5.5232E-10	
Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)						
C _{stdTEQ}	TEQ Concentration (ng/dscm)	6.0090E-03	5.8907E-03	4.5974E-03	5.4990E-03	
C _{std7TEQ}	TEQ Concentration @7% O ₂ (ng/dscm)	6.7631E-03	7.0770E-03	5.2167E-03	6.3523E-03	
C _{std12TEQ}	TEQ Concentration @12% CO ₂ (ng/dscm)	6.3812E-03	6.7004E-03	4.9479E-03	6.0098E-03	
C _{stdTEQ}	TEQ Concentration (ng/Nm ³ dry)	6.4486E-03	6.3218E-03	4.9338E-03	5.9014E-03	
C _{std7TEQ}	TEQ Concentration @7% O ₂ (ng/Nm ³ dry)	7.2580E-03	7.5949E-03	5.5984E-03	6.8171E-03	
C _{std12TEQ}	TEQ Concentration @12% CO ₂ (ng/Nm ³ dry)	6.8481E-03	7.1906E-03	5.3099E-03	6.4496E-03	
E _{lb/hrTEQ}	TEQ Rate (lb/hr)	2.0735E-09	2.0726E-09	1.6489E-09	1.9317E-09	
E _{g/sTEQ}	TEQ Rate (g/sec)	2.6122E-10	2.6110E-10	2.0773E-10	2.4335E-10	
E _{Ton/yrTEQ}	TEQ Rate (Ton/yr)	9.0821E-09	9.0781E-09	7.2223E-09	8.4608E-09	
E _{FdTEQ}	TEQ Rate - F _d -based (lb/MMBtu)	6.0772E-12	6.3592E-12	4.6876E-12	5.7080E-12	
E _{FcTEQ}	TEQ Rate - F _c -based (lb/MMBtu)	6.0437E-12	6.3460E-12	4.6862E-12	5.6920E-12	

041408 120930
 J K M P_M

Prepared by Clean Air Engineering Proprietary Software
 SS PCDD-F v2007-01a

Copyright © 2007 Clean Air Engineering Inc.

QA/QC _____
 Date _____

**USEPA Method 23 Maximum Emissions Parameters (NDs & EMPCs included)
 Total Tetra- through Octa-PCDD/F Results (TEQ based on USEPA/INTL 1989 TEFs)**

Run No.	1	2	3	4	Average
Date (2008)	Mar 10	Mar 11	Mar 11	Mar 12	
Start Time (approx.)	10:08	06:26	11:26	06:42	
Stop Time (approx.)	14:30	11:05	15:45	11:13	
Process Conditions					
R _p Production rate - (units/hour)	184	185	184	184	184
P ₁ Process data - (units)	320	322	320	319	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂ Oxygen (dry volume %)	8.5500	8.8800	9.3300	8.6500	8.8525
CO ₂ Carbon dioxide (dry volume %)	11.3000	10.9700	10.5500	11.1500	10.9925
T _s Sample temperature (°F)	307.0	307.0	305.3	306.0	306.3
B _w Actual water vapor in gas (% by volume)	21.6086	20.7391	20.9618	20.1481	20.8644
Gas Flow Rate					
Q _a Volumetric flow rate, actual (acfm)	172,759	178,893	175,038	176,461	175,788
Q _s Volumetric flow rate, standard (scfm)	117,485	121,121	118,810	119,878	119,324
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,098	96,002	93,905	95,725	94,433
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	81,828	83,017	78,164	84,362	81,843
Q _a Volumetric flow rate, actual (acf/hr)	10,365,543	10,733,581	10,502,280	10,587,630	10,547,259
Q _s Volumetric flow rate, standard (scf/hr)	7,049,098	7,267,251	7,128,595	7,192,703	7,159,412
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,525,886	5,760,091	5,634,313	5,743,514	5,665,951
Q _a Volumetric flow rate, actual (m ³ /hr)	293,558	303,981	297,431	299,848	298,705
Q _s Volumetric flow rate, standard (m ³ /hr)	199,635	205,813	201,886	203,702	202,759
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	156,496	163,129	159,567	162,660	160,463
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	139,045	141,066	132,819	143,351	139,070
Q _s Volumetric flow rate, normal (Nm ³ /hr)	186,023	191,780	188,121	189,813	188,934
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	145,826	152,007	148,687	151,569	149,522
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	129,565	131,448	123,764	133,577	129,588
Sampling Data					
V _{std} Volume metered, standard (dscf)	138.6788	146.0241	142.0613	141.3194	142.0209
%I Isokinetic sampling (%)	99.9457	100.9604	100.4132	97.9896	99.8272
Laboratory Data from USEPA Method 23, including NDs and EMPCs					
m _n Total PCDDs & PCDFs (ng)	2.26000		2.55000	1.89000	
m _{n,TEQ} Total TEQ PCDDs & PCDFs (ng)	0.02420		0.02720	0.01990	
Total PCDD/F Results (TEF=1)					
C _{sd} PCDD/F Concentration (ng/dscm)	5.7543E-01		6.3381E-01	4.7223E-01	5.6049E-01
C _{sd7} PCDD/F Concentration @7% O ₂ (ng/dscm)	6.4766E-01		7.6145E-01	5.3584E-01	6.4832E-01
C _{sd12} PCDD/F Concentration @12% CO ₂ (ng/dscm)	6.1108E-01		7.2093E-01	5.0823E-01	6.1341E-01
C _{sd} PCDD/F Concentration (ng/Nm ³ dry)	6.1754E-01		6.8019E-01	5.0679E-01	6.0151E-01
C _{sd7} PCDD/F Concentration @7% O ₂ (ng/Nm ³ dry)	6.9504E-01		8.1717E-01	5.7505E-01	6.9575E-01
C _{sd12} PCDD/F Concentration @12% CO ₂ (ng/Nm ³ dry)	6.5579E-01		7.7368E-01	5.4542E-01	6.5830E-01
E _{lb/hr} PCDD/F Rate (lb/hr)	1.9857E-07		2.2300E-07	1.6937E-07	1.9898E-07
E _{g/s} PCDD/F Rate (g/s)	2.5015E-08		2.8093E-08	2.1337E-08	2.4815E-08
E _{T/yr} PCDD/F Rate (Ton/yr)	8.6973E-07		9.7876E-07	7.4186E-07	8.6278E-07
E _{Fd} PCDD/F - F _d -based (lb/MMBtu)	5.8197E-10		6.8422E-10	4.8149E-10	5.8256E-10
E _{Fc} PCDD/F Rate - F _c -based (lb/MMBtu)	5.7876E-10		6.8280E-10	4.8135E-10	5.8097E-10
Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)					
C _{sdTEQ} TEQ Concentration (ng/dscm)	6.1617E-03		6.7607E-03	4.9722E-03	5.9649E-03
C _{sd7TEQ} TEQ Concentration @7% O ₂ (ng/dscm)	6.9351E-03		8.1222E-03	5.6419E-03	6.8997E-03
C _{sd12TEQ} TEQ Concentration @12% CO ₂ (ng/dscm)	6.5434E-03		7.6899E-03	5.3513E-03	6.5282E-03
C _{sdTEQ} TEQ Concentration (ng/Nm ³ dry)	6.6126E-03		7.2554E-03	5.3360E-03	6.4013E-03
C _{sd7TEQ} TEQ Concentration @7% O ₂ (ng/Nm ³ dry)	7.4425E-03		8.7165E-03	6.0548E-03	7.4046E-03
C _{sd12TEQ} TEQ Concentration @12% CO ₂ (ng/Nm ³ dry)	7.0222E-03		8.2526E-03	5.7428E-03	7.0059E-03
E _{lb/hrTEQ} TEQ Rate (lb/hr)	2.1263E-09		2.3787E-09	1.7834E-09	2.0961E-09
E _{g/sTEQ} TEQ Rate (g/sec)	2.6786E-10		2.9966E-10	2.2466E-10	2.6406E-10
E _{T/yrTEQ} TEQ Rate (Ton/yr)	9.3130E-09		1.0419E-08	7.8111E-09	9.1810E-09
E _{FdTEQ} TEQ Rate - F _d -based (lb/MMBtu)	6.2317E-12		7.2984E-12	5.0697E-12	6.1999E-12
E _{FcTEQ} TEQ Rate - F _c -based (lb/MMBtu)	6.1974E-12		7.2832E-12	5.0682E-12	6.1829E-12

041409 120203
 J.K.M.P.M

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 SDA Inlet

USEPA Method 26A (HCl) Sampling, Velocity and Moisture Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 12	Mar 12	Mar 12	
Start Time (approx.)		06:36	08:25	10:10	
Stop Time (approx.)		07:36	09:25	11:10	
Sampling Conditions					
Y_d	Dry gas meter correction factor	1.0028	1.0028	1.0028	
C_p	Pitot tube coefficient	0.8400	0.8400	0.8400	
P_g	Static pressure (in. H ₂ O)	-2.2000	-2.2000	-2.2000	
A_s	Sample location area (ft ²)	60.1320	60.1320	60.1320	
P_{bar}	Barometric pressure (in. Hg)	30.20	30.20	30.20	30.2000
O_2	Oxygen (dry volume %)	7.7900	8.1200	8.1900	8.0333
CO_2	Carbon dioxide (dry volume %)	11.6800	11.3900	11.6400	11.5700
N_2+CO	Nitrogen plus carbon monoxide (dry volume %)	80.5300	80.4900	80.1700	80.3967
V_{lc}	Total Liquid collected (ml)	139.50	140.20	146.00	
V_m	Volume metered, meter conditions (ft ³)	32.1300	33.7200	35.0500	
T_m	Dry gas meter temperature (°F)	73.5000	79.5417	84.2083	
T_s	Sample temperature (°F)	495.6667	499.3333	498.2500	497.7500
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.0192	1.1150	1.1667	
θ	Total sampling time (min)	60.0	60.0	60.0	
Flow Results					
V_{wstd}	Volume of water collected (ft ³)	6.5649	6.5978	6.8708	6.6778
V_{mstd}	Volume metered, standard (dscf)	32.2532	33.4780	34.5044	33.4119
P_s	Sample gas pressure, absolute (in. Hg)	30.0382	30.0382	30.0382	30.0382
P_v	Vapor pressure, actual (in. Hg)	30.0382	30.0382	30.0382	30.0382
B_{wo}	Moisture measured in sample (% by volume)	16.9119	16.4633	16.6060	16.6604
B_{ws}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B_w	Actual water vapor in gas (% by volume)	16.9119	16.4633	16.6060	16.6604
M_d	MW of sample gas, dry (lb/lb-mole)	30.1804	30.1472	30.1900	30.1725
M_s	MW of sample gas, wet (lb/lb-mole)	28.1205	28.1474	28.1657	28.1445

Comments:

Average includes 3 runs.

041409 115716
 KML@

USEPA Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 12	Mar 12	Mar 12	
Start Time (approx.)		06:36	08:25	10:10	
Stop Time (approx.)		07:36	09:25	11:10	
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	184.0	183.6	183.8	183.8
P ₁	Fabric Filter Inlet Temperature (°F)	320	317	320	319
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	7.7900	8.1200	8.1900	8.0333
CO ₂	Carbon dioxide (dry volume %)	11.6800	11.3900	11.6400	11.5700
T _s	Sample temperature (°F)	495.6667	499.3333	498.2500	497.7500
B _w	Actual water vapor in gas (% by volume)	16.9119	16.4633	16.6060	16.6604
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	32.2532	33.4780	34.5044	33.4119
Laboratory Data					
m _n	Total HCl collected (mg)	711.8015	610.9163	602.0750	
Hydrogen Chloride (HCl) Results					
C _{sd}	HCl Concentration (lb/dscf)	4.8663E-05	4.0237E-05	3.8476E-05	4.2459E-05
C _{sd7}	HCl Concentration @7% O ₂ (lb/dscf)	5.1595E-05	4.3764E-05	4.2078E-05	4.5812E-05
C _{sd12}	HCl Concentration @12% CO ₂ (lb/dscf)	4.9996E-05	4.2392E-05	3.9665E-05	4.4018E-05
C _{sd}	HCl Concentration (ppmdv)	514.4898	425.4145	406.7864	448.8969
C _{sd7}	HCl Concentration @7% O ₂ (ppmdv)	545.4926	462.6965	444.8726	484.3539
C _{sd12}	HCl Concentration @12% CO ₂ (ppmdv)	528.5854	448.1978	419.3674	465.3836
C _w	HCl Concentration (ppmwv)	427.4798	355.3771	339.2354	374.0308
C _{sd}	HCl Concentration (mg/dscm)	779.2632	644.3467	616.1320	679.9139
C _{sd7}	HCl Concentration @7% O ₂ (mg/dscm)	826.2210	700.8153	673.8186	733.6183
C _{sd12}	HCl Concentration @12% CO ₂ (mg/dscm)	800.6128	678.8552	635.1876	704.8852
C _{sd}	HCl Concentration (mg/Nm ³ dry)	836.2824	691.4940	661.2148	729.6637
C _{sd7}	HCl Concentration @7% O ₂ (mg/Nm ³ dry)	886.6762	752.0944	723.1224	787.2977
C _{sd12}	HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	859.1943	728.5275	681.6648	756.4622
E _{Fd}	HCl Rate - Fd-based (lb/MMBtu)	0.7424	0.6297	0.6055	0.6592
E _{Fc}	HCl Rate - Fc-based (lb/MMBtu)	0.7583	0.6430	0.6016	0.6676

041409 115716
 KML@_@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

USEPA Modified Method 26A (HCI) Sampling, Velocity and Moisture Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 12	Mar 12	Mar 12	
Start Time (approx.)		06:36	08:25	10:10	
Stop Time (approx.)		07:36	09:25	11:10	
Sampling Conditions					
Y _d	Dry gas meter correction factor	0.9916	0.9916	0.9916	
C _p	Pitot tube coefficient	0.8400	0.8400	0.8400	
P _g	Static pressure (in. H ₂ O)	-9.7000	-9.7000	-9.7000	
A _s	Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar}	Barometric pressure (in. Hg)	30.20	30.20	30.20	30.2000
O ₂	Oxygen (dry volume %)	8.9000	9.1400	8.8900	8.9767
CO ₂	Carbon dioxide (dry volume %)	10.7300	10.5100	10.9500	10.7300
N ₂ +CO	Nitrogen plus carbon monoxide (dry volume %)	80.3700	80.3500	80.1600	80.2933
V _{lc}	Total Liquid collected (ml)	226.90	233.20	231.50	
V _m	Volume metered, meter conditions (ft ³)	40.4650	41.9400	42.6800	
T _m	Dry gas meter temperature (°F)	72.3333	76.7500	79.8750	
T _s	Sample temperature (°F)	307.2500	304.4167	306.2500	305.9722
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.5000	1.5000	1.5000	
θ	Total sampling time (min)	60.0	60.0	60.0	
Flow Results					
V _{wstd}	Volume of water collected (ft ³)	10.6779	10.9744	10.8944	10.8489
V _{mstd}	Volume metered, standard (dscf)	40.3015	41.4268	41.9137	41.2140
P _s	Sample gas pressure, absolute (in. Hg)	29.4868	29.4868	29.4868	29.4868
P _v	Vapor pressure, actual (in. Hg)	29.4868	29.4868	29.4868	29.4868
B _{wo}	Moisture measured in sample (% by volume)	20.9455	20.9430	20.6301	20.8396
B _{ws}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w	Actual water vapor in gas (% by volume)	20.9455	20.9430	20.6301	20.8396
M _d	MW of sample gas, dry (lb/lb-mole)	30.0728	30.0472	30.1076	30.0759
M _s	MW of sample gas, wet (lb/lb-mole)	27.5441	27.5242	27.6098	27.5593

Comments:

Average includes 3 runs.

041409 115818
 O L L @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

USEPA Modified Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 12	Mar 12	Mar 12	
Start Time (approx.)		06:36	08:25	10:10	
Stop Time (approx.)		07:36	09:25	11:10	
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	184.0	183.6	183.8	183.8
P ₁	Fabric Filter Inlet Temperature (°F)	320	317	320	319
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.9000	9.1400	8.8900	8.9767
CO ₂	Carbon dioxide (dry volume %)	10.7300	10.5100	10.9500	10.7300
T _s	Sample temperature (°F)	307.2500	304.4167	306.2500	305.9722
B _w	Actual water vapor in gas (% by volume)	20.9455	20.9430	20.6301	20.8396
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	40.3015	41.4268	41.9137	41.2140
Laboratory Data					
m _n	Total HCl collected (mg)	33.4232	21.9550	19.7170	
Hydrogen Chloride (HCl) Results					
C _{sd}	HCl Concentration (lb/dscf)	1.8287E-06	1.1686E-06	1.0373E-06	1.3448E-06
C _{sd7}	HCl Concentration @7% O ₂ (lb/dscf)	2.1182E-06	1.3812E-06	1.2005E-06	1.5666E-06
C _{sd12}	HCl Concentration @12% CO ₂ (lb/dscf)	2.0451E-06	1.3343E-06	1.1367E-06	1.5054E-06
C _{sd}	HCl Concentration (ppmdv)	19.3338	12.3550	10.9667	14.2185
C _{sd7}	HCl Concentration @7% O ₂ (ppmdv)	22.3950	14.6033	12.6925	16.5636
C _{sd12}	HCl Concentration @12% CO ₂ (ppmdv)	21.6221	14.1065	12.0183	15.9156
C _w	HCl Concentration (ppmwv)	15.2842	9.7675	8.7042	11.2520
C _{sd}	HCl Concentration (mg/dscm)	29.2836	18.7133	16.6105	21.5358
C _{sd7}	HCl Concentration @7% O ₂ (mg/dscm)	33.9201	22.1186	19.2244	25.0877
C _{sd12}	HCl Concentration @12% CO ₂ (mg/dscm)	32.7496	21.3662	18.2032	24.1063
C _{sd}	HCl Concentration (mg/Nm ³ dry)	31.4263	20.0825	17.8259	23.1116
C _{sd7}	HCl Concentration @7% O ₂ (mg/Nm ³ dry)	36.4021	23.7370	20.6311	26.9234
C _{sd12}	HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	35.1459	22.9296	19.5352	25.8702
E _{Fd}	HCl Rate - Fd-based (lb/MMBtu)	0.0305	0.0199	0.0173	0.0225
E _{Fc}	HCl Rate - Fc-based (lb/MMBtu)	0.0310	0.0202	0.0172	0.0228

041409 115818
 DLL @ _@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

USEPA Method 5/29 (Particulate/Metals) Sampling, Velocity and Moisture Parameters

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:29	08:58	11:39	
Stop Time (approx.)	08:40	11:20	13:49	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9886	0.9886	0.9886	
C _p Pilot tube coefficient	0.8120	0.8120	0.8120	
P _g Static pressure (in. H ₂ O)	-10.7000	-10.7000	-10.7000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.20	30.20	30.20	30.2000
D _n Nozzle diameter (in.)	0.2680	0.2680	0.2680	
O ₂ Oxygen (dry volume %)	8.9900	10.0100	8.2600	9.0867
CO ₂ Carbon dioxide (dry volume %)	10.6100	9.7100	11.7100	10.6767
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.4000	80.2800	80.0300	80.2367
V _{lc} Total Liquid collected (ml)	420.20	404.10	406.40	
V _m Volume metered, meter conditions (ft ³)	73.1250	69.6350	70.2850	
T _m Dry gas meter temperature (°F)	79.5800	83.1800	85.5600	
T _s Sample temperature (°F)	310.6400	310.7600	311.1200	310.8400
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.1360	1.0240	1.0480	
θ Total sampling time (min)	125.0	125.0	125.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	19.7746	19.0169	19.1252	19.3056
V _{mstd} Volume metered, standard (dscf)	71.5708	67.6848	68.0226	69.0927
P _s Sample gas pressure, absolute (in. Hg)	29.4132	29.4132	29.4132	29.4132
P _v Vapor pressure, actual (in. Hg)	29.4132	29.4132	29.4132	29.4132
B _{wo} Moisture measured in sample (% by volume)	21.6482	21.9337	21.9457	21.8425
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	21.6482	21.9337	21.9457	21.8425
√ΔP Velocity head (√in. H ₂ O)	0.6748	0.6527	0.6598	0.6624
M _d MW of sample gas, dry (lb/lb-mole)	30.0572	29.9540	30.2040	30.0717
M _s MW of sample gas, wet (lb/lb-mole)	27.4470	27.3320	27.5257	27.4349
V _s Velocity of sample (ft/sec)	45.7671	44.3621	44.6967	44.9420
%I Isokinetic sampling (%)	100.9176	98.8364	98.6473	99.4671
Q _a Volumetric flow rate, actual (acfm)	175,746	170,351	171,635	172,577
Q _s Volumetric flow rate, standard (scfm)	118,372	114,720	115,531	116,208
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,746	89,558	90,177	90,827
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	79,468	70,164	82,003	77,212
Q _a Volumetric flow rate, actual (acf/hr)	10,544,732	10,221,033	10,298,111	10,354,625
Q _s Volumetric flow rate, standard (scf/hr)	7,102,302	6,883,206	6,931,875	6,972,461
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,564,783	5,373,461	5,410,626	5,449,624
Q _a Volumetric flow rate, actual (m ³ /hr)	298,633	289,466	291,649	293,249
Q _s Volumetric flow rate, standard (m ³ /hr)	201,141	194,936	196,315	197,464
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	157,598	152,180	153,232	154,337
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,035	119,226	139,342	131,201
Q _a Volumetric flow rate, normal (Nm ³ /hr)	187,427	181,645	182,930	184,001
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	146,853	141,804	142,784	143,814
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	125,828	111,097	129,841	122,255

Comments:

Average includes 3 runs.

041409 121631
 N J K @

**USEPA Method 5/29
 Filterable Particulate Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:29	08:58	11:39	
Stop Time (approx.)	08:40	11:20	13:49	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	184.6	183.7	184.3	184.2
P ₁ Fabric Filter Inlet Temperature (°F)	321	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.9900	10.0100	8.2600	9.0867
CO ₂ Carbon dioxide (dry volume %)	10.6100	9.7100	11.7100	10.6767
T _s Sample temperature (°F)	310.6400	310.7600	311.1200	310.8400
B _w Actual water vapor in gas (% by volume)	21.6482	21.9337	21.9457	21.8425
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	175,746	170,351	171,635	172,577
Q _s Volumetric flow rate, standard (scfm)	118,372	114,720	115,531	116,208
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,746	89,558	90,177	90,827
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	79,468	70,164	82,003	77,212
Q _a Volumetric flow rate, actual (acf/hr)	10,544,732	10,221,033	10,298,111	10,354,625
Q _s Volumetric flow rate, standard (scf/hr)	7,102,302	6,883,206	6,931,875	6,972,461
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,564,783	5,373,461	5,410,626	5,449,624
Q _a Volumetric flow rate, actual (m ³ /hr)	298,633	289,466	291,649	293,249
Q _s Volumetric flow rate, standard (m ³ /hr)	201,141	194,936	196,315	197,464
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	157,598	152,180	153,232	154,337
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,035	119,226	139,342	131,201
Q _s Volumetric flow rate, normal (Nm ³ /hr)	187,427	181,645	182,930	184,001
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	146,853	141,804	142,784	143,814
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	125,828	111,097	129,841	122,255
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.5708	67.6848	68.0226	69.0927
%I Isokinetic sampling (%)	100.9176	98.8364	98.6473	99.4671
Laboratory Data				
m _{filter} Matter collected on filter(s) (g)	0.00010	0.00030	0.00010	
m _s Matter collected in solvent rinse(s) (g)	0.00099	0.00105	0.00075	
m _n Total particulate matter collected (g)	0.00099	0.00135	0.00075	
Filterable Particulate Results				
C _{sd} Particulate Concentration (lb/dscf)	3.0622E-08	4.4007E-08	2.4339E-08	3.2990E-08
C _{sd7} Particulate Concentration @7% O ₂ (lb/dscf)	3.5739E-08	5.6171E-08	2.6766E-08	3.9558E-08
C _{sd12} Particulate Concentration @12% CO ₂ (lb/dscf)	3.4634E-08	5.4386E-08	2.4942E-08	3.7987E-08
C _a Particulate Concentration (lb/acf)	1.6160E-08	2.3136E-08	1.2788E-08	1.7361E-08
C _{sd} Particulate Concentration (gr/dscf)	0.0002	0.0003	0.0002	0.0002
C _{sd7} Particulate Concentration @7% O ₂ (gr/dscf)	0.0003	0.0004	0.0002	0.0003
C _{sd12} Particulate Concentration @12% CO ₂ (gr/dscf)	0.0002	0.0004	0.0002	0.0003
C _a Particulate Concentration (gr/acf)	0.0001	0.0002	0.0001	0.0001
C _{sd} Particulate Concentration (mg/dscm)	0.4904	0.7047	0.3898	0.5283
C _{sd7} Particulate Concentration @7% O ₂ (mg/dscm)	0.5723	0.8995	0.4286	0.6335
C _{sd12} Particulate Concentration @12% CO ₂ (mg/dscm)	0.5546	0.8709	0.3994	0.6083
C _a Particulate Concentration (mg/m ³ (actual,wet))	0.2588	0.3705	0.2048	0.2780
C _{sd} Particulate Concentration (mg/Nm ³ dry)	0.5263	0.7563	0.4183	0.5669
C _{sd7} Particulate Concentration @7% O ₂ (mg/Nm ³ dry)	0.6142	0.9653	0.4600	0.6798
C _{sd12} Particulate Concentration @12% CO ₂ (mg/Nm ³ dry)	0.5952	0.9346	0.4286	0.6528
E _{lb/hr} Particulate Rate (lb/hr)	0.1704	0.2365	0.1317	0.1795
E _{kg/hr} Particulate Rate (kg/hr)	0.0773	0.1072	0.0597	0.0814
E _{T/yr} Particulate Rate (Ton/yr)	0.7464	1.0357	0.5768	0.7863
E _{pd} Particulate Rate - F _d -based (lb/MMBtu)	0.0005	0.0008	0.0004	0.0006
E _{pc} Particulate Rate - F _c -based (lb/MMBtu)	0.0005	0.0008	0.0004	0.0006

Comments:

Average includes 3 runs.

041509 084946
 N J K @_M

Wheelabrator North Broward, Inc.
 Clean Air Project No. 10735
 Unit 2 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 12	Mar 12	Mar 12	
Start Time (approx.)		06:29	08:58	11:39	
Stop Time (approx.)		08:40	11:20	13:49	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	184.6	183.7	184.3	184.2
P ₁	Fabric Filter inlet Temperature (°F)	321	320	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.9900	10.0100	8.2600	9.0867
CO ₂	Carbon dioxide (dry volume %)	10.6100	9.7100	11.7100	10.6767
T _s	Sample temperature (°F)	310.6400	310.7600	311.1200	310.8400
B _w	Actual water vapor in gas (% by volume)	21.6482	21.9337	21.9457	21.8425
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	175,746	170,351	171,635	172,577
Q _s	Volumetric flow rate, standard (scfm)	118,372	114,720	115,531	116,208
Q _{std}	Volumetric flow rate, dry standard (dscfm)	92,746	89,558	90,177	90,827
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	79,468	70,164	82,003	77,212
Q _a	Volumetric flow rate, actual (acf/hr)	10,544,732	10,221,033	10,298,111	10,354,625
Q _s	Volumetric flow rate, standard (scf/hr)	7,102,302	6,883,206	6,931,875	6,972,461
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,564,783	5,373,461	5,410,626	5,449,624
Q _a	Volumetric flow rate, actual (m ³ /hr)	298,633	289,466	291,649	293,249
Q _s	Volumetric flow rate, standard (m ³ /hr)	201,141	194,936	196,315	197,464
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	157,598	152,180	153,232	154,337
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,035	119,226	139,342	131,201
Q _n	Volumetric flow rate, normal (Nm ³ /hr)	187,427	181,645	182,930	184,001
Q _{nd}	Volumetric flow rate, dry normal (Nm ³ /hr)	146,853	141,804	142,784	143,814
Q _{nd7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	125,828	111,097	129,841	122,255
Sampling Data					
V _{std}	Volume metered, standard (dscf)	71.5708	67.6848	68.0226	69.0927
%I	Isokinetic sampling (%)	100.9176	98.8364	98.6473	99.4671
Laboratory Data					
m _{n-1b}	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	
m _{n-2b}	Fraction 2B (µg)	21.7723	16.7306	18.4327	
m _{n-3a}	Fraction 3A (µg)	0.5279	<0.2000	0.2274	
m _{n-3b}	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m _{n-3c}	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	
m _n	Total matter corrected for allowable blanks (µg)	22.3002	16.7306	18.6602	
Mercury Results - Total					
C _{std}	Concentration (lb/dscf)	6.8704E-10	5.4504E-10	6.0488E-10	6.1232E-10
C _{std7}	Concentration @7% O ₂ (lb/dscf)	8.0183E-10	6.9569E-10	6.6518E-10	7.2090E-10
C _{std12}	Concentration @12% CO ₂ (lb/dscf)	7.7705E-10	6.7358E-10	6.1986E-10	6.9016E-10
C _a	Concentration (lb/acf)	3.6257E-10	2.8654E-10	3.1781E-10	3.2231E-10
C _{std}	Concentration (µg/dscm)	1.1002E+01	8.7280E+00	9.6864E+00	9.8055E+00
C _{std7}	Concentration @7% O ₂ (µg/dscm)	1.2840E+01	1.1140E+01	1.0652E+01	1.1544E+01
C _{std12}	Concentration @12% CO ₂ (µg/dscm)	1.2443E+01	1.0786E+01	9.9262E+00	1.1052E+01
C _{std}	Concentration (mg/dscm)	1.1002E-02	8.7280E-03	9.6864E-03	9.8055E-03
C _{std7}	Concentration @7% O ₂ (mg/dscm)	1.2840E-02	1.1140E-02	1.0652E-02	1.1544E-02
C _{std12}	Concentration @12% CO ₂ (mg/dscm)	1.2443E-02	1.0786E-02	9.9262E-03	1.1052E-02
C _a	Concentration (µg/m ³ (actual,wet))	5.8061E+00	4.5886E+00	5.0892E+00	5.1613E+00
C _{std}	Concentration (µg/Nm ³ dry)	1.1807E+01	9.3667E+00	1.0395E+01	1.0523E+01
C _{std7}	Concentration @7% O ₂ (µg/Nm ³ dry)	1.3780E+01	1.1956E+01	1.1431E+01	1.2389E+01
C _{std12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	1.3354E+01	1.1576E+01	1.0653E+01	1.1861E+01
E _{lb/hr}	Rate (lb/hr)	3.8232E-03	2.9287E-03	3.2728E-03	3.3416E-03
E _{g/s}	Rate (g/s)	4.8164E-04	3.6895E-04	4.1229E-04	4.2096E-04
E _{T/yr}	Rate (Ton/yr)	1.6746E-02	1.2828E-02	1.4335E-02	1.4636E-02
E _{Fd}	Rate - Fd-based (lb/MMBtu)	1.1538E-05	1.0011E-05	9.5716E-06	1.0373E-05
E _{Fc}	Rate - Fc-based (lb/MMBtu)	1.1785E-05	1.0216E-05	9.4013E-06	1.0467E-05

041508 075049
 N J K @ _

Prepared by Clean Air Engineering Proprietary Software
 SS Metals-1 Version 2008-12a

Copyright © 2008 Clean Air Engineering Inc.

QA/QC _____
 Date _____

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Front Half Results**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:29	08:58	11:39	
Stop Time (approx.)	08:40	11:20	13:49	

Mercury Results - Front Half

C _{sd}	Concentration (lb/dscf)	<3.0809E-12	<3.2577E-12	<3.2416E-12	<3.1934E-12
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<3.5956E-12	<4.1582E-12	<3.5647E-12	<3.7728E-12
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<3.4845E-12	<4.0261E-12	<3.3218E-12	<3.6108E-12
C _a	Concentration (lb/acf)	<1.6259E-12	<1.7127E-12	<1.7031E-12	<1.6806E-12
C _{sd}	Concentration (µg/dscm)	<4.9336E-02	<5.2168E-02	<5.1909E-02	<5.1138E-02
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<5.7579E-02	<6.6588E-02	<5.7084E-02	<6.0417E-02
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<5.5799E-02	<6.4472E-02	<5.3195E-02	<5.7822E-02
C _{sd}	Concentration (mg/dscm)	<4.9336E-05	<5.2168E-05	<5.1909E-05	<5.1138E-05
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<5.7579E-05	<6.6588E-05	<5.7084E-05	<6.0417E-05
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<5.5799E-05	<6.4472E-05	<5.3195E-05	<5.7822E-05
C _a	Concentration (µg/m ³ (actual,wet))	<2.6036E-02	<2.7426E-02	<2.7273E-02	<2.6912E-02
C _{sd}	Concentration (µg/Nm ³ dry)	<5.2946E-02	<5.5985E-02	<5.5707E-02	<5.4880E-02
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<6.1792E-02	<7.1460E-02	<6.1261E-02	<6.4838E-02
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<5.9882E-02	<6.9189E-02	<5.7087E-02	<6.2053E-02
E _{lb/hr}	Rate (lb/hr)	<1.7144E-05	<1.7505E-05	<1.7539E-05	<1.7396E-05
E _{g/s}	Rate (g/s)	<2.1598E-06	<2.2053E-06	<2.2095E-06	<2.1915E-06
E _{T/yr}	Rate (Ton/yr)	<7.5092E-05	<7.6674E-05	<7.6821E-05	<7.6195E-05
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<5.1739E-08	<5.9834E-08	<5.1294E-08	<5.4289E-08
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<5.2848E-08	<6.1062E-08	<5.0381E-08	<5.4764E-08

041509 075048
 NJK@J

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:29	08:58	11:39	
Stop Time (approx.)	08:40	11:20	13:49	

Mercury Results - Impingers 1-3 Solution

C _{sd}	Concentration (lb/dscf)	6.7078E-10	5.4504E-10	5.9751E-10	6.0444E-10
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	7.8285E-10	6.9569E-10	6.5707E-10	7.1187E-10
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	7.5865E-10	6.7358E-10	6.1231E-10	6.8151E-10
C _a	Concentration (lb/acf)	3.5399E-10	2.8654E-10	3.1393E-10	3.1815E-10
C _{sd}	Concentration (µg/dscm)	1.0742E+01	8.7280E+00	9.5683E+00	9.6793E+00
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	1.2536E+01	1.1140E+01	1.0522E+01	1.1400E+01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	1.2149E+01	1.0786E+01	9.8053E+00	1.0913E+01
C _{sd}	Concentration (mg/dscm)	1.0742E-02	8.7280E-03	9.5683E-03	9.6793E-03
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	1.2536E-02	1.1140E-02	1.0522E-02	1.1400E-02
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	1.2149E-02	1.0786E-02	9.8053E-03	1.0913E-02
C _a	Concentration (µg/m ³ (actual,wet))	5.6686E+00	4.5886E+00	5.0272E+00	5.0948E+00
C _{sd}	Concentration (µg/Nm ³ dry)	1.1528E+01	9.3667E+00	1.0268E+01	1.0388E+01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	1.3454E+01	1.1956E+01	1.1292E+01	1.2234E+01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	1.3038E+01	1.1576E+01	1.0523E+01	1.1712E+01
E _{lb/hr}	Rate (lb/hr)	3.7327E-03	2.9287E-03	3.2329E-03	3.2981E-03
E _{g/s}	Rate (g/s)	4.7023E-04	3.6895E-04	4.0727E-04	4.1549E-04
E _{T/yr}	Rate (Ton/yr)	1.6349E-02	1.2828E-02	1.4160E-02	1.4446E-02
E _{Fd}	Rate - Fd-based (lb/MMBtu)	1.1265E-05	1.0011E-05	9.4549E-06	1.0243E-05
E _{Fc}	Rate - Fc-based (lb/MMBtu)	1.1506E-05	1.0216E-05	9.2867E-06	1.0336E-05

041509 075049
 N J K @ _ J

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Impinger 4 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:29	08:58	11:39	
Stop Time (approx.)	08:40	11:20	13:49	

Mercury Results - Impinger 4 Solution

C _{sd}	Concentration (lb/dscf)	1.6263E-11	<6.5155E-12	7.3729E-12	<1.0051E-11
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	1.8981E-11	<8.3164E-12	8.1079E-12	<1.1802E-11
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	1.8394E-11	<8.0521E-12	7.5555E-12	<1.1334E-11
C _a	Concentration (lb/acf)	8.5827E-12	<3.4254E-12	3.8737E-12	<5.2939E-12
C _{sd}	Concentration (µg/dscm)	2.6044E-01	<1.0434E-01	1.1807E-01	<1.6095E-01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	3.0395E-01	<1.3318E-01	1.2984E-01	<1.8899E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	2.9455E-01	<1.2894E-01	1.2099E-01	<1.8150E-01
C _{sd}	Concentration (mg/dscm)	2.6044E-04	<1.0434E-04	1.1807E-04	<1.6095E-04
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	3.0395E-04	<1.3318E-04	1.2984E-04	<1.8899E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	2.9455E-04	<1.2894E-04	1.2099E-04	<1.8150E-04
C _a	Concentration (µg/m ³ (actual,wet))	1.3744E-01	<5.4852E-02	6.2032E-02	<8.4775E-02
C _{sd}	Concentration (µg/Nm ³ dry)	2.7949E-01	<1.1197E-01	1.2671E-01	<1.7272E-01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	3.2619E-01	<1.4292E-01	1.3934E-01	<2.0282E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	3.1611E-01	<1.3838E-01	1.2984E-01	<1.9478E-01
E _{lb/hr}	Rate (lb/hr)	9.0502E-05	<3.5011E-05	3.9892E-05	<5.5135E-05
E _{g/s}	Rate (g/s)	1.1401E-05	<4.4105E-06	5.0255E-06	<6.9457E-06
E _{T/yr}	Rate (Ton/yr)	3.9640E-04	<1.5335E-04	1.7473E-04	<2.4149E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	2.7312E-07	<1.1967E-07	1.1667E-07	<1.6982E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	2.7898E-07	<1.2212E-07	1.1459E-07	<1.7190E-07

041509 075048
 NJK@J

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:29	08:58	11:39	
Stop Time (approx.)	08:40	11:20	13:49	

Mercury Results - Filtered Permanganate Solution

C _{sd}	Concentration (lb/dscf)	<1.5404E-11	<1.6289E-11	<1.6208E-11	<1.5967E-11
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<1.7978E-11	<2.0791E-11	<1.7824E-11	<1.8864E-11
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<1.7422E-11	<2.0130E-11	<1.6609E-11	<1.8054E-11
C _a	Concentration (lb/acf)	<8.1293E-12	<8.5634E-12	<8.5156E-12	<8.4028E-12
C _{sd}	Concentration (µg/dscm)	<2.4668E-01	<2.6084E-01	<2.5955E-01	<2.5569E-01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<2.8790E-01	<3.3294E-01	<2.8542E-01	<3.0208E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<2.7900E-01	<3.2236E-01	<2.6597E-01	<2.8911E-01
C _{sd}	Concentration (mg/dscm)	<2.4668E-04	<2.6084E-04	<2.5955E-04	<2.5569E-04
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<2.8790E-04	<3.3294E-04	<2.8542E-04	<3.0208E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<2.7900E-04	<3.2236E-04	<2.6597E-04	<2.8911E-04
C _a	Concentration (µg/m ³ (actual,wet))	<1.3018E-01	<1.3713E-01	<1.3637E-01	<1.3456E-01
C _{sd}	Concentration (µg/Nm ³ dry)	<2.6473E-01	<2.7993E-01	<2.7854E-01	<2.7440E-01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<3.0896E-01	<3.5730E-01	<3.0630E-01	<3.2419E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<2.9941E-01	<3.4595E-01	<2.8544E-01	<3.1026E-01
E _{lb/hr}	Rate (lb/hr)	<8.5722E-05	<8.7527E-05	<8.7695E-05	<8.6981E-05
E _{g/s}	Rate (g/s)	<1.0799E-05	<1.1026E-05	<1.1047E-05	<1.0958E-05
E _{T/yr}	Rate (Ton/yr)	<3.7546E-04	<3.8337E-04	<3.8410E-04	<3.8098E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<2.5870E-07	<2.9917E-07	<2.5647E-07	<2.7145E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<2.6424E-07	<3.0531E-07	<2.5191E-07	<2.7382E-07

Mercury Results - HCl Rinse + HCl/MnO2 Precipitate

C _{sd}	Concentration (lb/dscf)	<1.2323E-11	<1.3031E-11	<1.2966E-11	<1.2774E-11
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<1.4383E-11	<1.6633E-11	<1.4259E-11	<1.5091E-11
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<1.3938E-11	<1.6104E-11	<1.3287E-11	<1.4443E-11
C _a	Concentration (lb/acf)	<6.5035E-12	<6.8507E-12	<6.8125E-12	<6.7222E-12
C _{sd}	Concentration (µg/dscm)	<1.9734E-01	<2.0867E-01	<2.0764E-01	<2.0455E-01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<2.3032E-01	<2.6635E-01	<2.2833E-01	<2.4167E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<2.2320E-01	<2.5789E-01	<2.1278E-01	<2.3129E-01
C _{sd}	Concentration (mg/dscm)	<1.9734E-04	<2.0867E-04	<2.0764E-04	<2.0455E-04
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<2.3032E-04	<2.6635E-04	<2.2833E-04	<2.4167E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<2.2320E-04	<2.5789E-04	<2.1278E-04	<2.3129E-04
C _a	Concentration (µg/m ³ (actual,wet))	<1.0414E-01	<1.0970E-01	<1.0909E-01	<1.0765E-01
C _{sd}	Concentration (µg/Nm ³ dry)	<2.1178E-01	<2.2394E-01	<2.2283E-01	<2.1952E-01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<2.4717E-01	<2.8584E-01	<2.4504E-01	<2.5935E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<2.3953E-01	<2.7676E-01	<2.2835E-01	<2.4821E-01
E _{lb/hr}	Rate (lb/hr)	<6.8577E-05	<7.0021E-05	<7.0156E-05	<6.9585E-05
E _{g/s}	Rate (g/s)	<8.6391E-06	<8.8210E-06	<8.8380E-06	<8.7660E-06
E _{T/yr}	Rate (Ton/yr)	<3.0037E-04	<3.0669E-04	<3.0728E-04	<3.0478E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<2.0696E-07	<2.3934E-07	<2.0518E-07	<2.1716E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<2.1139E-07	<2.4425E-07	<2.0153E-07	<2.1905E-07

D41506 075048
 N J K @ J

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

USEPA Method 5/29 Beryllium (Be) Emission Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 12	Mar 12	Mar 12	
Start Time (approx.)		06:29	08:58	11:39	
Stop Time (approx.)		08:40	11:20	13:49	
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	184.6	183.7	184.3	184.2
P ₁	Fabric Filter Inlet Temperature (°F)	321	320	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.9900	10.0100	8.2600	9.0867
CO ₂	Carbon dioxide (dry volume %)	10.6100	9.7100	11.7100	10.6767
T _a	Sample temperature (°F)	310.6400	310.7600	311.1200	310.8400
B _w	Actual water vapor in gas (% by volume)	21.6482	21.9337	21.9457	21.8425
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	175,746	170,351	171,635	172,577
Q _s	Volumetric flow rate, standard (scfm)	118,372	114,720	115,531	116,208
Q _{std}	Volumetric flow rate, dry standard (dscfm)	92,746	89,558	90,177	90,827
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	79,468	70,164	82,003	77,212
Q _a	Volumetric flow rate, actual (acf/hr)	10,544,732	10,221,033	10,298,111	10,354,625
Q _s	Volumetric flow rate, standard (scf/hr)	7,102,302	6,883,206	6,931,875	6,972,461
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,564,783	5,373,461	5,410,626	5,449,624
Q _a	Volumetric flow rate, actual (m ³ /hr)	298,633	289,466	291,649	293,249
Q _s	Volumetric flow rate, standard (m ³ /hr)	201,141	194,936	196,315	197,464
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	157,598	152,180	153,232	154,337
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,035	119,226	139,342	131,201
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	187,427	181,645	182,930	184,001
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	146,853	141,804	142,784	143,814
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	125,828	111,097	129,841	122,255
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	71.5708	67.6848	68.0226	69.0927
%I	Isokinetic sampling (%)	100.9176	98.8364	98.6473	99.4671
Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total					
C _{std}	Concentration (lb/dscf)	<1.5404E-12	<1.6289E-12	<1.6208E-12	<1.5967E-12
C _{std7}	Concentration @7% O ₂ (lb/dscf)	<1.7978E-12	<2.0791E-12	<1.7824E-12	<1.8864E-12
C _{std12}	Concentration @12% CO ₂ (lb/dscf)	<1.7422E-12	<2.0130E-12	<1.6609E-12	<1.8054E-12
C _s	Concentration (lb/acf)	<8.1293E-13	<8.5634E-13	<8.5156E-13	<8.4028E-13
C _{sd}	Concentration (µg/dscm)	<2.4668E-02	<2.6084E-02	<2.5955E-02	<2.5569E-02
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<2.8790E-02	<3.3294E-02	<2.8542E-02	<3.0208E-02
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<2.7900E-02	<3.2236E-02	<2.6597E-02	<2.8911E-02
C _{sd}	Concentration (mg/dscm)	<2.4668E-05	<2.6084E-05	<2.5955E-05	<2.5569E-05
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<2.8790E-05	<3.3294E-05	<2.8542E-05	<3.0208E-05
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<2.7900E-05	<3.2236E-05	<2.6597E-05	<2.8911E-05
C _a	Concentration (µg/m ³ (actual,wet))	<1.3018E-02	<1.3713E-02	<1.3637E-02	<1.3456E-02
C _{sd}	Concentration (µg/Nm ³ dry)	<2.6473E-02	<2.7993E-02	<2.7854E-02	<2.7440E-02
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<3.0896E-02	<3.5730E-02	<3.0630E-02	<3.2419E-02
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<2.9941E-02	<3.4595E-02	<2.8544E-02	<3.1026E-02
E _{lb/hr}	Rate (lb/hr)	<8.5722E-06	<8.7527E-06	<8.7695E-06	<8.6981E-06
E _{g/s}	Rate (g/s)	<1.0799E-06	<1.1026E-06	<1.1047E-06	<1.0958E-06
E _{T/yr}	Rate (Ton/yr)	<3.7546E-05	<3.8337E-05	<3.8410E-05	<3.8098E-05
E _{fd}	Rate - Fd-based (lb/MMBtu)	<2.5870E-08	<2.9917E-08	<2.5647E-08	<2.7145E-08
E _{fc}	Rate - Fc-based (lb/MMBtu)	<2.6424E-08	<3.0531E-08	<2.5191E-08	<2.7382E-08

Prepared by Clean Air Engineering Proprietary Software
 SS Metals-1 Version 2008-12a

Copyright © 2005 Clean Air Engineering Inc.

QA/QC _____
 Date _____

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

USEPA Method 5/29 Cadmium (Cd) Emission Parameters

Run No.	1	2	3	Average	
Date (2009)	Mar 12	Mar 12	Mar 12		
Start Time (approx.)	06:29	08:58	11:39		
Stop Time (approx.)	08:40	11:20	13:49		
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	184.6	183.7	184.3	184.2
P ₁	Fabric Filter Inlet Temperature (°F)	321	320	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.9900	10.0100	8.2600	9.0867
CO ₂	Carbon dioxide (dry volume %)	10.6100	9.7100	11.7100	10.6767
T _a	Sample temperature (°F)	310.6400	310.7600	311.1200	310.8400
B _w	Actual water vapor in gas (% by volume)	21.6482	21.9337	21.9457	21.8425
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	175,746	170,351	171,635	172,577
Q _s	Volumetric flow rate, standard (scfm)	118,372	114,720	115,531	116,208
Q _{std}	Volumetric flow rate, dry standard (dscfm)	92,746	89,558	90,177	90,827
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	79,468	70,164	82,003	77,212
Q _a	Volumetric flow rate, actual (acf/hr)	10,544,732	10,221,033	10,298,111	10,354,625
Q _s	Volumetric flow rate, standard (scf/hr)	7,102,302	6,883,206	6,931,875	6,972,461
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,564,783	5,373,461	5,410,626	5,449,624
Q _a	Volumetric flow rate, actual (m ³ /hr)	298,633	289,466	291,649	293,249
Q _s	Volumetric flow rate, standard (m ³ /hr)	201,141	194,936	196,315	197,464
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	157,598	152,180	153,232	154,337
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,035	119,226	139,342	131,201
Q _a	Volumetric flow rate, normal (Nm ³ /hr)	187,427	181,645	182,930	184,001
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	146,853	141,804	142,784	143,814
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	125,828	111,097	129,841	122,255
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	71.5708	67.6848	68.0226	69.0927
%I	Isokinetic sampling (%)	100.9176	98.8364	98.6473	99.4671
Laboratory Data					
m _n	Total matter corrected for allowable blanks (µg)	<0.2000	0.2028	<0.2000	
Cadmium Results - Total					
C _{std}	Concentration (lb/dscf)	<6.1617E-12	6.6056E-12	<6.4831E-12	<6.4168E-12
C _{std7}	Concentration @7% O ₂ (lb/dscf)	<7.1913E-12	8.4314E-12	<7.1294E-12	<7.5840E-12
C _{std12}	Concentration @12% CO ₂ (lb/dscf)	<6.9690E-12	8.1635E-12	<6.6437E-12	<7.2587E-12
C _a	Concentration (lb/acf)	<3.2517E-12	3.4728E-12	<3.4062E-12	<3.3769E-12
C _{std}	Concentration (µg/dscm)	<9.8672E-02	1.0578E-01	<1.0382E-01	<1.0276E-01
C _{std7}	Concentration @7% O ₂ (µg/dscm)	<1.1516E-01	1.3502E-01	<1.1417E-01	<1.2145E-01
C _{std12}	Concentration @12% CO ₂ (µg/dscm)	<1.1160E-01	1.3073E-01	<1.0639E-01	<1.1624E-01
C _{std}	Concentration (mg/dscm)	<9.8672E-05	1.0578E-04	<1.0382E-04	<1.0276E-04
C _{std7}	Concentration @7% O ₂ (mg/dscm)	<1.1516E-04	1.3502E-04	<1.1417E-04	<1.2145E-04
C _{std12}	Concentration @12% CO ₂ (mg/dscm)	<1.1160E-04	1.3073E-04	<1.0639E-04	<1.1624E-04
C _a	Concentration (µg/m ³ (actual,wet))	<5.2072E-02	5.5611E-02	<5.4546E-02	<5.4077E-02
C _{std}	Concentration (µg/Nm ³ dry)	<1.0589E-01	1.1352E-01	<1.1141E-01	<1.1028E-01
C _{std7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<1.2358E-01	1.4490E-01	<1.2252E-01	<1.3033E-01
C _{std12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<1.1976E-01	1.4029E-01	<1.1417E-01	<1.2474E-01
E _{lb/hr}	Rate (lb/hr)	<3.4289E-05	3.5495E-05	<3.5078E-05	<3.4954E-05
E _{g/s}	Rate (g/s)	<4.3196E-06	4.4715E-06	<4.4190E-06	<4.4034E-06
E _{T/yr}	Rate (Ton/yr)	<1.5018E-04	1.5547E-04	<1.5364E-04	<1.5310E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<1.0348E-07	1.2132E-07	<1.0259E-07	<1.0913E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<1.0570E-07	1.2381E-07	<1.0076E-07	<1.1009E-07

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Method 5/29
 Lead (Pb) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 12	Mar 12	Mar 12	
Start Time (approx.)	06:29	08:58	11:39	
Stop Time (approx.)	08:40	11:20	13:49	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	184.6	183.7	184.3	184.2
P ₁ Fabric Filter Inlet Temperature (°F)	321	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.9900	10.0100	8.2600	9.0867
CO ₂ Carbon dioxide (dry volume %)	10.6100	9.7100	11.7100	10.6767
T _s Sample temperature (°F)	310.6400	310.7600	311.1200	310.8400
B _w Actual water vapor in gas (% by volume)	21.6482	21.9337	21.9457	21.8425
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	175,746	170,351	171,635	172,577
Q _s Volumetric flow rate, standard (scfm)	118,372	114,720	115,531	116,208
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,746	89,558	90,177	90,827
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	79,468	70,164	82,003	77,212
Q _a Volumetric flow rate, actual (acf/hr)	10,544,732	10,221,033	10,298,111	10,354,625
Q _s Volumetric flow rate, standard (scf/hr)	7,102,302	6,883,206	6,931,875	6,972,461
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,564,783	5,373,461	5,410,626	5,449,624
Q _a Volumetric flow rate, actual (m ³ /hr)	298,633	289,466	291,649	293,249
Q _s Volumetric flow rate, standard (m ³ /hr)	201,141	194,936	196,315	197,464
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	157,598	152,180	153,232	154,337
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	135,035	119,226	139,342	131,201
Q _s Volumetric flow rate, normal (Nm ³ /hr)	187,427	181,645	182,930	184,001
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	146,853	141,804	142,784	143,814
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	125,828	111,097	129,841	122,255
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.5708	67.6848	68.0226	69.0927
%I Isokinetic sampling (%)	100.9176	98.8364	98.6473	99.4671
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.5592	0.8264	0.5117	
Lead Results - Total				
C _{sd} Concentration (lb/dscf)	1.7229E-11	2.6922E-11	1.6589E-11	2.0246E-11
C _{sd7} Concentration @7% O ₂ (lb/dscf)	2.0107E-11	3.4363E-11	1.8242E-11	2.4238E-11
C _{sd12} Concentration @12% CO ₂ (lb/dscf)	1.9486E-11	3.3271E-11	1.6999E-11	2.3252E-11
C _a Concentration (lb/acf)	9.0921E-12	1.4154E-11	8.7157E-12	1.0654E-11
C _{sd} Concentration (µg/dscm)	2.7589E-01	4.3112E-01	2.6564E-01	3.2422E-01
C _{sd7} Concentration @7% O ₂ (µg/dscm)	3.2199E-01	5.5028E-01	2.9212E-01	3.8813E-01
C _{sd12} Concentration @12% CO ₂ (µg/dscm)	3.1204E-01	5.3279E-01	2.7222E-01	3.7235E-01
C _{sd} Concentration (mg/dscm)	2.7589E-04	4.3112E-04	2.6564E-04	3.2422E-04
C _{sd7} Concentration @7% O ₂ (mg/dscm)	3.2199E-04	5.5028E-04	2.9212E-04	3.8813E-04
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	3.1204E-04	5.3279E-04	2.7222E-04	3.7235E-04
C _a Concentration (µg/m ³ (actual,wet))	1.4560E-01	2.2665E-01	1.3957E-01	1.7061E-01
C _{sd} Concentration (µg/Nm ³ dry)	2.9608E-01	4.6266E-01	2.8508E-01	3.4794E-01
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	3.4555E-01	5.9054E-01	3.1350E-01	4.1653E-01
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	3.3487E-01	5.7178E-01	2.9214E-01	3.9960E-01
E _{lb/hr} Rate (lb/hr)	9.5873E-05	1.4466E-04	8.9755E-05	1.1010E-04
E _{g/s} Rate (g/s)	1.2078E-05	1.8224E-05	1.1307E-05	1.3870E-05
E _{T/yr} Rate (Ton/yr)	4.1992E-04	6.3363E-04	3.9313E-04	4.8223E-04
E _{Fd} Rate - Fd-based (lb/MMBtu)	2.8933E-07	4.9447E-07	2.6250E-07	3.4876E-07
E _{Fc} Rate - Fc-based (lb/MMBtu)	2.9553E-07	5.0461E-07	2.5782E-07	3.5266E-07

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Method 13B (Total Fluorides)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	07:30	11:28	13:12	
Stop Time (approx.)	08:48	12:46	14:24	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9886	0.9886	0.9886	
C _p Pitot tube coefficient	0.8250	0.8250	0.8250	
P _g Static pressure (in. H ₂ O)	-9.5000	-9.5000	-9.5000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.20	30.20	30.20	30.2000
D _n Nozzle diameter (in.)	0.2720	0.2720	0.2720	
O ₂ Oxygen (dry volume %)	8.3900	9.2000	9.0500	8.8800
CO ₂ Carbon dioxide (dry volume %)	10.8100	10.7100	10.7600	10.7600
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.8000	80.0900	80.1900	80.3600
V _{lc} Total Liquid collected (ml)	237.20	220.20	240.20	
V _m Volume metered, meter conditions (ft ³)	38.7760	38.3400	41.5450	
T _m Dry gas meter temperature (°F)	78.5000	89.7600	103.3000	
T _s Sample temperature (°F)	317.8400	311.8000	313.5200	314.3867
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.3000	1.1968	1.3840	
θ Total sampling time (min)	62.5	62.5	62.5	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	11.1626	10.3626	11.3038	10.9430
V _{mstd} Volume metered, standard (dscf)	38.0431	36.8357	38.9732	37.9507
P _s Sample gas pressure, absolute (in. Hg)	29.5015	29.5015	29.5015	29.5015
P _v Vapor pressure, actual (in. Hg)	29.5015	29.5015	29.5015	29.5015
B _{w0} Moisture measured in sample (% by volume)	22.6856	21.9555	22.4831	22.3747
B _{w0s} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	22.6856	21.9555	22.4831	22.3747
√ΔP Velocity head (√in. H ₂ O)	0.7102	0.6951	0.7313	0.7122
M _d MW of sample gas, dry (lb/lb-mole)	30.0652	30.0816	30.0836	30.0768
M _w MW of sample gas, wet (lb/lb-mole)	27.3281	27.4290	27.3668	27.3747
V _s Velocity of sample (ft/sec)	49.1973	47.8804	50.4853	49.1877
%I Isokinetic sampling (%)	98.8115	96.6310	97.8406	97.7610
Q _a Volumetric flow rate, actual (acfm)	188,918	183,861	193,864	188,881
Q _s Volumetric flow rate, standard (scfm)	126,444	124,022	130,479	126,982
Q _{std} Volumetric flow rate, dry standard (dscfm)	97,759	96,793	101,143	98,565
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	87,983	81,473	86,227	85,228
Q _a Volumetric flow rate, actual (acf/hr)	11,335,063	11,031,640	11,631,817	11,332,840
Q _s Volumetric flow rate, standard (scf/hr)	7,586,644	7,441,343	7,828,743	7,618,910
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,865,565	5,807,560	6,068,602	5,913,909
Q _a Volumetric flow rate, actual (m ³ /hr)	321,016	312,423	329,420	320,953
Q _s Volumetric flow rate, standard (m ³ /hr)	214,858	210,743	221,715	215,772
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	166,116	164,474	171,866	167,485
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	149,505	138,442	146,519	144,822
Q _s Volumetric flow rate, normal (Nm ³ /hr)	200,209	196,374	206,598	201,060
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	154,790	153,259	160,148	156,066
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	139,311	129,003	136,529	134,948

Comments:

Average includes 3 runs.

041400 122414
 ILL@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Method 13B
 HF Parameters**

Run No.	1	2	3	Average	
Date (2009)	Mar 11	Mar 11	Mar 11		
Start Time (approx.)	07:30	11:28	13:12		
Stop Time (approx.)	08:48	12:46	14:24		
Process Conditions					
R _p	Steam Production Rate (Klbs/hour)	184.4	184.0	183.5	184.0
P ₁	Fabric Filter Inlet Temperature (°F)	330	320	320	323
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.3900	9.2000	9.0500	8.8800
CO ₂	Carbon dioxide (dry volume %)	10.8100	10.7100	10.7600	10.7600
T _s	Sample temperature (°F)	317.8400	311.8000	313.5200	314.3867
B _w	Actual water vapor in gas (% by volume)	22.6856	21.9555	22.4831	22.3747
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	188,918	183,861	193,864	188,881
Q _s	Volumetric flow rate, standard (scfm)	126,444	124,022	130,479	126,982
Q _{std}	Volumetric flow rate, dry standard (dscfm)	97,759	96,793	101,143	98,565
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	87,983	81,473	86,227	85,228
Q _a	Volumetric flow rate, actual (acf/hr)	11,335,063	11,031,640	11,631,817	11,332,840
Q _s	Volumetric flow rate, standard (scf/hr)	7,586,644	7,441,343	7,828,743	7,618,910
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,865,565	5,807,560	6,068,602	5,913,909
Q _a	Volumetric flow rate, actual (m ³ /hr)	321,016	312,423	329,420	320,953
Q _s	Volumetric flow rate, standard (m ³ /hr)	214,858	210,743	221,715	215,772
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	166,116	164,474	171,866	167,485
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	149,505	138,442	146,519	144,822
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	200,209	196,374	206,598	201,060
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	154,790	153,259	160,148	156,066
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	139,311	129,003	136,529	134,948
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	38.0431	36.8357	38.9732	37.9507
%I	Isokinetic sampling (%)	98.8115	96.6310	97.8406	97.7610
Laboratory Data					
m _n	Total HF collected (mg)	<0.0246	<0.0235	<0.0242	
Hydrogen Fluoride (HF) Results					
C _{sd}	HF Concentration (lb/dscf)	<1.4282E-09	<1.4045E-09	<1.3693E-09	<1.4007E-09
C _{sd7}	HF Concentration @7% O ₂ (lb/dscf)	<1.5868E-09	<1.6686E-09	<1.6062E-09	<1.6205E-09
C _{sd12}	HF Concentration @12% CO ₂ (lb/dscf)	<1.5854E-09	<1.5737E-09	<1.5271E-09	<1.5620E-09
C _a	HF Concentration (lb/acf)	<7.3903E-10	<7.3939E-10	<7.1439E-10	<7.3094E-10
C _{sd}	HF Concentration (ppmdv)	<0.0275	<0.0271	<0.0264	<0.0270
C _{sd7}	HF Concentration @7% O ₂ (ppmdv)	<0.0306	<0.0322	<0.0309	<0.0312
C _{sd12}	HF Concentration @12% CO ₂ (ppmdv)	<0.0305	<0.0303	<0.0294	<0.0301
C _w	HF Concentration (ppmvv)	<0.0213	<0.0211	<0.0205	<0.0209
C _{sd}	HF Concentration (mg/dscm)	<0.0229	<0.0225	<0.0219	<0.0224
C _{sd7}	HF Concentration @7% O ₂ (mg/dscm)	<0.0254	<0.0267	<0.0257	<0.0260
C _{sd12}	HF Concentration @12% CO ₂ (mg/dscm)	<0.0254	<0.0252	<0.0245	<0.0250
C _a	HF Concentration (mg/m ³ (actual,wet))	<0.0118	<0.0118	<0.0114	<0.0117
C _{sd}	HF Concentration (mg/Nm ³ dry)	<0.0245	<0.0241	<0.0235	<0.0241
C _{sd7}	HF Concentration @7% O ₂ (mg/Nm ³ dry)	<0.0273	<0.0287	<0.0276	<0.0278
C _{sd12}	HF Concentration @12% CO ₂ (mg/Nm ³ dry)	<0.0272	<0.0270	<0.0262	<0.0268
E _{lb/hr}	HF Rate (lb/hr)	<0.0084	<0.0082	<0.0083	<0.0083
E _{kg/hr}	HF Rate (kg/hr)	<0.0038	<0.0037	<0.0038	<0.0038
E _{T/yr}	HF Rate (Ton/yr)	<0.0367	<0.0357	<0.0364	<0.0363
E _{Fd}	HF Rate - Fd-based (lb/MMBtu)	<0.000023	<0.000024	<0.000023	<0.000023
E _{Fc}	HF Rate - Fc-based (lb/MMBtu)	<0.000024	<0.000024	<0.000023	<0.000024

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 SDA Inlet

USEPA Method 26A (HCI) Sampling, Velocity and Moisture Parameters

Run No.	1	2	3	Average
Date (2009)	Mar 10	Mar 10	Mar 10	
Start Time (approx.)	06:51	08:38	10:04	
Stop Time (approx.)	08:03	09:38	11:04	
Sampling Conditions				
Y_d Dry gas meter correction factor	1.0028	1.0028	1.0028	
P_g Static pressure (in. H ₂ O)	-2.1000	-2.1000	-2.1000	
A_s Sample location area (ft ²)	60.1320	60.1320	60.1320	
P_{bar} Barometric pressure (in. Hg)	30.25	30.25	30.25	30.2500
O_2 Oxygen (dry volume %)	7.1900	9.1500	8.3600	8.2333
CO_2 Carbon dioxide (dry volume %)	12.1300	10.4500	11.3000	11.2933
N_2+CO Nitrogen plus carbon monoxide (dry volume %)	80.6800	80.4000	80.3400	80.4733
V_{lc} Total Liquid collected (ml)	177.70	149.60	150.00	
V_m Volume metered, meter conditions (ft ³)	34.2000	33.7900	32.8700	
T_m Dry gas meter temperature (°F)	71.0833	78.7500	85.0833	
T_s Sample temperature (°F)	503.1667	508.0833	508.3333	506.5278
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.2167	1.1108	1.0858	
θ Total sampling time (min)	60.0	60.0	60.0	
Flow Results.				
V_{wstd} Volume of water collected (ft ³)	8.3626	7.0402	7.0590	7.4872
V_{mstd} Volume metered, standard (dscf)	34.5608	33.6520	32.3534	33.5221
P_s Sample gas pressure, absolute (in. Hg)	30.0956	30.0956	30.0956	30.0956
P_v Vapor pressure, actual (in. Hg)	30.0956	30.0956	30.0956	30.0956
B_{wo} Moisture measured in sample (% by volume)	19.4825	17.3011	17.9106	18.2314
B_{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B_w Actual water vapor in gas (% by volume)	19.4825	17.3011	17.9106	18.2314
M_d MW of sample gas, dry (lb/lb-mole)	30.2284	30.0380	30.1424	30.1363
M_s MW of sample gas, wet (lb/lb-mole)	27.8460	27.9553	27.9676	27.9230

Comments:

Average includes 3 runs.

041409 122626
 JNL@

USEPA Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 10	Mar 10	Mar 10	
Start Time (approx.)		06:51	08:38	10:04	
Stop Time (approx.)		08:03	09:38	11:04	
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	184.6	183.8	184.1	184.2
P ₁	Fabric Filter Inlet Temperature (°F)	319	322	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	7.1900	9.1500	8.3600	8.2333
CO ₂	Carbon dioxide (dry volume %)	12.1300	10.4500	11.3000	11.2933
T _s	Sample temperature (°F)	503.1667	508.0833	508.3333	506.5278
B _w	Actual water vapor in gas (% by volume)	19.4825	17.3011	17.9106	18.2314
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	34.5608	33.6520	32.3534	33.5221
Laboratory Data					
m _n	Total HCl collected (mg)	510.8082	510.6186	584.4054	
Hydrogen Chloride (HCl) Results					
C _{sd}	HCl Concentration (lb/dscf)	3.2590E-05	3.3458E-05	3.9829E-05	3.5292E-05
C _{sd7}	HCl Concentration @7% O ₂ (lb/dscf)	3.3041E-05	3.9580E-05	4.4149E-05	3.8923E-05
C _{sd12}	HCl Concentration @12% CO ₂ (lb/dscf)	3.2241E-05	3.8420E-05	4.2297E-05	3.7652E-05
C _{sd}	HCl Concentration (ppmdv)	344.5593	353.7339	421.0995	373.1309
C _{sd7}	HCl Concentration @7% O ₂ (ppmdv)	349.3344	418.4597	466.7690	411.5210
C _{sd12}	HCl Concentration @12% CO ₂ (ppmdv)	340.8666	406.2016	447.1853	398.0845
C _w	HCl Concentration (ppmwv)	277.4305	292.5341	345.6780	305.2142
C _{sd}	HCl Concentration (mg/dscm)	521.8809	535.7770	637.8112	565.1563
C _{sd7}	HCl Concentration @7% O ₂ (mg/dscm)	529.1134	633.8128	706.9837	623.3033
C _{sd12}	HCl Concentration @12% CO ₂ (mg/dscm)	516.2878	615.2463	677.3216	602.9519
C _{sd}	HCl Concentration (mg/Nm ³ dry)	560.0673	574.9802	684.4803	606.5092
C _{sd7}	HCl Concentration @7% O ₂ (mg/Nm ³ dry)	567.8290	680.1893	758.7142	668.9108
C _{sd12}	HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	554.0649	660.2643	726.8817	647.0703
E _{Fd}	HCl Rate - Fd-based (lb/MMBtu)	0.4754	0.5695	0.6353	0.5601
E _{Fc}	HCl Rate - Fc-based (lb/MMBtu)	0.4890	0.5827	0.6415	0.5711

041509 090126
 JNL @ _ @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

USEPA Modified Method 26A (HCI) Sampling, Velocity and Moisture Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 10	Mar 10	Mar 10	
Start Time (approx.)		06:51	08:38	10:04	
Stop Time (approx.)		08:03	09:38	11:04	
Sampling Conditions					
Y_d	Dry gas meter correction factor	0.9886	0.9886	0.9886	
C_p	Pitot tube coefficient	0.8400	0.8400	0.8400	
P_g	Static pressure (in. H ₂ O)	-9.0000	-9.0000	-9.0000	
A_s	Sample location area (ft ²)	64.0000	64.0000	64.0000	
P_{bar}	Barometric pressure (in. Hg)	30.25	30.25	30.25	30.2500
O_2	Oxygen (dry volume %)	8.7800	9.5500	9.0000	9.1100
CO_2	Carbon dioxide (dry volume %)	10.6600	10.0600	10.6700	10.4633
N_2+CO	Nitrogen plus carbon monoxide (dry volume %)	80.5600	80.3900	80.3300	80.4267
V_{lc}	Total Liquid collected (ml)	256.50	229.20	237.10	
V_m	Volume metered, meter conditions (ft ³)	40.6850	40.9150	41.4450	
T_m	Dry gas meter temperature (°F)	75.7917	86.4167	95.8750	
T_s	Sample temperature (°F)	311.5000	312.6667	312.7500	312.3056
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.5000	1.5000	1.5000	
θ	Total sampling time (min)	60.0	60.0	60.0	
Flow Results					
V_{wstd}	Volume of water collected (ft ³)	12.0709	10.7862	11.1579	11.3383
V_{mstd}	Volume metered, standard (dscf)	40.2035	39.6446	39.4748	39.7743
P_s	Sample gas pressure, absolute (in. Hg)	29.5882	29.5882	29.5882	29.5882
P_v	Vapor pressure, actual (in. Hg)	29.5882	29.5882	29.5882	29.5882
B_{wo}	Moisture measured in sample (% by volume)	23.0914	21.3881	22.0370	22.1721
B_{ws}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B_w	Actual water vapor in gas (% by volume)	23.0914	21.3881	22.0370	22.1721
M_d	MW of sample gas, dry (lb/lb-mole)	30.0568	29.9916	30.0672	30.0385
M_s	MW of sample gas, wet (lb/lb-mole)	27.2727	27.4268	27.4080	27.3692

Comments:

Average includes 3 runs.

041409 122712
 LKP@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

USEPA Modified Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 10	Mar 10	Mar 10	
Start Time (approx.)		06:51	08:38	10:04	
Stop Time (approx.)		08:03	09:38	11:04	
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	184.6	183.8	184.1	184.2
P ₁	Fabric Filter Inlet Temperature (°F)	319	322	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.7800	9.5500	9.0000	9.1100
CO ₂	Carbon dioxide (dry volume %)	10.6600	10.0600	10.6700	10.4633
T _s	Sample temperature (°F)	311.5000	312.6667	312.7500	312.3056
B _w	Actual water vapor in gas (% by volume)	23.0914	21.3881	22.0370	22.1721
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	40.2035	39.6446	39.4748	39.7743
Laboratory Data					
m _n	Total HCl collected (mg)	30.4028	20.3235	17.7085	
Hydrogen Chloride (HCl) Results					
C _{sd}	HCl Concentration (lb/dscf)	1.6675E-06	1.1304E-06	9.8917E-07	1.2623E-06
C _{sd7}	HCl Concentration @7% O ₂ (lb/dscf)	1.9124E-06	1.3843E-06	1.1554E-06	1.4840E-06
C _{sd12}	HCl Concentration @12% CO ₂ (lb/dscf)	1.8771E-06	1.3484E-06	1.1125E-06	1.4460E-06
C _{sd}	HCl Concentration (ppmdv)	17.6295	11.9510	10.4581	13.3462
C _{sd7}	HCl Concentration @7% O ₂ (ppmdv)	20.2187	14.6361	12.2158	15.6902
C _{sd12}	HCl Concentration @12% CO ₂ (ppmdv)	19.8456	14.2557	11.7617	15.2877
C _w	HCl Concentration (ppmwv)	13.5586	9.3949	8.1535	10.3690
C _{sd}	HCl Concentration (mg/dscm)	26.7022	18.1014	15.8402	20.2146
C _{sd7}	HCl Concentration @7% O ₂ (mg/dscm)	30.6239	22.1682	18.5024	23.7648
C _{sd12}	HCl Concentration @12% CO ₂ (mg/dscm)	30.0588	21.5921	17.8146	23.1552
C _{sd}	HCl Concentration (mg/Nm ³ dry)	28.6561	19.4259	16.9992	21.6937
C _{sd7}	HCl Concentration @7% O ₂ (mg/Nm ³ dry)	32.8646	23.7903	19.8562	25.5037
C _{sd12}	HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	32.2582	23.1721	19.1182	24.8495
E _{Fd}	HCl Rate - Fd-based (lb/MMBtu)	0.0275	0.0199	0.0166	0.0214
E _{Fc}	HCl Rate - Fc-based (lb/MMBtu)	0.0285	0.0205	0.0169	0.0219

041409 122712
 L K P @ . @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	
Sampling Conditions				
Y_d	Dry gas meter correction factor	1.0079	1.0079	1.0079
C_p	Pitot tube coefficient	0.8120	0.8120	0.8120
P_g	Static pressure (in. H ₂ O)	-10.5000	-10.5000	-10.5000
A_s	Sample location area (ft ²)	64.0000	64.0000	64.0000
P_{bar}	Barometric pressure (in. Hg)	30.20	30.20	30.20
D_n	Nozzle diameter (in.)	0.2680	0.2680	0.2680
O_2	Oxygen (dry volume %)	8.7600	8.9900	8.7500
CO_2	Carbon dioxide (dry volume %)	10.5600	10.8800	11.0700
N_2+CO	Nitrogen plus carbon monoxide (dry volume %)	80.6800	80.1300	80.1800
V_{lc}	Total Liquid collected (ml)	380.40	397.10	392.70
V_m	Volume metered, meter conditions (ft ³)	70.9500	75.1250	73.3650
T_m	Dry gas meter temperature (°F)	73.1200	79.7400	94.1800
T_s	Sample temperature (°F)	307.5600	307.8000	310.4800
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.0416	1.1316	1.0744
θ	Total sampling time (min)	125.0	125.0	125.0
Flow Results				
V_{wstd}	Volume of water collected (ft ³)	17.9016	18.6875	18.4805
V_{mstd}	Volume metered, standard (dscf)	71.6391	74.9407	71.2682
P_s	Sample gas pressure, absolute (in. Hg)	29.4279	29.4279	29.4279
P_v	Vapor pressure, actual (in. Hg)	29.4279	29.4279	29.4279
B_{wo}	Moisture measured in sample (% by volume)	19.9927	19.9593	20.5914
B_{we}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000
B_w	Actual water vapor in gas (% by volume)	19.9927	19.9593	20.5914
$\sqrt{\Delta P}$	Velocity head ($\sqrt{\text{in. H}_2\text{O}}$)	0.6567	0.6776	0.6568
M_d	MW of sample gas, dry (lb/lb-mole)	30.0400	30.1004	30.1212
M_w	MW of sample gas, wet (lb/lb-mole)	27.6329	27.6852	27.6253
V_s	Velocity of sample (ft/sec)	44.2921	45.6597	44.3855
%I	Isokinetic sampling (%)	101.7587	103.2492	102.1675
Q_a	Volumetric flow rate, actual (acfm)	170,082	175,333	170,440
Q_s	Volumetric flow rate, standard (scfm)	115,074	118,590	114,880
Q_{std}	Volumetric flow rate, dry standard (dscfm)	92,068	94,920	91,224
Q_{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	80,410	81,331	79,739
Q_a	Volumetric flow rate, actual (acf/hr)	10,204,907	10,519,996	10,226,424
Q_s	Volumetric flow rate, standard (scf/hr)	6,904,448	7,115,406	6,892,783
Q_{std}	Volumetric flow rate, dry standard (dscf/hr)	5,524,062	5,695,222	5,473,466
Q_a	Volumetric flow rate, actual (m ³ /hr)	289,009	297,932	289,618
Q_s	Volumetric flow rate, standard (m ³ /hr)	195,538	201,512	195,208
Q_{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	156,445	161,292	155,012
Q_{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	136,636	138,201	135,496
Q_n	Volumetric flow rate, normal (Nm ³ /hr)	182,206	187,773	181,898
Q_{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	145,778	150,295	144,443
Q_{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	127,320	128,778	126,258

Comments:

Average includes 3 runs.

041409 122843
 KPI @

**USEPA Method 5/29
 Filterable Particulate Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	184.0	184.1	184.0	184.0
P ₁ Fabric Filter Inlet Temperature (°F)	321	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.7600	8.9900	8.7500	8.8333
CO ₂ Carbon dioxide (dry volume %)	10.5600	10.8800	11.0700	10.8367
T _a Sample temperature (°F)	307.5600	307.8000	310.4800	308.6133
B _w Actual water vapor in gas (% by volume)	19.9927	19.9593	20.5914	20.1811
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	170,082	175,333	170,440	171,952
Q _s Volumetric flow rate, standard (scfm)	115,074	118,590	114,880	116,181
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,068	94,920	91,224	92,737
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	80,410	81,331	79,739	80,494
Q _a Volumetric flow rate, actual (acf/hr)	10,204,907	10,519,996	10,226,424	10,317,109
Q _s Volumetric flow rate, standard (scf/hr)	6,904,448	7,115,406	6,892,783	6,970,879
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,524,062	5,695,222	5,473,466	5,564,250
Q _a Volumetric flow rate, actual (m ³ /hr)	289,009	297,932	289,618	292,187
Q _s Volumetric flow rate, standard (m ³ /hr)	195,538	201,512	195,208	197,419
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	156,445	161,292	155,012	157,583
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	136,636	138,201	135,496	136,777
Q _s Volumetric flow rate, normal (Nm ³ /hr)	182,206	187,773	181,898	183,959
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	145,778	150,295	144,443	146,839
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	127,320	128,778	126,258	127,452
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.6391	74.9407	71.2682	72.6160
%I Isokinetic sampling (%)	101.7587	103.2492	102.1675	102.3918
Laboratory Data				
m _{filter} Matter collected on filter(s) (g)	0.00060	0.00050	0.00010	
m _a Matter collected in solvent rinse(s) (g)	0.00312	0.00070	0.00112	
m _n Total particulate matter collected (g)	0.00372	0.00120	0.00112	
Filterable Particulate Results				
C _{sd} Particulate Concentration (lb/dscf)	1.1436E-07	3.5244E-08	3.4574E-08	6.1393E-08
C _{sd7} Particulate Concentration @7% O ₂ (lb/dscf)	1.3094E-07	4.1133E-08	3.9554E-08	7.0542E-08
C _{sd12} Particulate Concentration @12% CO ₂ (lb/dscf)	1.2995E-07	3.8872E-08	3.7479E-08	6.8769E-08
C _a Particulate Concentration (lb/acf)	6.1905E-08	1.9080E-08	1.8505E-08	3.3163E-08
C _{sd} Particulate Concentration (gr/dscf)	0.0008	0.0002	0.0002	0.0004
C _{sd7} Particulate Concentration @7% O ₂ (gr/dscf)	0.0009	0.0003	0.0003	0.0005
C _{sd12} Particulate Concentration @12% CO ₂ (gr/dscf)	0.0009	0.0003	0.0003	0.0005
C _a Particulate Concentration (gr/acf)	0.0004	0.0001	0.0001	0.0002
C _{sd} Particulate Concentration (mg/dscm)	1.8313	0.5644	0.5537	0.9831
C _{sd7} Particulate Concentration @7% O ₂ (mg/dscm)	2.0968	0.6587	0.6334	1.1296
C _{sd12} Particulate Concentration @12% CO ₂ (mg/dscm)	2.0810	0.6225	0.6002	1.1012
C _a Particulate Concentration (mg/m ³ (actual,wet))	0.9913	0.3055	0.2963	0.5311
C _{sd} Particulate Concentration (mg/Nm ³ dry)	1.9653	0.6057	0.5942	1.0551
C _{sd7} Particulate Concentration @7% O ₂ (mg/Nm ³ dry)	2.2502	0.7069	0.6798	1.2123
C _{sd12} Particulate Concentration @12% CO ₂ (mg/Nm ³ dry)	2.2333	0.6680	0.6441	1.1818
E _{lb/hr} Particulate Rate (lb/hr)	0.6317	0.2007	0.1892	0.3406
E _{kg/hr} Particulate Rate (kg/hr)	0.2865	0.0910	0.0858	0.1545
E _{T/yr} Particulate Rate (Ton/yr)	2.7670	0.8792	0.8289	1.4917
E _{Fd} Particulate Rate - F _d -based (lb/MMBtu)	0.0019	0.0006	0.0006	0.0010
E _{Fc} Particulate Rate - F _c -based (lb/MMBtu)	0.0020	0.0006	0.0006	0.0010

Comments:

Average includes 3 runs.

041408 123458
 K P I @ _ H

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	184.0	184.1	184.0	184.0
P ₁ Fabric Filter Inlet Temperature (°F)	321	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.7600	8.9900	8.7500	8.8333
CO ₂ Carbon dioxide (dry volume %)	10.5600	10.8800	11.0700	10.8367
T _s Sample temperature (°F)	307.5600	307.8000	310.4800	308.6133
B _w Actual water vapor in gas (% by volume)	19.9927	19.9593	20.5914	20.1811
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	170,082	175,333	170,440	171,952
Q _s Volumetric flow rate, standard (scfm)	115,074	118,590	114,880	116,181
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,068	94,920	91,224	92,737
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	80,410	81,331	79,739	80,494
Q _a Volumetric flow rate, actual (acf/hr)	10,204,907	10,519,996	10,226,424	10,317,109
Q _s Volumetric flow rate, standard (scf/hr)	6,904,448	7,115,406	6,892,783	6,970,879
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,524,062	5,695,222	5,473,466	5,564,250
Q _a Volumetric flow rate, actual (m ³ /hr)	289,009	297,932	289,618	292,187
Q _s Volumetric flow rate, standard (m ³ /hr)	195,538	201,512	195,208	197,419
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	156,445	161,292	155,012	157,583
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	136,636	138,201	135,496	136,777
Q _s Volumetric flow rate, normal (Nm ³ /hr)	182,206	187,773	181,898	183,959
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	145,778	150,295	144,443	146,839
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	127,320	128,778	126,258	127,452
Sampling Data				
V _{std} Volume metered, standard (dscf)	71.6391	74.9407	71.2682	72.6160
%I Isokinetic sampling (%)	101.7587	103.2492	102.1675	102.3918
Laboratory Data				
m _{n-1b} Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	
m _{n-2b} Fraction 2B (µg)	11.5809	8.1043	6.8887	
m _{n-3a} Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m _{n-3b} Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m _{n-3c} Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	
m _n Total matter corrected for allowable blanks (µg)	11.5809	8.1043	6.8887	
Mercury Results - Total				
C _{std} Concentration (lb/dscf)	3.5645E-10	2.3845E-10	2.1313E-10	2.6935E-10
C _{std7} Concentration @7% O ₂ (lb/dscf)	4.0813E-10	2.7830E-10	2.4383E-10	3.1009E-10
C _{std12} Concentration @12% CO ₂ (lb/dscf)	4.0506E-10	2.6300E-10	2.3104E-10	2.9970E-10
C _a Concentration (lb/acf)	1.9295E-10	1.2909E-10	1.1408E-10	1.4537E-10
C _{std} Concentration (µg/dscm)	5.7081E+00	3.8185E+00	3.4130E+00	4.3132E+00
C _{std7} Concentration @7% O ₂ (µg/dscm)	6.5356E+00	4.4565E+00	3.9046E+00	4.9656E+00
C _{std12} Concentration @12% CO ₂ (µg/dscm)	6.4865E+00	4.2116E+00	3.6998E+00	4.7993E+00
C _{std} Concentration (mg/dscm)	5.7081E-03	3.8185E-03	3.4130E-03	4.3132E-03
C _{std7} Concentration @7% O ₂ (mg/dscm)	6.5356E-03	4.4565E-03	3.9046E-03	4.9656E-03
C _{std12} Concentration @12% CO ₂ (mg/dscm)	6.4865E-03	4.2116E-03	3.6998E-03	4.7993E-03
C _a Concentration (µg/m ³ (actual,wet))	3.0899E+00	2.0672E+00	1.8268E+00	2.3279E+00
C _{std} Concentration (µg/Nm ³ dry)	6.1257E+00	4.0979E+00	3.6628E+00	4.6288E+00
C _{std7} Concentration @7% O ₂ (µg/Nm ³ dry)	7.0138E+00	4.7826E+00	4.1903E+00	5.3289E+00
C _{std12} Concentration @12% CO ₂ (µg/Nm ³ dry)	6.9611E+00	4.5197E+00	3.9705E+00	5.1504E+00
E _{lb/hr} Rate (lb/hr)	1.9691E-03	1.3580E-03	1.1666E-03	1.4979E-03
E _{g/s} Rate (g/s)	2.4806E-04	1.7108E-04	1.4696E-04	1.8870E-04
E _{T/yr} Rate (Ton/yr)	8.6245E-03	5.9482E-03	5.1096E-03	6.5608E-03
E _{Fd} Rate - Fd-based (lb/MMBtu)	5.8727E-06	4.0045E-06	3.5086E-06	4.4620E-06
E _{Fc} Rate - Fc-based (lb/MMBtu)	6.1434E-06	3.9888E-06	3.5041E-06	4.5454E-06

041409 123459
 KPI @_O

Prepared by Clean Air Engineering Proprietary Software
 SS Metals-1 Version 2005-12a

Copyright © 2008 Clean Air Engineering Inc.

QA/QC _____
 Date _____

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Front Half Results**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	

Mercury Results - Front Half

C _{sd}	Concentration (lb/dscf)	<3.0779E-12	<2.9423E-12	<3.0939E-12	<3.0381E-12
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<3.5241E-12	<3.4339E-12	<3.5396E-12	<3.4992E-12
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<3.4976E-12	<3.2452E-12	<3.3539E-12	<3.3656E-12
C _a	Concentration (lb/acf)	<1.6661E-12	<1.5929E-12	<1.6560E-12	<1.6383E-12
C _{sd}	Concentration (µg/dscm)	<4.9289E-02	<4.7117E-02	<4.9545E-02	<4.8650E-02
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<5.6434E-02	<5.4990E-02	<5.6681E-02	<5.6035E-02
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<5.6010E-02	<5.1968E-02	<5.3708E-02	<5.3895E-02
C _{sd}	Concentration (mg/dscm)	<4.9289E-05	<4.7117E-05	<4.9545E-05	<4.8650E-05
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<5.6434E-05	<5.4990E-05	<5.6681E-05	<5.6035E-05
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<5.6010E-05	<5.1968E-05	<5.3708E-05	<5.3895E-05
C _a	Concentration (µg/m ³ (actual,wet))	<2.6681E-02	<2.5508E-02	<2.6518E-02	<2.6236E-02
C _{sd}	Concentration (µg/Nm ³ dry)	<5.2895E-02	<5.0565E-02	<5.3171E-02	<5.2210E-02
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<6.0564E-02	<5.9014E-02	<6.0829E-02	<6.0135E-02
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<6.0108E-02	<5.5770E-02	<5.7637E-02	<5.7839E-02
E _{lb/hr}	Rate (lb/hr)	<1.7003E-05	<1.6757E-05	<1.6935E-05	<1.6898E-05
E _{g/s}	Rate (g/s)	<2.1419E-06	<2.1110E-06	<2.1334E-06	<2.1288E-06
E _{T/yr}	Rate (Ton/yr)	<7.4472E-05	<7.3397E-05	<7.4174E-05	<7.4014E-05
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<5.0710E-08	<4.9413E-08	<5.0932E-08	<5.0352E-08
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<5.3048E-08	<4.9219E-08	<5.0867E-08	<5.1045E-08

041409 123459
 K P I @ _ 0

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	

Mercury Results - Impingers 1-3 Solution

C _{sd}	Concentration (lb/dscf)	3.5645E-10	2.3845E-10	2.1313E-10	2.6935E-10
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	4.0813E-10	2.7830E-10	2.4383E-10	3.1009E-10
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	4.0506E-10	2.6300E-10	2.3104E-10	2.9970E-10
C _a	Concentration (lb/acf)	1.9295E-10	1.2909E-10	1.1408E-10	1.4537E-10
C _{sd}	Concentration (µg/dscm)	5.7081E+00	3.8185E+00	3.4130E+00	4.3132E+00
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	6.5356E+00	4.4565E+00	3.9046E+00	4.9656E+00
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	6.4865E+00	4.2116E+00	3.6998E+00	4.7993E+00
C _{sd}	Concentration (mg/dscm)	5.7081E-03	3.8185E-03	3.4130E-03	4.3132E-03
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	6.5356E-03	4.4565E-03	3.9046E-03	4.9656E-03
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	6.4865E-03	4.2116E-03	3.6998E-03	4.7993E-03
C _a	Concentration (µg/m ³ (actual,wet))	3.0899E+00	2.0672E+00	1.8268E+00	2.3279E+00
C _{sd}	Concentration (µg/Nm ³ dry)	6.1257E+00	4.0979E+00	3.6628E+00	4.6288E+00
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	7.0138E+00	4.7826E+00	4.1903E+00	5.3289E+00
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	6.9611E+00	4.5197E+00	3.9705E+00	5.1504E+00
E _{lb/hr}	Rate (lb/hr)	1.9691E-03	1.3580E-03	1.1666E-03	1.4979E-03
E _{g/s}	Rate (g/s)	2.4806E-04	1.7108E-04	1.4696E-04	1.8870E-04
E _{T/yr}	Rate (Ton/yr)	8.6245E-03	5.9482E-03	5.1096E-03	6.5608E-03
E _{Fd}	Rate - Fd-based (lb/MMBtu)	5.8727E-06	4.0045E-06	3.5086E-06	4.4620E-06
E _{Fc}	Rate - Fc-based (lb/MMBtu)	6.1434E-06	3.9888E-06	3.5041E-06	4.5454E-06

041400 125456
 K P I @ _ O

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Impinger 4 Results**

Run No.	1	2	3	Average
Date (2008)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	

Mercury Results - Impinger 4 Solution

C _{sd}	Concentration (lb/dscf)	<6.1559E-12	<5.8847E-12	<6.1879E-12	<6.0761E-12
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<7.0483E-12	<6.8679E-12	<7.0792E-12	<6.9985E-12
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<6.9953E-12	<6.4904E-12	<6.7077E-12	<6.7312E-12
C _a	Concentration (lb/acf)	<3.3323E-12	<3.1858E-12	<3.3119E-12	<3.2767E-12
C _{sd}	Concentration (µg/dscm)	<9.8577E-02	<9.4235E-02	<9.9091E-02	<9.7301E-02
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<1.1287E-01	<1.0998E-01	<1.1336E-01	<1.1207E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<1.1202E-01	<1.0394E-01	<1.0742E-01	<1.0779E-01
C _{sd}	Concentration (mg/dscm)	<9.8577E-05	<9.4235E-05	<9.9091E-05	<9.7301E-05
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<1.1287E-04	<1.0998E-04	<1.1336E-04	<1.1207E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<1.1202E-04	<1.0394E-04	<1.0742E-04	<1.0779E-04
C _a	Concentration (µg/m ³ (actual,wet))	<5.3361E-02	<5.1016E-02	<5.3036E-02	<5.2471E-02
C _{sd}	Concentration (µg/Nm ³ dry)	<1.0579E-01	<1.0113E-01	<1.0634E-01	<1.0442E-01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<1.2113E-01	<1.1803E-01	<1.2166E-01	<1.2027E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<1.2022E-01	<1.1154E-01	<1.1527E-01	<1.1568E-01
E _{lb/hr}	Rate (lb/hr)	<3.4005E-05	<3.3514E-05	<3.3869E-05	<3.3796E-05
E _{g/s}	Rate (g/s)	<4.2839E-06	<4.2220E-06	<4.2667E-06	<4.2575E-06
E _{T/yr}	Rate (Ton/yr)	<1.4894E-04	<1.4679E-04	<1.4835E-04	<1.4803E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<1.0142E-07	<9.8825E-08	<1.0186E-07	<1.0070E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<1.0610E-07	<9.8438E-08	<1.0173E-07	<1.0209E-07

041409 123459
 KP1@_O

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29
 Mercury (Hg) Emission Parameters (continued)
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	

Mercury Results - Filtered Permanganate Solution

C _{sd}	Concentration (lb/dscf)	<1.5390E-11	<1.4712E-11	<1.5470E-11	<1.5190E-11
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<1.7621E-11	<1.7170E-11	<1.7698E-11	<1.7496E-11
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<1.7488E-11	<1.6226E-11	<1.6769E-11	<1.6829E-11
C _a	Concentration (lb/acf)	<8.3306E-12	<7.9645E-12	<8.2798E-12	<8.1916E-12
C _{sd}	Concentration (µg/dscm)	<2.4644E-01	<2.3559E-01	<2.4773E-01	<2.4325E-01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<2.8217E-01	<2.7495E-01	<2.8341E-01	<2.8018E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<2.8005E-01	<2.5984E-01	<2.6854E-01	<2.6948E-01
C _{sd}	Concentration (mg/dscm)	<2.4644E-04	<2.3559E-04	<2.4773E-04	<2.4325E-04
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<2.8217E-04	<2.7495E-04	<2.8341E-04	<2.8018E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<2.8005E-04	<2.5984E-04	<2.6854E-04	<2.6948E-04
C _a	Concentration (µg/m ³ (actual,wet))	<1.3340E-01	<1.2754E-01	<1.3259E-01	<1.3118E-01
C _{sd}	Concentration (µg/Nm ³ dry)	<2.6448E-01	<2.5282E-01	<2.6585E-01	<2.6105E-01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<3.0282E-01	<2.8507E-01	<3.0414E-01	<3.0068E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<3.0054E-01	<2.7885E-01	<2.8819E-01	<2.8919E-01
E _{lb/hr}	Rate (lb/hr)	<8.5013E-05	<8.3786E-05	<8.4673E-05	<8.4491E-05
E _{g/s}	Rate (g/s)	<1.0710E-05	<1.0555E-05	<1.0667E-05	<1.0644E-05
E _{T/yr}	Rate (Ton/yr)	<3.7236E-04	<3.6698E-04	<3.7087E-04	<3.7007E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<2.5355E-07	<2.4706E-07	<2.5466E-07	<2.5176E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<2.6524E-07	<2.4610E-07	<2.5434E-07	<2.5522E-07

Mercury Results - HCl Rinse + HCl/MnO2 Precipitate

C _{sd}	Concentration (lb/dscf)	<1.2312E-11	<1.1769E-11	<1.2376E-11	<1.2152E-11
C _{sd7}	Concentration @7% O ₂ (lb/dscf)	<1.4097E-11	<1.3736E-11	<1.4158E-11	<1.3997E-11
C _{sd12}	Concentration @12% CO ₂ (lb/dscf)	<1.3991E-11	<1.2981E-11	<1.3415E-11	<1.3462E-11
C _a	Concentration (lb/acf)	<6.6645E-12	<6.3716E-12	<6.6239E-12	<6.5533E-12
C _{sd}	Concentration (µg/dscm)	<1.9715E-01	<1.8847E-01	<1.9818E-01	<1.9460E-01
C _{sd7}	Concentration @7% O ₂ (µg/dscm)	<2.2574E-01	<2.1996E-01	<2.2673E-01	<2.2414E-01
C _{sd12}	Concentration @12% CO ₂ (µg/dscm)	<2.2404E-01	<2.0787E-01	<2.1483E-01	<2.1558E-01
C _{sd}	Concentration (mg/dscm)	<1.9715E-04	<1.8847E-04	<1.9818E-04	<1.9460E-04
C _{sd7}	Concentration @7% O ₂ (mg/dscm)	<2.2574E-04	<2.1996E-04	<2.2673E-04	<2.2414E-04
C _{sd12}	Concentration @12% CO ₂ (mg/dscm)	<2.2404E-04	<2.0787E-04	<2.1483E-04	<2.1558E-04
C _a	Concentration (µg/m ³ (actual,wet))	<1.0672E-01	<1.0203E-01	<1.0607E-01	<1.0494E-01
C _{sd}	Concentration (µg/Nm ³ dry)	<2.1158E-01	<2.0226E-01	<2.1268E-01	<2.0884E-01
C _{sd7}	Concentration @7% O ₂ (µg/Nm ³ dry)	<2.4225E-01	<2.3605E-01	<2.4332E-01	<2.4054E-01
C _{sd12}	Concentration @12% CO ₂ (µg/Nm ³ dry)	<2.4043E-01	<2.2308E-01	<2.3055E-01	<2.3135E-01
E _{lb/hr}	Rate (lb/hr)	<6.8011E-05	<6.7029E-05	<6.7738E-05	<6.7593E-05
E _{g/s}	Rate (g/s)	<8.5677E-06	<8.4440E-06	<8.5334E-06	<8.5151E-06
E _{T/yr}	Rate (Ton/yr)	<2.9789E-04	<2.9359E-04	<2.9669E-04	<2.9606E-04
E _{Fd}	Rate - Fd-based (lb/MMBtu)	<2.0284E-07	<1.9765E-07	<2.0373E-07	<2.0141E-07
E _{Fc}	Rate - Fc-based (lb/MMBtu)	<2.1219E-07	<1.9688E-07	<2.0347E-07	<2.0416E-07

041409 123459
 XPI@_0

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29
 Beryllium (Be) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	184.0	184.1	184.0	184.0
P ₁ Fabric Filter Inlet Temperature (°F)	321	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.7600	8.9900	8.7500	8.8333
CO ₂ Carbon dioxide (dry volume %)	10.5600	10.8800	11.0700	10.8367
T _s Sample temperature (°F)	307.5600	307.8000	310.4800	308.6133
B _w Actual water vapor in gas (% by volume)	19.9927	19.9593	20.5914	20.1811
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	170,082	175,333	170,440	171,952
Q _s Volumetric flow rate, standard (scfm)	115,074	118,590	114,880	116,181
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,068	94,920	91,224	92,737
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	80,410	81,331	79,739	80,494
Q _a Volumetric flow rate, actual (acf/hr)	10,204,907	10,519,996	10,226,424	10,317,109
Q _s Volumetric flow rate, standard (scf/hr)	6,904,448	7,115,406	6,892,783	6,970,879
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,524,062	5,695,222	5,473,466	5,564,250
Q _a Volumetric flow rate, actual (m ³ /hr)	289,009	297,932	289,618	292,187
Q _s Volumetric flow rate, standard (m ³ /hr)	195,538	201,512	195,208	197,419
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	156,445	161,292	155,012	157,583
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	136,636	138,201	135,496	136,777
Q _s Volumetric flow rate, normal (Nm ³ /hr)	182,206	187,773	181,898	183,959
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	145,778	150,295	144,443	146,839
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	127,320	128,778	126,258	127,452
Sampling Data				
V _{std} Volume metered, standard (dscf)	71.6391	74.9407	71.2682	72.6160
%I Isokinetic sampling (%)	101.7587	103.2492	102.1675	102.3918
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
Beryllium Results - Total				
C _{sd} Concentration (lb/dscf)	<1.5390E-12	<1.4712E-12	<1.5470E-12	<1.5190E-12
C _{sd7} Concentration @7% O ₂ (lb/dscf)	<1.7621E-12	<1.7170E-12	<1.7698E-12	<1.7496E-12
C _{sd12} Concentration @12% CO ₂ (lb/dscf)	<1.7488E-12	<1.6226E-12	<1.6769E-12	<1.6828E-12
C _a Concentration (lb/acf)	<8.3306E-13	<7.9645E-13	<8.2798E-13	<8.1916E-13
C _{sd} Concentration (µg/dscm)	<2.4644E-02	<2.3559E-02	<2.4773E-02	<2.4325E-02
C _{sd7} Concentration @7% O ₂ (µg/dscm)	<2.8217E-02	<2.7495E-02	<2.8341E-02	<2.8018E-02
C _{sd12} Concentration @12% CO ₂ (µg/dscm)	<2.8005E-02	<2.5984E-02	<2.6854E-02	<2.6948E-02
C _{sd} Concentration (mg/dscm)	<2.4644E-05	<2.3559E-05	<2.4773E-05	<2.4325E-05
C _{sd7} Concentration @7% O ₂ (mg/dscm)	<2.8217E-05	<2.7495E-05	<2.8341E-05	<2.8018E-05
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	<2.8005E-05	<2.5984E-05	<2.6854E-05	<2.6948E-05
C _a Concentration (µg/m ³ (actual,wet))	<1.3340E-02	<1.2754E-02	<1.3259E-02	<1.3118E-02
C _{sd} Concentration (µg/Nm ³ dry)	<2.6448E-02	<2.5282E-02	<2.6585E-02	<2.6105E-02
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	<3.0282E-02	<2.9507E-02	<3.0414E-02	<3.0068E-02
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	<3.0054E-02	<2.7885E-02	<2.8819E-02	<2.8919E-02
E _{lb/hr} Rate (lb/hr)	<8.5013E-06	<8.3786E-06	<8.4673E-06	<8.4491E-06
E _{g/s} Rate (g/s)	<1.0710E-06	<1.0555E-06	<1.0667E-06	<1.0644E-06
E _{T/yr} Rate (Ton/yr)	<3.7236E-05	<3.6698E-05	<3.7087E-05	<3.7007E-05
E _{Fd} Rate - F _d -based (lb/MMBtu)	<2.5355E-08	<2.4706E-08	<2.5466E-08	<2.5176E-08
E _{Fc} Rate - F _c -based (lb/MMBtu)	<2.6524E-08	<2.4610E-08	<2.5434E-08	<2.5522E-08

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29
 Cadmium (Cd) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	
Process Conditions				
R _p Steam Production Rate (Klbs/hr)	184.0	184.1	184.0	184.0
P ₁ Fabric Filter Inlet Temperature (°F)	321	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.7600	8.9900	8.7500	8.8333
CO ₂ Carbon dioxide (dry volume %)	10.5600	10.8800	11.0700	10.8367
T _s Sample temperature (°F)	307.5600	307.8000	310.4800	308.6133
B _w Actual water vapor in gas (% by volume)	19.9927	19.9593	20.5914	20.1811
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	170,082	175,333	170,440	171,952
Q _s Volumetric flow rate, standard (scfm)	115,074	118,590	114,880	116,181
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,068	94,920	91,224	92,737
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	80,410	81,331	79,739	80,494
Q _a Volumetric flow rate, actual (acf/hr)	10,204,907	10,519,996	10,226,424	10,317,109
Q _s Volumetric flow rate, standard (scf/hr)	6,904,448	7,115,406	6,892,783	6,970,879
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,524,062	5,695,222	5,473,466	5,564,250
Q _a Volumetric flow rate, actual (m ³ /hr)	289,009	297,932	289,618	292,187
Q _s Volumetric flow rate, standard (m ³ /hr)	195,538	201,512	195,208	197,419
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	156,445	161,292	155,012	157,583
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	136,636	138,201	135,496	136,777
Q _s Volumetric flow rate, normal (Nm ³ /hr)	182,206	187,773	181,898	183,959
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	145,778	150,295	144,443	146,839
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	127,320	128,778	126,258	127,452
Sampling Data				
V _{mstd} Volume metered, standard (dscf)	71.6391	74.9407	71.2682	72.6160
%I Isokinetic sampling (%)	101.7587	103.2492	102.1675	102.3918
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	0.2826	<0.2000	0.2161	
Cadmium Results - Total				
C _{sd} Concentration (lb/dscf)	8.6990E-12	<5.8847E-12	6.6873E-12	<7.0903E-12
C _{sd7} Concentration @7% O ₂ (lb/dscf)	9.9602E-12	<6.8679E-12	7.6505E-12	<8.1595E-12
C _{sd12} Concentration @12% CO ₂ (lb/dscf)	9.8852E-12	<6.4904E-12	7.2491E-12	<7.8749E-12
C _a Concentration (lb/acf)	4.7089E-12	<3.1858E-12	3.5792E-12	<3.8246E-12
C _{sd} Concentration (µg/dscm)	1.3930E-01	<9.4235E-02	1.0709E-01	<1.1354E-01
C _{sd7} Concentration @7% O ₂ (µg/dscm)	1.5950E-01	<1.0998E-01	1.2251E-01	<1.3066E-01
C _{sd12} Concentration @12% CO ₂ (µg/dscm)	1.5830E-01	<1.0394E-01	1.1608E-01	<1.2611E-01
C _{sd} Concentration (mg/dscm)	1.3930E-04	<9.4235E-05	1.0709E-04	<1.1354E-04
C _{sd7} Concentration @7% O ₂ (mg/dscm)	1.5950E-04	<1.0998E-04	1.2251E-04	<1.3066E-04
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	1.5830E-04	<1.0394E-04	1.1608E-04	<1.2611E-04
C _a Concentration (µg/m ³ (actual,wet))	7.5407E-02	<5.1016E-02	5.7317E-02	<6.1246E-02
C _{sd} Concentration (µg/Nm ³ dry)	1.4950E-01	<1.0113E-01	1.1492E-01	<1.2185E-01
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	1.7117E-01	<1.1803E-01	1.3148E-01	<1.4022E-01
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	1.6988E-01	<1.1154E-01	1.2458E-01	<1.3533E-01
E _{lb/hr} Rate (lb/hr)	4.8054E-05	<3.3514E-05	3.6603E-05	<3.9390E-05
E _{g/s} Rate (g/s)	6.0537E-06	<4.2220E-06	4.6111E-06	<4.9623E-06
E _{T/yr} Rate (Ton/yr)	2.1048E-04	<1.4679E-04	1.6032E-04	<1.7253E-04
E _{Fd} Rate - Fd-based (lb/MMBtu)	1.4332E-07	<9.8825E-08	1.1009E-07	<1.1741E-07
E _{Fc} Rate - Fc-based (lb/MMBtu)	1.4993E-07	<9.8438E-08	1.0995E-07	<1.1944E-07

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29
 Lead (Pb) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:46	09:24	11:58	
Stop Time (approx.)	08:58	11:38	14:10	
Process Conditions				
R _p Steam Production Rate (Klbs/hour)	184.0	184.1	184.0	184.0
P ₁ Fabric Filter Inlet Temperature (°F)	321	320	320	320
F _d Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions				
O ₂ Oxygen (dry volume %)	8.7600	8.9900	8.7500	8.8333
CO ₂ Carbon dioxide (dry volume %)	10.5600	10.8800	11.0700	10.8367
T _s Sample temperature (°F)	307.5600	307.8000	310.4800	308.6133
B _w Actual water vapor in gas (% by volume)	19.9927	19.9593	20.5914	20.1811
Gas Flow Rate				
Q _a Volumetric flow rate, actual (acfm)	170,082	175,333	170,440	171,952
Q _s Volumetric flow rate, standard (scfm)	115,074	118,590	114,880	116,181
Q _{std} Volumetric flow rate, dry standard (dscfm)	92,068	94,920	91,224	92,737
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dscfm)	80,410	81,331	79,739	80,494
Q _a Volumetric flow rate, actual (acf/hr)	10,204,907	10,519,996	10,226,424	10,317,109
Q _s Volumetric flow rate, standard (scf/hr)	6,904,448	7,115,406	6,892,783	6,970,879
Q _{std} Volumetric flow rate, dry standard (dscf/hr)	5,524,062	5,695,222	5,473,466	5,564,250
Q _a Volumetric flow rate, actual (m ³ /hr)	289,009	297,932	289,618	292,187
Q _s Volumetric flow rate, standard (m ³ /hr)	195,538	201,512	195,208	197,419
Q _{std} Volumetric flow rate, dry standard (dry m ³ /hr)	156,445	161,292	155,012	157,583
Q _{std7} Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	136,636	138,201	135,496	136,777
Q _n Volumetric flow rate, normal (Nm ³ /hr)	182,206	187,773	181,898	183,959
Q _{std} Volumetric flow rate, dry normal (Nm ³ /hr)	145,778	150,295	144,443	146,839
Q _{std7} Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	127,320	128,778	126,258	127,452
Sampling Data				
V _{metd} Volume metered, standard (dscf)	71.6391	74.9407	71.2682	72.6160
%I Isokinetic sampling (%)	101.7587	103.2492	102.1675	102.3918
Laboratory Data				
m _n Total matter corrected for allowable blanks (µg)	1.4108	0.4894	0.4760	
Lead Results - Total				
C _{sd} Concentration (lb/dscf)	4.3423E-11	1.4399E-11	1.4728E-11	2.4183E-11
C _{sd7} Concentration @7% O ₂ (lb/dscf)	4.9718E-11	1.6805E-11	1.6849E-11	2.7791E-11
C _{sd12} Concentration @12% CO ₂ (lb/dscf)	4.9344E-11	1.5882E-11	1.5965E-11	2.7063E-11
C _a Concentration (lb/acf)	2.3505E-11	7.7954E-12	7.8827E-12	1.3061E-11
C _{sd} Concentration (µg/dscm)	6.9535E-01	2.3059E-01	2.3584E-01	3.8726E-01
C _{sd7} Concentration @7% O ₂ (µg/dscm)	7.9616E-01	2.6911E-01	2.6981E-01	4.4503E-01
C _{sd12} Concentration @12% CO ₂ (µg/dscm)	7.9017E-01	2.5432E-01	2.5566E-01	4.3338E-01
C _{sd} Concentration (mg/dscm)	6.9535E-04	2.3059E-04	2.3584E-04	3.8726E-04
C _{sd7} Concentration @7% O ₂ (mg/dscm)	7.9616E-04	2.6911E-04	2.6981E-04	4.4503E-04
C _{sd12} Concentration @12% CO ₂ (mg/dscm)	7.9017E-04	2.5432E-04	2.5566E-04	4.3338E-04
C _a Concentration (µg/m ³ (actual,wet))	3.7640E-01	1.2483E-01	1.2623E-01	2.0916E-01
C _{sd} Concentration (µg/Nm ³ dry)	7.4623E-01	2.4746E-01	2.5310E-01	4.1560E-01
C _{sd7} Concentration @7% O ₂ (µg/Nm ³ dry)	8.5442E-01	2.8880E-01	2.8956E-01	4.7759E-01
C _{sd12} Concentration @12% CO ₂ (µg/Nm ³ dry)	8.4799E-01	2.7293E-01	2.7436E-01	4.6509E-01
E _{lb/hr} Rate (lb/hr)	2.3987E-04	8.2007E-05	8.0612E-05	1.3416E-04
E _{g/s} Rate (g/s)	3.0218E-05	1.0331E-05	1.0155E-05	1.6901E-05
E _{T/yr} Rate (Ton/yr)	1.0506E-03	3.5919E-04	3.5308E-04	5.8763E-04
E _{Fd} Rate - F _d -based (lb/MMBtu)	7.1541E-07	2.4182E-07	2.4245E-07	3.9989E-07
E _{Fc} Rate - F _c -based (lb/MMBtu)	7.4838E-07	2.4087E-07	2.4214E-07	4.1046E-07

Prepared by Clean Air Engineering Proprietary Software
 SS Metals-1 Version 2006-12a

Copyright © 2008 Clean Air Engineering Inc.

QA/QC _____
 Date _____

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

USEPA Method 13B (Total Fluorides) Sampling, Velocity and Moisture Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 10	Mar 10	Mar 10	
Start Time (approx.)		08:17	11:31	13:16	
Stop Time (approx.)		10:32	12:49	14:30	
Sampling Conditions					
Y _d	Dry gas meter correction factor	1.0079	1.0079	1.0079	
C _p	Pitot tube coefficient	0.8250	0.8250	0.8250	
P _g	Static pressure (in. H ₂ O)	-10.9000	-9.3000	-9.3000	
A _s	Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar}	Barometric pressure (in. Hg)	30.21	30.25	30.25	30.2367
D _n	Nozzle diameter (in.)	0.2720	0.2720	0.2720	
O ₂	Oxygen (dry volume %)	8.8500	8.7500	8.9400	8.8467
CO ₂	Carbon dioxide (dry volume %)	10.7000	11.0400	10.9300	10.8900
N ₂ +CO	Nitrogen plus carbon monoxide (dry volume %)	80.4500	80.2100	80.1300	80.2633
V _{lc}	Total Liquid collected (ml)	241.80	224.00	191.60	
V _m	Volume metered, meter conditions (ft ³)	37.7130	36.8750	35.1000	
T _m	Dry gas meter temperature (°F)	74.4400	96.3400	102.2800	
T _a	Sample temperature (°F)	309.6400	308.8000	313.1600	310.5333
ΔH	Meter box orifice pressure drop (in. H ₂ O)	1.2100	1.0372	0.9864	
θ	Total sampling time (min)	62.5	62.5	62.5	
Flow Results					
V _{wstd}	Volume of water collected (ft ³)	11.3791	10.5414	9.0167	10.3124
V _{mstd}	Volume metered, standard (dscf)	38.0133	35.7377	33.6539	35.8017
P _s	Sample gas pressure, absolute (in. Hg)	29.4085	29.5662	29.5662	29.5136
P _v	Vapor pressure, actual (in. Hg)	29.4085	29.5662	29.5662	29.5136
B _{wo}	Moisture measured in sample (% by volume)	23.0382	22.7779	21.1309	22.3157
B _{ws}	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w	Actual water vapor in gas (% by volume)	23.0382	22.7779	21.1309	22.3157
√ΔP	Velocity head (√in. H ₂ O)	0.6903	0.6518	0.6246	0.6556
M _d	MW of sample gas, dry (lb/lb-mole)	30.0660	30.1164	30.1064	30.0963
M _s	MW of sample gas, wet (lb/lb-mole)	27.2862	27.3565	27.5482	27.3970
V _s	Velocity of sample (ft/sec)	47.6782	44.8215	42.9221	45.1406
%I	Isokinetic sampling (%)	101.5878	100.6013	97.4111	99.8667
Q _a	Volumetric flow rate, actual (acfm)	183,084	172,115	164,821	173,340
Q _s	Volumetric flow rate, standard (scfm)	123,455	116,808	111,227	117,163
Q _{std}	Volumetric flow rate, dry standard (dscfm)	95,013	90,201	87,724	90,980
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	82,368	78,845	75,480	78,898
Q _a	Volumetric flow rate, actual (acf/hr)	10,985,055	10,326,882	9,889,259	10,400,399
Q _s	Volumetric flow rate, standard (scf/hr)	7,407,305	7,008,472	6,673,626	7,029,801
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,700,799	5,412,086	5,263,428	5,458,771
Q _a	Volumetric flow rate, actual (m ³ /hr)	311,103	292,463	280,070	294,545
Q _s	Volumetric flow rate, standard (m ³ /hr)	209,779	198,484	189,001	199,088
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	161,450	153,273	149,063	154,596
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	139,962	133,976	128,259	134,066
Q _a	Volumetric flow rate, normal (Nm ³ /hr)	195,476	184,951	176,115	185,514
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	150,442	142,823	138,900	144,055
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	130,419	124,842	119,514	124,925

Comments:

Average includes 3 runs.

041409 125041
 N J @ @

**USEPA Method 13B
 HF Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 10	Mar 10	Mar 10	
Start Time (approx.)		08:17	11:31	13:16	
Stop Time (approx.)		10:32	12:49	14:30	
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	184.8	184.6	183.9	184.4
P ₁	Fabric Filter Inlet Temperature (°F)	320	320	320	320
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.8500	8.7500	8.9400	8.8467
CO ₂	Carbon dioxide (dry volume %)	10.7000	11.0400	10.9300	10.8900
T _s	Sample temperature (°F)	309.6400	308.8000	313.1600	310.5333
B _w	Actual water vapor in gas (% by volume)	23.0382	22.7779	21.1309	22.3157
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	183,084	172,115	164,821	173,340
Q _s	Volumetric flow rate, standard (scfm)	123,455	116,808	111,227	117,163
Q _{std}	Volumetric flow rate, dry standard (dscfm)	95,013	90,201	87,724	90,980
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dscfm)	82,368	78,845	75,480	78,898
Q _a	Volumetric flow rate, actual (acf/hr)	10,985,055	10,326,882	9,889,259	10,400,399
Q _s	Volumetric flow rate, standard (scf/hr)	7,407,305	7,008,472	6,673,626	7,029,801
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	5,700,799	5,412,086	5,263,428	5,458,771
Q _a	Volumetric flow rate, actual (m ³ /hr)	311,103	292,463	280,070	294,545
Q _s	Volumetric flow rate, standard (m ³ /hr)	209,779	198,484	189,001	199,088
Q _{std}	Volumetric flow rate, dry standard (dry m ³ /hr)	161,450	153,273	149,063	154,596
Q _{std7}	Volumetric flow rate, dry std@7%O ₂ (dry m ³ /hr)	139,962	133,976	128,259	134,066
Q _s	Volumetric flow rate, normal (Nm ³ /hr)	195,476	184,951	176,115	185,514
Q _{std}	Volumetric flow rate, dry normal (Nm ³ /hr)	150,442	142,823	138,900	144,055
Q _{std7}	Volumetric flow rate, dry normal @7%O ₂ (Nm ³ /hr)	130,419	124,842	119,514	124,925
Sampling Data					
V _{metd}	Volume metered, standard (dscf)	38.0133	35.7377	33.6539	35.8017
%I	Isokinetic sampling (%)	101.5878	100.6013	97.4111	99.8667
Laboratory Data					
m _n	Total HF collected (mg)	<0.0280	<0.0267	<0.0234	
Hydrogen Fluoride (HF) Results					
C _{sd}	HF Concentration (lb/dscf)	<1.6230E-09	<1.6504E-09	<1.5337E-09	<1.6024E-09
C _{sd7}	HF Concentration @7% O ₂ (lb/dscf)	<1.8722E-09	<1.8881E-09	<1.7825E-09	<1.8476E-09
C _{sd12}	HF Concentration @12% CO ₂ (lb/dscf)	<1.8202E-09	<1.7939E-09	<1.6838E-09	<1.7660E-09
C _a	HF Concentration (lb/acf)	<8.4228E-10	<8.6492E-10	<8.1629E-10	<8.4116E-10
C _{sd}	HF Concentration (ppmdv)	<0.0313	<0.0318	<0.0296	<0.0309
C _{sd7}	HF Concentration @7% O ₂ (ppmdv)	<0.0361	<0.0364	<0.0343	<0.0356
C _{sd12}	HF Concentration @12% CO ₂ (ppmdv)	<0.0351	<0.0346	<0.0324	<0.0340
C _w	HF Concentration (ppmwv)	<0.0241	<0.0246	<0.0233	<0.0240
C _{sd}	HF Concentration (mg/dscm)	<0.0260	<0.0264	<0.0246	<0.0257
C _{sd7}	HF Concentration @7% O ₂ (mg/dscm)	<0.0300	<0.0302	<0.0285	<0.0296
C _{sd12}	HF Concentration @12% CO ₂ (mg/dscm)	<0.0291	<0.0287	<0.0270	<0.0283
C _a	HF Concentration (mg/m ³ (actual,wet))	<0.0135	<0.0139	<0.0131	<0.0135
C _{sd}	HF Concentration (mg/Nm ³ dry)	<0.0279	<0.0284	<0.0264	<0.0275
C _{sd7}	HF Concentration @7% O ₂ (mg/Nm ³ dry)	<0.0322	<0.0324	<0.0306	<0.0318
C _{sd12}	HF Concentration @12% CO ₂ (mg/Nm ³ dry)	<0.0313	<0.0308	<0.0289	<0.0303
E _{lb/hr}	HF Rate (lb/hr)	<0.0093	<0.0089	<0.0081	<0.0088
E _{kg/hr}	HF Rate (kg/hr)	<0.0042	<0.0041	<0.0037	<0.0040
E _{Tyr}	HF Rate (Ton/yr)	<0.0405	<0.0391	<0.0354	<0.0383
E _{Fd}	HF Rate - Fd-based (lb/MMBtu)	<0.000027	<0.000027	<0.000026	<0.000027
E _{Fc}	HF Rate - Fc-based (lb/MMBtu)	<0.000028	<0.000027	<0.000026	<0.000027

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 SDA Inlet

USEPA Method 26A (HCl) Sampling, Velocity and Moisture Parameters

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:57	08:29	10:02	
Stop Time (approx.)	07:57	09:29	11:02	
Sampling Conditions				
Y_d Dry gas meter correction factor	1.0028	1.0028	1.0028	
P_g Static pressure (in. H ₂ O)	-2.2000	-2.2000	-2.2000	
A_s Sample location area (ft ²)	60.1320	60.1320	60.1320	
P_{bar} Barometric pressure (in. Hg)	30.20	30.20	30.20	30.2000
O_2 Oxygen (dry volume %)	8.2200	8.2100	8.2200	8.2167
CO_2 Carbon dioxide (dry volume %)	11.0900	11.3000	11.5900	11.3267
N_2+CO Nitrogen plus carbon monoxide (dry volume %)	80.6900	80.4900	80.1900	80.4567
V_{lc} Total Liquid collected (ml)	134.40	134.40	133.30	
V_m Volume metered, meter conditions (ft ³)	32.1700	32.2100	33.7300	
T_m Dry gas meter temperature (°F)	70.0417	75.2083	81.0000	
T_s Sample temperature (°F)	487.1667	495.3333	495.8333	492.7778
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.0800	1.0358	1.1150	
θ Total sampling time (min)	60.0	60.0	60.0	
Flow Results				
V_{wstd} Volume of water collected (ft ³)	6.3249	6.3249	6.2731	6.3076
V_{mstd} Volume metered, standard (dscf)	32.5088	32.2316	33.3977	32.7127
P_s Sample gas pressure, absolute (in. Hg)	30.0382	30.0382	30.0382	30.0382
P_v Vapor pressure, actual (in. Hg)	30.0382	30.0382	30.0382	30.0382
B_{wo} Moisture measured in sample (% by volume)	16.2871	16.4042	15.8129	16.1680
B_{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B_w Actual water vapor in gas (% by volume)	16.2871	16.4042	15.8129	16.1680
M_d MW of sample gas, dry (lb/lb-mole)	30.1032	30.1364	30.1832	30.1409
M_s MW of sample gas, wet (lb/lb-mole)	28.1319	28.1455	28.2567	28.1781

Comments:

Average includes 3 runs.

041409 124830
 OKK@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 SDA Inlet

USEPA Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 11	Mar 11	Mar 11	
Start Time (approx.)		06:57	08:29	10:02	
Stop Time (approx.)		07:57	09:29	11:02	
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	184.2	182.9	183.9	183.7
P ₁	Fabric Filter Inlet Temperature (°F)	321	321	320	321
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.2200	8.2100	8.2200	8.2167
CO ₂	Carbon dioxide (dry volume %)	11.0900	11.3000	11.5900	11.3267
T _s	Sample temperature (°F)	487.1667	495.3333	495.8333	492.7778
B _w	Actual water vapor in gas (% by volume)	16.2871	16.4042	15.8129	16.1680
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	32.5088	32.2316	33.3977	32.7127
Laboratory Data					
m _n	Total HCl collected (mg)	698.7197	595.7498	572.4612	
Hydrogen Chloride (HCl) Results					
C _{sd}	HCl Concentration (lb/dscf)	4.7393E-05	4.0756E-05	3.7795E-05	4.1981E-05
C _{sd7}	HCl Concentration @7% O ₂ (lb/dscf)	5.1952E-05	4.4642E-05	4.1432E-05	4.6009E-05
C _{sd12}	HCl Concentration @12% CO ₂ (lb/dscf)	5.1281E-05	4.3281E-05	3.9132E-05	4.4565E-05
C _{sd}	HCl Concentration (ppmdv)	501.0626	430.8962	399.5951	443.8513
C _{sd7}	HCl Concentration @7% O ₂ (ppmdv)	549.2721	471.9825	438.0419	486.4321
C _{sd12}	HCl Concentration @12% CO ₂ (ppmdv)	542.1777	457.5889	413.7309	471.1658
C _w	HCl Concentration (ppmwv)	419.4543	360.2113	336.4075	372.0244
C _{sd}	HCl Concentration (mg/dscm)	758.9258	652.6495	605.2398	672.2717
C _{sd7}	HCl Concentration @7% O ₂ (mg/dscm)	831.9455	714.8801	663.4726	736.7661
C _{sd12}	HCl Concentration @12% CO ₂ (mg/dscm)	821.2002	693.0792	626.6504	713.6432
C _{sd}	HCl Concentration (mg/Nm ³ dry)	814.4570	700.4044	649.5256	721.4623
C _{sd7}	HCl Concentration @7% O ₂ (mg/Nm ³ dry)	892.8196	767.1884	712.0194	790.6758
C _{sd12}	HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	881.2880	743.7923	672.5028	765.8610
E _{Fd}	HCl Rate - Fd-based (lb/MMBtu)	0.7476	0.6424	0.5962	0.6620
E _{Fc}	HCl Rate - Fc-based (lb/MMBtu)	0.7778	0.6564	0.5935	0.6759

041409 142717
 O K K @ _ @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Modified Method 26A (HCl)
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 11	Mar 11	Mar 11	
Start Time (approx.)	06:57	08:29	10:02	
Stop Time (approx.)	07:57	09:29	11:02	
Sampling Conditions				
Y _d Dry gas meter correction factor	0.9897	0.9897	0.9897	
P _g Static pressure (in. H ₂ O)	-10.5000	-10.5000	-10.5000	
A _s Sample location area (ft ²)	64.0000	64.0000	64.0000	
P _{bar} Barometric pressure (in. Hg)	30.20	30.20	30.20	30.2000
O ₂ Oxygen (dry volume %)	9.2100	9.1800	9.0100	9.1333
CO ₂ Carbon dioxide (dry volume %)	10.0400	10.2500	10.7600	10.3500
N ₂ +CO Nitrogen plus carbon monoxide (dry volume %)	80.7500	80.5700	80.2300	80.5167
V _{lc} Total Liquid collected (ml)	210.80	221.70	211.60	
V _m Volume metered, meter conditions (ft ³)	40.3100	40.9350	40.9350	
T _m Dry gas meter temperature (°F)	75.4167	81.0000	86.2083	
T _s Sample temperature (°F)	309.1667	310.5000	309.3333	309.6667
ΔH Meter box orifice pressure drop (in. H ₂ O)	1.5000	1.5000	1.5000	
θ Total sampling time (min)	60.0	60.0	60.0	
Flow Results				
V _{wstd} Volume of water collected (ft ³)	9.9202	10.4332	9.9579	10.1038
V _{mstd} Volume metered, standard (dscf)	39.8394	40.0396	39.6578	39.8456
P _s Sample gas pressure, absolute (in. Hg)	29.4279	29.4279	29.4279	29.4279
P _v Vapor pressure, actual (in. Hg)	29.4279	29.4279	29.4279	29.4279
B _{wo} Moisture measured in sample (% by volume)	19.9363	20.6709	20.0700	20.2258
B _{ws} Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B _w Actual water vapor in gas (% by volume)	19.9363	20.6709	20.0700	20.2258
M _d MW of sample gas, dry (lb/lb-mole)	29.9748	30.0072	30.0820	30.0213
M _s MW of sample gas, wet (lb/lb-mole)	27.5875	27.5252	27.6571	27.5899

Comments:

Average includes 3 runs.

041408 123915
 O O P @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

USEPA Modified Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 11	Mar 11	Mar 11	
Start Time (approx.)		06:57	08:29	10:02	
Stop Time (approx.)		07:57	09:29	11:02	
Process Conditions					
R _P	Steam Production Rate (Klbs/hour)	184.2	182.9	183.9	183.7
P ₁	Fabric Filter Inlet Temperature (°F)	321	321	320	321
F _d	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F _c	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	9.2100	9.1800	9.0100	9.1333
CO ₂	Carbon dioxide (dry volume %)	10.0400	10.2500	10.7600	10.3500
T _s	Sample temperature (°F)	309.1667	310.5000	309.3333	309.6667
B _w	Actual water vapor in gas (% by volume)	19.9363	20.6709	20.0700	20.2258
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	39.8394	40.0396	39.6578	39.8456
Laboratory Data					
m _n	Total HCl collected (mg)	7.9377	13.6807	13.2000	
Hydrogen Chloride (HCl) Results					
C _{sd}	HCl Concentration (lb/dscf)	4.3933E-07	7.5340E-07	7.3393E-07	6.4222E-07
C _{sd7}	HCl Concentration @7% O ₂ (lb/dscf)	5.2238E-07	8.9354E-07	8.5800E-07	7.5797E-07
C _{sd12}	HCl Concentration @12% CO ₂ (lb/dscf)	5.2509E-07	8.8203E-07	8.1851E-07	7.4188E-07
C _{sd}	HCl Concentration (ppmdv)	4.6448	7.9654	7.7595	6.7899
C _{sd7}	HCl Concentration @7% O ₂ (ppmdv)	5.5229	9.4470	9.0713	8.0138
C _{sd12}	HCl Concentration @12% CO ₂ (ppmdv)	5.5516	9.3254	8.6538	7.8436
C _w	HCl Concentration (ppmwv)	3.7188	6.3189	6.2022	5.4133
C _{sd}	HCl Concentration (mg/dscm)	7.0352	12.0647	11.7529	10.2843
C _{sd7}	HCl Concentration @7% O ₂ (mg/dscm)	8.3652	14.3088	13.7397	12.1379
C _{sd12}	HCl Concentration @12% CO ₂ (mg/dscm)	8.4086	14.1245	13.1073	11.8801
C _{sd}	HCl Concentration (mg/Nm ³ dry)	7.5500	12.9475	12.6128	11.0368
C _{sd7}	HCl Concentration @7% O ₂ (mg/Nm ³ dry)	8.9773	15.3558	14.7450	13.0260
C _{sd12}	HCl Concentration @12% CO ₂ (mg/Nm ³ dry)	9.0239	15.1580	14.0663	12.7494
E _{Fd}	HCl Rate - Fd-based (lb/MMBtu)	0.0075	0.0129	0.0123	0.0109
E _{Fc}	HCl Rate - Fc-based (lb/MMBtu)	0.0080	0.0134	0.0124	0.0113

041409 123915
 O O P @ @

Wheelabrator North Broward, Inc.
 CleanAir Project No. 10735
 Lime Silo

Visible Emission Parameters

Run 1
 Date (2009) Mar 12
 Start Time 8:16

Time (min)	Time (sec)			
	15	30	45	60
0	0	0	0	0
1	0	0	0	0
2	0	0	0	0
3	0	0	0	0
4	0	0	0	0
5	0	0	0	0
6	0	0	0	0
7	0	0	0	0
8	0	0	0	0
9	0	0	0	0
10	0	0	0	0
11	0	0	0	0
12	0	0	0	0
13	0	0	0	0
14	0	0	0	0
15	0	0	0	0
16	0	0	0	0
17	0	0	0	0
18	0	0	0	0
19	0	0	0	0
20	0	0	0	0
21	0	0	0	0
22	0	0	0	0
23	0	0	0	0
24	0	0	0	0
25	0	0	0	0
26	0	0	0	0
27	0	0	0	0
28	0	0	0	0
29	0	0	0	0
30	0	0	0	0
31	0	0	0	0
32	0	0	0	0
33	0	0	0	0
34	0	0	0	0
35	0	0	0	0
36	0	0	0	0
37	0	0	0	0
38	0	0	0	0
39	0	0	0	0
40	0	0	0	0
41	0	0	0	0
42	0	0	0	0
43	0	0	0	0
44	0	0	0	0
45	0	0	0	0
46	0	0	0	0
47	0	0	0	0
48	0	0	0	0
49	0	0	0	0
50	0	0	0	0
51	0	0	0	0
52	0	0	0	0
53	0	0	0	0
54	0	0	0	0
55	0	0	0	0
56	0	0	0	0
57	0	0	0	0
58	0	0	0	0
59	0	0	0	0

Time (min)	Time (sec)			
	15	30	45	60
0	0	0	0	0
1	0	0	0	0
2	0	0	0	0
3	0	0	0	0
4	0	0	0	0
5	0	0	0	0
6	0	0	0	0
7	0	0	0	0
8	0	0	0	0
9	0	0	0	0
10	0	0	0	0
11	0	0	0	0
12	0	0	0	0
13	0	0	0	0
14	0	0	0	0
15	0	0	0	0
16	0	0	0	0
17	0	0	0	0
18	0	0	0	0
19	0	0	0	0
20	0	0	0	0
21	0	0	0	0
22	0	0	0	0
23	0	0	0	0
24	0	0	0	0
25	0	0	0	0
26	0	0	0	0
27	0	0	0	0
28	0	0	0	0
29	0	0	0	0
30	0	0	0	0
31	0	0	0	0
32	0	0	0	0
33	0	0	0	0
34	0	0	0	0
35	0	0	0	0
36	0	0	0	0
37	0	0	0	0
38	0	0	0	0
39	0	0	0	0
40	0	0	0	0
41	0	0	0	0
42	0	0	0	0
43	0	0	0	0
44	0	0	0	0
45	0	0	0	0
46	0	0	0	0
47	0	0	0	0
48	0	0	0	0
49	0	0	0	0
50	0	0	0	0
51	0	0	0	0
52	0	0	0	0
53	0	0	0	0
54	0	0	0	0
55	0	0	0	0
56	0	0	0	0
57	0	0	0	0
58	0	0	0	0
59	0	0	0	0

Average Opacity 0
 Minimum Reading 0
 Maximum Reading 0
 No. of Readings >5% 0

QA/QC DATA

E

This Page Intentionally Left Blank

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 10	Mar 10	Mar 10
Start Time (approx.)	06:48	09:25	11:59
Stop Time (approx.)	09:03	11:37	14:13
Total Duration of Test Run (min.)	135	132	134
Net Sampling Time (min.)	125	125	125

Sampling System Calibration Summary

	Nozzle ID No:	268-1	268-1	268-1
D _n	Nozzle Diameter (in):	0.268	0.268	0.268
	Probe ID No:	67-8-4	67-8-4	67-8-4
C _p	Pitot Coefficient:	0.8120	0.8120	0.8120
	Meter Box ID. No:	66-6	66-6	66-6
Y _d	Meter Box Yd - Field Sheet	0.9916	0.9916	0.9916
	Meter Box Yd - Database	0.9916	0.9916	0.9916
	Meter Box ΔH@ - Field Sheet	1.8053	1.8053	1.8053
	Meter Box ΔH@ - Database	1.8053	1.8053	1.8053

QA/QC

<u>Final Leak Check</u>				
	(a) 4% of Sampling Rate (cfm)	0.0210	0.0225	0.0224
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0020	0.0020	0.0020
<u>Sample Volume</u>				
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	65.915	69.187	67.923
<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>				
√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	0.9789	1.0196	1.0168
Y _{qa}	Alternative Meter Calibration Factor	1.0130	0.9952	1.0043
	Variation from full-test Y _d (average ≤ ±5%)	2.2%	0.4%	1.3%
<u>Mean Isokinetic Sampling Rate Variation</u>				
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	100.02	99.07	96.74
<u>Point-by-Point Isokinetic Variation</u>				
	Number of points <90%	1	1	0
	Number of points >110%	0	1	0
	Number of points <80%	1	0	0
	Number of points >120%	0	0	0
				Average 1.3%

041406 120109
 NOK@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 13B (Total Fluorides)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 12	Mar 12	Mar 12
Start Time (approx.)	11:47	13:09	14:33
Stop Time (approx.)	12:59	14:19	15:43
Total Duration of Test Run (min.)	72	70	70
Net Sampling Time (min.)	63	63	63

Sampling System Calibration Summary

	Nozzle ID No:	272-1	272-1	272-1
D _n	Nozzle Diameter (in):	0.272	0.272	0.272
	Probe ID No:	67-8-7	67-8-7	67-8-7
C _p	Pitot Coefficient:	0.8250	0.8250	0.8250
	Meter Box ID. No:	66-6	66-6	66-6
Y _d	Meter Box Yd - Field Sheet	0.9916	0.9916	0.9916
	Meter Box Yd - Database	0.9916	0.9916	0.9916
	Meter Box ΔH@ - Field Sheet	1.8053	1.8053	1.8053
	Meter Box ΔH@ - Database	1.8053	1.8053	1.8053

QA/QC

<u>Final Leak Check</u>				
	(a) 4% of Sampling Rate (cfm)	0.0248	0.0247	0.0259
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0020	0.0030	0.0020
<u>Sample Volume</u>				
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	38.083	37.501	39.555
<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>				
√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.1293	1.0731	1.1790
Y _{qa}	Alternative Meter Calibration Factor	1.0006	0.9610	1.0033
	Variation from full-test Y _d (average ≤ ±5%)	0.9%	-3.1%	1.2%
				Average -0.3%
<u>Mean Isokinetic Sampling Rate Variation</u>				
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	100.52	102.18	98.71
<u>Point-by-Point Isokinetic Variation</u>				
	Number of points <90%	0	0	1
	Number of points >110%	1	1	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

041409 120328
 K Q Q @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Method 23 (PCDD/F)
 QA/QC Results**

Run No.	1	2*	3	4
Date (2009)	Mar 10	Mar 11	Mar 11	Mar 12
Start Time (approx.)	10:08	06:26	11:26	06:42
Stop Time (approx.)	14:30	11:05	15:45	11:13
Total Duration of Test Run (min.)	262	279	259	271
Net Sampling Time (min.)	250	250	250	250

Sampling System Calibration Summary

	Nozzle ID No:	266-1	266-1	266-1	266-1
D_n	Nozzle Diameter (in):	0.266	0.266	0.266	0.266
	Probe ID No:	67-8-17	67-8-17	67-8-17	67-8-17
C_p	Pitot Coefficient:	0.8330	0.8330	0.8330	0.833
	Meter Box ID. No:	66-22	66-22	66-22	61-6
Y_d	Meter Box Y_d - Field Sheet	0.9937	0.9937	0.9937	0.9875
	Meter Box Y_d - Database	0.9937	0.9937	0.9937	0.9875
	Meter Box $\Delta H@$ - Field Sheet	1.7498	1.7498	1.7498	1.6981
	Meter Box $\Delta H@$ - Database	1.7498	1.7498	1.7498	1.6981

QA/QC

<u>Final Leak Check</u>					
	(a) 4% of Sampling Rate (cfm)	0.0229	0.0235	0.0234	0.0234
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0060	0.0040	0.0030	0.0040
<u>Sample Volume</u>					
	Minimum Volume Required (dscf)	30.00	30.00	30.00	30.00
V_{mstd}	Actual Sample Volume (dscf)	138.679	146.024	142.061	141.319
<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>					
$\sqrt{\Delta H}_{avg}$	Average of Square Root of ΔH (in. W.C.)	0.9999	1.0391	1.0189	1.0191
Y_{qa}	Alternative Meter Calibration Factor	0.9836	0.9830	0.9805	0.9934
	Variation from full-test Y_d (average $\leq \pm 5\%$)	-1.0%	-1.1%	-1.3%	0.6%
					Average -0.7%
<u>Mean Isokinetic Sampling Rate Variation</u>					
	Minimum Allowable (%)	90	90	90	90
	Maximum Allowable (%)	110	110	110	110
%I	Actual Variation (%)	99.95	100.96	100.41	97.99
<u>Point-by-Point Isokinetic Variation</u>					
	Number of points <90%	0	0	2	1
	Number of points >110%	0	0	2	0
	Number of points <80%	0	0	1	0
	Number of points >120%	0	0	1	0

0414D6 120930
 JK MP

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 SDA Inlet

**USEPA Method 26A (HCl)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 12	Mar 12	Mar 12
Start Time (approx.)	06:36	08:25	10:10
Stop Time (approx.)	07:36	09:25	11:10
Total Duration of Test Run (min.)	60	60	60
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

	Nozzle ID No:	NA	NA	NA
D _n	Nozzle Diameter (in):	NA	NA	NA
	Probe ID No:	NA	NA	NA
C _p	Pitot Coefficient:	0.8400	0.8400	0.8400
	Meter Box ID. No:	66-7	66-7	66-7
Y _d	Meter Box Yd - Field Sheet	1.0028	1.0028	1.0028
	Meter Box Yd - Database	1.0028	1.0028	1.0028
	Meter Box ΔH@ - Field Sheet	1.7673	1.7673	1.7673
	Meter Box ΔH@ - Database	1.7673	1.7673	1.7673

QA/QC

	<u>Final Leak Check</u>			
	(a) 4% of Sampling Rate (cfm)	0.0214	0.0225	0.0234
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0030	0.0030	0.0020
	<u>Sample Volume</u>			
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	32.253	33.478	34.504
	<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>			
√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0056	1.0539	1.0797
Y _{qa}	Alternative Meter Calibration Factor	1.0375	1.0423	1.0310
	Variation from full-test Y _d (average ≤ ±5%)	3.5%	3.9%	2.8%

**Average
 3.4%**

041409 115716
 KML@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 1 FF Outlet

**USEPA Modified Method 26A (HCl)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 12	Mar 12	Mar 12
Start Time (approx.)	06:36	08:25	10:10
Stop Time (approx.)	07:36	09:25	11:10
Total Duration of Test Run (min.)	60	60	60
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

	Nozzle ID No:	NA	NA	NA
D _n	Nozzle Diameter (in):	NA	NA	NA
	Probe ID No:	5G-48-1	5G-48-1	5G-48-1
C _p	Pitot Coefficient:	0.8400	0.8400	0.8400
	Meter Box ID. No:	66-6	66-6	66-6
Y _d	Meter Box Yd - Field Sheet	0.9916	0.9916	0.9916
	Meter Box Yd - Database	0.9916	0.9916	0.9916
	Meter Box ΔH@ - Field Sheet	1.8053	1.8053	1.8053
	Meter Box ΔH@ - Database	1.8053	1.8053	1.8053

QA/QC

	<u>Final Leak Check</u>			
	(a) 4% of Sampling Rate (cfm)	0.0270	0.0280	0.0285
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0020	0.0020	0.0020
	<u>Sample Volume</u>			
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	40.301	41.427	41.914
	<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>			
√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.2247	1.2247	1.2247
Y _{qa}	Alternative Meter Calibration Factor	0.9928	0.9622	0.9473
	Variation from full-test Y _q (average ≤ ±5%)	0.1%	-3.0%	-4.5%
				Average
				-2.4%

041408 115818
 0 LL @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 12	Mar 12	Mar 12
Start Time (approx.)	06:29	08:58	11:39
Stop Time (approx.)	08:40	11:20	13:49
Total Duration of Test Run (min.)	131	142	130
Net Sampling Time (min.)	125	125	125

Sampling System Calibration Summary

	Nozzle ID No:	268-1	268-1	268-1
D _n	Nozzle Diameter (in):	0.268	0.268	0.268
	Probe ID No:	67-8-4	67-8-4	67-8-4
C _p	Pitot Coefficient:	0.8120	0.8120	0.8120
	Meter Box ID. No:	61-7	61-7	61-7
Y _d	Meter Box Yd - Field Sheet	0.9886	0.9886	0.9886
	Meter Box Yd - Database	0.9886	0.9886	0.9886
	Meter Box ΔH@ - Field Sheet	1.7796	1.7796	1.7796
	Meter Box ΔH@ - Database	1.7796	1.7796	1.7796

QA/QC

Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0234	0.0223	0.0225
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0020	0.0030	0.0030

Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	71.571	67.685	68.023

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0574	1.0063	1.0197
Y _{qa}	Alternative Meter Calibration Factor	1.0026	1.0073	1.0092
	Variation from full-test Y _d (average ≤ ±5%)	1.4%	1.9%	2.1%

**Average
1.8%**

Mean Isokinetic Sampling Rate Variation

	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	100.92	98.84	98.65

Point-by-Point Isokinetic Variation

	Number of points <90%	1	1	0
	Number of points >110%	1	1	0
	Number of points <80%	0	1	0
	Number of points >120%	1	1	0

041408 121831
NJK@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 SDA Inlet

**USEPA Method 26A (HCI)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 10	Mar 10	Mar 10
Start Time (approx.)	06:51	08:38	10:04
Stop Time (approx.)	08:03	09:38	11:04
Total Duration of Test Run (min.)	72	60	60
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

	Nozzle ID No:	NA	NA	NA
D _n	Nozzle Diameter (in):	NA	NA	NA
	Probe ID No:	NA	NA	NA
C _p	Pitot Coefficient:	0.8400	0.8400	0.8400
	Meter Box ID. No:	66-7	66-7	66-7
Y _d	Meter Box Yd - Field Sheet	1.0028	1.0028	1.0028
	Meter Box Yd - Database	1.0028	1.0028	1.0028
	Meter Box ΔH@ - Field Sheet	1.7673	1.7673	1.7673
	Meter Box ΔH@ - Database	1.7673	1.7673	1.7673

QA/QC

	<u>Final Leak Check</u>			
	(a) 4% of Sampling Rate (cfm)	0.0228	0.0225	0.0219
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0030	0.0030	0.0020
	<u>Sample Volume</u>			
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	34.561	33.652	32.353
	<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>			
√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.1002	1.0517	1.0393
Y _{qa}	Alternative Meter Calibration Factor	1.0619	1.0382	1.0591
	Variation from full-test Y _d (average ≤ ±5%)	5.9%	3.5%	5.6%

041409 122626
 JNL@

**Average
 5.0%**

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Modified Method 26A (HCI)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 10	Mar 10	Mar 10
Start Time (approx.)	06:51	08:38	10:04
Stop Time (approx.)	08:03	09:38	11:04
Total Duration of Test Run (min.)	72	60	60
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

	Nozzle ID No:	NA	NA	NA
D _n	Nozzle Diameter (in):	NA	NA	NA
	Probe ID No:	5G-48-1	5G-48-1	5G-48-1
C _p	Pitot Coefficient:	0.8400	0.8400	0.8400
	Meter Box ID. No:	61-7	61-7	61-7
Y _d	Meter Box Yd - Field Sheet	0.9886	0.9886	0.9886
	Meter Box Yd - Database	0.9886	0.9886	0.9886
	Meter Box ΔH@ - Field Sheet	1.7796	1.7796	1.7796
	Meter Box ΔH@ - Database	1.7796	1.7796	1.7796

QA/QC

	<u>Final Leak Check</u>			
	(a) 4% of Sampling Rate (cfm)	0.0271	0.0273	0.0276
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0020	0.0030	0.0030
	<u>Sample Volume</u>			
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	40.203	39.645	39.475
	<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>			
√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.2247	1.2247	1.2247
Y _{qa}	Alternative Meter Calibration Factor	0.9972	1.0024	0.9969
	Variation from full-test Y _d (average ≤ ±5%)	0.9%	1.4%	0.8%
				Average 1.0%

041400 122712
 L K P @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 2 FF Outlet

**USEPA Method 13B (Total Fluorides)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 11	Mar 11	Mar 11
Start Time (approx.)	07:30	11:28	13:12
Stop Time (approx.)	08:48	12:46	14:24
Total Duration of Test Run (min.)	78	78	72
Net Sampling Time (min.)	63	63	63

Sampling System Calibration Summary

	Nozzle ID No:	272-1	272-1	272-1
D _n	Nozzle Diameter (in):	0.272	0.272	0.272
	Probe ID No:	67-8-7	67-8-7	67-8-7
C _p	Pitot Coefficient:	0.8250	0.8250	0.8250
	Meter Box ID. No:	61-7	61-7	61-7
Y _d	Meter Box Yd - Field Sheet	0.9886	0.9886	0.9886
	Meter Box Yd - Database	0.9886	0.9886	0.9886
	Meter Box ΔH@ - Field Sheet	1.7796	1.7796	1.7796
	Meter Box ΔH@ - Database	1.7796	1.7796	1.7796

QA/QC

	<u>Final Leak Check</u>			
	(a) 4% of Sampling Rate (cfm)	0.0248	0.0245	0.0266
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0030	0.0030	0.0040
	<u>Sample Volume</u>			
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{msid}	Actual Sample Volume (dscf)	38.043	36.836	38.973
	<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>			
√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.1377	1.0875	1.1724
Y _{qa}	Alternative Meter Calibration Factor	1.0159	0.9922	0.9989
	Variation from full-test Y _d (average ≤ ±5%)	2.8%	0.4%	1.0%
	<u>Mean Isokinetic Sampling Rate Variation</u>			
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	98.81	96.63	97.84
	<u>Point-by-Point Isokinetic Variation</u>			
	Number of points <90%	1	0	0
	Number of points >110%	1	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0
	Average			1.4%

D41408 122414
 ILL@

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 11	Mar 11	Mar 11
Start Time (approx.)	06:46	09:24	11:58
Stop Time (approx.)	08:58	11:38	14:10
Total Duration of Test Run (min.)	132	134	132
Net Sampling Time (min.)	125	125	125

Sampling System Calibration Summary

	Nozzle ID No:	268-1	268-1	268-1
D _n	Nozzle Diameter (in):	0.268	0.268	0.268
	Probe ID No:	67-8-4	67-8-4	67-8-4
C _p	Pitot Coefficient:	0.8120	0.8120	0.8120
	Meter Box ID. No:	61-8	61-8	61-8
Y _d	Meter Box Yd - Field Sheet	1.0079	1.0079	1.0079
	Meter Box Yd - Database	1.0079	1.0079	1.0079
	Meter Box ΔH@ - Field Sheet	1.7934	1.7934	1.7934
	Meter Box ΔH@ - Database	1.7934	1.7934	1.7934

QA/QC

Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0227	0.0240	0.0235
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0030	0.0040	0.0060

Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	71.639	74.941	71.268

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0114	1.0588	1.0318
Y _{qa}	Alternative Meter Calibration Factor	0.9791	0.9730	0.9836
	Variation from full-test Y _d (average ≤ ±5%)	-2.9%	-3.5%	-2.4%

**Average
-2.9%**

Mean Isokinetic Sampling Rate Variation

	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	101.76	103.25	102.17

Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

041409 122843
K P I @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

USEPA Method 13B (Total Fluorides) QA/QC Results

Run No.	1	2	3
Date (2009)	Mar 10	Mar 10	Mar 10
Start Time (approx.)	08:17	11:31	13:16
Stop Time (approx.)	10:32	12:49	14:30
Total Duration of Test Run (min.)	135	78	74
Net Sampling Time (min.)	63	63	63

Sampling System Calibration Summary

D _n	Nozzle ID No:	272-1	272-1	272-1
	Nozzle Diameter (in):	0.272	0.272	0.272
C _p	Probe ID No:	67-8-7	67-8-7	67-8-7
	Pitot Coefficient:	0.8250	0.8250	0.8250
Y _d	Meter Box ID. No:	61-8	61-8	61-8
	Meter Box Yd - Field Sheet	1.0079	1.0079	1.0079
	Meter Box Yd - Database	1.0079	1.0079	1.0079
	Meter Box ΔH@ - Field Sheet	1.7934	1.7934	1.7934
	Meter Box ΔH@ - Database	1.7934	1.7934	1.7934

QA/QC

<u>Final Leak Check</u>				
	(a) 4% of Sampling Rate (cfm)	0.0241	0.0236	0.0225
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0080	0.0020	0.0030
<u>Sample Volume</u>				
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	38.013	35.738	33.654
<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>				
√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0958	1.0169	0.9919
Y _{qa}	Alternative Meter Calibration Factor	0.9983	0.9654	0.9948
	Variation from full-test Y _d (average ≤ ±5%)	-0.9%	-4.2%	-1.3%
				Average -2.2%
<u>Mean Isokinetic Sampling Rate Variation</u>				
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	101.59	100.60	97.41
<u>Point-by-Point Isokinetic Variation</u>				
	Number of points <90%	0	0	1
	Number of points >110%	1	1	0
	Number of points <80%	0	0	0
	Number of points >120%	0	1	0

041408 125041
 NJ @ @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 SDA Inlet

**USEPA Method 26A (HCI)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 11	Mar 11	Mar 11
Start Time (approx.)	06:57	08:29	10:02
Stop Time (approx.)	07:57	09:29	11:02
Total Duration of Test Run (min.)	60	60	60
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

	Nozzle ID No:	NA	NA	NA
D _n	Nozzle Diameter (in):	NA	NA	NA
	Probe ID No:	NA	NA	NA
C _p	Pitot Coefficient:	0.8400	0.8400	0.8400
	Meter Box ID. No:	66-7	66-7	66-7
Y _d	Meter Box Yd - Field Sheet	1.0028	1.0028	1.0028
	Meter Box Yd - Database	1.0028	1.0028	1.0028
	Meter Box ΔH@ - Field Sheet	1.7673	1.7673	1.7673
	Meter Box ΔH@ - Database	1.7673	1.7673	1.7673

QA/QC

Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0214	0.0215	0.0225
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0030	0.0030	0.0030

Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	32.509	32.232	33.398

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.0368	1.0135	1.0539
Y _{qa}	Alternative Meter Calibration Factor	1.0661	1.0454	1.0428
	Variation from full-test Y _d (average ≤ ±5%)	6.3%	4.2%	4.0%

**Average
4.8%**

041409 124830
 O K K @

Wheelabrator North Broward, Inc.
 Clean Air Project No: 10735
 Unit 3 FF Outlet

**USEPA Modified Method 26A (HCl)
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 11	Mar 11	Mar 11
Start Time (approx.)	06:57	08:29	10:02
Stop Time (approx.)	07:57	09:29	11:02
Total Duration of Test Run (min.)	60	60	60
Net Sampling Time (min.)	60	60	60

Sampling System Calibration Summary

	Nozzle ID No:	NA	NA	NA
D _n	Nozzle Diameter (in):	NA	NA	NA
	Probe ID No:	5G-48-1	5G-48-1	5G-48-1
C _p	Pitot Coefficient:	0.8400	0.8400	0.8400
	Meter Box ID. No:	66-11	66-11	66-11
Y _d	Meter Box Yd - Field Sheet	0.9897	0.9897	0.9897
	Meter Box Yd - Database	0.9897	0.9897	0.9897
	Meter Box ΔH@ - Field Sheet	1.8958	1.8958	1.8958
	Meter Box ΔH@ - Database	1.8958	1.8958	1.8958

QA/QC

Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0269	0.0273	0.0273
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0020	0.0030	0.0030

Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V _{mstd}	Actual Sample Volume (dscf)	39.839	40.040	39.658

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH _{avg}	Average of Square Root of ΔH (in. W.C.)	1.2247	1.2247	1.2247
Y _{qa}	Alternative Meter Calibration Factor	0.9769	0.9665	0.9699
	Variation from full-test Y _d (average ≤ ±5%)	-1.3%	-2.3%	-2.0%

041409 123615
 OOP@


**Average
 -1.9%**

Nozzle Calibration Sheet

Client	Wheelabrator NS Howard	Project Number	10735
Calibrated by		Unit	1-3
Date	3/10-18/2009	Runs	1-3

	Nozzle Identification	D ₁ (inches)	D ₂ (inches)	D ₃ (inches)	ΔD (inches)	D _{ave} (inches)
5129	0.268-1	0.269	0.267	0.268	0.002	0.268
135	0.272-1	0.272	0.272	0.272	0.000	0.272
23	0.266-1	0.265	0.266	0.266	0.001	0.266
210	0.275-1	0.275	0.275	0.275	0.000	0.275

D_1, D_2, D_3 = three nozzle diameter measurements
 ΔD = maximum difference between any two diameters
 $\Delta D = 0.004$ inches
 D_{ave} = average of D_1, D_2, D_3



* (40 CFR 60, Appendix A, Method 5, Section 5.1)



Meter Box Full Test Calibration

Meter Box No: 61-6

Date of Calibration: 7/23/2008

Meter Box Y_d : 0.9875

Calibration Conducted by: OLEG

Meter Box $\Delta H@$: 1.6981

Barometric Pressure: 29.34

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.390	0.50	-1.30	1.0000	0.000	5.000	5.000	106.300	111.448	5.148	77.5	77.5	77.50	92.0	90.0	91.00	12.35	0.9912	1.7422
0.390	0.50	-1.30	1.0000	0.000	5.000	5.000	111.448	116.601	5.153	77.5	77.5	77.50	92.0	90.0	91.00	12.34	0.9902	1.7393
0.977	3.00	-1.80	1.0000	0.000	10.000	10.000	142.791	153.152	10.361	77.5	77.5	77.50	98.0	91.0	94.50	9.86	0.9838	1.6627
0.971	3.00	-1.90	1.0000	0.000	10.000	10.000	153.152	163.500	10.348	77.5	77.5	77.50	97.0	91.0	94.00	9.92	0.9839	1.6830
0.688	1.50	-1.50	1.0000	0.000	10.000	10.000	166.689	177.024	10.335	77.5	77.5	77.50	95.0	90.0	92.50	14.00	0.9871	1.6791
0.688	1.50	-1.50	1.0000	0.000	10.000	10.000	177.024	187.323	10.299	77.5	77.5	77.50	94.0	89.0	91.50	14.00	0.9888	1.6821
Averages																0.98750	1.69807	

E - 17

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O) $\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Standard (in.Hg)	Gauge (in.Hg)
5.8	5.0
10.6	10.0
15.8	15.0
20.4	20.0
25.6	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 61-6 Office: _____
 Calibrated by: OLEG Client: _____
 Date: 7/23/08 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1	2	3	4	5	6	7
	Stack	Probe	Filter	Imp Out	Aux	DGM In	DGM Out
50	50	48	52				
100	100	98	102				
150	150	148	152				
200	201	198	202				
250	251	248	252				
300	300	298	302				
350	350	348	352				
400	400	398	401				
450	450	449	452				
500	501	500	501				
550	550	549	551				
600	600	599	601				

Tolerance = $\pm 2^\circ\text{F}$ difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>10/7/2007</u>
Calibration Report No: <u>R044701</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735 Meter No. 61-6 Orifice A-2
 Location warehouse Meter Yd 0.9875 Orifice K' 0.4506
 Test Date 03/25/09 Meter ΔH@ 1.6981 Orifice Cal. Date 01/21/09
 Operator r. vicere Full Test Cal. Date 07/23/08

Leak Checks

Negative Pressure Pass
No movement of manometer in one-minute

Positive Pressure Pass
No movement of manometer in one-minute

Barom. Press. (P_b) 28.94 in. Hg

Important: All leak checks must pass in order for calibration to be valid.

Run	Elapsed Time (minutes)	Meter Volume (dscf)	Meter Temperature		Ambient Temp. (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time θ (minutes)	Net Meter Volume for Run - V _m (dscf)	Avg Meter Temp. for Run T _m (°F)	DGM Calibration Factor - Y _i	Percent Variation ΔY
			Inlet (°F)	Outlet (°F)								
	0.0	838.10	71	68								
1	5.0	841.08	72	69	75	1.00	20	5.0	2.98	70.0	0.9796	0.1%
2	10.0	844.06	72	69	76	1.00	20	5.0	2.98	70.5	0.9796	0.1%
3	15.0	847.05	73	70	76	1.00	20	5.0	2.99	71.0	0.9772	-0.2%

Average Y_i 0.9788
 Cal. Error -0.9%

Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E - 19



Meter Box Full Test Calibration

Meter Box No: 61-7

Date of Calibration: 11/17/2008

Meter Box Y_d : 0.9886

Calibration Conducted by: OLEG LAVROV

Meter Box $\Delta H@$: 1.7796

Barometric Pressure: 29.42

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.952	3.00	-1.80	1.0000	0.000	10.000	10.000	508.848	519.093	10.245	68.0	68.0	68.00	81.0	76.0	78.50	10.32	0.9836	1.8019
0.951	3.00	-1.80	1.0000	0.000	10.000	10.000	519.093	529.355	10.262	68.0	68.0	68.00	84.0	77.0	80.50	10.34	0.9857	1.8055
0.395	0.50	-1.20	1.0000	0.000	5.000	5.000	534.052	539.168	5.116	68.0	68.0	68.00	79.0	77.0	78.00	12.43	0.9916	1.7395
0.396	0.50	-1.20	1.0000	0.000	5.000	5.000	539.168	544.282	5.114	68.0	68.0	68.00	79.0	77.0	78.00	12.42	0.9920	1.7367
0.673	1.50	-1.60	1.0000	0.000	10.000	10.000	548.819	559.068	10.249	68.0	68.0	68.00	82.0	77.0	79.50	14.60	0.9893	1.7999
0.674	1.50	-1.60	1.0000	0.000	10.000	10.000	559.068	569.323	10.255	68.0	68.0	68.00	82.0	78.0	80.00	14.59	0.9896	1.7941
Averages																	0.98863	1.77958

E - 20

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O)</p> <p>$\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
5.3	5.0
10.3	10.0
15.0	15.0
19.7	20.0
24.8	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 61-7 Office: _____
 Calibrated by: OLEG LAVROV Client: _____
 Date: 11/17/08 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	50	48	49				
100	100	98	99				
150	150	148	149				
200	200	198	199				
250	250	248	248				
300	300	298	299				
350	350	348	349				
400	400	398	399				
450	450	448	449				
500	500	498	499				
550	550	548	549				
600	600	598	599				

Tolerance = $\pm 2^{\circ}\text{F}$ difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735 Meter No. 61-7 Orifice B-3
 Location warehouse Meter Yd 0.9886 Orifice K' 0.4534
 Test Date 03/25/09 Meter ΔH@ 1.7796 Orifice Cal. Date 02/13/09
 Operator r. vicere Full Test Cal. Date 11/17/08

Leak Checks

Negative Pressure Pass
No movement of manometer in one-minute
 Positive Pressure Pass
No movement of manometer in one-minute

Barom. Press. (P_b) 28.94 in. Hg

Important: All leak checks must pass in order for calibration to be valid.

Run	Elapsed Time (minutes)	Meter Volume (ccf)	Meter Temperature		Ambient Temp. (F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time Θ (minutes)	Net Meter Volume for Run - V _m (ccf)	Avg Meter Temp. for Run T _m (F)	DGM Calibration Factor - Y _i	Percent Variation - ΔY _i
			Inlet (F)	Outlet (F)								
	0.0	747.20	73	70								
1	5.0	750.09	73	70	73	1.00	19	5.0	2.89	71.5	1.0212	-0.3%
2	10.0	752.97	74	71	74	1.00	19	5.0	2.88	72.0	1.0247	0.1%
3	15.0	755.85	75	72	74	1.00	19	5.0	2.88	73.0	1.0266	0.2%
Average Y_i											1.0242	
Cal. Error											3.6%	

Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

Meter Box Full Test Calibration

Meter Box No: 61-8

Date of Calibration: 10/10/2008

Meter Box Y_d : 1.0079

Calibration Conducted by: OLEG LAVROV

Meter Box $\Delta H@$: 1.7934

Barometric Pressure: 29.41

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.962	3.00	-1.70	1.0000	0.000	10.000	10.000	178.888	188.822	9.934	70.0	70.0	70.00	78.0	73.0	75.50	10.18	1.0052	1.7772
0.957	3.00	-1.70	1.0000	0.000	10.000	10.000	188.822	198.772	9.950	70.0	70.0	70.00	81.0	74.0	77.50	10.23	1.0074	1.7913
0.381	0.50	-1.00	1.0000	0.000	5.000	5.000	216.571	221.528	4.957	70.5	70.5	70.50	79.0	76.0	77.50	12.82	1.0182	1.8720
0.382	0.50	-1.00	1.0000	0.000	5.000	5.000	221.528	226.500	4.972	70.5	70.5	70.50	80.0	77.0	78.50	12.81	1.0170	1.8656
0.686	1.50	-1.30	1.0000	0.000	10.000	10.000	231.519	241.649	10.130	70.5	70.5	70.50	84.0	79.0	81.50	14.26	1.0006	1.7275
0.685	1.50	-1.30	1.0000	0.000	10.000	10.000	241.649	251.820	10.171	70.5	70.5	70.50	86.0	80.0	83.00	14.27	0.9993	1.7267
Averages																1.00794	1.79338	

E - 23

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_1 \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O)</p> <p>$\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Standard (in. Hg)	Gauge (in. Hg)
5.2	5.0
9.7	10.0
14.3	15.0
19.7	20.0
24.1	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 61-8

Office: _____

Calibrated by: OLEG LAVROV

Client: _____

Date: 10/10/08

Job No: _____

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1	2	3	4	5	6	7
	Stack	Probe	Filter	Imp Out	Aux	DGM In	DGM Out
50	49	50	50				
100	99	100	100				
150	149	150	150				
200	199	200	200				
250	249	250	250				
300	299	300	300				
350	349	350	350				
400	399	400	400				
450	449	450	450				
500	499	500	500				
550	549	550	551				
600	599	600	601				

Tolerance = $\pm 2^\circ\text{F}$ difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735 Meter No. 61-8 Orifice A-4
 Location warehouse Meter Yd 1.0079 Orifice K' 0.4959
 Test Date 03/25/09 Meter ΔH@ 1.7934 Orifice Cal. Date 01/21/09
 Operator r. vicere Full Test Cal. Date 10/10/08

Leak Checks

Negative Pressure Pass
No movement of manometer in one-minute
Positive Pressure Pass
No movement of manometer in one-minute

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 28.94 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (d-cf)	Meter Temperature		Ambient Temp. T _{amb} (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time Θ (minutes)	Net Meter Volume for Run V _n (d-cf)	Avg Meter Temp. for Run T _m (°F)	DGM Calibration Factor - Y _i	Percent Variation ΔY _i
			Inlet (°F)	Outlet (°F)								
	0.0	255.80	73	70								
1	5.0	259.11	74	70	75	1.30	18	5.0	3.31	71.8	0.9731	-0.1%
2	10.0	262.41	74	71	75	1.30	18	5.0	3.30	72.3	0.9769	0.3%
3	15.0	265.73	75	71	75	1.30	18	5.0	3.32	72.8	0.9719	-0.2%

Average Y _i	0.9740
Cal. Error	-3.4%

Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E - 25

Meter Box Full Test Calibration

Meter Box No: 66-6

Date of Calibration: 2/23/2009

Meter Box Y_d : 0.9916

Calibration Conducted by: M. Vaquero

Meter Box $\Delta H@$: 1.8053

Barometric Pressure: 29.88

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.979	3.00	-1.90	1.0000	0.000	10.000	10.000	562.625	572.791	10.166	65.0	65.0	65.00	75.0	73.0	74.00	10.25	0.9886	1.7401
0.979	3.00	-1.90	1.0000	0.000	10.000	10.000	572.791	582.945	10.154	65.0	65.0	65.00	75.0	73.0	74.00	10.26	0.9897	1.7435
0.384	0.50	-1.20	1.0000	0.000	5.000	5.000	625.330	630.420	5.090	65.0	65.0	65.00	73.0	72.0	72.50	13.07	0.9922	1.8897
0.384	0.50	-1.20	1.0000	0.000	5.000	5.000	630.420	635.515	5.095	65.0	65.0	65.00	73.0	72.0	72.50	13.07	0.9912	1.8897
0.684	1.50	-1.50	1.0000	0.000	10.000	10.000	639.532	649.665	10.133	65.0	65.0	65.00	74.0	72.0	73.00	14.68	0.9945	1.7880
0.685	1.50	-1.50	1.0000	0.000	10.000	10.000	649.665	659.807	10.142	65.0	65.0	65.00	74.0	72.0	73.00	14.65	0.9937	1.7807
Averages																	0.99165	1.80528

E - 26

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O)</p> <p>$\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b (T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Standard (in.Hg)	Gauge (in.Hg)
5.0	5.0
10.2	10.0
15.2	15.0
20.0	20.0
24.4	24.5

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-6

Office: _____

Calibrated by: M. Vaquero

Client: _____

Date: 2/23/09

Job No: _____

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	48	48	49				
100	98	98	99				
150	148	148	149				
200	198	199	199				
250	248	249	249				
300	298	298	299				
350	348	349	349				
400	398	399	399				
450	448	449	449				
500	498	499	499				
550	548	549	549				
600	598	599	599				

Tolerance = ±2°F difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>10/13/2009</u>
Calibration Report No: <u>R044701</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735 Meter No. 66-6 Orifice A-4
 Location warehouse Meter Yd 0.9916 Orifice K' 0.4959
 Test Date 03/24/09 Meter ΔH@ 1.8053 Orifice Cal. Date 01/21/09
 Operator r. vicere Full Test Cal. Date 02/23/09

Leak Checks

Negative Pressure Pass
 No movement of manometer in one-minute

Positive Pressure Pass
 No movement of manometer in one-minute

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 28.95 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (scf)	Meter Temperature		Ambient Temp. T _{amb} (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V _m (scf)	Avg Meter Temp. for Run T _m (°F)	DGM Calibration Factor - Y _i	Percent Variation - ΔY _i
			Inlet (°F)	Outlet (°F)								
	0.0	697.90	72	71								
1	5.0	701.17	72	69	77	1.30	17	5.0	3.27	71.0	0.9817	0.7%
2	10.0	704.48	72	69	79	1.30	17	5.0	3.31	70.5	0.9672	-0.8%
3	15.0	707.76	73	70	80	1.30	17	5.0	3.28	71.0	0.9760	0.1%
Average Y_i											0.9750	
Cal. Error											-1.7%	

Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec. : } \text{Cal. Error} \leq \pm 5\%$$

Meter Box Full Test Calibration

Meter Box No: 66-7

Date of Calibration: 2/20/2009

Meter Box Y_d : 1.0028

Calibration Conducted by: Martin Vaquero

Meter Box $\Delta H@$: 1.7673

Barometric Pressure: 29.36

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.960	3.00	-1.80	1.0000	0.000	10.000	10.000	930.751	940.869	10.118	65.5	65.5	65.50	80.0	73.0	76.50	10.27	0.9970	1.7812
0.961	3.00	-1.80	1.0000	0.000	10.000	10.000	940.869	950.970	10.101	65.5	65.5	65.50	80.0	73.0	76.50	10.26	0.9987	1.7777
0.394	0.50	-1.00	1.0000	0.000	5.000	5.000	954.620	959.686	5.066	65.5	65.5	65.50	77.0	74.0	75.50	12.51	1.0020	1.7587
0.394	0.50	-1.00	1.0000	0.000	5.000	5.000	959.686	964.737	5.051	65.5	65.5	65.50	76.0	74.0	75.00	12.51	1.0040	1.7587
0.681	1.50	-1.40	1.0000	0.000	10.000	10.000	980.882	990.970	10.088	65.5	65.5	65.50	80.0	75.0	77.50	14.47	1.0066	1.7614
0.680	1.50	-1.40	1.0000	0.000	10.000	10.000	990.970	1001.037	10.067	65.5	65.5	65.50	80.0	75.0	77.50	14.49	1.0087	1.7663
Averages																1.00282	1.76732	

E-29

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O)</p> <p>$\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Standard (in. Hg)	Gauge (in. Hg)
5.0	5.0
10.2	10.0
15.2	15.0
19.8	20.0
25.2	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-7

Office: _____

Calibrated by: Martin Vaquero

Client: _____

Date: 2/20/09

Job No: _____

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1	2	3	4	5	6	7
	Stack	Probe	Filter	Imp Out	Aux	DGM In	DGM Out
50	51	51	51				
100	100	100	101				
150	151	151	151				
200	201	201	201				
250	252	250	251				
300	302	301	301				
350	352	351	351				
400	401	400	401				
450	450	450	451				
500	500	500	501				
550	550	550	551				
600	601	600	601				

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735 Meter No. 66-7 Orifice B-5
 Location warehouse Meter Yd 1.0028 Orifice K' 0.5612
 Test Date 03/25/09 Meter ΔH@ 1.7673 Orifice Cal. Date 02/13/09
 Operator r. vicere Full Test Cal. Date 02/20/09

Leak Checks

Negative Pressure Pass
No movement of manometer in one-minute
Positive Pressure Pass
No movement of manometer in one-minute

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 28.94 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcl)	Meter Temperature		Ambient Temp. T _{amb} (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V _m (dcl)	Avg Meter Temp. for Run T _m (°F)	DGM Calibration Factor - Y _i	Percent Variation (ΔY _i)
			Inlet (°F)	Outlet (°F)								
	0.0	632.90	73	70								
1	5.0	636.47	73	70	71	1.50	18	5.0	3.57	71.5	1.0238	-0.2%
2	10.0	640.02	74	70	72	1.50	18	5.0	3.55	71.8	1.0291	0.3%
3	15.0	643.59	74	71	72	1.50	18	5.0	3.57	72.3	1.0243	-0.1%

Average Y_i	1.0257
Cal. Error	2.3%

Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E-31

Meter Box Full Test Calibration

Meter Box No: 66-11

Date of Calibration: 10/29/2008

Meter Box Y_d : 0.9897

Calibration Conducted by: OLEG LAVROV

Meter Box $\Delta H@$: 1.8958

Barometric Pressure: 29.38

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.938	3.00	-1.90	1.0000	0.000	10.000	10.000	17.805	27.997	10.192	69.0	69.0	69.00	83.0	75.0	79.00	10.44	0.9875	1.8570
0.938	3.00	-1.90	1.0000	0.000	10.000	10.000	27.997	38.210	10.213	69.0	69.0	69.00	84.0	76.0	80.00	10.44	0.9873	1.8536
0.371	0.50	-1.30	1.0000	0.000	5.000	5.000	42.333	47.433	5.100	69.0	69.0	69.00	80.0	77.0	78.50	13.22	0.9935	1.9777
0.371	0.50	-1.30	1.0000	0.000	5.000	5.000	47.433	52.542	5.109	69.0	69.0	69.00	80.0	77.0	78.50	13.21	0.9918	1.9747
0.660	1.50	-1.50	1.0000	0.000	10.000	10.000	67.288	77.585	10.297	69.0	69.0	69.00	85.0	80.0	82.50	14.84	0.9885	1.8587
0.661	1.50	-1.50	1.0000	0.000	10.000	10.000	77.585	87.887	10.302	69.0	69.0	69.00	86.0	81.0	83.50	14.83	0.9898	1.8528
Averages																	0.98974	1.89577

E-32

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O)</p> <p>$\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \right] \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Standard (in. Hg)	Gauge (in. Hg)
4.5	5.0
9.7	10.0
14.9	15.0
20.3	20.0
25.3	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-11 Office: _____
 Calibrated by: OLEG LAVROV Client: _____
 Date: 10/29/08 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	50	50				
100	99	100	100				
150	149	150	150				
200	199	200	200				
250	249	250	250				
300	299	300	300				
350	349	350	350				
400	399	400	399				
450	449	450	449				
500	499	499	499				
550	549	549	549				
600	599	600	599				

Tolerance = ±2°F difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10715 Meter No. 66-11 Orifice A-2
 Location warehouse Meter Yd 0.9897 Orifice K' 0.4506
 Test Date 03/26/09 Meter ΔH@ 1.8958 Orifice Cal. Date 01/21/09
 Operator r. vicere Full Test Cal. Date 10/29/08

Leak Checks

Negative Pressure Pass
 No movement of manometer in one-minute

Positive Pressure Pass
 No movement of manometer in one-minute

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 29.07 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. T _{amb} (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time θ (minutes)	Net Meter Volume for Run - V _m (dcf)	Avg Meter Temp. for Run T _m (°F)	OGM Calibration Factor - Y _i	Percent Variation ΔY _i
			Inlet (°F)	Outlet (°F)								
	0.0	587.30	72	69								
1	5.0	590.28	73	70	75	1.10	20	5.0	2.98	71.0	0.9812	0.0%
2	10.0	593.26	73	70	76	1.10	20	5.0	2.98	71.5	0.9812	0.0%
3	15.0	596.24	74	71	77	1.10	20	5.0	2.98	72.0	0.9812	0.0%

Average Y_i 0.9812
 Cal. Error -0.9%

Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}}{\bar{Y}} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y} - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E - 34

Meter Box Full Test Calibration

Meter Box No: 66-22

Date of Calibration: 11/13/2008

Meter Box Y_d : 0.9937

Calibration Conducted by: Martin Vaquero

Meter Box $\Delta H@$: 1.7498

Barometric Pressure: 29.01

				Standard Meter Gas Volume (ft ³)			Meter Box Gas Volume (ft ³)			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y_{ds}	Initial	Final	V_{ds} Net	Initial	Final	V_d Net	T_{is} In	T_{os} Out	T_{ds} Avg.	T_i In	T_o Out	T_d Avg.	Θ	Y_d	$\Delta H@$
0.966	3.00	-1.90	1.0000	0.000	10.000	10.000	937.916	948.134	10.218	69.5	69.5	69.50	87.0	79.0	83.00	10.00	0.9912	1.7160
0.966	3.00	-1.90	1.0000	0.000	11.000	11.000	948.134	959.364	11.230	69.5	69.5	69.50	87.0	80.0	83.50	11.00	0.9930	1.7128
0.385	0.50	-1.10	1.0000	0.000	5.000	5.000	962.944	968.050	5.106	69.5	69.5	69.50	80.0	79.0	79.50	12.55	0.9937	1.8018
0.385	0.50	-1.10	1.0000	0.000	5.000	5.000	968.050	973.153	5.103	69.5	69.5	69.50	80.0	79.0	79.50	12.55	0.9943	1.8018
0.679	1.50	-1.40	1.0000	0.000	10.000	10.000	974.427	984.641	10.214	69.5	69.5	69.50	85.0	79.0	82.00	14.23	0.9948	1.7373
0.680	1.50	-1.40	1.0000	0.000	10.000	10.000	984.641	994.859	10.218	69.5	69.5	69.50	85.0	80.0	82.50	14.21	0.9954	1.7293
Averages																	0.99374	1.74982

E - 35

Nomenclature	Equations
<p>P_b Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure Differential (in. H₂O)</p> <p>ΔP Inlet Pressure Differential (in. H₂O)</p> <p>V_d Gas Meter Volume - Dry (ft³)</p> <p>V_{ds} Standard Meter Volume - Dry (ft³)</p> <p>T_d Average Meter Box Temperature (°F)</p> <p>T_o Outlet Meter Box Temperature (°F)</p> <p>T_{ds} Average Standard Meter Temperature (°F)</p> <p>Y_d Meter Correction Factor (unitless), $Y_i \leq Y_{avg} \pm 0.02$</p> <p>$Y_{ds}$ Standard Meter Correction Factor (unitless)</p> <p>$\Delta H@$ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H₂O) $\Delta H@_i \leq \Delta H@_{avg} \pm 0.2$</p> <p>$\Theta$ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[\frac{V_{ds}}{V_d} \left[\frac{T_d + 460}{T_{ds} + 460} \right] \left[\frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right] \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[\frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
5.0	5.0
10.1	10.0
14.7	15.0
19.3	20.0
24.0	25.0

Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-22 Office: _____
 Calibrated by: Martin Vaquero Client: _____
 Date: 11/13/08 Job No: _____
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	49	49				
100	99	99	99				
150	149	149	149				
200	199	199	199				
250	249	249	249				
300	299	299	299				
350	349	349	349				
400	399	399	399				
450	449	449	449				
500	499	499	499				
550	549	549	549				
600	599	599	599				

Tolerance = ±2°F difference from reference setting.

Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735 Meter No. 66-22 Orifice A-2
 Location warehouse Meter Yd 0.9937 Orifice K' 0.4506
 Test Date 03/24/09 Meter ΔH@ 1.7498 Orifice Cal. Date 01/21/09
 Operator r. vicere Full Test Cal. Date 11/13/08

Leak Checks

Negative Pressure Pass
 No movement of manometer in one-minute

Positive Pressure Pass
 No movement of manometer in one-minute

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P_b) 28.95 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcl)	Meter Temperature		Ambient Temp. (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - G (minutes)	Net Meter Volume for Run - V _m (dcl)	Avg Meter Temp. for Run T _m (°F)	DCM Calibration Factor - Y _i	Percent Variation - ΔY _i
			Inlet (°F)	Outlet (°F)								
	0.0	324.90	72	68								
1	5.0	327.89	74	68	75	1.10	21	5.0	2.99	70.5	0.9770	-0.6%
2	10.0	330.86	75	69	78	1.10	21	5.0	2.97	71.5	0.9827	0.0%
3	15.0	333.81	77	70	81	1.10	21	5.0	2.95	72.8	0.9889	0.6%

Average Y _i	0.9829
Cal. Error	-1.1%

Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times \left(P_b + \frac{\Delta H}{13.6}\right) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E - 37

Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-4
 Project Number: 10735

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	66	68	-2	0.38%	
2	200°F-250°F	250	255	-5	0.70%	%Difference ≤ 1.5

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel Reference Pitot Cp: 0.99

Pitot Side 'A' :				Abs. Deviation from Avg. C _{P(A)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{P(S)} *		
1	0.546	0.836	0.801	0.008	
2	0.553	0.826	0.810	0.001	
3	0.546	0.806	0.815	0.007	
Side 'A' Average Probe C _{P(A)} =			0.8085	0.0053	

Pitot Side 'B' :				Abs. Deviation from Avg. C _{P(B)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{P(S)} *		
1	0.550	0.823	0.810	0.006	
2	0.550	0.810	0.816	0.000	
3	0.553	0.803	0.822	0.006	
Side 'B' Average Probe C _{P(B)} =			0.8157	0.0039	

'A' Average C _p 0.809	—	'B' Average C _p 0.816	=	Difference -0.007	Specification Difference ≤ 0.01
-------------------------------------	---	-------------------------------------	---	----------------------	--------------------------------------

Does assembly meet specifications? YES → If "Yes", C_p= Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta p_{(STD)}}{\Delta p_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

All specifications are from EPA-600/9-76-005, section 3.1

Probe Cp= 0.812 Calibrated by: W. Berry Date: 01/06/2009



Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-4

Project Number: _____

Thermocouple Calibration

Reference Type: Thermometer Reference I.D. No: _____ Pyrometer I.D. No: _____ Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient					
2	200°F-250°F					

* Based on Absolute Temperature (Rankine)

%Difference ≤ 1.5

Geometric Pitot Calibration

Is pitot assembly in good repair? Yes No If no, explain:

"S" Pitot

Dimensions	Dimensions	Specifications	Within Spec?
$\alpha 1 = 2$	$\alpha 2 = 1$	$\leq 10^\circ$	YES
$\beta 1 = 0$	$\beta 2 = 0$	$\leq 5^\circ$	YES
$\gamma = 1$	$\theta = 2$	None	N/A
$A = 0.713$		None	N/A
$Dt = 0.244$		$0.1875" \leq Dt \leq 0.375"$	YES

	Calculations	Specifications	Within Spec?
$A/2 = P_a = P_b =$	0.357 inches	None	N/A
$P_a/Dt = P_b/Dt =$	1.461 inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma =$	0.012 inches	$\leq 0.125"$	YES
$w = A \sin \theta =$	0.025 inches	$\leq 0.03125"$	YES

Pitot $C_p = 0.84$ according to 40 CFR 60 section 10.1

Standard Pitot

	Measurement	Specification	Calculation	Within Spec?
Tube O.D.		None		
Static Hole I.D.		within 10% of (0.1*O.D.)		
Tip to Static		$\geq 6^*O.D.$		
Static to Bend		$\geq 8^*O.D.$		

Pitot $C_p =$

Calibrated by: Danial Luckhard

Date: 1/6/2009

Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-7

Project Number: 10735

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	72.0	79.0	-7	1.32%	%Difference ≤ 1.5
2	200°F-250°F	213.0	213.0	0	0.00%	

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot tube calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A' :				Abs. Deviation from Avg. C _{p(A)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.563	0.822	0.820	0.009	
2	0.568	0.800	0.834	0.006	
3	0.571	0.811	0.830	0.002	
Side 'A' Average Probe C _{p(A)} =			0.8281	0.0057	

Pitot Side 'B' :				Abs. Deviation from Avg. C _{p(B)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.573	0.822	0.827	0.005	
2	0.574	0.832	0.822	0.001	
3	0.570	0.839	0.816	0.006	
Side 'B' Average Probe C _{p(B)} =			0.8216	0.0040	

'A' Average C _p 0.828	-	'B' Average C _p 0.822	=	Difference 0.006	Specification Difference ≤ 0.01
-------------------------------------	---	-------------------------------------	---	---------------------	--------------------------------------

Does assembly meet specifications?

YES

If "Yes", C_p = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \bar{C}_{P(A \text{ or } B)}|$$

All Specifications are from EPA-600/9-76-005, Section 3.7.

Probe Cp= 0.825

Calibrated by: W. Berry

Date: 03/05/2009



Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-7
 Project Number: 10735

Thermocouple Calibration

Reference Type: Thermometer Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient	72.0	79.0	-7.0	1.32%	YES
2	200°F-250°F	213.0	213.0	0.0	0.00%	YES

* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5

YES

Geometric Pitot Calibration

Is pitot assembly in good repair? Yes No If no, explain:

"S" Pitot

Dimensions		Dimensions		Specifications	Within Spec?
$\alpha 1 =$	2	$\alpha 2 =$	1	$\leq 10^\circ$	YES
$\beta 1 =$	2	$\beta 2 =$	1	$\leq 5^\circ$	YES
$\gamma =$	2	$\theta =$	1	None	N/A
A =	0.716			None	N/A
Dt =	0.250			$0.1875" \leq Dt \leq 0.375"$	YES

Calculations		Specifications	Within Spec?
$A/2 = Pa = Pb =$	0.358 inches	None	N/A
$Pa/Dt = Pb/Dt =$	1.432 inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma =$	0.025 inches	$\leq 0.125"$	YES
$w = A \sin \theta =$	0.012 inches	$\leq 0.03125"$	YES

Pitot Cp= **0.84** according to 40 CFR 60 section 10.1

Standard Pitot

	Measurement	Specification	Calculation	Within Spec?
Tube O.D.		None		
Static Hole I.D.		within 10% of (0.1*O.D.)		
Tip to Static		$\geq 6 \times O.D.$		
Static to Bend		$\geq 8 \times O.D.$		

Pitot Cp=

Calibrated by: N. Hitchins

Date: 3/4/2009

Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-17

Project Number: 10735

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	73.0	74.0	-1	0.19%	%Difference ≤ 1.5
2	200°F-250°F	221.0	219.0	2	0.29%	

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A' :				Abs. Deviation from Avg. C _{p(A)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.566	0.801	0.832	0.006	
2	0.570	0.794	0.839	0.001	
3	0.566	0.781	0.843	0.005	
Side 'A' Average Probe C _{p(A)} =			0.8381	0.0039	

Pitot Side 'B' :				Abs. Deviation from Avg. C _{p(B)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.573	0.815	0.830	0.001	
2	0.565	0.808	0.828	0.000	
3	0.566	0.809	0.828	0.001	
Side 'B' Average Probe C _{p(B)} =			0.8288	0.0007	

'A' Average C _p 0.838	—	'B' Average C _p 0.829	=	Difference 0.009	Specification Difference ≤ 0.01
-------------------------------------	---	-------------------------------------	---	---------------------	--------------------------------------

Does assembly meet specifications?

YES

If "Yes", C_p = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta p_{(STD)}}{\Delta p_{(S)}}}$$

$$** \text{Deviation} = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

All specifications are from EPA 600/9-76-005, section 3.

Probe Cp= 0.833

Calibrated by: W. Berry

Date: 03/05/2009



Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-17
 Project Number: 10735

Thermocouple Calibration

Reference Type: Thermometer Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient	73.0	74.0	-1.0	0.19%	YES
2	200°F-250°F	221.0	219.0	2.0	0.29%	YES

* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5
YES

Geometric Pitot Calibration

Is pitot assembly in good repair? Yes No If no, explain:

"S" Pitot

Dimensions	Dimensions	Specifications	Within Spec?
$\alpha 1 = 1$	$\alpha 2 = 1$	$\leq 10^\circ$	YES
$\beta 1 = 1$	$\beta 2 = 1$	$\leq 5^\circ$	YES
$\gamma = 0$	$\theta = 1$	None	N/A
$A = 0.714$		None	N/A
$Dt = 0.250$		$0.1875" \leq Dt \leq 0.375"$	YES

Calculations	Specifications	Within Spec?
$A/2 = Pa = Pb = 0.357$ inches	None	N/A
$Pa/Dt = Pb/Dt = 1.428$ inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma = 0.000$ inches	$\leq 0.125"$	YES
$w = A \sin \theta = 0.012$ inches	$\leq 0.03125"$	YES

Pitot Cp= **0.84** according to 40 CFR 60 section 10.1

Standard Pitot

	Measurement	Specification	Calculation	Within Spec?
Tube O.D.		None		
Static Hole I.D.		within 10% of (0.1*O.D.)		
Tip to Static		$\geq 6 \times O.D.$		
Static to Bend		$\geq 8 \times O.D.$		

Pitot Cp=

Calibrated by: N. Hitchins

Date: 3/4/2009

Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-1

Project Number:

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	68.0	71.0	-3	0.57%	%Difference ≤ 1.5
2	200°F-250°F	232.0	224.0	8	1.16%	

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A' :				Abs. Deviation from Avg. C _{p(A)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.571	0.826	0.823	0.003	
2	0.572	0.816	0.829	0.002	
3	0.570	0.816	0.828	0.001	
Side 'A' Average Probe C _{p(A)} =			0.8265	0.0021	

Pitot Side 'B' :				Abs. Deviation from Avg. C _{p(B)} **	Specification Avg. C _p Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *		
1	0.564	0.830	0.816	0.003	
2	0.571	0.829	0.822	0.002	
3	0.568	0.827	0.821	0.001	
Side 'B' Average Probe C _{p(B)} =			0.8193	0.0023	

'A' Average C _p 0.827	-	'B' Average C _p 0.819	=	Difference 0.008	Specification Difference ≤ 0.01
-------------------------------------	---	-------------------------------------	---	---------------------	--------------------------------------

Does assembly meet specifications?

YES



If "Yes", C_p = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

All specifications are from EPA 600/9-76-005 section 9

Probe Cp= 0.823

Calibrated by: W. Berry

Date: 03/04/2009

Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-1
 Project Number: 10735

Thermocouple Calibration

Reference Type: Thermometer Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient	68.0	71.0	-3.0	0.57%	YES
2	200°F-250°F	232.0	224.0	8.0	1.16%	YES

* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5

YES

Geometric Pitot Calibration

Is pitot assembly in good repair? Yes No If no, explain:

"S" Pitot

Dimensions		Dimensions		Specifications	Within Spec?
$\alpha 1 =$	1	$\alpha 2 =$	1	$\leq 10^\circ$	YES
$\beta 1 =$	2	$\beta 2 =$	1	$\leq 5^\circ$	YES
$\gamma =$	1	$\theta =$	1	None	N/A
A =	0.714			None	N/A
Dt =	0.250			$0.1875" \leq Dt \leq 0.375"$	YES

Calculations		Specifications	Within Spec?
$A/2 = Pa = Pb =$	0.357 inches	None	N/A
$Pa/Dt = Pb/Dt =$	1.428 inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma =$	0.012 inches	$\leq 0.125"$	YES
$w = A \sin \theta =$	0.012 inches	$\leq 0.03125"$	YES

Pitot Cp= **0.84** according to 40 CFR 60 section 10.1

Standard Pitot

Measurement	Specification	Calculation	Within Spec?
Tube O.D.	None		
Static Hole I.D.	within 10% of (0.1*O.D.)		
Tip to Static	$\geq 6 \times O.D.$		
Static to Bend	$\geq 8 \times O.D.$		

Pitot Cp=

Calibrated by: N. Hitchins

Date: 3/4/2009

Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-4

Project Number: 10735

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	69.0	71.0	-2	0.38%	%Difference ≤ 1.5
2	200°F-250°F	223.0	217.0	6	0.88%	

* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A' :

Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *	Abs. Deviation from Avg. C _{p(A)} **	Specification
1	0.561	0.822	0.818	0.002	Avg. C _p Deviations ≤ 0.01
2	0.568	0.822	0.823	0.003	
3	0.564	0.822	0.820	0.001	
Side 'A' Average Probe C _{p(A)} =			0.8204	0.0020	

Pitot Side 'B' :

Trial No.	Reference ΔP	Probe ΔP	Probe C _{p(S)} *	Abs. Deviation from Avg. C _{p(B)} **	Specification
1	0.568	0.815	0.826	0.001	Avg. C _p Deviations ≤ 0.01
2	0.563	0.816	0.823	0.002	
3	0.574	0.825	0.826	0.001	
Side 'B' Average Probe C _{p(B)} =			0.8249	0.0015	

'A' Average C _p 0.820	-	'B' Average C _p 0.825	=	Difference -0.005	Specification Difference ≤ 0.01
-------------------------------------	---	-------------------------------------	---	----------------------	--------------------------------------

Does assembly meet specifications?

YES

→ If "Yes", C_p = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

All specifications are from EPA 800/9-76-005, section 3.

Probe Cp= 0.823

Calibrated by: W. Berry

Date: 03/04/2009



Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-4
Project Number: 10735

Thermocouple Calibration

Reference Type: Thermometer Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient	69.0	71.0	-2.0	0.38%	YES
2	200°F-250°F	223.0	217.0	6.0	0.88%	YES

* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5

YES

Geometric Pitot Calibration

Is pitot assembly in good repair? Yes No If no, explain:

"S" Pitot

Dimensions	Dimensions	Specifications	Within Spec?
$\alpha 1 = 2$	$\alpha 2 = 1$	$\leq 10^\circ$	YES
$\beta 1 = 0$	$\beta 2 = 2$	$\leq 5^\circ$	YES
$\gamma = 2$	$\theta = 1$	None	N/A
$A = 0.724$		None	N/A
$Dt = 0.250$		$0.1875" \leq Dt \leq 0.375"$	YES

Calculations	Specifications	Within Spec?
$A/2 = Pa = Pb = 0.362$ inches	None	N/A
$Pa/Dt = Pb/Dt = 1.448$ inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma = 0.025$ inches	$\leq 0.125"$	YES
$w = A \sin \theta = 0.013$ inches	$\leq 0.03125"$	YES

Pitot Cp= **0.84** according to 40 CFR 60 section 10.1


Standard Pitot

	Measurement	Specification	Calculation	Within Spec?
Tube O.D.		None		
Static Hole I.D.		within 10% of (0.1*O.D.)		
Tip to Static		$\geq 6*O.D.$		
Static to Bend		$\geq 8*O.D.$		

Pitot Cp=

Calibrated by: N. Hitchins

Date: 3/4/2009



Air Liquide America
Specialty Gases LLC



RATA CLASS

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory

P.O. No.: 57134-71-65000
AIR LIQUIDE AMERICA SPECIALTY GASES LLC Project No.: 05-72060-003
1290 COMBERMERE STREET
TROY, MI 48083

Customer

CLEAN AIR ENGINEERING
DON ALLEN
500 W. WOOD STREET
PALATINE IL 60067

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALMO45493 Certification Date: 13Jan2009 Exp. Date: 13Jan2012
Cylinder Pressure***: 2000 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)		ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	14.0	%	+/- 1%	Direct NIST and NMi
OXYGEN	6.05	%	+/- 1%	Direct NIST and NMi
NITROGEN	BALANCE			

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2000	01Jul2009	K026898	5.006 %	CARBON DIOXIDE
NTRM 2350	01Dec2011	K016398	23.20 %	OXYGEN

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
PIR/2000/609015	13Jan2009	NDIR
CAI/110P/V03018	22Dec2008	PARAMAGNETIC

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)


First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE


Date: 13Jan2009	Response Unit: MV	
Z1 = 0.00000	R1 = 39.30000	T1 = 83.10000
R2 = 39.40000	Z2 = 0.00000	T2 = 83.10000
Z3 = 0.00000	T3 = 83.10000	R3 = 39.40000
Avg. Concentration:	14.00	%



Concentration = A + Bx + Cx2 + Dx3 + Ex4	
r = 0.999998	
Constants:	A = -0.0052472
B = 0.108852633	C = 0.0002522
D = 5.75883E-06	E = 0

OXYGEN

Date: 13Jan2008	Response Unit: %	
Z1 = 0.00000	R1 = 23.20000	T1 = 6.06000
R2 = 23.20000	Z2 = 0.00000	T2 = 6.06000
Z3 = 0.00000	T3 = 6.06000	R3 = 23.20000
Avg. Concentration:	6.053	%



Concentration = A + Bx + Cx2 + Dx3 + Ex4	
r = 0.999999	
Constants:	A = -0.00558057
B = 0.999821843	C = 0
D = 0	E = 0

APPROVED BY: _____

JEFF BROTEAU

RATA CLASS



Scott Specialty Gases

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory

SCOTT SPECIALTY GASES
1290 COMBERMERE STREET
TROY, MI 48083

P.O. No.: 55647-71-65000
Project No.: 05-53475-001

Customer

CLEAN AIR ENGINEERING
DON ALLEN
500 W. WOOD STREET
PALATINE IL 60067

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: AAL9828 Certification Date: 05Apr2007 Exp. Date: 04Apr2010
Cylinder Pressure***: 1900 PSIG

<u>COMPONENT</u>	<u>CERTIFIED CONCENTRATION (Moles)</u>	<u>ANALYTICAL ACCURACY**</u>	<u>TRACEABILITY</u>
CARBON DIOXIDE	6.054 %	+/- 1%	Direct NIST and NMi
OXYGEN	14.02 %	+/- 1%	Direct NIST and NMi
NITROGEN	BALANCE		

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

REFERENCE STANDARD

<u>TYPE/SRM NO.</u>	<u>EXPIRATION DATE</u>	<u>CYLINDER NUMBER</u>	<u>CONCENTRATION</u>	<u>COMPONENT</u>
NTRM 2300	01Nov2010	1D002807	23.04 %	CARBON DIOXIDE
NTRM 2350	01May2009	K026542	23.48 %	OXYGEN

INSTRUMENTATION

<u>INSTRUMENT/MODEL/SERIAL#</u>	<u>DATE LAST CALIBRATED</u>	<u>ANALYTICAL PRINCIPLE</u>
VARIAN/3400/10693	04Apr2007	THERMAL CONDUCTIVITY
CALIFORNIA/110P/S02041	05Apr2007	PARAMAGNETIC

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)


First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE


Date: 04Apr2007 Response Unit: AREA
Z1 = 0.00000 R1 = 1166892. T1 = 305456.0
R2 = 1166031. Z2 = 0.00000 T2 = 305856.0
Z3 = 0.00000 T3 = 305949.0 R3 = 1166669.
Avg. Concentration: 6.054 %



Concentration = A + Bx + Cx2 + Dx3 + Ex4
r = 0.999996
Constants: A = 0.010560
B = 0.000020 C = 0
D = 0 E = 0

OXYGEN

Date: 05Apr2007 Response Unit: %
Z1 = 0.00000 R1 = 23.48000 T1 = 14.03000
R2 = 23.48000 Z2 = 0.00000 T2 = 14.03000
Z3 = 0.00000 T3 = 14.02000 R3 = 23.49000
Avg. Concentration: 14.02 %



Concentration = A + Bx + Cx2 + Dx3 + Ex4
r = 0.999999
Constants: A = -0.002923
B = 0.999759 C = 0
D = 0 E = 0

APPROVED BY: _____



AIR LIQUIDE

Scott Specialty Gases
Air Liquide America Specialty Gases LLC

Shipped 1290 COMBERMERE STREET
From: TROY MI 48083
Phone: 248-589-2950 Fax: 248-589-2134
C E R T I F I C A T E O F A N A L Y S I S

WAREHOUSE/STOCK PROJECT #: 05-69004-002
WAREHOUSE/STOCK/ PO#: GENERAL STOCK
CHICAGO WAREHOUSE ITEM #: 0501813 AL
868 SIVERT DATE: 15Sep2008
WOOD DALE IL 60191

CYLINDER #: ALM061790
FILL PRESSURE: 02000 PSIG

PURE MATERIAL: NITROGEN CAS# 7727-37-9

GRADE: ZERO GAS

PURITY: 99.998%

<u>IMPURITY</u>	<u>MAXIMUM</u> <u>CONCENTRATIONS</u>
THC	0.5 PPM

ANALYST: 