

REPORT ON MERCURY TESTING

WHEELABRATOR NORTH BROWARD  
UNIT 1 FF OUTLET  
POMPANO BEACH, FLORIDA

CLIENT REFERENCE No: 14200357  
CLEANAIR PROJECT No: 9281-3  
REVISION 0: JULY 1, 2003



**Wheelabrator North Broward Inc.**

A Waste Management Company

2600 N.W. 48th Street  
Pompano Beach, FL 33073  
(954) 971-8701  
(954) 971-8703 Fax

**RECEIVED**

JUL 09 2003

**BUREAU OF AIR REGULATION**

July 7, 2003

CERTIFIED MAIL  
#70022030000323872720

Mr. John Moulton  
Florida Department of Environmental Protection  
400 North Congress Ave., Suite 200  
West Palm Beach, FL 33401

Re: Wheelabrator North Broward *0112120-NA-AC*  
F.A.C. 62-296.416 Quarterly Mercury Stack Testing *PSD-FL-112*  
Second Quarter of 2003, Report Submittal

Dear Ms. Meeker:

As required by F.A.C. 62-296.416, please find enclosed the 2003 second quarter report on mercury stack testing which was conducted on Unit #1.

If there are any questions, please contact this office at (954) 971-8701.

Sincerely,

Paul Grego  
Plant Manager

cc: USEPA, Region IV, Pesticides and Toxics Management Division, Air & EPCRA Enforcement  
Branch, Air Enforcement Section CERTIFIED MAIL#70022030000323872690  
**FDEP**, Tallahassee, Bureau of Air Regulation, New Source Review Section,  
CERTIFIED MAIL#70022030000323872706  
Broward County Department of Planning and Environmental Protection, Air Quality Division  
CERTIFIED MAIL#70022030000323872713

Chuck Faller (with)  
Matt Killeen (without)  
Tim Porter (without)  
Ray Schauer - MPI - (with)  
Jeff Turpin - BCOIWM (without)  
File: 3.7.2 (without)  
5.1.3.2 (without)

s:/admin/receptionist/070703



**Wheelabrator North Broward  
Certification by Responsible Official**

*I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this submittal. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements and information in this document are true, accurate and complete.*

Signature: Paul Grego  
Paul Grego

Date: 7/7/03



Wheelabrator North Broward  
2600 NW 48<sup>th</sup> Street  
Pompano Beach, FL 33073

---

**REPORT ON MERCURY TESTING**

Performed for:  
**WHEELABRATOR NORTH BROWARD  
UNIT 1 FF OUTLET  
POMPANO BEACH, FLORIDA**

Client Reference No: 14200357  
CleanAir Project No: 9281-3  
Revision 0: July 1, 2003


---

To the best of our knowledge, the data presented in this report are accurate, complete and error free, legible and representative of the actual emissions during the test program.

Submitted by,

  
\_\_\_\_\_  
Scott Brown

Reviewed by,

  
\_\_\_\_\_  
Peter Kaufmann

**CONTENTS**

**1 PROJECT OVERVIEW .....1-1**  
     Table 1-1: Schedule of Activities .....1-1  
     Table 1-2: Summary of Test Results .....1-2

**2 RESULTS .....2-1**  
     Table 2-1: Unit 1 FF Outlet - Mercury .....2-1  
     Table 2-2: Quality Assurance and Quality Control .....2-2

**3 DESCRIPTION OF INSTALLATION.....3-1**  
     Figure 3-1: General Process Schematic .....3-1  
     Figure 3-2: Process Schematic .....3-2

**4 METHODOLOGY .....4-1**  
     Table 4-1: Summary of Sampling Procedures .....4-1  
     **SAMPLING POINT DETERMINATION - EPA METHOD 1 .....4-1**  
         Table 4-2: Sampling Points .....4-1  
         Figure 4-1: Unit 1 FF Outlet - Sampling Point Determination (EPA Method 1) .....4-2  
     **VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2 .....4-3**  
     **GAS COMPOSITION AND MOLECULAR WEIGHT - EPA METHOD 3B .....4-3**  
     **MOISTURE CONTENT - EPA METHOD 4 .....4-3**  
     **MERCURY EMISSIONS - EPA METHOD 29 .....4-4**  
         Figure 4-2: Metals Sampling Apparatus (EPA Method 29) .....4-6  
     **QUALITY ASSURANCE AND QUALITY CONTROL .....4-7**  
         Table 4-3: Method Field Blanks and Matrix Spikes .....4-7

**5 APPENDIX .....5-1**  
     **SAMPLE CALCULATIONS ..... A**  
     **PARAMETERS ..... B**  
     **CALIBRATION DATA ..... C**  
     **FIELD DATA ..... D**  
     **FIELD DATA PRINTOUTS ..... E**  
     **LABORATORY DATA ..... F**  
     **OPERATING DATA ..... G**

**PROJECT OVERVIEW**

1-1

Wheelabrator North Broward, Inc. operates a Refuse to Energy Facility located in Pompano Beach, Florida. The facility's emission levels are regulated by the Florida Department of Environmental Protection. Wheelabrator North Broward, Inc. contracted Clean Air Engineering (CleanAir) to perform a compliance test program at their municipal waste combustor (MWC) facility in Pompano Beach, Florida. Testing was conducted in accordance with 40 CFR 60 Subpart Cb and applicable sections of PSD-FL-112(B) and PA86-22. The sampling was conducted at the Unit 1 Fabric Filter (FF) Outlet on June 5, 2002.

The testing included the determination of the following constituents:

- moisture (H<sub>2</sub>O);
- oxygen (O<sub>2</sub>);
- carbon dioxide (CO<sub>2</sub>);
- total flow (dscfm);
- mercury (Hg).

Coordinating and observing the field portion of the program were:

C. Faller - Wheelabrator North Broward, Inc.  
K. O'Halloren - CleanAir

The schedule of activities is shown in Table 1-1. A summary of the results is presented in Table 1-2 on page 1-2.

**Table 1-1:  
Schedule of Activities**

<u>Date (2003)</u>	<u>Start Time</u>	<u>Stop Time</u>	<u>Unit</u>	<u>Location</u>	<u>Pollutant</u>	<u>Method</u>	<u>Run No.</u>
June 5	07:41	09:46	1	FF Outlet	Mercury	EPA 29	1
	09:46	11:51	1	FF Outlet	Mercury	EPA 29	2
	11:51	13:56	1	FF Outlet	Mercury	EPA 29	3

**PROJECT OVERVIEW**

1-2

Table 1-2:  
Summary of Test Results

Source Constituent (Units)	Sampling Method	Average Emission	Permit Limit <sup>1</sup>
<u>Unit 1 FF Outlet</u>			
Mercury ( $\mu\text{g}/\text{dscm}$ @ 7% O <sub>2</sub> )	EPA M29	1.9	70

<sup>1</sup> Limits obtained from 40 Code of Federal Register part 60 Subpart Cb - Emission Guidelines and Compliance Times for Large Municipal Waste Combustors That Are Constructed on or Before September 20, 1994 published in Federal Register as 62 FR 45123 on December 19, 1995 as modified on August 25, 1997, 40 CFR 60.33b (a) (3), Rule 62-296.416 (3) (b) and PSD-FL-112.

The test conditions and results of analysis are presented in Table 2-1 on page 2-1 and the Quality Control and Quality Assurance Results are shown in Table 2-2 on page 2-2.

**RESULTS**

2-1

**Table 2-1:  
Unit 1 FF Outlet - Mercury**

Run No.	1	2	3	Average
Date (2003)	Jun 5	Jun 5	Jun 5	
Start Time (approx.)	07:41	09:46	11:51	
Stop Time (approx.)	09:46	11:51	13:56	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate - (units/hour)	184.3	183.7	184.2	184.1
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.3	9.8	9.1	9.4
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.1	10.0	10.4	10.2
T <sub>s</sub> Sample temperature (*F)	308	306	309	308
B <sub>w</sub> Actual water vapor in gas (% by volume)	24.1	24.3	24.3	24.2
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	176,116	185,695	181,469	181,094
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	117,757	124,375	121,090	121,074
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	89,357	94,169	91,630	91,719
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	74.615	78.038	73.965	75.539
%I Isokinetic sampling (%)	104.5	101.4	101.0	102.3
<b>Laboratory Data</b>				
m <sub>n-1b</sub> Fraction 1B Prorated (µg)	0.1358	0.2538	0.1539	0.1812
m <sub>n-2b</sub> Fraction 2B Prorated (µg)	2.6270	2.5806	2.3890	2.5322
m <sub>n-3a</sub> Fraction 3A Prorated (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>n-3b</sub> Fraction 3B Prorated (µg)	<0.6000	<0.7000	<0.6000	<0.6333
m <sub>n-3c</sub> Fraction 3C Prorated (µg)	0.5137	0.6561	0.9079	0.6925
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	3.2765	3.4905	3.4508	3.4059
<b>Mercury Results - Total</b>				
C <sub>sd</sub> Concentration (lb/dscf)	9.7E-11	9.9E-11	1.0E-10	9.9E-11
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	1.2E-10	1.2E-10	1.2E-10	1.2E-10
C <sub>sd</sub> Concentration (µg/dscm)	1.6	1.6	1.6	1.6
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	1.9	2.0	1.9	1.9
C <sub>sd</sub> Concentration (mg/dscm)	0.0016	0.0016	0.0016	0.0016
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	0.0019	0.0020	0.0019	0.0019
E <sub>lb/hr</sub> Rate (lb/hr)	5.2E-04	5.6E-04	5.7E-04	5.5E-04
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	1.7E-06	1.8E-06	1.7E-06	1.7E-06



**RESULTS**

2-2

**Table 2-2:  
Quality Assurance and Quality Control**

Mercury RPD RESULTS						
Run Number	Max = 7.4% Front half	3.5% H2O2/HNO3	0.0% Empty Impinger	0.0% KMnO4	4.8% HCl	
U1 FF Out R1	0.3%	1.7%	NA	NA	2.5%	
U1 FF Out R2	2.5%	2.5%	NA	NA	4.8%	
U1 FF Out R3	7.4%	3.5%	NA	NA	2.2%	
Field Blank	NA	NA	NA	NA	NA	
Reagent Blank	NA	NA	NA	NA	NA	

Mercury Sample Spike and Recovery						
Run Number		Front half	H2O2/HNO3	Empty Impinger	KMnO4	HCl
U1 FF Out R3	# 1	109%	101%	81%	90%	97%
	# 2	109%	98%	80%	89%	92%

Run Number	Average Total Catch ug	Front half	H2O2/HNO3	Empty Impinger	KMnO4	HCl
Field Blank	# 1	< 0.6	< 0.1	< 0.3	< 0.2	< 0.4
	# 2		< 0.1	< 0.3	< 0.2	< 0.4
Reagent Blank	# 1	< 0.4	< 0.1	< 0.3	< 0.2	< 0.4
	# 2		< 0.1	< 0.3	< 0.2	< 0.4

**DESCRIPTION OF INSTALLATION**

3-1

The North Broward Resource Recovery Facility operates three 750 tons per day municipal refuse fired, water wall boiler trains. The trains were manufactured by Babcock and Wilcox to produce electricity for sale to a local utility company. Each boiler is equipped a spray dryer absorber (SDA) for acid gas removal, followed by a fabric filter (FF) baghouse for the control of particulate emissions. Wheelabrator Air Pollution Control, Inc supplies the control equipment. Each fabric filter baghouse is followed by an induced draft fan, which directs the flue gas to a dedicated flue in a common stack.

Figure 3-1 shows a general schematic for the facility. The testing occurred at the Unit 1 FF Outlet as shown in Figure 3-1.




Figure 3-1: General Process Schematic

**DESCRIPTION OF INSTALLATION**

3-2




Figure 3-2: Process Schematic

**METHODOLOGY**

4-1

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1, 2, 3, 3B, 4 and 29. The following table summarizes the methods and their respective sources.

**Table 4-1:  
Summary of Sampling Procedures**

<u>Title 40 CFR Part 60 Appendix A</u>	
Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
Method 3	"Gas Analysis for the Determination of Dry Molecular Weight"
Method 3B	"Gas Analysis for the Determination of Emission Rate Correction Factor or Excess Air"
Method 4	"Determination of Moisture Content in Stack Gases"
Method 29	"Determination of Metals Emissions from Stationary Sources"

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and on the World Wide Web at <http://www.cleanair.com>.

These sampling, recovery and analytical procedures are summarized on pages 4-1 through 4-7.

The sampling nozzles were calibrated on site. All other equipment was calibrated at the Clean Air Engineering laboratory prior to shipment to the job site. A post-test calibration was performed on the meter boxes at the conclusion of testing to verify that calibration was maintained throughout the test program. Calibration sheets can be found in Appendix Section C.

**SAMPLING POINT DETERMINATION - EPA METHOD 1**

Sampling point locations were determined according to EPA Method 1.

Table 4-2 outlines the sampling point configurations. Figure 4-1 illustrates the sampling points and orientation of sampling ports for the source tested in the program.


**Table 4-2:  
Sampling Points**

Location	Method	Run No.	Points per Port	Minutes per Point	Total Minutes	Figure
<u>Unit 1 FF Outlet</u>						
Mercury	29	1-3	5	5	125	4-1

**METHODOLOGY**

4-2

**SAMPLING POINT DETERMINATION (CONTINUED)**



Diameters upstream from disturbance: 2 diameters      Limit: 2  
Diameters downstream from disturbance: 0.5 diameters      Limit: 0.5

Figure 4-1: Unit 1 FF Outlet - Sampling Point Determination (EPA Method 1)

## **METHODOLOGY**

4-3

### **VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2**

EPA Method 2 was used, in conjunction with the wet method testing, to determine the gas velocity and flow rate at the FF Outlet test location.

Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the EPA Method 1 traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made using a Type K thermocouple and digital pyrometer. Figure 4-2 includes the components of the EPA Method 2 sampling apparatus.

### **GAS COMPOSITION AND MOLECULAR WEIGHT - EPA METHOD 3B**

In order to determine the oxygen (O<sub>2</sub>) concentration, carbon dioxide (CO<sub>2</sub>) concentration and gas molecular weight, a time-integrated sample of the gas was obtained for each sampling train and analyzed in accordance with EPA Method 3B. The gas sample was collected into a vinyl sample bag from isokinetic test methods. The contents of the bag was analyzed for O<sub>2</sub> and CO<sub>2</sub> concentrations using an Orsat gas analyzer.

### **MOISTURE CONTENT - EPA METHOD 4**

The flue gas moisture content at each of the test locations was determined in accordance with EPA Method 4, in conjunction with the mercury testing. Figure 4-2 includes the components of the EPA Method 4 sampling apparatus. The gas moisture was determined by quantitatively condensing the moisture in chilled impingers. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. The amount of water condensed and the volume of gas sampled were used to calculate the gas moisture content in accordance with EPA Method 4.

## METHODOLOGY

4-4

### MERCURY EMISSIONS - EPA METHOD 29

EPA Method 29 was used to measure mercury emissions at the Unit 1 FF Outlet. This method defines metal emissions as particulate and gaseous material isokinetically withdrawn through a temperature controlled probe and collected on a high-efficiency filter and in acidified absorbing solutions.

Figure 4-2 illustrates the EPA Method 29 sampling train which was used. The sampling apparatus contained a glass-lined temperature-controlled probe equipped with a pitot tube (for measuring stack flow rate) and a sharp-edged glass button-hook nozzle. The exit of the probe was connected to a high efficiency quartz fiber filter (Pallflex 2500QAT-UP) supported in a glass filter holder inside an oven. The exit of the filter holder connected directly to a series of seven full size impingers.

The first impinger of the sampling train was left empty to accommodate collection of the flue gas moisture. The second and third impingers of the sampling apparatus each contained 100 milliliters of 5% nitric acid/10% hydrogen peroxide solution. The fourth impinger was left empty. The fifth and sixth impingers each contained 100 milliliters of 4% potassium permanganate/10% sulfuric acid solution. The seventh impinger contained 200 to 300 grams of silica gel. All of the impingers were maintained at a temperature below 68°F for the duration of each test.

Procedures for selecting sampling locations and for the operation of the apparatus were derived from EPA Method 29 and associated EPA Methods 1 through 5. The entire sampling apparatus was leak-checked before and after each test run. Sampling was performed at an average isokinetic rate greater than 90% and less than 110%.

At the conclusion of each test run, the probe and nozzle was rinsed and brushed with 0.1 Normal nitric acid to remove any particulate matter. These rinses were collected into polyethylene sample containers. The quartz fiber filter was recovered and placed into a polyethylene sample container. The volume of liquid collected in each of the impingers was quantified.

The liquid from the first three impingers was transferred to a leak-free polyethylene storage container. The back-half of the filter housing, the first three impingers and all connecting glassware were rinsed with 0.1 Normal nitric acid which was added to the storage container.

**METHODOLOGY**

4-5

**MERCURY EMISSIONS (CONTINUED)**

Any liquid collected in the fourth impinger was transferred to a separate polyethylene container, and the impinger was rinsed into the same container with 0.1 Normal nitric acid. The contents of impingers 5 and 6 were collected into an amber glass container. Both impingers 5 and 6 and the connecting glassware were then rinsed with acidified potassium permanganate followed by distilled water. These rinses were collected in the glass container. Any residual potassium permanganate retained by the impingers was removed using a rinse of 8 Normal hydrochloric acid, which was collected into a separate glass container. 200 milliliters of distilled water was used to rinse impingers 5 and 6 and added to the same container to also dilute the acid.

All containers were sealed, labeled and liquid levels marked prior to transport to the laboratory. The silica gel weight and the volume of condensate collected in the impingers were used to determine moisture content of the stack gas.

The nitric acid probe rinses, and samples recovered from impingers 1 through 3 were reduced to near dryness and digested with hydrofluoric acid and concentrated nitric acid. The filter was digested with hydrofluoric and nitric acids. The samples obtained from Impingers 4, 5 and 6 were digested separately with acidified potassium permanganate and subsequently analyzed only for mercury. The digested samples were analyzed by cold vapor atomic absorption spectroscopy (CVAAS per Method 7470 in EPA publication SW 846) for mercury by Element One, Inc of Wilmington, North Carolina.



**METHODOLOGY**

**MERCURY EMISSIONS (CONTINUED)**

4-6




Figure 4-2: Metals Sampling Apparatus (EPA Method 29)

WHEELABRATOR NORTH BROWARD  
POMPANO BEACH, FLORIDA

Client Reference No: 14200357  
CleanAir Project No: 9281-3

**METHODOLOGY**

4-7

**QUALITY ASSURANCE AND QUALITY CONTROL**

All testing followed the EPA quality assurance and quality control guidelines as outlined in the respective methods. Field blanks and matrix spikes for the mercury testing were done as shown in the following Table 4-3. The results of the analysis are shown in Table 2-2.

**Table 4-3:  
Method Field Blanks and Matrix Spikes**

---

<u>Method</u>	<u>Reagent Blank Sets</u>	<u>Field Blank</u>	<u>Duplicate Analysis</u>	<u>Matrix Spikes</u>
EPA M29	1	1	On all analysis	1 predigested filter blank and 1 postdigested sample

---

WHEELABRATOR NORTH BROWARD  
POMPANO BEACH, FLORIDA

Client Reference No: 14200357  
CleanAir Project No: 9281-3

**APPENDIX**

SAMPLE CALCULATIONS .....	A
PARAMETERS.....	B
CALIBRATION DATA.....	C
FIELD DATA.....	D
FIELD DATA PRINTOUTS.....	E
LABORATORY DATA .....	F
OPERATING DATA.....	G

WHEELABRATOR NORTH BROWARD  
POMPANO BEACH, FLORIDA

Client Reference No: 14200357  
CleanAir Project No: 9281-3

**SAMPLE CALCULATIONS**

**A**

**EPA Method 1-4 Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

062503 100637

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04707)(V_{lc})$$

Where:

$V_{lc}$	= total volume of liquid collected in impingers and silica gel (ml)	=	503.8	ml
0.04707	= ideal gas conversion factor (ft <sup>3</sup> water vapor/ml or gm)	=	0.04707	ft <sup>3</sup> /ml
$V_{wstd}$	= volume of water vapor collected at standard conditions (ft <sup>3</sup> )	=	23.71	ft <sup>3</sup>

2. Volume of gas metered, standard conditions (dscf)

$$V_{nstd} = \frac{(17.64)(V_m) \left( P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	29.90	in. Hg
$T_m$	= average dry gas meter temperature (°F)	=	86.32	°F
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	77.90	dcf
$Y_d$	= gas meter correction factor (dimensionless)	=	0.9891	
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.24	in. H <sub>2</sub> O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$V_{nstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	74.615	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left( \frac{P_g}{13.6} \right)$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	29.90	in. Hg
$P_g$	= sample gas static pressure (in. H <sub>2</sub> O)	=	-11.00	in. H <sub>2</sub> O
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.09	in. Hg

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left( \frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

$T_s$	= average sample gas temperature (°F)	=	307.80	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
$P_v$	= vapor pressure, actual (in. Hg)	=	29.09	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.09	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.09	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	74.615	dscf
$V_{wstd}$	= volume of water collected at standard conditions (scf)	=	23.71	scf
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2412	
		=	24.12	%

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.09	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.09	in. Hg
$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2412	
$B_w$	= actual water vapor in gas	=	0.2412	
		=	24.12	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.1	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.3	%
100	= conversion factor (%)	=	100	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.60	%

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2 + CO)}{(100)}$$

Where:

$M_{CO_2}$	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
$M_{O_2}$	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
$M_{N_2+CO}$	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.1	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.3	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.6	%
100	= conversion factor (%)	=	100	%
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	29.98	%

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2412	
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	29.98	lb/lb-mole
$M_{H_2O}$	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
$M_s$	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.09	lb/lb-mole

12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left( \sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

$K_p$	= velocity pressure constant	=	85.49	
$C_p$	= pitot tube coefficient	=	0.84	
$M_s$	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.09	lb/lb-mole
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.09	in. Hg
$T_s$	= average sample gas temperature (°F)	=	307.80	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H <sub>2</sub> O)	=	0.647	√in. H <sub>2</sub> O
460	= °F to °R conversion constant	=	460	
$V_s$	= sample gas velocity (ft/sec)	=	45.86	ft/sec



13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

$A_s$	= cross sectional area of sampling location (ft <sup>2</sup> )	=	64.00	ft <sup>2</sup>
$V_s$	= sample gas velocity (ft/sec)	=	45.86	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	176,116	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left( \frac{P_s}{29.92} \right) \left( \frac{68 + 460}{T_s + 460} \right)$$

Where:

$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	176,116	acfm
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.09	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
$T_s$	= average sample gas temperature (°F)	=	307.8	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	117,757	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2412	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	117,757	scfm
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,357	dscfm

16. Dry flow of sample gas corrected to 7%O<sub>2</sub> (dscfm)

$$Q_{std7} = (Q_{std}) \left( \frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,357	dscfm
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.3	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
$Q_{std7}$	= volumetric flow rate at STP and 7%O <sub>2</sub> , dry basis (dscfm)	=	74,357	dscfm

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 9281-2  
 Unit 1 FF Outlet

17. Hourly time basis conversion of volumetric flow rate ( $Q_{std}$  example)

$$Q_{std-hr} = (Q_{std-min})(60)$$

Where

$Q_{std-min}$  = volumetric flow rate, english units (ft<sup>3</sup>/min) = 89,357 dscfm

60 = conversion factor (min/hr) = 60 min/hr

$Q_{std-hr}$  = volumetric flow rate, hourly basis (dscf/hr) = 5,361,439 dscf/hr

18. Metric Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{std-metric} = (Q_{std-english}) \left( \frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$  = volumetric flow rate, english units (ft<sup>3</sup>/min) = 89,357 dscfm

35.31 = conversion factor (ft<sup>3</sup>/m<sup>3</sup>) = 35.31 ft<sup>3</sup>/m<sup>3</sup>

60 = conversion factor (min/hr) = 60 min/hr

$Q_{std-metric}$  = volumetric flow rate, metric units (m<sup>3</sup>/hr) = 151,839 dry std m<sup>3</sup>/hr

19. Standard to Normal Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{Normal} = (Q_{std-metric}) \left( \frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$  = volumetric flow rate, metric units (dry std m<sup>3</sup>/hr) = 151,839 dry std m<sup>3</sup>/hr

32 = normal temperature (°F) = 32 °F

68 = standard temperature (°F) = 68 °F

460 = standard temperature in Rankine (68°F) = 460

$Q_{Normal}$  = volumetric flow rate, metric units (dry Nm<sup>3</sup>/hr) = 141,486 dry Nm<sup>3</sup>/hr

20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\overline{T_s} + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n}{144}\right)^2\left(\frac{\pi}{4}\right)(\Theta)(1 - B_w)}$$

Where:

$D_n$	= diameter of nozzle (in)	=	0.274	in.
$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2412	
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.09	in. Hg
$T_s$	= average sample gas temperature (°F)	=	307.8	°F
$V_{mstd}$	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	74.615	dscf
$V_s$	= sample gas velocity (ft/sec)	=	45.86	ft/sec
$\Theta$	= total sampling time (min)	=	125	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
$I$	= percent of isokinetic sampling (%)	=	104.47	%

21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\Theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{@})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

$\Theta$	= total sampling time (min)	=	125	min
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	77.90	dcf
$T_m$	= average dry gas meter temperature (°F)	=	86.32	°F
$\Delta H_{@}$	= dry gas meter orifice coefficient	=	1.8341	
$P_{bar}$	= barometric pressure (in. Hg)	=	29.90	in. Hg
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.242	in. H <sub>2</sub> O
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	29.98	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.107	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$Y_{qa}$	= alternative Method 5 post-test meter calibration factor	=	0.9828	

## LOGIC FOR TREATING DETECTION LIMITS

(mercury only)

### 1. Logic for Determining Total Blank ( $m_{Total-B}$ ) from 5 Fractions

	CASE 1	CASE 2	CASE 3
	All 5 fractions are D.	1 to 4 fractions are ND	All 5 fractions are ND
<b>Rule</b>			
$ND = 0$	$m_{Total-B} = \text{Sum D, 1-5}$	$m_{Total-B} = \text{Sum D}$	$m_{Total-B} = < \text{Sum ND}$
$ND = 1x$	$m_{Total-B} = \text{Sum D, 1-5}$	$m_{Total-B} = \text{Sum D}$	$m_{Total-B} = < \text{Sum ND}$
$ND = 0.5x$	$m_{Total-B} = \text{Sum D, 1-5}$	$m_{Total-B} = \text{Sum D}$	$m_{Total-B} = < 0.5 \text{ Sum ND}$

### 2. Logic for Determining Total Sample ( $m_{Total-S}$ ) from 5 Fractions

	CASE 1	CASE 2	CASE 3
	All 5 fractions are D.	1 to 4 fractions are ND	All 5 fractions are ND
<b>Rule</b>			
$ND = 0$	$m_{Total-S} = \text{Sum D, 1-5}$	$m_{Total-S} = \text{Sum D}$	$m_{Total-S} = < \text{Sum ND}$
$ND = 1x$	$m_{Total-S} = \text{Sum D, 1-5}$	$m_{Total-S} = < [\text{Sum D} + \text{Sum ND}]$	$m_{Total-S} = < \text{Sum ND}$
$ND = 0.5x$	$m_{Total-S} = \text{Sum D, 1-5}$	$m_{Total-S} = < [\text{Sum D} + 0.5 \text{ Sum ND}]$	$m_{Total-S} = < 0.5 \text{ Sum ND}$

### 3. Logic for Determining Maximum Allowable Blank Correction ( $m_{T-B-allow}$ )

	CASE 1	CASE 2	CASE 3	CASE 4
	All 5 fractions are D.	1 to 4 sample fractions are ND	All 5 fractions are ND	Any type of fractions
	$m_{Total-B} = D$	$m_{Total-B} = D$	$m_{Total-B} = D$	$m_{Total-B} = ND$
<b>Rule</b>				
$ND = 0$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = 0$	$m_{T-B-allow} = 0$
$ND = 1x$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = 0$	$m_{T-B-allow} = 0$
$ND = 0.5x$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = \text{M29 Rule}$	$m_{T-B-allow} = 0$	$m_{T-B-allow} = 0$

\* M29 rule using only detected sample quantities for logical comparisons.

### 4. Logic for Determining Blank-Corrected Sample Amount ( $m_n$ )

	CASE 1	CASE 2	CASE 3	CASE 4
	All 5 fractions are D.	1 to 4 sample fractions are ND	All 5 fractions are ND	Any type of fractions
	$m_{Total-S} - m_{T-B-allow} \geq \text{MIN(MDL)}$	$m_{Total-S} - m_{T-B-allow} \geq \text{MIN(MDL)}$	$m_{Total-S}$ and $m_{T-B-allow}$ anything	$m_{Total-S} - m_{T-B-allow} < \text{MIN(MDL)}$
<b>Rule</b>				
$ND = 0$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = < m_{Total-S}$	$m_n = < \text{MIN(MDL)}$
$ND = 1x$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = < [m_{Total-S} - m_{T-B-allow}]$	$m_n = < m_{Total-S}$	$m_n = < \text{MIN(MDL)}$
$ND = 0.5x$	$m_n = m_{Total-S} - m_{T-B-allow}$	$m_n = < [m_{Total-S} - m_{T-B-allow}]$	$m_n = < m_{Total-S}$	$m_n = < \text{MIN(MDL)}$

#### Definitions and Notes

The term "Rule" refers to the rule being implemented for handling non-detectable quantities in summations.

MDL = minimum detection limit.

D = Detectable quantity reported as D.

ND = Non-Detectable quantity reported at a value of ND.

MIN[MDL] = lowest quantity of all detection limits for 5 fractions.

**EPA Method 29 Sample Calculations - Mercury Analytical Result**

Sample data taken from Run 1

The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

062503 100637

1. Total blank amount (µg)

$$m_{total-B} = \sum_{i=1}^n m_{i-B}$$

Where:

$m_{1b-B}$	= mercury amount in blank for Fraction 1b	=	<0.1000	µg
$m_{2b-B}$	= mercury amount in blank for Fraction 2b	=	<0.3000	µg
$m_{3a-B}$	= mercury amount in blank for Fraction 3a	=	<0.2000	µg
$m_{3b-B}$	= mercury amount in blank for Fraction 3b	=	<0.4000	µg
$m_{3c-B}$	= mercury amount in blank for Fraction 3c	=	<0.4000	µg
$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg

2. Total sample amount (µg)

$$m_{total-S} = \sum_{i=1}^n m_{i-S}$$

Where:

$m_{1b-S}$	= mercury amount in sample for Fraction 1b	=	0.1358	µg
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	=	2.6270	µg
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	=	<0.2000	µg
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	=	<0.6000	µg
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	=	0.5137	µg
$m_{total-S}$	= total amount of mercury in sample	=	3.2765	µg

3. Allowable blank correction (µg)

$$m_{T-B-allow} = m_{total-B} \text{ if } m_{total-B} \leq 0.6$$

$$m_{T-B-allow} = \text{MAX} [0.6, \text{MIN} (m_{total-B}, 0.05 \times m_{total-S})] \text{ if } m_{total-B} > 0.6$$

Where:

$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg
$m_{total-S}$	= total amount of mercury in sample	=	3.2765	µg
$0.05 \times m_{total-S}$	= 5% of $m_{total-S}$	=	0.1638	µg
MAX	= Arithmetic operator that returns the maximum of two values			
MIN	= Arithmetic operator that returns the minimum of two values			
$m_{T-B-allow}$	= total allowable blank correction	=	0.0000	µg

NOTE: In this case, the second criteria applies.

4. Sample corrected for allowable blank - Total (µg)

$$m_n = m_{total-S} - m_{T-B-allow}$$

Where:

$m_{total-S}$	= total amount of mercury in sample	=	3.2765	µg
$m_{T-B-allow}$	= total allowable blank correction	=	0.0000	µg
$m_n$	= total mercury in sample corrected for allowable blank	=	3.2765	µg

5. Sample corrected for allowable blank - Prorated for each fraction (µg)

$$m_{n-i} = \left( \frac{m_{i-S}}{m_{total+S}} \right) (m_n)$$

Where:

$m_n$	= total mercury in sample corrected for allowable blank	=	3.2765	µg
$m_{1b-S}$	= mercury amount in sample for Fraction 1b	=	0.1358	µg
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	=	2.6270	µg
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	=	<0.2000	µg
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	=	<0.6000	µg
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	=	0.5137	µg
$m_{total-S}$	= total amount of mercury in sample	=	3.2765	µg
$m_{n-1b}$	= mercury corrected for blank - prorated for Fraction 1b	=	0.1358	µg
$m_{n-2b}$	= mercury corrected for blank - prorated for Fraction 2b	=	2.6270	µg
$m_{n-3a}$	= mercury corrected for blank - prorated for Fraction 3a	=	<0.2000	µg
$m_{n-3b}$	= mercury corrected for blank - prorated for Fraction 3b	=	<0.6000	µg
$m_{n-3c}$	= mercury corrected for blank - prorated for Fraction 3c	=	0.5137	µg

**EPA Method 29 Sample Calculations - Mercury Emissions Results**

Sample data taken from Run 1

The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

062503 100637

1. Mercury concentration (lb/dscf)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

$m_n$	= Mercury collected in sample (total $\mu\text{g}$ )	=	3.2765	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.6147	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$C_{sd}$	= Mercury concentration (lb/dscf)	=	9.6826E-11	lb/dscf

2. Mercury concentration ( $\mu\text{g/dscm}$ )

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= Mercury collected in sample (total $\mu\text{g}$ )	=	3.2765	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.6147	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
$C_{sd}$	= Mercury concentration ( $\mu\text{g/dscm}$ )	=	1.5505E+00	$\mu\text{g/dscm}$

3. Mercury concentration (mg/dscm)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{35.31}{1000} \right)$$

Where:

$m_n$	= Mercury collected in sample (total $\mu\text{g}$ )	=	3.2765	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.6147	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
1000	= conversion factor ( $\mu\text{g/mg}$ )	=	1000	$\mu\text{g/mg}$
$C_{sd}$	= Mercury concentration (mg/dscm)	=	1.5505E-03	mg/dscm

4. Mercury concentration ( $\mu\text{g}/\text{Nm}^3$  dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= Mercury collected in sample (total $\mu\text{g}$ )	=	3.2765	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.6147	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature ( $^{\circ}\text{F}$ )	=	68	$^{\circ}\text{F}$
32	= normal temperature ( $^{\circ}\text{F}$ )	=	32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	=	460	
$C_{sd}$	= Mercury concentration ( $\mu\text{g}/\text{Nm}^3$ dry)	=	1.6640E+00	$\mu\text{g}/\text{Nm}^3$ dry

5. Mercury concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= Mercury concentration (lb/dscf)	=	9.6826E-11	lb/dscf
x	= oxygen content of corrected gas (%)	=	7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.3	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
$C_{sdx}$	= Mercury concentration corrected to x% oxygen (lb/dscf)	=	1.1636E-10	lb/dscf @ x% $O_2$

6. Mercury concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= Mercury concentration (lb/dscf)	=	9.6826E-11	lb/dscf
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.1	%
$C_{sdy}$	= Mercury conc. corrected to y% carbon dioxide (lb/dscf)	=	1.1542E-10	lb/dscf @ y% $CO_2$

7. Mercury concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= Mercury concentration (lb/dscf)	=	9.6826E-11	lb/dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,357	dscfm
$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	176,116	acfm
$C_a$	= Mercury concentration at actual gas conditions (lb/acf)	=	4.9127E-11	lb/acf



8. Mercury emission rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

$m_n$	= Mercury collected in sample (total $\mu\text{g}$ )	=	3.2765	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.6147	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,357	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
$E_{lb/hr}$	= Mercury emission rate (lb/hr)	=	5.1913E-04	lb/hr

9. Mercury emission rate (g/s)

$$E_{g/s} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

$m_n$	= Mercury collected in sample (total $\mu\text{g}$ )	=	3.2765	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.6147	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,357	dscfm
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	=	60	sec/min
$E_{g/s}$	= Mercury emission rate (g/s)	=	6.5398E-05	g/s

10. Mercury emission rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_n$	= Mercury collected in sample (total $\mu\text{g}$ )	=	3.2765	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.6147	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,357	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Cap	= capacity factor for process (hours operated/year)	=	8,760	hours/yr
2000	= conversion factor (lb/Ton)	=	2000	lb/Ton
$E_{T/yr}$	= Mercury emission rate (Ton/yr)	=	2.2738E-03	Ton/yr

11. Mercury emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= Mercury collected in sample (total $\mu\text{g}$ )	=	3.2765	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.6147	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.3	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
$E_{Fd}$	= Mercury emission rate - Fd-based (lb/MMBtu)	=	1.6743E-06	lb/MMBtu

12. Mercury emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= Mercury collected in sample (total $\mu\text{g}$ )	=	3.2765	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	74.6147	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	=	10.1	%
100	= conversion factor	=	100	
$E_{Fc}$	= Mercury emission rate - Fc-based (lb/MMBtu)	=	1.7506E-06	lb/MMBtu

WHEELABRATOR NORTH BROWARD  
POMPANO BEACH, FLORIDA

Client Reference No: 14200357  
CleanAir Project No: 9281-3

**PARAMETERS**

**B**

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 9281-2  
 Unit 1 FF Outlet

**USEPA Method 29  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average	
Date (2003)	Jun 5	Jun 5	Jun 5		
Start Time (approx.)	07:41	09:46	11:51		
Stop Time (approx.)	09:46	11:51	13:56		
<b>Sampling Conditions</b>					
Y <sub>d</sub>	Dry gas meter correction factor	0.9891	1.0051	0.9891	
C <sub>p</sub>	Pitot tube coefficient	0.84	0.84	0.84	
P <sub>g</sub>	Static pressure (in. H <sub>2</sub> O)	-11.0000	-11.0000	-11.0000	
A <sub>s</sub>	Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub>	Barometric pressure (in. Hg)	29.90	29.90	29.90	29.9000
D <sub>n</sub>	Nozzle diameter (in.)	0.2740	0.2770	0.2740	
O <sub>2</sub>	Oxygen (dry volume %)	9.3333	9.8000	9.1333	9.4222
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.0667	10.0000	10.4000	10.1556
N <sub>2</sub> +CO	Nitrogen plus carbon monoxide (dry volume %)	80.6000	80.2000	80.4667	80.4222
V <sub>lc</sub>	Total Liquid collected (ml)	503.80	531.80	505.20	
V <sub>m</sub>	Volume metered, meter conditions (ft <sup>3</sup> )	77.9000	81.1250	78.7750	
T <sub>m</sub>	Dry gas meter temperature (°F)	86.3200	92.8800	97.3000	
T <sub>s</sub>	Sample temperature (°F)	307.8000	306.4800	309.3600	307.8800
ΔH	Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.2416	1.3156	1.2336	
θ	Total sampling time (min)	125.0	125.0	125.0	
<b>Flow Results</b>					
V <sub>wstd</sub>	Volume of water collected (ft <sup>3</sup> )	23.7139	25.0318	23.7798	24.1752
V <sub>mstd</sub>	Volume metered, standard (dscf)	74.6147	78.0379	73.9648	75.5391
P <sub>s</sub>	Sample gas pressure, absolute (in. Hg)	29.0912	29.0912	29.0912	29.0912
P <sub>v</sub>	Vapor pressure, actual (in. Hg)	29.0912	29.0912	29.0912	29.0912
B <sub>wo</sub>	Moisture measured in sample (% by volume)	24.1170	24.2863	24.3285	24.2439
B <sub>ws</sub>	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000
B <sub>w</sub>	Actual water vapor in gas (% by volume)	24.1170	24.2863	24.3285	24.2439
√ΔP	Velocity head (√in. H <sub>2</sub> O)	0.6471	0.6827	0.6662	0.6653
M <sub>d</sub>	MW of sample gas, dry (lb/lb-mole)	29.9840	29.9920	30.0293	30.0018
M <sub>s</sub>	MW of sample gas, wet (lb/lb-mole)	27.0938	27.0796	27.1028	27.0921
V <sub>s</sub>	Velocity of sample (ft/sec)	45.8637	48.3582	47.2576	47.1598
%I	Isokinetic sampling (%)	104.4699	101.4462	100.9910	102.3024
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	176,116	185,695	181,469	181,094
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	117,757	124,375	121,090	121,074
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	89,357	94,169	91,630	91,719
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,357	75,200	77,567	75,708
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,566,986	11,141,719	10,888,143	10,865,616
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,065,398	7,462,511	7,265,372	7,264,427
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,361,439	5,650,143	5,497,817	5,503,133
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	299,263	315,540	308,359	307,721
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	200,096	211,343	205,760	205,733
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	151,839	160,015	155,701	155,852
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,351	127,782	131,805	128,646
Q <sub>s</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	186,453	196,933	191,731	191,706
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	141,486	149,105	145,085	145,226
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	117,736	119,070	122,818	119,874

Comments:  
 None

062503 100637

**USEPA Method 29  
 Mercury (Hg) Emission Parameters**

Run No.	1	2	3	Average	
Date (2003)	Jun 5	Jun 5	Jun 5		
Start Time (approx.)	07:41	09:46	11:51		
Stop Time (approx.)	09:46	11:51	13:56		
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate - (units/hour)	184.3	183.7	184.2	
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.3333	9.8000	9.1333	9.4222
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.0667	10.0000	10.4000	10.1556
T <sub>s</sub>	Sample temperature (°F)	307.8000	306.4800	309.3600	307.8800
B <sub>w</sub>	Actual water vapor in gas (% by volume)	24.1170	24.2863	24.3285	24.2439
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	176,116	185,695	181,469	181,094
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	117,757	124,375	121,090	121,074
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	89,357	94,169	91,630	91,719
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,357	75,200	77,567	75,708
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,566,986	11,141,719	10,888,143	10,865,616
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,065,398	7,462,511	7,265,372	7,264,427
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,361,439	5,650,143	5,497,817	5,503,133
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	299,263	315,540	308,359	307,721
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	200,096	211,343	205,760	205,733
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	151,839	160,015	155,701	155,852
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,351	127,782	131,805	128,646
Q <sub>n</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	186,453	196,933	191,731	191,706
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	141,486	149,105	145,085	145,226
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	117,736	119,070	122,818	119,874
<b>Sampling Data</b>					
V <sub>maid</sub>	Volume metered, standard (dscf)	74.6147	78.0379	73.9648	75.5391
%I	Isokinetic sampling (%)	104.4699	101.4462	100.9910	102.3024
<b>Laboratory Data</b>					
m <sub>n-1b</sub>	Fraction 1B Prorated (µg)	0.1358	0.2538	0.1539	0.1812
m <sub>n-2b</sub>	Fraction 2B Prorated (µg)	2.6270	2.5806	2.3890	2.5322
m <sub>n-3a</sub>	Fraction 3A Prorated (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>n-3b</sub>	Fraction 3B Prorated (µg)	<0.6000	<0.7000	<0.6000	<0.6333
m <sub>n-3c</sub>	Fraction 3C Prorated (µg)	0.5137	0.6561	0.9079	0.6925
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	3.2765	3.4905	3.4508	3.4059
<b>Mercury Results - Total</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	9.6826E-11	9.8624E-11	1.0287E-10	9.9442E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	1.1636E-10	1.2350E-10	1.2153E-10	1.2046E-10
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	1.1542E-10	1.1835E-10	1.1870E-10	1.1749E-10
C <sub>a</sub>	Concentration (lb/acf)	4.9127E-11	5.0014E-11	5.1945E-11	5.0362E-11
C <sub>sd</sub>	Concentration (µg/dscm)	1.5505E+00	1.5793E+00	1.6474E+00	1.5924E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	1.8633E+00	1.9777E+00	1.9461E+00	1.9290E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	1.8483E+00	1.8952E+00	1.9008E+00	1.8815E+00
C <sub>sd</sub>	Concentration (mg/dscm)	1.5505E-03	1.5793E-03	1.6474E-03	1.5924E-03
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	1.8633E-03	1.9777E-03	1.9461E-03	1.9290E-03
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	1.8483E-03	1.8952E-03	1.9008E-03	1.8815E-03
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	7.8671E-01	8.0091E-01	8.3183E-01	8.0648E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	1.6640E+00	1.6949E+00	1.7679E+00	1.7089E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.9997E+00	2.1224E+00	2.0885E+00	2.0702E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.9836E+00	2.0339E+00	2.0399E+00	2.0191E+00
E <sub>lb/hr</sub>	Rate (lb/hr)	5.1913E-04	5.5724E-04	5.6559E-04	5.4732E-04
E <sub>g/s</sub>	Rate (g/s)	6.5398E-05	7.0199E-05	7.1251E-05	6.8949E-05
E <sub>Ton/yr</sub>	Rate (Ton/yr)	2.2738E-03	2.4407E-03	2.4773E-03	2.3973E-03
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	1.6743E-06	1.7771E-06	1.7487E-06	1.7334E-06
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	1.7506E-06	1.7950E-06	1.8003E-06	1.7819E-06

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Front Half Results**

Run No.	1	2	3	Average
Date (2003)	Jun 5	Jun 5	Jun 5	
Start Time (approx.)	07:41	09:46	11:51	
Stop Time (approx.)	09:46	11:51	13:56	

**Mercury Results - Front Half**

C <sub>sd</sub>	Concentration (lb/dscf)	4.0130E-12	7.1702E-12	4.5881E-12	5.2571E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	4.8225E-12	8.9789E-12	5.4199E-12	6.4071E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	4.7837E-12	8.6043E-12	5.2939E-12	6.2273E-12
C <sub>a</sub>	Concentration (lb/acf)	2.0361E-12	3.6361E-12	2.3167E-12	2.6630E-12
C <sub>sd</sub>	Concentration (µg/dscm)	6.4263E-02	1.1482E-01	7.3472E-02	8.4185E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	7.7226E-02	1.4378E-01	8.6792E-02	1.0260E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	7.6605E-02	1.3779E-01	8.4775E-02	9.9722E-02
C <sub>sd</sub>	Concentration (mg/dscm)	6.4263E-05	1.1482E-04	7.3472E-05	8.4185E-05
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	7.7226E-05	1.4378E-04	8.6792E-05	1.0260E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	7.6605E-05	1.3779E-04	8.4775E-05	9.9722E-05
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	3.2605E-02	5.8228E-02	3.7098E-02	4.2644E-02
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	6.8965E-02	1.2322E-01	7.8848E-02	9.0345E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	8.2877E-02	1.5431E-01	9.3143E-02	1.1011E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	8.2210E-02	1.4787E-01	9.0978E-02	1.0702E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	2.1516E-05	4.0513E-05	2.5224E-05	2.9084E-05
E <sub>g/s</sub>	Rate (g/s)	2.7104E-06	5.1036E-06	3.1777E-06	3.6639E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	9.4238E-05	1.7745E-04	1.1048E-04	1.2739E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	6.9394E-08	1.2920E-07	7.7989E-08	9.2195E-08
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	7.2553E-08	1.3050E-07	8.0291E-08	9.4447E-08

062503 102220

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 9281-2  
 Unit 1 FF Outlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2003)	Jun 5	Jun 5	Jun 5	
Start Time (approx.)	07:41	09:46	11:51	
Stop Time (approx.)	09:46	11:51	13:56	

**Mercury Results - Impingers 1-3 Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	7.7634E-11	7.2917E-11	7.1221E-11	7.3924E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	9.3295E-11	9.1310E-11	8.4133E-11	8.9579E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	9.2543E-11	8.7500E-11	8.2178E-11	8.7407E-11
C <sub>a</sub>	Concentration (lb/acf)	3.9389E-11	3.6977E-11	3.5962E-11	3.7443E-11
C <sub>sd</sub>	Concentration (µg/dscm)	1.2432E+00	1.1677E+00	1.1405E+00	1.1838E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	1.4940E+00	1.4622E+00	1.3473E+00	1.4345E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	1.4820E+00	1.4012E+00	1.3160E+00	1.3997E+00
C <sub>sd</sub>	Concentration (mg/dscm)	1.2432E-03	1.1677E-03	1.1405E-03	1.1838E-03
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	1.4940E-03	1.4622E-03	1.3473E-03	1.4345E-03
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	1.4820E-03	1.4012E-03	1.3160E-03	1.3997E-03
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	6.3077E-01	5.9214E-01	5.7588E-01	5.9960E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	1.3342E+00	1.2531E+00	1.2240E+00	1.2704E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.6033E+00	1.5692E+00	1.4459E+00	1.5395E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.5904E+00	1.5037E+00	1.4123E+00	1.5021E+00
E <sub>lb/hr</sub>	Rate (lb/hr)	4.1623E-04	4.1199E-04	3.9156E-04	4.0659E-04
E <sub>g/s</sub>	Rate (g/s)	5.2435E-05	5.1901E-05	4.9327E-05	5.1221E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	1.8231E-03	1.8045E-03	1.7150E-03	1.7809E-03
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	1.3425E-06	1.3139E-06	1.2106E-06	1.2890E-06
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	1.4036E-06	1.3271E-06	1.2464E-06	1.3257E-06

062503 102220

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 4 Results**

Run No.	1	2	3	Average
Date (2003)	Jun 5	Jun 5	Jun 5	
Start Time (approx.)	07:41	09:46	11:51	
Stop Time (approx.)	09:46	11:51	13:56	
<b>Mercury Results - Impinger 4 Solution</b>				
C <sub>sd</sub>	<5.9104E-12	<5.6511E-12	<5.9623E-12	<5.8413E-12
C <sub>sd7</sub>	<7.1027E-12	<7.0766E-12	<7.0433E-12	<7.0742E-12
C <sub>sd12</sub>	<7.0455E-12	<6.7813E-12	<6.8796E-12	<6.9021E-12
C <sub>a</sub>	<2.9988E-12	<2.8658E-12	<3.0106E-12	<2.9584E-12
C <sub>sd</sub>	<9.4646E-02	<9.0494E-02	<9.5478E-02	<9.3540E-02
C <sub>sd7</sub>	<1.1374E-01	<1.1332E-01	<1.1279E-01	<1.1328E-01
C <sub>sd12</sub>	<1.1282E-01	<1.0859E-01	<1.1017E-01	<1.1053E-01
C <sub>sd</sub>	<9.4646E-05	<9.0494E-05	<9.5478E-05	<9.3540E-05
C <sub>sd7</sub>	<1.1374E-04	<1.1332E-04	<1.1279E-04	<1.1328E-04
C <sub>sd12</sub>	<1.1282E-04	<1.0859E-04	<1.1017E-04	<1.1053E-04
C <sub>a</sub>	<4.8021E-02	<4.5891E-02	<4.8210E-02	<4.7374E-02
C <sub>sd</sub>	<1.0157E-01	<9.7116E-02	<1.0246E-01	<1.0038E-01
C <sub>sd7</sub>	<1.2206E-01	<1.2161E-01	<1.2104E-01	<1.2157E-01
C <sub>sd12</sub>	<1.2108E-01	<1.1654E-01	<1.1823E-01	<1.1862E-01
E <sub>g/hr</sub>	<3.1688E-05	<3.1930E-05	<3.2780E-05	<3.2132E-05
E <sub>g/s</sub>	<3.9919E-06	<4.0224E-06	<4.1295E-06	<4.0479E-06
E <sub>T/yr</sub>	<1.3879E-04	<1.3985E-04	<1.4357E-04	<1.4074E-04
E <sub>Fd</sub>	<1.0220E-07	<1.0183E-07	<1.0135E-07	<1.0179E-07
E <sub>Fc</sub>	<1.0686E-07	<1.0285E-07	<1.0434E-07	<1.0468E-07

062503 102220



Wheelabrator North Broward, Inc.  
 Clean Air Project No: 9281-2  
 Unit 1 FF Outlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average
Date (2003)	Jun 5	Jun 5	Jun 5	
Start Time (approx.)	07:41	09:46	11:51	
Stop Time (approx.)	09:46	11:51	13:56	
<b>Mercury Results - Filtered Permanganate Solution</b>				
C <sub>sd</sub>	<1.7731E-11	<1.9779E-11	<1.7887E-11	<1.8466E-11
C <sub>sd7</sub>	<2.1308E-11	<2.4768E-11	<2.1130E-11	<2.2402E-11
C <sub>sd12</sub>	<2.1136E-11	<2.3735E-11	<2.0639E-11	<2.1837E-11
C <sub>a</sub>	<8.9963E-12	<1.0030E-11	<9.0317E-12	<9.3527E-12
C <sub>sd</sub>	<2.8394E-01	<3.1673E-01	<2.8643E-01	<2.9570E-01
C <sub>sd7</sub>	<3.4122E-01	<3.9663E-01	<3.3837E-01	<3.5874E-01
C <sub>sd12</sub>	<3.3847E-01	<3.8008E-01	<3.3050E-01	<3.4968E-01
C <sub>sd</sub>	<2.8394E-04	<3.1673E-04	<2.8643E-04	<2.9570E-04
C <sub>sd7</sub>	<3.4122E-04	<3.9663E-04	<3.3837E-04	<3.5874E-04
C <sub>sd12</sub>	<3.3847E-04	<3.8008E-04	<3.3050E-04	<3.4968E-04
C <sub>a</sub>	<1.4406E-01	<1.6062E-01	<1.4463E-01	<1.4977E-01
C <sub>sd</sub>	<3.0471E-01	<3.3991E-01	<3.0739E-01	<3.1734E-01
C <sub>sd7</sub>	<3.6618E-01	<4.2565E-01	<3.6312E-01	<3.8499E-01
C <sub>sd12</sub>	<3.6324E-01	<4.0789E-01	<3.5468E-01	<3.7527E-01
E <sub>lb/hr</sub>	<9.5064E-05	<1.1175E-04	<9.8339E-05	<1.0172E-04
E <sub>g/s</sub>	<1.1976E-05	<1.4078E-05	<1.2388E-05	<1.2814E-05
E <sub>T/yr</sub>	<4.1638E-04	<4.8948E-04	<4.3072E-04	<4.4553E-04
E <sub>Fd</sub>	<3.0661E-07	<3.5640E-07	<3.0405E-07	<3.2235E-07
E <sub>Fc</sub>	<3.2057E-07	<3.5998E-07	<3.1302E-07	<3.3119E-07
<b>Mercury Results - HCl Rinse + HCl/MnO2 Precipitate</b>				
C <sub>sd</sub>	1.5180E-11	1.8537E-11	2.7066E-11	2.0261E-11
C <sub>sd7</sub>	1.8242E-11	2.3213E-11	3.1973E-11	2.4476E-11
C <sub>sd12</sub>	1.8095E-11	2.2245E-11	3.1230E-11	2.3857E-11
C <sub>a</sub>	7.7019E-12	9.4005E-12	1.3667E-11	1.0256E-11
C <sub>sd</sub>	2.4308E-01	2.9685E-01	4.3343E-01	3.2445E-01
C <sub>sd7</sub>	2.9212E-01	3.7173E-01	5.1201E-01	3.9195E-01
C <sub>sd12</sub>	2.8977E-01	3.5622E-01	5.0011E-01	3.8203E-01
C <sub>sd</sub>	2.4308E-04	2.9685E-04	4.3343E-04	3.2445E-04
C <sub>sd7</sub>	2.9212E-04	3.7173E-04	5.1201E-04	3.9195E-04
C <sub>sd12</sub>	2.8977E-04	3.5622E-04	5.0011E-04	3.8203E-04
C <sub>a</sub>	1.2333E-01	1.5054E-01	2.1885E-01	1.6424E-01
C <sub>sd</sub>	2.6087E-01	3.1857E-01	4.6514E-01	3.4819E-01
C <sub>sd7</sub>	3.1349E-01	3.9893E-01	5.4947E-01	4.2063E-01
C <sub>sd12</sub>	3.1097E-01	3.8228E-01	5.3670E-01	4.0998E-01
E <sub>lb/hr</sub>	8.1386E-05	1.0474E-04	1.4880E-04	1.1164E-04
E <sub>g/s</sub>	1.0253E-05	1.3195E-05	1.8746E-05	1.4064E-05
E <sub>T/yr</sub>	3.5647E-04	4.5875E-04	6.5176E-04	4.8899E-04
E <sub>Fd</sub>	2.6249E-07	3.3403E-07	4.6008E-07	3.5220E-07
E <sub>Fc</sub>	2.7444E-07	3.3738E-07	4.7366E-07	3.6183E-07

062503 102220

WHEELABRATOR NORTH BROWARD  
POMPANO BEACH, FLORIDA

Client Reference No: 14200357  
CleanAir Project No: 9281-3

**CALIBRATION DATA**

C

# Nozzle Calibration Sheet

Client <i>Whee Laboratories North Broward</i>	Project Number <i>9281-2</i>
Calibrated by <i>K. O'Halloran</i>	Unit <i>1 FF Outlet</i>
Date <i>6/3/2003</i>	Runs <i>1-6</i>

Nozzle Identification	D <sub>1</sub> (inches)	D <sub>2</sub> (inches)	D <sub>3</sub> (inches)	ΔD (inches)	ΔD <sub>ave</sub> (inches)
<i>274-1</i>	<i>0.274</i>	<i>0.273</i>	<i>0.275</i>	<i>0.002</i>	<i>0.274</i>
<i>277-1</i>	<i>0.276</i>	<i>0.277</i>	<i>0.277</i>	<i>0.001</i>	<i>0.277</i>

D<sub>1</sub>, D<sub>2</sub>, D<sub>3</sub> = three nozzle diameter measurements

ΔD = maximum difference between any two diameters  
ΔD ≤ 0.004 inches\*

ΔD<sub>ave</sub> = average of D<sub>1</sub>, D<sub>2</sub>, D<sub>3</sub>

\* (40 CFR 60, Appendix A, Method 5, Section 5.1)

# Meter Box Full Test Calibration


Meter Box No: 61-11

Date of Calibration: 10/11/02

Meter Box Y<sub>d</sub>: 1.0051

Calibration conducted by: R.R.

Meter Box ΔH@: 1.7561

  
Signature

Barometric Pressure: 29.49

Q	ΔH	ΔP	Y <sub>ds</sub>	Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
				Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	In	Out	T <sub>ds</sub> Avg.	In	T <sub>o</sub> Out	T <sub>d</sub> Avg.		Θ	Y <sub>d</sub>
0.979	3.00	-1.80	1.0000	0.000	10.000	10.000	459.757	469.722	9.965	71.5	71.5	71.50	85.0	76.0	80.50	10.00	1.0084	1.7103
0.977	3.00	-1.80	1.0000	0.000	10.000	10.000	469.722	479.717	9.995	71.5	71.5	71.50	87.0	77.0	82.00	10.02	1.0081	1.7140
0.385	0.50	-1.20	1.0000	0.000	5.000	5.000	489.962	495.002	5.040	71.5	71.5	71.50	81.0	78.0	79.50	12.70	1.0027	1.8322
0.385	0.50	-1.20	1.0000	0.000	5.000	5.000	495.002	500.049	5.047	71.5	71.5	71.50	81.0	78.0	79.50	12.70	1.0013	1.8322
0.687	1.50	-1.40	1.0000	0.000	10.000	10.000	501.625	511.706	10.081	71.5	71.5	71.50	86.0	79.0	82.50	14.25	1.0052	1.7269
0.687	1.50	-1.40	1.0000	0.000	10.000	10.000	511.706	521.799	10.093	71.5	71.5	71.50	86.0	80.0	83.00	14.24	1.0049	1.7212

Averages 1.00512 1.75614

Nomenclature	Equations
P <sub>b</sub> Barometric Pressure (in. Hg)	$Y_d = \frac{V_{ds} \cdot T_d \cdot P_b}{V_d \cdot T_{ds} \cdot P}$ $H@ = \frac{0.0319 \cdot H \cdot (T_{ds} - 460)}{P_b \cdot (T_o - 460) \cdot (V_{ds} \cdot Y_{ds})}$ $Q = \frac{17.64 \cdot (V_{ds} \cdot P_b)}{(T_{ds} - 460) \cdot Y_{ds}}$
Q Flow Rate (cfm)	
ΔH Orifice Pressure differential (in. H <sub>2</sub> O)	
ΔP Inlet Pressure Differential (in. H <sub>2</sub> O)	
V <sub>d</sub> Gas Meter Volume - Dry (ft <sup>3</sup> )	
V <sub>ds</sub> Standard Meter Volume - Dry (ft <sup>3</sup> )	
T <sub>d</sub> Average Meter Box Temperature (°F)	
T <sub>o</sub> Outlet Meter Box Temperature (°F)	
T <sub>ds</sub> Average Standard Meter Temperature (°F)	
Y <sub>d</sub> Meter Correction Factor (unitless)	
Y <sub>ds</sub> Standard Meter Correction Factor (unitless)	
ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H <sub>2</sub> O)	
Θ Duration of Run (minutes)	

Vacuum Gauge		DGM Thermocouples		
Standard (in. Hg)	Gauge (in. Hg)	Standard (°F)	Inlet (°F)	Outlet (°F)
5.0	5.4			
10.0	10.1			
15.0	15.1			
20.0	20.1			
25.0	25.0			



# Pyrometer Calibration Test Report

Pyrometer No.: 66-11  
Calibrated By: R.R.  
Date: 10/11/02

Office: Palatine, IL  
Client: \_\_\_\_\_  
Job Number: \_\_\_\_\_

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading
50 °F	48 °F
100 °F	98 °F
150 °F	148 °F
200 °F	198 °F
250 °F	249 °F
300 °F	299 °F
350 °F	349 °F
400 °F	399 °F
450 °F	449 °F
500 °F	499 °F
550 °F	549 °F
600 °F	599 °F

## Calibration Reference Information

Reference Used: Omega CL23A  
Calibrated By: Omega Engineering, Inc.  
Report No: R 044791

Serial No: T-225950  
Date: August 28 2003

Meter Box Critical Orifice Post-Test Calibration Data

Project No. 9281-2/9282-2 Meter No. 61-11 Orifice L-2  
 Location North South Broward Meter Yd 1.0051 Orifice K' 0.381  
 Test Date 6/6/2003 Meter ΔH@ 1.7561 Orifice Cal. Date 9/9/2002  
 Operator J. Szafranski Full Test Cal. Date 10/11/2002

Leak Checks

Negative Pressure

No movement of manometer in one-minute  Pass

Positive Pressure

No movement of manometer in one-minute  Pass

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 29.95 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dsc)	Meter Temperature		Ambient Temp. (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time (minutes)	Net Meter Volume for Run (dsc)	Avg. Meter Temp. for Run (°F)	DGM Calibration Factor Y <sub>i</sub>	Percent Variation (ΔY <sub>i</sub> )
			Inlet (°F)	Outlet (°F)								
	0	626.700	84	82								
1	5	629.240	85	81	82	0.79	22	5.0	2.54	83.0	0.9897	-0.5%
2	10	631.770	85	82	83	0.79	22	5.0	2.53	83.3	0.9932	-0.1%
3	15	634.280	85	82	84	0.79	22	5.0	2.51	83.5	1.0006	0.6%

Average Y<sub>i</sub> 0.9945  
 Cal. Error -1.1%

Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

# Meter Box Full Test Calibration

Meter Box No: 66-6

Date of Calibration: 4/8/03

Meter Box  $Y_d$ : 0.9891

Calibration conducted by: M.V.

Meter Box  $\Delta H@$ : 1.8341

*M.V.*  
Signature

Barometric Pressure: 29.45

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	$\Delta H$	$\Delta P$	$Y_{ds}$	Initial	Final	$V_{ds}$ Net	Initial	Final	$V_d$ Net	In	Out	$T_{ds}$ Avg.	In	Out	Avg.	$\Theta$	$Y_d$	$\Delta H@$
0.942	3.00	-1.80	1.0000	0.000	10.000	10.000	174.125	184.389	10.264	64.0	64.0	64.00	83.0	75.0	79.00	10.53	0.9902	1.8492
0.942	3.00	-1.80	1.0000	0.000	10.000	10.000	184.389	194.663	10.274	64.0	64.0	64.00	83.0	75.0	79.00	10.53	0.9893	1.8492
0.387	0.50	-1.10	1.0000	0.000	5.000	5.000	229.029	234.171	5.142	65.0	65.0	65.00	78.0	76.0	77.00	12.79	0.9906	1.8223
0.387	0.50	-1.10	1.0000	0.000	5.000	5.000	234.171	239.321	5.150	65.0	65.0	65.00	78.0	76.0	77.00	12.77	0.9891	1.8166
0.668	1.50	-1.40	1.0000	0.000	10.000	10.000	251.734	262.029	10.295	66.0	66.0	66.00	82.0	76.0	79.00	14.79	0.9882	1.8346
0.668	1.50	-1.40	1.0000	0.000	11.000	11.000	262.029	273.365	11.336	66.0	66.0	66.00	82.0	76.0	79.00	16.26	0.9872	1.8326

Averages 0.98910 1.83410

Nomenclature	Equations
<p><math>P_b</math> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p><math>\Delta H</math> Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p><math>\Delta P</math> Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p><math>V_d</math> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>V_{ds}</math> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>T_d</math> Average Meter Box Temperature (°F)</p> <p><math>T_o</math> Outlet Meter Box Temperature (°F)</p> <p><math>T_{ds}</math> Average Standard Meter Temperature (°F)</p> <p><math>Y_d</math> Meter Correction Factor (unitless)</p> <p><math>Y_{ds}</math> Standard Meter Correction Factor (unitless)</p> <p><math>\Delta H@</math> Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p><math>\Theta</math> Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge		DGM Thermocouples		
Standard (in.Hg)	Gauge (in.Hg)	Standard (°F)	Inlet (°F)	Outlet (°F)
5.0	4.8			
10.0	10.2			
15.0	15.1			
20.0	20.0			
25.0	25.0			

## Pyrometer Calibration Test Report

Pyrometer No.:	<u>66-6</u>	Office:	<u>Palatine, IL</u>
Calibrated By:	<u>M.V.</u>	Client:	<u></u>
Date:	<u>4/8/03</u>	Job Number:	<u></u>

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading
50 °F	50 °F
100 °F	100 °F
150 °F	150 °F
200 °F	201 °F
250 °F	251 °F
300 °F	301 °F
350 °F	350 °F
400 °F	399 °F
450 °F	448 °F
500 °F	498 °F
550 °F	548 °F
600 °F	599 °F

### Calibration Reference Information

Reference Used:	<u>Omega CL23A</u>	Serial No:	<u>T-225950</u>
Calibrated By:	<u>Omega Engineering, Inc.</u>	Date:	<u>8/28/03</u>
Report No:	<u>R 044791</u>		





Meter Box Critical Orifice Post-Test Calibration Data

Project No. 9281-2 / 9282-2 Meter No. 66-6 Orifice L-2  
 Location North South Broward Meter Yd 0.9891 Orifice K' 0.381  
 Test Date 6/6/2003 Meter ΔH@ 1.8341 Orifice Cal. Date 9/9/2002  
 Operator J. Szafranski Full Test Cal. Date 4/8/2003

Leak Checks

Negative Pressure

No movement of manometer in one-minute  Pass

Positive Pressure

No movement of manometer in one-minute  Pass

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 29.95 in. Hg

Run	Elapsed time (minutes)	Meter Volume (dcl)	Meter Temperature		Ambient Temp. (F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time θ (minutes)	Net Meter Volume for Run V <sub>m</sub> (dcl)	Avg. Meter Temp. for Run T <sub>m</sub> (F)	DGM Calibration Factor Y <sub>i</sub>	Percent Variation ΔY
			Inlet (F)	Outlet (F)								
	0	598.000	93	90								
1	5	600.580	92	90	90	0.80	18	5.0	2.58	91.3	0.9820	0.9%
2	10	603.190	91	90	89	0.80	18	5.0	2.61	90.8	0.9707	-0.2%
3	15	605.810	92	90	90	0.80	18	5.0	2.62	90.8	0.9661	-0.7%

Average Y<sub>i</sub>

0.9729  
Cal. Error -1.6%

Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

**SAMPLE PROBE CALIBRATION DATA**

Probe Type: M5 I.D. number: 67-8-11

**Thermocouple Calibration**

Reference Type: \_\_\_\_\_ Reference I.D. No: \_\_\_\_\_ Pyrameter I.D. No: \_\_\_\_\_ Degrees: F / C

Point No.	Target Temp.	Reference Temp	Indicated Temp	Temp Difference	% Difference	Specification
1	ice-32°F					%Difference ≤1.5
2	ambient-70°F					
3	hot oil-150°F					
4	boiling H <sub>2</sub> O-212°F					
5	hot oil-320°F					

Does assembly meet specifications?  → If "NO" thermocouple must be replaced.

**Geometric Pitot Calibration**

Is pitot assembly in good repair?  YES / NO If "NO" explain: \_\_\_\_\_  
 If repairs are required, pitot does not meet specification.



**"S" Pitot**



**Standard Pitot**

**Measurement**  
 a1 = 0      a2 = 1  
 b1 = 0      b2 = 0  
 γ = 0      θ = 1  
 Pa = 0.370      Pb = 0.346  
 A = 0.736      Dt = 0.250

**Calculations**  
 z = A sin γ = 0.0000      <0.125°  
 w = A sin θ = 0.0128453      <0.03125°

Pa + Pb = A

**Measurement**  
 Tube O.D. \_\_\_\_\_      Specification (D)  
 Static Hole I.D. \_\_\_\_\_      0.1 x D =  
 Length, \_\_\_\_\_  
 Tip to Static \_\_\_\_\_      > 6xD =  
 Static to Bend \_\_\_\_\_      > 8xD =

Does assembly meet specifications? YES / NO

If "YES" "S" pitot Cp=0.84; Std pitot Cp=0.99  
 If "NO" wind tunnel calibration is required.

Does assembly meet specifications?  YES / NO

**Wind Tunnel Pitot Calibration**

Reference Pitot I.D. No: \_\_\_\_\_ Reference Pitot Cp: \_\_\_\_\_

**Pitot Side 'A':**

Trial No.	Reference ΔP	Probe ΔP	Probe Cp*	Deviation from Average Cp*	Specification
1					Cp Deviations ≤0.01
2					
3					

Side 'A' Average Probe Cp= \_\_\_\_\_

**Pitot Side 'B':**

Trial No.	Reference ΔP	Probe ΔP	Probe Cp*	Deviation from Average Cp*	Specification
1					Cp Deviations ≤0.01
2					
3					

Side 'B' Average Probe Cp= \_\_\_\_\_

\* Probe Cp=(Reference Cp)√(Reference ΔP / Probe ΔP); Cp Deviation= Trial Probe Cp - Average Probe Cp

Side 'A' Average Cp \_\_\_\_\_ Side 'B' Average Cp \_\_\_\_\_ = \_\_\_\_\_ Difference \_\_\_\_\_ Abs. Diff. ≤0.01

Does assembly meet specifications?  YES / NO → If "YES" Cp=Average of Side 'A' and 'B' Cp values.  
 If "NO" PITOT MUST BE REPLACED.

**All Specifications are from EPA-600/9-76-006, Section 3.1**

PROBE Cp = 0.84      Calibrated by: [Signature]      Date: 03-13-03

**SAMPLE PROBE CALIBRATION DATA**

Probe Type: 115 I.D. number: 67-8-4

**Thermocouple Calibration**

Reference Type: \_\_\_\_\_ Reference I.D. No: \_\_\_\_\_ Pyrometer I.D. No: \_\_\_\_\_ Degrees: F / C

Point No.	Target Temp.	Reference Temp	Indicated Temp	Temp Difference	% Difference	Specification
1	ice-32°F					%Difference ≤ 1.5
2	ambient-70°F					
3	hot oil-150°F					
4	boiling H <sub>2</sub> O-212°F					
5	hot oil-320°F					

Does assembly meet specifications?  → If "NO" thermocouple must be replaced.

**Geometric Pitot Calibration diagrams on reverse**

Is pitot assembly in good repair?  YES / NO If "NO" explain: \_\_\_\_\_  
 If repairs are required, pitot does not meet specification.

<input checked="" type="checkbox"/> <b>"S" Pitot</b>	<input type="checkbox"/> <b>Standard Pitot</b>
<p><b>Measurement</b></p> <p>a1 = <u>0</u>      a2 = <u>10</u></p> <p>b1 = <u>0</u>      b2 = <u>0</u></p> <p>γ = <u>0</u>      θ = <u>1</u></p> <p>Pa = <u>365</u>      Pb = <u>367</u></p> <p>A = <u>732</u>      Dt = <u>.254</u></p> <p>Calculations</p> <p>z = A sin γ = <u>0.0</u></p> <p>w = A sin θ = <u>0.0127753</u></p>	<p><b>Specification</b></p> <p>&lt;10°</p> <p>&lt;5°</p> <p>Pa + Pb = A</p> <p>&lt;0.125"</p> <p>&lt;0.03125"</p>
<p><b>Measurement</b></p> <p>Tube O.D. _____</p> <p>Static Hole I.D. _____</p> <p>Length, _____</p> <p>Tip to Static _____</p> <p>Static to Bend _____</p>	<p><b>Specification (D)</b></p> <p>0.1 x D = _____</p> <p>&gt; 6xD = _____</p> <p>&gt; 8xD = _____</p>

Does assembly meet specifications?  YES / NO

If "YES" "S" pitot Cp=0.84; Std pitot Cp=0.99  
 If "NO" wind tunnel calibration is required.

**Wind Tunnel Pitot Calibration**

Reference Pitot I.D. No: \_\_\_\_\_ Reference Pitot Cp: \_\_\_\_\_

Pitot Side 'A':				Deviation from Average Cp*	Specification
Trial No.	Reference ΔP	Probe ΔP	Probe Cp*		
1				Cp Deviations ≤ 0.01	
2					
3					

Side 'A' Average Probe Cp = \_\_\_\_\_

Pitot Side 'B':				Deviation from Average Cp*	Specification
Trial No.	Reference ΔP	Probe ΔP	Probe Cp*		
1				Cp Deviations ≤ 0.01	
2					
3					

Side 'B' Average Probe Cp = \_\_\_\_\_

\* Probe Cp = (Reference Cp) \* (Reference ΔP / Probe ΔP); Cp Deviation = Trial Probe Cp - Average Probe Cp

Side 'A' Average Cp: \_\_\_\_\_ Side 'B' Average Cp: \_\_\_\_\_ = \_\_\_\_\_ Abs. Diff. ≤ 0.01

Does assembly meet specifications?  YES / NO → If "YES" Cp = Average of Side 'A' and 'B' Cp values.  
 If "NO" PITOT MUST BE REPLACED.

All specifications are from EPA 600/9-76-003, section 3.1

PROBE Cp = 0.84      Calibrated by: [Signature]      Date: 1-9-03

WHEELABRATOR NORTH BROWARD  
POMPANO BEACH, FLORIDA

Client Reference No: 14200357  
CleanAir Project No: 9281-3

**FIELD DATA**

D

TEST LOCATION: FF OUTLET


Hg  
**TESTING  
FIELD DATA SHEET**

METHOD: 29 PAGE 1 OF 3

UNIT: 1 RUN: 1

Client	<u>WHEELABRATOR</u>	Project No.	<u>9281-2</u>
Plant	<u>N. BROWARD</u>	Date	<u>6-5-03</u>
Meter Operator	<u>J. SZARANSKI</u>		
Probe Operator	<u>"</u>		

Meter Box No.	<u>66-6</u>	Sample Box No.	<u>67-29</u>
Meter Yd	<u>0.9891</u>	Meter ΔH@	<u>1.8341</u>
K Factor	<u>2.95</u>	Pitot Cp	<u>0.84</u>
Leak Rate Before	<u>.004</u> (cfm) [Lpm] @ <u>25</u> (in.Hg)		
Leak Rate After	<u>.001</u> (cfm) [Lpm] @ <u>7</u> (in.Hg)		
Pitot Leak Check Before:	<input checked="" type="checkbox"/>	After:	Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>



Duct Dimensions (in.) <u>96 x 96</u>			
Static Press. (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (In) [Out] of page	First point all the way (In) [Out]
<u>-11.0</u>	<u>16</u>	<u>(In)</u>	<u>(In)</u>

Amb. Temp. (°F)	Bar. Press. <u>29.90</u> [ <u>in. Hg</u> ] [mbar]
Probe I.D. No.	<u>67-8-11</u>
Liner Material	<u>P<sub>7</sub>REX</u>

Filter No.	<u>NA</u>		
Thimble No.	<u>NA</u>		
Nozzle Diameter	<u>0.274</u>	Nozzle I.D.	<u>274-1</u>

H <sub>2</sub> O	[ml] [gm]	Silica Gel (gm)
Total V <sub>IC</sub>		

Start Time:	<u>7:41</u>	Stop Time:	<u>9:46</u>
-------------	-------------	------------	-------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume - V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp T <sub>t</sub> (°F)	Notes
						T <sub>p</sub> (°F)	T <sub>f</sub> (°F)						
				<u>354.530</u>		Set Points							
						<u>250</u>	<u>250</u>						
1-1	5	0.21	0.62	356.78	309	250	251	68	80	80	2	NA	
2	10	0.23	0.68	359.09	306	248	252	65	81	80	2		
3	15	0.32	0.94	361.82	301	250	252	54	82	80	2		
4	20	0.52	1.6	365.25	308	251	252	51	84	81	3		
5	25	0.55	1.6	368.77	309	251	253	53	85	81	3		
2-1	30	0.51	1.5	372.20	299	251	252	52	86	81	3		
2	35	0.39	1.2	375.32	309	255	253	56	87	82	3		
3	40	0.39	1.2	378.35	309	251	253	56	88	83	3		
4	45	0.52	1.5	381.77	310	251	253	58	89	83	3		
5	50	0.55	1.6	385.31	309	252	254	58	91	84	3		
		<del>6.3821</del>	<del>12.34</del>	<del>30.2</del>	<del>306.4</del>				<del>86.8</del>				
	Total	<u>16.1772</u>	<u>31.04</u>	<u>77.900</u>	<u>7695</u>				<u>4316</u>				
	Average	<u>0.6471</u>	<u>1.2416</u>	<u>307.8000</u>					<u>86.3200</u>				

Clean Air Engineering  
500 West Wood Street  
Palatine, IL 60067

TEST LOCATION: FF OUTLET

Hg TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 2 OF 3

UNIT: 1 RUN: 1

Client <u>WHEELABRATOR</u>	Project No. <u>9281-2</u>
Plant <u>N. BROWARD</u>	Date <u>6-5-03</u>
Meter Operator <u>J. SZAFRANSKI</u>	
Probe Operator <u>11</u>	

Meter Box No.	Sample Box No.
Meter Yd	Meter ΔH@
K Factor	Pitot Cp
Leak Rate Before	[cfm] [Lpm] @ (in. Hg)
Leak Rate After	[cfm] [Lpm] @ (in. Hg)
Pitot Leak Check Before:	After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Press. (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
---	--------------------	-----------------------------------	--

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

H <sub>2</sub> O	[ml] [gm]	Silica Gel (gm)
Total V <sub>lc</sub>		

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume - V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>mout</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp T <sub>t</sub> (°F)	Notes
						Set Points							
3-1	55	0.43	1.3	388.60	310	252	253	61	91	85	3	NA	
2	60	0.35	1.0	391.41	310	253	253	61	91	85	3		
3	65	0.36	1.1	394.34	310	251	253	57	90	85	3		
4	70	0.51	1.5	397.87	310	252	253	53	90	86	3		
5	75	0.52	1.5	401.27	308	252	253	53	90	85	3		
4-1	80	0.40	1.2	404.42	303	252	254	54	90	86	3		
2	85	0.36	1.1	407.40	309	252	253	56	90	86	3		
3	90	0.46	1.3	410.62	309	252	254	57	90	86	3		K' → 2.90
4	95	0.52	1.5	414.04	311	252	254	59	91	87	4		
5	100	0.52	1.5	417.48	310	253	253	59	91	87	4		
		<del>0.276</del>	<del>25.34</del>		<del>6154</del>				<del>3130</del>				
	Total												
	Average												



TEST LOCATION: FF OUTLET

Hg TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 1 OF 3

UNIT: 1 RUN: 2

Client <u>WHEELABRATORZ</u>	Project No. <u>9281-2</u>
Plant <u>N. BROWARD</u>	Date <u>6-5-03</u>
Meter Operator <u>J. SZAFRANSKI</u>	
Probe Operator <u>IC</u>	

Meter Box No. <u>61-11</u>	Sample Box No. <u>67-30</u>
Meter Yd <u>1.0051</u>	Meter ΔH@ <u>1.7561</u>
K Factor <u>2.90</u>	Pitot Cp <u>0.84</u>
Leak Rate Before <u>.003</u> (cfm) [Lpm] @ <u>15</u> (in.Hg)	
Leak Rate After <u>.002</u> (cfm) [Lpm] @ <u>8</u> (in.Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	

Cross-Section of Test Location

Duct Dimensions (in.) 96x96

Static Press. (in. H2O) <u>-11.0</u>	Port Len. (in.) <u>10</u>	Gas Flow (In) [Out] of page <u>(In)</u>	First point all the way <u>(In)</u> [Out]
--------------------------------------	---------------------------	---	---

Amb. Temp. (°F) <u>85</u>	Bar. Press. <u>29.90</u> (in. Hg) [mbar]
Probe I.D. No. <u>67-8-4</u>	
Liner Material <u>Pyrex</u>	

Filter No. <u>NA</u>		
Thimble No. <u>NA</u>		
Nozzle Diameter <u>0.277</u>	Nozzle I.D. <u>277-1</u>	

H2O [ml] [gm]	Silica Gel (gm)
Total V <sub>lc</sub>	

Start Time: <u>9:46</u>	Stop Time: <u>11:51</u>
-------------------------	-------------------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume - V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp T <sub>t</sub> (°F)	Notes
						250	250						
1-1	5	0.21	0.61	463.54	304	253	249	62	85	85	2	NA	
2	10	0.20	0.58	465.66	304	252	254	59	87	85	2		
3	15	0.36	1.0	468.42	292	251	255	56	87	86	2		
4	20	0.46	1.3	471.66	305	252	254	54	90	86	3		
5	25	0.56	1.6	475.26	305	252	254	58	92	87	4		
2-1	30	0.60	1.7	478.93	303	252	253	60	93	87	5		
2	35	0.48	1.4	482.27	308	253	254	61	94	88	4		
3	40	0.42	1.2	485.38	307	252	253	57	94	88	4		K' 2.74
4	45	0.50	1.4	488.71	308	251	252	54	94	88	4		
5	50	0.55	1.5	492.18	308	251	250	54	95	89	4		
		<del>6.4163</del>	<del>12.29</del>	<del>21.065</del>	<del>3050</del>				<del>1720</del>				
	Total	17.0674	32.89	81.125	7662				4646				
	Average	0.6827	1.3156	81.125	306.4800				92.9200				



TEST LOCATION: FF OUTLET

Hg TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 2 OF 3

UNIT: 1 RUN: 2

Client	WHEELABRATOR	Project No.	9281-2
Plant	N BROWARD	Date	6-5-03
Meter Operator	J. SZAFRANSKI		
Probe Operator	"		

Meter Box No.	Sample Box No.
Meter Yd	Meter ΔH@
K Factor	Pitot Cp
Leak Rate Before	[cfm] [Lpm] @ (in.Hg)
Leak Rate After	[cfm] [Lpm] @ (in.Hg)
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Cross-Section of Test Location

↑

[N] [UP]

Duct Dimensions (in.)

Static Press. (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
---	--------------------	-----------------------------------	--

Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

H <sub>2</sub> O	[ml] [gm]	Silica Gel (gm)
Total V <sub>ic</sub>		

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume - V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp T <sub>t</sub> (°F)	Notes	
						T <sub>p</sub> (°F)	T <sub>f</sub> (°F)							
						250	250							
3-1	55	0.50	1.4	495.57	306	251	251	56	96	89	4	NA		
2	60	0.43	1.2	498.70	307	252	255	57	97	89	4			
3	65	0.43	1.2	501.78	308	252	254	57	97	90	4			
4	70	0.53	1.5	505.30	309	252	250	60	98	91	5			
5	75	0.61	1.7	508.98	308	252	251	60	99	91	5			
4-1	80	0.41	1.1	511.96	303	251	250	61	98	91	4			
2	85	0.44	1.2	515.10	308	252	255	62	98	92	4			
3	90	0.46	1.3	518.35	309	252	254	62	99	92	4			
4	95	0.61	1.7	522.04	309	252	253	62	100	93	5			
5	100	0.55	1.5	525.55	309	252	250	63	100	93	5			
		<del>13.5264</del>	<del>26.09</del>											
						<del>6126</del>				<del>3675</del>				
	Total													
	Average													

Clean Air Engineering  
500 West Wood Street  
Palatine, IL 60067

TEST LOCATION: FF OUTLET

UNIT: 1 RUN: 2

Client	WHEELABRATOR	Project No.	9281-2
Plant	N BROWARD	Date	6-5-03
Meter Operator	J. SZARANSKI		
Probe Operator			

Meter Box No.	Sample Box No.
Meter Yd	Meter ΔH @
K Factor	Pitot Cp
Leak Rate Before	[cfm] [Lpm] @ (in.Hg)
Leak Rate After	[cfm] [Lpm] @ (in.Hg)
Pitot Leak Check Before:	<input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

H<sub>2</sub> TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 3 OF 3

Cross-Section of Test Location

↑

[N] [UP]

Duct Dimensions (in.)

Static Press. (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
---	--------------------	-----------------------------------	--

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

H <sub>2</sub> O [ml] [gm]	Silica Gel (gm)
Total V <sub>lc</sub>	

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt ↙ Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume - V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp. T <sub>t</sub> (°F)	Notes
						T <sub>p</sub> (°F)	T <sub>f</sub> (°F)						
5-1	105	0.45	1.2	528.72	306	252	251	65	100	94	4	NM ↓	
2	110	0.45	1.2	531.82	307	252	253	63	100	94	4		
3	115	0.51	1.4	535.14	308	252	254	64	101	94	4		
4	120	0.56	1.5	538.72	308	252	252	65	100	94	4		
5	125	0.54	1.5	542.240	307	253	252	65	100	94	5		
	Total	*											
	Average												

TEST LOCATION: FF OUTLET

UNIT: 1 RUN: 3

Client	WHERAB7A02	Project No.	9281-2
Plant	N BOWARD	Date	6-5-03
Meter Operator	J. SZERANSKI		
Probe Operator			

Meter Box No.	66-6	Sample Box No.	67-24
Meter Yd	0.9891	Meter ΔH@	1.8341
K Factor	2.74	Pitot Cp	0.84
Leak Rate Before	0.02 [cfm] [Lpm] @ 15 (in.Hg)		
Leak Rate After	0.03 [cfm] [Lpm] @ 8 (in.Hg)		
Pitot Leak Check Before:	<input checked="" type="checkbox"/>	After:	Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Hg TESTING FIELD DATA SHEET

METHOD: 29 PAGE 1 OF 3

Cross-Section of Test Location

Duct Dimensions (in.) 96 x 96

Static Press. (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (in) [Out] of page	First point all the way (in) [Out]
-11.0	10		

Amb. Temp. (°F)	Bar. Press. <u>29.90</u> [in. Hg] [mbar]
Probe I.D. No.	<u>67-8-11</u>
Liner Material	<u>Pyrex</u>

Filter No.	<u>NA</u>	
Thimble No.	<u>NA</u>	
Nozzle Diameter	<u>0.274</u>	Nozzle I.D. <u>274-1</u>

H <sub>2</sub> O	[ml] [gm]	Silica Gel (gm)
Total V <sub>lc</sub>		

Start Time:	<u>11:51</u>	Stop Time:	<u>13:56</u>
-------------	--------------	------------	--------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume - V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp T <sub>t</sub> (°F)	Notes
						T <sub>p</sub> (°F)	T <sub>f</sub> (°F)						
				433.115		250	250						
1-1	5	0.27	0.74	435.66	308	250	251	66	95	92	2	NA	
2	10	0.27	0.74	438.05	308	252	252	65	95	92	2		
3	15	0.34	0.93	440.75	303	251	254	62	96	92	2		
4	20	0.61	1.7	444.41	310	251	253	60	97	93	3		
5	25	0.52	1.4	447.80	310	251	252	61	100	94	3		
2-1	30	0.52	1.4	451.19	306	254	253	63	99	95	3		
2	35	0.42	1.2	454.29	310	255	253	53	101	95	3		
3	40	0.36	0.99	457.15	310	250	253	50	99	95	3		
4	45	0.52	1.4	460.36	312	250	253	51	99	95	3		
5	50	0.63	1.7	464.11	312	250	254	53	100	95	4		
		<del>6.6085</del>	<del>18.2</del>		3086				1919				
	Total	16.6549	30.84	78.775	7734				4865				
	Average	0.6662	1.2336	309.3600					97.3000				

TEST LOCATION: FF OUTLET

Hg  
**TESTING  
FIELD DATA SHEET**

METHOD: 29 PAGE 2 OF 3

UNIT: 1 RUN: 3

Client	WHEELABRATOR	Project No.	9271-2
Plant	N BREWERS	Date	6-5-03
Meter Operator	J. SZARANSKI		
Probe Operator	"		

Meter Box No.	Sample Box No.
Meter Yd	Meter ΔH@
K Factor	Pitot Cp
Leak Rate Before	[cfm] [Lpm] @ (in. Hg)
Leak Rate After	[cfm] [Lpm] @ (in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Press. (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
---	--------------------	-----------------------------------	--

Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

H <sub>2</sub> O	[ml] [gm]	Silica Gel (gm)
Total V <sub>IC</sub>		

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume - V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe	Filter	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>out</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp T <sub>t</sub> (°F)	Notes
						T <sub>p</sub> (°F)	T <sub>f</sub> (°F)						
3-1	55	0.34	0.93	466.95	305	250	250	55	100	95	3	NA	
2	60	0.44	1.2	470.05	311	251	253	57	99	96	3		
3	65	0.44	1.2	473.16	312	252	254	58	99	96	3		
4	70	0.55	1.5	476.60	311	251	254	60	99	96	4		
5	75	0.57	1.6	480.18	311	252	253	61	99	96	4		
4-1	80	0.40	1.1	483.17	305	253	253	62	100	95	4		
2	85	0.36	0.99	486.07	310	255	254	63	101	96	4		
3	90	0.44	1.2	489.89	311	252	254	63	101	97	4		
4	95	0.44	1.2	492.38	311	252	255	61	101	97	4		
5	100	0.53	1.5	495.87	310	251	254	62	100	97	4		
		<del>3.302</del>	<del>24.42</del>		<del>4123</del>				<del>3879</del>				
	Total												
	Average												

Clean Air Engineering  
500 West Wood Street  
Palatine, IL 60067

TEST LOCATION: FF OUTLET

Hg TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 3 OF 3

UNIT: 1 RUN: 3

Client	WHEELABRATOR	Project No.	9281-2
Plant	N BROWARD	Date	6-5-03
Meter Operator	J. SZAFRANSKI		
Probe Operator	11		

Cross-Section of Test Location

↑  
[N] [UP]

Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Meter Box No.	Sample Box No.
Meter Yd	Meter ΔH@
K Factor	Pitot Cp
Leak Rate Before	[cfm] [Lpm] @ (in. Hg)
Leak Rate After	[cfm] [Lpm] @ (in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.)			
Static Press.	Port Len.	Gas Flow	First point
(in. H2O)	(in.)	[In] [Out]	all the way
		of page	[In] [Out]

Filter No.		
Thimble No.		
Nozzle Diameter	Nozzle I.D.	

H2O	[ml] [gm]	Silica Gel (gm)
Total V <sub>1c</sub>		

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume - V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>mout</sub> (°F)	Pump Vacuum (in. Hg)	XAD Trap Temp T <sub>t</sub> (°F)	Notes
						T <sub>p</sub> (°F)	T <sub>f</sub> (°F)						
5-1	105	0.30	0.82	498.51	308	253	254	63	100	97	3	NA	
2	110	0.44	1.2	501.65	311	254	254	63	100	97	4		
3	115	0.48	1.3	504.94	311	253	255	64	100	97	4		
4	120	0.54	1.5	508.32	311	253	254	64	101	97	4		
5	125	0.51	1.4	511.890	310	252	253	65	100	97	4	↓	
	Total												
	Average												

Clean Air Engineering  
500 West Wood Street  
Palatine, IL 60067

# ORSAT READINGS

TEST LOCATION: FF Outlet

PAGE \_\_\_\_\_ OF \_\_\_\_\_

Client: Wheelabrator North Broward	Project Number: 9281-2	$F_o = \frac{20.9 - \%O_2}{\%CO_2}$
Plant: Pompano Beach, FL	Unit: 1	
Orsat ID: #8	Fuel Type: Refuse	Leak Check Passed <input checked="" type="checkbox"/>

Run Number	Method Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	F <sub>o</sub>	Analyst	Analysis	
								Date	Time
1	29	1	10.0%	19.4%	9.4%		KRO	6/5/2003	10:09
		2	10.2%	19.4%	9.2%				
		3	10.0%	19.4%	9.4%				
		Avg.	10.1%	19.4%	9.3%				
2	29	1	10.0%	19.8%	9.8%		KRO	6/5/2003	12:15
		2	10.0%	19.8%	9.8%				
		3	10.0%	19.8%	9.8%				
		Avg.	10.0%	19.8%	9.8%				
3	29	1	10.4%	19.6%	9.2%		KRO	6/5/2003	14:28
		2	10.4%	19.4%	9.0%				
		3	10.4%	19.6%	9.2%				
		Avg.	10.4%	19.5%	9.1%				
4	29	1	10.4%	19.6%	9.2%		KRO	6/5/2003	
		2	10.4%	19.6%	9.2%				
		3	10.4%	19.6%	9.2%				
		Avg.	10.4%	19.6%	9.2%				
5	29	1	9.8%	19.4%	9.6%		KRO	6/6/2003	
		2	9.8%	19.4%	9.6%				
		3	9.8%	19.6%	9.8%				
		Avg.	9.8%	19.5%	9.7%				
6	29	1	9.8%	19.0%	9.2%		KRO	6/6/2003	
		2	9.8%	19.0%	9.2%				
		3	9.8%	19.0%	9.2%				
		Avg.	9.8%	19.0%	9.2%				

Repeat the analysis procedure until the results of any three analyses differ by no more than 0.2 percent by volume. Average the three acceptable values and report the results to the nearest 0.1 percent. Calculate F<sub>o</sub> to verify results.

Acceptable ranges for F<sub>o</sub>:

Coal: Anthracite and lignite	1.016-1.130	Gas: Natural	1.600-1.836
Oil: Bituminous	1.083-1.230	Propane	1.434-1.586
Oil: Distillate	1.260-1.413	Butane	1.405-1.553
Oil: Residual	1.210-1.370	Wood:	1.000-1.120

# Impinger Weight Sheet

Client: Wheelabrator North Broward	Unit Name/Location: 1/FF Outlet
Plant: Pompano Beach, FL	Job No: 9281-2
	Method: 29

Run No: 1	Filter Type: Quartz	Sample Box No: 67-29
Date: 6/5/2003	Lot No:	pH:
Analyst: K. O'Halloren	Filter No: NA	Rinse:

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	717.5	442.7	274.8	
Impinger 2	100 ml 5%HNO3/10%H2O2	739.1	542.1	197.0	QA/QC Date
Impinger 3	100 ml 5%HNO3/10%H2O2	545.0	531.5	13.5	
Impinger 4	Empty	451.5	450.3	1.2	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	535.1	534.8	0.3	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	552.5	553.1	(0.6)	486.2
Impinger 7	Silica Gel	772.2	754.6	17.6	503.8

Run No: 2	Filter Type: Quartz	Sample Box No: 67-30
Date: 6/5/2003	Lot No:	pH:
Analyst: K. O'Halloren	Filter No: NA	Rinse:

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	706.0	436.6	269.4	
Impinger 2	100 ml 5%HNO3/10%H2O2	773.3	545.0	228.3	QA/QC Date
Impinger 3	100 ml 5%HNO3/10%H2O2	539.8	523.8	16.0	
Impinger 4	Empty	430.0	429.5	0.5	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	529.2	529.5	(0.3)	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	552.3	551.5	0.8	514.7
Impinger 7	Silica Gel	716.3	699.2	17.1	531.8

Run No: 3	Filter Type: Quartz	Sample Box No: 67-29
Date: 6/5/2003	Lot No:	pH:
Analyst: K. O'Halloren	Filter No: NA	Rinse:

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	745.0	442.8	302.2	
Impinger 2	100 ml 5%HNO3/10%H2O2	713.9	540.7	173.2	QA/QC Date
Impinger 3	100 ml 5%HNO3/10%H2O2	543.0	530.5	12.5	
Impinger 4	Empty	451.6	450.5	1.1	
Impinger 5	100 ml 4%KMnO4/10%H2SO4	532.4	532.1	0.3	Total Weight (gm)
Impinger 6	100 ml 4%KMnO4/10%H2SO4	555.2	554.4	0.8	490.1
Impinger 7	Silica Gel	718.8	703.7	15.1	505.2

WHEELABRATOR NORTH BROWARD  
POMPANO BEACH, FLORIDA

Client Reference No: 14200357  
CleanAir Project No: 9281-3

**FIELD DATA PRINTOUTS**

E



Field Data Printout

Test Method: USEPA Method 29  
 Analyte: Mercury

Location: Unit 1 FF Outlet

Test Run: 1

Client: Wheelabrator North Broward, Inc.  
 Project No: 9281-2  
 Source Area (ft<sup>2</sup>): 64.00000

Bar. Press. (in. Hg): 29.90  
 Static P: -11.0  
 O<sub>2</sub> (dry volume %): 9.33  
 CO<sub>2</sub> (dry volume %): 10.07  
 N<sub>2</sub>+CO (dry volume %): 80.60

Nozzle ID No: 274-1  
 Nozzle Diameter (D<sub>n</sub>): 0.274  
 Probe ID No: 67-8-11  
 Pitot C<sub>p</sub>: 0.84  
 Pitot Leak Check:  Pass  Fail

Test Date: 6/05/03  
 Start Time: 07:41  
 Stop Time: 09:46  
 Leak Rate Before: 0.004 cfm @ 25 "Hg  
 Leak Rate After: 0.001 cfm @ 7 "Hg

H<sub>2</sub>O (condensate, ml or gm): 486.2  
 H<sub>2</sub>O (silica, g): 17.6  
 Actual Moisture (%): 24.12

Meter Box ID. No: 66-6  
 Meter ΔH@: 1.83410  
 Meter Y<sub>d</sub>: 0.98910

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
1-01	0.0	0.21	0.62	354.53	304	80	80	0.46	2.25	107.3
1-02	5.0	0.23	0.68	359.09	306	81	80	0.48	2.31	105.4
1-03	10.0	0.32	0.94	361.82	301	82	80	0.57	2.73	105.2
1-04	15.0	0.52	1.50	365.25	308	84	81	0.72	3.43	104.0
1-05	20.0	0.55	1.60	368.77	309	85	81	0.74	3.52	103.8
2-01	25.0	0.51	1.50	372.20	299	86	81	0.71	3.43	104.2
2-02	30.0	0.39	1.20	375.32	309	87	82	0.62	3.12	108.8
2-03	35.0	0.39	1.20	378.35	309	88	83	0.62	3.03	105.5
2-04	40.0	0.52	1.50	381.77	310	89	83	0.72	3.42	103.2
2-05	45.0	0.55	1.60	385.31	309	91	84	0.74	3.54	103.5
3-01	50.0	0.43	1.30	388.60	310	91	85	0.66	3.29	108.7
3-02	55.0	0.35	1.00	391.41	310	91	85	0.59	2.81	102.8
3-03	60.0	0.36	1.10	394.34	310	90	85	0.60	2.93	105.8
3-04	65.0	0.51	1.50	397.87	310	90	86	0.71	3.53	107.1
3-05	70.0	0.52	1.50	401.27	308	90	85	0.72	3.40	102.1
4-01	75.0	0.40	1.20	404.42	303	90	86	0.63	3.15	107.4
4-02	80.0	0.36	1.10	407.40	309	90	86	0.60	2.98	107.5
4-03	85.0	0.46	1.30	410.62	309	90	86	0.68	3.22	102.8
4-04	90.0	0.52	1.50	414.04	311	91	87	0.72	3.42	102.7
4-05	95.0	0.52	1.50	417.48	310	91	87	0.72	3.44	103.2
5-01	100.0	0.35	1.00	420.36	303	91	87	0.59	2.88	104.7
5-02	105.0	0.35	1.00	423.21	309	90	87	0.59	2.85	104.1
5-03	110.0	0.40	1.20	426.08	310	90	87	0.63	2.87	98.2
5-04	115.0	0.46	1.30	429.31	308	90	87	0.68	3.23	102.9
5-05	120.0	0.43	1.20	432.43	311	90	87	0.66	3.12	103.0
Final	125.0		1.24160	77.90000	307.80000	86.32000		0.64709	77.90000	

25 points sampled  
 QC-Check: Field Averages  
 Sq.RIΔP  
 0.6471    1.2416    77.9000    307.8000    86.3200  
 Avg. OK     Avg. OK     Avg. OK     Avg. OK     Avg. OK

062503 100637

**Field Data Printout**

**Test Method:** USEPA Method 29  
**Analyte:** Mercury

Location: Unit 1 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator North Broward, Inc.  
 Project No: 9281-2  
 Source Area (ft<sup>2</sup>): 64.00000

Bar. Press. (in. Hg): 29.90  
 Static P: -11.0  
 O<sub>2</sub> (dry volume %): 9.80  
 CO<sub>2</sub> (dry volume %): 10.00  
 N<sub>2</sub>+CO (dry volume %): 80.20

Nozzle ID No: 277-1  
 Nozzle Diameter (D<sub>n</sub>): 0.277  
 Probe ID No: 67-8-4  
 Pitot C<sub>p</sub>: 0.84  
 Pitot Leak Check:  Pass  Fail

Test Date: 6/05/03  
 Start Time: 09:46  
 Stop Time: 11:51  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.002 cfm @ 8 "Hg

H<sub>2</sub>O (condensate, ml or gm): 514.7  
 H<sub>2</sub>O (silica, g): 17.1  
 Actual Moisture (%): 24.29

Meter Box ID. No: 61-11  
 Meter ΔH@: 1.75610  
 Meter Y<sub>g</sub>: 1.00510

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			461.12						
1-01	5.0	0.21	0.61	463.54	304	85	85	0.46	2.43	114.2*
1-02	10.0	0.20	0.58	465.66	304	87	85	0.45	2.12	102.1
1-03	15.0	0.36	1.00	468.42	298	87	86	0.60	2.76	98.7
1-04	20.0	0.46	1.30	471.66	305	90	86	0.68	3.24	102.8
1-05	25.0	0.56	1.60	475.26	305	92	87	0.75	3.60	103.3
2-01	30.0	0.60	1.70	478.93	303	93	87	0.77	3.67	101.5
2-02	35.0	0.48	1.40	482.27	308	94	88	0.69	3.34	103.4
2-03	40.0	0.42	1.20	485.38	307	94	88	0.65	3.11	102.8
2-04	45.0	0.50	1.40	488.71	308	94	88	0.71	3.33	101.0
2-05	50.0	0.55	1.50	492.18	308	95	89	0.74	3.47	100.2
3-01	55.0	0.50	1.40	495.57	306	96	89	0.71	3.39	102.4
3-02	60.0	0.43	1.20	498.70	307	97	89	0.66	3.13	101.9
3-03	65.0	0.43	1.20	501.78	308	97	90	0.66	3.08	100.2
3-04	70.0	0.53	1.50	505.30	309	98	91	0.73	3.52	103.1
3-05	75.0	0.61	1.70	508.98	308	99	91	0.78	3.68	100.4
4-01	80.0	0.41	1.10	511.96	303	98	91	0.64	2.98	98.8
4-02	85.0	0.44	1.20	515.10	308	98	92	0.66	3.14	100.7
4-03	90.0	0.46	1.30	518.35	309	99	92	0.68	3.25	102.0
4-04	95.0	0.61	1.70	522.04	309	100	93	0.78	3.69	100.4
4-05	100.0	0.55	1.50	525.55	309	100	93	0.74	3.51	100.6
5-01	105.0	0.45	1.20	528.72	306	100	94	0.67	3.17	100.1
5-02	110.0	0.45	1.20	531.82	307	100	94	0.67	3.10	97.9
5-03	115.0	0.51	1.40	535.14	308	101	94	0.71	3.32	98.5
5-04	120.0	0.56	1.50	538.72	308	100	94	0.75	3.58	101.5
5-05	125.0	0.54	1.50	542.24	307	100	94	0.73	3.52	101.6
Final	125.0		1.31560	81.12500	306.48000	92.88000		0.68269	81.12500	

25 points sampled Sq. RL ΔP  
 QC-Check: Field Averages 

0.6827	1.3156	81.1250	306.4800	92.9200
--------	--------	---------	----------	---------

 Avg. OK  
 Avg. OK  
 Avg. OK  
 Avg. OK  
 Avg. OK

062503 100637

Field Data Printout

Test Method: USEPA Method 29  
 Analyte: Mercury

Location: Unit 1 FF Outlet

Test Run: 3

Client: Wheelabrator North Broward, Inc.

Project No: 9281-2

Source Area (ft<sup>2</sup>): 64.00000

Bar. Press. (in. Hg): 29.90

Static P: -11.0

O<sub>2</sub> (dry volume %): 9.13

CO<sub>2</sub> (dry volume %): 10.40

N<sub>2</sub>+CO (dry volume %): 80.47

Nozzle ID No: 274-1

Nozzle Diameter (D<sub>n</sub>): 0.274

Probe ID No: 67-8-11

Pilot C<sub>p</sub>: 0.84

Pitot Leak Check:  Pass  Fail

Test Date: 6/05/03

Start Time: 11:51

Stop Time: 13:56

Leak Rate Before: 0.002 cfm

Leak Rate After: 0.003 cfm

@ 15 "Hg

@ 8 "Hg

H<sub>2</sub>O (condensate, ml or gm): 490.1

H<sub>2</sub>O (silica, g): 15.1

Actual Moisture (%): 24.33

Meter Box ID. No: 66-6

Meter ΔH@: 1.83410

Meter Y<sub>d</sub>: 0.98910

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
1-01	5.0	0.27	0.74	433.12	308	95	92	0.52	2.49	102.6
1-02	10.0	0.27	0.74	438.05	305	95	92	0.52	2.45	101.0
1-03	15.0	0.34	0.93	440.75	303	96	92	0.58	2.70	99.0
1-04	20.0	0.61	1.70	444.41	310	97	93	0.78	3.66	100.6
1-05	25.0	0.52	1.40	447.80	310	100	94	0.72	3.39	100.5
2-01	30.0	0.52	1.40	451.19	306	99	95	0.72	3.39	100.3
2-02	35.0	0.42	1.20	454.29	310	101	95	0.65	3.10	102.0
2-03	40.0	0.36	0.99	457.15	310	99	95	0.60	2.86	101.8
2-04	45.0	0.52	1.40	460.36	312	99	95	0.72	3.21	95.3
2-05	50.0	0.63	1.70	464.11	312	100	95	0.79	3.75	101.1
3-01	55.0	0.34	0.93	466.95	305	100	95	0.58	2.84	103.6
3-02	60.0	0.44	1.20	470.05	311	99	96	0.66	3.10	99.8
3-03	65.0	0.44	1.20	473.16	312	99	96	0.66	3.11	100.2
3-04	70.0	0.55	1.50	476.60	311	99	96	0.74	3.44	99.2
3-05	75.0	0.57	1.60	480.18	311	99	96	0.75	3.58	101.4
4-01	80.0	0.40	1.10	483.17	305	100	95	0.63	2.99	100.6
4-02	85.0	0.36	0.99	486.07	310	101	96	0.60	2.90	103.0
4-03	90.0	0.44	1.20	489.19	311	101	97	0.66	3.12	100.2
4-04	95.0	0.44	1.20	492.38	311	101	97	0.66	3.19	102.5
4-05	100.0	0.53	1.50	495.87	310	100	97	0.73	3.49	102.2
5-01	105.0	0.30	0.82	498.51	308	100	97	0.55	2.64	102.5
5-02	110.0	0.44	1.20	501.65	311	100	97	0.66	3.14	101.0
5-03	115.0	0.48	1.30	504.94	311	100	97	0.69	3.29	101.3
5-04	120.0	0.54	1.50	508.32	311	101	97	0.73	3.38	98.1
5-05	125.0	0.51	1.40	511.89	310	100	97	0.71	3.57	106.6
Final	125.0		1.23360	78.77500	309.36000	97.30000		0.66619	78.77500	
25 points sampled		Sq.RIΔP								
QC-Check: Field Averages		0.6662	1.2336	78.7750	309.3600	97.3000				
		<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK				

062503 100637

WHEELABRATOR NORTH BROWARD  
POMPANO BEACH, FLORIDA

Client Reference No: 14200357  
CleanAir Project No: 9281-3

**LABORATORY DATA**

F

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 9281-2  
 Unit 1 FF Outlet

**USEPA Method 29  
 Mercury (Hg) Laboratory Parameters**

**Blank Analysis**

m <sub>1b-B</sub>	Fraction 1B Blank (µg)	<0.1000
m <sub>2b-B</sub>	Fraction 2B Blank (µg)	<0.3000
m <sub>3a-B</sub>	Fraction 3A Blank (µg)	<0.2000
m <sub>3b-B</sub>	Fraction 3B Blank (µg)	<0.4000
m <sub>3c-B</sub>	Fraction 3C Blank (µg)	<0.4000
m <sub>total-B</sub>	Total Blank Amount (µg)	<1.4000

**Run No.**

	1	2	3
Date (2003)	Jun 5	Jun 5	Jun 5
Start Time (approx.)	07:41	09:46	11:51
Stop Time (approx.)	09:46	11:51	13:56

**Sample Analysis**

m <sub>1b-S</sub>	Fraction 1B Sample (µg)	0.1358	0.2538	0.1539
m <sub>2b-S</sub>	Fraction 2B Sample (µg)	2.6270	2.5806	2.3890
m <sub>3a-S</sub>	Fraction 3A Sample (µg)	<0.2000	<0.2000	<0.2000
m <sub>3b-S</sub>	Fraction 3B Sample (µg)	<0.6000	<0.7000	<0.6000
m <sub>3c-S</sub>	Fraction 3C Sample (µg)	0.5137	0.6561	0.9079
m <sub>total-S</sub>	Total Sample Amount (µg)	3.2765	3.4905	3.4508

**Allowable Blank**

m <sub>T-B-allow</sub>	Total Allowable Blank (µg)	0.0000	0.0000	0.0000
------------------------	----------------------------	--------	--------	--------

**Sample Corrected for Blank**

m <sub>n</sub>	Total Sample Amount (µg)	3.2765	3.4905	3.4508
----------------	--------------------------	--------	--------	--------

**Sample Corrected for Blank - Prorated Fractions**

m <sub>n-1b</sub>	Fraction 1B Prorated (µg)	0.1358	0.2538	0.1539
m <sub>n-2b</sub>	Fraction 2B Prorated (µg)	2.6270	2.5806	2.3890
m <sub>n-3a</sub>	Fraction 3A Prorated (µg)	<0.2000	<0.2000	<0.2000
m <sub>n-3b</sub>	Fraction 3B Prorated (µg)	<0.6000	<0.7000	<0.6000
m <sub>n-3c</sub>	Fraction 3C Prorated (µg)	0.5137	0.6561	0.9079

062503 100637

Project 9281

**TOTAL ug CATCH**

Run Number		Average Total Catch ug	Front half	H2O2/HNO <sub>3</sub>	Empty Impinger	KMnO <sub>4</sub>	HCl
U1 FF Out R1	# 1	3.276	0.136	2.649	< 0.2	< 0.6	0.507
	# 2		0.136	2.605	< 0.2	< 0.6	0.520
U1 FF Out R2	# 1	3.490	0.251	2.612	< 0.2	< 0.7	0.672
	# 2		0.257	2.549	< 0.2	< 0.7	0.640
U1 FF Out R3	# 1	3.451	0.160	2.430	< 0.2	< 0.6	0.918
	# 2		0.148	2.348	< 0.2	< 0.6	0.898
Field Blank	# 1	< 0.6	< 0.1	< 0.3	< 0.2	< 0.6	< 0.4
	# 2		< 0.1	< 0.3	< 0.2	< 0.6	< 0.4
Reagent Blank	# 1	< 0.4	< 0.1	< 0.3	< 0.2	< 0.4	< 0.4
	# 2		< 0.1	< 0.3	< 0.2	< 0.4	< 0.4

# Clean Air Engineering, Inc.


500 West Wood Street  
Palatine, IL 60067

Project Number: 9281

Mercury

EPA Method 29 Analysis

Analytical Report  
1832




Element One, Inc.  
5022-C Wrightsville Av., Wilmington, NC 28403  
910-793-0128 FAX:910-792-6853 e1lab@hotmail.com

I have reviewed the following data for completeness,  
accuracy, adherence to method protocol, and compliance  
with quality assurance guidelines.


Quality assurance review by Bruce Hawks

*Bruce Hawks* 6/24/03






# SUMMARY OF RESULTS



## Summary of North Broward Mercury Analysis

Run Number		Average Total Catch, $\mu\text{g}$	Front half $\mu\text{g}$	$\text{H}_2\text{O}_2$ / $\text{HNO}_3$ $\mu\text{g}$	Empty Impinger $\mu\text{g}$	$\text{KMnO}_4$ $\mu\text{g}$	$\text{HCl}$ $\mu\text{g}$
U1 FF Out R1	# 1	3.28	0.14	2.65	< 0.2	< 0.6	0.51
	# 2		0.14	2.60	< 0.2	< 0.6	0.52
U1 FF Out R2	# 1	3.49	0.25	2.61	< 0.2	< 0.7	0.67
	# 2		0.26	2.55	< 0.2	< 0.7	0.64
U1 FF Out R3	# 1	3.45	0.16	2.43	< 0.2	< 0.6	0.92
	# 2		0.15	2.35	< 0.2	< 0.6	0.90
Field Blank	# 1	< 0.6	< 0.1	< 0.3	< 0.2	< 0.6	< 0.4
	# 2		< 0.1	< 0.3	< 0.2	< 0.6	< 0.4
Reagent Blank	# 1	< 0.4	< 0.1	< 0.3	< 0.2	< 0.4	< 0.4
	# 2		< 0.1	< 0.3	< 0.2	< 0.4	< 0.4

# ANALYTICAL NARRATIVE



## Element One Analytical Narrative

Client	Clean Air Engineering	Element One #:	1832
Client ID:	9281	Analyst:	IJJ, KJJ
Date Received	6/11/03	Method:	M29
Analytes	Hg	Dates Analyzed	6/16, 19, & 24/03

### Summary of Analysis

The samples were digested, prepared and analyzed according to Method 29 protocol. Samples were analyzed for mercury on a PerkinElmer FIMS-100 CVAA mercury analyzer.

### Detection Limits

The FIMS-100 CVAA instrument reporting limit for mercury was 0.001 µg/ml.

### Analysis QA/QC

Duplicate analyses relative percent difference (RPD) and spike sample recovery data are summarized on the following pages. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank values or spike recovery values. Nothing unusual was noticed with any of the samples or analyses.


### Mercury Duplicate Analysis RPD

Run Number	Front half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U1 FF Out R1	0.3%	1.7%	NA	NA	2.5%
U1 FF Out R2	2.5%	2.5%	NA	NA	4.8%
U1 FF Out R3	7.4%	3.5%	NA	NA	2.2%
Field Blank	NA	NA	NA	NA	NA
Reagent Blank	NA	NA	NA	NA	NA

### Mercury Spike Recoveries

Run Number		Front half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U1 FF Out R3	# 1	109%	101%	81%	90%	97%
	# 2	109%	98%	80%	89%	92%

# SAMPLE CUSTODY



## CHAIN OF CUSTODY FORM


CLIENT Wheelabrator North Broward  
 PLANT Same  
 PROJECT MANAGER Scott Brown

PROJECT NO. 9281  
 DEPT. 66

NO. OF CONTAINERS

ORIGINAL VOLUME

ANALYSIS REQUESTED



ADDITIONAL INFORMATION

CLEANAIR  
 LAB NO.    RUN NO.    TEST LOCATION    DATE    SAMPLE MATRIX

LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				ADDITIONAL INFORMATION
	1	Unit 1 FF Outlet		Filter	1	X					
	1			Front-Half 0.1N HNO3 Rinse	1	X					
	1			Imp. 1,2,3 + 0.1N HNO3 Rinse	1	X					
	1			Imp. 4 + 0.1N HNO3 Rinse	1	X					
	1			Imp. 5,6 KMnO4+H2O Rinse	1	X					
	1			Imp. 5,6 HCl Rinse	1	X					
	2			Filter	1	X					
	2			Front-Half 0.1N HNO3 Rinse	1	X					
	2			Imp. 1,2,3 + 0.1N HNO3 Rinse	1	X					
	2			Imp. 4 + 0.1N HNO3 Rinse	1	X					
	2			Imp. 5,6 KMnO4+H2O Rinse	1	X					
	2	V		Imp. 5,6 HCl Rinse	1	X					

Relinquished by: (Signature) <i>Ken Hallen</i>	Date / Time <i>6/16/03 13:00</i>	Received by: (Signature)	Date / Time	Relinquished by: (Signature)	Date / Time
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by <i>B. Hark</i>	Date / Time <i>6/16/03 0935</i>

Special Handling Instructions

Forwarding Lab: Element One  
Wilmington, NC 28403

PO Number: \_\_\_\_\_

This form was completed by:  
Scott Brown  
 Signature \_\_\_\_\_ Date \_\_\_\_\_

**CleanAir**  
ENGINEERING

LD9001A\_1-COC Palatine\_M29, Jul 2002  
Copyright © 2002 Clean Air Engineering Inc.

500 West Wood Street  
 Palatine, IL 60067


(800) 627-0033 ph  
 (847) 991-3385 fax  
 www.cleanair.com

### CHAIN OF CUSTODY FORM

CLIENT <u>Wheelabrator North Broward</u>	PROJECT NO. <u>9281</u>	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED				
PLANT <u>Same</u>	DEPT. <u>66</u>							
PROJECT MANAGER <u>Scott Brown</u>								

CLEANAIR LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	Hg, Cd, Cr, Pb	Archive	ADDITIONAL INFORMATION
	3	Unit 1 FF Outlet		Filter	1		X		
	3			Front-Half 0.1N HNO3 Rinse	1		X		
	3			Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X		
	3			Imp. 4 + 0.1N HNO3 Rinse	1		X		
	3			Imp. 5,6 KMnO4+H2O Rinse	1		X		
	3			Imp. 5,6 HCl Rinse	1		X		
	4			Filter	1			X	
	4			Front-Half 0.1N HNO3 Rinse	1			X	
	4			Imp. 1,2,3 + 0.1N HNO3 Rinse	1			X	
	4			Imp. 4 + 0.1N HNO3 Rinse	1			X	
	4			Imp. 5,6 KMnO4+H2O Rinse	1			X	
	4	V		Imp. 5,6 HCl Rinse	1			X	

Relinquished by: (Signature) <i>Kenneth Hallen</i>	Date / Time <i>6/6/2003 13:00</i>	Received by: (Signature)	Date / Time	Relinquished by: (Signature)	Date / Time
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by: <i>for [Signature]</i>	Date / Time <i>6/11/03 0935</i>

Special Handling Instructions	This form was completed by: <u>Scott Brown</u>	 <p style="font-size: small;">LD8001A, 1-COC Palatine, IL29, Jul 2002 Copyright © 2002 Clean Air Engineering Inc.</p>	500 West Wood Street Palatine, IL 60067 (800) 627-0033 ph (847) 991-3385 fax www.cleanair.com
Forwarding Lab: <u>Element One</u> <u>Wilmington, NC 28403</u>	Signature _____ Date _____		PO Number: _____



## CHAIN OF CUSTODY FORM

CLIENT Wheelabrator North Broward  
 PLANT Same  
 PROJECT MANAGER Scott Brown

PROJECT NO. 9281  
 DEPT. 68

NO. OF CONTAINERS

ORIGINAL VOLUME

ANALYSIS REQUESTED

Hg, Pb, Cd, Cr, Ni	Archive			

ADDITIONAL INFORMATION

CLEANAIR LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED	ADDITIONAL INFORMATION
	5	Unit 1 FF Outlet		Filter	1		X	
	5			Front-Half 0.1N HNO3 Rinse	1		X	
	5			Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X	
	5			Imp. 4 + 0.1N HNO3 Rinse	1		X	
	5			Imp. 5,6 KMnO4+H2O Rinse	1		X	
	5			Imp. 5,6 HCl Rinse	1		X	
	6			Filter	1		X	
	6			Front-Half 0.1N HNO3 Rinse	1		X	
	6			Imp. 1,2,3 + 0.1N HNO3 Rinse	1		X	
	6			Imp. 4 + 0.1N HNO3 Rinse	1		X	
	6			Imp. 5,6 KMnO4+H2O Rinse	1		X	
	6	V		Imp. 5,6 HCl Rinse	1		X	

Relinquished by: (Signature) <i>Kemp Hallen</i>	Date / Time 6/16/2003	Received by: (Signature)	Date / Time 13:00	Relinquished by: (Signature)	Date / Time
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by: <i>B. Hark</i>	Date / Time 6/16/03 0935

Special Handling Instructions

Forwarding Lab: Element One  
Wilmington, NC 28403

PO Number:

This form was completed by:  
Scott Brown  
 Signature \_\_\_\_\_ Date \_\_\_\_\_



**CleanAir**  
ENGINEERING

LDS001A\_1-COC Palatine\_M29\_Aul 2002  
Copyright © 2002 Clean Air Engineering Inc.

500 West Wood Street  
 Palatine, IL 60067  
 (800) 627-0033 ph  
 (847) 991-3385 fax  
 www.cleanair.com

### CHAIN OF CUSTODY FORM

CLIENT Wheelabrator North Broward  
 PLANT Pompano Beach, FL  
 PROJECT MANAGER Scott Brown

PROJECT NO. 9281-2  
 DEPT. 66

NO. OF CONTAINERS

ORIGINAL VOLUME

ANALYSIS REQUESTED

Hg			
----	--	--	--

ADDITIONAL INFORMATION

**CLEANAIR**

LAB NO.	RUN NO.	TEST LOCATION	DATE	SAMPLE MATRIX	NO. OF CONTAINERS	ORIGINAL VOLUME	ANALYSIS REQUESTED	ADDITIONAL INFORMATION
	NA	Reagent Blank	6/5	3 Quartz Filters	1	NA	X	
	NA	Reagent Blank	6/5	0.1N HNO <sub>3</sub>	1	300	X	
	NA	Reagent Blank	6/5	DI H <sub>2</sub> O	1	100	X	
	NA	Reagent Blank	6/5	5% HNO <sub>3</sub> / 10% H <sub>2</sub> O <sub>2</sub>	1	<del>300</del> 250	X	
	NA	Reagent Blank	6/5	4% KMnO <sub>4</sub> / 10% H <sub>2</sub> SO <sub>4</sub>	1	100	X	
	NA	Reagent Blank	6/5	8 N HCl / DI H <sub>2</sub> O	1	225	X	
	Field Blank	Unit 1 FF Outlet		Filter	1		X	
	Field Blank			Imp 1,2,3 + 0.1N HNO <sub>3</sub> Rinse	1		X	
	Field Blank			Imp 4 + 0.1N HNO <sub>3</sub> Rinse	1		X	
	Field Blank			Imp 5,6 KMnO <sub>4</sub> + H <sub>2</sub> O Rinse	1		X	
	Field Blank			Imp 5,6 HCl Rinse	1		X	
	Field Blank			Front Half 0.1N HNO <sub>3</sub> Rinse	1		X	


Relinquished by: (Signature) <i>Kevin O'Halloran</i>	Date / Time 6/6/2003 13:00	Received by: (Signature)	Date / Time	Relinquished by: (Signature)	Date / Time
Courier:	Date / Time	Relinquished by: (Signature)	Date / Time	Received for Analysis by: <i>Scott Brown</i>	Date / Time 6/11/03 0935

Special Handling Instructions: \_\_\_\_\_

Forwarding Lab: Element One  
Wilmington, NC 28403

PO Number: \_\_\_\_\_

This form was completed by:  
 Kevin O'Halloran  
 Signature: *Kevin O'Halloran* Date: 6/6/2003




**CleanAir**  
ENGINEERING

LDS001A\_3-COC Palatine\_2002B\_July 2002  
Copyright © 2002 Clean Air Engineering Inc.

e1832  
 500 West Wood Street  
 Palatine, IL 60067  
 (800) 627-0033 ph  
 (847) 991-3385 fax  
 www.cleanair.com

# ANALYTICAL DATA



Client ID/PO#: 9281		Date Received: 6/11/03	Page: 1 of 1
Customer: Clean Air		Results Requested: 6/25/03	Time Rec:
Address:		Contact: Scott Brown	Rec by: BGH
		Email:	Via:
		Phone:	Fax:
HNO <sub>3</sub> Lot: 1102100	HF Lot: 5101122	HCl Lot: 4102080	
Volume Marked <input checked="" type="radio"/> Y / <input type="radio"/> N	Volume Loss Y / <input checked="" type="radio"/> N / ?	pH < 2.0 <input checked="" type="radio"/> Y / <input type="radio"/> N	Ref. Method: 29

	Sample Identification		Sample Identification
1	North Broward Run 1	7	North Broward Run 4
2	North Broward Run 2	8	North Broward Run 5
3	North Broward Run 3	9	North Broward Run 6
4	North Broward Run 3 Spike		
5	Field Blank		
6	Reagent Blank		

Elements to Analyze: Hg – Only analyze sample 1-6; Archive Sample 7-9

SAMPLE	Front Half		Back Half			HNO <sub>3</sub> (A)		KMnO <sub>4</sub> (B)		HCl (C)	
	BV, ml	FV, ml	BV, ml	Used	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml
1	104ml	100ml	800ml	—	—	104ml	200ml	580ml	600ml	230ml	400ml
2	92ml		820ml	—	—	102ml		610ml	700ml	215ml	
3/4	100ml		830ml	—	—	104ml		570ml	600ml	235ml	
5	110ml		300ml	—	—	101ml		585ml		225ml	
6	100ml	↓	290ml	—	—	200ml	↓	100ml 200ml 38ml 38ml Calculate as 400ml		225ml	↓
7											
8											
9											

Comments:

## Mercury Perkin-Elmer AAWinLab

ID #	Sample_ID	Sam_Date	Sam_Time	Mean_Sig	Mean_ST	Mean_SA	Units	Wt	Dilu
1	Calib Blank	6/17/2003	12:48:25	0.000534			mg/L		
2	STD1=.100ug	6/17/2003	12:49:26	0.014085			mg/L		
3	STD2=.200ug	6/17/2003	12:50:28	0.027796			mg/L		
4	STD3=.300ug	6/17/2003	12:51:34	0.040923			mg/L		
5	STD4=.400ug	6/17/2003	12:52:38	0.056473			mg/L		
6	STD5=.500ug	6/17/2003	12:53:43	0.069552			mg/L		
7	Reagent Blank	6/17/2003	12:55:15	-0.000048	-0.00034	-0.00034	mg/L		
8	0.010 = DL	6/17/2003	12:56:23	0.001281	0.00917	0.00917	mg/L		
9	0.200 = QC STD 2	6/17/2003	12:57:28	0.027683	0.198509	0.198509	mg/L		
10	0.200 = QC STD 3	6/17/2003	12:58:32	0.027609	0.197977	0.197977	mg/L		
11	0.020 = DL	6/17/2003	12:59:39	0.002734	0.019576	0.019576	mg/L		
12	REAGENT BLANK	6/17/2003	13:00:43	-9.03E-05	-0.00065	-0.00065	mg/L		
13	1832-B-001	6/17/2003	13:28:02	0.000209	0.001495	0.089703	mg/L	10	600
14	1832-B-002	6/17/2003	13:29:34	0.00013	0.000934	0.065376	mg/L	10	700
15	1832-B-003	6/17/2003	13:31:09	0.000136	0.000976	0.058538	mg/L	10	600
16	1832-B-004-SPK	6/17/2003	13:32:43	0.024964	0.17898	10.73879	mg/L	10	600
17	1832-B-005	6/17/2003	13:34:16	0.000176	0.001258	0.075471	mg/L	10	600
18	1832-B-006	6/17/2003	13:35:49	0.000162	0.00116	0.046404	mg/L	10	400
19	0.010 = DL	6/17/2003	13:36:54	0.001437	0.010287	0.010287	mg/L	10	400
20	0.200 = QC STD 2	6/17/2003	13:37:59	0.027912	0.200151	0.200151	mg/L	10	400
21	REAGENT BLANK	6/17/2003	13:39:05	0.000105	0.00075	0.00075	mg/L	10	400
22	1832-A-001	6/17/2003	13:46:46	1.82E-05	0.00013	0.002599	mg/L	10	200
23	1832-A-002	6/17/2003	13:48:18	0.000175	0.001249	0.024988	mg/L	10	200
24	1832-A-003	6/17/2003	13:49:47	6.72E-05	0.000481	0.009626	mg/L	10	200
25	1832-A-004-SPK	6/17/2003	13:51:16	0.022524	0.161458	3.229151	mg/L	10	200
26	1832-A-005	6/17/2003	13:52:47	3.12E-05	0.000223	0.004464	mg/L	10	200
27	1832-A-006	6/17/2003	13:54:17	0.000141	0.001011	0.020222	mg/L	10	200
28	0.010 = DL	6/17/2003	13:55:21	0.001309	0.00937	0.00937	mg/L	10	200
29	0.200 = QC STD 2	6/17/2003	13:56:29	0.028285	0.202832	0.202832	mg/L	10	200
30	REAGENT BLANK	6/17/2003	13:57:31	0.000113	0.000808	0.000808	mg/L	10	200
31	1832-BH-001	6/17/2003	14:26:45	0.004586	0.032838	2.627031	mg/L	10	800
32	1832-BH-002	6/17/2003	14:28:16	0.004396	0.031471	2.58063	mg/L	10	820
33	1832-BH-003	6/17/2003	14:29:48	0.00402	0.028784	2.389036	mg/L	10	830
34	1832-BH-004-SPK	6/17/2003	14:31:23	0.031698	0.227356	18.87056	mg/L	10	830
35	0.010 = DL	6/17/2003	14:32:28	0.001353	0.009684	0.009684	mg/L	10	830
36	0.200 = QC STD 2	6/17/2003	14:33:33	0.028058	0.201196	0.201196	mg/L	10	830
37	REAGENT BLANK	6/17/2003	14:34:35	2.65E-05	0.00019	0.00019	mg/L	10	830
38	1832-BH-005	6/17/2003	14:36:07	0.000478	0.003418	0.102537	mg/L	10	300
39	1832-BH-006	6/17/2003	14:37:41	0.0004	0.002863	0.083031	mg/L	10	290
40	0.010 = DL	6/17/2003	14:38:49	0.00143	0.010233	0.010233	mg/L	10	290
41	0.200 = QC STD 3	6/17/2003	14:39:54	0.028272	0.202736	0.202736	mg/L	10	290
42	0.020 = DL	6/17/2003	14:40:59	0.002937	0.021025	0.021025	mg/L	10	290
43	REAGENT BLANK	6/17/2003	14:42:02	-9.95E-05	-0.00071	-0.00071	mg/L	10	290
44	Calib Blank	6/19/2003	9:05:31	0.000443			mg/L		
45	STD1=.100ug	6/19/2003	9:06:32	0.014004			mg/L		
46	STD2=.200ug	6/19/2003	9:07:34	0.027399			mg/L		

ID #	Sig 1	Std_U 1	Smp_U 1	Sig 2	Std_U 2	Smp_U 2
1	0.0005335					
	0.01408514					
	0.02779602					
4	0.04092301					
5	0.05647348					
6	0.06955246					
7	-0.0000753	-0.0005396	-0.0005396	-0.0000206	-0.0001477	-0.0001477
8	0.00128101	0.00916968	0.00916968			
9	0.02768342	0.19850877	0.19850877			
10	0.02760936	0.19797674	0.19797674			
11	0.00273449	0.01957578	0.01957578			
12	-0.0000903	-0.0006465	-0.0006465			
13	0.00020787	0.00148786	0.08927194	0.00020987	0.0015022	0.0901337
14	0.0001579	0.00113025	0.07911777	0.00010305	0.0007376	0.0516334
15	0.00018375	0.00131527	0.07891631	0.00008885	0.000636	0.03816
16	0.02498496	0.1791269	10.7476142	0.024944	0.1788328	10.729966
17	0.00013001	0.00093059	0.05583587	0.00022145	0.0015851	0.0951061
18	0.00013435	0.00096168	0.03846722	0.0001898	0.0013585	0.0543407
19	0.00143714	0.01028739	0.01028739			
20	0.02791198	0.20015072	0.20015072			
21	0.00010471	0.0007495	0.0007495			
	0.0000747	0.00053468	0.01069379	-0.0000383	-0.0002748	-0.0054967
23	0.0002082	0.00149023	0.02980465	0.0001409	0.0010085	0.0201704
24	0.00007223	0.000517	0.01034	0.00006226	0.0004456	0.0089126
25	0.02269532	0.16268684	3.25373695	0.02235283	0.1602282	3.204564
26	-0.0000285	-0.0002042	-0.0040849	0.00009089	0.0006506	0.0130122
27	0.00016653	0.00119197	0.02383954	0.00011598	0.0008302	0.0166037
28	0.00130898	0.00936989	0.00936989			
29	0.02828522	0.20283219	0.20283219			
30	0.00011281	0.00080751	0.00080751			
31	0.00462553	0.03311752	2.64940202	0.00454744	0.0325583	2.6046606
32	0.00444957	0.03185732	2.61230058	0.00434171	0.0310849	2.5489593
33	0.00408975	0.02928041	2.43027476	0.00395099	0.0282867	2.3477979
34	0.0320886	0.23016415	19.1036246	0.03130727	0.2245482	18.6375
35	0.00135286	0.00968403	0.00968403			
36	0.02805752	0.20119628	0.20119628			
37	0.00002653	0.00018992	0.00018992			
38	0.00049456	0.00353998	0.10619957	0.00046045	0.0032958	0.0988745
39	0.00038044	0.00272311	0.07897025	0.00041956	0.0030031	0.0870911
40	0.00142951	0.01023272	0.01023272			
41	0.02827185	0.20273608	0.20273608			
	0.00293686	0.02102474	0.02102474			
43	-0.0000995	-0.0007122	-0.0007122			
44	0.00044291					
45	0.01400434					
46	0.02739905					

## Mercury Perkin-Elmer AAWinLab

ID #	Sample_ID	Sam_Date	Sam_Time	Mean_Sig	Mean_ST	Mean_SA	Units	Wt	Dilu
47	STD3=.300ug	6/19/2003	9:08:37	0.040599			mg/L		
48	STD4=.400ug	6/19/2003	9:09:41	0.055286			mg/L		
49	STD5=.500ug	6/19/2003	9:10:49	0.071994			mg/L		
50	Reagent Blank	6/19/2003	9:12:21	1.99E-05	0.000146	0.000146	mg/L		
51	0.010 = DL	6/19/2003	9:13:25	0.001352	0.009919	0.009919	mg/L		
52	0.200 = QC STD 2	6/19/2003	9:14:30	0.027658	0.200351	0.200351	mg/L		
53	0.200 = QC STD 3	6/19/2003	9:15:34	0.02805	0.203149	0.203149	mg/L		
54	0.020 = DL	6/19/2003	9:16:40	0.002796	0.020491	0.020491	mg/L		
55	REAGENT BLANK	6/19/2003	9:17:47	9.9E-07	7.31E-06	7.31E-06	mg/L		
56	1832-FH-BLK	6/19/2003	10:08:49	-6.2E-06	-4.6E-05	-0.00046	mg/L	10	100
57	1832-FH-BLK-SPK	6/19/2003	10:10:20	0.027946	0.202407	5.060171	mg/L	4	100
58	0.010 = DL	6/19/2003	10:11:24	0.001413	0.010365	0.010365	mg/L	4	100
59	0.200 = QC STD 2	6/19/2003	10:12:29	0.028223	0.20439	0.20439	mg/L	4	100
60	REAGENT BLANK	6/19/2003	10:13:31	1.17E-05	8.6E-05	8.6E-05	mg/L	4	100
61	1832-FH-001	6/19/2003	10:22:47	0.001852	0.01358	0.135796	mg/L	10	100
62	1832-FH-002	6/19/2003	10:24:21	0.003464	0.025376	0.253763	mg/L	10	100
63	1832-FH-003	6/19/2003	10:25:59	0.002099	0.01539	0.153903	mg/L	10	100
64	1832-FH-004-SPK	6/19/2003	10:27:34	0.03226	0.233183	2.33183	mg/L	10	100
65	1832-FH-005	6/19/2003	10:29:05	0.000178	0.001307	0.013069	mg/L	10	100
66	0.010 = DL	6/19/2003	10:30:07	0.001474	0.01081	0.01081	mg/L	10	100
67	0.200 = QC STD 2	6/19/2003	10:31:12	0.027989	0.202719	0.202719	mg/L	10	100
68	REAGENT BLANK	6/19/2003	10:32:15	6.27E-05	0.00046	0.00046	mg/L	10	100
69	1832-FH-006	6/19/2003	10:33:47	6.06E-05	0.000445	0.004446	mg/L	10	100
70	0.010 = DL	6/19/2003	10:48:30	0.001446	0.010605	0.010605	mg/L	10	600
71	0.200 = QC STD 2	6/19/2003	10:49:38	0.028028	0.202999	0.202999	mg/L	10	600
72	REAGENT BLANK	6/19/2003	10:50:40	0.000173	0.001269	0.001269	mg/L	10	600
73	1832-C-001	6/19/2003	11:12:02	0.001751	0.012842	0.513667	mg/L	10	400
74	1832-C-002	6/19/2003	11:13:36	0.002237	0.016401	0.656059	mg/L	10	400
75	1832-C-003	6/19/2003	11:15:07	0.003209	0.023513	0.940531	mg/L	10	400
76	1832-C-004-SPK	6/19/2003	11:16:39	0.002967	0.021744	0.869755	mg/L	10	400
77	1832-C-005	6/19/2003	11:18:12	0.000653	0.00479	0.191588	mg/L	10	400
78	1832-C-006	6/19/2003	11:19:45	0.000511	0.003747	0.149883	mg/L	10	400
79	0.010 = DL	6/19/2003	11:25:29	0.001396	0.010241	0.010241	mg/L	2	1
80	0.200 = QC STD 2	6/19/2003	11:26:33	0.028962	0.209668	0.209668	mg/L	2	1
81	Reagent Blank	6/19/2003	11:29:12	8.88E-05	0.000652	0.000652	mg/L	2	1
82	Calib Blank	6/24/2003	14:47:28	0.000988			mg/L		
83	STD1=.100ug	6/24/2003	14:48:28	0.015011			mg/L		
84	STD2=.200ug	6/24/2003	14:49:30	0.030386			mg/L		
85	STD3=.300ug	6/24/2003	14:50:34	0.047784			mg/L		
86	STD4=.400ug	6/24/2003	14:51:38	0.062101			mg/L		
87	STD5=.500ug	6/24/2003	14:52:46	0.076884			mg/L		
88	Reagent Blank	6/24/2003	14:54:18	-2.84E-05	-0.00019	-0.00019	mg/L		
89	0.010 = DL	6/24/2003	14:55:21	0.001437	0.009515	0.009515	mg/L		
90	0.200 = QC STD 2	6/24/2003	14:56:26	0.029446	0.192504	0.192504	mg/L		
91	0.200 = QC STD 3	6/24/2003	14:57:31	0.030379	0.198523	0.198523	mg/L		
92	0.020 = DL	6/24/2003	14:58:37	0.002926	0.019359	0.019359	mg/L		

ID #	Sig 1	Std_U 1	Smp_U 1	Sig 2	Std_U 2	Smp_U 2
47	0.04059904					
48	0.05528628					
49	0.07199438					
50	-0.0000562	-0.0004125	-0.0004125	0.00009596	0.0007042	0.0007042
51	0.00135247	0.00991903	0.00991903			
52	0.02765815	0.200351	0.200351			
53	0.02804954	0.20314895	0.20314895			
54	0.00279584	0.02049078	0.02049078			
55	0.00000099	0.00000731	0.00000731			
56	-0.0000195	-0.0001437	-0.0014377	0.00000714	5.242E-05	0.0005243
57	0.02821795	0.20435264	5.10881606	0.02767355	0.2004611	5.0115267
58	0.00141334	0.01036521	0.01036521			
59	0.0282232	0.20439013	0.20439013			
60	0.00001172	0.00008602	0.00008602			
61	0.00185489	0.01360059	0.13600593	0.00184915	0.0135585	0.1355854
62	0.00342039	0.02506069	0.25060692	0.0035067	0.025692	0.2569199
63	0.00217708	0.01596049	0.15960495	0.00202137	0.0148201	0.148201
64	0.03227267	0.23327465	2.33274655	0.03224693	0.2330914	2.3309136
65	0.00021606	0.00158548	0.01585487	0.00014013	0.0010283	0.0102832
66	0.00147403	0.01080998	0.01080998			
67	0.02798942	0.20271929	0.20271929			
68	0.00006274	0.00046042	0.00046042			
69	0.00004434	0.00032541	0.00325414	0.00007683	0.0005638	0.0056383
70	0.00144604	0.01060484	0.01060484			
71	0.02802849	0.20299853	0.20299853			
72	0.00017291	0.00126887	0.00126887			
73	0.00172959	0.01268261	0.50730472	0.00177301	0.0130007	0.5200289
74	0.00229133	0.01679723	0.67188948	0.00218325	0.0160057	0.6402286
75	0.00322883	0.02365929	0.94637175	0.00318891	0.0233672	0.9346898
76	0.0029797	0.02183634	0.8734539	0.00295443	0.0216514	0.8660558
77	0.00064089	0.00470187	0.18807502	0.00066483	0.0048775	0.1951011
78	0.00051825	0.00380241	0.15209662	0.00050317	0.0036918	0.1476703
79	0.00139641	0.01024111	0.01024111			
80	0.02896195	0.20966772	0.20966772			
81	0.00009548	0.0007007	0.0007007	0.00008216	0.000603	0.000603
82	0.0009882					
83	0.01501071					
84	0.03038553					
85	0.0477837					
86	0.06210067					
87	0.07688407					
88	-0.0000451	-0.0002991	-0.0002991	-0.0000116	-0.0000774	-0.0000774
89	0.00143737	0.00951503	0.00951503			
90	0.02944586	0.19250358	0.19250358			
91	0.03037921	0.19852329	0.19852329			
92	0.00292638	0.01935901	0.01935901			



Mercury Perkin-Elmer AAWinLab

ID #	Sample_ID	Sam_Date	Sam_Time	Mean_Sig	Mean_ST	Mean_SA	Units	Wt	Dilu
93	REAGENT BLANK	6/24/2003	14:59:44	0.000143	0.00095	0.00095	mg/L		
94	1832-C-003	6/24/2003	15:04:14	0.003432	0.022698	0.907907	mg/L	10	400
95	1832-C-004-SPK	6/24/2003	15:05:46	0.03243	0.211733	8.469327	mg/L	10	400
96	0.010 = DL	6/24/2003	15:16:13	0.001604	0.01062	0.01062	mg/L	10	500
97	0.200 = QC STD 2	6/24/2003	15:17:18	0.028714	0.187778	0.187778	mg/L	10	500
98	REAGENT BLANK	6/24/2003	15:18:20	5.91E-05	0.000391	0.000391	mg/L	10	500

ID #	Sig 1	Std_U 1	Smp_U 1	Sig 2	Std_U 2	Smp_U 2
93	0.00014338	0.00094972	0.00094972			
95	0.00346886	0.02294213	0.91768542	0.00339483	0.0224532	0.8981291
95	0.03310248	0.21605862	8.64234489	0.03175816	0.2074077	8.2963084
96	0.00160447	0.0106204	0.0106204			
97	0.02871362	0.18777752	0.18777752			
98	0.00005909	0.0003914	0.0003914			

WHEELABRATOR NORTH BROWARD  
POMPANO BEACH, FLORIDA

Client Reference No: 14200357  
CleanAir Project No: 9281-3

**OPERATING DATA**

**G**

General Average Report

Reporting Period: 06/05/2003 to 06/05/2003

Site Name: UNIT1

Time of Report: 06/09/03 08:32

Data Averaging Type: 15m

Rolling Average Interval: 1

Date	Time	STMRPT_1 (KLB/HR )
06/05/03	00:00	170.7
	00:15	175.1
	00:30	176.7
	00:45	176.7
	01:00	178.3
	01:15	182.7
	01:30	181.6
	01:45	170.5
	02:00	176.2
	02:15	181.7
	02:30	185.7
	02:45	187.3
	03:00	183.6
	03:15	184.0
	03:30	184.7
	03:45	185.7
	04:00	185.2
	04:15	185.8
	04:30	185.1
	04:45	184.2
	05:00	181.4
	05:15	178.6
	05:30	148.8
	05:45	165.9
	06:00	181.2
	06:15	186.6
	06:30	187.4
	06:45	185.8
	07:00	183.5
	07:15	180.5
	07:30	184.6
	07:45	185.9
	08:00	184.4
	08:15	184.4
	08:30	186.4
	08:45	182.8
	09:00	183.2
	09:15	184.2
	09:30	184.4
	09:45	183.3
	10:00	183.2
	10:15	184.6
	10:30	185.6
	10:45	184.7
	11:00	181.6
	11:15	182.9
	11:30	184.1
	11:45	182.8
	12:00	184.7
	12:15	184.3

Run 1

Run 2

## General Average Report

Reporting Period: 06/05/2003 to 06/05/2003

Site Name: UNIT1

Time of Report: 06/09/03 08:32

Data Averaging Type: 15m

Rolling Average Interval: 1

Date	Time	STMRT_1 (KLB/HR )
06/05/03	12:30	184.6
	12:45	183.6
	13:00	184.3
	13:15	185.4
	13:30	184.3
	13:45	184.0
	14:00	182.7
	14:15	185.1
	14:30	186.1
	14:45	185.4
	15:00	183.4
	15:15	183.2
	15:30	181.7
	15:45	184.7
	16:00	185.0
	16:15	183.1
	16:30	183.0
	16:45	174.6
	17:00	172.3
	17:15	182.2
	17:30	183.9
	17:45	183.9
	18:00	182.8
	18:15	184.2
	18:30	183.5
	18:45	178.9
	19:00	181.0
	19:15	182.2
	19:30	184.4
	19:45	183.2
	20:00	184.7
	20:15	185.3
	20:30	181.1
	20:45	159.0
	21:00	164.1
	21:15	162.1
	21:30	165.2
	21:45	173.3
	22:00	177.1
	22:15	178.3
	22:30	182.0
	22:45	181.4
	23:00	181.9
	23:15	184.2
	23:30	184.5
	23:45	185.4

Run 3

---

Average =	181.2
Geometric Avg. =	181.1
Maximum =	187.4
Minimum =	148.8
Possible Values =	96
Included Values =	96
Total =	17399.8

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing