



**Wheelabrator North Broward**

A Waste Management Company

2600 Wiles Road  
Pompano Beach, FL 33073  
(954) 971-8701 Tel  
(954) 971-8703 Fax

**RECEIVED**

**JAN 24 2014**

**DIVISION OF AIR  
RESOURCE MANAGEMENT**

January 17, 2014

CERTIFIED MAIL #70051160000234573426

Mr. Joseph Lurix  
Air Program Administrator  
Florida Department of Environmental Protection  
Southeast District  
400 North Congress Ave., Suite 200  
West Palm Beach, FL 33401

Re: Wheelabrator North Broward  
F.A.C. 62-296.416 Quarterly Mercury Stack Testing  
Fourth Quarter of 2013, Report Submittal

Dear Mr. Lurix:

As required by F.A.C. 62-296.416, please find enclosed the 2013 fourth quarter report on mercury stack testing which was conducted on Unit #1.

I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this submittal. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements and information in this document are true, accurate and complete.

If there are any questions, please contact this office at (954) 971-8701.

Sincerely,

Jim Epsilantis  
Plant Manager

cc: USEPA, Region IV, Pesticides and Toxics Management Division, Air & EPCRA Enforcement  
Branch, Air Enforcement Section CERTIFIED MAIL #70051160000234573396  
FDEP, Tallahassee, Bureau of Air Regulation, New Source Review Section,  
CERTIFIED MAIL #70051160000234573402  
Broward County Department of Planning and Environmental Protection, Air Quality Division  
CERTIFIED MAIL #70051160000234573419  
Chuck Faller (with)  
Rob French – MPI - (with)  
Ram Tewari – BCWRS (without)





Wheelabrator North Broward, Inc.  
2600 Wiles Road  
Pompano Beach, FL 33073

---

**REPORT ON MERCURY TESTING**

Performed for:  
**WHEELABRATOR NORTH BROWARD, INC.**  
**UNIT 1 FF OUTLET**  
**POMPANO BEACH, FL**

Client Reference No: Service Agreement  
CleanAir Project No: 12218-7  
Revision 0: January 15, 2014

---

To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the actual emissions during the test program. Clean Air Engineering operates in conformance with the requirements of ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies.

Submitted by,

A handwritten signature in black ink, appearing to read "Scott Brown".

\_\_\_\_\_  
Scott Brown  
Senior Project Manager  
sbrown@cleanair.com  
(800) 627-0033 ext. 4544

Reviewed by,

A handwritten signature in black ink, appearing to read "Mark Roach".

\_\_\_\_\_  
Mark Roach, P.E.  
Engineering Group Technical Leader  
mroach@cleanair.com  
(800) 627-0033 ext. 4599

**REVISION HISTORY**

**REPORT ON MERCURY TESTING**

***DRAFT REPORT REVISION HISTORY***

<b>Revision:</b>	<b>Date</b>	<b>Pages</b>	<b>Comments</b>
D0a	01/10/14	All	Draft version of original document.

***FINAL REPORT REVISION HISTORY***

<b>Revision:</b>	<b>Date</b>	<b>Pages</b>	<b>Comments</b>
0	01/15/14	All	Final version of original document.

## CONTENTS

iii

<b>1</b>	<b>PROJECT OVERVIEW</b> .....	<b>1-1</b>
	INTRODUCTION .....	1-1
	Key Project Participants .....	1-1
	Test Program Parameters .....	1-1
	TEST PROGRAM SYNOPSIS.....	1-2
	Test Schedule.....	1-2
	Table 1-1: Schedule of Activities .....	1-2
	Results Summary .....	1-2
	Table 1-2: Summary of Test Results.....	1-2
<b>2</b>	<b>RESULTS</b> .....	<b>2-1</b>
	Table 2-1: Unit 1 FF Outlet – Mercury .....	2-1
	Table 2-2: Quality Assurance and Quality Control.....	2-2
<b>3</b>	<b>DESCRIPTION OF INSTALLATION</b> .....	<b>3-1</b>
	PROCESS DESCRIPTION .....	3-1
	Figure 3-1: General Process Schematic.....	3-1
	Figure 3-2: Process Schematic .....	3-2
	DESCRIPTION OF SAMPLING LOCATION .....	3-3
	Table 3-1: Sampling Points .....	3-3
	Figure 3-3: Unit 1 FF Outlet Sampling Point Determination (EPA Method 1).....	3-3
<b>4</b>	<b>METHODOLOGY</b> .....	<b>4-1</b>
	Table 4-1: Summary of Sampling Procedures.....	4-1
<b>5</b>	<b>APPENDIX</b> .....	<b>5-1</b>
	TEST METHOD SPECIFICATIONS .....	A
	SAMPLE CALCULATIONS .....	B
	PARAMETERS .....	C
	QA/QC DATA.....	D
	FIELD DATA .....	E
	FIELD DATA PRINTOUTS .....	F
	LABORATORY DATA.....	G
	PLANT DATA.....	H

**PROJECT OVERVIEW**

1-1

**INTRODUCTION**

Wheelabrator North Broward, Inc. operates a refuse-to-energy facility, located in Pompano Beach, Florida. The facility's emission levels are regulated by the Florida Department of Environmental Protection (DEP). Wheelabrator North Broward contracted Clean Air Engineering (CleanAir) to perform a compliance test program at its municipal waste combustor (MWC) facility in Pompano Beach, Florida. Testing was conducted in accordance with 40 CFR 60, Subpart Cb, and applicable sections of PSD-FL-112(B) and PA86-22. The sampling was conducted at the Unit 1 Fabric Filter (FF) Outlet on December 10 and 11, 2013.

All testing was conducted in accordance with the regulations set-forth by the United States Environmental Protection Agency (US EPA) and the DEP.

**Key Project Participants**

Individuals responsible for coordinating and conducting the test program were:

- C. Faller – Wheelabrator North Broward, Inc.
- D. Dreska – CleanAir

**Test Program Parameters**

The testing included the following emissions measurements:

- flue gas composition (e.g., O<sub>2</sub>, CO<sub>2</sub>, H<sub>2</sub>O)
- flue gas flow rate
- flue gas temperature
- mercury (Hg)

Chuck Faller of Wheelabrator North Broward provided all the process (operating) data. This data is presented in its entirety in Appendix H.

The CleanAir test crew consisted of Paul Bihun, and all equipment utilized for testing was manufactured by CleanAir.

**PROJECT OVERVIEW**

**TEST PROGRAM SYNOPSIS**

**Test Schedule**

The on-site schedule followed during the test program is outlined in Table 1-1.

**Table 1-1:  
Schedule of Activities**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	Unit 1 FF Outlet	USEPA Method 29	Mercury	12/10/13	12:24	14:34
2	Unit 1 FF Outlet	USEPA Method 29	Mercury	12/11/13	08:09	10:21
3	Unit 1 FF Outlet	USEPA Method 29	Mercury	12/11/13	10:42	12:54
4	Unit 1 FF Outlet	USEPA Method 29	Mercury	12/11/13	13:14	15:25

**Results Summary**

Table 1-2 summarizes the results of the test program. A more detailed presentation of the test conditions and results of analysis are shown in Tables 2-1 and 2-2 on pages 2-1 and 2-2.

**Table 1-2:  
Summary of Test Results**

Source Constituent	Sampling Method	Average Emission	Permit Limit <sup>1</sup>
Unit 1 FF Outlet Mercury (µg/dscm @7% O <sub>2</sub> )	EPA M29	6.6	50

<sup>1</sup> Limit obtained from the facility's Title V Permit No. 0112120-010-AV and Subpart Cb as of April 28, 2009.

During the compliance testing, Unit 1 was operated within 10% of the 186,000 lb/hr maximum steam flow rating. The Unit 3 boiler and air pollution control equipment are in a well-maintained operating condition. Normal operating parameters for the fabric filters are a pressure drop of 2 to 7 inches of water and scrubber dilution water flow varies from 0 to 40 gallons per minute (gpm). The equipment operated within these ranges during compliance testing. Table 2-1 on the following page presents the boiler's steam output for every test run.

Four Method 29 test runs for mercury were performed at the Unit 1 FF Outlet, and all four runs were averaged to determine compliance with the permit limit. An audit sample was shipped and analyzed, along with the test run samples. The analytical results of the audit sample passed all requirements and are presented in Appendix G.

*End of Section 1 – Project Overview*

**RESULTS**

2-1

**Table 2-1:  
Unit 1 FF Outlet – Mercury**

Run No.	1	2	3	4	Average
Date (2013)	Dec 10	Dec 11	Dec 11	Dec 11	
Start Time (approx.)	12:24	08:09	10:42	13:14	
Stop Time (approx.)	14:34	10:21	12:54	15:25	
<b>Process Conditions</b>					
R <sub>p</sub> Steam Production Rate - (klbs/hour)	179.5	180.1	180.2	180.4	<b>180.0</b>
P <sub>1</sub> Fabric Filter Inlet Temperature - (°F)	321	320	320	320	<b>320</b>
<b>Gas Conditions</b>					
O <sub>2</sub> Oxygen (dry volume %)	10.2	9.8	10.0	9.8	<b>10.0</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.0	9.2	8.8	9.0	<b>9.0</b>
T <sub>s</sub> Sample temperature (°F)	311	310	310	310	<b>310</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	22.4	22.6	23.1	22.7	<b>22.7</b>
<b>Gas Flow Rate</b>					
Q <sub>e</sub> Volumetric flow rate, actual (acfm)	202,000	198,000	207,000	208,000	<b>204,000</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	105,000	103,000	107,000	108,000	<b>106,000</b>
<b>Sampling Data</b>					
V <sub>std</sub> Volume metered, standard (dscf)	83.54	83.24	86.38	86.61	<b>84.94</b>
%I Isokinetic sampling (%)	98.5	100.1	100.3	99.7	<b>99.7</b>
<b>Laboratory Data</b>					
m <sub>n-1b</sub> Fraction 1B Prorated (µg)	<0.1000	<0.1000	<0.1000	<0.1000	
m <sub>n-2b</sub> Fraction 2B Prorated (µg)	2.3378	18.2270	16.2002	13.8613	
m <sub>n-3a</sub> Fraction 3A Prorated (µg)	<0.2000	<0.2000	<0.2000	<0.2000	
m <sub>n-3b</sub> Fraction 3B Prorated (µg)	<0.5000	<0.5000	<0.5000	<0.5000	
m <sub>n-3c</sub> Fraction 3C Prorated (µg)	<0.4000	<0.4000	<0.4000	<0.4000	
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	2.3378	18.2270	16.2002	13.8613	
<b>Mercury Results - Total</b>					
C <sub>std</sub> Concentration (µg/dscm)	1.0	7.7	6.6	5.7	<b>5.2</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	1.3	9.7	8.4	7.1	<b>6.6</b>
C <sub>sd</sub> Concentration (mg/dscm)	0.0010	0.0077	0.0066	0.0057	<b>0.0052</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	0.0013	0.0097	0.0084	0.0071	<b>0.0066</b>
E <sub>lb/hr</sub> Rate (lb/hr)	3.9E-04	3.0E-03	2.7E-03	2.3E-03	<b>2.1E-03</b>
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	1.2E-06	8.7E-06	7.6E-06	6.4E-06	<b>6.0E-06</b>

**RESULTS**

**Table 2-2:  
 Quality Assurance and Quality Control**

<b>Mercury RPD RESULTS</b>						
<b>Run Number</b>		<b>FH</b>	<b>BH</b>	<b>A</b>	<b>B</b>	<b>C</b>
		<b>Front</b>	<b>H<sub>2</sub>O<sub>2</sub>/HNO<sub>3</sub></b>	<b>Empty</b>	<b>KMnO<sub>4</sub></b>	<b>HCl</b>
		<b>Half</b>		<b>Impinger</b>		
<b>U1-R1</b>		NA	1.5%	NA	NA	NA
<b>U1-R2</b>		NA	2.3%	NA	NA	NA
<b>U1-R3</b>		NA	1.3%	NA	NA	NA
<b>U1-R4</b>		NA	0.2%	NA	NA	NA
<b>Field Blank</b>		NA	NA	NA	NA	NA
<b>Reagent Blank</b>		NA	NA	NA	NA	NA
<b>Mercury Sample Spike and Recovery</b>						
<b>U1-R3</b>	<b>#1</b>	112%	90%	95%	93%	95%
	<b>#2</b>	114%	88%	94%	91%	93%
<b>Blanks</b>						
<b>Field Blank</b>	<b>#1</b>	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
	<b>#2</b>	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
<b>Reagent Blank</b>	<b>#1</b>	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
	<b>#2</b>	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4

*End of Section 2 – Results*



**DESCRIPTION OF INSTALLATION****PROCESS DESCRIPTION**

The North Broward Resource Recovery facility operates three (3) 750 tons-per-day municipal refuse-fired, water-wall boiler trains. The trains were manufactured by Babcock & Wilcox to produce electricity for sale to a local utility company.

Each boiler is equipped with the following air pollution controls (APCs):

- 1) A selective non-catalytic reduction (SNCR) for nitrogen oxides (NO<sub>x</sub>) control;
- 2) A spray dry absorber (SDA) for acid gas removal;
- 3) A fabric filter for the control of particulate emissions.

Each fabric filter is followed by an induced draft (ID) fan that directs the flue gas to a dedicated flue in a common stack. The APC equipment is manufactured by Wheelabrator Air Pollution Control, Inc. All APC equipment is generally in excellent condition. Each boiler is also equipped with a continuous emission monitoring (CEM) system to demonstrate the compliance with sulfur dioxide (SO<sub>2</sub>), NO<sub>x</sub> and carbon monoxide (CO) limits.

Figure 3-1 shows a general schematic for the facility. All of the testing reported in this document was performed at the Unit 1 FF Outlet, as shown in Figure 3-2 on page 3-2.




Figure 3-1: General Process Schematic

**DESCRIPTION OF INSTALLATION**

3-2




Figure 3-2: Process Schematic


**DESCRIPTION OF INSTALLATION**

**DESCRIPTION OF SAMPLING LOCATION**

Sampling point locations were determined according to EPA Method 1. Table 3-1 outlines the sampling point configurations. Figure 3-3 illustrates the sampling points and orientation of sampling ports for the source tested in the program.

**Table 3-1:  
Sampling Points**

Location	Constituent	Method	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
Unit 1 FF Outlet	Mercury	29	1-4	5	5	5	125	3-3



Sampling Point	Port to Point Distance (in.)
1	86.4
2	67.2
3	48.0
4	28.8
5	9.6

Equivalent Duct diameters upstream from flow disturbance (A): 0.5 Limit: 0.5  
 Equivalent Duct diameters downstream from flow disturbance (B): 2.0 Limit: 2.0

**Figure 3-3: Unit 1 FF Outlet Sampling Point Determination (EPA Method 1)**

**METHODOLOGY**

4-1

Clean Air Engineering followed procedures as detailed in US EPA Methods 1, 2, 3, 3B, 4 and 29. The following table summarizes the methods and their respective sources.

**Table 4-1:  
Summary of Sampling Procedures**

Title 40 CFR Part 60 Appendix A

Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
Method 3	"Gas Analysis for the Determination of Dry Molecular Weight"
Method 3B	"Gas Analysis for the Determination of Emission Rate Correction Factor or Excess Air"
Method 4	"Determination of Moisture Content in Stack Gases"
Method 29	"Determination of Metals Emissions from Stationary Sources"

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and are located on the internet at <http://ecfr.gpoaccess.gov>.

Diagrams of the sampling apparatus and major specifications of the sampling, recovery and analytical procedures are summarized for each method in Appendix A.

CleanAir followed specific quality assurance and quality control (QA/QC) procedures as outlined in the individual methods and as prescribed in CleanAir's internal Quality Manual. Results of all QA/QC activities performed by CleanAir are summarized in Appendix D.

*End of Section 4 – Methodology*

**APPENDIX**

**5-1**

TEST METHOD SPECIFICATIONS .....	A
SAMPLE CALCULATIONS .....	B
PARAMETERS .....	C
QA/QC DATA .....	D
FIELD DATA .....	E
FIELD DATA PRINTOUTS .....	F
LABORATORY DATA .....	G
PLANT DATA .....	H

**TEST METHOD SPECIFICATIONS**

A

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials:     *W*    

Date:     1/15/14    



**This Page Intentionally Left Blank**

## Specification Sheet for

## EPA Method 29

Source Location Name(s) Unit 1 FF Outlet  
 Pollutant(s) to be Determined Mercury  
 Other Parameters to be Determined from Train Gas Density, Moisture, Flow Rate

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Pollutant Sampling Information</b>		
Duration of Run	N/A	125 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	5 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
<b>Sampling Probe</b>		
Nozzle Material	Borosilicate or Quartz Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
<b>Velocity Measuring Equipment</b>		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.814
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
<b>Metering System Console</b>		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
<b>Filter Description</b>		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Teflon (or other non-metallic)	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Quartz or Glass Fiber	Quartz Fiber
<b>Other Components</b>		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A




# Specification Sheet for

# EPA Method 29

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Impinger Train Description</b>		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	7	7
<b>Impinger Stem Types</b>		
Impinger 1	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 2	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 3	Greenburg-Smith	Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 6	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 7	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 8		
<b>Gas Density Determination</b>		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	Orsat
<b>Sample Recovery Information</b>		
Probe Brush Material	Non-metallic swab or bristle	Teflon Mat
Probe Rinse Reagent	0.1N Nitric Acid	0.1 N Nitric Acid
Probe Rinse Wash Bottle Material	Glass or Teflon	Teflon
Probe Rinse Storage Container	Polyethylene or glass	Polyethylene
Filter Recovered?	Yes	Yes
Filter Storage Container	Petri Dish - Glass or Polystyrene	Polyethylene
Impinger Contents Recovered?	Yes	Yes
Impinger Rinse Reagent	See Method 29 Recovery Flow Chart	See Recovery Flow Chart
Impinger Wash Bottle	Glass or Teflon	Teflon
Impinger Storage Container	See Recovery Flow Chart	See Recovery Flow Chart
<b>Analytical Information</b>		
Method 4 H <sub>2</sub> O Determination by	Volumetric or Gravimetric	Gravimetric and Volumetric
Filter Preparation Conditions	See Method 29 Analytical Flow Chart	For Metals Analysis
Front-Half Rinse Preparation	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Back-Half Analysis	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Additional Analysis	None	None


# EPA Method 29 Sampling Train Configuration



**Impinger Contents**


Impinger 1	Empty
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>
Impinger 4	Empty
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>
Impinger 7	Silica Gel

## EPA Method 29 Glassware Preparation Procedures




# EPA Method 29 Sample Recovery Flowchart (includes Mercury)

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)
- Collect one complete blank set per field test



**EPA Method 29**  
**Analytical Flowchart**  
 (includes Mercury)



**SAMPLE CALCULATIONS**

**B**

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: ME

Date: 1/15/14



**This Page Intentionally Left Blank**

**USEPA Method 29 (Mercury)  
 Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

010314 123749  
 0

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

$V_{lc}$	= total volume of liquid collected in impingers and silica gel (ml)	=	513.5	ml
0.04706	= ideal gas conversion factor (ft <sup>3</sup> water vapor/ml or gm)	=	0.04706	ft <sup>3</sup> /ml
$V_{wstd}$	= volume of water vapor collected at standard conditions (ft <sup>3</sup> )	=	24.17	ft <sup>3</sup>

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.14	in. Hg
$T_m$	= average dry gas meter temperature (°F)	=	96.40	°F
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	86.82	dcf
$Y_d$	= gas meter correction factor (dimensionless)	=	1.0031	
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.60	in. H <sub>2</sub> O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in.H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	83.538	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left( \frac{P_g}{13.6} \right)$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.14	in. Hg
$P_g$	= sample gas static pressure (in. H <sub>2</sub> O)	=	-10.60	in. H <sub>2</sub> O
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.36	in. Hg



4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left( \frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

$T_s$	= average sample gas temperature (°F)	=	310.60	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
$P_v$	= vapor pressure, actual (in. Hg)	=	29.36	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.36	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.36	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	83.538	dscf
$V_{wstd}$	= volume of water collected at standard conditions (scf)	=	24.17	scf
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2244	%
		=	22.44	%

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.36	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.36	in. Hg
$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	%
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2244	
$B_w$	= actual water vapor in gas	=	0.2244	
		=	22.44	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.0	%
100	= conversion factor (%)	=	100	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.80	%

10. Molecular weight of dry gas stream (lb/lb·mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2 + CO)}{(100)}$$

Where:

$M_{CO_2}$	= molecular weight of carbon dioxide (lb/lb·mole)	=	44.00	lb/lb·mole
$M_{O_2}$	= molecular weight of oxygen (lb/lb·mole)	=	32.00	lb/lb·mole
$M_{N_2+CO}$	= molecular weight of nitrogen and carbon monoxide (lb/lb·mole)	=	28.00	lb/lb·mole
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.0	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.8	%
100	= conversion factor (%)	=	100	%
$M_d$	= dry molecular weight of sample gas (lb/lb·mole)	=	29.99	lb/lb·mole

11. Molecular weight of sample gas (lb/lb·mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2244	
$M_d$	= dry molecular weight of sample gas (lb/lb·mole)	=	29.99	lb/lb·mole
$M_{H_2O}$	= molecular weight of water (lb/lb·mole)	=	18.00	lb/lb·mole
$M_s$	= molecular weight of sample gas, wet basis (lb/lb·mole)	=	27.30	lb/lb·mole

12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left( \sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

$K_p$	= velocity pressure constant	=	85.49	
$C_p$	= pitot tube coefficient	=	0.81	
$M_s$	= wet molecular weight of sample gas, wet basis (lb/lb·mole)	=	27.30	lb/lb·mole
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.36	in. Hg
$T_s$	= average sample gas temperature (°F)	=	310.60	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H <sub>2</sub> O)	=	0.769	$\sqrt{\text{in. H}_2\text{O}}$
460	= °F to °R conversion constant	=	460	
$V_s$	= sample gas velocity (ft/sec)	=	52.49	ft/sec

13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

$A_s$	= cross sectional area of sampling location (ft <sup>2</sup> )	=	64.00	ft <sup>2</sup>
$V_s$	= sample gas velocity (ft/sec)	=	52.49	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	201,572	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left( \frac{P_s}{29.92} \right) \left( \frac{68 + 460}{T_s + 460} \right)$$

Where:

$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	201,572	acfm
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.36	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
$T_s$	= average sample gas temperature (°F)	=	310.6	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	135,531	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2244	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	135,531	scfm
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	105,122	dscfm

16. Dry flow of sample gas corrected to 7%O<sub>2</sub> (dscfm)

$$Q_{std7} = (Q_{std}) \left( \frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

Q <sub>std</sub>	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	105,122	dscfm
O <sub>2</sub>	= proportion of oxygen in the gas stream by volume (%)	=	9.0	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
Q <sub>std7</sub>	= volumetric flow rate at STP and 7%O <sub>2</sub> , dry basis (dscfm)	=	89,997	dscfm

17. Hourly time basis conversion of volumetric flow rate (Q<sub>std</sub> example)

$$Q_{std-hr} = (Q_{std-min}) (60)$$

Where

Q <sub>std-min</sub>	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	105,122	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Q <sub>std-hr</sub>	= volumetric flow rate, hourly basis (dscf/hr)	=	6,307,325	dscf/hr

18. Metric Conversion of Gas Volumes (Q<sub>std</sub> example)

$$Q_{std-metric} = (Q_{std-english}) \left( \frac{60}{35.31} \right)$$

Where:

Q <sub>std-english</sub>	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	105,122	dscfm
35.31	= conversion factor (ft <sup>3</sup> /m <sup>3</sup> )	=	35.31	ft <sup>3</sup> /m <sup>3</sup>
60	= conversion factor (min/hr)	=	60	min/hr
Q <sub>std-metric</sub>	= volumetric flow rate, metric units (m <sup>3</sup> /hr)	=	178,627	dry std m <sup>3</sup> /hr

19. Standard to Normal Conversion of Gas Volumes (Q<sub>std</sub> example)

$$Q_{Normal} = (Q_{std-metric}) \left( \frac{32 + 460}{68 + 460} \right)$$

Where:

Q <sub>std-metric</sub>	= volumetric flow rate, metric units (dry std m <sup>3</sup> /hr)	=	178,627	dry std m <sup>3</sup> /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	
Q <sub>Normal</sub>	= volumetric flow rate, metric units (dry Nm <sup>3</sup> /hr)	=	166,448	dry Nm <sup>3</sup> /hr

20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\overline{T_s} + 460)(V_{msld})}{(P_s)(V_s)\left(\frac{D_n^2(\pi)}{(144)(4)}\right)(\Theta)(1 - B_w)}$$

Where:

$D_n$	= diameter of nozzle (in)	=	0.275	in.
$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2244	
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.36	in. Hg
$T_s$	= average sample gas temperature (°F)	=	310.6	°F
$V_{msld}$	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	83.538	dscf
$V_s$	= sample gas velocity (ft/sec)	=	52.49	ft/sec
$\Theta$	= total sampling time (min)	=	125	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
$I$	= percent of isokinetic sampling (%)	=	98.70	%

21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\Theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{@})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

$\Theta$	= total sampling time (min)	=	125	min
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	86.82	dcf
$T_m$	= average dry gas meter temperature (°F)	=	96.40	°F
$\Delta H_{@}$	= dry gas meter orifice coefficient	=	1.7992	
$P_{bar}$	= barometric pressure (in. Hg)	=	30.14	in. Hg
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.600	in. H <sub>2</sub> O
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	29.99	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.262	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in.H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$Y_{qa}$	= alternative Method 5 post-test meter calibration factor	=	1.0198	

## LOGIC FOR TREATING DETECTION LIMITS (mercury only)

### 1. Logic for Determining Total Blank ( $m_{\text{Total-B}}$ ) from 5 Fractions

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 fractions are ND	<b>CASE 3</b> All 5 fractions are ND
<b>Rule</b>			
$ND = 0$	$m_{\text{Total-B}} = \text{Sum D, 1-5}$	$m_{\text{Total-B}} = \text{Sum D}$	$m_{\text{Total-B}} = < \text{Sum ND}$
$ND = 1x$	$m_{\text{Total-B}} = \text{Sum D, 1-5}$	$m_{\text{Total-B}} = \text{Sum D}$	$m_{\text{Total-B}} = < \text{Sum ND}$
$ND = 0.5x$	$m_{\text{Total-B}} = \text{Sum D, 1-5}$	$m_{\text{Total-B}} = \text{Sum D}$	$m_{\text{Total-B}} = < 0.5 \text{ Sum ND}$

### 2. Logic for Determining Total Sample ( $m_{\text{Total-S}}$ ) from 5 Fractions

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 fractions are ND	<b>CASE 3</b> All 5 fractions are ND
<b>Rule</b>			
$ND = 0$	$m_{\text{Total-S}} = \text{Sum D, 1-5}$	$m_{\text{Total-S}} = \text{Sum D}$	$m_{\text{Total-S}} = < \text{Sum ND}$
$ND = 1x$	$m_{\text{Total-S}} = \text{Sum D, 1-5}$	$m_{\text{Total-S}} = < [\text{Sum D} + \text{Sum ND}]$	$m_{\text{Total-S}} = < \text{Sum ND}$
$ND = 0.5x$	$m_{\text{Total-S}} = \text{Sum D, 1-5}$	$m_{\text{Total-S}} = < [\text{Sum D} + 0.5 \text{ Sum ND}]$	$m_{\text{Total-S}} = < 0.5 \text{ Sum ND}$

### 3. Logic for Determining Maximum Allowable Blank Correction ( $m_{\text{T-B-allow}}$ )

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 sample fractions are ND	<b>CASE 3</b> All 5 fractions are ND	<b>CASE 4</b> Any type of fractions
	$m_{\text{Total-B}} = D$	$m_{\text{Total-B}} = D$	$m_{\text{Total-B}} = D$	$m_{\text{Total-B}} = ND$
<b>Rule</b>				
$ND = 0$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = 0$	$m_{\text{T-B-allow}} = 0$
$ND = 1x$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = 0$	$m_{\text{T-B-allow}} = 0$
$ND = 0.5x$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = 0$	$m_{\text{T-B-allow}} = 0$

\* M29 rule using only detected sample quantities for logical comparisons.

### 4. Logic for Determining Blank-Corrected Sample Amount ( $m_n$ )

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 sample fractions are ND	<b>CASE 3</b> All 5 fractions are ND	<b>CASE 4</b> Any type of fractions
	$m_{\text{Total-S}} - m_{\text{T-B-allow}} \geq \text{MIN}(\text{MDL})$	$m_{\text{Total-S}} - m_{\text{T-B-allow}} \geq \text{MIN}(\text{MDL})$	$m_{\text{Total-S}}$ and $m_{\text{T-B-allow}}$ anything	$m_{\text{Total-S}} - m_{\text{T-B-allow}} < \text{MIN}(\text{MDL})$
<b>Rule</b>				
$ND = 0$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = < m_{\text{Total-S}}$	$m_n = < \text{MIN}[\text{MDL}]$
$ND = 1x$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = < [m_{\text{Total-S}} - m_{\text{T-B-allow}}]$	$m_n = < m_{\text{Total-S}}$	$m_n = < \text{MIN}[\text{MDL}]$
$ND = 0.5x$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = < [m_{\text{Total-S}} - m_{\text{T-B-allow}}]$	$m_n = < m_{\text{Total-S}}$	$m_n = < \text{MIN}[\text{MDL}]$

#### Definitions and Notes

The term "Rule" refers to the rule being implemented for handling non-detectable quantities in summations.

MDL = minimum detection limit.

D = Detectable quantity reported as D.

ND = Non-Detectable quantity reported at a value of ND.

MIN[MDL] = lowest quantity of all detection limits for 5 fractions.

**USEPA Method 29 (Mercury)  
 Mercury Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

010314 123749

1. Total blank amount (µg)

$$m_{total-B} = \sum_{i=1}^n m_{i-B}$$

Where:

$m_{1b-B}$	= mercury amount in blank for Fraction 1b	=	<0.1000	µg
$m_{2b-B}$	= mercury amount in blank for Fraction 2b	=	<0.2000	µg
$m_{3a-B}$	= mercury amount in blank for Fraction 3a	=	<0.2000	µg
$m_{3b-B}$	= mercury amount in blank for Fraction 3b	=	<0.5000	µg
$m_{3c-B}$	= mercury amount in blank for Fraction 3c	=	<0.4000	µg
$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg

2. Total sample amount (µg)

$$m_{total-S} = \sum_{i=1}^n m_{i-S}$$

Where:

$m_{1b-S}$	= mercury amount in sample for Fraction 1b	=	<0.1000	µg
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	=	2.3378	µg
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	=	<0.2000	µg
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	=	<0.5000	µg
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	=	<0.4000	µg
$m_{total-S}$	= total amount of mercury in sample	=	2.3378	µg

3. Allowable blank correction (µg)

$$m_{T-B-allow} = m_{total-B} \text{ if } m_{total-B} \leq 0.6$$

$$m_{T-B-allow} = \text{MAX} [0.6, \text{MIN} (m_{total-B}, 0.05 \times m_{total-S})] \text{ if } m_{total-B} > 0.6$$

Where:

$m_{total-B}$	= total amount of mercury in blank	=	<1.4000	µg
$m_{total-S}$	= total amount of mercury in sample	=	2.3378	µg
$0.05 \times m_{total-S}$	= 5% of $m_{total-S}$	=	0.1169	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
$m_{T-B-allow}$	= total allowable blank correction	=	0.0000	µg

NOTE: In this case, the second criteria applies.

4. Sample corrected for allowable blank - Total ( $\mu\text{g}$ )

$$m_n = m_{\text{total-S}} - m_{T-B-\text{allow}}$$

Where:

$m_{\text{total-S}}$	= total amount of mercury in sample	=	2.3378	$\mu\text{g}$
$m_{T-B-\text{allow}}$	= total allowable blank correction	=	0.0000	$\mu\text{g}$
$m_n$	= total mercury in sample corrected for allowable blank	=	2.3378	$\mu\text{g}$

5. Sample corrected for allowable blank - Prorated for each fraction ( $\mu\text{g}$ )

$$m_{n-i} = \left( \frac{m_{i-S}}{m_{\text{total-S}}} \right) (m_n)$$

Where:

$m_n$	= total mercury in sample corrected for allowable blank	=	2.3378	$\mu\text{g}$
$m_{1b-S}$	= mercury amount in sample for Fraction 1b	=	<0.1000	$\mu\text{g}$
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	=	2.3378	$\mu\text{g}$
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	=	<0.2000	$\mu\text{g}$
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	=	<0.5000	$\mu\text{g}$
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	=	<0.4000	$\mu\text{g}$
$m_{\text{total-S}}$	= total amount of mercury in sample	=	2.3378	$\mu\text{g}$
$m_{n-1b}$	= mercury corrected for blank - prorated for Fraction 1b	=	<0.1000	$\mu\text{g}$
$m_{n-2b}$	= mercury corrected for blank - prorated for Fraction 2b	=	2.3378	$\mu\text{g}$
$m_{n-3a}$	= mercury corrected for blank - prorated for Fraction 3a	=	<0.2000	$\mu\text{g}$
$m_{n-3b}$	= mercury corrected for blank - prorated for Fraction 3b	=	<0.5000	$\mu\text{g}$
$m_{n-3c}$	= mercury corrected for blank - prorated for Fraction 3c	=	<0.4000	$\mu\text{g}$



**USEPA Method 29 (Mercury)  
 Mercury Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

010914 140047  
 P\_0

1. Mercury concentration (lb/dscf)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	2.3378	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	83.5383	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$C_{sd}$	= mercury concentration (lb/dscf)	=	6.1706E-11	lb/dscf

2. Mercury concentration ( $\mu\text{g/dscm}$ )

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	2.3378	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	83.5383	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
$C_{sd}$	= mercury concentration ( $\mu\text{g/dscm}$ )	=	9.8813E-01	$\mu\text{g/dscm}$

3. Mercury concentration (mg/dscm)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{35.31}{1000} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	2.3378	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	83.5383	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
1000	= conversion factor ( $\mu\text{g/mg}$ )	=	1000	$\mu\text{g/mg}$
$C_{sd}$	= mercury concentration (mg/dscm)	=	9.8813E-04	mg/dscm

4. Mercury concentration ( $\mu\text{g}/\text{Nm}^3$  dry)

$$C_{sd} = \left( \frac{m_n}{V_{msid}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 2.3378	$\mu\text{g}$
$V_{msid}$	= volume metered, standard (dscf)	= 83.5383	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ( $^{\circ}\text{F}$ )	= 68	$^{\circ}\text{F}$
32	= normal temperature ( $^{\circ}\text{F}$ )	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	
$C_{sd}$	= mercury concentration ( $\mu\text{g}/\text{Nm}^3$ dry)	= 1.0604E+00	$\mu\text{g}/\text{Nm}^3$ dry

5. Mercury concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 6.1706E-11	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 10.2	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$C_{sdx}$	= mercury concentration corrected to x% oxygen (lb/dscf)	= 8.0160E-11	lb/dscf @ x% $O_2$

6. Mercury concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 6.1706E-11	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	= 9.0	%
$C_{sdy}$	= mercury conc. corrected to y% carbon dioxide (lb/dscf)	= 8.2275E-11	lb/dscf @ y% $CO_2$

7. Mercury concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 6.1706E-11	lb/dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 105,338	dscfm
$Q_a$	= volumetric flow rate at actual conditions (acfm)	= 201,986	acfm
$C_a$	= mercury concentration at actual gas conditions (lb/acf)	= 3.2180E-11	lb/acf

8. Mercury emission rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 2.3378	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 83.5383	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 105,338	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$E_{lb/hr}$	= mercury emission rate (lb/hr)	= 3.9000E-04	lb/hr

9. Mercury emission rate (g/s)

$$E_{g/s} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 2.3378	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 83.5383	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 105,338	dscfm
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60	sec/min
$E_{g/s}$	= mercury emission rate (g/s)	= 4.9131E-05	g/s

10. Mercury emission rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 2.3378	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 83.5383	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 105,338	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2000	lb/Ton
$E_{T/yr}$	= mercury emission rate (Ton/yr)	= 1.7082E-03	Ton/yr

11. Mercury emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	2.3378	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	83.5383	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	10.2	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
$E_{Fd}$	= mercury emission rate - Fd-based (lb/MMBtu)	=	1.1535E-06	lb/MMBtu

12. Mercury emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	2.3378	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	83.5383	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.0	%
100	= conversion factor	=	100	
$E_{Fc}$	= mercury emission rate - Fc-based (lb/MMBtu)	=	1.2478E-06	lb/MMBtu

**This Page Intentionally Left Blank**

WHEELABRATOR NORTH BROWARD, INC.  
POMPANO BEACH, FL

Client Reference No: Service Agreement  
CleanAir Project No: 12218-7

**PARAMETERS**

C

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: MR

Date: 1/15/14



**This Page Intentionally Left Blank**

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 29 (Mercury)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	4	Average
Date (2013)	Dec 10	Dec 11	Dec 11	Dec 11	
Start Time (approx.)	12:24	08:09	10:42	13:14	
Stop Time (approx.)	14:34	10:21	12:54	15:25	
<b>Sampling Conditions</b>					
Y <sub>d</sub> Dry gas meter correction factor	1.0031	1.0031	1.0031	1.0031	
C <sub>p</sub> Pitot tube coefficient	0.8140	0.8140	0.8140	0.8140	
P <sub>g</sub> Static pressure (in. H <sub>2</sub> O)	-10.6000	-9.5000	-11.2000	-11.2000	
A <sub>s</sub> Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	64.0000	
P <sub>bar</sub> Barometric pressure (in. Hg)	30.14	30.16	30.16	30.16	30.1550
D <sub>n</sub> Nozzle diameter (in.)	0.2750	0.2750	0.2750	0.2750	
O <sub>2</sub> Oxygen (dry volume %)	10.2000	9.8000	10.0000	9.8000	9.9500
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.0000	9.2000	8.8000	9.0000	9.0000
N <sub>2</sub> +CO Nitrogen plus carbon monoxide (dry volume %)	80.8000	81.0000	81.2000	81.2000	81.0500
V <sub>lc</sub> Total Liquid collected (ml)	513.50	517.60	551.40	540.80	
V <sub>m</sub> Volume metered, meter conditions (ft <sup>3</sup> )	86.8150	84.6500	89.4800	89.6000	
T <sub>m</sub> Dry gas meter temperature (°F)	96.4000	84.7600	95.1000	94.3800	
T <sub>s</sub> Sample temperature (°F)	310.6000	310.0400	309.6400	310.3600	310.1600
ΔH Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.6000	1.5440	1.6800	1.6920	
θ Total sampling time (min)	125.0	125.0	125.0	125.0	
<b>Flow Results</b>					
V <sub>wstd</sub> Volume of water collected (ft <sup>3</sup> )	24.1653	24.3583	25.9489	25.4500	24.9806
V <sub>mstd</sub> Volume metered, standard (dscf)	83.5383	83.2391	86.3782	86.6089	84.9411
P <sub>a</sub> Sample gas pressure, absolute (in. Hg)	29.3606	29.4615	29.3365	29.3365	29.3738
P <sub>v</sub> Vapor pressure, actual (in. Hg)	29.3606	29.4615	29.3365	29.3365	29.3738
B <sub>wo</sub> Moisture measured in sample (% by volume)	22.4369	22.6383	23.1012	22.7113	22.7219
B <sub>ws</sub> Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	100.0000	100.0000
B <sub>w</sub> Actual water vapor in gas (% by volume)	22.4369	22.6383	23.1012	22.7113	22.7219
√ΔP Velocity head (in. H <sub>2</sub> O)	0.7693	0.7546	0.7865	0.7900	0.7751
M <sub>d</sub> MW of sample gas, dry (lb/lb-mole)	29.8480	29.8640	29.8080	29.8320	29.8380
M <sub>s</sub> MW of sample gas, wet (lb/lb-mole)	27.1897	27.1782	27.0802	27.1448	27.1482
V <sub>s</sub> Velocity of sample (ft/sec)	52.6005	51.4974	53.8693	54.0721	53.0098
%I Isokinetic sampling (%)	98.4995	100.0932	100.2655	99.7444	99.6507
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	201,986	197,750	206,858	207,637	203,558
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	135,809	133,515	139,144	139,537	137,001
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	105,338	103,289	107,000	107,847	105,868
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	81,087	82,483	83,907	86,122	83,400
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	12,119,144	11,864,991	12,411,491	12,458,201	12,213,457
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	8,148,544	8,010,892	8,348,655	8,372,243	8,220,083
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	6,320,266	6,197,360	6,420,017	6,470,797	6,352,110
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	343,221	336,024	351,501	352,824	345,892
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	230,772	226,873	236,439	237,107	232,798
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	178,994	175,513	181,819	183,257	179,895
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	137,786	140,158	142,577	146,342	141,716
Q <sub>a</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	215,037	211,405	220,318	220,940	216,925
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	166,790	163,546	169,422	170,762	167,630
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	128,392	130,602	132,856	136,364	132,053

**Comments:**

Average Includes 4 runs.

010914 135935  
 PLKP



Wheelabrator North Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	4	Average
Date (2013)		Dec 10	Dec 11	Dec 11	Dec 11	
Start Time (approx.)		12:24	08:09	10:42	13:14	
Stop Time (approx.)		14:34	10:21	12:54	15:25	
<b>Process Conditions</b>						
R <sub>p</sub>	Steam Production Rate - (klbs/hour)	179.5	180.1	180.2	180.4	180.0
P <sub>1</sub>	Fabric Filter Inlet Temperature - (°F)	321	320	320	320	320
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>						
O <sub>2</sub>	Oxygen (dry volume %)	10.2000	9.8000	10.0000	9.8000	9.9500
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.0000	9.2000	8.8000	9.0000	9.0000
T <sub>s</sub>	Sample temperature (°F)	310.6000	310.0400	309.6400	310.3600	310.1600
B <sub>w</sub>	Actual water vapor in gas (% by volume)	22.4369	22.6383	23.1012	22.7113	22.7219
<b>Gas Flow Rate</b>						
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	201,986	197,750	206,858	207,637	203,558
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	135,809	133,515	139,144	139,537	137,001
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	105,338	103,289	107,000	107,847	105,868
<b>Sampling Data</b>						
V <sub>mstd</sub>	Volume metered, standard (dscf)	83.5363	83.2391	86.3782	86.6089	84.9411
%I	Isokinetic sampling (%)	98.4995	100.0932	100.2655	99.7444	99.6507
<b>Laboratory Data</b>						
m <sub>n-1b</sub>	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	<0.1000	
m <sub>n-2b</sub>	Fraction 2B (µg)	2.3378	18.2270	16.2002	13.8613	
m <sub>n-3a</sub>	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	<0.2000	
m <sub>n-3b</sub>	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	<0.5000	
m <sub>n-3c</sub>	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	<0.4000	
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	2.3378	18.2270	16.2002	13.8613	
<b>Mercury Results - Total</b>						
C <sub>std</sub>	Concentration (lb/dscf)	6.1706E-11	4.8283E-10	4.1355E-10	3.5290E-10	3.2775E-10
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	8.0160E-11	6.0463E-10	5.2737E-10	4.4192E-10	4.1352E-10
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	8.2275E-11	6.2978E-10	5.6393E-10	4.7053E-10	4.3663E-10
C <sub>a</sub>	Concentration (lb/acf)	3.2180E-11	2.5219E-10	2.1391E-10	1.8330E-10	1.7040E-10
C <sub>sd</sub>	Concentration (µg/dscm)	9.8813E-01	7.7319E+00	6.6224E+00	5.6512E+00	5.2484E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	1.2837E+00	9.6823E+00	8.4450E+00	7.0767E+00	6.6219E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	1.3175E+00	1.0085E+01	9.0305E+00	7.5349E+00	6.9920E+00
C <sub>sd</sub>	Concentration (mg/dscm)	9.8813E-04	7.7319E-03	6.6224E-03	5.6512E-03	5.2484E-03
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	1.2837E-03	9.6823E-03	8.4450E-03	7.0767E-03	6.6219E-03
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	1.3175E-03	1.0085E-02	9.0305E-03	7.5349E-03	6.9920E-03
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	5.1532E-01	4.0385E+00	3.4255E+00	2.9352E+00	2.7287E+00
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	1.0604E+00	8.2976E+00	7.1069E+00	6.0647E+00	5.6324E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.3776E+00	1.0391E+01	9.0630E+00	7.5945E+00	7.1064E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.4139E+00	1.0823E+01	9.6913E+00	8.0863E+00	7.5036E+00
E <sub>lb/hr</sub>	Rate (lb/hr)	3.9000E-04	2.9923E-03	2.6550E-03	2.2835E-03	2.0802E-03
E <sub>g/s</sub>	Rate (g/s)	4.9131E-05	3.7696E-04	3.3446E-04	2.8767E-04	2.6206E-04
E <sub>T/yr</sub>	Rate (Ton/yr)	1.7082E-03	1.3106E-02	1.1629E-02	1.0002E-02	9.1113E-03
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	1.1535E-06	8.7002E-06	7.5885E-06	6.3590E-06	5.9503E-06
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	1.2478E-06	9.5517E-06	8.5529E-06	7.1364E-06	6.6222E-06

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Front Half Results**

Run No.	1	2	3	4	Average
Date (2013)	Dec 10	Dec 11	Dec 11	Dec 11	
Start Time (approx.)	12:24	08:09	10:42	13:14	
Stop Time (approx.)	14:34	10:21	12:54	15:25	

**Mercury Results - Front Half**

C <sub>sd</sub>	Concentration (lb/dscf)	<2.6395E-12	<2.6490E-12	<2.5527E-12	<2.5459E-12	<2.5968E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<3.4289E-12	<3.3172E-12	<3.2553E-12	<3.1881E-12	<3.2974E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<3.5193E-12	<3.4552E-12	<3.4810E-12	<3.3946E-12	<3.4625E-12
C <sub>a</sub>	Concentration (lb/acf)	<1.3765E-12	<1.3836E-12	<1.3204E-12	<1.3224E-12	<1.3507E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<4.2268E-02	<4.2420E-02	<4.0878E-02	<4.0769E-02	<4.1584E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<5.4909E-02	<5.3120E-02	<5.2129E-02	<5.1054E-02	<5.2803E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<5.6357E-02	<5.5330E-02	<5.5743E-02	<5.4359E-02	<5.5448E-02
C <sub>sd</sub>	Concentration (mg/dscm)	<4.2268E-05	<4.2420E-05	<4.0878E-05	<4.0769E-05	<4.1584E-05
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<5.4909E-05	<5.3120E-05	<5.2129E-05	<5.1054E-05	<5.2803E-05
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<5.6357E-05	<5.5330E-05	<5.5743E-05	<5.4359E-05	<5.5448E-05
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<2.2043E-02	<2.2157E-02	<2.1145E-02	<2.1176E-02	<2.1630E-02
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<4.5361E-02	<4.5524E-02	<4.3869E-02	<4.3753E-02	<4.4627E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<5.8927E-02	<5.7007E-02	<5.5944E-02	<5.4789E-02	<5.6667E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<6.0481E-02	<5.9379E-02	<5.9822E-02	<5.8337E-02	<5.9505E-02
E <sub>lb/hr</sub>	Rate (lb/hr)	<1.6682E-05	<1.6417E-05	<1.6389E-05	<1.6474E-05	<1.6490E-05
E <sub>g/s</sub>	Rate (g/s)	<2.1016E-06	<2.0681E-06	<2.0646E-06	<2.0754E-06	<2.0774E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<7.3069E-05	<7.1905E-05	<7.1782E-05	<7.2157E-05	<7.2228E-05
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<4.9340E-08	<4.7733E-08	<4.6842E-08	<4.5876E-08	<4.7448E-08
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<5.3377E-08	<5.2404E-08	<5.2795E-08	<5.1484E-08	<5.2515E-08

010914 140047  
 PLKP\_O

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 1-3 Results**

Run No.	1	2	3	4	Average
Date (2013)	Dec 10	Dec 11	Dec 11	Dec 11	
Start Time (approx.)	12:24	08:09	10:42	13:14	
Stop Time (approx.)	14:34	10:21	12:54	15:25	
<b>Mercury Results - Impingers 1-3 Solution</b>					
C <sub>sd</sub> Concentration (lb/dscf)	6.1706E-11	4.8283E-10	4.1355E-10	3.5290E-10	3.2775E-10
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	8.0160E-11	6.0463E-10	5.2737E-10	4.4192E-10	4.1352E-10
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	8.2275E-11	6.2978E-10	5.6393E-10	4.7053E-10	4.3663E-10
C <sub>a</sub> Concentration (lb/acf)	3.2180E-11	2.5219E-10	2.1391E-10	1.8330E-10	1.7040E-10
C <sub>sd</sub> Concentration (µg/dscm)	9.8813E-01	7.7319E+00	6.6224E+00	5.6512E+00	5.2484E+00
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	1.2837E+00	9.6823E+00	8.4450E+00	7.0767E+00	6.6219E+00
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	1.3175E+00	1.0085E+01	9.0305E+00	7.5349E+00	6.9920E+00
C <sub>sd</sub> Concentration (mg/dscm)	9.8813E-04	7.7319E-03	6.6224E-03	5.6512E-03	5.2484E-03
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	1.2837E-03	9.6823E-03	8.4450E-03	7.0767E-03	6.6219E-03
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	1.3175E-03	1.0085E-02	9.0305E-03	7.5349E-03	6.9920E-03
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	5.1532E-01	4.0385E+00	3.4255E+00	2.9352E+00	2.7287E+00
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	1.0604E+00	8.2976E+00	7.1069E+00	6.0647E+00	5.6324E+00
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.3776E+00	1.0391E+01	9.0630E+00	7.5945E+00	7.1064E+00
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.4139E+00	1.0823E+01	9.6913E+00	8.0863E+00	7.5036E+00
E <sub>lb/hr</sub> Rate (lb/hr)	3.9000E-04	2.9923E-03	2.6550E-03	2.2835E-03	2.0802E-03
E <sub>g/s</sub> Rate (g/s)	4.9131E-05	3.7696E-04	3.3446E-04	2.8767E-04	2.6206E-04
E <sub>T/yr</sub> Rate (Ton/yr)	1.7082E-03	1.3106E-02	1.1629E-02	1.0002E-02	9.1113E-03
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	1.1535E-06	8.7002E-06	7.5885E-06	6.3590E-06	5.9503E-06
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	1.2478E-06	9.5517E-06	8.5529E-06	7.1364E-06	6.6222E-06

010914 140047  
 PLKP\_O

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 4 Results**

Run No.	1	2	3	4	Average
Date (2013)	Dec 10	Dec 11	Dec 11	Dec 11	
Start Time (approx.)	12:24	08:09	10:42	13:14	
Stop Time (approx.)	14:34	10:21	12:54	15:25	

**Mercury Results - Impinger 4 Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	<5.2790E-12	<5.2980E-12	<5.1055E-12	<5.0919E-12	<5.1936E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<6.8578E-12	<6.6344E-12	<6.5106E-12	<6.3763E-12	<6.5948E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<7.0387E-12	<6.9104E-12	<6.9620E-12	<6.7891E-12	<6.9251E-12
C <sub>a</sub>	Concentration (lb/acf)	<2.7531E-12	<2.7673E-12	<2.6409E-12	<2.6447E-12	<2.7015E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<8.4536E-02	<8.4840E-02	<8.1757E-02	<8.1539E-02	<8.3168E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<1.0982E-01	<1.0624E-01	<1.0426E-01	<1.0211E-01	<1.0561E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<1.1271E-01	<1.1066E-01	<1.1149E-01	<1.0872E-01	<1.1090E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<8.4536E-05	<8.4840E-05	<8.1757E-05	<8.1539E-05	<8.3168E-05
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<1.0982E-04	<1.0624E-04	<1.0426E-04	<1.0211E-04	<1.0561E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<1.1271E-04	<1.1066E-04	<1.1149E-04	<1.0872E-04	<1.1090E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<4.4086E-02	<4.4314E-02	<4.2290E-02	<4.2351E-02	<4.3260E-02
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<9.0722E-02	<9.1048E-02	<8.7739E-02	<8.7505E-02	<8.9253E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.1785E-01	<1.1401E-01	<1.1189E-01	<1.0958E-01	<1.1333E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2096E-01	<1.1876E-01	<1.1964E-01	<1.1667E-01	<1.1901E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<3.3365E-05	<3.2834E-05	<3.2777E-05	<3.2948E-05	<3.2981E-05
E <sub>g/s</sub>	Rate (g/s)	<4.2032E-06	<4.1362E-06	<4.1291E-06	<4.1507E-06	<4.1548E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<1.4614E-04	<1.4381E-04	<1.4356E-04	<1.4431E-04	<1.4446E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<9.8680E-08	<9.5465E-08	<9.3684E-08	<9.1751E-08	<9.4895E-08
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<1.0675E-07	<1.0481E-07	<1.0559E-07	<1.0297E-07	<1.0503E-07

010914 140047  
 PLK P\_O

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 5-6 Results**

Run No.	1	2	3	4	Average
Date (2013)	Dec 10	Dec 11	Dec 11	Dec 11	
Start Time (approx.)	12:24	08:09	10:42	13:14	
Stop Time (approx.)	14:34	10:21	12:54	15:25	
<b>Mercury Results - Filtered Permanganate Solution</b>					
C <sub>sd</sub> Concentration (lb/dscf)	<1.3198E-11	<1.3245E-11	<1.2764E-11	<1.2730E-11	<1.2984E-11
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	<1.7144E-11	<1.6586E-11	<1.6277E-11	<1.5941E-11	<1.6487E-11
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.7597E-11	<1.7276E-11	<1.7405E-11	<1.6973E-11	<1.7313E-11
C <sub>a</sub> Concentration (lb/acf)	<6.8827E-12	<6.9182E-12	<6.6022E-12	<6.6118E-12	<6.7537E-12
C <sub>sd</sub> Concentration (µg/dscm)	<2.1134E-01	<2.1210E-01	<2.0439E-01	<2.0385E-01	<2.0792E-01
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	<2.7454E-01	<2.6560E-01	<2.6065E-01	<2.5527E-01	<2.6402E-01
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.8179E-01	<2.7665E-01	<2.7872E-01	<2.7180E-01	<2.7724E-01
C <sub>sd</sub> Concentration (mg/dscm)	<2.1134E-04	<2.1210E-04	<2.0439E-04	<2.0385E-04	<2.0792E-04
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	<2.7454E-04	<2.6560E-04	<2.6065E-04	<2.5527E-04	<2.6402E-04
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.8179E-04	<2.7665E-04	<2.7872E-04	<2.7180E-04	<2.7724E-04
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	<1.1022E-01	<1.1078E-01	<1.0572E-01	<1.0588E-01	<1.0815E-01
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	<2.2680E-01	<2.2762E-01	<2.1935E-01	<2.1876E-01	<2.2313E-01
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.9463E-01	<2.8504E-01	<2.7972E-01	<2.7395E-01	<2.8333E-01
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.0241E-01	<2.9689E-01	<2.9911E-01	<2.9168E-01	<2.9752E-01
E <sub>lb/hr</sub> Rate (lb/hr)	<8.3412E-05	<8.2084E-05	<8.1943E-05	<8.2371E-05	<8.2452E-05
E <sub>g/s</sub> Rate (g/s)	<1.0508E-05	<1.0341E-05	<1.0323E-05	<1.0377E-05	<1.0387E-05
E <sub>T/yr</sub> Rate (Ton/yr)	<3.6534E-04	<3.5953E-04	<3.5891E-04	<3.6078E-04	<3.6114E-04
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	<2.4670E-07	<2.3866E-07	<2.3421E-07	<2.2938E-07	<2.3724E-07
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	<2.6688E-07	<2.6202E-07	<2.6398E-07	<2.5742E-07	<2.6258E-07
<b>Mercury Results - HCl Rinse + HCl/MnO2 Precipitate</b>					
C <sub>sd</sub> Concentration (lb/dscf)	<1.0558E-11	<1.0596E-11	<1.0211E-11	<1.0184E-11	<1.0387E-11
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	<1.3716E-11	<1.3269E-11	<1.3021E-11	<1.2753E-11	<1.3190E-11
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.4077E-11	<1.3821E-11	<1.3924E-11	<1.3578E-11	<1.3850E-11
C <sub>a</sub> Concentration (lb/acf)	<5.5061E-12	<5.5345E-12	<5.2817E-12	<5.2894E-12	<5.4030E-12
C <sub>sd</sub> Concentration (µg/dscm)	<1.6907E-01	<1.6968E-01	<1.6351E-01	<1.6308E-01	<1.6634E-01
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	<2.1964E-01	<2.1248E-01	<2.0852E-01	<2.0421E-01	<2.1121E-01
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.2543E-01	<2.2132E-01	<2.2297E-01	<2.1744E-01	<2.2179E-01
C <sub>sd</sub> Concentration (mg/dscm)	<1.6907E-04	<1.6968E-04	<1.6351E-04	<1.6308E-04	<1.6634E-04
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	<2.1964E-04	<2.1248E-04	<2.0852E-04	<2.0421E-04	<2.1121E-04
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.2543E-04	<2.2132E-04	<2.2297E-04	<2.1744E-04	<2.2179E-04
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	<8.8173E-02	<8.8628E-02	<8.4580E-02	<8.4703E-02	<8.6521E-02
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	<1.8144E-01	<1.8210E-01	<1.7548E-01	<1.7501E-01	<1.7851E-01
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.3571E-01	<2.2803E-01	<2.2377E-01	<2.1916E-01	<2.2667E-01
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.4192E-01	<2.3752E-01	<2.3929E-01	<2.3335E-01	<2.3802E-01
E <sub>lb/hr</sub> Rate (lb/hr)	<6.6730E-05	<6.5667E-05	<6.5554E-05	<6.5897E-05	<6.5962E-05
E <sub>g/s</sub> Rate (g/s)	<8.4063E-06	<8.2725E-06	<8.2583E-06	<8.3014E-06	<8.3096E-06
E <sub>T/yr</sub> Rate (Ton/yr)	<2.9228E-04	<2.8762E-04	<2.8713E-04	<2.8863E-04	<2.8891E-04
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	<1.9736E-07	<1.9093E-07	<1.8737E-07	<1.8350E-07	<1.8979E-07
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	<2.1351E-07	<2.0962E-07	<2.1118E-07	<2.0594E-07	<2.1006E-07

010914 140047  
 PLK\_P\_0

WHEELABRATOR NORTH BROWARD, INC.  
POMPANO BEACH, FL

Client Reference No: Service Agreement  
CleanAir Project No: 12218-7

**QA/QC DATA**

D

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: MR

Date: 1/15/14



**This Page Intentionally Left Blank**

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

### USEPA Method 29 (Mercury) QA/QC Results

Run No.	1	2	3	4
Date (2013)	Dec 10	Dec 11	Dec 11	Dec 11
Start Time (approx.)	12:24	08:09	10:42	13:14
Stop Time (approx.)	14:34	10:21	12:54	15:25
Total Duration of Test Run (min.)	130	132	132	131
Net Sampling Time (min.)	125	125	125	125

#### Sampling System Calibration Summary

$D_n$	Nozzle ID No:	275-1	275-1	275-1	275-1
	Nozzle Diameter (in):	0.275	0.275	0.275	0.275
$C_p$	Probe ID No:	66-8-1	66-8-1	66-8-1	66-8-1
	Pitot Coefficient:	0.814	0.814	0.814	0.814
$Y_d$	Meter Box ID. No:	66-20	66-20	66-20	66-20
	Meter Box Yd - Field Sheet	1.0031	1.0031	1.0031	1.0031
	Meter Box Yd - Database	1.0031	1.0031	1.0031	1.0031
	Meter Box $\Delta H@$ - Field Sheet	1.7992	1.7992	1.7992	1.7992
	Meter Box $\Delta H@$ - Database	1.7992	1.7992	1.7992	1.7992

#### QA/QC

##### Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0278	0.0271	0.0286	0.0287
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0050	0.0030	0.0040	0.0030

##### Sample Volume

$V_{mstd}$	Minimum Volume Required (dscf)	60.00	60.00	60.00	60.00
	Actual Sample Volume (dscf)	83.538	83.239	86.378	86.609

##### Alternative Method 5 Post-Test Calibration (EPA ALT-009)

$\sqrt{\Delta H}_{avg}$	Average of Square Root of $\Delta H$ (in. W.C.)	1.2623	1.2402	1.2929	1.2966
$Y_{qa}$	Alternative Meter Calibration Factor	1.0198	1.0174	1.0125	1.0154
	Variation from full-test $Y_d$ (average $\leq \pm 5\%$ )	1.7%	1.4%	0.9%	1.2%
					<b>Average 1.3%</b>

##### Mean Isokinetic Sampling Rate Variation

	Minimum Allowable (%)	90	90	90	90
	Maximum Allowable (%)	110	110	110	110
%I	Actual Variation (%)	98.70	100.20	100.47	99.74

##### Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0	0
	Number of points >110%	0	0	0	0
	Number of points <80%	0	0	0	0
	Number of points >120%	0	0	0	0

D10314 123748  
 O O I P



# Nozzle Calibration Sheet


Client: <i>Wheelabrator NORTH</i>	Project Number: <i>12218</i>
Calibrated by: <i>D<sup>2</sup></i>	Unit: <i>1</i>
Date: <i>12/11/13</i>	Runs: <i>ALL</i>

Nozzle Identification	D <sub>1</sub> (inches)	D <sub>2</sub> (inches)	D <sub>3</sub> (inches)	ΔD (inches)	D <sub>ave</sub> (inches)
<i>.275-1</i>	<i>0.275</i>	<i>0.276</i>	<i>0.275</i>	<i>0.001</i>	<i>0.275</i>

D<sub>1</sub>, D<sub>2</sub>, D<sub>3</sub> = three nozzle diameter measurements


ΔD = maximum difference between any two diameters  
ΔD = 0.004 inches\*

D<sub>ave</sub> = average of D<sub>1</sub>, D<sub>2</sub>, D<sub>3</sub>



\* (40 CFR 60, Appendix A, Method 5, Section 5.1)


# Clean Air Engineering - Meter Box Full Test Calibration

**Client:** Source                      **Reviewed By:** R. REDEL                      **Calibration Signature:**   
**ID No:** 66-20                          **Calibrated By:** J. Ivens                      **Meter Box Yd:** 1.0031  
**Dept No:** 66                              **Date of Calibration:** 03/12/13                      **Meter Box ΔH@:** 1.7992  
**Meter Box Serial No:** 66-20                      **Due Date of Calibration:** 03/13/13                      **Barometer Serial No:** W12637  
**Manufacturer Part No:** 0028                      **Meter Box Vacuum:** 1.0 in. H<sub>2</sub>O                      **Barometric Pressure:** 29.10 in. Hg

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y <sub>ds</sub>	Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	T <sub>is</sub> In	T <sub>os</sub> Out	T <sub>ds</sub> Avg.	T <sub>i</sub> In	T <sub>o</sub> Out	T <sub>d</sub> Avg.	Θ	Y <sub>d</sub>	ΔH@
0.389	0.50	-1.20	1.0000	0.000	5.000	5.000	207.700	212.795	5.095	65.0	65.0	65.00	82.0	80.0	81.00	12.58	1.0069	1.7710
0.389	0.50	-1.20	1.0000	0.000	5.000	5.000	212.795	217.883	5.088	65.0	65.0	65.00	82.0	79.0	80.50	12.57	1.0074	1.7714
0.669	1.50	-1.50	1.0000	0.000	10.000	10.000	231.600	241.831	10.231	65.0	65.0	65.00	86.0	80.0	83.00	14.61	1.0033	1.7915
0.669	1.50	-1.50	1.0000	0.000	10.000	10.000	241.831	252.066	10.235	65.0	65.0	65.00	86.0	80.0	83.00	14.61	1.0029	1.7915
0.936	3.00	-1.80	1.0000	0.000	10.000	10.000	178.902	187.162	10.280	64.0	64.0	64.00	88.0	80.0	84.00	10.47	0.9997	1.8331
0.935	3.00	-1.80	1.0000	0.000	10.000	10.000	187.162	197.433	10.271	64.0	64.0	64.00	88.0	80.0	84.00	10.48	0.9985	1.8366
Averages																	1.00313	1.79918

Nomenclature	Equations
P <sub>b</sub> Barometric Pressure (in. Hg) Q Flow Rate (cfm) ΔH Orifice Pressure differential (in. H <sub>2</sub> O) ΔP Inlet Pressure Differential (in. H <sub>2</sub> O) V <sub>d</sub> Gas Meter Volume - Dry (ft <sup>3</sup> ) V <sub>ds</sub> Standard Meter Volume - Dry (ft <sup>3</sup> ) T <sub>d</sub> Average Meter Box Temperature (°F) T <sub>o</sub> Outlet Meter Box Temperature (°F) T <sub>ds</sub> Average Standard Meter Temperature (°F) Y <sub>d</sub> Meter Correction Factor (unitless), Y <sub>i</sub> ≤ Y <sub>avg</sub> ± 0.02 Y <sub>ds</sub> Standard Meter Correction Factor (unitless) ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H <sub>2</sub> O) ΔH@ ≤ ΔH@ <sub>avg</sub> ± 0.2 Θ Duration of Run (minutes)	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Average YD vs. Average CFM



Average CFM

Vacuum Gauge

Standard (in.Hg)	Gauge (in.Hg)
4.5	5.0
9.4	10.0
14.0	15.0
19.0	20.0
24.0	25.0

Calibration Reference Information (Standard Meter)			
Reference Used:	<u>Wet Test Meter</u>	Serial No:	<u>11AG9</u>
Calibrated By:	<u>Martin Vaquero</u>	Date Calibrated:	<u>7/22/2012</u>
Percent Error:	<u>0.245%</u>	Calibration Due Date:	<u>7/23/2013</u>

Meter Box Pre-Calibration Inspection			
Positive Leak Check:	Pass	Electrical Check:	Pass
Negative Leak Check:	Pass	Pyrometer Check:	Pass
Vacuum Gauge Check:	Pass	YD Tolerance:	Pass



# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-20 Office: n/a  
 Calibrated by: J. Ivens Client: n/a  
 Date: 3/12/13 Job No: n/a  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6	7
50	52	51	50	52	52		
100	102	101	100	102	102		
150	152	151	150	152	152		
200	202	201	200	202	202		
250	252	251	250	252	252		
300	302	301	300	302	302		
350	352	351	350	352	352		
400	402	401	400	402	402		
450	452	451	450	452	452		
500	502	501	500	502	502		
550	552	551	550	552	552		
600	602	601	600	602	602		

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

### Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>10/18/2012</u>
Calibration Report No: <u>1000164938</u>	Calibration Due Date: <u>10/18/2013</u>

# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 66-8-1

Project Number: Browards

**Thermocouple Calibration**

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	69	69	0	0.00%	
2	200°F-250°F	248	249	-1	0.14%	%Difference ≤ 1.5

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

**Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)**

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(A)</sub> **
1	0.559	0.823	0.816	0.001
2	0.555	0.823	0.813	0.001
3	0.555	0.820	0.815	0.000
Side 'A' Average Probe C <sub>p(A)</sub> =			0.8145	0.0009

Specification  
Avg. C<sub>p</sub> Deviations ≤ 0.01

Pitot Side 'B':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(B)</sub> **
1	0.557	0.821	0.815	0.002
2	0.555	0.822	0.814	0.001
3	0.552	0.824	0.810	0.003
Side 'B' Average Probe C <sub>p(B)</sub> =			0.8130	0.0019

Specification  
Avg. C<sub>p</sub> Deviations ≤ 0.01

'A' Average C <sub>p</sub> 0.814	-	'B' Average C <sub>p</sub> 0.813	=	Difference 0.001
-------------------------------------	---	-------------------------------------	---	---------------------

Specification  
|Difference| ≤ 0.01

Does assembly meet specifications?

YES

If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

**All specifications are from EPA 600/9-76-005 section 3.**

Probe Cp= 0.814

Calibrated by: S DOOLEY

Date: 03/13/2013



# Certificate of Calibration

2032001831

Page 1 of 2

## Customer Information

**On Site Calibration**  
 CleanAir Engineering, Inc.  
 500 W. Wood Street  
 Palatine, IL 60067

PO #: 04854-64-65800  
 Reference #: 1334648dd  
 Account #: 09352MT  
 SO #: 34648

## Instrument Identification

Instrument Id: **8028101133**  
 Noun: Scale, 4100/0.1 Gram Digital  
 Mfr: Ohaus  
 Accuracy:  $\pm 0.1$  Gram repeatability,  $\pm 0.3$  Linearity

Location:  
 Model: AV4101C  
 Serial #: 8028101133

## Certification Information

Reason For Service: Calibration with Data  
 Type Of Calibration: Normal  
 As Found Condition: In Tolerance  
 As Left Condition: Left As Found  
 Procedure: 33K6-4-41-1 : Scales

Technician: Oscar Trinidad, Jr  
 Cal Date: 22 JUL 13  
 Cal Due: 22 JUL 14  
 Temperature: 26.0 °C  
 Humidity: 46.0 %

✓ In Tolerance    ✗ Out of Tolerance

## Calibration Data

Range	Nominal	As Found	As Left	Min	Max
Plate Repeatability					
Center	5.0	5.0	✓ As Found	4.9	5.1
Left Rear	5.0	5.0	✓ As Found	4.9	5.1
Right Rear	5.0	5.0	✓ As Found	4.9	5.1

*No sampling plan or other procedure was used for this calibration. Measurements and information on this certificate are valid at time of calibration only and any number of factors may cause calibration to drift out of tolerance prior to calibration due date.*

*This instrument has been calibrated using standards with accuracies traceable to the National Institute of Standards and Technology, derived from natural physical constants, from ratio measurements, or compared to consensus standards.*

*The expanded uncertainty of the measurement process has not exceeded 25% of the tolerance allowed for the individual characteristics measured, unless otherwise stated. The uncertainties are based on a 95% confidence level, K=2.*

*J.H. Metrology Co., Inc's Calibration Control System complies with applicable requirements of ANSI Z540-1-1994, ISO 9001, and ISO/IEC 17025-2005.*

*The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without the written approval of J.H. Metrology Co., Inc.*

*[Signature]*  
 Approved by: Vice President

Printed: 7/31/2013 13:46:42

Date: Jul 29, 2013



METROLOGY

# Certificate of Calibration

2032001831

Page 2 of 2

✓ In Tolerance   ✗ Out of Tolerance

Calibration Data							
Range	Nominal	As Found	As Left	Min	Max		
Plate Repeatability							
Left Front	5.0	5.0	✓	As Found	4.9	5.1	
Right Front	5.0	5.0	✓	As Found	4.9	5.1	
Center	5.0	5.0	✓	As Found	4.9	5.1	
Linearity							
4100 Grams	100.0	100.0	✓	As Found	99.7	100.3	
	2000.0	1999.9	✓	As Found	1999.7	2000.3	
	4000.0	3999.8	✓	As Found	3999.7	4000.3	

End of Datasheet

## Calibration Standards

<u>NIST Traceable #</u>	<u>Instrument ID#</u>	<u>Description</u>	<u>Model</u>	<u>Calibration Date</u>	<u>Date Due</u>
1000166191	00941	Metric Weight Set, 12 Piece, Class 2	Unknown	19 MAR 2013	31 MAR 2015
1000166195	01088	Weight Set, 1mg - 200g, Class 1	Unknown	19 MAR 2013	31 MAR 2015
1000168221	01195	RH/Temperature Data Logger	EL-USB-2-LCD	20 MAY 2013	31 MAY 2014

*No sampling plan or other procedure was used for this calibration. Measurements and information on this certificate are valid at time of calibration only and any number of factors may cause calibration to drift out of tolerance prior to calibration due date.*

*This instrument has been calibrated using standards with accuracies traceable to the National Institute of Standards and Technology, derived from natural physical constants, from ratio measurements, or compared to consensus standards.*

*The expanded uncertainty of the measurement process has not exceeded 25% of the tolerance allowed for the individual characteristics measured, unless otherwise stated. The uncertainties are based on a 95% confidence level, K=2.*

*J.H. Metrology Co., Inc's Calibration Control System complies with applicable requirements of ANSI Z540-1-1994, ISO 9001, and ISO/IEC 17025-2005.*

*The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without the written approval of J.H. Metrology Co., Inc.*

*Deborah M. Kline*  
 Approved by:      Vice President

Printed: 7/31/2013 13:46:42

Date: Jul 29, 2013

**This Page Intentionally Left Blank**

WHEELABRATOR NORTH BROWARD, INC.  
POMPANO BEACH, FL

Client Reference No: Service Agreement  
CleanAir Project No: 12218-7

**FIELD DATA**

E

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: WPC

Date: 1/18/14





**This Page Intentionally Left Blank**

TEST LOCATION: FF Outlet

UNIT: 1

RUN: 1

Mercury TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 1 OF 2

Client: laboratory Project No. 12218  
 Plant: Broward Date 12/10/13  
 Meter Operator: P. Bihy  
 Probe Operator: P. Bihy

Meter Box: 66-20 Sample Box No. M11  
 Meter Yr: 10031 Meter ΔH: 1.7932  
 K Factor: 2.70 Pitot Co: 0.814  
 Leak Rate Before: 1004 (cm) [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 1005 (cm) [Lpm] @ 15 (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad

Cross-Section of Test Location

Duct Dimensions (in.): 96 x 96

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (in) [Out]	First point all the way (in) [Out]
<u>-10.10/10.0</u>			

Amb. Temp. (°F) 83 Bar. Press. 30.14 (in. Hg) [mbar]  
 Probe I.D. No. 106-8-1  
 Liner Material: Glass

Filter No. N/A  
 Thimble No. P1A  
 Nozzle Diameter 0.275 Nozzle I.D. 275-1

Start Time: 12:24 Stop Time: 14:34

Traverse Point Number	Min/pi 5 Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub>		Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (% dv)	<input type="checkbox"/> Amb Filter <input type="checkbox"/> Dioxin Trap	Notes
				Init. Vol.	(in) [L]										
				749.200			210	210							
5-1	5	0.46	1.2	752.26		311	251	252	66	89	87	6.5	10.0	N/A	
2	10	0.54	1.5	755.61		311	280	282	66	89	87	7.5	10.0		
3	15	0.54	1.5	758.95		309	283	280	65	92	88	7.5	10.0		
4	20	0.65	1.8	762.60		311	287	287	65	94	88	9.0	9.5		
5	25	0.60	1.6	766.125		311	251	254	65	97	89	8.5	8.5		766.225
4-1	30	0.57	1.5	769.60		311	249	249	65	96	90	7.5	9.7		(-0.10)
2	35	0.53	1.4	772.87		311	248	253	57	98	90	7.5	8.9		
3	40	0.57	1.5	776.24		310	251	250	55	98	90	8.0	9.0		
4	45	0.68	1.8	779.94		310	251	249	55	100	91	9.0	9.8		
5	50	0.68	1.8	783.600		310	251	249	56	101	92	9.0	9.0		783.665
3-1	55	0.60	1.6	787.11		310	249	251	59	100	93	8.5	9.9		(-0.065)
2	60	0.52	1.4	790.41		310	249	248	65	101	93	8.0	10.2		
	Total					7725									
	Average					310.6000									

Sum of square roots.

Circle correct bracketed units on data sheet.

18.16

87.815

3725

96.4000

2233

TEST LOCATION: FF DuHd-

UNIT: 1

RUN: 1

Mercury TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 2 OF 2

Client: <u>Whitcomb</u>	Project No: <u>12214</u>
Plant: <u>By P. work</u>	Date: <u>12/10/13</u>
Meter Operator: <u>P. Bunker</u>	
Probe Operator: <u>P. Bunker</u>	

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)			
Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out]	First point all the way [In] [Out]
		of page	

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Meter Box	Sample Box No.
Meter Y <sub>d</sub>	Meter ΔH <sub>e</sub>
K Factor	Pilot C <sub>p</sub>
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pilot Leak Check Before: <input type="checkbox"/>	After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub>		Stack Temp. Ts (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (% dv)	<input type="checkbox"/> Amb Filter <input type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
				Init. Vol.	( <u>CF</u> ) [L]										
							210	212							
3	65	0.17	1.5	793.79	311	280	250	62	102	94	8.0	10.1			
4	70	0.70	1.9	797.54	313	257	250	64	102	94	10.0	10.5			
5	75	0.70	1.9	801.34	313	250	249	64	103	95	10.0	10.3			
2-1	80	0.61	1.7	804.96	311	250	251	66	102	95	8.5	10.3			
2	85	0.52	1.4	808.22	311	248	249	64	103	95	8.0	9.9			
3	90	0.57	1.5	811.58	311	257	249	62	102	95	8.1	9.4			
4	95	0.62	1.7	815.14	310	252	249	63	103	95	9.0	9.7			
5	100	0.68	1.8	818.85	311	250	249	64	104	96	10.0	9.7			
1-1	105	0.62	1.7	822.50	308	249	251	62	103	96	9.0	10.7			
2	110	0.65	1.8	826.20	311	270	257	58	105	96	10.0	10.5			
3	115	0.95	1.2	829.30	310	257	250	60	106	97	7.5	10.7			
4	120	0.52	1.4	832.58	310	250	250	62	105	97	8.0	10.5			
5	125	0.70	1.9	836.36	310	249	251	63	105	97	10.0	10.3			
Total															
Average															

\* Sum of square roots.

Circle correct bracketed units on data sheet.



E-4

TEST LOCATION: FF Outlet  
 UNIT: 1 RUN: 2


Mercury TESTING  
**FIELD DATA SHEET**

METHOD: 29 PAGE 1 OF 2

Client: Chelubator Project No. 12218  
 Plant: Mc Brown Date: 12/11/13  
 Meter Operator: P. Bihun  
 Probe Operator: P. Bihun

Meter Box: 66-20 Sample Box No.: M10  
 Meter Ya: 10031 Meter ΔH: 17992  
 K Factor: 2.7 Pitot Co: 0.814

Leak Rate Before: 0.003 [Cfm] [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 0.003 [Cfm] [Lpm] @ 15 (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad



Amb. Temp. (°F): 75 Bar. Press.: 30.16 (in. Hg) (mbar)  
 Probe I.D. No.: 66-8-1  
 Liner Material: Glass

Filter No.: N/A  
 Thimble No.: N/A  
 Nozzle Diameter: 0.225 Nozzle I.D.: 0.225-1

Start Time: 8:09 Stop Time: 10:21

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (L)	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>in</sub> (°F)	DGM Outlet T <sub>out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (% dv)	<input type="checkbox"/> Amb Filter <input type="checkbox"/> Dioxin Trap	Notes
						Set Points	Set Points								
1	5	0.48	1.3	836.770	310	247	248	67	75	75	8.0	10.6	N/A		
2	10	0.55	1.5	843.23	310	248	249	60	78	76	8.5	9.5			
3	15	0.60	1.6	846.67	311	248	243	60	81	77	9.5	10.5			
4	20	0.60	1.6	850.10	310	247	251	59	84	78	10.0	9.4			
5	25	0.62	1.7	853.605	311	248	247	59	85	79	10.0	9.7		853.605	
4-1	30	0.52	1.4	856.94	309	249	248	60	84	78	8.5	9.7		(-0.09)	
2	35	0.49	1.3	860.10	310	249	247	60	85	80	8.0	10.1			
3	40	0.53	1.4	863.36	309	249	249	61	86	80	8.5	10.5			
4	45	0.58	1.6	866.80	311	249	257	6.0	86	80	9.5	9.0			
5	50	0.67	1.8	870.380	310	247	249	61	86	81	10.0	9.7		870.465	
3-1	55	0.55	1.5	873.81	309	250	250	63	86	81	9.0	9.0		(-0.08)	
2	60	0.47	1.3	877.09	310	250	250	64	86	81	8.0	10.6			
Total		188.07	38.6	85005	725					4238					
Average		0.7546	1.5440	85005	310.0400					84.7600					1908

Sum of square roots: 18.0

Circle correct bracketed units on data sheet: 84.650

3120

QA/QC: PB  
 Date: 12/11/13




TEST LOCATION: FF Outlet

Mercury TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 2 OF 2

UNIT: 1 RUN: 2

Client: <u>Wheeler Foods</u>	Project No: <u>17218</u>
Plant: <u>N. Broward</u>	Date: <u>12/11/13</u>
Meter Operator: <u>P. Bikun</u>	
Probe Operator: <u>P. Bikun</u>	



Amb. Temp. (°F)	Bar. Press. (in. Hg) [mbar]
Probe I.D. No.	
Liner Material	

Meter Box	Sample Box No.
Meter Y <sub>d</sub>	Meter ΔH <sub>g</sub>
K Factor	Pitot C <sub>p</sub>

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Leak Rate Before (cfm) [Lpm] @ (in. Hg)	
Leak Rate After (cfm) [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Duct Dimensions (in.)			
Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (In) [Out]	First point all the way (In) [Out]

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/rpt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (L)	Stack Temp Ts (°F)	Probe T <sub>p</sub> (°F)		Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (% dv)	<input type="checkbox"/> Amb Filter <input type="checkbox"/> Dioxin Trap	Notes
						Set Points									
3	65	0.57	1.5	880.40	311	249	249	51	88	82	8.5	9.7			
4	70	0.67	1.8	881.02	310	247	248	51	87	82	10.0	9.4			
5	75	0.70	1.9	887.740	310	245	249	53	90	82	11.0	9.7			
2-1	80	0.79	1.6	891.28	310	249	251	57	89	83	9.5	9.8		887.831	
2	85	0.96	1.2	894.33	311	249	243	59	91	84	8.0	10.6			
3	90	0.55	1.5	897.63	310	248	246	61	91	86	9.0	8.9			
4	95	0.63	1.7	901.18	311	247	248	62	94	86	10.0	9.3			
5	100	0.70	1.9	904.920	311	247	246	64	94	86	11.0	10.3		905.005	
1-1	105	0.53	1.4	908.27	309	249	248	62	90	87	8.5	10.1		-0.085	
2	110	0.51	1.4	911.52	309	249	251	61	91	87	8.5	9.5			
3	115	0.50	1.4	914.77	309	251	250	61	92	87	8.5	9.0			
4	120	0.55	1.5	918.11	310	251	249	62	93	87	9.0	9.3			
5	125	0.61	1.8	921.725	310	250	250	63	94	87	11.0	8.8			
Total															
Average															

Sum of square roots.

Circle correct bracketed units on data sheet.



TEST LOCATION: FF-Outlet


Mercury TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 1 OF 2

UNIT: 1 RUN: 3

Client: Whelan Project No: 1228  
Plant: D. Brunard Date: 12/11/13  
Meter Operator: P. Bihun  
Probe Operator: P. Bihun

Meter Box: 66-20 Sample Box No: M11  
Meter Yd: 1.0031 Meter ΔH: 12922  
K Factor: 2.70 Pilot Cp: 0.814  
Leak Rate Before: 0.0036 (lpm) @ 15 (in. Hg)  
Leak Rate After: 0.004 (lpm) @ 15 (in. Hg)  
Pilot Leak Check Before:  After: Good  Bad



Amb. Temp. (°F): 28 Bar. Press: 30.16 (in. Hg) (mbar)  
Probe I.D. No: 66-8-1  
Liner Material: Glass

Filter No: N/A  
Thimble No: N/A  
Nozzle Diameter: 0.275 Nozzle I.D.: 275-1

Start Time: 10:42 Stop Time: 12:14

Traverse Point Number	Min/pi Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub>		Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (%dv)	<input type="checkbox"/> Amb Filter <input type="checkbox"/> Dioxin Trap	Notes
				Init. Vol.	[L]										
				922.100			280	272							
1-1	5	0.53	1.4	925.42		311	286	255	64	91	91	6.5	10.2		N/A
2	10	0.57	1.4	928.70		309	284	257	66	93	90	6.5	9.6		
3	15	0.42	1.1	931.58		307	251	250	60	94	90	5.5	8.9		
4	20	0.52	1.4	934.86		306	287	251	61	96	91	6.5	9.6		
5	25	0.70	1.9	938.675		310	280	251	63	97	92	8.0	10.3		938.700
2-1	30	0.72	1.9	942.61		310	280	253	64	97	92	8.0	9.7		(-0.02)
2	35	0.55	1.5	946.07		310	288	250	65	98	92	7.0	9.8		
3	40	0.58	1.6	949.58		309	251	251	62	98	92	7.0	9.2		
4	45	0.62	1.7	953.17		310	257	250	58	101	93	7.5	9.0		
5	50	0.72	1.9	956.965		311	280	251	59	102	93	8.0	9.3		957.235
3-1	55	0.66	1.8	960.73		309	289	250	62	101	93	8.0	10.2		(-0.07)
2	60	0.60	1.6	964.24		310	280	250	63	100	92	7.5	9.5		
	Total	19.6620		89.480		3744				4285					
	Average	0.7865	1.5800			30.6400				95.1000					

Sum of square roots.

Circle correct bracketed units on data sheet.

19.2

3712

2269



TEST LOCATION: TF Outlet  
 UNIT: 1 RUN: 3

Mercury TESTING  
**FIELD DATA SHEET**

METHOD: 29 PAGE 2 OF 2

Client: <u>W. K. ...</u>	Project No.: <u>12218</u>
Plant: <u>W. Brown</u>	Date: <u>12/11/13</u>
Meter Operator: <u>P. Bihun</u>	
Probe Operator: <u>P. Bihun</u>	

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.):

Static Pres (in. H <sub>2</sub> O)	Port Len (in.)	Gas Flow (In) [Out]	First point all the way (In) [Out]

of page

Amb. Temp. (°F)	Bar. Press. (in. Hg) [mbar]
Probe I.D. No.	
Liner Material	

Meter Box	Sample Box No.
Meter Y <sub>0</sub>	Meter ΔH <sub>0</sub>
K <sub>i</sub> Factor	Pitot C <sub>p</sub>
Leak Rate Before (cfm) [Lpm] @ (in. Hg)	
Leak Rate After (cfm) [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (L)	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	<input type="checkbox"/> Amb Filter <input type="checkbox"/> Dioxin Trap	Notes
						Set Points	Set Points							
3	65	0.62	1.7	967.85	310	250	249	63	99	92	7.5	9.7		
4	70	0.70	1.9	971.65	310	251	249	64	99	92	8.5	9.2		975.56P
5	75	0.72	1.9	975.470	310	251	250	64	100	92	8.5	9.7		(0.085)
4-1	80	0.58	1.6	979.07	310	250	250	64	98	92	7.0	9.9		
2	85	0.55	1.5	982.49	310	251	249	60	99	92	7.0	9.5		
3	90	0.63	1.7	986.08	309	251	249	60	99	92	7.5	9.6		
4	95	0.73	2.0	989.96	308	250	250	61	98	92	9.0	9.7		
5	100	0.72	1.9	993.760	310	251	250	62	99	91	8.5	10.6		993.84K
5-1	105	0.55	1.5	997.21	310	249	250	64	99	92	7.5	9.5		(0.085)
2	110	0.53	1.4	1000.57	311	249	249	64	99	92	7.5	9.4		
3	115	0.65	1.8	1004.22	310	251	249	62	99	92	8.5	9.9		
4	120	0.70	1.9	1008.01	311	250	250	62	101	92	9.0	10.3		
5	125	0.73	2.0	1011.905	310	249	248	67	102	92	9.0	10.1		
Total														
Average														

Sum of square roots. Circle correct bracketed units on data sheet.



TEST LOCATION: FF Outlet


UNIT: 1 RUN: 4

Mercury TESTING  
FIELD DATA SHEET

METHOD: 29 PAGE 1 OF 2

Client <u>Whitcomb</u>	Project No. <u>72218</u>
Plant <u>A2 Broward</u>	Date <u>12/11/13</u>
Meter Operator <u>P. Bishop</u>	
Probe Operator <u>P. Bishop</u>	

Meter Box <u>66-20</u>	Sample Box No. <u>M.V.</u>
Meter Y <sub>0</sub> <u>1.0031</u>	Meter ΔH <sub>0</sub> <u>1.2922</u>
K Factor <u>2.70</u>	Pitot C <sub>p</sub> <u>0.814</u>
Leak Rate Before <u>0.003</u> [cm] [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.003</u> [cm] [Lpm] @ <u>15</u> (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	



Duct Dimensions (in.) <u>36 x 96</u>			
Static Pres (in. H <sub>2</sub> O) <u>-11.2</u>	Port Len. (in.) <u>10.0</u>	Gas Flow (ft <sup>3</sup> ) [Out] of page <u>10.0</u>	First point all the way (ft) [Out] <u>10.0</u>

Amb. Temp. (°F) <u>78</u>	Bar. Press. <u>30.16</u> (in. Hg) [mbar]
Probe I.D. No. <u>66-5-1</u>	
Liner Material <u>Glass</u>	

Filter No. <u>N/A</u>	
Thimble No. <u>N/A</u>	
Nozzle Diameter <u>0.275</u>	Nozzle I.D. <u>275-1</u>

Start Time: <u>13:14</u>	Stop Time: <u>15:25</u>
--------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>r</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (% dv)	<input type="checkbox"/> Amb Filter <input type="checkbox"/> Dioxin Trap	Notes
						Set Points								
5-1	5	0.63	1.7	16.21	311	250	251	67	93	90	9.5	10.2	N/A	
2	10	0.60	1.6	19.70	311	254	253	65	94	90	9.0	9.8		
3	15	0.70	1.9	23.49	311	252	255	60	95	90	10.5	10.5		
4	20	0.73	2.0	27.35	310	252	249	60	96	90	11.0	9.7		
5	25	0.73	2.0	31.275	311	250	249	62	96	90	11.0	10.5		31.350
4-1	30	0.57	1.5	34.75	310	280	250	64	96	90	9.0	9.4		(0.075)
2	35	0.58	1.6	38.24	310	244	251	64	96	90	9.5	9.6		
3	40	0.70	1.9	42.01	310	257	249	60	97	90	11.0	10.0		
4	45	0.73	2.0	45.90	311	251	250	58	98	90	11.0	10.6		
5	50	0.71	1.9	49.735	312	250	250	58	97	90	11.5	10.5		49.825
3-1	55	0.72	1.9	53.66	311	249	250	61	97	90	11.5	10.4		(-0.09)
2	60	0.59	1.6	57.23	312	250	252	61	98	91	10.0	10.2		
Total		19.7503	12.3	89.600					4719					
Average		0.7900	1.6920		310	3000			94.3800					

Sum of square-roots.

Circle correct bracketed units on data sheet.

21.6

3730

2234



6-E



TEST LOCATION: FF Outlet Mercury TESTING METHOD: 29 PAGE 2 OF 2  
 UNIT: 1 RUN: 4 FIELD DATA SHEET

Client Wachovia Project No. 12218  
 Plant M. Broward Date 12/11/13  
 Meter Operator P. Bigham  
 Probe Operator P. Bigham

Meter Box \_\_\_\_\_ Sample Box No. \_\_\_\_\_  
 Meter Y<sub>d</sub> \_\_\_\_\_ Meter ΔH<sub>@</sub> \_\_\_\_\_  
 K Factor \_\_\_\_\_ Pitot C<sub>p</sub> \_\_\_\_\_  
 Leak Rate Before [cfm] [Lpm] @ \_\_\_\_\_ (in. Hg)  
 Leak Rate After [cfm] [Lpm] @ \_\_\_\_\_ (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out]	First point all the way [In] [Out]
			of page

Amb. Temp. (°F) \_\_\_\_\_ Bar. Press. \_\_\_\_\_ [in. Hg] [mbar]  
 Probe I.D. No. \_\_\_\_\_  
 Liner Material \_\_\_\_\_

Filter No. \_\_\_\_\_  
 Thimble No. \_\_\_\_\_  
 Nozzle Diameter \_\_\_\_\_ Nozzle I.D. \_\_\_\_\_

Start Time: \_\_\_\_\_ Stop Time: \_\_\_\_\_

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>r</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (%dv)	<input type="checkbox"/> Amb Filter <input type="checkbox"/> Dioxin Trap <input type="checkbox"/> _____	Notes
						Set Points								
3	65	0.60	1.6	60.78	312	252	249	61	98	91	10.0	8.7		
4	70	0.65	1.8	64.48	310	251	250	62	98	91	10.5	8.2		
5	75	0.73	2.0	68.35	309	250	251	62	99	91	12.0	9.3		
2-1	80	0.69	1.7	71.98	309	250	254	64	99	92	10.0	9.5		68.440 -0.09
2	85	0.52	1.4	75.32	309	250	251	64	100	92	9.0	9.7		
3	90	0.45	1.2	78.45	309	250	246	65	100	92	8.5	9.2		
4	95	0.57	1.5	81.81	310	250	251	66	100	92	9.5	10.2		
5	100	0.73	2.0	85.86	312	249	250	63	101	93	11.5	9.9		85.635 -0.07
1-1	105	0.53	1.4	88.92	309	250	253	63	99	92	9.0	10.2		
2	110	0.60	1.6	92.39	310	250	247	58	99	92	10.0	10.5		
3	115	0.42	1.1	95.36	310	251	250	59	100	92	8.0	9.9		
4	120	0.53	1.4	98.62	310	250	248	60	99	92	9.0	9.3		
5	125	0.73	2.0	102.47	310	250	250	60	99	92	12.0	9.5		
Total														
Average														

Sum of square roots.

Circle correct bracketed units on data sheet.



E-10

# Impinger Weight Sheet

Client   Wheelabrator	Unit Name / Location   Unit 1 FF Outlet
Plant   North Broward	Job No.   12118
	Method   29

Balance Calibration Check			
Balance ID.	8028101133	Reference Weight Mass.	1000.0
Reference Weight ID	68152	Reference Weight Reading	1000.0

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No.	1	Filter Type   Quartz	Sample Box No.	M11
Date	12/10/13	Lot No.   NA	pH	NA
Analyst	D^2	Filter No.   Untared	Rinse	NA

	Contents.	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	778.4	440.8	337.6	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	674.3	552.1	122.2	QA/QC   D^2
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	588.3	<del>546.2</del> 563.6	247	Date   12/10
Impinger 4	Empty	457.4	452.0	5.4	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	550.8	547.9	2.9	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	552.4	551.0	1.4	494.2
Impinger 7	≈ 250 g Silica Gel	772.5	753.2	19.3	513.5

Run No.	2	Filter Type   Quartz	Sample Box No.	M10
Date	12/11/13	Lot No.   NA	pH	NA
Analyst	D^2	Filter No.   Untared	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	775.3	436.9	338.4	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	669.0	544.8	124.2	QA/QC   D^2
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	550.6	525.2	25.4	Date   12/11
Impinger 4	Empty	444.7	439.1	5.6	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	556.9	553.8	3.1	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	535.7	534.4	1.3	498
Impinger 7	≈ 250 g Silica Gel	721.3	701.7	19.6	517.6

Run No.	3	Filter Type   Quartz	Sample Box No.	M11
Date	12/11/13	Lot No.   NA	pH	NA
Analyst	D^2	Filter No.   Untared	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	776.1	442.2	333.9	0
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	693.1	540.1	153.0	0
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	578.7	549.9	28.8	0
Impinger 4	Empty	460.7	453.2	7.5	0
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	557.5	553.3	4.2	0
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	556.4	552.8	3.6	0
Impinger 7	≈ 250 g Silica Gel	777.2	756.8	20.4	0

QA/QC | D^2  
Date | 12/11/13



# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 1 FF Outlet	
Plant North Broward	Job No. 12118	Method	29

Balance Calibration Check			
Balance ID	8028101133	Reference Weight Mass	1010.0
Reference Weight ID	60152	Reference Weight Reading	1000.1

Check must be performed at least Once per Method per Job      Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No.	4	Filter Type Quartz	Sample Box No. M10
Date	12/11/13	Lot No. NA	pH NA
Analyst	D^2	Filter No. Untared	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	100 ml 0.1 N H2SO4	785.9	437.9	348.0	QA/QC D^2 Date 12/11
Impinger 2	100 ml 0.1 N H2SO4	709.1	549.1	160.0	
Impinger 3	Empty	536.6	525.4	11.2	
Impinger 4	Empty	443.5	440.6	2.9	Total Weight (gm) 524.3
Impinger 5	100 ml 4%KMnO4/10%H2SO4	542.6	543.0	-0.4	
Impinger 6	100 ml 4%KMnO4/10%H2SO4	557.5	554.9	2.6	
Impinger 7	≈ 250 g Silica Gel	737.4	720.9	16.5	
					540.8

Run No.		Filter Type	Sample Box No.
Date		Lot No.	pH
Analyst	D^2	Filter No.	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1					QA/QC Date
Impinger 2					
Impinger 3					
Impinger 4					Total Weight (gm)
Impinger 5					
Impinger 6					
Impinger 7					

Run No.		Filter Type	Sample Box No.
Date		Lot No.	pH
Analyst	D^2	Filter No.	Rinse

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1				0	QA/QC Date
Impinger 2				0	
Impinger 3				0	
Impinger 4				0	Total Weight (gm)
Impinger 5				0	
Impinger 6				0	
Impinger 7				0	

QA/QC D^2  
Date 12/11/13



# ORSAT READINGS

TEST LOCATION: UNIT 1 FF outlet

PAGE 1 OF 1

Client <u>Wheelabrator, NORTH</u>	Project Number <u>12218</u>	$F_o = \frac{20.9 - \%O_2}{\%CO_2}$
Plant <u>NORTH</u>	Unit <u>1</u>	
Orsat ID <u>#6</u>	Fuel Type <u>mw</u>	Leak Check Passed <input checked="" type="checkbox"/>

Run Number	Method Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	F <sub>o</sub>	Analyst	Analysis	
								Date	Time
1	m29	1	9.0	19.2	10.2		D <sup>2</sup>	12/10	1537
		2	9.0	19.2	10.2				
		3	9.0	19.2	10.2				
		Avg.	9.0		10.2				
2	m29	1	9.2	19.0	9.8		D <sup>2</sup>	12/11	1131
		2	9.2	19.0	9.8				
		3	9.2	19.0	9.8				
		Avg.	9.2		9.8				
3	m29	1	8.8	18.8	10.0		D <sup>2</sup>	12/11	1452
		2	8.8	18.8	10.0				
		3	8.8	18.8	10.0				
		Avg.	8.8		10.0				
4	m29	1	9.0	18.8	9.8		D <sup>2</sup>	12/11	1547
		2	9.0	18.8	9.8				
		3	9.0	18.8	9.8				
		Avg.	9.0		9.8				
		1							
		2							
		3							
		Avg.							
		1							
		2							
		3							
		Avg.							

Repeat the analysis procedure until the results of any three analyses differ by no more than 0.2 percent by volume. Average the three acceptable values and report the results to the nearest 0.1 percent. Calculate  $F_o$  to verify results

Acceptable ranges for  $F_o$ :

Coal: Anthracite and Lignite	1.016-1.130	Gas: Natural	1.600-1.836
Oil: Bituminous	1.083-1.230	Propane	1.434-1.586
Oil: Distillate	1.260-1.413	Butane	1.405-1.553
Oil: Residual	1.210-1.370	Wood	1.000-1.120
Municipal Solid Waste	1.030-1.300	Wood Bark	1.003-1.130

**This Page Intentionally Left Blank**

WHEELABRATOR NORTH BROWARD, INC.  
POMPANO BEACH, FL

Client Reference No: Service Agreement  
CleanAir Project No: 12218-7


**FIELD DATA PRINTOUTS**

F

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: MR

Date: 1/18/14



**This Page Intentionally Left Blank**

**Field Data Printout**

**Test Method:**  
**Analyte:**

**USEPA Method 29**  
**Mercury**

Location: Unit 1 FF Outlet

Test Run: 1

Client: Wheelabrator North Broward, Inc.

Project No: 12218

Source Area (ft<sup>2</sup>): 64.00000

Meter Operator:	P. Bihun	505
Probe Operator:	P. Bihun	505

Test Date: 12/10/13

Start Time: 12:24

Stop Time: 14:34

Leak Rate Before: 0.004 cfm @ 15 "Hg

Leak Rate After: 0.005 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.14

Static P: -10.6

O<sub>2</sub> (dry volume %): 10.20

CO<sub>2</sub> (dry volume %): 9.00

N<sub>2</sub>+CO (dry volume %): 80.80

Nozzle ID No: 275-1

Nozzle Diameter (D<sub>n</sub>): 0.275

Probe ID No: 66-8-1

Pitot C<sub>p</sub>: 0.814

Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 494.2

H<sub>2</sub>O (silica, g): 19.3

Actual Moisture (%): 22.44

Meter Box ID. No: 66-20

Meter ΔH@: 1.79920

Meter Y<sub>d</sub>: 1.00310

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			749.200						
5-01	5.0	0.46	1.20	752.260	311	89	87	0.68	3.06	99.9
5-02	10.0	0.54	1.50	755.610	311	89	87	0.73	3.35	101.0
5-03	15.0	0.54	1.50	758.950	309	92	88	0.73	3.34	100.2
5-04	20.0	0.65	1.80	762.600	311	94	88	0.81	3.65	99.8
5-05	25.0	0.60	1.60	766.125	311	97	89	0.77	3.52	99.9
LEAK CHECK	25.0			766.225						
4-01	30.0	0.57	1.50	769.600	311	96	90	0.75	3.38	98.2
4-02	35.0	0.54	1.40	772.870	311	98	90	0.74	3.27	97.2
4-03	40.0	0.57	1.50	776.240	310	98	90	0.75	3.37	97.8
4-04	45.0	0.68	1.80	779.940	310	100	91	0.82	3.70	98.1
4-05	50.0	0.68	1.80	783.600	310	101	92	0.82	3.66	96.8
LEAK CHECK	50.0			783.665						
3-01	55.0	0.60	1.60	787.110	310	100	93	0.77	3.45	97.0
3-02	60.0	0.52	1.40	790.410	310	101	93	0.72	3.30	99.7
3-03	65.0	0.56	1.50	793.790	311	102	94	0.75	3.38	98.3
3-04	70.0	0.70	1.90	797.540	313	102	94	0.84	3.75	97.8
3-05	75.0	0.70	1.90	801.345	313	103	95	0.84	3.81	99.0
LEAK CHECK	75.0			801.435						
2-01	80.0	0.61	1.70	804.960	311	102	95	0.78	3.53	98.2
2-02	85.0	0.52	1.40	808.220	311	103	95	0.72	3.26	98.2
2-03	90.0	0.57	1.50	811.580	311	102	95	0.75	3.36	96.8
2-04	95.0	0.62	1.70	815.140	310	103	95	0.79	3.56	98.2
2-05	100.0	0.68	1.80	818.850	311	104	96	0.82	3.71	97.6
LEAK CHECK	100.0			818.945						
1-01	105.0	0.62	1.70	822.500	308	103	96	0.79	3.55	97.8
1-02	110.0	0.65	1.80	826.200	311	105	96	0.81	3.70	99.5
1-03	115.0	0.45	1.20	829.300	310	106	97	0.67	3.10	99.8
1-04	120.0	0.52	1.40	832.580	310	105	97	0.72	3.28	98.4
1-05	125.0	0.70	1.90	836.365	310	105	97	0.84	3.78	97.9
Final	125.0		1.60000	86.81500	310.60000		96.40000	0.76934	86.81500	

25 points sampled

Sq. Rt. ΔP

QC-Check: Field Averages

0.7690	1.6000	86.8150	310.6000	96.4000
--------	--------	---------	----------	---------

Avg. OK    Avg. OK    Avg. OK    Avg. OK    Avg. OK

010914 135935  
P



**Field Data Printout**

**Test Method:**  
**Analyte:**

**USEPA Method 29**  
**Mercury**

Location: Unit 1 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator North Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: P. Bihun 505  
 Probe Operator: P. Bihun 505

Bar. Press. (in. Hg): 30.16  
 Static P: -9.5  
 O<sub>2</sub> (dry volume %): 9.80  
 CO<sub>2</sub> (dry volume %): 9.20  
 N<sub>2</sub>+CO (dry volume %): 81.00

Nozzle ID No: 275-1  
 Nozzle Diameter (D<sub>n</sub>): 0.275  
 Probe ID No: 66-8-1  
 Pitot C<sub>p</sub>: 0.814  
 Pitot Leak Check:  Pass  Fail

Test Date: 12/11/13  
 Start Time: 08:09  
 Stop Time: 10:21  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 15 "Hg

H<sub>2</sub>O (condensate, ml or gm): 498.0  
 H<sub>2</sub>O (silica, g): 19.6  
 Actual Moisture (%): 22.64

Meter Box ID. No: 66-20  
 Meter ΔH@: 1.79920  
 Meter Y<sub>g</sub>: 1.00310

Traverse Point	Run Time 5.0 min/read	Pilot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>c</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
5-01	5.0	0.48	1.30	839.960	310	75	75	0.69	3.19	104.5
5-02	10.0	0.55	1.50	843.230	310	78	76	0.74	3.27	99.8
5-03	15.0	0.60	1.60	846.670	311	81	77	0.77	3.44	100.2
5-04	20.0	0.60	1.60	850.100	310	84	78	0.77	3.43	99.5
5-05	25.0	0.62	1.70	853.605	311	85	79	0.79	3.51	99.9
LEAK CHECK	25.0			853.695						
4-01	30.0	0.52	1.40	856.940	309	84	78	0.72	3.25	101.0
4-02	35.0	0.49	1.30	860.100	310	85	80	0.70	3.16	101.1
4-03	40.0	0.53	1.40	863.360	309	86	80	0.73	3.26	100.1
4-04	45.0	0.58	1.60	866.800	311	86	80	0.76	3.44	101.2
4-05	50.0	0.67	1.80	870.380	310	86	81	0.82	3.58	97.8
LEAK CHECK	50.0			870.465						
3-01	55.0	0.55	1.50	873.810	309	86	81	0.74	3.34	100.8
3-02	60.0	0.47	1.30	877.090	310	86	81	0.69	3.28	106.9
3-03	65.0	0.57	1.50	880.400	311	88	82	0.75	3.31	97.8
3-04	70.0	0.67	1.80	884.020	310	87	82	0.82	3.62	98.8
3-05	75.0	0.70	1.90	887.740	310	90	82	0.84	3.72	99.0
LEAK CHECK	75.0			887.835						
2-01	80.0	0.59	1.60	891.280	310	89	83	0.77	3.44	99.8
2-02	85.0	0.46	1.20	894.330	311	91	84	0.68	3.05	99.8
2-03	90.0	0.55	1.50	897.630	310	91	86	0.74	3.30	98.6
2-04	95.0	0.63	1.70	901.180	311	94	86	0.79	3.55	98.9
2-05	100.0	0.70	1.90	904.920	311	94	86	0.84	3.74	98.9
LEAK CHECK	100.0			905.005						
1-01	105.0	0.53	1.40	908.270	309	90	87	0.73	3.26	99.3
1-02	110.0	0.51	1.40	911.520	309	91	87	0.71	3.25	100.6
1-03	115.0	0.50	1.40	914.770	309	92	87	0.71	3.25	101.5
1-04	120.0	0.55	1.50	918.110	310	93	87	0.74	3.34	99.5
1-05	125.0	0.67	1.80	921.775	310	94	87	0.82	3.66	98.9
Final	125.0		1.54400	84.65000	310.04000		84.76000	0.75462	84.65000	

25 points sampled  
 QC-Check: Field Averages  
 Sq.Rt.ΔP: 0.7546 1.5440 84.6500 310.0400 84.7600  
 Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

010814 135935  
L

### Field Data Printout

Location: Unit 1 FF Outlet  
 Test Run: 3  
 Client: Wheelabrator North Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: P. Bihun 505  
 Probe Operator: P. Bihun 505  
 Test Date: 12/11/13  
 Start Time: 10:42  
 Stop Time: 12:54  
 Leak Rate Before: 0.003 cfm @ 15" Hg  
 Leak Rate After: 0.004 cfm @ 15" Hg

Test Method:  
 Analyte:

USEPA Method 29  
 Mercury

Bar. Press. (in. Hg): 30.16  
 Static P: -11.2  
 O<sub>2</sub> (dry volume %): 10.00  
 CO<sub>2</sub> (dry volume %): 8.80  
 N<sub>2</sub>+CO (dry volume %): 81.20

Nozzle ID No: 275-1  
 Nozzle Diameter (D<sub>n</sub>): 0.275  
 Probe ID No: 66-8-1  
 Pitot C<sub>p</sub>: 0.814  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 531.0  
 H<sub>2</sub>O (silica, g): 20.4  
 Actual Moisture (%): 23.10

Meter Box ID. No: 66-20  
 Meter ΔH@: 1.79920  
 Meter Y<sub>2</sub>: 1.00310

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			922.100						
1-01	5.0	0.53	1.40	925.420	311	91	91	0.73	3.32	101.2
1-02	10.0	0.51	1.40	928.700	309	93	90	0.71	3.28	101.7
1-03	15.0	0.42	1.10	931.580	307	94	90	0.65	2.88	98.2
1-04	20.0	0.52	1.40	934.860	306	96	91	0.72	3.28	100.2
1-05	25.0	0.70	1.90	938.675	310	97	92	0.84	3.81	100.6
LEAK CHECK	25.0			938.750						
2-01	30.0	0.72	1.90	942.610	310	97	92	0.85	3.86	100.4
2-02	35.0	0.55	1.50	946.070	310	98	92	0.74	3.46	102.8
2-03	40.0	0.58	1.60	949.580	309	98	92	0.76	3.51	101.5
2-04	45.0	0.62	1.70	953.170	310	101	93	0.79	3.59	100.1
2-05	50.0	0.72	1.90	956.965	311	102	93	0.85	3.80	98.3
LEAK CHECK	50.0			957.035						
3-01	55.0	0.66	1.80	960.930	309	101	93	0.81	3.89	105.3
3-02	60.0	0.60	1.60	964.240	310	100	92	0.77	3.31	94.0
3-03	65.0	0.62	1.70	967.850	310	99	92	0.79	3.61	101.0
3-04	70.0	0.70	1.90	971.650	310	99	92	0.84	3.80	100.1
3-05	75.0	0.72	1.90	975.470	310	100	92	0.85	3.82	99.1
LEAK CHECK	75.0			975.565						
4-01	80.0	0.58	1.60	979.070	310	98	92	0.76	3.51	101.4
4-02	85.0	0.55	1.50	982.490	310	99	92	0.74	3.42	101.5
4-03	90.0	0.63	1.70	986.080	309	99	92	0.79	3.59	99.5
4-04	95.0	0.73	2.00	989.960	308	98	92	0.85	3.88	100.0
4-05	100.0	0.72	1.90	993.760	310	99	91	0.85	3.80	98.8
LEAK CHECK	100.0			993.845						
5-01	105.0	0.55	1.50	997.210	310	99	92	0.74	3.37	99.9
5-02	110.0	0.53	1.40	1000.510	311	99	92	0.73	3.30	99.8
5-03	115.0	0.65	1.80	1004.220	310	99	92	0.81	3.71	101.4
5-04	120.0	0.70	1.90	1008.010	311	101	92	0.84	3.79	99.7
5-05	125.0	0.73	2.00	1011.905	310	102	92	0.85	3.89	100.2
Final	125.0		1.68000	89.48000	309.64000		95.10000	0.78648	89.48000	

25 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	0.7865	1.6800	89.4800	309.6400	95.1000
----------	--------	--------	---------	----------	---------

Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK

010814 135935  
K

### Field Data Printout

**Test Method:**

**USEPA Method 29**

**Analyte:**

**Mercury**

Location: Unit 1 FF Outlet

Test Run: 4

Client: Wheelabrator North Broward, Inc.

Project No: 12218

Source Area (ft<sup>2</sup>): 64.00000

Meter Operator: P. Bihun 505

Probe Operator: P. Bihun 505

Test Date: 12/11/13

Start Time: 13:14

Stop Time: 15:25

Leak Rate Before: 0.003 cfm @ 15 "Hg

Leak Rate After: 0.003 cfm @ 18 "Hg

Bar. Press. (in. Hg): 30.16

Static P: -11.2

O<sub>2</sub> (dry volume %): 9.80

CO<sub>2</sub> (dry volume %): 9.00

N<sub>2</sub>+CO (dry volume %): 81.20

Nozzle ID No: 275-1

Nozzle Diameter (D<sub>n</sub>): 0.275

Probe ID No: 66-8-1

Pitot C<sub>p</sub>: 0.814

Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 524.3

H<sub>2</sub>O (silica, g): 16.5

Actual Moisture (%): 22.71

Meter Box ID. No: 66-20

Meter ΔH@: 1.79920

Meter Y<sub>a</sub>: 1.00310

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
5-01	5.0	0.63	1.70	16.210	311	93	90	0.79	3.67	102.1
5-02	10.0	0.60	1.60	19.700	311	94	90	0.77	3.49	99.5
5-03	15.0	0.70	1.90	23.490	311	95	90	0.84	3.79	100.0
5-04	20.0	0.73	2.00	27.380	310	96	90	0.85	3.89	100.4
5-05	25.0	0.73	2.00	31.275	311	96	90	0.85	3.90	100.6
LEAK CHECK	25.0			31.350						
4-01	30.0	0.57	1.50	34.750	310	96	90	0.75	3.40	99.2
4-02	35.0	0.58	1.60	38.240	310	96	90	0.76	3.49	101.0
4-03	40.0	0.70	1.90	42.010	310	97	90	0.84	3.77	99.3
4-04	45.0	0.73	2.00	45.900	311	98	90	0.85	3.89	100.3
4-05	50.0	0.71	1.90	49.735	312	97	90	0.84	3.84	100.4
LEAK CHECK	50.0			49.825						
3-01	55.0	0.72	1.90	53.660	311	97	90	0.85	3.83	99.6
3-02	60.0	0.59	1.60	57.230	312	98	91	0.77	3.57	102.3
3-03	65.0	0.60	1.60	60.780	312	98	91	0.77	3.55	100.8
3-04	70.0	0.65	1.80	64.480	310	98	91	0.81	3.70	100.9
3-05	75.0	0.73	2.00	68.350	309	99	91	0.85	3.87	99.5
LEAK CHECK	75.0			68.440						
2-01	80.0	0.64	1.70	71.980	309	99	92	0.80	3.54	97.0
2-02	85.0	0.52	1.40	75.320	309	100	92	0.72	3.34	101.4
2-03	90.0	0.45	1.20	78.450	309	100	92	0.67	3.13	102.1
2-04	95.0	0.57	1.50	81.810	310	100	92	0.75	3.36	97.5
2-05	100.0	0.73	2.00	85.565	312	101	93	0.85	3.76	96.3
LEAK CHECK	100.0			85.635						
1-01	105.0	0.53	1.40	88.920	309	99	92	0.73	3.29	98.9
1-02	110.0	0.60	1.60	92.390	310	99	92	0.77	3.47	98.3
1-03	115.0	0.42	1.10	95.360	310	100	92	0.65	2.97	100.3
1-04	120.0	0.53	1.40	98.620	310	99	92	0.73	3.26	98.2
1-05	125.0	0.73	2.00	102.470	310	99	92	0.85	3.85	98.9
Final	125.0		1.69200	89.60000	310.36000		94.38000	0.79001	89.60000	

25 points sampled  
QC-Check: Field Averages

Sq,RLΔP				
0.7900	1.6920	89.6000	310.3600	94.3800
<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

010314 123749  
P

**USEPA Method 4 Laboratory Data**

Location: Unit 1 FF Outlet  
 Client: Wheelabrator North Broward, Inc.  
 Project No: 12218

**Test Method:** USEPA Method 29  
**Analyte:** Mercury

**Analyst:** D. Dreska  
**Analyst Emp No:** 364

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	778.4	440.8	337.6		
Impinger 2	5%HNO3/10%H2O2	674.3	552.1	122.2		
Impinger 3	5%HNO3/10%H2O2	588.3	563.6	24.7		
Impinger 4	Empty	457.4	452.0	5.4		
Impinger 5	4%KMnO4/10%H2SO4	550.8	547.9	2.9		
Impinger 6	4%KMnO4/10%H2SO4	552.4	551.0	1.4	494.2 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	772.5	753.2	19.3	0.0 less rinse (gm)	
Impinger 8					494.2 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 19.3 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					513.5 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)			

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	775.3	436.9	338.4		
Impinger 2	5%HNO3/10%H2O2	669.0	544.8	124.2		
Impinger 3	5%HNO3/10%H2O2	550.6	525.2	25.4		
Impinger 4	Empty	444.7	439.1	5.6		
Impinger 5	4%KMnO4/10%H2SO4	556.9	553.8	3.1		
Impinger 6	4%KMnO4/10%H2SO4	535.7	534.4	1.3	498.0 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	721.3	701.7	19.6	0.0 less rinse (gm)	
Impinger 8					498.0 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 19.6 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					517.6 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)			

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	776.1	442.2	333.9		
Impinger 2	5%HNO3/10%H2O2	693.1	540.1	153.0		
Impinger 3	5%HNO3/10%H2O2	578.7	549.9	28.8		
Impinger 4	Empty	460.7	453.2	7.5		
Impinger 5	4%KMnO4/10%H2SO4	557.5	553.3	4.2		
Impinger 6	4%KMnO4/10%H2SO4	556.4	552.8	3.6	531.0 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	777.2	756.8	20.4	0.0 less rinse (gm)	
Impinger 8					531.0 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 20.4 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					551.4 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)			

Test Run: 4

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	785.9	437.9	348.0		
Impinger 2	5%HNO3/10%H2O2	709.1	549.1	160.0		
Impinger 3	5%HNO3/10%H2O2	536.6	525.4	11.2		
Impinger 4	Empty	443.5	440.6	2.9		
Impinger 5	4%KMnO4/10%H2SO4	542.6	543.0	-0.4		
Impinger 6	4%KMnO4/10%H2SO4	557.5	554.9	2.6	524.3 Liquid (gm)	<i>Field Data Check</i>
Impinger 7	Silica Gel	737.4	720.9	16.5	0.0 less rinse (gm)	
Impinger 8					524.3 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 16.5 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					540.8 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)			

010314 123749  
 O O P

### USEPA Method 3 Laboratory Data

Location: Unit 1 FF Outlet  
 Client: Wheelabrator North Broward, Inc.  
 Project No: 12218  
 Method: EPA Method 3A  
 Fuel Type: Municipal Waste  
 F<sub>o</sub> for Fuel: 1.03 to 1.3

Test Method: USEPA Method 29  
 Analyte: Mercury

Analyst:	D. Dreska
Analyst Emp No:	364

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
	Avg.							
CEM or Other Avg:		9.00000		10.20000	80.80000	29.84800	1.18889	<input checked="" type="checkbox"/> Fo value within expected range.
2	1							
	2							
	3							
	Avg.							
CEM or Other Avg:		9.20000		9.80000	81.00000	29.86400	1.20652	<input checked="" type="checkbox"/> Fo value within expected range.
3	1							
	2							
	3							
	Avg.							
CEM or Other Avg:		8.80000		10.00000	81.20000	29.80800	1.23864	<input checked="" type="checkbox"/> Fo value within expected range.
4	1							
	2							
	3							
	Avg.							
CEM or Other Avg:		9.00000		9.80000	81.20000	29.83200	1.23333	<input checked="" type="checkbox"/> Fo value within expected range.

010914 140047  
 P L K P

**LABORATORY DATA**

G

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: WR

Date: 1/15/14



**This Page Intentionally Left Blank**

Wheelabrator North Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Laboratory Parameters**

**Detection Limits**

m <sub>1b-DL</sub>	Fraction 1B Detection Limit (µg)	0.1000
m <sub>2b-DL</sub>	Fraction 2B Detection Limit (µg)	0.2000
m <sub>3a-DL</sub>	Fraction 3A Detection Limit (µg)	0.2000
m <sub>3b-DL</sub>	Fraction 3B Detection Limit (µg)	0.5000
m <sub>3c-DL</sub>	Fraction 3C Detection Limit (µg)	0.4000

**Blank Analysis**

m <sub>1b-B</sub>	Fraction 1B Blank (µg)	<0.1000
m <sub>2b-B</sub>	Fraction 2B Blank (µg)	<0.2000
m <sub>3a-B</sub>	Fraction 3A Blank (µg)	<0.2000
m <sub>3b-B</sub>	Fraction 3B Blank (µg)	<0.5000
m <sub>3c-B</sub>	Fraction 3C Blank (µg)	<0.4000
m <sub>total-B</sub>	Total Blank Amount (µg)	<1.4000

**Run No.**

	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>
Date (2013)	Dec 10	Dec 11	Dec 11	Dec 11
Start Time (approx.)	12:24	08:09	10:42	13:14
Stop Time (approx.)	14:34	10:21	12:54	15:25

**Sample Analysis**

	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	
m <sub>1b-S</sub>	Fraction 1B Sample (µg)	<0.1000	<0.1000	<0.1000	<0.1000
m <sub>2b-S</sub>	Fraction 2B Sample (µg)	2.3378	18.2270	16.2002	13.8613
m <sub>3a-S</sub>	Fraction 3A Sample (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>3b-S</sub>	Fraction 3B Sample (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>3c-S</sub>	Fraction 3C Sample (µg)	<0.4000	<0.4000	<0.4000	<0.4000
m <sub>total-S</sub>	Total Sample Amount (µg)	2.3378	18.2270	16.2002	13.8613

**Allowable Blank**

m <sub>T-B-allow</sub>	Total Allowable Blank (µg)	0.0000	0.0000	0.0000	0.0000
------------------------	----------------------------	--------	--------	--------	--------

**Sample Corrected for Blank**

m <sub>n</sub>	Total Sample Amount (µg)	2.3378	18.2270	16.2002	13.8613
----------------	--------------------------	--------	---------	---------	---------

**Sample Corrected for Blank - Prorated Fractions**

	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	
m <sub>n-1b</sub>	Fraction 1B Prorated (µg)	<0.1000	<0.1000	<0.1000	<0.1000
m <sub>n-2b</sub>	Fraction 2B Prorated (µg)	2.3378	18.2270	16.2002	13.8613
m <sub>n-3a</sub>	Fraction 3A Prorated (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>n-3b</sub>	Fraction 3B Prorated (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>n-3c</sub>	Fraction 3C Prorated (µg)	<0.4000	<0.4000	<0.4000	<0.4000

010314 123749  
 O



# **Clean Air Engineering, Inc.**


500 West Wood Street  
Palatine, IL 60067

Project Number: 12218

Mercury

EPA Method 29 Analysis

Analytical Report  
21650



Element One, Inc.

6319-D Carolina Beach Rd., Wilmington, NC 28412  
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com

The following data for Analytical Report 21650  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Review by:



Daphne Woodman, Chemist  
December 30, 2013

Report Reviewed and Finalized By:



Ken Smith, Laboratory Director  
December 30, 2013

**elementOne**

21650 CAE M29 Report Packet Rev 12.30.13  
Page 2 of 34

# SUMMARY OF RESULTS

**elementOne**

21650 CAE M29 Report Packet Rev 12.30.13  
Page 3 of 34

## Summary of Analysis

### Unit 1 - Summary of Method 29 Mercury Analysis

Run Number		Average Total Catch, $\mu\text{g}$	Front Half $\mu\text{g}$	$\text{H}_2\text{O}_2$ / $\text{HNO}_3$ $\mu\text{g}$	Empty Impinger $\mu\text{g}$	$\text{KMnO}_4$ $\mu\text{g}$	$\text{HCl}$ $\mu\text{g}$
U1 FF Outlet R1	#1	2.34	< 0.1	2.32	< 0.2	< 0.5	< 0.4
	#2		< 0.1	2.36	< 0.2	< 0.5	< 0.4
U1 FF Outlet R2	#1	18.2	< 0.1	18.4	< 0.2	< 0.5	< 0.4
	#2		< 0.1	18.0	< 0.2	< 0.5	< 0.4
U1 FF Outlet R3	#1	16.2	< 0.1	16.1	< 0.2	< 0.5	< 0.4
	#2		< 0.1	16.3	< 0.2	< 0.5	< 0.4
U1 FF Outlet R4	#1	13.9	< 0.1	13.8	< 0.2	< 0.5	< 0.4
	#2		< 0.1	13.9	< 0.2	< 0.5	< 0.4
Field Blank	#1	< 0.5	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
Reagent Blank	#1	< 0.5	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.2	< 0.2	< 0.5	< 0.4

## Summary of Analysis

### Audit - Summary of Method 29 Mercury Analysis

<u>Element</u>	120613L- Cat 1427 Audit e21650-7 <u>Total µg</u>	120613L- Cat 1428 Audit e21650-8 <u>ng/mL</u>
Mercury	47.1	53.0

**elementOne**

21650 CAE M29 Report Packet Rev 12.30.13  
Page 5 of 34

# ANALYTICAL NARRATIVE

**elementOne**

21650 CAE M29 Report Packet Rev 12.30.13  
Page 6 of 34

## Element One Analytical Narrative

Client:	Clean Air, IL	Element One #:	21650
Client ID:	12218 / Wheelabrator Pompano Beach, FL	Analyst:	JWL
Method:	Method 29	Dates Received:	12/12/13
Analytes:	Hg	Dates Analyzed:	12/17-24/13

### Summary of Analysis

The Method 29 samples were digested, prepared, and analyzed according to Method 29 protocol. Samples were analyzed for mercury on a PerkinElmer FIMS-100 CVAA mercury analyzer.

### Detection Limits

The FIMS-100 CVAA instrument reporting limit for mercury was 0.004 µg per aliquot analyzed.

### Analysis QA/QC

Duplicate analyses relative percent difference (RPD) and spike sample recovery data are summarized in the Quality Control Section. All QA/QC data was within the criteria of the method.

The audit results for the Stationary Source Audit Program have been reported to ERA for Project #120613L. Copies of the audit reporting forms are included in the analytical data section of this report.

### Additional Comments

The reported results have not been corrected for any blank values or spike recovery values.

This is the first revision to this report; the samples were labeled "Inlet" instead of "FF Outlet".

# QUALITY CONTROL SUMMARY

**elementOne**

21650 CAE M29 Report Packet Rev 12.30.13  
Page 8 of 34



## Summary of Quality Control Data

### Mercury Duplicate Analysis RPD

*(Method 29 QC limits: < 10% for RPD)*

Run Number	Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U1 Inlet R1	NA	1.5%	NA	NA	NA
U1 Inlet R2	NA	2.3%	NA	NA	NA
U1 Inlet R3	NA	1.3%	NA	NA	NA
U1 Inlet R4	NA	0.2%	NA	NA	NA
Field Blank	NA	NA	NA	NA	NA
Reagent Blank	NA	NA	NA	NA	NA

### Mercury Spike Recoveries

*(Method 29 QC limits: 75-125% for Spike Recoveries)*

Run Number		Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U1 Inlet R3	#1	112%	90%	95%	93%	95%
	#2	114%	88%	94%	91%	93%

**elementOne**

21650 CAE M29 Report Packet Rev 12.30.13




Page 9 of 34

# SAMPLE CUSTODY

**elementOne**




21650 CAE M29 Report Packet Rev 12.30.13  
Page 10 of 34

21650


CLIENT <u>Wholecabrator</u>		PROJECT <u>1221B</u>		66-1221B-11		
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>GG</u>				
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palestine, IL 60067 838-627-0033 (phone) 847-501-3385 (fax)				
ANALYTICAL METHOD	CONTAINER NUMBER	SAMPLE FRACTION		FORWARDING LAB		
USEPA M-28	1	QUARTZ FILTER 250 mL HDPE		Element One, Inc. 6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ken Smith		
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ANALYSIS REQUESTED	ADDITIONAL INFORMATION
	10/10	Unit 1	1	Quartz Filter, 250 mL HDPE	X	
	12/11	Unit 1	2	Quartz Filter, 250 mL HDPE	X	
		Unit 1	3	Quartz Filter, 250 mL HDPE	X	
		Unit 1	4	Quartz Filter, 250 mL HDPE	X	
		Unit 1	Field Blank	Quartz Filter, 250 mL HDPE	X	
		Audit Sample			X	
Requested By: (signature)		Date / Time	Requested By: (signature)	Date / Time	This form completed by:	
D*2		6-5-13 @17:00			R. Vicero	
Received By: (signature)		Date / Time	Received By: (signature)	Date / Time	Signature Date	
		12-12-13 11:00				

Samples received in good condition in Fisherbrand + QRC Level 2 containers. No empty containers.


21650

CLIENT <u>Wheclabrator</u>			PROJECT <u>12218</u>		66-12218-12		
PLANT <u>Pompano Beach, FL</u>			DEPT. <u>66</u>				
PROJECT MANAGER <u>S. Brown</u>							
ANALYTICAL METHOD	CONTAINER NUMBER	SAMPLE FRACTION	500 West Wood Street Palmdale, IL 61067 800-627-0333 (phone) 847-991-3365 (fax)		FORWARDING LAB		
USEPA M-29	3	FRONT HALF HNO <sub>3</sub> RINSE 250 mL HDPE			Element One, Inc 6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ken Smith		
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	NUMBER OF CONTAINERS	CONTAINER SEALED? LIQUID LEVEL MARKED?	
	12/10	Unit:	Train Proof	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1	X	
		Unit:					
	12/10	Unit:	1	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1	X	
	12/11	Unit:	2	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1	X	
		Unit:	3	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1	X	
		Unit:	4	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1	X	
	12/10	Unit:	Field Blank	Front Half HNO <sub>3</sub> Rinse, 250 mL HDPE	1	X	
					ANALYSIS REQUESTED		
					Mercury		
					Aroclor		
					Report Front and Back Half Separately		
Relinquished By: (signature)		Date / Time		Relinquished By: (signature)		Date / Time	
D'2		6-5-13 @ 17:00					
Received By: (signature)		Date / Time		Relinquished By: (signature)		Date / Time	
		11-12-13 1100				This form completed by: R. Victoro Signature Date	



21650

CLIENT <u>Wheelabrator</u>		PROJECT <u>12218</u>		66-12216-13	
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>66</u>			
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palatka, FL 32907 800-627-0033 (phone) 847-951-3265 (fax)		ANALYSIS REQUESTED	
ANALYTICAL METHOD	CONTAINER NUMBER			SAMPLE FRACTION	<i>Mercury</i>
USEPA M-29	4	IMPINGERS 1-3 CATCH AND RINSE 1000 mL HDPE			FORWARDING LAB Element One, Inc. 6319C Carolina Beach Rd Wilmington, NC 28412 910-703-0128 (phone) Ken Smith
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ADDITIONAL INFORMATION
	12/10	Unit 1	1	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	
	12/11	Unit 1	2	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	
	↓	Unit 1	3	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	
		Unit 1	4	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	
	12/10	Unit 1	Field Blank	Impingers 1-3 Catch and Rinse, 1000 mL HDPE	
Relinquished By: (signature)		Date / Time	Relinquished By: (signature)	Date / Time	This form completed by:
D*2		6-5-13 @17:00			R. Vicuro
Received By: (signature)		Date / Time	Received By: (signature)	Date / Time	Signature Date
<i>Sara Britton</i>		12-12-13 1100			




21650

CLIENT <u>Wheelabrator</u>		PROJECT <u>12218</u>		66-12218-14	
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>66</u>			
PROJECT MANAGER <u>S. Brown</u>		 503 West Wood Street Palatka, FL 32909 800-627-0033 (phone) 847-981-3285 (fax)		ANALYSIS REQUESTED <input type="checkbox"/> Mercury <input type="checkbox"/> Arsenic	
ANALYTICAL METHOD <b>USEPA M-29</b>	CONTAINER NUMBER <b>6A</b>	SAMPLE FRACTION <b>IMPINGER 4 CATCH AND RINSE 250 mL HDPE</b>		FORWARDING LAB Element One, Inc. 6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ken Smith	
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ADDITIONAL INFORMATION
	12/10	Unit 1	1	Impinger 4 Catch and Rinse, 250 ml. HDPE	
	12/11	Unit 1	2	Impinger 4 Catch and Rinse, 250 ml. HDPE	
	↓	Unit 1	3	Impinger 4 Catch and Rinse, 250 ml. HDPE	
		Unit 1	4	Impinger 4 Catch and Rinse, 250 ml. HDPE	
	12/10	Unit 1	Field Blank	Impinger 4 Catch and Rinse, 250 ml. HDPE	
Relinquished By: (signature)		Date / Time	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)
D-2		6-5-13 @ 17:00			This form completed by:
Received By: (signature)		Date / Time	Received By: (signature)	Date / Time	Relinquished By: (signature)
<i>S. Brown</i>		12-12-13 11:00			R. Vicora Signature Date

2165D




CLIENT <u>Wheelerator</u>		PROJECT <u>12218</u>		58-12218-16		
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>66</u>				
PROJECT MANAGER <u>S. Brown</u>		 <p>Clean Air INCORPORATED 500 West Wood Street Poncaire, LA 70067 800 627-6033 (phone) 847-995-3365 (fax)</p>		NUMBER OF CONTAINERS	CONTAINER SEALED? LIQUID LEVEL MARKED?	ANALYSIS REQUESTED Mercury Arsenic
ANALYTICAL METHOD <u>USEPA M-29</u>	CONTAINER NUMBER <u>5B</u>					
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX		ADDITIONAL INFORMATION
	<u>12/10</u>	Unit 1	1	Impingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X
	<u>12/11</u>	Unit 1	2	Impingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X
	↓	Unit 1	3	Impingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X
		Unit 1	4	Impingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X
	<u>12/10</u>	Unit 1	Field Blank	Impingers 5-6 Catch and Rinse, 950 mL Amber Glass	1	X
						Report Front and Back Half
						Separately
Relinquished By: (signature) <u>D*2</u>	Date / Time <u>8-5-13 @ 17:00</u>	Relinquished By: (signature) 	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by: <u>R. Vicera</u>
Received By: (signature) <u>Log Braton</u>	Date / Time <u>12-12-13 1100</u>	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Signature      Date

21650

CLIENT <u>Wheatlaborator</u>		PROJECT <u>12218</u>		66-12218-15									
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>06</u>											
PROJECT MANAGER <u>S. Brown</u>													
ANALYTICAL METHOD <b>USEPA M-29</b>	CONTAINER NUMBER <b>0</b>	SAMPLE FRACTION <b>IMPINGERS 5-6 CATCH AND RINSE 250 mL AMBER GLASS</b>		FORWARDING LAB Element One, Inc. 6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0178 (phone) Ken Smith									
		528 West Wood Street Pawnee, LA 70067 800-627-0033 (phone) 847-991-3365 (fax)		ADDITIONAL INFORMATION									
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	NUMBER OF CONTAINERS	CONTAINER SEALED?	LIQUID LEVEL MARKED?	ANALYSIS REQUESTED					
	12/10	Unit 1	1	Impinger 5-6 RN HCl + DI Water, Container: 250 mL Amber Glass	1	X		X					
	12/11	Unit 1	2	Impinger 5-6 RN HCl + DI Water, Container: 250 mL Amber Glass	1	X		X					
	↓	Unit 1	3	Impinger 5-6 RN HCl + DI Water, Container: 250 mL Amber Glass	1	X		X					
	↓	Unit 1	4	Impinger 5-6 RN HCl + DI Water, Container: 250 mL Amber Glass	1	X		X					
	12/10	Unit 1	Field Blank	Impinger 5-6 RN HCl + DI Water, Container: 250 mL Amber Glass	1	X		X					
											Report Front and Back Half Separately		
Relinquished By: (signature)		Date / Time		Relinquished By: (signature)		Date / Time		Relinquished By: (signature)		Date / Time		This form completed by:	
D'2		12/11 6:13 @ 17:00										R. Vicera	
Received By: (signature)		Date / Time		Received By: (signature)		Date / Time		Relinquished By: (signature)		Date / Time		Signature Date	
		12-13 11:00											



21650

CLIENT <u>Whoofabrator</u>		PROJECT <u>12218</u>		66-12218-17					
PLANT <u>Pompano Beach, FL</u>		DEPT. <u>68</u>							
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palatka, FL 32907 888-527-0633 (phone) 847-991-3305 (fax)		NUMBER OF CONTAINERS	CONTAINER SEALED? LIQUID LEVEL MARKED?	ANALYSIS REQUESTED			FORWARDING LAB
ANALYTICAL METHOD	CONTAINER NUMBER					SAMPLE FRACTION	<i>Mercury</i>	<i>Archieve</i>	Element One, Inc.
USEPA M-29	SEE BELOW (IF APPLICABLE)	REAGENT BLANKS					6319C Carolina Beach Rd Wilmington, NC 28412 910-793-0128 (phone) Ken Smith		
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX			ADDITIONAL INFORMATION		
	<u>12/10</u>	Unit 1	AI	0.1% HNO <sub>3</sub> (300 mL), Container 8A, 500 mL HDPE	1	X	X		
		Unit 1	AI	DI Water (100 mL), Container 8B, 250 mL HDPE	1	X	X		
		Unit 1	AI	5% HNO <sub>3</sub> , 70% H <sub>2</sub> O <sub>2</sub> (200 mL), Container 9, 250 mL HDPE	1	X	X		
		Unit 1	AI	4% KMnO <sub>4</sub> , 70% H <sub>2</sub> SO <sub>4</sub> (100 mL), Container 10, 250 mL Amber Glass	1	X	X		
	<u>12/10</u>	Unit 1	AI	DI Water (200 mL) / 8N HCl (20 mL), Container 11, 250 mL Amber Glass	1	X	X		
		Reagent Blank	AI	Quartz Filters (3), Container 12, 250 mL HDPE	1	X	X		
Relinquished By: (signature)		Date / Time	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by:		
<u>D*2</u>		<u>12/11</u> <u>06:45 @ 17:00</u>					<u>R. Vicere</u>		
Received By: (signature)		Date / Time	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Signature      Date		
		<u>12-12-13 1140</u>							

# ANALYTICAL DATA

**elementOne**

21650 CAE M29 Report Packet Rev 12.30.13  
Page 18 of 34

## Analytical Calculations

### Mercury-

$$\text{Mercury Results } (\mu\text{g}) = \frac{\text{CVAA Results } (\mu\text{g}) * \text{Final Volume (ml)}}{\text{Aliquot (ml)}}$$

### Where-

CVAA Results= Raw sample reading ( $\mu\text{g}$ )--*Hg-Data Sheet*

Aliquot= Sample Aliquot (Alq.)--*Hg-Data Sheet*

Final Volume=Final Volume (FV)\*--*Sample Submission*

\* With the exception of the BH fraction where-  
=Received Volume (BV)--*Sample Submission*

## Analytical Calculations

### Spike Recovery-

$$\text{Spike (\%)} = \frac{(\text{Spiked Result } (\mu\text{g}) - \text{Sample Result } (\mu\text{g}))}{\text{Spike Amount } (\mu\text{g})} \times 100$$

### Where-

Spike Result = Raw sample concentration ( $\mu\text{g}$ )--*Hg Data Sheet*

Sample Result = Raw sample concentration ( $\mu\text{g}$ )--*Hg Data Sheet*

Spike Amount—*Hg Run Sheet*

### Duplicate Analysis RPD-

$$\text{RPD (\%)} = \frac{(\text{Duplicate Result } (\mu\text{g}) - \text{Sample Result } (\mu\text{g}))}{\text{Average } (\mu\text{g})} \times 100$$

### Where-

Sample Result = Raw sample concentration ( $\mu\text{g}$ )--*Hg Data Sheet*

Duplicate Results = Raw sample concentration ( $\mu\text{g}$ )--*Hg Data Sheet*

Average =  $\frac{(\text{Duplicate} + \text{Sample Results})}{2}$

elementOne AIR TESTING SAMPLE SUBMISSION FORM Lab ID 21650

[Empty Box]

Analysis Due Date 12.19.13  
QA/QC/Report Due Date 12.23.13

Client Clean Air IL  
Project No 12218

Date Rec 12.12.13  
Time Rec 1100

HNO<sub>3</sub> Lot 1113040 HF Lot 0080055115 HCl Lot 411102 Ref. Method: 29  
Volume Marked  N Volume Loss Y  / ?

Sample Identification

1	U1-M29-R1	5	Field Blank	7	120613L-Cat 1427
2	U1-M29-R2	6	Reagent Blank	8	120613L-Cat 1428
3	U1-M29-R2 Duplicate				
	U1-M29-R3				
4	U1-M29-R3 Spike				
	U1-M29-R4				

Analyses Requested Samples 1-8 Hg

Runs / FB	Fil / Ace (FH)		HNO <sub>3</sub> (FH)		5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub> (BH)		HNO <sub>3</sub> (A)		KMnO <sub>4</sub> (B)		HCl (C)		
	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	
Lab ID	FH ID	BV ml	BV ml	FV ml	BV ml	Used	FV ml	BV ml	FV ml	BV ml	FV ml	BV ml	FV ml
1			180	100	850			114	200	390	500	230	400
2.D			230		840			126		380		250	
3.S			200		360			116		420		270	
4			134		910			103		400		290	
5			164		320			106		390		230	

M-29 Reagent Blank

Lab ID	Fraction	BV, ml	FV, ml	Comments
6	C-7 FH Acetone Blank			
	C-8A FH 0.1N HNO <sub>3</sub>	300	100	Used 100 ml
	C-8A A 0.1N HNO <sub>3</sub>	300		
	C-8B B DI H <sub>2</sub> O	110	100/33	Used 33 ml
	C-9 BH 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	200		
	C-10 B 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	230	100/33	Used 100 ml
	C-11 C 8N HCl DI H <sub>2</sub> O	230	400	
	C-12 FH Filter			

Audits See Attached Audit Instructions

Sample ID	Analyses Requested	Prep By / Date
7	120613L-Cat 1427 Hg	Jwr 12.19.13
8	120613L-Cat 1428 Hg	Jwr 12.16.13

Lab Communications

LBK (FH) spiked w/ 100 ml of std A @ 25 ppm

M29: Recv'd C1, C3, C4, C5A, C5B, C5C, RB C12, C8A, C8B, C9, C10, C11: 2 Audits— Archive Train Proof—12.12.13 LLB

SS Page 1 of 1  
12/12/2013 3:13:31 PM  
SS by [Signature]  
Labeled By/Date Jwr 12.13.13

FH Prep By/Date Jwr 12.18.13 A Prep By/Date Jwr 12.16.13  
BH Prep By/Date Jwr 12.16.13 B Prep By/Date Jwr 12.16.13  
BH/FH Prep By/Date Jwr 12.17.13 C Prep By/Date Jwr 12.17.13  
PM Prep By/Date Jwr 12.17.13 ID Verification By/Date KLS 12.13.13  
BV 314 Jwr 12.16.13



A Waters Company

21650

### Stationary Source Audit Program Data Reporting Form Project #: 120613L

Lab Name: Clean Air Engineering

ERA Customer Number: C144861

**INSTRUCTIONS:**

Please refer to the results, methods references and analysis dates for the analyte(s) you wish to report for Project #120613L. Questions? See the Data Reporting Instructions section of your Data Package or call ERA at 1-800-372-0122. Please photocopy this form if you are reporting multiple methods.

#### Stationary Source Audit Program Mercury on Filter Paper (cat# 1127)

Method Description	EPA 29	Rev/Ed				
Analysis Date (mm-dd)	12-23	Analyst	JWL			
TNI Code		Analyte	Units	PTRL	Concentration Range	Reported Value
1005		Mercury	µg/Filter	0.750	1.00 to 75.0	47.1





21650

**Stationary Source Audit Program Data Reporting Form**  
**Project #: 120613L**

Lab Name: Clean Air Engineering

ERA Customer Number: C144861

**INSTRUCTIONS:**

Please fill in the results, methods references and analysis dates for the analyte(s) you wish to report for Project #120613L. Questions? See the Data Reporting Instructions section of your Data Package or call ERA at 1-800-372-0122. Please photocopy this form if you are reporting multiple methods.

**Stationary Source Audit Program Mercury in Impinger Solution (cat# 1128)**

Method Description	EPA 29	Rev/Ed			
Analysis Date (mm-dd)	12-19	Analyst	JUL		
Workgroup					
TNI Code	Analyte	Units	PTRL	Concentration Range	Reported Value
1055	Mercury	ng/mL	0.680	0.900 to 200	53.0

4 of 4

16341 Table Mountain Pkwy • Golden, CO 80403 • 800.372.0122 • 303.431.8454 • fax 303.421.0159 • www.eraqc.com



**elementOne**

21650 CAE M29 Report Packet Rev 12.30.13  
Page 23 of 34

elementOne

Method 29 Microwave Worksheet

Lab ID # e 21650

Client: Clean Air

Date Digested: 12.19.13 Initials: JWL Worksheet Prepared by: JWL

Auto Sample Loc.	Sample Lab ID	Sample Weight (g)	# of filters digested	Spike	Prep Volume (ml)	Weight In Micro / Weight Out Micro	Units
1	CRB				100		
2	CRB+			100 mL Std A			
4	-1		1				
5	-2						
6	-3						
8	-4						
9	-5						
10	-6						
12	-7			100 mL Concentrate			
13	BLK						
14	BLK						
16	BLK						
CRB+ Spiked w/ 100 mL of Std A @ 25 ppm							
21650-7 Transferred 100 mL of Concentrate onto filter + digested							

Element One, Inc. Form 104 - Revision 1.0

HF Lot # 00005515

2ml

HNO<sub>3</sub> Lot # 11.3040

6ml

elementOne

21650 CAE M29 Report Packet Rev 12.30.13

Page 24 of 34



elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

Date Prepared/Digested: 12-16-13 Prep By: JWL SIF File #: 121613-1  
 Block #1 Temperature: 93.93 Start Time: 6:55 Machine ID: #1  
 Block #2 Temperature: 95.55 Stop Time: 8:10 Batch Analyst: JWL  
 Block #3 Temperature: - Typed By: JWL Verified By: P&T

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: 1316504
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: 121613-1 by: JWL
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml	40	40	Lot #: 121613-2
6	0.20ug	0.50ml	40	40	Standard #3 (QC #3): Lot #: 121613-3
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by: JWL

Initial Review By: JWL Date: 12-17-13 Time: 11:00  
 Final QC Review By: DCL Date: 12/17/13 Time: 13:23  
 Comments: 21613-34 @ 2 ml

A/S	LAB #	Client	Wt/FV	Ali Used	ml used	Sample Vol, ml	Spike ug
9	21648-3				5	1	
10	-3f				↓	↓	
11	21600-0				20	1	
12	-0f				↓	↓	
13	-9				↓	↓	
14	-9f				↓	↓	
15	21650-1B				4	500	
16	-2B				↓	↓	
17	-26g				↓	↓	
18	-3B				↓	↓	
19	-35f				↓	↓	

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
 Spike for Hg, Use calibration of 0.4 ug/ml standard at the rate of 0.20ml per 40ml sample.  
 Digestion chemicals to be added at the following rate per 40ml volumes.  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 51312 HNO<sub>3</sub> Lot # 1113040 HCl Lot # 411102  
 Persulfate Lot # 120613-3 KMnO<sub>4</sub> Lot # 111413-5 Hydrox Lot # 120213-0  
 Clear samples at digestion with 3.2ml of Hydroxylamine solution.

elementOne MERCURY TCI DIGESTION - RUN WORKSHEET

SIF File #: \_\_\_\_\_

A/S	LAB #	Client	V. FV	Ali Used	ml used	Sample Vol. ml	Spike µg
20	21050 - 4B				4	500	
21	- 5B				↓	↓	
22	- 6B				↓	↓	
23	21050 - 1A				4	200	
24	- 2A				↓	↓	
25	- 2AD				↓	↓	
26	- 3A				↓	↓	
27	- 3A+				↓	↓	
28	- 4A				↓	↓	
29	- 5A				↓	↓	
30	- 6A				↓	↓	
31	21050 - 1BH				4	850	
32	- 2BH				↓	890	
33	- 2BH D				↓	↓	
34	- 3BH				↓	860	
35	- 3BH+				↓	↓	
36	- 4BH				↓	910	
37	- 5BH				↓	320	
38	- 6BH				↓	200	
39	21050 - 8				.05	5	
40	- 8				- 1	↓	
41	- 8				- 2	↓	
42	21059 - 1A				4	200	
43	- 1AD				↓	↓	
44	- 1A+				↓	↓	
45	- 1B				4	600	
46	- 1BD				↓	↓	
47	- 1B+				↓	↓	
48	- 1BH				4	1410	
49	- 1BH D				↓	↓	
50	- 1BH+				↓	↓	
51	21329 BLK				1	1	
5.	BLK+				↓	↓	
5.	- Filter				↓	↓	
5.	- Petri				↓	↓	

elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

Date Prepared/Digested: 12-12-13 Prep By: SMW SIF File #: 12113-1  
 Block #1 Temperature: 95.56 Start Time: 6:55 Machine ID: #1  
 Block #2 Temperature: 94.52 Stop Time: 8:10 Batch Analyst: JML  
 Block #3 Temperature: - Typed By: SMW Verified By: ACB

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: 1310504
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: 121613-1 by: JML
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml	40	40	Lot #: 121613-2
6	0.20ug	0.50ml	40	40	Standard #3 (QC #3): Lot #: 121613-3
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by: JML

Initial Review By: JML Date: 12-18-13 Time: 1:00  
 Final QC Review By: ACB Date: 12/19/13 Time: 1:05  
 Comments: 21650-8 @ 2ml from dilution 21617-17 @ 4ml

A/S	LAB #	Client	W/V/FV	Ali Used	ml used	Sample Vol, ml	Spike ug
✓ 9	21648-3				2	1	
10	-3+				↓	↓	
11	-3				↓	↓	
12	-3+				↓	↓	
✓ 13	21553/574 BLK				26	1	
14	BLK+					↓	
✓ 15	21655/656 BLK					↓	
16	BLK+					↓	
✓ 17	21658/6162/63 BLK					↓	
18	BLK+					↓	
✓ 19	21655 A					↓	

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
**Spike for Hg.** Use calibration working 0.4ug/ml standard at the rate of 0.20ml per 40ml sample.  
**Digestion chemicals to be added in order at the following rate per 40ml volumes.**  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 51312 HNO<sub>3</sub> Lot # 1113040 HCl Lot #: 4111102  
 Persulfate Lot # 120613-3 KMnO<sub>4</sub> Lot # 111413-5 Hydrox Lot#: 120213-6  
 Clear samples at digestion with 3.2ml of Hydroxylamine solution.

elementOne

MERCURY BATCH DIGESTION - RUN WORKSHEET

SIF File #: \_\_\_\_\_

A/S	LAB #	Client	V/VFV	Ali Used	ml used	Sample Vol, ml	Spike µg
✓ 20	21655 A t				20	1	
21	- B						
✓ 22	- C						
✓ 23	21656 - 1						
24	- 2						
25	- 2D						
26	- 3						
27	- 4						
28	- 5						
29	- 6						
30	- 7						
✓ 31	- 7 t						
✓ 32	21661						
✓ 33	- Dup						
✓ 34	21662						
✓ 35	21663 - 1						
36	- 2						
✓ 37	- 2D						
✓ 38	21553 - 1						
39	- 1 t						
40	- 1D						
41	- 5						
✓ 42	- 5D						
✓ 43	21574 - 2						
44	- 2D						
45	- 4						
46	- 4D						
47	- 1						
48	- 7D						
49	21650 - 1C				4	400	
50	- 2C						
51	- 2CD						
52	- 3C						
53	- 3C t						
54	- 4C						

elementOne MERCURY BATCH DEFINITION - RUN WORKSHEET

SIF File #: \_\_\_\_\_

A/S	LAB #	CIP	W/V/FV	ml Used	ml used	Sample Vol, ml	Spike µg
55	21050-5C				4	400	
56	-6C				↓	↓	
57	21050-8				.2	1000	
58	-8				.5		
59	21050-8				1	↓	
60	21059-10				4	400	
61	-10D				↓	↓	
62	-10E						
✓ 63	21281-30 QL				.1	5	
64	LL QL				1	1	
65	21063 LAB (TOT)				2.4	1	
✓ 66	(TOT) LCB+				2.2	↓	
67	-1		0.5027/50	4	.0402	1	
68	-1+		↓		↓		
69	-2		0.5019/50		.0416		
70	-2D		0.4935/50	↓	.0395		
71	(TOT) 21057 LCB				2.4	1	
72	LCB+				2.2	↓	
73	21057-1		0.5041/50	4	.0403		
74	-1D		0.5009/50	↓	.0401		
75	-2		0.5047/50	4	.0407	↓	
76	-2+		↓		↓		
✓ 77	21329-020047				1	50	
78	-020047+				↓	↓	
79	21017-LAB FH				4	100	
80	-LAB FH+				1.0		
81	-1FH				4		
82	-2FH						
83	-2FH D						
84	-3FH						
85	-3FH+						
86	-4FH						
87	-5FH						
88	-5FH D						
89	-6FH						

elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

Date Prepared/Digested: 12.19.13 Prep By: JWL SIF File #: 122013-1  
 Block #1 Temperature: 94.41 Start Time: 5:55 Machine ID: FF1  
 Block #2 Temperature: 95.75 Stop Time: 8:10 Batch Analyst: JWL  
 Block #3 Temperature: - Typed By: JWL Verified By: LAL

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: 1310504
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: 121613-1 by: JWL
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml	40	40	Lot #: 121613-2
6	0.20ug	0.50ml	40	40	Standard #3 (QC #3): Lot #: 121613-3
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by: JWL

Initial Review By: JWL Date: 12.20.13 Time: 12:45  
 Final QC Review By: LAL Date: 12.20.13 Time: 16:00  
 Comments: 21667-3 @ 10 + 5ml 21659 LAB FH+ @ 40 ml

A/S	LAB #	Client	WT/FV	Ali Used	ml used	Sample Vol. ml	Spike µg
✓ 9	21665-3				10	1	
10	-3+				↓	↓	
11	-3				5	↓	
12	-3+				↓	↓	
✓ 13	21666-3				10	↓	
14	-3+				↓	↓	
15	-3				5	↓	
✓ 16	-3+				↓	↓	
✓ 17	21667 BLK				20	1	
18	BLK+				↓	↓	
19	21667-1				↓	↓	

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
**Spike for Hg,** Use calibration working 0.4ug/ml standard at the rate of 0.20ml per 40ml sample.  
**Digestion chemicals to be added in order at the following rate per 40ml volumes.**  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 51312 HNO<sub>3</sub> Lot # 1113040 HCl Lot #: 411102  
 Persulfate Lot # 120613-3 KMnO<sub>4</sub> Lot # 111413-5 Hydrox Lot #: 120213-6  
 Clear samples after digestion with 3.2ml of Hydroxylamine solution.

elementOne

MERCURY BATCH DIGESTION - RUN WORKSHEET

SIF File #: 122013-1

A/S	LAB #	Client	Wt/FV	Ali Used	ml used	Sample Vol, ml	Spike ug
✓ 20	21067-2				20	1	
21	- 3D				↓	↓	
22	- 3				↓	↓	
23	- 34				↓	↓	
24	- 4				↓	↓	
✓ 25	21090 LAB FH				4	100	
26	LAB FH +				1.6	↓	
27	- 1 FH				4	↓	
28	- 2 FH				↓	↓	
29	- 2 FH D				↓	↓	
30	- 3 FH				↓	↓	
31	- 3 FH +				↓	↓	
32	- 4 FH				↓	↓	
33	- 5 FH				↓	↓	
34	- 6 FH				↓	↓	
35	- 7				.5	↓	
36	- 7				1	↓	
37	- 7				2	↓	
✓ 38	21059 LAB FH				4	100	
39	LAB FH +				1.6	↓	
40	- 1 FH				4	↓	
41	- 1 FH D				↓	↓	
✓ 42	- 1 FH +				↓	↓	
✓ 43	21064-1B				4	500	
44	- 2B				↓	↓	
45	- 2DD				↓	↓	
46	- 3B				↓	↓	
47	- 3B4				↓	↓	
48	- 4B				↓	↓	
49	- 5B				↓	↓	
✓ 50	21065 (TOT) LAB				4	1	
51	LAB +				.2	↓	
52	- 1		0.4991/50	4	0.0359	↓	
53	- 2		0.5260/50	↓	.0421	↓	
54	- 2D		0.4816/50	↓	.0315	↓	

elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

Date Prepared/Digested: 12-23-13 Prep By: JWL/LAL SIF File #: 122313-1  
 Block #1 Temperature: 94.14 Start Time: 7:06 Machine ID: #1  
 Block #2 Temperature: 95.45 Stop Time: 10:15 Batch Analyst: JWL  
 Block #3 Temperature: \_\_\_\_\_ Typed By: JWL Verified By: LAL

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: <u>1316504</u>
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: <u>122313-1</u> by: <u>JWL</u>
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml	40	40	Lot #: <u>122313-2</u>
6	0.20ug	0.50ml	40	40	Standard #3 (QC #3): Lot #: <u>122313-3</u>
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by: <u>JWL</u>

Initial Review By: LAL Date: 12-23-13 Time: 3:02  
 Final QC Review By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Comments: 21167-3t @ 2.5ml, 21659LRBFH+

A/S	LAB #	Client	WV/FV	Aliq (ml)	Sample Vol, ml	Spike ug
9	21167-3				10	
10	-3t				↓	
11	-3				5	
12	-3t				↓	
13	21059 LRBFH				4	100
14	LRBFH+				1.6	↓
15	21064-4A				4	200
16	21064-1C				4	400
17	-2C				↓	
18	2CD				↓	
19	-3C				↓	

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
 Spike for Hg, Use calibration working 0.4ug/ml standard. Use 0.20ml per 40ml sample.  
 Digestion chemicals to be added in order at the following volumes.  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 52151 HNO<sub>3</sub> Lot # 113040 H<sub>2</sub>O<sub>2</sub> Lot # 35187  
 Persulfate Lot # 12063-3 KMnO<sub>4</sub> Lot # 11413-5 Hydrox Lot # 120213-6  
 Clear samples after digestion with \_\_\_\_\_ solution.



IF File #: 122313-1

A/S	LAB #	Client	W/FV	Vol.	Sample Vol. ml	Spike µg
✓ 20	21064-3C+				4	400
21	-4C				↓	
22	-5C				↓	
✓ 23	21072 BLK				20	
24	BLK+				↓	
✓ 25	21082-1					
26	-2					
27	-20					
✓ 28	-3					
✓ 29	-3+					
✓ 30	21090 LABKIT				4	1000
31	-7				2	100
32	-7				↓	↓
✓ 33	21492-1A				20	
34	-1B					
35	-1C					
✓ 36	-1D					
✓ 37	21492-2A					
38	-2B					
39	-2C					
40	-2D					
41	-3A					
42	-3B					
43	-3C					
44	-3C+					
45	-3D					
46	-4A					
47	-4B					
48	-4C					
49	-4D					
50	-5A					
51	-5B					
52	-5C					
53	-5D					
54	-6A					

PerkinElmer FIMS-100 CVA Mercury Analyzer

Sample_ID	Date	Time	Mean_Sig	Mean_Rd	Mean_Rt	Units	Alq.	Vol.	Sig 1	Reading-1	Result-1	Sig 2	Reading-2	Result-2
Calib Blank	12/17/2013	8:48:20 AM	-2.65E-06			µg			5.21E-06			-1.05E-05		
STD1 = .004ug	12/17/2013	8:50:01 AM	0.0009873			µg			0.000982			0.0009926		
STD2 = .04ug	12/17/2013	8:51:42 AM	0.0100748			µg			0.0101002			0.0100495		
STD3 = .08ug	12/17/2013	8:53:35 AM	0.0205835			µg			0.020897			0.0202699		
STD4 = .16ug	12/17/2013	8:55:30 AM	0.0400284			µg			0.0401091			0.0399478		
STD5 = .2ug	12/17/2013	8:57:24 AM	0.050074			µg			0.0513032			0.0488448		
Reagent Blank	12/17/2013	8:59:17 AM	8.43E-05	0.000336	0.000336	µg			4.58E-05	0.0001826	0.0001826	0.0001228	0.0004894	0.0004894
0.004ug = DL	12/17/2013	9:00:57 AM	0.0010543	0.0042013	0.0042013	µg			0.0010456	0.0041664	0.0041664	0.0010631	0.0042362	0.0042362
0.080ug = QC STD 2	12/17/2013	9:02:40 AM	0.0197926	0.0788699	0.0788699	µg			0.0200609	0.0799391	0.0799391	0.0195243	0.0778008	0.0778008
0.080ug = QC STD 3	12/17/2013	9:04:37 AM	0.0197128	0.0785518	0.0785518	µg			0.019775	0.0787997	0.0787997	0.0196506	0.0783039	0.0783039
Reagent Blank	12/17/2013	9:06:32 AM	6.00E-05	0.0002391	0.0002391	µg			5.08E-05	0.0002022	0.0002022	6.92E-05	0.0002759	0.0002759
21650-1B	12/17/2013	9:19:01 AM	0.0001063	8.77E-05	0.0109605	µg	4	500	0.0001255	0.0001639	0.0204885	8.72E-05	1.15E-05	0.0014325
21650-2B	12/17/2013	9:20:47 AM	0.0002533	0.0006734	0.0841713	µg	4	500	0.0002659	0.0007234	0.0904256	0.0002407	0.0006233	0.0779171
21650-2B DUP	12/17/2013	9:22:29 AM	0.0002446	0.0006387	0.079837	µg	4	500	0.0002514	0.000666	0.083247	0.0002378	0.0006114	0.076427
21650-3B	12/17/2013	9:24:09 AM	0.0001301	0.0001825	0.0228092	µg	4	500	0.0001424	0.0002315	0.0289364	0.0001178	0.0001335	0.0166819
0.004ug = DL	12/17/2013	9:25:49 AM	0.0010352	0.0041253	0.0041253	µg			0.0010488	0.0041794	0.0041794	0.0010217	0.0040712	0.0040712
0.080ug = QC STD 2	12/17/2013	9:27:33 AM	0.0186955	0.0744983	0.0744983	µg			0.0187008	0.0745193	0.0745193	0.0186903	0.0744774	0.0744774
Reagent Blank	12/17/2013	9:29:27 AM	9.48E-05	0.0003778	0.0003778	µg			9.40E-05	0.0003744	0.0003744	9.57E-05	0.0003812	0.0003812
21650-3B SPK	12/17/2013	9:31:07 AM	0.0185998	0.0737808	9.2226021	µg	4	500	0.0187638	0.0744342	9.3042772	0.0184358	0.0731274	9.140927
21650-4B	12/17/2013	9:32:58 AM	0.0001885	0.0004153	0.0519072	µg	4	500	0.0001906	0.0004235	0.0529381	0.0001865	0.000407	0.0508762
21650-5B	12/17/2013	9:34:39 AM	0.0001376	0.0002122	0.0265299	µg	4	500	0.0001533	0.0002749	0.0343661	0.0001219	0.0001496	0.0186938
21650-6B	12/17/2013	9:36:20 AM	9.35E-05	3.67E-05	0.0045827	µg	4	500	0.0001065	8.83E-05	0.0110336	8.06E-05	-1.49E-05	-0.0018682
21650-1A	12/17/2013	9:38:02 AM	0.0001498	0.000261	0.0130484	µg	4	200	0.0001543	0.0002788	0.0139413	0.0001453	0.0002431	0.0121555
21650-2A	12/17/2013	9:39:44 AM	0.0002512	0.0006648	0.0332423	µg	4	200	0.0002352	0.0006014	0.030068	0.0002671	0.0007283	0.0364166
21650-2A DUP	12/17/2013	9:41:26 AM	0.0002494	0.0006576	0.0328812	µg	4	200	0.0002564	0.0006859	0.0342938	0.0002423	0.0006294	0.0314686
21650-3A	12/17/2013	9:43:10 AM	0.0003228	0.0009501	0.0475066	µg	4	200	0.0003174	0.0009288	0.0464376	0.0003281	0.0009715	0.0485755
21650-3A SPK	12/17/2013	9:44:54 AM	0.0191307	0.0758962	3.7948079	µg	4	200	0.0192053	0.0761937	3.8096835	0.019056	0.0755986	3.779323
21650-4A	12/17/2013	9:46:49 AM	0.0002088	0.000496	0.0247997	µg	4	200	0.000209	0.000497	0.0248503	0.0002085	0.000495	0.0247491
0.004ug = DL	12/17/2013	9:48:32 AM	0.0010511	0.0041885	0.0041885	µg			0.0010862	0.0043284	0.0043284	0.0010116	0.0040486	0.0040486
0.080ug = QC STD 2	12/17/2013	9:50:15 AM	0.0187478	0.0747066	0.0747066	µg			0.0188868	0.0752606	0.0752606	0.0186088	0.0741526	0.0741526
Reagent Blank	12/17/2013	9:52:09 AM	0.0001451	0.0005783	0.0005783	µg			0.0001442	0.0005748	0.0005748	0.000146	0.0005817	0.0005817
21650-5A	12/17/2013	9:53:51 AM	0.000165	0.0003215	0.0160762	µg	4	200	0.0001572	0.0002802	0.0145105	0.0001729	0.0003528	0.017642
21650-6A	12/17/2013	9:55:37 AM	0.0001807	0.0003842	0.0192078	µg	4	200	0.0001776	0.0003716	0.0185775	0.0001839	0.0003968	0.0198382
21650-1BH	12/17/2013	9:57:22 AM	0.0028451	0.0110013	2.337782	µg	4	850	0.0028243	0.0109181	2.3201053	0.002866	0.0110845	2.3554586
21650-2BH	12/17/2013	9:59:04 AM	0.0218658	0.0867951	18.226976	µg	4	840	0.0221205	0.0878101	18.440128	0.0216111	0.0857801	18.013823
21650-2BH DUP	12/17/2013	10:00:54 AM	0.0218551	0.0867527	18.21807	µg	4	840	0.0220342	0.0874662	18.367897	0.0216761	0.0860392	18.068242
21650-3BH	12/17/2013	10:02:44 AM	0.0189935	0.0753496	16.200166	µg	4	860	0.0188741	0.0748737	16.097849	0.0191129	0.0758255	16.302484
21650-3BH SPK	12/17/2013	10:04:34 AM	0.0368433	0.1464778	31.492733	µg	4	860	0.037108	0.1475325	31.719484	0.0365786	0.1454232	31.265983
21650-4BH	12/17/2013	10:06:25 AM	0.0153746	0.060929	13.861338	µg	4	910	0.0153603	0.060872	13.848389	0.0153889	0.0609859	13.874288
21650-5BH	12/17/2013	10:08:16 AM	0.0001965	0.000447	0.0357572	µg	4	320	0.0001911	0.0004253	0.0340245	0.0002019	0.0004686	0.0374899
21650-6BH	12/17/2013	10:09:58 AM	0.0001974	0.0004505	0.0225228	µg	4	200	0.0002033	0.0004741	0.0237032	0.0001914	0.0004268	0.0213425
0.004ug = DL	12/17/2013	10:15:01 AM	0.0010738	0.0042789	0.0042789	µg			0.0010983	0.0043767	0.0043767	0.0010493	0.0041812	0.0041812
0.080ug = QC STD 2	12/17/2013	10:16:45 AM	0.018596	0.0741017	0.0741017	µg			0.0184802	0.0736404	0.0736404	0.0187118	0.074563	0.074563
Reagent Blank	12/17/2013	10:18:38 AM	0.0001501	0.0005981	0.0005981	µg			0.0001497	0.0005966	0.0005966	0.0001505	0.0005995	0.0005995
Calib Blank	12/18/2013	9:04:55 AM	3.31E-05			µg			1.70E-05			4.93E-05		
STD1 = .004ug	12/18/2013	9:06:35 AM	0.0009697			µg			0.0009631			0.0009762		
STD2 = .04ug	12/18/2013	9:08:16 AM	0.0099189			µg			0.010091			0.0097468		
STD3 = .08ug	12/18/2013	9:10:10 AM	0.0203436			µg			0.0204998			0.0201873		
STD4 = .16ug	12/18/2013	9:12:04 AM	0.0409107			µg			0.0415003			0.0403211		
STD5 = .2ug	12/18/2013	9:13:59 AM	0.0490001			µg			0.0490456			0.0489546		
Reagent Blank	12/18/2013	9:15:53 AM	1.69E-05	6.77E-05	6.77E-05	µg			1.30E-05	5.19E-05	5.19E-05	2.08E-05	8.35E-05	8.35E-05
0.004ug = DL	12/18/2013	9:17:33 AM	0.0009972	0.0039938	0.0039938	µg			0.0009971	0.0039934	0.0039934	0.0009973	0.0039942	0.0039942
0.080ug = QC STD 2	12/18/2013	9:19:16 AM	0.0198256	0.0793999	0.0793999	µg			0.0197441	0.0790725	0.0790725	0.0199072	0.0797255	0.0797255
0.080ug = QC STD 3	12/18/2013	9:21:13 AM	0.0200994	0.0804954	0.0804954	µg			0.0205375	0.0822498	0.0822498	0.0196613	0.0787409	0.0787409
Reagent Blank	12/18/2013	9:23:07 AM	5.68E-05	0.0002273	0.0002273	µg			4.74E-05	0.0001898	0.0001898	6.61E-05	0.0002648	0.0002648
0.004ug = DL	12/18/2013	10:53:42 AM	0.000984	0.0039408	0.0039408	µg			0.0009982	0.0039977	0.0039977	0.0009698	0.0038839	0.0038839
0.080ug = QC STD 2	12/18/2013	10:55:25 AM	0.0191768	0.0768005	0.0768005	µg			0.0190531	0.0763052	0.0763052	0.0193005	0.0772958	0.0772958
Reagent Blank	12/18/2013	10:57:19 AM	9.01E-05	0.0003607	0.0003607	µg			7.86E-05	0.000315	0.000315	0.0001015	0.0004065	0.0004065
21650-1C	12/18/2013	10:58:58 AM	0.000195	0.0007131	0.071307	µg	4	400	0.0001824	0.0006627	0.0662685	0.0002075	0.0007635	0.0763455
21650-2C	12/18/2013	11:00:37 AM	0.0003053	0.0011549	0.115493	µg	4	400	0.0002977	0.0011246	0.1124611	0.0003129	0.0011852	0.1185248
21650-2C DUP	12/18/2013	11:02:16 AM	0.0002681	0.0010058	0.1005789	µg	4	400	0.0002651	0.0009938	0.0993826	0.000271	0.0010178	0.1017753
21650-3C	12/18/2013	11:03:56 AM	0.0004863	0.0018798	0.1879777	µg	4	400	0.0004753	0.0018358	0.1835843	0.0004973	0.0019237	0.1923711
21650-3C SPK	12/18/2013	11:05:36 AM	0.0188687	0.0754988	7.5498755	µg	4	400	0.0190863	0.0763704				

PerkinElmer FIMS-100 CVAA Mercury Analyzer

Sample_ID	Date	Time	Mean_Sig	Mean_Rd	Mean_Rt	Units	Alq.	Vol.	Sig_1	Reading-1	Result-1	Sig_2	Reading-2	Result-2
0.004ug = DL	12/19/2013	10:37:42 AM	0.0009904	0.0040702	0.0040702	µg			0.0010037	0.0041246	0.0041246	0.0009772	0.0040158	0.0040158
0.080ug = QC STD 2	12/19/2013	10:39:25 AM	0.0194374	0.0798781	0.0798781	µg			0.0195788	0.0804595	0.0804595	0.0192959	0.0792967	0.0792967
Reagent Blank	12/19/2013	10:41:19 AM	-1.92E-05	-7.90E-05	-7.90E-05	µg			-3.57E-05	-0.0001467	-0.0001467	-2.74E-06	-1.12E-05	-1.12E-05
0.004ug = DL	12/19/2013	11:00:05 AM	0.0009679	0.0039774	0.0039774	µg			0.0009764	0.0040123	0.0040123	0.0009594	0.0039425	0.0039425
0.080ug = QC STD 2	12/19/2013	11:01:48 AM	0.0198633	0.0816284	0.0816284	µg			0.019809	0.0814054	0.0814054	0.0199175	0.0818514	0.0818514
Reagent Blank	12/19/2013	11:03:42 AM	-4.60E-05	-0.000189	-0.000189	µg			-3.19E-05	-0.0001312	-0.0001312	-6.01E-05	-0.0002468	-0.0002468
21650-8	12/19/2013	11:18:00 AM	0.0257519	0.1059325	0.1059325	µg	2	1000	0.0257523	0.1059343	0.1059343	0.0257514	0.1059306	0.1059306
0.004ug = DL	12/19/2013	11:23:28 AM	0.0009251	0.0038015	0.0038015	µg			0.0009292	0.0038186	0.0038186	0.0009209	0.0037844	0.0037844
0.080ug = QC STD 2	12/19/2013	11:25:12 AM	0.0196335	0.0806843	0.0806843	µg			0.0195089	0.080172	0.080172	0.0197582	0.0811966	0.0811966
Reagent Blank	12/19/2013	11:27:06 AM	-3.35E-05	-0.0001377	-0.0001377	µg			-3.18E-05	-0.0001308	-0.0001308	-3.52E-05	-0.0001445	-0.0001445
Calib Blank	12/20/2013	9:54:29 AM	0.0001709			µg			0.0001684					
STD1 = .004ug	12/20/2013	9:56:10 AM	0.0008571			µg			0.0008793				0.0008349	
STD2 = .04ug	12/20/2013	9:57:51 AM	0.0091288			µg			0.0093286				0.008929	
STD3 = .08ug	12/20/2013	9:59:44 AM	0.0187422			µg			0.0187316				0.0187528	
STD4 = .16ug	12/20/2013	10:01:38 AM	0.0364318			µg			0.0368332				0.0360303	
STD5 = .2ug	12/20/2013	10:03:34 AM	0.0458814			µg			0.0467634				0.0449994	
Reagent Blank	12/20/2013	10:05:27 AM	0.0001289	0.0005622	0.0005622	µg			0.0001581	0.0006895	0.0006895	9.97E-05	0.0004349	0.0004349
0.004ug = DL	12/20/2013	10:07:07 AM	0.0009516	0.0041516	0.0041516	µg			0.0009518	0.0041523	0.0041523	0.0009515	0.0041509	0.0041509
0.080ug = QC STD 2	12/20/2013	10:08:50 AM	0.0182821	0.0797577	0.0797577	µg			0.0183524	0.0800644	0.0800644	0.0182118	0.079451	0.079451
Reagent Blank	12/20/2013	10:10:44 AM	6.12E-05	0.0002671	0.0002671	µg			7.22E-05	0.0003149	0.0003149	5.03E-05	0.0002194	0.0002194
21650 LRB FH	12/20/2013	10:22:45 AM	-4.38E-05	-0.0007534	-0.0188356	µg	4	100	-2.46E-05	-0.0006697	-0.0167423	-6.30E-05	-0.0008372	-0.0209288
21650 LRB FH SPK	12/20/2013	10:24:28 AM	0.0152239	0.0658537	0.0658537	µg	1.6	100	0.0153961	0.066605	0.066605	0.0150517	0.0651025	0.0651025
21650-1FH	12/20/2013	10:26:22 AM	-5.89E-06	-0.0005879	-0.0146983	µg	4	100	-2.27E-05	-0.0006612	-0.0165308	1.09E-05	-0.0005146	-0.0128657
21650-2FH	12/20/2013	10:28:06 AM	0.0002054	0.000334	0.000334	µg	4	100	0.0002122	0.0003635	0.0003635	0.0001987	0.0003045	0.0003045
0.004ug = DL	12/20/2013	10:29:49 AM	0.0009621	0.0041972	0.0041972	µg			0.0009408	0.0041041	0.0041041	0.0009834	0.0042903	0.0042903
0.080ug = QC STD 2	12/20/2013	10:31:32 AM	0.0181598	0.0792239	0.0792239	µg			0.0182427	0.0795858	0.0795858	0.0180768	0.0788621	0.0788621
Reagent Blank	12/20/2013	10:33:28 AM	-1.28E-05	-5.58E-05	-5.58E-05	µg			-1.12E-05	-4.89E-05	-4.89E-05	-1.43E-05	-6.26E-05	-6.26E-05
21650-2FH DUP	12/20/2013	10:35:08 AM	5.89E-05	-0.0003053	-0.0076328	µg	4	100	5.84E-05	-0.0003077	-0.0076914	5.94E-05	-0.000303	-0.0075743
21650-3FH	12/20/2013	10:36:53 AM	7.66E-06	-0.0005288	-0.0132204	µg	4	100	1.37E-05	-0.0005026	-0.0125652	1.65E-06	-0.000555	-0.0138755
21650-3FH SPK	12/20/2013	10:38:38 AM	0.0208923	0.0905826	0.0905826	µg	4	100	0.0206828	0.0896688	0.0896688	0.0211017	0.0914963	0.0914963
21650-4FH	12/20/2013	10:40:31 AM	4.03E-05	-0.0003863	-0.0096575	µg	4	100	5.76E-05	-0.000311	-0.0077747	2.31E-05	-0.0004616	-0.0115404
21650-5FH	12/20/2013	10:42:10 AM	4.21E-05	-0.0003788	-0.0094692	µg	4	100	4.15E-05	-0.0003812	-0.0095294	4.26E-05	-0.0003764	-0.009409
21650-6FH	12/20/2013	10:43:50 AM	-4.44E-05	-0.0007561	-0.0189029	µg	4	100	-3.09E-05	-0.0006973	-0.0174313	-5.79E-05	-0.000815	-0.0203745
0.004ug = DL	12/20/2013	10:52:44 AM	0.0009102	0.0039708	0.0039708	µg			0.0009031	0.00394	0.00394	0.0009172	0.0040016	0.0040016
0.080ug = QC STD 2	12/20/2013	10:54:28 AM	0.0185348	0.0808602	0.0808602	µg			0.0184598	0.0805328	0.0805328	0.0186099	0.0811876	0.0811876
Reagent Blank	12/20/2013	10:56:21 AM	-2.46E-05	-0.0001074	-0.0001074	µg			-3.32E-06	-1.45E-05	-1.45E-05	-4.59E-05	-0.0002004	-0.0002004
Calib Blank	12/23/2013	11:00:27 AM	-8.13E-06			µg			1.27E-05					
STD1 = .004ug	12/23/2013	11:02:07 AM	0.0011768			µg			0.0011626				0.0011909	
STD2 = .04ug	12/23/2013	11:03:48 AM	0.0113154			µg			0.011049				0.0115819	
STD3 = .08ug	12/23/2013	11:05:41 AM	0.0234453			µg			0.0233786				0.023512	
STD4 = .16ug	12/23/2013	11:07:35 AM	0.0460205			µg			0.0459325				0.0461084	
STD5 = .2ug	12/23/2013	11:09:30 AM	0.0554668			µg			0.054886				0.0560476	
Reagent Blank	12/23/2013	11:11:23 AM	3.75E-05	0.0001328	0.0001328	µg			3.62E-05	0.0001281	0.0001281	3.89E-05	0.0001376	0.0001376
0.004ug = DL	12/23/2013	11:13:04 AM	0.0011871	0.0042019	0.0042019	µg			0.0012124	0.0042915	0.0042915	0.0011618	0.0041123	0.0041123
0.080ug = QC STD 2	12/23/2013	11:14:47 AM	0.0226767	0.0802646	0.0802646	µg			0.0227222	0.0804256	0.0804256	0.0226312	0.0801035	0.0801035
0.080ug = QC STD 3	12/23/2013	11:16:44 AM	0.0231828	0.0820559	0.0820559	µg			0.0240586	0.085156	0.085156	0.0223069	0.0789559	0.0789559
Reagent Blank	12/23/2013	11:18:38 AM	9.91E-05	0.0003508	0.0003508	µg			0.0001051	0.0003721	0.0003721	9.31E-05	0.0003295	0.0003295
0.004ug = DL	12/23/2013	12:00:51 PM	0.001145	0.0040527	0.0040527	µg			0.0011407	0.0040375	0.0040375	0.0011493	0.0040678	0.0040678
0.080ug = QC STD 2	12/23/2013	12:02:35 PM	0.0216477	0.0766226	0.0766226	µg			0.0218963	0.0775025	0.0775025	0.0213992	0.0757428	0.0757428
Reagent Blank	12/23/2013	12:04:28 PM	7.01E-05	0.0002481	0.0002481	µg			7.17E-05	0.0002539	0.0002539	6.85E-05	0.0002423	0.0002423
21650-7	12/23/2013	12:09:52 PM	0.027115	0.0958414	0.0958414	µg	0.2	100	0.0275976	0.0975495	0.0975495	0.0266324	0.0941333	0.0941333
0.004ug = DL	12/23/2013	12:23:37 PM	0.0012127	0.0042924	0.0042924	µg			0.0011643	0.0041211	0.0041211	0.0012611	0.0044638	0.0044638
0.080ug = QC STD 2	12/23/2013	12:25:20 PM	0.0209385	0.0741122	0.0741122	µg			0.0204823	0.0724976	0.0724976	0.0213947	0.0757269	0.0757269
Reagent Blank	12/23/2013	12:27:13 PM	0.0001041	0.0003685	0.0003685	µg			9.98E-05	0.0003531	0.0003531	0.0001085	0.0003839	0.0003839

WHEELABRATOR NORTH BROWARD, INC.  
POMPANO BEACH, FL

Client Reference No: Service Agreement  
CleanAir Project No: 12218-7

**PLANT DATA**

H

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials:       NK      

Date:       1/15/14      



**This Page Intentionally Left Blank**

**WHEELABRATOR NORTH BROWARD  
TONS OF REFUSE PROCESSED PER STACK TEST RUN LOG**

UNIT #1						
Date	Test	Method#	Run #	Steam (klb/hr)	Run Length (hr)	Trash Processed (tons)
12/10/2013	Mercury	29	1	179.5	2.17	74.9
12/11/2013	Mercury	29	2	180.1	2.20	76.2
12/11/2013	Mercury	29	3	180.2	2.18	75.5
12/11/2013	Mercury	29	4	180.4	2.18	75.6

## Wheelabrator NORTH BROWARD Emission Test Log

Date: 12/10/13  
Start Time: 12:24  
End Time: 14:34

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

	Test	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	29 run 1	434.15	320.68	44.10	35.29	8.81	19.96	304.64	6.59	-11.11
Unit 2		459.93	320.02	25.34	15.72	9.62	34.86	262.29	6.16	0.00
Unit 3		490.00	319.05	31.30	22.27	9.02	28.19	307.79	6.13	-5.26

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	179.59	885.74	831.52	78.76	-0.10	252.73	1152.76	4.52	179.51
Unit 2	157.49	881.68	832.94	79.11	-0.10	263.80	1000.06	2.71	150.34
Unit 3	154.98	883.01	812.22	67.22	-0.09	262.66	1058.36	1.48	151.01

U1 lime (#/hr) 585.12

U2 lime (#/hr) 638.56

U3 lime (#/hr) 599.13

Specific Gravity 1.106

Round Down 1.100 1.050

Round Up 1.110 1.150

**Wheelabrator  
NORTH BROWARD  
Emission Test Log**

Date: 12/11/13  
Start Time: 8:09  
End Time: 10:21

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
----------------	-----------------	-----------------	----------------	------------	-----------	-------------	-------	----------------

	Test	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1	29 run 2	424.56	320.10	43.21	34.02	9.19	21.24	303.14	6.54	-11.12
Unit 2		468.76	319.76	26.79	16.83	9.95	34.29	289.86	6.03	0.00
Unit 3		502.17	319.98	35.75	26.38	9.37	25.74	308.52	6.44	-3.87

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
---------------	------------------	----------------	--------------	---------------	----------------	-------------	----------------	------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	181.20	888.53	843.26	75.87	-0.10	252.13	1145.56	4.54	180.07
Unit 2	156.55	883.79	826.98	85.43	-0.10	263.62	1013.02	5.99	150.39
Unit 3	154.86	885.25	812.77	69.70	-0.10	262.59	1089.16	2.73	150.56

U1 lime (#/hr) 579.22

U2 lime (#/hr) 627.16

U3 lime (#/hr) 590.27

Specific Gravity 1.100

Round Down 1.100 1.050

Round Up 1.110 1.150



## Wheelabrator NORTH BROWARD Emission Test Log

Date: 12/11/13  
 Start Time: 10:43  
 End Time: 12:54

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF/OUT TEMP	FF DP	ID INLET PRESS
	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1 Test 29 run 3	439.39	320.31	47.78	37.41	10.37	19.14	303.67	6.64	-11.36
Unit 2	458.12	319.87	24.83	15.17	9.66	36.87	289.32	6.04	0.00
Unit 3	503.02	320.13	35.67	26.34	9.33	25.55	308.31	6.41	-4.05

	FEED H2O FLOW	SH/OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH/ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBS/hr
Unit 1	180.83	888.03	836.49	80.97	-0.10	252.50	1141.13	5.93	180.19
Unit 2	156.24	883.36	830.23	85.19	-0.10	263.52	995.12	5.99	149.64
Unit 3	155.72	885.26	822.90	70.10	-0.10	262.47	1102.57	1.67	150.22

U1 lime (#/hr) 655.45

U2 lime (#/hr) 610.69

U3 lime (#/hr) 590.24

Specific Gravity 1.100

Round Down 1.100 1.050

Round Up 1.110 1.150

**Wheelabrator  
NORTH BROWARD  
Emission Test Log**

Date: 12/11/13  
Start Time: 13:14  
End Time: 15:25

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	TOTAL LIME	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS
-------------------	--------------------	--------------------	-------------------	---------------	--------------	----------------	----------	-------------------

Test	DEG F	DEG F	GPM	GPM	GPM	%	DEG F	" H2O	" H2O
Unit 1 29 run 4	441.68	319.82	49.06	34.87	14.19	18.64	304.31	6.69	-11.47
Unit 2	460.78	319.99	25.71	16.13	9.57	35.62	290.67	6.00	0.00
Unit 3	505.61	319.97	36.62	27.30	9.32	24.94	308.40	6.42	-5.08

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	STEAM FLOW
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	KLBs/hr
Unit 1	179.85	887.88	827.68	80.14	-0.10	252.44	1149.35	6.56	180.38
Unit 2	157.73	884.04	835.97	84.56	-0.10	263.39	1011.43	5.99	150.46
Unit 3	155.05	885.37	820.12	68.23	-0.10	262.37	1111.37	3.62	149.96

U1 lime (#/hr) 899.94

U2 lime (#/hr) 607.27

U3 lime (#/hr) 591.06

Specific Gravity 1.101

Round Down 1.100 1.050

Round Up 1.110 1.150

**This Page Intentionally Left Blank**