

May 2, 2011

093-87674

Via Electronic Delivery

Mr. Cleve Holladay Florida Department of Environmental Protection 2600 Blair Stone Road Tallahassee, Florida 32399

RE:

**WASTE MANAGEMENT, INC. OF FLORIDA** 

AIR PERMIT APPLICATION NO. 0250615-012-AC (PSD-FL-414)

MEDLEY LANDFILL GAS-TO-ENERGY PROJECT

REQUEST FOR ADDITIONAL MODELING INFORMATION



Dear Mr. Holladay:

Golder Associates, Inc. (Golder) received an e-mail from you on February 1, 2011, where you had forwarded comments from the Environmental Protection Agency (EPA) regarding the revised modeling analysis for the Medley Landfill Gas-to-Energy (LFGTE) project (FDEP project No. 0250615-012-AC/PSD-FL-414) submitted to the Florida Department of Environmental Protection (FDEP) in January 2011. Golder is providing additional information below in response to EPA's comments. Each of EPA's comments are presented below, followed by a response.

Comment 1. Urban Option – The AERMOD Implementation Guide state that the land use characteristics across the full modeling domain should be considered not those within 3 km of the proposed source. The urban heat island is not a localized effect but more regional in character. The use of the urban option for this application only considered land use within 3 km of the proposed project and the population used appears to be associated with Miami and not that of the modeling domain.

Response: The land use classification within 3 kilometers (km) of the proposed project site is predominantly urban. As suggested in Section 5.1 of the Aermod Implementation Guide, the full modeling domain of an approximately 50 km radius area surrounding the project site was considered for the rural versus urban land use classification. However, the Atlantic Ocean is approximately 20 km east of the site and almost all of the western half of the domain (west of State Road 821) is rural. The attached Figure 1 shows an area that may be considered as an urban complex. This area extends approximately 5 km to the northwest, north, east, and south of the project site. Except for this area, the urban area west of the Miami International Airport, the downtown City of Miami, and the City of Miami Beach, most of the Miami-Ft. Lauderdale metropolitan area within the modeling domain has single family homes, which is classified as rural. Therefore, the full modeling domain cannot be considered as an urban complex. As a result, all existing sources included in the cumulative modeling analysis were not modeled using the urban option.

However, certain existing sources are located within the urban complex identified in Figure 1. The  $NO_2$  1-hour average NAAQS model runs were revised with these existing sources as urban, and the revised results are presented in Tables 6-11 and 6-12. As shown, the total 1-hour average  $NO_2$  air quality impact of 180.7  $\mu$ g/m³ is the same as was reported in the modeling report. Therefore, modeling additional sources as urban had little or no effect of the reported modeling results. Figure 2 shows all facilities included in the NAAQS modeling with identification of which sources were modeled as urban.

The NAAQS modeling analysis performed for the project is based on very conservative assumptions and approaches and most likely overestimate the maximum predicted 1-hour concentrations for this project. In the recent June 29, 2010, and the March 1, 2011, guidance memos, EPA has cautioned against the use of the literal and uncritical application of very prescriptive procedures for identifying which background

Y:\Projects\2009\093-87674 WM Medley PSD\Modeling Rpt\RAI\R050211\_674.docx





sources should be included in the modeled emission inventory for NAAQS compliance demonstration. The use of the North Carolina Screening Approach used in the NAAQS analysis for the project is such a prescriptive procedure. This procedure, although adequate for use in long-term average analyses (e.g., annual), may be and probably is not adequate for the 1-hour average analysis. However, it was used in the original modeling analysis since no clear guidance was provided by EPA about which background sources should be considered for cumulative source modeling.

EPA indicated in the March 1, 2011 memo that more factors are needed to consider which background sources should be included in modeling on a case-by-case basis. In fact, because concentration gradients associated for a particular source will generally be largest between the source location and distance of maximum concentration from the source, concentrations beyond the maximum impact distance will generally be smaller and non-spatially uniform. According to EPA, the general "rule-of-thumb" for estimating the distance to the maximum 1-hour impact and region of significant gradient that may apply in flat terrain is approximately 10 times the source release height. However, based on other factors, such as source operating characteristics, the emphasis should focus on the area within 10 km of the project location in most cases. In fact, ambient monitoring data should be used to account for the potential impacts from sources located at large distances from the project

From these EPA guidance memos, which strongly indicate a need to understand which sources should be included in the cumulative source modeling, it is clear that the following factors used in the NAAQS analysis for the project provided a very conservative assessment of maximum impacts:

- Sources located more than 10 km from the project were included in the analysis. Based on certain sources located more than the 20 km from the project, high 1-hour NO₂ impacts were predicted near the project yet the meteorological conditions are not realistic to transport the plumes from those sources to the area around the project. For example, the Fort Lauderdale Plant and the Port Everglades Plant are located about 28 and 33 km, respectively, from the project. Based on the time periods that produced the maximum impacts from these sources near the project area, the wind speeds were generally 4 meters per second (m/s) or less. With a 4-m/s wind speed, a plume would be transported about 14 km in an hour. With lower wind speeds, the plume would be transported at even shorter distances. Given the distance that these sources are located from the project, it is highly unlikely that these source's plumes would be transported to the critical areas around the project.
- Ambient NO₂ monitoring data were added to the modeled concentration to account for non-modeled background concentrations yet the monitoring data account for impacts from sources that were modeled in the analysis ("double counting" impacts as stated by EPA). In fact, the primary NO₂ monitoring station (Metro Annex #864002) is located only about 500 meters from a major highway (U.S. Interstate 95). Given the traffic is much greater at that site than near the project, the measurements are expected to be higher than what would be experienced near the project.

The population used in the  $NO_2$  NAAQS analysis is based on the population of the City of Miami, not the population of the metropolitan area. A modeling analysis was conducted to estimate the sensitivity of the population value input to AERMOD on the maximum predicted concentrations due to the proposed project. Impacts were predicted for input populations of 100,000; 150,000; 300,000; 500,000 and 700,000. The results of the analysis indicated that the maximum predicted impacts were not sensitive to changes in the input populations. See the modeling files in the attached CD.



# Comment 2. Appropriate Meteorological Data Record – Table 6-9 which provides the SIL modeling results show the meteorological data record processed with the airport land use characteristics (MIA) produce the maximum annual concentrations for all pollutants while the meteorological record processes with the site land use characteristics produce the maximum short-term concentrations for all pollutants. Confirmation is needed that the MIA processed meteorological data were used for all subsequent annual modeling and the site processed meteorological data were used for all short-term standard modeling in this revised modeling analyses. [Note: Even with the increased PM emissions, all revised SIL concentrations are less than those reported in the initial PSD permit application.]

Response: The procedure for selecting the most conservative meteorological data records to use for model predictions is illustrated in Table 1. To date, this determination has been performed from general inspection of the various pollutant impacts relative to the criteria that are most critical to a specific project. In this regard, as shown in the table, the predicted concentration differences between the two meteorological records are clearly more significant for short-term pollutant averaging times than for the annual averaging times relative to the SIL and NAAQS area with higher impacts predicted for the site processed meteorological data. The project-only concentration differences between the two meteorological records are not as large for the annual averaging time with slightly higher impacts predicted for the MIA processed meteorological data and the annual cumulative source modeling results are seldom if ever as critical for NAAQS compliance as are the short-term averaging times. As a result, the site processed meteorological data were used for all averaging standard modeling.

With no formal written guidance for how to quantify the differences in the meteorological patterns between a measurement site (airport) and an application site (project) and determine what is and is not acceptable, the procedures expected by different states to address this issue have become increasingly varied over the years. Presently, many states have adopted the policy of creating a second meteorological record with measured land use parameters at the project site and comparing the predicted impacts to those predicted with the airport land use record. One state agency in reviewing a PSD permit application even suggested that small changes in the measured Bowen Ratio were also important and requested that three meteorological records consisting of 15 years of data be developed and compared to SIL. Such policies tend to promote the idea that 5 years (43,824 hours) of predicted concentrations are not sufficient to determine whether or not a facility meets all applicable air standards and that another 43,824 or 87,648 predictions are needed. Mixing and matching meteorological records by specific pollutant or averaging times would add considerable effort to the preparation of an application and, more importantly, further complicate the regulatory review process.

EPA's March 1, 2011 memorandum provides clarification and additional guidance for modeling procedures for the 1-hour NO<sub>2</sub> (and SO<sub>2</sub>) compliance modeling that will result in a simplification of the required effort to conduct detailed cumulative source modeling analyses. Based on lack of specific guidance regarding the issues of meteorological representation, additional simplification and/or guidance is needed in that area as well.

Please note that the stack height increase for the project sources is the cause of the reduction in the revised PM SIL concentrations that are less than those reported in the initial PSD permit application.

## Comment 3. Justification for Use of Tier 3 OLM Procedure – As indicated in the 28 June 2010 Tyler Fox memorandum and in Appendix W, the use of the Tier 3 non-regulatory modeling techniques requires EPA Regional Office approval. Responses to the following comments and requested information are needed to complete the evaluation of the justification provided for the use of the non-regulatory Tier 3 OLM modeling technique to assess NO<sub>2</sub> NAAQS compliance.

- The demonstration that the OLM modeling technique is appropriate for this application (2<sup>nd</sup> Criterion) has not been completely addressed. The issue of photosynthesis' contribution to the NO to NO<sub>2</sub> formation is only addressed



generically and not its importance at the project's location. The reason it is "reasonable to assume that the ozone titration mechanism in OLM" is appropriate for use at the project location was not addressed. A possible compensative procedure for any possible photosynthesis formation of NO<sub>2</sub> at the project site would be, for example, the use of conservative, rather than just representative, ozone concentrations in the OLM procedure.

**Response:** A compensative procedure for any possible photosynthesis formation of  $NO_2$  is photodissociation, which has already been described in the modeling methodology. If photosynthesis formation is to be considered, it would not be reasonable to consider photodissociation. Please note that the ozone titration mechanism of the OLM modeling technique is already conservative because it assumes that all of the ground-level ozone concentration from monitoring data is available to the plume for conversion of NO to  $NO_2$ . In reality, only the ozone available within the plume should be available for the conversion mechanism.

Since the modeling analysis was submitted in December 2010, EPA published a Guidance Memorandum on March 1, 2011, where EPA has accepted the use of PVMRM and OLM modeling options in AERMOD for estimating hourly NO<sub>2</sub> concentrations provided reasonable demonstrations can be made of the appropriateness of the key inputs for these options, the in-stack NO<sub>2</sub>/NO<sub>X</sub> ratio, and the background ozone concentration.

Please also note that the OLM modeling technique is an EPA Reglan X-approved method in the state of Alaska. Recently, states like New Mexico have approved the use of OLM. It is also a modeling technique approved internationally in many countries.

- The information on the availability and adequacy of the databases (3rd Criterion) needed for this technique was not completely given. Three databases are needed: ambient ozone measurements, ambient background  $NO_2$  measurements, and appropriate  $NO_2/NO_X$  in-stack ratios.

Hourly Ozone – The appropriate ozone monitoring data base to represent the project location should consider not only the proximity of the monitor but also the characteristics of the measurements. Summaries of the measurements from the three available monitors (e.g., annual 1-hour maximums, monthly 1-hour maximum, annual averages, 98th percentile, etc.) would allow evaluation of the range tends, etc, that are important in determining which would be representative or conservative for application at the project location. The summaries would also be valuable in determining the appropriate measurements to be used for missing values from the primary record.

**Response:** The hourly ozone monitoring data used in the analysis were described in pages 7 and 8 of the modeling report along with summary tables, which provided the completeness of the annual data sets and total number of missing data that were replaced in each year. A total of three monitoring stations located within 30 km of the Medley Landfill were used and 5-year data for each were analyzed. The nearest monitor at Krome Avenue (#860021) was used as the primary station and any missing data were replaced with data from the 2<sup>nd</sup> nearest monitor. If data were also missing from this monitor, then data from the 3<sup>rd</sup> nearest monitor were used. As a result, the hourly ozone data used in the modeling analysis are a combination of data from three monitoring sites.

The attached Table 2 summarizes the hourly ozone monitoring data from the three monitoring sites and shows the overall maximum 1-hour, the 98<sup>th</sup> percentile of the daily maximum 1-hour, and seasonal maximum 1-hour average concentrations. As shown, there is little variability in the 5-year 98<sup>th</sup> percentile daily maximum 1-hour data from all three stations.



Hourly  $NO_2$  Background – Similar to the ozone databases above, the available hourly  $NO_2$  measurements for application to this assessment should be provided along with summaries of the measurements. Proximity of the measurements along with the characteristics of the measurements should be used to evaluate and determine the appropriate data records to use in developing the needed background  $NO_2$  measurements for this procedure.

**Response**: The hourly  $NO_2$  monitoring data used in the analysis were described in pages 10 and 11 of the modeling report along with summary tables, which provided the completeness of the annual data sets and total number of missing data that were replaced in each year. Similar to the hourly ozone data, three monitoring stations located within 30 km of the Medley Landfill were used and 5-year data for each were analyzed. The nearest monitor at Metro Annex (#864002) was used as the primary station and any missing data were replaced with data from the  $2^{nd}$  nearest monitor. If data were also missing from this monitor, then data from the  $3^{rd}$  nearest monitor were used. As a result, the hourly  $NO_2$  data used in the modeling analysis are a combination of data from three monitoring sites.

The attached Table 3 summarizes the hourly NO<sub>2</sub> monitoring data from the three monitoring sites and shows the overall maximum 1-hour, the 98<sup>th</sup> percentile of the daily maximum 1-hour, and seasonal maximum 1-hour average concentrations. As shown, there is little variability in the 5-year 98<sup>th</sup> percentile daily maximum 1-hour data from all three stations.

 $NO_2/NO_X$  Ratios – The proposed  $NO_2/NO_X$  ratios for combustion turbine and boiler sources in both the Medley emission units and those in the inventory of other sources are not based on specific project stack tests. It has been assumed the boiler  $NO_2/NO_X$  ratios from two stack tests for power plants in Georgia are applicable to the Medley and other boilers emissions. Because the references for in-stack ratios have not been shown to be specifically applicable to the boilers and turbines in the Medley impact modeling, the largest of the reported ratios should be used to ensure the concentrations are not underestimated. This would result in 0.2 for boilers and 0.3 for turbines. All emission units using  $NO_2/NO_X$  ratios other than 1.0 should be identified in the emission inventories.

**Response:** The reference stack tests from Georgia are provided in Tables 4 and 5. Tests were conducted on simple-cycle CTs at two plants. The  $NO_2/NO_X$  ratio was found in the range from approximately 0.03 to 0.17. As a conservative approach, the  $NO_2/NO_X$  ratio for existing combustion turbine sources included in the cumulative source modeling for the project was used as 0.2.

Among the  $NO_2/NO_X$  ratios for boilers in Alaska, New Mexico, Texas, and California that were presented in the modeling report, there are no references of a ratio of 0.2. The MACTEC study used a representative ratio of 0.05 for boilers. Hanrahan used an in-stack ratio of 0.1 for boilers in the initial design of the PVMRM algorithm. The Air Pollution Control Technology Handbook (By Karl B. Schnelle, Charles Arnold Brown) states that the typical NO to  $NO_2$  ratio in boiler emissions is 10:1 to 20:1, which is equivalent to a  $NO_2/NO_X$  ratio from approximately 0.09 to 0.05.

Please note that for most sources included in modeling, the  $NO_2/NO_X$  ratio used is 1.0, which means that the  $NO_2$  impacts from these sources are based on full conversion and no credit was taken for OLM. The revised Table D-1 shows the in-stack  $NO_2/NO_X$  ratios used for each stack.



- The following comments are associated with the protocol of methods and procedures proposed to be used (5th Criterion).

Off Season Observations – Confirm that the Rosenstiel School and Perdue Medical Center ozone stations include measurements including the non-ozone season.

**Response**: Data from both the Rosenstiel School and Perdue Medical Center stations include nonozone season measurements. Based on data completeness summary presented in Page 8 of the modeling report, except for 2001 when data from Rosenstiel School were 89.7% complete, the rest of the yearly data for both stations are more than 90% complete.

Annual NO<sub>2</sub> Concentrations – From the discussion in Section 3.2.2 and the results provided in Section 3.6 it appears that the OLM technique was not used in estimating the annual concentrations. This method is appropriate for estimates of annual concentrations. Table 6-11 provides annual NO<sub>2</sub> concentrations using the Tier 3 OLM procedure. Because the Tier 3 OLM produced annual concentrations are larger than the Tier 1 values, the OLM resultant annual NO<sub>2</sub> values should be the reported concentrations or the reason for not using the OLM for annual NAAQS concentrations should be provided.

**Response**: The annual average  $NO_2$  concentrations modeled in the NAAQS analysis and provided in the revised Table 6-11 of the modeling report are based on both the Tier 1 procedure (actually Tier 2) and Tier 3 OLM procedure. It should be noted that the reported Tier 1 values used the  $NO_2/NO_x$  ratio of 0.75, assuming that 75 percent of the  $NO_x$  emissions were converted to  $NO_2$  (this is actually a Tier 2 approach). If 100% of the  $NO_x$  emissions were assumed to be converted to  $NO_2$  as a Tier 1 approach, the OLM resultant annual  $NO_2$  values would be lower. In both cases, maximum predicted impacts were well below the NAAQS.

Comment 4. Emission Inventory Other Sources – All maximum impacts (i.e., NO<sub>2</sub>, CO, PM<sub>10</sub>, and PM<sub>2.5</sub>) from project emissions are greater than the SILs. Therefore, cumulative NAAQS/PSD compliance modeling is needed. The following comments are associated with the inventories of other sources used in the cumulative modeling.

#### NO<sub>2</sub> Inventory

- The 20D procedure is a screening procedure to identify sources that can be considered for elimination from the cumulative modeling. The North District Wastewater Treatment Plant (0250600) in the NO<sub>2</sub> inventory (Table 6-5) is 0.5 TPY less than the 20D value. This source should have been included in the NAAQS compliance modeling.

**Response:** Table 6-5 uses a North Carolina screening technique approach based on 20 x (D-SID) where SID is the maximum significant impact distance of the proposed project. The North Carolina Screening Technique recommends using a 20 x (D-SID) approach for the annual averaging time and a 20 x D approach for short-term averaging times. Use of the 20 x (D-SID) approach is extremely conservative for selecting background sources to be included for a 1-hour averaging time modeling analysis. For the North District Wastewater Treatment Plant, for example, use of a 20 x D approach, instead of the 20 x (D-SID) approach, would result in an emission threshold (i.e., Q value in Table 6-5) of nearly 400 TPY instead of the 229 TPY shown in the table. Therefore, considering the conservative approach taken, background sources such as North District Wastewater Treatment Plant that are marginally below the emission threshold need not be included in the modeling analysis.



- The sources of the hourly NO<sub>2</sub> emission rates, in order of priority, were 1) FDEP's data query report, 2) Potential emission limits from facility operating permits, if any, or 3) Emission factors from EPA's AP-42 or similar document along with operating capacity. Given only a previous annual NO<sub>2</sub> ambient standard, it appears that most of these sources of hourly emission rates would be based on the annual allowable/permitted TPY and not the maximum hourly rate. The NO<sub>2</sub> hourly emission rates that are known to be reflective of the maximum potential or allowable hourly rate should be identified in the inventory of NO<sub>2</sub> emission units (Table D-1).
- For emission rates that are not reflective of maximum hourly values, Attachment A to the 28 June 2010 Tyler Fox memorandum provides suggested technique to develop the appropriate values.

**Response**: Table D-1 has been updated to include a more detailed description of emission sources as well as a column to show whether or not the emissions are based on hourly averaging times. As shown in Table D-1, the majority of the emission rates used in the 1-hour NO<sub>2</sub> modeling analysis was based on hourly average emission rates.

For several emissions sources, an annual permitted emission limit was used instead of the available potential hourly emissions rate provided in FDEP's data query report. This was done only when the emission rate, calculated in lb/hr based on the permitted annual average emission rate in TPY, was greater than the potential hourly rate provided in lb/hr in FDEP's data query report. As an example, for General Asphalt – Plant No. 1 (Facility ID No. 0250020), the potential hourly emission rate provided in FDEP's data query report are 9.58 lb/hr. However, permit ID no. 0250005-007-AO has a facility-wide emission limit of 100 TPY for NO<sub>2</sub>. At the permitted operating hours of 8,760 hr/yr, the calculated hourly rate from 100 TPY is 22.83 lb/hr. This value is higher and, therefore, conservative when compared to the hourly rate provided in FDEP's data query report.

It should also be noted that the sources included in the 1-hour NO<sub>2</sub> analysis extend out to 50 km and beyond from the project site. At the time of the original analysis, there was some uncertainty about screening procedures for background sources for the 1-hour averaging time. As stated in Response to Comment 1, EPA recently has provided some clarification for these procedures in the March 1, 2011 Tyler Fox memo. As stated on page 16 of the memo:

"...these considerations suggest that the emphasis on determining which nearby sources to include in the modeling analysis should focus on the area within 10 kilometers of the project location in most cases. The routine inclusion of all sources within 50 kilometers of the project location, the nominal distance for which AERMOD is applicable, is likely to produce an overly conservative result in most cases."

Based on the above statement, is reasonable to assume that the number of background sources included 1-hour  $NO_2$  analysis is conservative. In addition, the highest 1-hour emissions rates were used as available.

- The reason for the correction to the emission rates for units EU003 and EU015 at the Fort Lauderdale Plant should be provided.

**Response:** The correction was made to correct a calculation error. Emission units EU003 and EU015 include a bank of 12 combustion turbines each. The initial modeling analysis used the emission rate from only one turbine for each bank. In the revised modeling, the initial modeling emission rates for EU003 and EU015 were each multiplied by 12 to account for the emission rate from all 12 turbines. The revised emission rate for each of EU003 and EU015 is 7,572 lb/hr, corrected from 631 lb/hr.

- The basis (e.g., minor source baseline date) for removing emission units from the NAAQS inventory of other sources to develop the PSD increment inventory should be provided.



**Response**: All emission units modeled in the NAAQS analysis for NOx were also modeled in the PSD increment analysis. Several corrections were made to Table D-1 to reflect the modeling analysis.

Two emission units, Units 1 and 4 at Sugar Cane Growers Co-op, ID No. 0990026, were shown in Table D-1 as not modeled in the PSD Increment Analysis. These sources were modeled in the PSD increment analysis, and Table D-1 has been corrected to show this.

In addition, the South District Wastewater Treatment Plant was shown in Table D-1 of the December 2010 modeling report as being modeled in the NAAQS analysis but not the PSD Increment analysis. Upon further review, it determined that total emissions for this facility shown in Table 6-5 were incorrect and this facility was not screened out of the analysis. Table 6-5 has now been updated to show the correct emissions, which are lower than previous emissions. Table D-1 has been updated to exclude this facility from the detailed inventory based on the updated emissions.

#### PM<sub>2.5</sub> Inventory

- The report indicates the inventory of  $PM_{10}$  emission sources was used for  $PM_{2.5}$  NAAQS compliance modeling. The  $PM_{10}$  emission rates were assumed to be the  $PM_{2.5}$  rates.

**Response:** Without available data, most  $PM_{2.5}$  emission rates were assumed to be equal to  $PM_{10}$  emission rates, which is a conservative assumption because, for certain type of emission sources,  $PM_{2.5}$  emission rate can be a small fraction of the  $PM_{10}$  emission rate.

- The sources of the maximum PM<sub>2.5</sub> emission rate was the same as indicated for the NO<sub>2</sub> inventory. Because PM<sub>10</sub> had a 24-hour NAAQS, it would appear that the hourly emission rates provided in FDEP records would be associated with this period (i.e., hourly rate developed from maximum emissions over 24-hours).

**Response**: The hourly emission rates developed for the  $PM_{2.5}$  emission rates were based on the same approach used to develop the  $NO_2$  inventory (see response to Comment 4).

- Actual emission rates for PSD increment assessment were not available so NAAQS emission rates were used for the  $PM_{10}$  PSD increment assessment.

**Response**: NAAQS emission rates are based on either allowable or potential emission rates, which are higher than the actual emission rates. Therefore, the PM<sub>10</sub> increment assessment for the proposed project, which is based on NAAQS emission rates, provides a conservative (higher-than-expected) estimate of PSD increment consumption.

- The basis for the use of 30 percent of the  $PM_{10}$  emission as  $PM_{2.5}$  for baghouse emission units at the Miami Dade Resource Recovery facility should be explained. The 0.01 grain per dry standard cubic foot emission limit used in the calculation should be a permit limit. In addition, the largest baghouse emissions appear to be associated with Units 6 and 7 which do not appear to be material handling, the category used for the particle size information. Confirmation is needed that the  $PM_{10}$  emission rates were used for the  $PM_{10}$  NAAQS and PSD increment compliance modeling.

**Response**: The 30-percent factor is based on Category 4 of Table B.2.2 in Appendix B.2 of AP-42, which provides generalized particle size distribution for particulate matter emissions from material handling and processing of processed ores and nonmetallic minerals. This category is similar to Category 3, which covers processing of aggregate and unprocessed ore. These categories include such processes as milling, grinding, crushing, screening, conveying, cooling, and drying. Emissions are generated through either the movement of the material or the interaction of the material with mechanical devices.



Emission Unit 6 at the Miami Dade Resource Recovery Facility (MDCRRF) is a processing activity of receiving, handling and converting of municipal solid waste into refuge derived fuel. Emission Unit 7 at the MDCRRF is a bulky waste processing system, which is designed to process bulky waste into biomass. PM emissions from both units are controlled by baghouses. PM emission from Unit 7 is limited to 0.01 gr/dscf. PM emission from Unit 6 is assumed to have the same grain loading.

PM emissions were used in PM<sub>10</sub> NAAQS analysis. In reality, on Category 4 of Table B.2.2 in Appendix B.2 of AP-42, PM<sub>10</sub> is 85-percent of PM.

- The basis (e.g., minor source baseline date) for removing emission units from the NAAQS inventory of other sources to develop the PSD increment inventory should be provided.

**Response:** For this project, the PSD increment inventory of background sources was the same as the NAAQS background source inventory with a few exceptions for some sources that are well beyond 50-km from the proposed site .

- The PSD increment expanding Units 4 & 5 at FP&L Fort Lauderdale facility should be modeled using the actual emissions, not allowable, just prior to their shut down.

**Response**: PSD increment expanding sources were not included in the PSD increment analyses for this project.

- Comment 7. Receptor Grids The following comments are associated with the modeled receptor grids.
  - Receptor grids of 250-m resolution from 2 km to 4 km and 500-m resolution from 4 km to 7 km appear too coarse to allow the identification of concentrations needing refined 100-m resolution modeling

**Response:** The receptor where the maximum 1-hour NO2 NAAQS concentration is predicted is on the northernmost row of the receptor grid that was developed based on a maximum significant impact distance of 8.5 km. Similarly, the receptor where the maximum 24-hour PM<sub>2.5</sub> NAAQS concentration is located approximately 3.6 km west-northwest of the proposed project site. The proposed project's maximum impact is well below the significant impact level at both of these locations and the predicted concentrations are mostly due to the influence of background sources.

Recent  $NO_2$  modeling guidance published by EPA on March 1, 2011, suggests that a reasonable approach to cumulative source modeling is to consider only those receptors where a project has a significant impact. Use of such an approach on future cumulative source modeling applications would largely eliminate the need to consider additional refinements for receptors where the predicted impacts are mainly due to the influence of background source emissions.

- To ensure the appropriate controlling concentrations are identified, the maximum modeled concentrations and all concentrations challenging the maximum concentrations (e.g., within 10%) should be modeled to 100-m resolution.

**Response:** The controlling maximum concentrations are predicted on the edge of the outside receptors of the receptor grid and are exclusively due to emissions from background sources located beyond 25 km from the project site. As a result, no refinements were performed for those locations. There are no other isolated concentration hotspots within 10 percent of the magnitude of the controlling concentrations. The inclusion of numerous background sources that are located well beyond 10 km from the proposed site was based on the modeling guidance that prevailed at that time of the original modeling.



Comment 8. Post-processing Programs – To provide an opportunity to evaluate the proper operation of the Golder post-processing software used to pair modeling and monitored values and to obtain the form of the NAAQS, the post-processing software should be provided along with the input and output files. Any documentation and associated testing files used in Golder's verification analyses for the post-processor programs should also be provided with the revised modeling report.

**Response:** A sample test, in two parts, is being provided to demonstrate that Golder's preprocessor program correctly computes the maximum 5-year average 8<sup>th</sup> highest daily maximum 1-hour concentration. In the first part of the test (in folder Test 1), a sample 1-hour NO2 analysis is run with AERMOD version 09292 separately for 5 years of data. For each year, a 1-hour post files is output. Golder's postprocessor program reads the output post files for each year and outputs a comma delineated (csv) file for each year showing the highest daily 1 hour maximum concentration for each receptor. The program then creates a sixth csv file that averages data from the 5 yearly csv files and determines the highest 5-year average 8<sup>th</sup> highest 1-hour concentration. For the example presented, that concentration is 434.36877.

In the second part of the test (folder Test 2), the same input file is run using AERMOD version 11103 with a concatenated 5-year meteorological record. An 8<sup>th</sup> highest value is requested on the RECTABLE card. The AERMOD output summary shows an 8<sup>th</sup> concentration of 434.36877.

Comment 9. PSD Class I Area Assessment – Although the SIL for the nearest PSD Class I area revealed impacts less than the SIL, the report does not address any expected changes in the project's impact on AQRV.

**Response**: The AQRV analyses have been updated and the revised AQRV results are presented in the attached revised Tables 7-5 and 7-6. The results are slightly higher than those previously reported but are still below the criteria.

Thank you for your consideration of this information. If you have any questions, please do not hesitate to call me at (352) 336-5600.

Salahuddin K. Mohammad

Senior Project Engineer

Sincerely,

GOLDER ASSOCIATES INC.

David A. Buff, P.E. Principal Engineer

cc: D. Thorley, WMI

**Enclosures** 

SKM/nav



TABLE 1
PREDICTED CONCENTRATION DIFFERENCES FROM LAND USE PARAMETERS
RELATIVE TO THE SIL AND NAAQS

Pollutant ·	Concentrations Land Use Para		Conc. Difference (Diff) (Site - MIA)	EPA SIL	Fraction Diff/SIL	NAAQS	Fraction Diff/NAAQS
	Site	MIA	(µg/m³)	(µg/m³)		(µg/m³)	
Short-Term Ave	eraging Times <sup>a</sup>						
PM <sub>10</sub>	15.8	13.1	2.7	5	0.54	150	0.018
PM <sub>2.5</sub>	15.8	13.1	2.7	1.2	2.25	35	0.077
NO <sub>2</sub> Tier 1	105.1	94.1	11	7.52	1.46	188.1	0.058
Annual Averagi	ng Time						
PM <sub>10</sub>	1.5	1.9	-0.4	ነ	-0.40	50.0	-0.008
PM <sub>2.5</sub>	1.5	1.9	-0. <b>4</b>	0.3	-1.33	15.0	-0.027
NO <sub>2</sub> Tier 2	3	3.7	-0.7	1	-0.70	100.0	-0.007

 $<sup>^{\</sup>rm a}$  Short-term averaging time is 24-hours for PM $_{\rm 10}$  and PM $_{\rm 2.5}$  and 1-hour for NO $_{\rm 2}$ . SIL = Significant Impact Level NAAQS = National ambient air quality standard



TABLE 2
HOURLY AMBIENT OZONE MONITORING DATA SUMMARY
AIR QUALITY ANALYSIS FOR MEDLEY PSD APPLICATION

		1-Hour Avera	age O <sub>3</sub> Conce	ntration (ppm)	
Monitoring Station and ID	2001	2002	2003	2004	2005
Maximum 1-Hour Average					
# 860021 (Krome Ave)	0.107	0.095	0.090		
# 860027 (Rosenstiel School)	0.119	0.084	0.094	0.094	0.092
# 860029 (Perdue Med Center)	0.119	0.091	0.102	0.090	0.088
98th Percentile of Daily Maximum 1-Hour Average	9				
# 860021 (Krome Ave)	0.077	0.071	0.073		
# 860027 (Rosenstiel School)	0.071	0.071	0.075	0.077	0.077
# 860029 (Perdue Med Center)	0.075	0.073	0.069	0.071	0.071
Maximum 1-Hour Average - Winter					
# 860021 (Krome Ave)	0.063	0.071	0.074		
# 860027 (Rosenstiel School)	0.071	0.072	0.084	0.066	0.062
# 860029 (Perdue Med Center)	0.074	0.068	0.076	0.069	0.062
Maximum 1-Hour Average - Spring					
# 860021 (Krome Ave)	0.107	0.095	0.090		
# 860027 (Rosenstiel School)	0.119	0.083	0.094	0.094	0.086
# 860029 (Perdue Med Center)	0.119	0.091	0.102	0.090	0.077
Maximum 1-Hour Average - Summer					
# 860021 (Krome Ave)	0.092	0.094			
# 860027 (Rosenstiel School)	0.056	0.084	0.059	0.067	0.084
# 860029 (Perdue Med Center)	0.101	0.086	0.057	0.053	0.077
Maximum 1-Hour Average - Fall					
# 860021 (Krome Ave)	0.080	0.066			
# 860027 (Rosenstiel School)	0.079	0.067	0.071	0.071	0.092
# 860029 (Perdue Med Center)	0.076	0.066	0.070	0.062	0.088



TABLE 3
HOURLY AMBIENT NO2 MONITORING DATA SUMMARY
AIR QUALITY ANALYSIS FOR MEDLEY PSD APPLICATION

		1-Hour Avera	ge NO <sub>2</sub> Concer	ntration (ppm)	
Monitoring Station and ID	2001	2002	2003	2004	2005
Maximum 1-Hour Average					
# 864002 (Metro Annex)	0.076	0.059	0.085	0.417	0.063
# 860027 (Rosenstiel School)	0.055	0.050	0.058	0.066	0.058
# 118002 (Dania, Broward County)	0.086	0.080	0.068	0.070	0.094
98th Percentile of Daily Maximum 1-Hour Average					
# 864002 (Metro Annex)	0.058	0.052	0.051	0.058	0.056
# 860027 (Rosenstiel School)	0.050	0.044	0.045	0.047	0.053
# 118002 (Dania, Broward County)	0.061	0.047	0.052	0.057	0.051
Maximum 1-Hour Average - Winter			•		
# 864002 (Metro Annex)	0.076	0.059	0.085	0.065	0.062
# 860027 (Rosenstiel School)	0.055	0.049	0.058	0.066	0.058
# 118002 (Dania, Broward County)	0.084	0.080	0.068	0.064	0.067
Maximum 1-Hour Average - Spring					
# 864002 (Metro Annex)	0.074	0.044	0.051	0.417	0.063
# 860027 (Rosenstiel School)	0.051	0.040	0.038	0.043	0.058
# 118002 (Dania, Broward County)	0.086	0.052	0.06	0.07	0.094
Maximum 1-Hour Average - Summer					
# 864002 (Metro Annex)	0.049	0.043	0.037	0.046	0.051
# 860027 (Rosenstiel School)	0.041	0.039	0.043	0.045	0.049
# 118002 (Dania, Broward County)	0.050	0.044	0.042	0.047	0.046
Maximum 1-Hour Average - Fall					
# 864002 (Metro Annex)	0.055	0.048	0.037	0.046	0.056
# 860027 (Rosenstiel School)	0.047	0.050	0.040	0.044	0.047
# 118002 (Dania, Broward County)	0.062	0.048	0.058	0.042	0.050



TABLE 4
WASHINGTON COUNTY POWER, LLC
NO - NO₂ Data

	1	Manufacture or	Emissis- H-it			Combuster	T	Deta Sauras	<del>-</del>	If Source Test,	Sauraa ar	NO2	NO	NOx	NO2/NOx	%CO <sub>2</sub>	Provided by	
Stationany Source	Linit Decemention			Size	Fuel Time	Combustor	Control Equipment	Data Source	Test Run	Load Level	Source or Test Year	PPMv	NO PPMv	PPMv	Ratio		test firm, site contact	(Submitted by
Stationary Source	Unit Description	Vendor	Number	Size	Fuel Type	Equipment	Control Equipment	(CEM, Source	Test Run	Load Level	lest fear	PPWV	PPIMV	PPWIV	Ratio		test iim, site contact	Asabitated by
Washington T1	СТ	General Electric	T1	169	PNG	Can Annular	DLN	Source Test	1	158	6/29/2010	0.7	9.1	9.8	0.07	4.2	C.E.M. Solutions	Joe Conti
Washington T1	CT	General Electric	T1	169	PNG	Can Annular	DLN	Source Test	2	157	6/29/2010	0.6	9.1	9.7	0.06	4.2	C.E.M. Solutions	Joe Conti
Washington T1	CT	General Electric	T1	169	PNG	Can Annular	DLN	Source Test	3	157	6/29/2010	0.6	9.1	9.7		4.2	C.E.M. Solutions	Joe Conti
Washington T1	CT	General Electric	T1	169	PNG	Can Annular	DLN	Source Test	4	157	6/29/2010	0.6	9.0	9.6		4.2	C.E.M. Solutions	Joe Conti
Washington T1	CT	General Electric	T1	169	PNG	Can Annular	DLN	Source Test	5	158	6/29/2010	0.6	9.0	9.6		4.1	C.E.M. Solutions	Joe Conti
Washington T1	CT	General Electric	T1	169	PNG	Can Annular	DLN	Source Test	6	158	6/29/2010	0.8	8.9	9.7		4.1	C.E.M. Solutions	Joe Conti
Washington T1	CT	General Electric	T1	169	PNG	Can Annular	DLN	Source Test	7	158	6/29/2010	0.7	9.0	9.7			C.E.M. Solutions	Joe Conti
Washington T1	CT	General Electric	T1	169	PNG	Can Annular	DLN	Source Test	8	158	6/29/2010	0.6	8.4	9.0		4.1	C.E.M. Solutions	Joe Conti
Washington T1	CT	General Electric	T1	169	PNG	Can Annular	DLN	Source Test	9	157	6/29/2010	0.6	6.9	7.5			C.E.M. Solutions	Joe Conti
Washington T2	СТ	General Electric	T2	169	PNG	Can Annular	DLN	Source Test	1	159	6/29/2010	0.8	9.7	10.5	0.08	4.1	C.E.M. Solutions	Joe Conti
Washington T2	CT	General Electric	T2	169	PNG	Can Annular	DLN	Source Test	3	158	6/29/2010	0.6	9.8	10.4	0.06	4.2	C.E.M. Solutions	Joe Conti
Washington T2	CT	General Electric	T2	169	PNG	Can Annular	DLN	Source Test	4	158	6/29/2010	0.8	9.8	10.6	0.08	4.2	C.E.M. Solutions	Joe Conti
Washington T2	CT	General Electric	T2	169	PNG	Can Annular	DLN	Source Test	5	158	6/29/2010	0.8	9.8	10.6	0.08	4.2	C.E.M. Solutions	Joe Conti
Washington T2	CT	General Electric	T2	169	PNG	Can Annular	DLN	Source Test	6	157	6/29/2010	0.8	9.8	10.6	0.08	4.2	C.E.M. Solutions	Joe Conti
Washington T2	CT	General Electric	T2	169	PNG	Can Annular	DLN	Source Test	7	157	6/29/2010	0.8	9.8	10.6	0.08	4.2	C.E.M. Solutions	Joe Conti
Washington T2	CT	General Electric	T2	169	PNG	Can Annular	DLN	Source Test	8	157	6/29/2010	0.8	9.9	10.7	0.07	4.1	C.E.M. Solutions	Joe Conti
Washington T2	CT	General Electric	T2	169	PNG	Can Annular	DLN	Source Test	9	157	6/29/2010	0.8	9.8	10.6	0.08	4.2	C.E.M. Solutions	Joe Conti
Washington T2	СТ	General Electric	T2	169	PNG	Can Annular	DLN	Source Test	10	156	6/29/2010	8.0	9.7	10.5	0.08	4.2	C.E.M. Solutions	Joe Conti
Washington T3	СТ	General Electric	Т3	169	PNG	Can Annular	DLN	Source Test	1	164	6/30/2010	0.5	9.4	9.9		4.2	C.E.M. Solutions	Joe Conti
Washington T3	CT	General Electric	Т3	169	PNG	Can Annular	DLN	Source Test	2	162	6/30/2010	0.4	8.7	9.1		4.2	C.E.M. Solutions	Joe Conti
Washington T3	CT	General Electric	T3	169	PNG	Can Annular	DLN	Source Test	3	161	6/30/2010	0.3	8.6	8.9	0.03	4.2	C.E.M. Solutions	Joe Conti
Washington T3	CT	General Electric	Т3	169	PNG	Can Annular	DLN	Source Test	4	161	6/30/2010	0.4	8.5	8.9	0.04	4.2	C.E.M. Solutions	Joe Conti
Washington T3	CT	General Electric	Т3	169	PNG	Can Annular	DLN	Source Test	5	161	6/30/2010	0.4	8.5	8.9			C.E.M. Solutions	Joe Conti
Washington T3	CT	General Electric	T3	169	PNG	Can Annular	DLN	Source Test	6	166	6/30/2010	0.4	8.5	8.9			C.E.M. Solutions	Joe Conti
Washington T3	CT	General Electric	Т3	169	PNG	Can Annular	DLN	Source Test	7	166	6/30/2010	0.5	8.4	8.9		4.2	C.E.M. Solutions	Joe Conti
Washington T3	CT	General Electric	Т3	169	PNG	Can Annular	DLN	Source Test	8	166	6/30/2010	0.5	8.3	8.8		4.2	C.E.M. Solutions	Joe Conti
Washington T3	СТ	General Electric	Т3	169	PNG	Can Annular	DLN	Source Test	9	165	6/30/2010	0.5	8.3	8.8	0.06	4.2	C.E.M. Solutions	Joe Conti
Washington T4	СТ	General Electric	T4	169	PNG	Can Annular	DLN	Source Test	1	159	6/30/2010	0.6	7.1	7.7			C.E.M. Solutions	Joe Conti
Washington T4	CT	General Electric	T4	169	PNG	Can Annular	DLN	Source Test	2	159	6/30/2010	0.6	6.9	7.5			C.E.M. Solutions	Joe Conti
Washington T4	CT	General Electric	T4	169	PNG	Can Annular	DLN	Source Test	3	159	6/30/2010	0.6	7.1	7.7			C.E.M. Solutions	Joe Conti
Washington T4	CT	General Electric	T4	169	PNG	Can Annular	DLN	Source Test	4	159	6/30/2010	0.6	6.9	7.5		4.1	C.E.M. Solutions	Joe Conti
Washington T4	CT	General Electric	T4	169	PNG	Can Annular	DLN	Source Test	5	159	6/30/2010	0.6	6.8	7.4			C.E.M. Solutions	Joe Conti
Washington T4	CT	General Electric	T4	169	PNG	Can Annular	DLN	Source Test	6	159	6/30/2010	0.6	6.8	7.4	0.08	4.1	C.E.M. Solutions	Joe Conti
Washington T4	CT	General Electric	T4	169	PNG	Can Annular	DLN	Source Test	7	159	6/30/2010	0.6	6.8	7.4		4.1	C.E.M. Solutions	Joe Conti
Washington T4	CT	General Electric	T4	169	PNG	Can Annular	DLN	Source Test.	8	159	6/30/2010	0.6	6.8	7.4	0.08	4.1	C.E.M. Solutions	Joe Conti
Washington T4	CT	General Electric	T4	169	PNG	Can Annular	DLN	Source Test	9	159	6/30/2010	0.6	6.7	7.3	0.08	4.0	C.E.M. Solutions	Joe Conti



May 2011

TABLE 5 WALTON COUNTY POWER, LLC NO - NO $_2$  Data

		••••••••••••••••••••••••••••••••••••••	Forincian Hair			Combustor		Data Source		If Source Test,	Source or	NO2	NO	NOx	NO2/NOx	%O <sub>2</sub>	Provided by	
			Emission Unit	•			0 4 1 F 3 4		Tant Dum	Load Level	Test Year	PPMv	PPMv	PPMv	Ratio	_	(test firm, site contact)	Submitted by
Stationary Source	Unit Description	Vendor	Number	Size	Fuel Type	Equipment	Control Equipment	(CEM, Source Test)	rest Run	Load Level	rest rear	LLMIA	LLIMIA	FFINA	Nauo		(test min, site contact)	Submitted by
Walton T1	СТ	Siemens	T1	162	PNG	Annular	DLN	Source Test	1	153	6/23/2010	1.8	10.5	12.3	0.15	14.6 (	C.E.M. Solutions	Joe Conti
Walton T1	CT	Siemens	T1	162	PNG	Annular	DLN	Source Test	2	153	6/23/2010	1.6	10.8	12.4	0.13		C.E.M. Solutions	Joe Conti
Walton T1	CT	Siemens	T1	162	PNG	Annular	DLN	Source Test	3	154	6/23/2010	1.9	10.7	12.6	0.15		C.E.M. Solutions	Joe Conti
Walton T1	CT	Siemens	T1	162	PNG	Annular	DLN	Source Test	4	153	6/23/2010	1.9	10.7	12.6	0.15	14.6 (	C.E.M. Solutions	Joe Conti
Walton T1	CT	Siemens	T1	162	PNG	Annular	DLN	Source Test	5	153	6/23/2010	1.8	10.9	12.7	0.14		C.E.M. Solutions	Joe Conti
Walton T1	CT	Siemens	T1	162	PNG	Annular	DLN	Source Test	6	154	6/23/2010	1.8	10.8	12.6	0.14		C.E.M. Solutions	Joe Conti
Waiton T1	CT	Siemens	T1	162	PNG	Annular	DLN	Source Test	7	154	6/23/2010	1.7	11.0	12.7	0.13		C.E.M. Solutions	Joe Conti
Walton T1	CT	Siemens	T1	162	PNG	Annular	DLN	Source Test	8	154	6/23/2010	1.7	10.8	12.5	0.14		C.E.M. Solutions	Joe Conti
Walton T1	CT	Siemens	T1	162	PNG	Annular	DLN	Source Test	9	154	6/23/2010	1.7	10.9	12.6	0.13	14.5 (	C.E.M. Solutions	Joe Conti
										450	0/00/0040	0.0	40.7	45.0	0.45	4427	C.E.M. Solutions	Joe Conti
Walton T2	СТ	Siemens	T2	162	PNG	Annular	DLN	Source Test	1	152	6/22/2010	2.3	12.7	15.0	0.15			
Walton T2	CT	Siemens	T2	162	PNG	Annular	DLN	Source Test	3	154	6/22/2010	2.3	13.4	15.7	0.15		C.E.M. Solutions	Joe Conti
Walton T2	CT	Siemens	T2	162	PNG	Annular	DLN	Source Test	4	154	6/22/2010	2.5	13.2	15.7	0.16		C.E.M. Solutions	Joe Conti
Walton T2	СТ	Siemens	T2	162	PNG	Annular	DLN	Source Test	5	154	6/22/2010	2.6	13.6	16.2	0.16		C.E.M. Solutions	Joe Conti
Walton T2	СТ	Siemens	T2	162	PNG	Annular	DLN	Source Test	6	154	6/22/2010	2.7	13.5	16.2	0.17		C.E.M. Solutions	Joe Conti
Walton T2	СТ	Siemens	T2	162	PNG	Annular	DLN	Source Test	7	154	6/22/2010	2.6	13.5	16.1	0.16		C.E.M. Solutions	Joe Conti
Walton T2	СТ	Siemens	T2	162	PNG	Annular	DLN	Source Test	8	154	6/22/2010	2.6	13.5	16.1	0.16		C.E.M. Solutions	Joe Conti
Walton T2	CT	Siemens	T2	162	PNG	Annular	DLN	Source Test	9	154	6/22/2010	2.6	13.5	16.1	0.16		C.E.M. Solutions	Joe Conti
Walton T2	СТ	Siemens	T2	162	PNG	Annular	DLN	Source Test	10	154	6/22/2010	2.6	12.6	15.2	0.17	14.6 (	C.E.M. Solutions	Joe Conti
Walton T3	СТ	Siemens	Т3	162	PNG	Annular	DLN	Source Test	1	156	6/22/2010	1.9	10.0	11.9	0.16	14.2 (	C.E.M. Solutions	Joe Conti
Walton T3	CT	Siemens	Т3	162	PNG	Annular	DLN	Source Test	2	157	6/22/2010	1.8	10.9	12.7	0.14	14.3 (	C.E.M. Solutions	Joe Conti
Walton T3	CT	Siemens	Т3	162	PNG	Annular	DLN	Source Test	3	157	6/22/2010	1.8	10.9	12.7	0.14	14.3 (	C.E.M. Solutions	Joe Conti
Walton T3	CT	Siemens	Т3	162	PNG	Annular	DLN	Source Test	4	157	6/22/2010	1.9	10.8	12.7	0.15	14.3 (	C.E.M. Solutions	Joe Conti
Walton T3	CT	Siemens	Т3	162	PNG	Annular	DLN	Source Test	5	158	6/22/2010	1.9	11.1	13.0	0.15	14.4 (	C.E.M. Solutions	Joe Conti
Walton T3	CT	Siemens	Т3	162	PNG	Annular	DLN	Source Test	6	157	6/22/2010	1.9	11.0	12.9	0.15	14.4 (	C.E.M. Solutions	Joe Conti
Walton T3	CT	Siemens	Т3	162	PNG	Annular	DLN	Source Test	7	157	6/22/2010	1.9	10.9	12.8	0.15	14.4 (	C.E.M. Solutions	Joe Conti
Walton T3	CT	Siemens	Т3	162	PNG	Annular	DLN	Source Test	8	157	6/22/2010	1.9	10.9	12.8	0.15	14.3 (	C.E.M. Solutions	Joe Conti
Walton T3	CT	Siemens	Т3	162	PNG	Annular	DLN	Source Test	9	157	6/22/2010	1.9	10.9	12.8	0.15	14.3 (	C.E.M. Solutions	Joe Conti



May 2011 1 1

TABLE 6-5 (Revised 4/29/11)
SUMMARY OF THE NO<sub>x</sub> FACILITIES CONSIDERED FOR INCLUSION IN THE AAQS AND PSD CLASS II AIR MODELING ANALYSES

ABS				UTM C	oordinates		Relative to M	edley Landfill		Maximum NO <sub>x</sub>	Q, (TPY) Emission	Include
200506   Wasselshampmert-Merby Lenfis   Maint-Dobe   505 6   2,556 8   2,556 8   1   1   50		cility	County	East	North	x	. A	Distance	Direction	<b>Emissions</b>	Short-Term Threshold b,c	Modelir Analysi
Marie Debit Service				_	-				-			
SECURED LESS FORMS   Manufacture Corp.   Manufacture Corp.   Manufacture Corp.   Security									-			YES
SIGNATION   APPLICATION   Control												YES YES
												YES
Control   Cont												YES
2505002   December Medical Grampin   Marin Tache   2564   2502   2.5   .07   .250   .05												YES
												YES
												YES
	0250020 Tita	an America-Pennsuco Cement	Miami-Dade	562.3			1.8	4.05	296			YES
	0250005 Ger	neral Asphalt - Plant No. 1	Miami-Dade	568.8	2,855.4	2.9	<b>-4</b> .5	5.35	147	100.0	SIA	YEŞ
Main-Coate   Mai			Miami-Dade							1.0		YES
Main-Dasis   Mai												YES
Main-Cade   963.8   286.21   2.1   7.8   60.4   195   5.0   50.4   50.0   50.												YES
Marie-Cade   ST0.6   2,853.4   4.7   6.5   8.04   144   42   31A   1.2												YES
Mars-Loade   507   2,080.3   3.8   8.4   9.23   24   81.3   14.6   10000000   14.5												YES YES
Mars-Loade   507   2,863   3.8   8.4   9.23   24   813   14   6   15   15   15   15   15   15   15												
CSCASCA   Taulbornisates	0250624 Ger											YES
												NO
7777221 Ranger Contruction, South - Mann No. 2.  Main Dude 58.1 2, 2888.9 7.8 9.0 11.53 319 8.0 68.6 (2020) Mann Code 50.0 2.00.0 1.8 9.0 11.53 319 8.0 68.6 (2020) Mann Code 50.0 2.00.0 1.8 9.0 11.53 319 8.0 68.6 (2020) Mann Code 50.0 2.00.0 1.8 9.0 11.53 319 8.0 68.6 (2020) Mann Code 50.0 2.00.0 1.8 9.0 11.53 319 8.0 68.6 (2020) Mann Code 50.0 2.00.0 11.50												NO
COSCORD   Main Deck Soil Visit Myreth Opade L   Main Deck Str 70   2,886.3   4.59   4.12   4.17   12.8   8.8   9.4   12.9   4.17   12.8   8.8   9.4   12.9   4.17   12.8   8.8   9.4   12.9   4.17   12.8   8.8   9.4   12.9   4.17   12.8   12.9   12.7   12.8   12.9   12.7   12.8   12.9   12.7   12.8   12.9   12.7   12.8   12.9   12.7   12.8   12.9   12.7   12.8   12.9   12.7   12.8   12.9   12.7   12.8   12.9   12.7   12.8   12.9   1												YES
COSPORT   Control Description   Control De												NO
2025023   Bakson Memorial Histopials												NO
## STRICT   ## S												YES
2025004   Powers Baking Company of Miami												NO
2025013 Abanander ORR Wilster Treatment Plant   Mann-Dade   597.5   2,943.4   1.6   16.5   16.02   17.5   436.0   162.4   17.5												NO NO
												YES
1011207 Broward Courtly interin Confingency II DOUGNET Central District Valenteant Framework Mann-Caste State Stat												NO
2026476   Central District Westsweller Freidmert Plant   Main-Dade   584.6   2.947.8   187.   1.21   22.31   151.4   278.1   277.757.27   Westshort Askarda Flaving, Inc., Plant No. 1   Broward   597.3   2.886.6   2.947.8   2.241   337   3.55   278.2   2.241   337   2.241   337   2.242   337   2.241   337   2.242   337   2.241   337   2.242   337   2.241   337   2.242   337   2.241   337   2.242   337   2.241   337   2.242   337   2.241   337   2.242   337												NO
### ST75212 Weelery Apphill Paving, Inc., Plant No. 1  ### Stranger Conference From Part 1  ### Stranger Conference From P												NO
												NO
1011002   Memoria Regio Hosp, Size, Broward Hosp, Dist.   Broward   Size, 2007.9   15.3   18.0   2362   40   7.1   302.4												NO
1012410 Shamd Pump Station S-36-Se												NO
Decision   FPAL_Cutier Power Part   Mismi-Dade   598.9   2,353.0   4.0   24.9   25.24   171   2,242.6   30.48   1.0   30.48												NO
D111014 Arigstrom Graphics												YES
01101037 FL Luadridae Power Plant												NO
0110037 Ft_Lauderdate Previer Plant   Broward   580.1   2.883.6   14.2   23.7   27.61   31   10.389.6   382.2   0110056 Mores Enterprises - South   Broward   586.2   2.884.6   2.99   2.47   2.285.3   32.99   40   11.00   477.1   0112688 Vencentrepri Logistics Profit Everglades Term   Broward   586.2   2.884.6   2.99   2.47   2.285.3   32.99   40   17.7   489.2   2.885.6   2.99   2.70   2.885.6   2.99   2.70   2.885.6   2.99   2.70   2.885.6   2.99   2.70   2.985.6   2.99   2.70   2.985.6   2.99   2.70   2.985.6   2.99   2.70												YES
0110505 RPAL - Port Everglades Terminal Broward \$67.0	0110037 Ft. L	Lauderdale Power Plant	Broward	580.1	2,883.6	14.2	23.7	27.61	31	10,395.6	382.2	YES
0110036 F242. Port Everigades Terminal Broward 586.9 2, 285.7 21.0 25.8 33.27 39 7.9 495.3 0110036 F242. Port Everigades (South) Broward 587.1 2, 285.6 21.2 25.4 33.32 40 11.8 496.3 0110035 Transmontage Port Everigades (South) Broward 587.1 2, 285.6 21.2 25.7 33.32 40 11.8 496.3 0110035 Transmontage Port Everigades (South) Broward 587.1 2, 285.6 21.2 25.7 33.32 40 11.8 496.3 01.0 01.0 01.0 01.0 01.0 01.0 01.0 01	0110050 Mot	tiva Enterprises - South	Broward	586.8	2,884.6	20.9	24.7	32.36	40	10.0	477.1	NO
0110036 FP8L- Port Everglades Power Plant of 100035 Transmontage Port Everglades (South) Broward 587.4 2,885.3 21.5 25.4 33.28 40 59,031.9 495.6 1010037 Intermental Broward 586.4 2,885.3 20.5 26.4 33.39 38 3.5 497.9 110034 High Stein Terminaling, Little Power Plant Comment of P	0112688 Ven	ncenergy Logistics Port Everglades Term	Broward	587.0	2,885.2	21.1	25.3	32.96	40	17.7	489.2	NO
O110033 Transmontagine Port Everpladers (South)			Broward	586.9	2,885.7	21.0	25.8		39		495.3	NO
0110034 Hgb Siren Terminaling, LLC Broward 586.5 2,886.5 20.5 26.6 33.39 38 3.5 497.9 0110034 Hgb Siren Terminaling, LLC Broward 586.5 2,886.5 20.5 26.6 33.63 38 9.3 502.6 0205020 South District Wastewater Treatment Plant Mann-Dade 585.8 2,825.6 -0.1 3-43.3 34.32 180 34.2 516.3 30.2 52.6 0.1 3-43.3 34.32 180 34.2 516.3 30.2 52.6 0.1 3-43.3 34.32 180 34.2 516.3 30.2 52.6 0.1 3-43.3 34.32 180 34.2 516.3 30.2 52.6 0.1 3-43.3 34.32 180 34.2 516.3 30.2 52.6 0.1 3-43.3 34.32 180 34.2 516.3 30.2 52.6 0.1 3-43.3 34.32 180 34.2 516.3 30.2 52.6 0.1 3-43.4 34.3 34.32 180 34.2 516.3 30.2 52.6 0.1 3-43.4 34.3 34.32 180 34.2 51.6 32.6 0.1 3-43.4 34.3 34.3 51.8 51.2 51.2 51.2 51.2 51.2 51.2 51.2 51.2												YES
O11003 High Sizera Terminaling, LLC												NO
QC25022 South District Wastewalter Treatment Plant   Mam-Dade   565.8   2,825.6   -0.1   -34.3   34.32   180   34.2   516.3   34.2   516.3   34.2   34.32												NO
0255053 Mismil Dade Solid Waste Mgmt / South Dade LF Miam-Dade 565.5												NO
0250553 Homestead Air Reserve Base   Miam-Dade   599,9   2,870,1   -5,0   -39,8   40,25   189   2,7   635,0												NO
01112152 Gold Casst Cernatory   Broward   584,7   2,897,8   18,8   37,9   42,29   26   10,2   675,8   01110191 Hylly Cross Hospital   Broward   587,1   2,896,5   21,2   36,6   42,31   30   10,9   676,2   0250013 Gordon W, Ivey Power Plant   Mlami-Dade   552,8   2,817,5   13,2   42,4   44,37   197   435,7   717,5   0110003 W R Grace & Co   Broward   585,7   2,902,8   19,8   42,9   47,27   25   1,2   775,4   0110003 W R Grace & Co   Broward   583,5   2,905,0   17,6   45,1   48,42   21   88,3   798,4   0110303 Borsal American   Broward   583,5   2,905,0   17,5   45,1   48,42   21   88,3   798,4   0110303 Borsal American   Broward   583,5   2,905,0   17,5   45,1   48,42   21   88,3   798,4   0110303 Borsal American   Broward   583,5   2,905,0   17,5   45,1   48,42   21   88,3   798,4   0110003 Borsal American   Broward   583,5   2,905,0   17,5   45,1   48,42   21   88,3   798,4   0110005 Power Deerfield Plant   Broward   583,9   2,907,6   18,9   44,7   49,09   24   22   3   811,9   0110005 Power Deerfield Plant   Broward   583,9   2,907,6   18,9   44,7   49,09   24   22   3   81,9   4   0110005 Power Deerfield Plant   Broward   583,9   2,907,6   18,4   48,1   51,50   21   5,0   880,0   0110005 Power Deerfield Plant   Broward   583,8   2,908,1   17,9   49,2   52,38   20   10,8   877,6   0110005 Power Deerfield Plant   Broward   583,8   2,909,1   17,9   49,2   52,38   20   10,8   877,6   0990054 SFWMD - Pump Station S-7   Palm Beach   563,5   2,912,8   20,1   52,9   56,56   339   235,5   961,3   0990055 Borsa Raton Resort And Club   Palm Beach   592,0   2,913,7   28,1   50,8   6,6   29,9   337   246,5   1,04,2   0990055 Borsa Raton Community Hospital   Palm Beach   592,0   2,912,7   2,8   50,8   6,6   2,9   337   246,5   1,04,2   1,04,2   0990055 Stwind / Pump Station S-8 & G-Q4   Broward   592,0   2,913,7   28,1   50,8   6,6   6,7   3,3   24,4   4,4   6,6   1,31,2   0990055 Stwind / Pump Station S-8 & G-Q4   Broward   592,0   2,913,7   28,1   50,8   6,6   6,7   7,0   7,8   1,04,2   1,04,2   1,04,2   1,04,2   1,04,2												NO
0111019 Holy Cross Hospital Broward 587.1 2,896.5 21.2 36.6 42.31 30 10.9 676.2 (20013 Grofton W. Ivey Power Plant Miami-Dade 552.8 2,817.5 1.32 4.24 44.37 197 435.7 717.5 (250003 Turkey Point Power Plant Miami-Dade 552.8 2,817.5 1.32 4.24 44.37 197 18,967.2 763.3 77.7 (250003 Turkey Point Power Plant Miami-Dade 552.8 2,813.2 0.9 46.7 46.67 179 18,967.2 763.3 77.7 (250003 Turkey Point Power Plant Miami-Dade 562.8 2,813.2 0.9 46.7 46.67 179 18,967.2 763.3 77.7 (250003 Turkey Point Power Plant Miami-Dade 585.5 2,905.0 17.6 45.1 48.42 21 88.3 786.4 110038 Broward 586.5 2,904.6 45.1 48.42 21 88.3 786.4 110038 Broward 586.2 2,904.6 45.1 48.42 21 88.3 786.4 110038 Broward 586.2 2,904.6 45.1 48.42 21 88.3 786.4 1110038 Broward 586.2 2,904.6 18.0 47.7 50.9 21 13.3 844.2 11120 Wheelstrater North Broward Broward 583.9 2,907.6 18.9 47.1 50.71 22 13.3 844.2 11120 Wheelstrater North Broward Broward 583.9 2,907.6 18.0 47.7 50.90 21 13.39 2.2 84.7 1 112094 Central Exposel Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 11003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 46.1 51.12 27 74.6 852.3 1 1003 110045 Broward 583.8 2,903.0 17.7 4 10045 Broward 583.0 10045 Broward 583.8 2,903.0 17.7 4 10045 Broward 583.0 1 10045 Broward 583.8 2,903.0 17.7 4 10045 Broward 583.0 1 10045 Broward												NO NO
0250013 Gridon W, Ivey Power Plant   Miami-Dade   552.8   2,817.5   -13.2   42.4   44.37   197   435.7   717.5												NO NO
0250003 Turkey Point Power Plant												NO
0110033 W R Grace & Co 0112375 Revard CountyNorth Regional Wwf 0112375 Revard CountyNorth Regional Wwf 0112702 Netword CountyNorth Regional Wwf 0112702 Netword CountyNorth Regional Wwf 0112702 Netword S82.5 2,905.6 2.3 44.7 49.09 24 22.1 811.9 0112702 Netword Society Primpano Beach 0112702 Netword S82.5 2,905.6 18.9 47.1 50.71 22 1.3 844.2 0112102 Wheelabrator North Broward 0112904 Central Disposal 01229 Central Disposal 02229 C												YES
01120357 Broward County/North Regional Wwf Broward 583.5 2,905.0 17.6 45.1 48.42 21 88.3 788.4 0110038 Borsal American Broward 588.2 2,904.6 20.3 44.7 49.09 24 22.1 81.19 0112702 Neptune Society Pompano Beach Broward 581.8 2,907.0 18.9 47.1 50.71 22 1.3 844.2 0112102 Wheelshards North Broward Broward 583.9 2,907.6 18.0 47.7 50.98 21 1.399.2 849.7 Y 0112034 Central Disposal Broward 583.2 2,908.0 17.3 48.1 51.12 20 74.8 852.3 0110005 Pavex Described Plant Broward 583.2 2,908.0 17.3 48.1 51.12 20 74.8 852.3 0110005 Pavex Described Plant Broward 583.8 2,909.1 17.9 49.2 52.36 20 10.8 877.6 0110005 Pavex Described Plant Broward 583.8 2,909.1 17.9 49.2 52.38 20 10.8 877.6 0110005 Pavex Described Plant Broward 583.8 2,909.1 17.9 49.2 52.38 20 10.8 877.6 0110005 Pavex Described Plant Broward 583.8 2,909.1 17.9 49.2 52.38 20 10.8 877.6 0110005 Pavex Described Plant Broward 583.8 2,909.1 17.9 49.2 52.38 20 10.8 877.6 0110005 Pavex Described Plant Broward 583.8 2,912.8 20.1 52.9 56.56 339 235.5 961.3 0210031 Raccoon Point Collier 509.6 2,873.2 563.3 13.3 57.85 283 543.7 967.0 0110005 Pavex Described Plant Broward 583.8 2,912.8 20.1 52.9 56.56 339 235.5 961.3 0210031 Raccoon Point Collier 509.6 2,873.2 563.3 13.3 57.85 283 543.7 967.0 011005 Pavex Described Plant Broward 583.8 2,912.8 20.1 52.9 56.56 339 235.5 961.3 020005 Pavex Described Plant Broward 582.3 2,912.8 20.1 52.9 56.56 339 235.5 961.3 020005 Pavex Described Plant Broward 582.3 2,912.8 20.1 52.9 56.56 339 235.5 961.3 020005 Pavex Described Plant Broward 582.3 2,912.8 20.1 52.9 56.56 339 235.5 961.3 020005 Pavex Described Plant Broward 582.3 2,912.8 20.1 52.9 56.56 339 235.5 961.3 020005 Pavex Described Plant Broward 582.3 2,912.8 20.1 52.8 59.8 59.8 59.8 59.8 59.8 59.8 59.8 59			_									NO
0110038 Bonsal American Broward 588.2 2,904.6 20.3 44.7 49.09 24 22.1 811.9 0112702 Wheelabrator North Broward 584.8 2,907.0 18.9 47.1 50.71 22 1.3 844.2 0112102 Wheelabrator North Broward Broward 583.9 2,907.6 18.0 47.7 50.98 21 1,399.2 849.7 Y. 0112094 Central Disposal Broward 583.2 2,908.0 17.3 48.1 51.12 20 74.8 852.3 0110005 Pavex Deerfield Plant Broward 584.3 2,908.0 17.3 48.1 51.50 21 50 860.0 0110045 Hardrives / Deerfield Plant Broward 584.3 2,908.0 18.4 48.1 51.50 21 50 860.0 0110045 Hardrives / Deerfield Plant Broward 584.3 2,908.0 18.4 48.1 51.50 21 50 860.0 01064 Hardrives / Deerfield Plant Broward 584.3 2,908.0 18.4 48.1 51.50 21 50 860.0 01064 Hardrives / Deerfield Plant Broward 584.3 2,908.0 18.4 48.1 51.50 21 50 860.0 01064 Hardrives / Deerfield Plant Broward 584.3 2,908.0 18.4 48.1 51.50 21 50 860.0 0108 877.6 0250587 Asphalt Group, Inc. Miami-Dade 563.5 2,806.9 -2.4 -53.0 53.05 183 19.4 891.1 02000 18.0												NO NO
0112102 Melabration Vorth Broward  Brow												NO
0112/20 Wheelabrator North Broward												NO
0112094 Central Disposal 0110005 Pavex Deerfield Plant 070060 Broward 0710005 Pavex Deerfield Plant 0710006 Pavex Deerfield Plant 0710007 Pavex Deerfiel Plant 0710007 Pavex Deerfield Plant 0710007 Pavex Deerfield Pla												YES
0110005 Pavex Deerfield Plant Broward 584.3 2,908.0 18.4 48.1 51.50 21 5.0 860.0 1010045 Hardrives / Deerfield Plant Broward 583.8 2,909.1 17.9 49.2 52.38 20 10.8 877.6 0250587 Asphalt Group, Inc. Mami-Dade 563.5 2,806.9 2.4 53.0 53.05 183 19.4 891.1 0990354 SFWMD - Pump Station S-7 Palm Beach 545.8 2,912.8 -20.1 52.9 56.56 339 235.5 961.3 0210031 Raccoon Point Collier 509.6 2,873.2 -563 13.3 57.85 283 543.7 987.0 1990015 Boca Ration Resort And Club Palm Beach 592.0 2,913.7 26.1 53.8 59.84 26 12.4 1,026.7 0990119 Boca Ration Community Hospital Palm Beach 592.0 2,913.7 26.1 53.8 59.84 26 12.4 1,026.7 0990119 Boca Ration Community Hospital Palm Beach 592.0 2,913.7 26.1 53.8 59.84 26 12.4 1,026.7 0990119 Boca Ration Community Hospital Palm Beach 592.0 2,913.7 26.1 53.8 59.84 26 12.4 1,026.7 0990516 SFWMD - Pump Station G-370 Palm Beach 540.5 2,912.0 -13.3 62.1 63.50 348 60.7 1,100.0 0990514 SFWMD - Pump Station S-8 & G-404 Broward 522.3 2,912.2 -43.6 52.3 68.09 320 77.12 1,191.8 0990350 SFWMD / Pump Station S-6 Palm Beach 596.2 2,927.8 30.3 67.9 74.36 24 494.6 1,317.2 0990350 SFWMD / Pump Station G-372 Palm Beach 592.6 2,931.9 26.7 72.0 76.81 20 34.2 1,366.3 0990615 SFWMD - Pump Station G-372 Palm Beach 592.6 2,931.9 26.7 72.0 76.81 20 34.2 1,366.3 0990615 SFWMD - Pump Station G-372 Palm Beach 592.4 2,940.5 1.1.7 80.5 81.40 352 499.0 1,457.9 10990615 SFWMD - Pump Station S-6 Palm Beach 554.2 2,940.5 1.1.7 80.5 81.40 352 499.0 1,457.9 10990615 SFWMD - Pump Station S-362 Palm Beach 554.2 2,940.5 1.1.7 80.5 81.40 352 499.0 1,457.9 10990054 LW. Utilities / Tom G. Smith Per Plant Palm Beach 552.4 2,940.5 1.1.7 80.5 81.40 352 499.0 1,457.9 10990045 LW. Utilities / Tom G. Smith Per Plant Palm Beach 552.4 2,940.5 1.1.7 80.5 81.40 352 499.0 1,457.9 10990045 LW. Utilities / Tom G. Smith Per Plant Palm Beach 562.2 2,940.5 1.1.7 80.5 81.40 352 499.0 1,457.9 10990045 LW. Utilities / Tom G. Smith Per Plant Palm Beach 562.9 2,940.5 1.1.7 80.5 81.40 352 499.0 1,457.9 10990045 LW. Utilities / Tom G. Smith Per Plant Palm Beach 562.												NO
0110045 Hardrives / Deerfield Plant 025087 Asphalt Group, Inc. Milimir-Dade 583.5 2, 806.9 2.4 53.0 53.05 183 19.4 891.1 0990354 SFWMD - Pump Station S-7 Palm Beach 545.8 2,912.8 -20.1 52.9 56.56 339 235.5 961.3 0210031 Raccoon Point  0990015 Boca Ration Resort And Club Palm Beach 592.0 2,913.7 26.1 53.8 59.84 26 12.4 1,026.7 0990015 Boca Ration Resort And Club Palm Beach 592.0 2,913.7 26.1 53.8 59.84 26 12.4 1,026.7 0990015 Boca Ration Community Hospital Palm Beach 592.0 2,915.7 23.6 55.8 60.56 23 12.3 1,041.2 0990015 Boca Ration Community Hospital Palm Beach 592.0 2,915.7 23.6 55.8 60.56 23 12.3 1,041.2 0990015 Boca Ration Station G-335 Palm Beach 540.5 2,915.7 23.6 55.8 60.56 23 12.3 1,041.2 0990015 SFWMD - Pump Station G-370 Palm Beach 540.5 2,919.5 -25.4 59.6 64.79 337 248.5 1,125.8 1 0110351 SFWMD Pump Station S-8 & G-404 Broward 522.3 2,912.2 43.5 52.3 68.09 320 771.2 1,191.8 1 0990055 SFWMD Pump Station S-8 & G-404 Broward 522.3 2,912.2 43.5 52.3 68.09 320 771.2 1,191.8 1 0990055 SFWMD Pump Station G-372 Palm Beach 595.2 2,927.8 30.3 67.9 74.36 24 494.6 1,317.2 0 0990055 Bethesda Memorial Hospital Palm Beach 595.2 2,997.8 30.3 67.9 74.36 24 494.6 1,317.2 0 0990055 SFWMD - Pump Station G-372 Palm Beach 592.6 2,931.9 26.7 72.0 76.81 20 34.2 1,366.3 1 0990055 SFWMD - Pump Station G-372 Palm Beach 562.2 2,940.5 -11.7 80.5 81.40 352 488.0 1,457.9 1 0990051 SFWMD - Pump Station G-310 Palm Beach 562.2 2,945.0 1.3 85.1 85.09 1 249.2 1,531.8 1 0990015 All STWMD - Pump Station G-362 Palm Beach 563.0 2,945.4 -12.9 85.5 86.46 351 1,110.6 1,559.1 1 0990015 Community Asphalt Wip Plant Palm Beach 562.8 2,952.0 3.1 92.1 92.1 358 29.4 1,675.5 1 09900310 Community Asphalt Wip Plant Palm Beach 562.8 2,952.0 3.1 92.1 92.1 358 29.4 1,675.5 1 09900310 Community Asphalt Wip Plant Palm Beach 562.8 2,952.0 3.1 92.1 92.1 358 29.4 1,679.5 1 09900310 Community Asphalt Wip Plant Palm Beach 562.8 2,952.0 3.1 92.1 92.1 358 29.4 1,679.5 1 09900310 Community Asphalt Wip Plant Palm Beach 562.8 2,952.0 3.1 92.1 92.1 350.0 92.4 1,679.3 1											860.0	NO
0250587 A Sphalt Group, Inc.         Miami-Dade         563.5         2,806.9         2,4         -53.0         53.05         183         19,4         891.1           0990354 SFVMMD - Pump Station S-7         Palm Beach         545.8         2,912.8         -20.1         52.9         56.56         339         235.5         987.0           eyond Screening Area out to 100 km <sup>4</sup> 0990015 Boca Raton Resort And Club         Palm Beach         592.0         2,913.7         26.1         53.8         59.84         26         12.4         1,026.7           0990119 Boca Raton Community Hospital         Palm Beach         592.0         2,913.7         26.1         53.8         59.84         26         12.4         1,026.7           0990119 Boca Raton Community Hospital         Palm Beach         592.6         2,922.0         -13.3         62.1         63.50         348         60.7         1,100.0           0990515 SFVMD Pump Station G-370         Palm Beach         592.6         2,922.0         -13.3         62.1         63.50         348         60.7         1,100.0           0990350 SFVMD Pump Station S-8 & G-404         Broward         522.3         2,912.2         436         52.3         68.09         320         771.2         1,191.8 <td></td> <td></td> <td></td> <td></td> <td></td> <td>17.9</td> <td></td> <td></td> <td></td> <td>10.8</td> <td></td> <td>NO</td>						17.9				10.8		NO
990015 Boca Raton Resort And Club Palm Beach 592.0 2,913.7 26.1 53.8 59.84 26 12.4 1,026.7 9901015 Boca Raton Resort And Club Palm Beach 592.0 2,913.7 26.1 53.8 59.84 26 12.4 1,026.7 990119 Boca Raton Community Hospital Palm Beach 595.2 2,915.7 23.6 55.8 60.56 23 12.3 1,041.2 9900550 SFWMD - Pump Station G-335 Palm Beach 552.6 2,922.0 -13.3 62.1 63.50 348 60.7 1,100.0 990614 SFWMD - Pump Station G-370 Palm Beach 540.5 2,919.5 -25.4 59.6 64.79 337 248.5 1,125.8 9110351 SFWMD Pump Station S-8 G-404 Broward 522.3 2,912.2 43.6 52.3 68.09 300 771.2 1,191.8 9990350 Shmdr Pump Station S-8 G-404 Broward 522.3 2,912.2 43.6 52.3 68.09 300 771.2 1,191.8 9990355 Bethesda Memorial Hospital Palm Beach 596.2 2,927.8 30.3 67.9 74.36 24 494.6 1,317.2 9990356 SFWMD - Pump Station G-372 Palm Beach 596.2 2,931.9 26.7 72.0 76.81 20 34.2 1,366.3 9990515 SFWMD - Pump Station G-372 Palm Beach 551.2 2,945.5 1.17 80.5 81.40 352 498.0 1,457.9 9990515 SFWMD - Pump Station S-362 Palm Beach 551.2 2,945.5 1.17 80.5 81.40 352 498.0 1,457.9 1 9990051 SFWMD - Pump Station G-372 Palm Beach 553.0 2,945.4 1.10 80.5 81.40 352 498.0 1,457.9 1 9990051 SFWMD - Pump Station S-362 Palm Beach 553.0 2,945.4 1.29 85.5 86.46 351 1,110.6 1,559.1 9990051 Cheelanta Sugar Mill Palm Beach 553.0 2,945.4 1.29 85.5 86.46 351 1,110.6 1,559.1 9990052 SFWMD - Pump Station S-319 Palm Beach 562.4 2,940.1 41.0 80.2 90.07 333 84.4 1,631.4 1,695.2 1,6900052 SFWMD - Pump Station S-319 Palm Beach 562.6 2,951.3 3.3 91.4 91.46 358 249.4 1,655.5 1,9900057 SFWMD - Pump Station S-319 Palm Beach 562.6 2,951.3 3.3 91.4 91.4 91.46 358 249.4 1,659.2 1,9900057 SFWMD - Pump Station S-319 Palm Beach 562.6 2,951.3 3.3 91.4 91.4 91.46 358 249.4 1,659.2 1,9900057 Ranger Construction (Royal Palm Beach 562.6 2,951.3 3.3 91.4 91.4 91.46 358 249.4 1,659.2 1,9900057 Ranger Construction (Royal Palm Beach 562.6 2,951.3 3.3 91.4 91.4 91.46 358 249.4 1,659.2 1,9900057 Ranger Construction (Royal Palm Beach 562.6 2,951.3 3.3 91.4 91.4 91.4 91.8 92.86 9 24.4 1,672.5 1,9900057 Ranger Construction (Roya											891.1	NO
### Palm Beach   592.0   2.913.7   26.1   53.8   59.84   26   12.4   1.026.7   ### O990015 Boca Raton Community Hospital   Palm Beach   592.0   2.913.7   26.1   53.8   59.84   26   12.4   1.026.7   ### O990019 Boca Raton Community Hospital   Palm Beach   589.5   2.915.7   23.6   55.8   60.56   23   12.3   1.041.2   ### O990014 SFWMD - Pump Station G-375   Palm Beach   552.6   2.922.0   -13.3   62.1   63.50   348   60.7   1.100.0   ### O990014 SFWMD - Pump Station S-8 & G-404   Broward   522.3   2.912.2   -43.6   52.3   68.09   320   771.2   1.191.8   ### O990035 SFWMD Pump Station S-8 & G-404   Broward   522.3   2.912.2   -43.6   52.3   68.09   320   771.2   1.191.8   ### O990095 Bethesda Memorial Hospital   Palm Beach   592.6   2.931.9   26.7   72.0   76.81   20   34.2   1.366.3   ### O990095 SFWMD - Pump Station G-372   Palm Beach   592.6   2.931.9   26.7   72.0   76.81   20   34.2   1.366.3   ### O990095 SFWMD - Pump Station G-310   Palm Beach   519.3   2.923.6   -46.6   63.7   78.91   324   245.4   1.408.2   ### O990095 SFWMD - Pump Station S-362   Palm Beach   567.2   2.945.0   1.3   85.1   85.09   1   249.2   1.531.8   ### O990095 SFWMD - Pump Station S-362   Palm Beach   567.2   2.945.0   1.3   85.1   85.09   1   249.2   1.531.8   ### O990095 L.W. Utilities / Tom G. Smith Pwr Plant   Palm Beach   592.8   2.943.7   25.9   83.8   80.0   18   5.863.6   1.550.2   Y   ### O990005 Okeelanta Sugar Refinery   Palm Beach   524.9   2.940.1   41.0   80.2   90.07   333   1.498.0   1.635.3   ### O990035 SFWMD - Pump Station S-319   Palm Beach   566.3   2.951.2   0.4   91.3   91.32   0   241.4   1.656.4   ### O990036 SFWMD - Pump Station S-319   Palm Beach   562.6   2.951.3   3.3   91.4   91.6   358   249.4   1.672.5   ### O990037 Ranger Construction / (Royal Palm Beach   562.2   2.950.9   3.7   93.0   93.08   358   665.6   665.6   1.691.6   ### O990087 Ranger Construction / (Royal Palm Beach   562.2   2.950.9   3.7   93.0   93.08   358   665.6   1.691.6   ### O990087 Ranger Construction / (Royal Palm Beach   562.2												NO NO
0990015         Boca Raton Resort And Club         Palm Beach         592.0         2,913.7         26.1         53.8         59.84         26         12.4         1,026.7           0990119         Boca Raton Community Hospital         Palm Beach         589.5         2,915.7         23.6         55.8         60.56         23         12.3         1,041.2         10.00           0990505         SFWMD - Pump Station G-335         Palm Beach         540.5         2,922.0         -13.3         62.1         63.50         348         60.7         1,100.0           0990350         SFWMD - Pump Station G-370         Palm Beach         540.5         2,919.5         -25.4         59.6         64.79         337         248.5         1,125.8           0110351         SFWMD Pump Station S-8         G-404         Broward         522.3         2,912.2         -43.6         52.3         68.09         320         771.2         1,191.8           0990350 Shrmd / Pump Station S-8         G-404         Palm Beach         596.2         2,931.9         26.7         72.0         76.81         20         34.2         1,366.3           0990951 SFWMD - Pump Station G-310         Palm Beach         592.6         2,931.9         -11.7         80.5         81.40 <td></td> <td></td> <td>- Connect</td> <td>303.0</td> <td>2,013.2</td> <td>-50,5</td> <td>10.0</td> <td>37.00</td> <td>200</td> <td>5-15.7</td> <td>307.0</td> <td>NO</td>			- Connect	303.0	2,013.2	-50,5	10.0	37.00	200	5-15.7	307.0	NO
0990119         Boca Ration Community Hospital         Palm Beach         589.5         2,915.7         23.6         55.8         60.56         23         12.3         1,041.2         1,000.0         1,100.0         1,000.0         1,100.0         1,000.0         1,000.0         1,000.0         1,100.0			Palm Beach	592.0	2.913.7	26.1	53.8	59.84	26	12.4	1.026.7	NO
Septiment   Sept												NO
0990614 SFWMD - Pump Station G-370												NO
0110351 SFWMD Pump Station S-8 & G-404 Broward 522.3 2,912.2 43.6 52.3 68.09 320 771.2 1,191.8 0990350 Shwmd / Pump Station S-6 Palm Beach 592.6 2,927.8 30.3 67.9 74.36 24 494.6 1,317.2 0990350 Shwmd / Pump Station S-6 Palm Beach 592.6 2,931.9 26.7 72.0 76.81 20 34.2 1,366.3 0990615 SFWMD - Pump Station G-372 Palm Beach 592.6 2,931.9 26.7 72.0 76.81 20 34.2 1,366.3 0990615 SFWMD - Pump Station G-372 Palm Beach 592.6 2,931.9 26.7 72.0 76.81 20 34.2 1,366.3 0990615 SFWMD - Pump Station G-310 Palm Beach 554.2 2,940.5 -11.7 80.5 81.40 352 498.0 1,457.9 0990615 SFWMD - Pump Station G-310 Palm Beach 567.2 2,945.5 -11.7 80.5 81.40 352 498.0 1,457.9 0990615 SFWMD - Pump Station G-362 Palm Beach 567.2 2,945.5 -11.7 80.5 81.40 352 498.0 1,457.9 0990616 Attantic Sugar Mill Pump Station S-362 Palm Beach 553.0 2,945.4 -12.9 85.5 86.46 351 1,110.6 1,559.1 0990045 L.W. Utilities / Tom G. Smith Pwr Plant Palm Beach 592.8 2,943.7 26.9 83.8 88.01 18 5,863.6 1,590.2 990005 Okeelanta Sugar Refinery Palm Beach 524.9 2,940.1 41.0 80.2 90.07 333 84.4 1,631.4 0990332 Okeelanta Cogeneration Plant - New Hope Power Co. Palm Beach 562.4 2,940.0 41.5 80.1 90.27 333 1,498.0 1,635.3 0990620 SFWMD - Pump Station S-319 Palm Beach 562.8 2,951.2 0.4 91.3 91.32 0 241.4 1,656.4 0990349 SFWMD - Pump Station S-54 Palm Beach 562.8 2,951.3 -3.3 91.4 91.46 358 249.4 1,659.2 0990330 Community Asphalt / Wpb Plant Palm Beach 582.3 2,950.9 -3.1 92.1 92.12 358 29.4 1,672.5 0990310 Community Asphalt / Wpb Plant Palm Beach 579.9 2,951.7 14.0 91.8 92.86 9 24.8 1,687.2 0990046 FP&L / West County Energy Center Palm Beach 562.2 2,952.9 -3.7 93.0 93.08 358 665.6 1,691.6												NO
0990350 Shwmid / Pump Station S-6         Palm Beach         596.2         2,927.8         30.3         67.9         74.36         24         494.6         1,317.2           0990095 Bethesda Memorial Hospital         Palm Beach         592.6         2,931.9         26.7         72.0         76.81         20         34.2         1,366.3         1,366.3         1,367.9         1,367.9         1,467.9         1,468.2         1,408												NO
0990095 Bethesda Memorial Hospital Palm Beach 592.6 2,931.9 26.7 72.0 76.81 20 34.2 1,366.3 1   0990615 SFWMD - Pump Station G-372 Palm Beach 519.3 2,923.6 46.6 63.7 78.91 324 245.4 1,408.2 1   0990629 SFWMD - Pump Station S-362 Palm Beach 564.2 2,940.5 -11.7 80.5 81.40 352 498.0 1,457.9 1   0990621 SFWMD - Pump Station S-362 Palm Beach 567.2 2,945.0 1.3 85.1 85.09 1 249.2 1,531.8   0990016 Atlantic Sugar Mill Palm Beach 553.0 2,945.4 -12.9 85.5 86.46 351 1,110.6 1,559.1   0990045 L.W. Utilities / Tom G. Smith Pwr Plant Palm Beach 592.8 2,943.7 26.9 83.8 88.01 18 5,863.6 1,590.2 Y   0990005 Okeelanta Sugar Refinery Palm Beach 524.9 2,940.1 41.0 80.2 90.07 333 84.4 1,631.4 1   0990332 Okeelanta Cogeneration Plant - New Hope Power Co. Palm Beach 564.4 2,940.0 41.5 80.1 90.27 333 1,498.0 1,631.4 1   0990332 Okeelanta Cogeneration S-319 Palm Beach 562.6 2,951.3 -3.3 91.4 91.46 358 249.4 1,659.2 1   0990339 SFWMD - Pump Station S-5a Palm Beach 562.6 2,951.3 -3.3 91.4 91.46 358 249.4 1,659.2 1   0990330 Hubbard / East Coast Paving (Wpb) Palm Beach 562.8 2,952.0 -3.1 92.1 92.12 358 29.4 1,672.5 1   0990310 Community Asphalt / Wpb Plant Palm Beach 579.9 2,951.7 14.0 91.8 92.86 9 24.8 1,687.2 1   0990087 Ranger Construction / (Royal Palm Beach) Palm Beach 562.2 2,952.9 -3.7 93.0 93.08 358 665.6 1,691.6												NO
0990615 SFWMD - Pump Station G-372       Palm Beach       519.3       2,923.6       -46.6       63.7       78.91       324       245.4       1,408.2       1,408.2       1,9990649 SFWMD - Pump Station G-310       Palm Beach       554.2       2,940.5       -11.7       80.5       81.40       352       498.0       1,457.9       1,531.8       1,531												NO
0990549 SFWMD - Pump Station G-310         Palm Beach         554.2         2,940.5         -11.7         80.5         81.40         352         498.0         1,457.9           0990061 SFWMD - Pump Station S-362         Palm Beach         567.2         2,945.0         1.3         85.1         85.09         1         249.2         1,531.8                     0990016 Attantic Sugar Mill         Palm Beach         553.0         2,945.4         -12.9         85.5         86.46         351         1,110.6         1,559.1                     0990045 L.W. Utilities / Tom G. Smith Pwr Plant         Palm Beach         592.8         2,943.7         26.9         83.8         88.01         18         5,863.6         1,590.2         Y           0990032 Okeelanta Sugar Refinery         Palm Beach         524.9         2,940.1         -41.0         80.2         90.07         333         84.4         1,631.4                   1,631.4                             1,631.4                                       1,631.4                                       1,631.4                             1,631.4                                       1,631.4                             1,631.4                             1,631.4                     </td <td></td> <td>NO</td>												NO
0990621 SFWMD - Pump Station S-362       Palm Beach       567.2       2,945.0       1.3       85.1       85.09       1       249.2       1,531.8       1         0990016 Atfantic Sugar Mill       Palm Beach       553.0       2,945.4       -12.9       85.5       86.46       351       1,110.6       1,559.1       1         0990045 L.W. Utilities / Tom G, Smith Pwr Plant       Palm Beach       592.8       2,943.7       26.9       83.8       88.01       18       5,863.6       1,590.2       Y         0990035 Okeelanta Sugar Refinery       Palm Beach       524.9       2,940.1       -41.0       80.2       90.07       333       84.4       1,631.4       1         0990322 Okeelanta Cogeneration Plant - New Hope Power Co.       Palm Beach       524.4       2,940.0       -41.5       80.1       90.27       333       1,498.0       1,635.3         0990620 SFWMD - Pump Station S-319       Palm Beach       566.3       2,951.2       0.4       91.3       91.32       0       241.4       1,656.4       0         0990530 Hubbard / East Coast Paving (Wpb)       Palm Beach       562.6       2,951.3       -3.3       91.4       91.46       358       29.4       1,672.5       0       9909030       1,679.3       0												NO
0990016 Atlantic Sugar Mill         Palm Beach         553.0         2,945.4         -12.9         85.5         86.46         351         1,110.6         1,559.1         1,559.1           0990045 L.W. Utilities / Tom G. Smith Pwr Plant         Palm Beach         592.8         2,943.7         26.9         83.8         88.01         18         5,683.6         1,590.2         Y           0990030 Okeelanta Sugar Refinery         Palm Beach         524.9         2,940.1         41.0         80.2         90.07         333         84.4         1,631.4           0990332 Okeelanta Cogeneration Plant - New Hope Power Co.         Palm Beach         524.4         2,940.0         -41.5         80.1         90.27         333         1,498.0         1,635.3           0990620 SFWMD - Pump Station S-319         Palm Beach         562.6         2,951.2         0.4         91.3         91.32         0         241.4         1,656.4         0           0990349 SFWMD - Pump Station S-5a         Palm Beach         562.6         2,951.3         -3.3         91.4         91.46         358         249.4         1,659.2         0           0990530 Hubbard / East Coast Paving (Wpb)         Palm Beach         562.8         2,952.0         -3.1         92.1         92.12         358												NO
0990045 L.W. Utilities / Tom G. Smith Pwr Plant     Palm Beach     592.8     2,943.7     26.9     83.8     88.01     18     5,863.6     1,590.2     Y       0990005 Okeelanta Sugar Refinery     Palm Beach     524.9     2,940.1     -41.0     80.2     90.07     333     84.4     1,631.4     1       0990332 Okeelanta Cogeneration Plant - New Hope Power Co.     Palm Beach     524.4     2,940.0     -41.5     80.1     90.27     333     1,498.0     1,635.3     1       0990620 SFWMD - Pump Station S-319     Palm Beach     566.3     2,951.2     0.4     91.3     91.32     0     241.4     1,656.4     1       0990349 SFWMD - Pump Station S-5a     Palm Beach     562.6     2,951.3     -3.3     91.4     91.46     358     249.4     1,659.2     1       0990530 Hubbard / East Coast Paving (Wpb)     Palm Beach     562.8     2,952.0     -3.1     92.1     92.12     358     29.4     1,672.5     1       0990910 Community Asphalt / Wpb Plant     Palm Beach     562.3     2,950.9     16.4     91.0     92.47     10     33.9     1,679.3       099087 Ranger Construction / (Royal Palm Beach)     Palm Beach     562.2     2,951.7     14.0     91.8     92.86     9     24.8     1,687.2												NO
0990005 Okeelanta Sugar Refinery         Palm Beach         524.9         2,940.1         -41.0         80.2         90.07         333         84.4         1,631.4         1,631.4           0990032 Okeelanta Cogeneration Plant - New Hope Power Co.         Palm Beach         524.4         2,940.0         -41.5         80.1         90.27         333         1,498.0         1,635.3         1,635.3         1,630.1         1,631.4         1,												YES
0990332 Okeelanta Cogeneration Plant - New Hope Power Co.         Palm Beach         524.4         2,940.0         -41.5         80.1         90.27         333         1,498.0         1,635.3         1,635.2         1,635.2         1,635.2         1,659.2         1,635.3         1,438.0         1,635.2         1,659.2         1,659.2         1,637.2         1,637.2         1,637.2         1,637.2         1,637.2         1,637.2         1,637.2         1,637.2         1,637.2         1,637.2         1,637.2         1,637.2<	0990005 Oke	elanta Sugar Refinery										NO
0990620 SFWMD - Pump Station S-319     Palm Beach     566.3     2,951.2     0.4     91.3     91.32     0     241.4     1,656.4     1,659.2       0990349 SFWMD - Pump Station S-5a     Palm Beach     562.6     2,951.3     -3.3     91.4     91.46     358     249.4     1,659.2     1,659.2       0990530 Hubbard / East Coast Paving (Wpb)     Palm Beach     562.8     2,952.0     -3.1     92.1     92.12     358     29.4     1,679.5     1       0990310 Community Asphalt / Wpb Plant     Palm Beach     582.3     2,950.9     16.4     91.0     92.47     10     33.9     1,679.3     1       0990046 FP8L / West County Energy Center     Palm Beach     562.2     2,952.9     -3.7     93.0     93.08     358     665.6     1,691.6     1											1,635.3	NO
0990349 SFWMD - Pump Station S-5a     Palm Beach     562.6     2,951.3     -3.3     91.4     91.46     358     249.4     1,659.2     1       0990530 Hubbard / East Coast Paving (Wpb)     Palm Beach     562.8     2,952.0     -3.1     92.1     92.12     358     29.4     1,679.5     1       0990310 Community Asphalt / Wpb Plant     Palm Beach     582.3     2,950.9     16.4     91.0     92.47     10     33.9     1,679.3     1       0990646 Fability (Royal Palm Beach)     Palm Beach     579.9     2,951.7     14.0     91.8     92.86     9     24.8     1,687.2     1       0990646 Fability (West County Energy Center     Palm Beach     562.2     2,952.9     -3.7     93.0     93.08     358     665.6     1,691.6     1			Palm Beach	566.3	2,951.2	0.4	91.3	91.32				NO
0990530 Hubbard / East Coast Paving (Wpb)     Palm Beach     562.8     2,952.0     -3.1     92.1     92.12     358     29.4     1,672.5     1,672.5       0990310 Community Asphalt / Wpb Plant     Palm Beach     582.3     2,950.9     16.4     91.0     92.47     10     33.9     1,679.3     1,679.3     1,679.3       0990646 FP&L / West County Energy Center     Palm Beach     562.2     2,952.9     -3.7     93.0     93.08     358     665.6     1,691.6     1									358			NO
0990310 Community Asphalt / Wpb Plant     Palm Beach     582.3     2,950.9     16.4     91.0     92.47     10     33.9     1,679.3     1       0990087 Ranger Construction / (Royal Palm Beach)     Palm Beach     579.9     2,951.7     14.0     91.8     92.86     9     24.8     1,687.2     1       0990646 FP&L / West County Energy Center     Palm Beach     562.2     2,952.9     3.7     93.0     93.08     358     665.6     1,691.6     1												NO
0990087 Ranger Construction / (Royal Palm Beach)         Palm Beach         579.9         2,951.7         14.0         91.8         92.86         9         24.8         1,687.2         1           0990646 FP&L / West County Energy Center         Palm Beach         562.2         2,952.9         -3.7         93.0         93.08         358         665.6         1,691.6         1												NO
0990646 FP&L / West County Energy Center Palm Beach 562.2 2,952.9 -3.7 93.0 93.08 358 665.6 1,691.6 I												NO
									358			NO
1.124.0 / Description   Descri	0000010110								11			NO



093-87674 May 2011 2

### TABLE 6-5 (Revised 4/29/11) SUMMARY OF THE NO, FACILITIES CONSIDERED FOR INCLUSION IN THE AAQS AND PSD CLASS II AIR MODELING ANALYSES

		UTM Co	ordinates	F	telative to N	edley Landfill	• .	Maximum NO <sub>x</sub>	Q, (TPY) Emission	Include in
AIRS Number Facility	County	East (km)	North (km)	X (km)	Y (km)	Distance (km)	Direction (deg)	Emissions (TPY)	Short-Term Threshold <sup>b,c</sup> (Dist - SID) x 20	Modeling Analysis ?
0990026 Sugar Cane Growers Co-Op	Palm Beach	534.9	2,953.9	-31.0	94.0	98.95	342	3,470.7	1,809.0	YES

NA = Not applicable, ND = No data, SID = Significant impact distance for the project, SIA = Significant Impact Area

\* Medley Landfill East and North Coordinates (km) are:

565.9 2,859.9 km 8.5 km

<sup>b</sup> The significant impact distance for the project is estimated to be:



Based on the North Carolina Screening Threshold method, a background facility is included in the modeling analysis if the facility is beyond the modeling area and its emission rate is greater than the product of (Distance-SID) x 20.

<sup>&</sup>quot;Modeling Area" is the area in which the project is predicted to have a significant impact (8.5 km). EPA recommends that all sources within this area be modeled.

"Screening Area" is the significant impact distance for the Medley Landfill of 8.5 km, plus 50 km beyond the modeling area. EPA recommends that sources be modeled that are expected to have a significant impact in the modeling area. "Beyond Screening Area out to 100 km is the distance between the facilities and out to 100 km in which large sources are included in the modeling.

TABLE 6-11 (Revised 04/29/11) MAXIMUM PREDICTED PM $_{10}$ , PM $_{2.5}$ , AND NO $_{2}$  IMPACTS COMPARED TO THE AAQS

		Maximur	n Concentrati	on (µg/m³) ³	Receptor	Location		
Averaging Time	_		Modeled		UTM- East	UTM- North	Time Period	AAQS
and Rank		Total	Sources	Background	(m)	(m)	(YYMMDDHH)	(µg/m³
NO <sub>2</sub> Tier 1 (Tier 2 with	Conversion Fa	ctor)						
Annual, Highest <sup>b</sup>		26.7	6.0	20.7	562900	2858150	01123124	100
		27.6	6.9	20.7	563150	2858150	02123124	100
		27.3	6.6	20.7	563150	2858150	03123124	
		27.1°	6.4	20.7	563150	2857900	04123124	
		27.1	6.4	20.7	562900	2857900	05123124	
1-Hour, 98th Percentil	e of	_	236.1	_	571900	2868400	_	188
Daily Max Modeled <sup>c</sup>			255.2		571900	2868400		
•		_	251.6		571900	2868400	_	
			240.9		571900	2868400	-	
	_		238.5	-	571900	2868400	_	
5-Y	ear Average	357.4	244.5	112.9				
NO <sub>2</sub> Tier 3 with OLM								
Annual, Highest		28.2	7.5	20.7	565,754	2,860,013	01123124	100
		29.5	8.8	20.7	565,754	2,860,013	02123124	
		29.1	8.4	20.7	565,754	2,860,013	03123124	
		29.1	8.4	20.7	565,707	2,860,013	04123124	
		28.9	8.2	20.7	565,754	2,860,013	05123124	
1-Hour, 98th Percentik	e of		133.4	-	567,900	2,868,400	-	188
Daily Max Modeled <sup>c</sup>		-	133.0	-	567,900	2,868,400	_	
		_	157.3	_	567,900	2,868,400	_	
			161.0		567,900	2,868,400		
	_	-	156.5	_	` 567,900	2,868,400		
5-Y	ear Average	261.2	148.3	112.9				
PM <sub>10</sub>								
Annual, Highest		29.0	2.0	27.0	565,707	2,860,013	01123124	50
,		29.2	2.2	27.0	565,707	2,860,013	02123124	
		28.9	1.9	27.0	565,707	2,860,013	03123124	
		28.9	1.9	27.0	565,612	2,859,924	04123124	
		28.9	1.9	27.0	565,707	2,860,013	05123124	
24-Hour, H6H		75.1	10.1	65.0	565,754	2,860,013	05032224	150
PM <sub>2.5</sub>								
Annual, Highest		_	2.4		563,937	2,857,693	01123124	15
		-	2.6	-	56 <b>3</b> ,937	2,857,693	02123124	
		-	2.6		562,443	2,861,370	03123124	
		-	2.6	-	562,443	2,861,370	04123124	
		_	2.8		562,443	2,861,370	05123124	
5-Y	ear Average	10.5	2.6	7.9	,	-		
24-Hour, highest <sup>d</sup>		·	20.4		562,443	2,861,370		35
		_	19.8	-	562,443	2,861,370	-	
		-	17.8	-	562,443	2,861,370	-	
			18.7	-	562,443	2,861,370	-	
	_		22.7		562,443	2,861,370	-	
5-Y	ear Average	41.4	19.9	21.5				

Note

YYMMDDHH = Year, Month, Day, Hour Ending H6H = Highest, sixth-highest



<sup>&</sup>lt;sup>a</sup> Concentrations predicted are based on using 5 years of meteorological data from 2001 to 2005 of surface and upper air data from the National Weather Service stations at Miami International Airport and Florida International University, respectively.

<sup>&</sup>lt;sup>b</sup> A NO<sub>x</sub> to NO<sub>2</sub> conversion factor of 75% applied to annual average concentrations based on EPA's Guideline on Air Quality Models.

c 98th percentile of the annual distribution of the daily maximum 1-hour concentrations (average total (modeled and nonmodeled background).

<sup>&</sup>lt;sup>d</sup> Highest predicted 24-hour average concentrations.

### TABLE 6-12 (Revised 04/29/11) AAQS RESULTS BASED ON TEMPORAL PAIRING FOR 1-HOUR AVERAGE NO $_2$ AND 24-HOUR AVERAGE PM $_{2.5}$

	Maxim	um Concentra	tion (µg/m³) a	Receptor	Location		
Averaging Time		Modeled	Non-Modeled	UTM- East	UTM- North	Time Period	AAQS
and Rank	Total	Sources	Background	(m)	(m)	(YYMMDDHH)	(µg/m³
NO <sub>2</sub>			-				
1-Hour, 98th Percentile of	170.1	141.9	28.2	567,900	2,868,400	01031805	188
Daily Max Total <sup>b</sup>	174.1	98.9	75.2	567,900	2,868,400	02060722	
-	184.9	168.0	16.9	567,900	2,868,400	03120220	
	192.1	167.6	24.5	567,900	2,868,400	04032306	
	182.2	155.9	. 26.3	567,900	2,868,400	05012811	
Maximum 5-Year Average <sup>c</sup>	180.7						
PM <sub>2.5</sub>							
24-Hour, 98th Percentile of	28.6	20.4	8.2	562,443	2,861;370	01122624	35
Daily Max Total <sup>d</sup>	28.1	3.1	25.0	562,443	2,861,370	02070524	
-	28.8	0.4	28.4	562,443	2,861,370	03102424	
•	30.9	11.1	19.8	562,443	2,861,370	04021724	
_	26.8	17.6	9.2	562,443	2,861,370	05122024	
Maximum 5-Year Average <sup>c</sup>	28.6						

Note:

YYMMDDHH = Year, Month, Day, Hour Ending



<sup>&</sup>lt;sup>a</sup> Concentrations are based on concentrations predicted using 5 years of meteorological data from 2001 to 2005 of surface and upper air data from the National Weather Service stations at Miami International Airport and Florida International University, respectively.

<sup>&</sup>lt;sup>b</sup> 98th percentile of the annual distribution of daily maximum 1-hour total (modeled + non-modeled background) concentrations.

<sup>&</sup>lt;sup>c</sup> Maximum 5-year average among all receptors.

<sup>&</sup>lt;sup>d</sup> 98th percentile of annual distribution of daily 24-hour average total (modeled + non-modeled background) concentrations.

### TABLE 7-5 (Revised 4/29/11) MAXIMUM 24-HOUR VISIBILITY IMPAIRMENT PREDICTED FOR THE PROPOSED PROJECT AT THE EVERGLADES NP PSD CLASS I AREA

	Vişibili	ty Impairme	ent (%) <sup>a</sup>	Visibility Impairment
Background Extinction Calculations	2001	2002	2003	Criteria (%)
Method 2 with RHMAX = 95 Percent	0.67	0.73	0.85	5.0

<sup>&</sup>lt;sup>a</sup> Concentrations are highest predicted using CALPUFF V5.8 with CALMET V5.8 4-km Domains, 2001 to 2003. Background extinctions calculated using FLAG Document (December 2000) and stated method.



### TABLE 7-6 (Revised 4/29/11) MAXIMUM ANNUAL NITROGEN DEPOSITION PREDICTED FOR THE PROPOSED PROJECT AT THE PSD CLASS I AREAS

•	Total Depositi	on (Wet & Dry)		Deposition Analysis Threshold <sup>b</sup>
Species	(g/m²/s)	(kg/ha/yr) <sup>a</sup>	Year	(kg/ha/yr)
Nitrogen (N) Deposition	9.872E-13 1.278E-12	0.0003 0.0004	2001 2002	0.01 0.01
	1.19E-12	0.0004	2003	0.01

<sup>&</sup>lt;sup>a</sup> Conversion factor is used to convert g/m²/s to kg/hectare (ha)/yr with the following units:



Deposition analysis thresholds (DAT) for nitrogen deposition provided by the U.S. Fish and Wildlife Service, January 2002.

A DAT is the additional amount of N or S deposition within a Class I area, below which estimated impacts from a proposed new or modified source are considered insignificant.

### TABLE D-1 (Revised 4/29/11) SUMMARY OF NO, SOURCES INCLUDED IN THE AAQS AND PSD CLASS II MODELING ANALYSES

				UTMI	Location			Stack Pa	arameters				NO, Emissio	n Rate					
ID 5	acility Name		Modeling	X	Υ	Height		Diameter	Tempe	erature	Velocity	Stack Parameter	1-Hou		NO <sub>2</sub> /NO <sub>X</sub>	Emissions Data		Modeled In	
10 E	mission Unit Description	EU ID	ID Name	(m)	(m)	ft	m ft	m.	°F	K	ft/s m/s	Data Source	(lb/hr)	(g/sec)	Ratio	Source	Hourty Data?	AAQS	PSD C
	on Engine Service Inc. et Engine Test Cell	002	AVJET	566,640	2,859,630	30.0	9.14 * 5.0	0 1.52	* 800.0	699.8	50.0 15.24 ª	FDEP Data 5/10/10, See Footnote	10.7	1.35	1.0	FDEP Data 5/10/10 - 47 TPY, 8,760 hr/yr per 0251196-002-AC	No	Yes	Ye
	Foundry Manufacturing Corp. Stray Iron Foundry Cupola	003		567,300	2.859.800	50.0 1	5.24 2.5	5 0.76	480 N	522 0	143.6 43.8	FDEP Data 5/10/10, 0250022-011-AV	2,54	0.32		FDEP Data 5/10/10 - Potential hourly rate	Yes	Yes	Ye
<u> M</u>	lolding Line Loop 4	004		567,300	2,859,800	-			· <u>-</u>	-		No data, Grouped with EU 003	0.015	0.0018		FDEP Data 5/10/10 - AOR 2009 annual rate, and 8,760 hr/yr	No	Yes	Ye
<u>υ</u>	l.S. Foundry Emission Units		USFNDRY	567,300	2,859,800	50.0 1	5.24 2.	5 0.76	480.0	522.0	143.6 43.77		2.55	0.32	1.0			Yes	Ye
50640 AAR L	Landing Gear Services																		
N	latural Gas Ovens	005	AAROVEN	564,560	2,860,610	35.0 1	0.67 2.0	0 0.61	500.0	533.2	50.0 15.24	FDEP Data 5/10/10, See Footnote	0.50	0.064		0250640-021-AV, 5.15 MMBtu/hr (1.6 MMBtu/hr for each of 3 NG ovens, plu 0.35 MMBtu/hr for one NG oven). AP-42 Table 1.4-1	⊔\$ Yes	Yes	Y
	da Atuminum of Florida																		
	leat Treat Oven	002 004		567,400 567,400	2,859,400 2,859,400	5.0	1.52 1.0	0.30	500.0	533.2	50.0 15.24 °	FDEP Data 5/10/10, See Footnote	0.35 0.26	0.044		0250488-008-AV - 3.6 MMBtu/hr, AP-42 Table 1.4-1 0250488-008-AV - 2.7 + 0.0012 MMBtu/hr, AP-42 Table 1.4-1	Yes Yes	Yes Yes	Y
	wo Fire Tubes leat Treat Oven and Two Fire Tubes	004	BAFHTOFT	567,400		5.0	1.52 1.0	0 0.30	500.0	533.15	50.0 15.24	No data, grouped with EU 002 parameters	0.62	0.033	1.0	0250400-000-AV - 2.7 + 0.00 12 mimistanti, Ar-42 Table 1.4-1		Yes	,
_							_					•				· · ·			
	aint Bake Oven aint Hook Cleaning Oven	003 005	BAFPBO BAFPHO	567,400 567,400	2,859,400 2,859,400		3.66 1.0 0.67 3.0				50.0 15.24 ° 50.0 15.24 °	FDEP Data 5/10/10, See Footnote FDEP Data 5/10/10, See Footnote	0.59 0.70	0.074 0.088	1.0 1.0	0250488-008-AV - 3.0 MMBtu/hr each (2), AP-42 Table 1.4-1 0250488-008-AV - 3.58 MMBtu/hr each (2), AP-42 Table 1.4-1	Yes Yes	Yes Yes	,
1194 Bagel																			
	aking of bread,bagels and rolls	001	BAGEL	564,450	2,861,650	45.0 1	3.72 2.0	0 0.61	500.0	533.2 °	50.0 15.24 °	FDEP Data 5/10/10, See Footnote	0.90	0.11	1.0	0251194-002-AO - 9.14 MMBtu/hr total EU 001, AP-42 Table 1.4-1	Yes	Yes	
	trial Metal Spraying	001	IMCOCOTH	568,400	2,859,200	20.0	8 10 21	0 005	77	209.2	50.0 15.24 °	EDED Data 5/10/10 See Engine	0.49	0.062	1,0	FDEP Data 5/10/10 - Potential	Yes	Yes	,
	pray Booths	001	IMSBOOTH	JO0,400	2,009,200	20.0	5.10 2.0	8 0.85	"	298.2	UU.U 13.24	FDEP Data 5/10/10, See Footnote	0.43	0.002	1.0	i per pala y forto - rotefulat	163	169	
	Dade RRF/Montenay DF Spreader Stoker Unit No. 1	001		563.830	2,857,620	250.0 7	6.20 8.4	4 2.57	300.0	422.0	67.6 20.61	0250348-009-AV	143.7	18.11		Golder (0037532Y/F2) App. for 0250348-004-AV	Yes	Yes	
	DF Spreader Stoker Unit No. 2	002		563,830	2,857,620		6.20 8.4				67.6 20.61	0250348-009-AV	143.7	18,11		Golder (0037532Y/F2) App. for 0250348-004-AV	Yes	Yes	
	DF Spreader Stoker Unit No. 3	003		563,830	2,857,620		6.20 8.4				67.6 20.61	0250348-009-AV	143.7	18.11		Golder (0037532Y/F2) App. for 0250348-004-AV	Yes	Yes	
	DF Spreader Stoker Unit No. 4	004		563,830	2,857,620			4 2.57			67.6 20.61	0250348-009-AV	143.7	18.11		Golder (0037532Y/F2) App. for 0250348-004-AV	Yes ·	Yes	
<u>R</u>	DF Spreader Stoker Unit Nos. 1-4		RRFU14	563,830	2,857,620	250.0 7	6.20 8.4	4 2.57	300.0	422.0	67.6 20.61	· ·	574.8	72.4	1.0			Yes ·	
	America-Pennsuco Cement law Mill & Pyroprocessing System	028	TARAWML	562,270	2,861,700	410.0 12	24.97 14.	.0 4.27	200.0	366.5	55.8 17.00	Golder (0537642) - 515,000 acfm	720.00	90.72	1,0	0250020-021-AV, Emission limit of 720 lb/hr	Yes	Yes	
	ral Asphalt - Plant No. 1 sphalt Batch Plant	00 t	GENASPH	568.800	2,855,400	25	7.62 3.0	8 116	164.0	346.5	101.0 30.78	FDEP Data 5/10/10	22.83	2.88	1.0	0250005-007-AO - facility wide limit of 100 TPY and 8,760 hr/yr	No	Yes	
	spinan Baich Plans sh/Preston Water Treatment Plant	W1	GENASPH	300,000	2,655,400	25	1.02 3.0	0 1,10	104,0	340.5	101.0 30.76	PDEP Data 37 for 10	22.03	2.00	1.0	1230003-007-NO - facility wide limit of 100 TPT and 0,700 m/y	110	163	
نا	ime Recatc. Kitn	001	HPWTPLM	570,700	2,856,760	75.0 2	2.86 3.0	0 0.91	105.0	313.7	2.4 0.73	FDEP Data 5/10/10	2.50	0.32	1.0	0250281-010-AV, limit of 0.5 lb/MMBtu and 50 MMBtu/hr	Yes	Yes	
186 Aeroth O	nrust Corp ine (1) Test Cell - Jet Engines	001	AERJETST	569,200	2,853,120	40.0 1	2.19 17.	.5 5.33	500.0	533.2	50.0 15.24 *	FDEP Data 5/10/10, See Footnote	22.83	2.88	1.0	0251186-001-AO - facility wide limit of 100 TPY, and 8,760 lb/yr	No	Yes	
	ral Asphalt WDHMA counter Flow Drum Mix Asphalt Plant	001	GNASWDH	568.800	2,855,400	30 9	9.14 4.6	6 1.40	2 <b>7</b> 7 N	409.3	62.0 18.90	FDEP Data 5/10/10	22.83	2.88	1.0	0250624-007-AO - facility wide limit of 100 TPY, and 8,760 lb/yr	No	Yes	
	x - Miami Cement Plant			,	_,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,											,			
S	tone Dryer & Soil Thermal Treatment Fac.	014	CEMSTONE	558,200	2,851,300		4.38 4.5	5 1.37	800.0		38.0 11.58	0250014-028-AV	0.079	0.010	1.0	FDEP Data 5/10/10 - 2008 AOR annual rate and 8,760 hr/yr	No	Yes	
In	Line Kiln/Raw Mitt/Clinker Cooler	018	CEMKLN	557,490	2,852,050	359.0 10	09,42 8.0	0 2.44	464.0	513.2	160.9 49.04	FDEP Data 5/10/10	648.00	81.65	1.0	0250014-028-AV, hourly limit	Yes	Yes	
	Dade Solid Wste Mgmt/No Dade L1																		
	nclosed Flare Model GF-1000 8 Detroit Diesel Dual Fuel Generator Engines	002 003	NDLFLR NDLGEN	570,670 570,670	2,872,140 2,872,140		9.14 6.9 0.06 1.3				35.6 10.85 156.0 47.55	FDEP Data 5/10/10 FDEP Data 5/10/10	1.67 141.00	0.21 17.77	1.0 1.0	FDEP Data 5/10/10 - Potential hourly rate FDEP Data 5/10/10 - Potential hourly	Yes Yes	Yes Yes	
	nder ORR Water Treatment Plant																		
	ngine No. 5 ngine No. 6	005 006		565,920 565,920	2,843,330 2,843,330		 3.53 1.2					FDEP Data 5/10/10 FDEP Data 5/10/10	15.52 -65.23	1.96 8.22		FDEP Data 5/10/10 - 2008 AOR annual rate and 8,760 hr/yr FDEP Data 5/10/10 - Potential hourly rate	No Yes	Yes Yes	
	otary Lime Recalcining Kiln	007		565,920	2,843,330	20.0	- 3.0				166.0 50.60	FDEP Data 5/10/10	18.80	2.37		0250314-015-AV, hourly limit	Yes	Yes	
	ngines and Rotary Kiln <sup>c</sup>		AORREGRK	565,920	2,843,330	28.0 8	3.53 3.0	0 0.91	170.0	349.8	166.0 50.60		99.55	12.54	1.0	<u> </u>		Yes	
01 FP&L	-Cutler Power Plant																		
FI	FFSG - Unit No. 5	003				150.0 4		0 4.27		413.7	50.7 15.44	0250001-003-AV and Application - 467,837 actm	188.0 324.0	23.69		0250001-003-AV - trourly rate - Built in 1954	Yes	Yes	
<u> </u>	FFSG - Unit No. 6 · FFSG - Unit Nos. 5 & 6	004	FPLCUTLR		2,834,975 2,834,975	150.0 4 150.0 4	5.72 14. 5.72 14.	.0 4.27 .0 4.27	285.0 285.0	413.7	60.7 18.50 50.7 15.44	0250001-003-AV and Application - 560,464 acfm Gouped based on Unit 5 parameters	324.0 512.0	40.82 - 64.51	0.1	0250001-003-AV - hourly rate - Buitt in 1955	Yes	Yes Yes	
19 Wheel	labrator South Broward			_			_	_											
M	ISW Combustor & Auxiliary Burners- Unit 1	001		579,540	2,883,340		9.44 7.5				63.8 19.43	0112119-014-AV - 169,000 acfm	114.0	14:36		0112119-014-AV - hourly rate	Yes	Yes	
	ISW Combustor & Auxiliary Burners- Unit 2 ISW Combustor & Auxiliary Burners- Unit 3	002 003		579,540 579,540	2,883,340 2,883,340	195.0 5	9.44 7.5 9.44 7.5	5 2.29	300.0	422.0	63.8 19.43 63.8 19.43	0112119-014-AV - 169,000 acfm 0112119-014-AV - 169,000 acfm	114.0 114.0	14.36 14,36		0112119-014-AV - hourly rate 0112119-014-AV - hourly rate	Yes Yes	Yes Yes	
M	SW Combustor & Auxiliary Burners- Unit 3 SW Combustor & Auxiliary Burners- Unit Nos. 1-3		WHLSU13		2,883,340	195.0 5	9.44 7.		300.0	422.0			342.0	43.1	1.0			Yes	
37 Florida	a Power & Light (PFL) - Fort Lauderdale																		
C.	Ts 1-4 PSD	035-038	LAUDU45	580,200	2,883,500	150 4	5.7 18.				158.7 48.37	FDEP Data 5/10/10	1688.00	212.7	0.1	0110037-005-AV - 422 lb/hr/unit - 4 units	Yes	Yes	
	T 1-12 (0.5% fuel oil) T 13-24 (0.5% fuel oil)	003 015	LDGT1_12 LDGT1324	580,320 580,290	2,884,050 2,883,640		3.7 15. 3.7 15.				93.3 28.44 93.3 28.44	FDEP Data 5/10/10 FDEP Data 5/10/10	7572.00 7572.00	954.1 954.1	0.2 0.2	0110037-005-AV, each gas turbine limited to 631 lb/hr (12 turbines) 0110037-005-AV, each gas turbine limited to 631 lb/hr (12 turbines)	Yes Yes	Yes Yes	
		UIS	LDG1 1324	360,290	2,003,040	40 1	J./ 15.	.0 4.8	860.0	1332	3J.J 20.44	FDEF DAIS SHOTO	1312.00	334.1	0.2	C. 10007-000774, cach gas tachine initiated to our librii (12 (thibifies))	103	169	
	Port Everglades Plant		DTERMINA	587,400	2 005 200	242.0	n4		200.0	445.0	88.1 26.72	0110036-009-AV	1,656.0	208.7	0.1	0110036-009-AV, each unit limited to 828 lb/hr, 2 units	Vas	Yes	
U:	nits 1&2 at 2.5%s fuel oil nits 3&4 at 2.5%s fuel oil	_	PTEVU12 PTEVU34	587,400 587,400	2,885,300 2,885,300		04.5 14. 04.5 18.				88.1 26.72 81.8 23.88	0110036-009-AV 0110036-009-AV	1,656.0 4,240.0	534.2	0.1	0110036-009-AV, each unit limited to 2,120 lb/hr, 2 units	Yes Yes	Yes	
	T 1-12 (0.5% fuet oil)	-	PTEVGTS	587,300	2,885,600		3.4 15.	6 4.75			93.3 28.43	0110036-009-AV	7,581.6	955.3	0,2	0110036-009-AV, limit of 7,581.6 lb/hr	Yes	Yes	
03 Turkey	y Point Power Plant																		
Be	oiler- Unit 1	001		567,200	2,813,200	400.0 12	21.9 18.	.1 5.5			77.0 23.46	0250003-011-AV	2041.0	257.2		0250003-011-AV, hourly limit for fuel oil	Yes	Yes	
	oiler- Unit 2 oilers - Units 1 and 2	002	TPU12	567,200 567,200	2,813,200 2,813,200	400.0 12 400.0 12	21.9 18. 21.9 18.	.1 5.5 .1 5.5			77,0 23.46 77,0 23.46	0250003-011-AV	2041.0 4082.0	257.2 514.3	0.1 ·	0250003-011-AV, hourly limit for fuel oil	Yes	Yes Yes	
<u>=</u>			•.=	•															
	nit 5A CT with HRSG nit 5B CT with HRSG	009 01 <b>0</b>		566,590 566,590	2,813,210 2,813,210	131.0 3 131.0 3		.0 5.8 .0 5.8	202.0	367.6	59.0 17.98	FDEP Data 5/10/10 FDEP Data 5/10/10	62.1 62.1	7.8 7.8		0250003-011-AV, hourly limit 0250003-011-AV, hourly limit	Yes Yes	Yes Yes	
	nit 5C CT with HRSG	011		566,590	2,813,210	131.0 3	9,9 19.	.0 5.8	202.0		59.0 17.98	FDEP Data 5/10/10	62.1	7.8		0250003-011-AV, hourly limit	Yes	Yes	
U:		012		566,590	2,813,210	131.0 3	9.9 19.	.0 5.8	202.0	367.6	59.0 17.98	FDEP Data 5/10/10	62.1	7.8		0250003-011-AV, hourly limit	Yes	Yes	
Ui Ui Ui	nit 5D CT with HRSG	012	TOUR	500,030	2 042 040	124 00 -	0.02												
Ur Ur Ur	nit 5D CT with HRSG	012	TPU5AD.	566,590	2,813,210	131,00 3	9.93 19,0	00 5.79	. 202.00	367,59	59.00 17.98		248.4	31.3	1:0	<del></del>		Yes	
Ud Ud <u>Ud</u> 120 Wheel	nit 5 labrator North Broward		TPU5AD.	566,590	2,813,210										1:0				
Ui Ui <u>Ui</u> 120 Wheel M	nit 5	001 002	TPU5AD.	566,590 579,540 579,540	2,813,210 2,883,340 2,883,340	195.0 5	9.93 19.0 9.44 7.5 9.44 7.5	5 2.29	300.0	422.0	63.8 19.43 63.8 19.43	0112120-009-AV - 169,000 acfm 0112120-009-AV - 169,000 acfm	106.5 106.5	13.42 13.42	1:0	0112119-014-AV, hourly rate 0112119-014-AV, hourly rate	Yes Yes	Yes Yes Yes	



TABLE D-1 (Revised 4/29/11)
SUMMARY OF NO, SOURCES INCLUDED IN THE AAQS AND PSD CLASS II MODELING ANALYSES

Facility #D	Facility Name Emission Unit Description	EU ID	Modeling ID Name	UTM Location		Stack Parameters Height Diameter Temperature Velocity				Velocity	Stack Parameter	NO, Emission Rate		NO-/NOx	Emissions Data		Modeled In	
				(m)	(m) (m)	ft	<u>m</u> -	Diameter ft m	Temperature  °F K	ft/s m/s	Data Source	(lb/hr)	(g/sec)	Ratio	Source	Hourty Data?	AAQS	PSD Class
	MSW Combustor & Auxiliary Burners- Unit Nos. 1-3		WHLNU13	579,540	2,883,340	195.0	50 44	7.5 2.29	300.0 422.0	63.8 19.43		319.5	40.3				Yes	Yes
	MSW Combusion & Auxiliary Burners- Utili Nos. 1-3		WHENO 13	373,540	2,003,340	190.0	33.44	1.0 2.29	300.0 422.0	03.0 13.43		010.0	40.0	1.0				
990045 C	city of Lake Worth Utilities																	
	Diesel Generator Units 1-5	001-005	LAKWTHDG	592,800	2,943,700	16.5	5.0	1.83 0.6	667.0 625.9	121.7 37.10	0990045-005-AV Appl. (Golder 07389508) - 12,208 acfm	499.0	62.87	1.0	0990045-005-AV Appl. (Golder 07389508)	Yes	Yes	Yes
	Gas Turbine No.1	006	LAKWTHGT	592,800	2,943,700	46.0	14.0	16.0 4.9	837.0 720.4	81.5 24.85	0990045-005-AV Appl. (Golder 07389508) - 983,593 acfm	391.5	49.33	1.0	0990045-005-AV Appl. (Golder 07389508)	Yes	Yes	Yes
	Unit 3, S-3	009	LAKWTHU3	592,800	2,943,700	113.0	34.4	7.0 2,1	293.0 418.2	51.4 15.67	0990045-005-AV Appl. (Golder 07389508) - 118,719 acfm	162.6	20.49	1.0	0990045-005-AV Appl. (Golder 07389508)	Yes	Yes	Yes
	Combined Cycle Unit, S-5	011	LAKWTHU5	592,800	2,943,700	75.0	22.9	10.0 3.0	404.0 479.8	87.5 26.68	0990045-005-AV Appl. (Golder 07389508) - 412,466 acfm	285.8	36.01	1.0	0990045-005-AV Appl. (Golder 07389508)	Yes	Yes	Yes
990026 S	Sugar Cane Growers Co-Op																	
	On-crop season b																	
	Unit 1	001	SCBLR1N	534.900	2,953,300	150.0	45.72	7.0 2.13	156.0 342.0	49.6 15.12	BART for SCGCF, Golder 063-7534	159.2	20.05	1.0	From Southeast Renewable Fuels (Golder 0938-7660)	Yes	Yes	Yes
	Unit 2	002	SCBLR2N	534,900	2.953.300		45.72	7.0 2.13	156.0 342.0	51.1 15.58	BART for SCGCF, Golder 063-7534	128.6	16.20	1.0	From Southeast Renewable Fuels (Golder 0938-7660)	Yes	Yes	Yes
	Unit 3	003	SCBLR3N	534.900	2.953.300	180.0	54.86	5.3 1.62	156.0 342.0	40.3 12.28	HBCA Appl for SCGCF, Golder 063-7534	102.9	12.97	1.0	From Southeast Renewable Fuels (Golder 0938-7660)	Yes	Yes	Yes
	Unit 4	004	SCBLR4N	534.900	2,953,300	180.0	54.86	8.9 2.72	162.0 345.4	54.1 16.49	BART for SCGCF, Golder 063-7534	257.0	32.38	1.0	From Southeast Renewable Fuels (Golder 0938-7660)	Yes	Yes	Yes
	Unit 5	005	SCBLR5N	534.900	2.953.300		45.72	7.0 2.13	160.0 344.3	77.1 23.50	BART for SCGCF, Golder 063-7534	188.6	23.76	1.0	From Southeast Renewable Fuels (Golder 0938-7660)	Yes	Yes	Yes
	Unit 8	800	SCBLR6N	534,900	2,953,300		47.24	9.5 2.90	154,0 340.9	37.6 11.46	HBCA Appl for SCGCF, Golder 063-7534	123.0	15.50	1.0	From Southeast Renewable Fuels (Golder 0938-7660)	Yes	Yes	Yes
	Off-crop season b																	
	Unit 1	001	SCBLR1F	534,900	2,953,300		45.72	7.0 2.13	156.0 342.0	49.6 15.12	BART for SCGCF, Golder 063-7534	159.2	20.05	1.0	From Southeast Renewable Fuels (Golder 0938-7660)	Yes	Yes	Yes
	Unit 4	004	SCBLR4F	534,900	2,953,300	180.0	54.86	8.9 2.72	162.0 345.4	54,1 16,49	BART for SCGCF, Golder 063-7534	257.0	32.38	1.0	From Southeast Renewable Fuels (Golder 0938-7660)	Yes	Yes	Yes



Based on engineering estimates. Actual data not available.
Facilities or sources within facilities that operate only during the October 1 through April 31 crop season. For sources identified operating during off-crop season, the season is May through September.



### **LEGEND**

Approximate Extent of Urban Complex

### NOx Sources

- Rural
- Urban

### REFERENCES

PROJECT

1. NOx Sources, Urban Boundary, Golder Associates Inc., 2011.

0 2,500

Meters

1 INCH = 2,500 METERS
WHEN PRODUCED AT SIZE 11X17IN

FIGURE

DJECT No 033-87674

E No 09387674\_C002

7 0 SCALE: AS SHOWN

SIGN SKM 42:1/2011

NRL 4/25/2011

SCK SKM 4/29/2011

SKM 4/29/2011

ALEW SKM 4/29/2011

BACKGROUND NOX SOURCES
MODELED WITH URBAN
CLASSIFICATION

MEDLEY LANDFILL LFGTE PROJECT WASTE MANAGEMENT INC.

OF FLORIDA





#### **NOx Sources**

Rual

Urban

1. NOx Sources, Golder Associates Inc., 2011.

0 12,000

Meters

I INCH. = 1,000 METERS


WHEN PROBUCEDIAT SIZE 11X17IN

BA

BACKGROUND NOX SOURCES
USED IN MODELING ANALYSIS

MEDLEY LANDFILL LFGTE PROJECT WASTE MANAGEMENT INC. OF FLORIDA






(Modeling Files)



Golder Associates Inc. 6026 NW 1st Place Gainesville, FL 32607 USA

USA Tel (352) 336-5600 Fax (352) 336-6603



Project No. 093-87674

May 2011

Waste Management, Inc. of Florida 2700 NW 48<sup>th</sup> Street Pompano Beach, FL 33037