Seminole Energy, LLC

29261 Wall Street, MI 48393

November 3, 2008

Mr. Syed Arif, P.E.
Bureau of Air Regulation
Division of Air Resource Management
Department of Environmental Protection
STATE OF FLORIDA
2600 Blair Stone Road, MS 5505
Tallahassee, FL 32399-2400

RECEIVED

NOV 05 2008

BUREAU OF AIR REGULATION

Subject: Seminole Energy, LLC 6316358-011-AC
Air Construction Permit 1170084-005-AC (PSD-FL-376)
40 CFR Part 63 Subpart ZZZZ Applicability

Dear Mr. Arif:

Seminole Energy, LLC is submitting this document to the Florida Department of Environmental Protection (FDEP) Division of Air Resource Management (DARM) to provide the regulatory agency with information on the:

- 1. Date that construction commence for its landfill gas electricity generation facility that is operated at the Osceola Road Solid Waste Management Facility; and
- 2. Applicability of 40 CFR Part 63 Subpart ZZZZ (Subpart ZZZZ).

40 CFR Part 60.4230 specifies that ... the date that construction commences is the date the engine is ordered by the owner or operator.

40 CFR Part 63.6590 specifies that An affected source is any existing ... stationary RICE located at a ... area source.

40 CFR Part 63.6590 specifies that For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction ...before June 12, 2006.

40 CFR Part 63.6590 specifies that ... an existing stationary RICE that combusts landfill gas ... equivalent to 10 percent or more of the gross heat input on an annual basis, does not have to meet the requirements of this subpart and of subpart A of this part. No initial notification is necessary.

Seminole Energy, LLC placed an order on December 19, 2005 for the four (4) landfill gas fueled CAT G3520C IC engines that have been installed at the Osceola Road Solid Waste Management Facility. Attached is a copy of the original purchase order submitted to the equipment dealer for these engines.

Phone: (248) 380-3920 Fax: (248) 380-2038

Based on the cited Subpart ZZZZ provisions and the December 19, 2005 commencement of construction date, the stationary RICE installed at Seminole Energy, LLC are existing and not subject to these rules.

Seminole Energy, LLC appreciates the consideration of the FDEP-DARM of the information that is presented in this document.

Please contact us if you have any questions or require clarifications.

Sincerely,

SEMINOLE ENERGY, LLC.

Scott Salisbury

Managing Member (Secondary Responsible Official)

attachment

c: Mike Laframboise, Landfill Energy Systems Bill Owen, Landfill Energy Systems David Derenzo, Derenzo and Associates, Inc. 1-110 Gillinghim Lane

Will Advise



Michigan Cat

25000"Novi Rd:

29261 Wall Street Wixom, Michigan 48393 (248) 380-3920 (248) 380-2038 FAX

PURÇ		ORDE	
•	CS	- 22	70

▼ ORIGINAL		CHAN	C=	•
_ CHIGHWE	ب	CHANA	uc	:

DATE	ATTN		P.O. No.	TAG No.	DELIVERY REQUIRED		• • •
12/19/2005 Karl Grundemann		CS-2270 YOUR REFERENCE No.		UJy 15, 200	6	<u> </u>	
Best Wa	y	•		0070347-	Destination		<u>.</u>
QUANITTY	MODEL			DESCRIP	TION		
18	G3520TA	4160VA genset t #100703	ar G3520TA Gen C, 3 Phase, 60 H o include the eng 347, which by this s: Provide (3) the d parts manuals	z, for use o ine build co reference ee sets of d	n Low BTU Land pnsist as shown of is made a part h limensional and	ifill gas. Each on quote erein.	gs,
			Landfill En 29261 Wal Wixom, Mi	ergy Syster	ms 93		
·		TERMS	NET PRICE: Wi NET 30 DAYS IT: Included in I				
		Landfill	sign, date and re Energy Systems :hase order.				
		Name:			Dat	e:	·
						,	
POC\$2270		Title:	•			•	

IMPORTANT: Please note instructions below, which are part of this order.

- 1 pce our order number on all INVOICES, PACKING LISTS AND SHIPPING TAGS.
- 2. See Terms and Conditions on reverse side.
- 3. If you cannot deliver entire order as specified please advise us at once. Substitutions not authorized by us in writing automatically particular this order and we will not be responsible for same.

☐ Taxable)
-----------	---

_			
	Torre	Evernn	

B38-2712011

WHITE - CUSTOMER . YELLOW - ACCOUNTING . PINK - FIRE