



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET, N.E.
ATLANTA, GEORGIA 30365

4APT-AEB

AUG 02 1991

Mr. Clair H. Fancy, P.E., Chief
Bureau of Air Regulation
Florida Department of Environmental
Regulation
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400


RE: Champion International Corporation (PSD-FL-126A)

Dear Mr. Fancy:

This is to acknowledge receipt your final determination and Prevention of Significant Deterioration (PSD) permit for the above referenced facility by letter dated July 17, 1991. The application requests a PSD permit for the natural gas-fired Package Boiler #5 which previously operated under a temporary permit. The applicant has proposed a NO_x emission limit of 0.1 lb/MMBTU to be achieved through a combination of flue gas recirculation and a low NO_x burner. We have reviewed the package as requested and have no adverse comments.

Thank you for the opportunity to review and comment on this package. If you have any questions or comments, please contact Mr. Gregg Worley of my staff at (404) 347-5014.

Sincerely yours,


Jewell A. Harper, Chief
Air Enforcement Branch
Air, Pesticides, and Toxics
Management Division

cc: *D. Reynolds*
C. Halladay
B. Andrews
C. Middaswart, SW Dist

RECEIVED

AUG 5 1991

Division of Air
Resources Management