HARDEE POWER PARTNERS LIMITED

Invenergy

Via Federal Express

March 27, 2012

Ms. Danielle Henry
Florida Department of Environmental Protection
Southwest District Office
13051 North Telecom Parkway
Temple Terrace, FL 33637-0926

RECEIVED

MAR 28 2012

DIVISION OF AIR RESOURCE MANAGEMENT

Re:

Hardee Power Partners Limited

Hardee Power Station

Conditions of Certification PA 89-25

Title V Air Operations Permit No. 0490015-013-AV 2011 Annual Average Capacity Factor Report

Dear Ms. Henry,

Pursuant to the requirements of Specific Conditions A.20 and A.22 of Title V Air Operations Permit No. 0490015-013-AV, Hardee Power Partners Limited hereby submits the enclosed report providing calculations of the 2011 annual average capacity factor and cumulative lifetime average capacity factor for Hardee Power Station Units 1A, 1B, 2A, and the Steam Turbine.

Please feel free to contact Matt Drennan at (863) 375-3266 ext. 227 if you have any questions regarding this information.

I certify that, based on the information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate, and complete.

Sincerely,

Tim Frost Plant Manager

Attachment

cc: Florida Department of Environmental Protection

Division of Air Resource Management

Bureau of Air Regulation

Title V Section

2600 Blair Stone Rd., Mail Station #5505

Tallahassee, FL 32399-2400

ANNUAL CUMULATIVE LIFETIME CAPACITY FACTOR FOR HARDEE POWER STATION UNITS 1A, 1B, ST, 2A FOR THE CALENDAR YEAR 2011

	UNIT	2011 ANNUAL		CUMULATIVE LIFETIME	
	CAPABILITY		CAPACITY	- · · · · · · · · · · · · · · · · · · ·	CAPACITY
UNIT	(MW)	MWH	FACTOR	MWH	FACTOR
CT 1A	86	62,056	8.24%	3,582,136	25.03%
CT 1B	86	37,181	4.94%	3,586,497	25.06%
Steam Turbine	81	49,080	6.92%	3,621,084	26.86%
Total CC	253	148,317	6.69%_	10,789,717	25.62%
CT 2A	87	1,465	0.19%	846,048	5.84%
Total	340	149,782	5.03%	11,635,765	20.56%

Note: Commercial operation began January 1, 1993.