

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION



SOUTHWEST DISTRICT

7601 HIGHWAY 301 NORTH
TAMPA, FLORIDA 33610

813-985-7402
SunCom - 570-8000

BOB GRAHAM
GOVERNOR

VICTORIA J. TSCHINKEL
SECRETARY

DR. RICHARD D. GARRITY
DISTRICT MANAGER

July 28, 1986

Mr. A. Spencer Autry, Manager
Environmental Planning
Tampa Electric Company
Post Office Box 111
Tampa, FL 33601-0111

RE: Modification of Conditions
Permit No. A029-85099

Dear Mr. Autry:

We are in receipt of your request for a modification of the permit conditions.
The conditions are changed as follows:

Specific Condition No. 1

From:

1. Test the emissions for the following pollutant(s) at intervals of 12 months from the date March 15, 1984 and submit 2 copies of test data to the Air Section of the Hillsborough County Environmental Protection Commission Office within forty five days of such testing (Section 17-2.700 (2), Florida Administrative Code (F.A.C.)).

- | | |
|------------------|--------------------------|
| () Particulates | () Sulfur Oxides |
| () Fluorides | () Nitrogen Oxides |
| (X) Opacity | () Hydrocarbons |
| | () Total Reduced Sulfur |

*Fuel analysis may be submitted for required sulfur dioxide emission test.

To:

1. Test the emissions for the following pollutant(s) at intervals of 12 months from the date March 15, 1984, or within a ninety (90) day period prior to this date, and submit 2 copies of test data to the Air Section of the Hillsborough County Environmental Protection Commission Office within forty five days of such testing (Section 17-2.700 (2), Florida Administrative Code (F.A.C.)).

Mr. A. Spencer Autry, Manager
Tampa, FL

Page Two
July 28, 1986

- | | |
|---|---|
| <input type="checkbox"/> Particulates | <input type="checkbox"/> Sulfur Oxides |
| <input type="checkbox"/> Fluorides | <input type="checkbox"/> Nitrogen Oxides |
| <input checked="" type="checkbox"/> Opacity | <input type="checkbox"/> Hydrocarbons |
| | <input type="checkbox"/> Total Reduced Sulfur |

*Fuel analysis may be submitted for required sulfur dioxide emission test.

Specific Condition No. 4

From:

5. The Hillsborough County Environmental Protection Commission shall be notified in writing 15 days prior to compliance testing.

To:

5. The Hillsborough County Environmental Protection Commission shall be notified 15 days prior to compliance testing.

This letter must be attached to your permit and becomes a part of that permit.

Sincerely,



W. C. Thomas, P.E.
District Air Engineer

JWE/js

Mr. A. Spencer Autry, Manager
Tampa, FL

July 28, 1986
Page Three

CERTIFICATE OF SERVICE

This is to certify that this NOTICE OF PERMIT and all copies were mailed before the close of business on 7-30-86 to the listed persons.

FILING AND ACKNOWLEDGEMENT
FILED, on this date, pursuant to
§120.52(10), Florida Statutes, with
the designated Department Clerk,
receipt of which is hereby
acknowledged.

Jean Sebesta
Clerk

7/30/86
Date