

COMMISSION  
PHYLLIS BUSANSKY  
RODNEY COLSON  
PAM IORIO  
RUBIN E. PADGETT  
JAN KAMINIS PLATT  
HAVEN POE  
JAMES D. SELVEY



ROGER P. STEWART  
DIRECTOR  
1900 - 9th AVE  
TAMPA, FLORIDA 33605  
TELEPHONE (813) 272-5960

M E M O R A N D U M

DATE: June 26, 1989

TO: George Richardson THRU J. Harry Kerns, P.E.

FROM: Arthur J. Wells AW THRU Jerry Campbell, P.E. JK

RE: Two Operating Permits for Tampa Electric Company  
Units 1-6 Coal Bunkers with Six Roto-Clones  
(Gannon Station) A029-163823  
Units 1-3 Coal Bunkers with Three Roto-Clones  
(Big Bend Station) A029-163788

Visible emissions tests conducted by Tampa Electric Company on June 13, 1989 on the F.J. Gannon Unit #4 roto-clone and the Big Bend Unit #3 roto-clone show 0% opacity. The roto-clones are utilized for safety and to control dust emissions from their respective bunkers during coal transport.

Based on my inspections conducted on May 11, 1989 of the aforementioned units at the Big Bend and Gannon Station facilities, I recommend approval to issue two operating permits as no deficiencies were noted. Enclosed for your signature are the drafts of the proposed operating permits including preliminary determinations for each and a diskette.

RECEIVED ON JULY 5, 1989 FROM EPCHC  
88TH DAY

AJW:ROTO.1-6