

File

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION



**SOUTHWEST DISTRICT**

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610

813-985-7402  
SunCom - 570-8000

BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

DR. RICHARD D. GARRITY  
DISTRICT MANAGER

March 19, 1986

Mr. A. Spencer Autry  
Manager, Environmental Planning  
TAMPA ELECTRIC COMPANY  
P.O. Box 111  
Tampa, Florida 33601-0111

Re: Opacity Monitoring System: Gannon Station Unit 1; Permit No. A029-47731; Contraves Goerz Modes 400; Serial No. 400-3400-0009

Dear Mr. Autry:

This letter certifies that the above named monitoring system conforms with EPA performance requirements described in 40 CFR 60, Appendix B, specification 1, as specified by DER requirements 17-2.710. Modification to or replacement of system components beyond normal maintenance and repair procedures may render the monitor's acceptable status void.

Sincerely,

Kenneth Roberts  
Air Compliance Engineer

KMR/js