



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

SOUTHWEST DISTRICT
7601 HIGHWAY 301 NORTH
TAMPA, FLORIDA 33610

October 23, 1978
Tampa Electric Company
Hillsborough County -- AP

REUBIN O'D. ASKEW
GOVERNOR

JOSEPH W. LANDERS, JR.
SECRETARY

P. David Puchaty
District Manager

Dr. William J. Johnson, Senior Consulting Engineer
Acting Manager, Environmental Planning
Tampa Electric Company
P. O. Box 111
Tampa, Florida 33601

Dear Dr. Johnson:

Pursuant to Section 403.061(16), Florida Statutes, your application has been approved by the Department and therefore, we are issuing to you the enclosed permit no. A029-12601 which will expire on October 15, 1983.

This permit is not effective unless you accept it, including any and all of the conditions contained therein. If you do not choose to accept it, you must file an appropriate petition for a hearing pursuant to the provisions of Section 120.57, Florida Statutes.

A petition for a hearing must comply with the requirements of Florida Administrative Code, Section 28-5.15 and be filed (postmarked) with the Secretary of the Department of Environmental Regulation at 2562 Executive Center Circle, East, Montgomery Building, Tallahassee, Florida 32301, with a copy to this office within fourteen (14) days from receipt of this letter. Petitions which are not filed in accordance with the above provisions may be subject to dismissal.

Any time limits imposed in the permit are a condition to this permit and are enforceable under Section 403.061, Florida Statutes. You are hereby placed on notice that the Department will review this permit to check for compliance and will initiate enforcement action for violations of the conditions and requirements of this permit.

Your continued cooperation in this matter is appreciated. Please refer to your assigned permit number in all future communications.

Sincerely,

P. David Puchaty
District Manager

cc: Central Records
HCEPC

Enclosures

RULES OF THE ADMINISTRATION COMMISSION
MODEL RULES OF PROCEDURE
CHAPTER 28-5
DECISIONS DETERMINING SUBSTANTIAL INTERESTS

28-5.15 Requests for Formal and Informal Proceedings

- (1) Requests for proceedings shall be made by petition to the agency involved. Each petition shall be printed, typewritten or otherwise duplicated in legible form on white paper of standard legal size. Unless printed, the impression shall be on one side of the paper only and lines shall be double spaced and indented.
- (2) All petitions filed under these rules should contain:
 - (a) The name and address of each agency affected and each agency's file or identification number, if known;
 - (b) The name and address of the petitioner or petitioners;
 - (c) All disputed issues of material fact. If there are none, the petition must so indicate;
 - (d) A concise statement of the ultimate facts alleged, and the rules, regulations and constitutional provisions which entitle the petitioner to relief;
 - (e) A statement summarizing any informal action taken to resolve the issues, and the results of that action;
 - (f) A demand for the relief to which the petitioner deems himself entitled; and
 - (g) Such other information which the petitioner contends is material.

Note: At a formal hearing all parties shall have an opportunity to present evidence and argument on all issues involved, to conduct cross-examination and submit rebuttal evidence, to submit proposed findings of fact and orders, to file exceptions to any order or hearing officer's recommended order, and to be represented by counsel.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

OPERATION PERMIT

FOR Tampa Electric Company

P. O. Box 111

Tampa, Florida 33601

PERMIT NO. A029-12601 DATE OF ISSUE October 23, 1978

PURSUANT TO THE PROVISIONS OF SECTIONS 403.061 (16) AND 403.707 OF CHAPTER 403 FLORIDA STATUTES AND CHAPTERS 17-4 AND 17-7 FLORIDA ADMINISTRATIVE CODE THIS PERMIT IS ISSUED TO:

Dr. William J. Johnson, Senior Consulting Engineer, Acting Manager,
Environmental Planning

FOR THE OPERATION OF THE FOLLOWING:

Gannon Station No. 6 Steam Generator with an Electrostatic Precipitator

Subject to Attached Conditions of Approval Nos.: 1,2,3,4,5, & 6.

235 MW

LOCATED AT Port Sutton Road, Tampa

UTM: 17 - 360.0 E 3087.5 N

IN ACCORDANCE WITH THE APPLICATION DATED August 25, 1978

ANY CONDITIONS OR PROVISOS WHICH ARE ATTACHED HERETO ARE INCORPORATED INTO AND MADE A PART OF THIS PERMIT AS THOUGH FULLY SET FORTH HEREIN. FAILURE TO COMPLY WITH SAID CONDITIONS OR PROVISOS SHALL CONSTITUTE A VIOLATION OF THIS PERMIT AND SHALL SUBJECT THE APPLICANT TO SUCH CIVIL AND CRIMINAL PENALTIES AS PROVIDED BY LAW.

THIS PERMIT SHALL BE EFFECTIVE FROM THE DATE OF ISSUE UNTIL October 15, 1983

OR UNLESS REVOKED OR SURRENDERED AND SHALL BE SUBJECT TO ALL LAWS OF THE STATE AND THE RULES AND REGULATIONS OF THE DEPARTMENT.

[Signature]
DISTRICT ENGINEER

[Signature]
JOSEPH W. LANDERS, JR.
SECRETARY

[Signature]
Roger P. Stewart, Director
Hillsborough Co. Env. Protection Commission

[Signature]
DISTRICT MANAGER

File



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

SOUTHWEST DISTRICT
9721 EXECUTIVE CENTER DRIVE, NORTH, SUITE 200
~~PO BOX 20850~~
ST. PETERSBURG, FLORIDA ~~33708~~ 33702

REUBIN O'D. ASKEW
GOVERNOR

JOSEPH W. LANDERS, JR.
SECRETARY

April 5, 1976
Hillsborough County AP
Tampa Electric Company

Mr. Alex. Kaiser, Director
Power Plant Engineering
Tampa Electric Company
Post Office Box 111
Tampa, Florida 33601

Dear Mr. Kaiser:

Pursuant to your recent application, please find enclosed a permit
(No. AO 29-2470) dated April 5, 1976 to ~~construct~~/operate
the subject pollution source.

This permit will expire on April 5, 1978 , and will be subject
to the conditions, requirements, and restrictions checked or indi-
cated otherwise in the attached sheet "~~Construction~~/Operation Permit
Conditions".

This permit is issued under the authority of Florida Statute
403.061(16). The time limits imposed herein are a condition to
this permit and are enforceable under Florida Statute 403.161.
You are hereby placed on Notice that the Department will review this
permit before the scheduled date of expiry and will seek court action
for violation of the conditions and requirements of this permit.

You have ten days from the date of receipt hereof within which to
seek a review of the conditions and requirements contained in this
permit. Failure to file a written request to review or modify the
conditions or requirements contained in this permit shall be deemed
a waiver of any objections thereto.

Your continued cooperation in this matter is appreciated and in
future communication please refer to your permit number.

BBV
BBV/smw

Yours very truly,

cc: Central Files
Hillsborough County
Environmental Protection
Commission

B B Vest Jr
Banks B. Vest, Jr.
District Manager
Southwest District

101800052004006

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

OPERATION PERMIT

FOR TAMPA ELECTRIC COMPANY

P. O. BOX 111

TAMPA, FLORIDA 33601

PERMIT NO. AO 29-2470

DATE OF ISSUE April 5, 1976

PURSUANT TO THE PROVISIONS OF SECTIONS 403.061(16) AND 403.707 OF CHAPTER 403 FLORIDA STATUTES AND CHAPTERS 17-4 AND 17-7 FLORIDA ADMINISTRATIVE CODE, THIS PERMIT IS ISSUED TO:

ALEX KAISER, DIRECTOR OF POWER PLANT ENGINEERING AND ENVIRONMENTAL PLANNING

FOR THE OPERATION OF THE FOLLOWING:

GANNON STATION NO. 6 STEAM GENERATOR WITH AN ELECTROSTATIC

PRECIPITATOR SUBJECT TO ATTACHED CONDITIONS OF APPROVAL NOS:

1, 2, 3, 4, 5, 6, 7, & 8

LOCATED AT PORT SUTTON ROAD, TAMPA

UTM: 17-360.00E 3087.50N

IN ACCORDANCE WITH THE APPLICATION DATED 8/1/75

ANY CONDITIONS OR PROVISOS WHICH ARE ATTACHED HERETO ARE INCORPORATED INTO AND MADE A PART OF THIS PERMIT AS THOUGH FULLY SET FORTH HEREIN. FAILURE TO COMPLY WITH SAID CONDITIONS OR PROVISOS SHALL CONSTITUTE A VIOLATION OF THIS PERMIT AND SHALL SUBJECT THE APPLICANT TO SUCH CIVIL AND CRIMINAL PENALTIES AS PROVIDED BY LAW.

THIS PERMIT SHALL BE EFFECTIVE FROM THE DATE OF ISSUE UNTIL 4/5/78

OR UNTIL REVOKED OR SURRENDERED AND SHALL BE SUBJECT TO ALL LAWS OF THE STATE AND THE RULES AND REGULATIONS OF THE DEPARTMENT.

J. E. Hoffmann
DISTRICT ENGINEER

Joseph W. Landers, Jr.
JOSEPH W. LANDERS, JR.
SECRETARY

Roger P. Stewart
ROGER P. STEWART, DIRECTOR
HILLS COUNTY ENV. PROTECTION COMMISSION

Barb B. Vard
DISTRICT MANAGER

BEST AVAILABLE COPY
FOR AIR POLLUTION SOURCES

Permit No.: AO29-2470

Date: 4/5/76

- (X) 1. Fugitive dusts, odors and other pollutants from all sources shall be effectively controlled or eliminated by suitable means. (Chapter 17-2.04 (3)(4)(5))
- (X) 2. The pollution control equipment shall be maintained and operated in such a manner that all emissions will be in compliance with applicable rules and regulations of the DER. A log of maintenance activities shall be kept and available for DER review. (Chapter 17-2.03 (7))
- (X) 3. Report any problems encountered in the operation of the source that may result in discharge of pollutants in amounts higher than permitted herein. Cease operation forthwith unless permission has been obtained from the regional office of the DER to operate the source for an interim period. (Chapter 17-4.13)
- (X) 4. This permit is issued on the basis of the data submitted in the application and the existing requirements of this agency as set forth in Chapter 17-2 (revised January 18, 1972) Florida Administrative Code. The owner shall obtain written permission from the DER before making changes in the operation of the source (i.e. higher production rate, different raw materials and fuels, etc.) that may increase the quantity of pollutants or change their composition. (Chapter 17-2.01)
- (X) 5. This permit is not transferable. Upon the sale or legal transfer of the source covered by this permit, the new owner must apply by letter for a transfer of this permit within thirty days. (Chapter 17-4.12)
- (X) 6. Test the emissions for the following pollutant(s) at intervals of SIX MONTHS from the date of this permit and submit two copies of test results to the District engineer of this agency within fifteen days of such testing. (Chapter 17-2.07 (1))
- | | |
|-----------------------------------|---------------------|
| (X) Particulates (Stack Sampling) | (X) Sulfur Oxides * |
| () Fluorides | () Nitrogen Oxides |
| (X) Plume Density | () Hydrocarbons |
- * FUEL ANALYSIS WILL BE ACCEPTED IN LIEU OF SO₂ STACK SAMPLING
- (X) 7. Provide such sampling and testing facilities as may be necessary for the proper determination of the nature and quantity of air pollutants emitted from this source. (Chapter 17-2.07)
- (X) 8. Issuance of this permit does not relieve Tampa Electric Co from complying with the "Notice to Correct Violation" issued by the Hills. County Environmental Protection Commission on 2/19/76.