

Sheplak, Scott

From: Sheplak, Scott
Sent: Thursday, May 21, 2009 3:03 PM
To: 'Washington, Kevin'
Cc: laxmana_tallam@doh.state.fl.us; thomas_tittle@doh.state.fl.us
Subject: RE: EMERGENCY GENERATORS - FPL Martin Power Plant

Re: Permit No. 0850001-018-AV *-file-*

Thank you for the notification. They are most likely "insignificant." A copy of this e-mail will be kept on file here.

From: Washington, Kevin [mailto:Kevin.Washington@fpl.com]
Sent: Thursday, May 21, 2009 2:43 PM
To: Sheplak, Scott; laxmana_tallam@doh.state.fl.us; thomas_tittle@doh.state.fl.us
Subject: RE: EMERGENCY GENERATORS - FPL Martin Power Plant

Gentlemen,

Emergency Generators have been installed at the location referenced above as part of FPL's Hurricane Hardening program. The generators were installed after the Title V Permit renewal process was submitted completed. The generators provide power to a small "safe room" constructed for operating employees to use in the event of a significant storm. Each safe room has two generators; a primary and a back up. The generators are fueled by propane stored in four 120-gallon tanks at each of the two locations.

Location	Make	Model	Ignition	HP	Rated KW	Year Built
RPM	Rule Applicability					
Martin 2005 Units 1&2	Guardian, 3600 by Generac	004724-30 None 004723-1	Spark	27	20	
Martin 2005 Units 3&4	Guardian, 3600 by Generac	004725-3 None	Spark	34	25	

The generators are categorically exempt from permitting as provided by Rule 62-210.300(3)(a). They are also exempt from 40 CFR Part 60 Subparts JJJJ due to their manufacture date (2005), and from ZZZZ due to their size (<500 Hp).

The next time the Title V permit is opened for renewal, both generator packages will be added as insignificant or unregulated sources.

If you have any questions or require additional information feel free to contact me via return E:mail, or at (561) 691-2877.

Thank you,

5/21/2009

Kevin Washington
Project Manager
FPL Environmental Services
(561) 691-2877