

Friday, Barbara

To: GaryWiller@cogentrix.com; Laryea, Nicholas; bill.cannon@earthtech.com; Hoefert, Lee
Cc: Cascio, Tom
Subject: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.
Attachments: 0850102.013.AV.F_pdf[1].zip

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

2/5/2008

Friday, Barbara

From: System Administrator
To: Hoefert, Lee
Sent: Tuesday, February 05, 2008 2:04 PM
Subject: Delivered:FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Your message

To: 'GaryWiller@cogentrix.com'; 'Laryea, Nicholas'; 'bill.cannon@earthtech.com'; Hoefert, Lee
Cc: Cascio, Tom
Subject: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.
Sent: 2/5/2008 2:03 PM

was delivered to the following recipient(s):

Hoefert, Lee on 2/5/2008 2:04 PM

Friday, Barbara

From: System Administrator
To: Cascio, Tom
Sent: Tuesday, February 05, 2008 2:04 PM
Subject: Delivered:FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Your message

To: 'GaryWiller@cogentrix.com'; 'Laryea, Nicholas'; 'bill.cannon@earthtech.com'; Hoefert, Lee
Cc: Cascio, Tom
Subject: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.
Sent: 2/5/2008 2:03 PM

was delivered to the following recipient(s):

Cascio, Tom on 2/5/2008 2:03 PM

Friday, Barbara

From: Exchange Administrator
Sent: Tuesday, February 05, 2008 2:04 PM
To: Friday, Barbara
Subject: Delivery Status Notification (Relay)

Attachments: ATT161666.txt; FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.



ATT161666.txt (291 B) FINAL Title V Permit Revision ...

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

bill.cannon@earthtech.com

Friday, Barbara

From: Exchange Administrator
Sent: Tuesday, February 05, 2008 2:04 PM
To: Friday, Barbara
Subject: Delivery Status Notification (Relay)

Attachments: ATT161698.txt; FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.



ATT161698.txt (378 B) FINAL Title V Permit Revision ...

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

GaryWiller@cogentrix.com
NicholasLaryea@cogentrix.com

Friday, Barbara

From: Cascio, Tom
To: Friday, Barbara
Sent: Tuesday, February 05, 2008 2:14 PM
Subject: Read: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Your message

To: 'GaryWiller@cogentrix.com'; 'Laryea, Nicholas'; 'bill.cannon@earthtech.com'; Hoefert, Lee
Cc: Cascio, Tom
Subject: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.
Sent: 2/5/2008 2:03 PM

was read on 2/5/2008 2:14 PM.

Friday, Barbara

From: Hoefert, Lee
To: Friday, Barbara
Sent: Tuesday, February 05, 2008 3:26 PM
Subject: Read: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Your message

To: 'GaryWiller@cogentrix.com'; 'Laryea, Nicholas'; 'bill.cannon@earthtech.com'; Hoefert, Lee
Cc: Cascio, Tom
Subject: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.
Sent: 2/5/2008 2:03 PM

was read on 2/5/2008 3:26 PM.

Friday, Barbara

From: Willer, Gary [GaryWiller@Cogentrix.com]
To: Friday, Barbara
Sent: Tuesday, February 05, 2008 3:33 PM
Subject: Read: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Your message

To: GaryWiller@Cogentrix.com
Subject:

was read on 2/5/2008 3:33 PM.

Friday, Barbara

From: Willer, Gary [GaryWiller@Cogentrix.com]
Sent: Tuesday, February 05, 2008 4:52 PM
To: Friday, Barbara
Subject: RE: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Gary E. Willer
General Manager
Indiantown Cogeneration L.P.
(772) 597-6500 Ext.25
Fax (772) 597-6210
garywiller@kogentrix.com

From: Friday, Barbara [mailto:Barbara.Friday@dep.state.fl.us]
Sent: Tuesday, February 05, 2008 2:03 PM
To: Willer, Gary; Laryea, Nicholas; bill.cannon@earthtech.com; Hoefert, Lee
Cc: Cascio, Tom
Subject: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.

Thank you,

DEP, Bureau of Air Regulation

The Department of Environmental Protection values your feedback as a customer. DEP Secretary Michael W. Sole is committed to continuously assessing and improving the level and quality of services provided to you. Please take a few minutes to comment on the quality of service you received. Simply click on [this link to the DEP Customer Survey](#). Thank you in advance for completing the survey.

2/6/2008

Friday, Barbara

From: Laryea, Nicholas [NicholasLaryea@cogentrix.com]
To: Friday, Barbara
Sent: Tuesday, February 05, 2008 4:43 PM
Subject: Read: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Your message

To: NicholasLaryea@Cogentrix.com
Subject:

was read on 2/5/2008 4:43 PM.

Friday, Barbara

From: Cannon, Bill [Bill.Cannon@earthtech.com]
To: undisclosed-recipients
Sent: Wednesday, February 06, 2008 8:26 AM
Subject: Read: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Your message

To: Bill.Cannon@earthtech.com
Subject:

was read on 2/6/2008 8:26 AM.

Friday, Barbara

From: Cannon, Bill [Bill.Cannon@earthtech.com]
Sent: Wednesday, February 06, 2008 8:28 AM
To: Friday, Barbara
Subject: RE: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Received

Bill Cannon, PE
Project Engineer
Earth Tech

phone (864)-234-3581

From: Friday, Barbara [mailto:Barbara.Friday@dep.state.fl.us]
Sent: Tuesday, February 05, 2008 2:03 PM
To: GaryWiller@cogentrix.com; Laryea, Nicholas; Cannon, Bill; Hoefert, Lee
Cc: Cascio, Tom
Subject: FINAL Title V Permit Revision No.: 0850102-013-AV - Indiantown Cogeneration, L.P.

Dear Sir/Madam:

Please send a "reply" message verifying receipt of the attached document(s); this may be done by selecting "Reply" on the menu bar of your e-mail software and then selecting "Send". We must receive verification of receipt and your reply will preclude subsequent e-mail transmissions to verify receipt of the document(s).

The document(s) may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible.

The document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <http://www.adobe.com/products/acrobat/readstep.html>.

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record.


Thank you,

DEP, Bureau of Air Regulation


The Department of Environmental Protection values your feedback as a customer. DEP Secretary Michael W. Sole is committed to continuously assessing and improving the level and quality of services provided to you. Please take a few minutes to comment on the quality of service you received. Simply click on [this link to the DEP Customer Survey](#). Thank you in advance for completing the survey.

2/6/2008

MEMORANDUM

To: Joseph Kahn
From: Trina Vielhauer 
Subject: Indiantown Cogeneration Plant
Title V Air Operation Permit Revision No. 0850102-013-AV
Date: January 31, 2008

Attached is the FINAL Title V Air Operation Permit Revision for the subject plant. Day 55 is January 31, 2008. No comments were received from Region 4 USEPA during their review period. We recommend your signature.



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

NOTICE OF FINAL TITLE V PERMIT REVISION

Electronically Sent – Received Receipt Requested.

In the Matter of an
Application for Permit Revision

Mr. Gary E. Willer, General Manager
GaryWiller@Cogentrix.com
Indiantown Cogeneration, L.P.
P.O. Box 1799
13303 SW Silver Fox Lane
Indiantown, Florida 34956

DEP File No. 0850102-013-AV
Indiantown Cogeneration Plant
Martin County

Enclosed is the FINAL Title V Permit Revision Number 0850102-013-AV for the operation of the Indiantown Cogeneration Plant, located at 13303 SW Silver Fox Lane, Indiantown, Martin County. This permit revision is issued pursuant to Chapter 403, Florida Statutes (F.S.). No written comments were received from Region 4, United States Environmental Protection Agency (USEPA); therefore no changes were made to the PROPOSED Permit. The FINAL DETERMINATION is attached.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.

Trina L. Vielhauer, Chief
Bureau of Air Regulation

NOTICE OF FINAL TITLE V PERMIT REVISION
PERMIT NUMBER 0850102-013-AV

Page 2 of 2

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF FINAL PERMIT REVISION (including the FINAL permit revision) and all copies were sent electronically (with Received Receipt) before the close of business on 2/5/08 to the persons listed:

Gary E. Willer, ICLP: GaryWiller@Cogentrix.com
Nick Laryea, ICLP: NicholasLaryea@Cogentrix.com
Bill Cannon, P.E., Earth Tech: bill.cannon@earthtech.com
Lee Hoefert, P.E., Southeast District Office: lee.hoefert@dep.state.fl.us
Gracy Danois, EPA Region 4: danois.gracy@epa.gov

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Paula J. Snidger 2/5/08
(Clerk) (Date)

FINAL PERMIT DETERMINATION

Indiantown Cogeneration, L.P.
Indiantown Cogeneration Plant
Facility ID No. **0850102**
Martin County

Title V Air Operation Permit Revision
FINAL Permit Revision No. **0850102-013-AV**

No written comments on the PROPOSED Permit Revision were received from Region 4, United States Environmental Protection Agency (USEPA). Based on these findings, the PROPOSED permit was not changed.

The permitting authority hereby issues the FINAL Title V Air Operation Permit Revision No. **0850102-013-AV** with no changes.

STATEMENT OF BASIS

Title V Permit Revision No. **0850102-013-AV**

Indiantown Cogeneration, L.P.

Indiantown Cogeneration Plant

Martin County

This Title V air operation permit revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, and 62-213. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

The Indiantown Cogeneration Plant is a cogeneration facility which generates electricity for sale and exports steam to the Louis Dreyfus Citrus Processing Plant. The facility includes one high-pressure pulverized coal (PC) main boiler rated at 3,422 million British thermal units (MMBtu)/hour heat input, and has a nominal net electrical power output of approximately 330 megawatts (MW). It is permitted to fire natural gas, propane, or No. 2 fuel oil for startup, shutdown, or load changes. It commenced commercial operation in July, 1995.

The unit is equipped with low nitrogen oxides (NO_x) burners, overfire air, a steam coil air heater and air preheater, dual register burners and windbox design, a selective catalytic reduction system, spray dryer absorber, and fabric filter baghouse.

The emissions unit is regulated under Standards of Performance for New Stationary Sources (NSPS)-40 CFR 60, Subpart Da, Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT).

Also included are two identical auxiliary boilers used for supplying steam to the steam host during times when the PC boiler is offline, as well as during PC boiler startup and shutdown periods. Steam produced by the auxiliary boilers is not used to generate electricity. These emissions units are regulated under Rule 62-210.300, F.A.C., Permits Required; and NSPS-40 CFR 60, Subpart Db, Standards of Performance for Industrial- Commercial-Institutional Steam Generating Units, adopted and incorporated by reference in Rule 62-204.800(8), F.A.C.

In addition, the facility has a variety of ancillary equipment needed to support operations as a coal-fired cogeneration plant.

Based on the Title V permit revision application received on July 11, 2007, this facility is a major source of hazardous air pollutants (HAP).

This permit revision modifies the language of two specific conditions as noted below. Double underline indicates additions and strikethrough indicates deletions to the text.

9. ~~Inactive~~ Outdoor coal storage piles shall be shaped, compacted, and oriented to minimize wind erosion, ~~and covered~~. Water sprays or chemical wetting agents and stabilizers shall be applied to uncovered storage piles, roads, handling equipment, etc., during dry periods and as necessary to all facilities to maintain an opacity of less than or equal to 5 percent. When adding, moving, or removing coal from the coal pile an opacity of 20 percent is allowed. The coal pile is accessed as needed; ~~disturbance of the covering is minimized and the coal pile is re-covered periodically.~~

[PSD-FL-168, Specific Condition No. 10; ~~and~~, Rule 62-296.320(4)(c), F.A.C.; and 0850102-012-AC.]

C.6. Fugitive Emissions. ~~Inactive~~ Outdoor coal storage piles shall be shaped, compacted, and oriented to minimize wind erosion, ~~and covered~~. Water sprays or chemical wetting agents and stabilizers shall be applied to uncovered storage piles, roads, handling equipment, etc., during dry periods and as necessary to all facilities to maintain an opacity of less than or equal to 5 percent. When adding, moving, or removing coal from the coal pile an opacity of 20% is allowed.

[PSD-FL-168, Specific Condition No. 10.; and 0850102-012-AC.]

Indiantown Cogeneration, L.P.
Indiantown Cogeneration Plant
Facility ID No. **0850102**
Martin County

Title V Air Operation Permit Revision
FINAL Permit No. **0850102-013-AV**

Permitting Authority:
State of Florida
Department of Environmental Protection
Division of Air Resource Management
Bureau of Air Regulation

Mail Station #5505
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Telephone: 850/488-0114
Fax: 850/921-9533

Compliance Authority:
Department of Environmental Protection
Southeast District

400 North Congress Avenue
West Palm Beach, Florida 33401

Telephone: 561/681-6600
Fax: 561/681-6755



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

Permittee:

Indiantown Cogeneration, L.P.
P.O. Box 1799
Indiantown, Florida 34956

FINAL Permit No. 0850102-013-AV

Facility ID No. 0850102

SIC Nos.: 49, 4911

Project: Title V Air Operation Permit Revision


This permit revision is for the operation of the Indiantown Cogeneration Plant. This facility is located 9 miles east of Lake Okeechobee, and 3 miles northwest of Indiantown, Martin County; UTM Coordinates: Zone 17, 422.3 km East and 2952.9 km North; Latitude: 27° 02' 20" North and Longitude: 80° 30' 45" West.

This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, and 62-213. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

Appendix I-1, List of Insignificant Emissions Units and/or Activities
Appendix U-1, List of Unregulated Emissions Units and/or Activities
APPENDIX TV-4, TITLE V CONDITIONS (version dated 2/12/02)
APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)
Appendix 40 CFR 60, Subpart A - General Provisions (dated 07/23/97)
Appendix CAM

Effective Date: January 12, 2005
Revision Effective Date: January 31, 2008
Renewal Application Due Date: July 11, 2009
Expiration Date: January 11, 2010



Joseph Kahn, Director
Division of Air Resource
Management

JK/tlv/aal/tbc

Title V Air Operation Permit Revision
FINAL Permit No. 0850102-013-AV

Table of Contents

Section	Page Number
Placard Page	1
I. Facility Information	2
A. Facility Description.	
B. Summary of Emissions Unit ID Nos. and Brief Descriptions.	
C. Relevant Documents.	
II. Facility-wide Conditions	4
III. Emissions Units and Conditions	
A. Pulverized Coal Fired Main Boiler (E.U. ID No. -001).....	8
B. Temporary Package Boiler.....	28
C. Coal Handling System (E.U. ID No. -004).....	30
D. Ash Handling System (E.U. ID No. -005).....	35
E. Lime Handling System (E.U. ID No. -006).....	39
F. Two Auxiliary Boilers (E.U. No. -007).....	43
Appendix I-1. List of Insignificant Emissions Units and/or Activities.....	54
Appendix H-1. Permit History/ID Number Changes.....	55
Appendix U-1. List of Unregulated Emissions Units and/or Activities.....	56
Appendix CAM.....	57

Section I. Facility Information.

Subsection A. Facility Description.

The Indiantown Cogeneration Plant is a cogeneration facility which generates electricity for sale and exports steam to the Louis Dreyfus Citrus Processing Plant. The facility includes one high-pressure pulverized coal main boiler (PC boiler) rated at 3,422 MMBtu/hour heat input, and has a nominal net electrical power output of approximately 330 megawatts (MW). It is permitted to fire natural gas, propane, or No. 2 fuel oil for startup, shutdown, or load changes.

Also included are two natural gas (or propane) fired identical auxiliary boilers used for supplying steam to the steam host during times when the PC boiler is offline, as well as during PC boiler startup and shutdown periods. The two identically sized packaged water-tube steam boilers have a combined rated maximum capacity of 350 MMBtu/hr.

Steam produced by the auxiliary boilers is not used to generate electricity. In addition, the facility has a variety of ancillary equipment needed to support operations as a coal-fired cogeneration plant.

The permittee may install and operate an unregulated temporary package boiler in the event that the PC boiler and at least one auxiliary boiler are inoperable.

Based on the Title V permit revision application received on April 16, 2007, this facility is a major source of hazardous air pollutants (HAP).

Subsection B. Summary of Emissions Unit ID Nos. and Brief Descriptions.

E.U. ID No.	Brief Description
-001	Pulverized Coal Main Boiler
	Temporary Package Boiler (unregulated)
-004	Coal Handling System
-005	Ash Handling System
-006	Lime Handling System
-007	(2) Victory Energy Model 23M Keystone Packaged Water-tube Steam Boilers

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.

Subsection C. Relevant Documents.

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:

Table 1-1, Summary of Air Pollutant Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

Appendix H-1, Permit History/ID Number Changes
Statement of Basis

These documents are on file with permitting authority:

Title V Air Operation Permit Revision Application received on July 11, 2007.

DRAFT Title V Air Operation Permit clerked on October 18, 2007.

PROPOSED Title V Air Operation Permit posted for EPA review on December 7, 2007.

Documents on file with USEPA

The Responsible Official has certified that the Risk Management Plan was submitted to the RMP Reporting Center.

Section II. Facility-wide Conditions.

The following conditions apply facility-wide:

1. APPENDIX TV-4, TITLE V CONDITIONS, is a part of this permit.
{Permitting note: APPENDIX TV-4, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}
2. **Not federally enforceable.** General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.
[Rule 62-296.320(2), F.A.C.]
3. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.
[Rule 62-296.320(4)(b)1. & 4., F.A.C.]
4. Prevention of Accidental Releases (Section 112(r) of CAA).
 - a. As required by Section 112(r)(7)(B)(iii) of the CAA and 40 CFR 68, the owner or operator shall submit an updated Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center.
 - b. As required under Section 252.941(1)(c), F.S., the owner or operator shall report to the appropriate representative of the Department of Community Affairs (DCA), as established by department rule, within one working day of discovery of an accidental release of a regulated substance from the stationary source, if the owner or operator is required to report the release to the United States Environmental Protection Agency under Section 112(r)(6) of the CAA.
 - c. The owner or operator shall submit the required annual registration fee to the DCA on or before April 1, in accordance with Part IV, Chapter 252, F.S., and Rule 9G-21, F.A.C.

Any required written reports, notifications, certifications, and data required to be sent to the DCA, should be sent to:

Department of Community Affairs
Division of Emergency Management
2555 Shumard Oak Boulevard
Tallahassee, FL 32399-2100
Telephone: 850/413-9921, Fax: 850/488-1739

Any Risk Management Plans, original submittals, revisions or updates to submittals, should be sent to:

RMP Reporting Center
P.O. Box 1515
Lanham-Seabrook, Maryland 20703-1515
Telephone: 301/429-5018

Any required reports to be sent to the National Response Center, should be sent to:

National Response Center
EPA Office of Solid Waste and Emergency Response
USEPA (5305 W)
401 M Street, SW
Washington, D.C. 20460
Telephone: 1/800/424-8802

Send the required annual registration fee using approved forms made payable to:

Cashier
Department of Community Affairs
State Emergency Response Commission
2555 Shumard Oak Boulevard
Tallahassee, FL 32399-2149

[Part IV, Chapter 252, F.S.; and, Rule 9G-21, F.A.C.]

5. Unregulated Emissions Units and/or Activities. Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.
[Rule 62-213.440(1), F.A.C.]

6. Insignificant Emissions Units and/or Activities. Appendix I-1, List of Insignificant Emissions Units and/or Activities, is a part of this permit.
[Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]

7. Compliance Plan. Based on the application, emissions unit(s) were not in compliance. Appendix CP-1, Compliance Plan, is a part of this permit.
[Rule 62-213.440(2), F.A.C.]

8. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department.
Nothing was deemed necessary and ordered at this time.
[Rule 62-296.320(1)(a), F.A.C.]

9. Outdoor coal storage piles shall be shaped, compacted, and oriented to minimize wind erosion. Water sprays or chemical wetting agents and stabilizers shall be applied to uncovered storage piles, roads, handling equipment, etc., during dry periods and as necessary to all facilities

to maintain an opacity of less than or equal to 5 percent. When adding, moving, or removing coal from the coal pile an opacity of 20 percent is allowed. The coal pile is accessed as needed. [PSD-FL-168, Specific Condition No. 10; Rule 62-296.320(4)(c), F.A.C.; and 0850102-012-AC.]

10. Emissions of Unconfined Particulate Matter. Pursuant to Rules 62-296.320(4)(c)1., 3. & 4., F.A.C., reasonable precautions to prevent emissions of unconfined particulate matter (PM) at this facility include the following requirements (see Condition 57. of APPENDIX TV-4, TITLE V CONDITIONS):

The following requirements are “not federally enforceable”:

- a. Unconfined PM related to coal transfer points is controlled by water spray in key locations;
- b. Unconfined PM related to coal, lime and ash mobile equipment operations is controlled by wetting the coal pile and road surfaces; and
- c. Water spray is used as-needed in the ash loadout process.

[Rule 62-296.320(4)(c)2., F.A.C.; proposed by the applicant in the Title V permit renewal application received on February 23, 2004; and 0850102-008-AC, Specific Condition 8.]

11. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one. [Rule 62-213.440, F.A.C.]

12. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3)(a)2., F.A.C., shall be submitted to the Department and EPA within 60 (sixty) days after the end of the calendar year using DEP Form No. 62-213.900(7), F.A.C. [Rules 62-213.440(3) and 62-213.900, F.A.C.]

{Permitting Note: This condition implements the requirements of Rules 62-213.440(3)(a)2. & 3., F.A.C. (see Condition 51. of APPENDIX TV-4, TITLE V CONDITIONS)}

13. The permittee shall submit all compliance related notifications and reports required of this permit to the Department’s Southeast District office:

Department of Environmental Protection
Southeast District
400 North Congress Avenue
West Palm Beach, Florida 33401
Telephone: 561/681-6600; Fax: 561/681-6755

14. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency Region 4
Air, Pesticides & Toxics Management Division
Air & EPCRA Enforcement Branch, Air Enforcement Section
61 Forsyth Street
Atlanta, Georgia 30303
Telephone: 404/562-9155; Fax: 404/562-9163 or 404/562-9164

15. Certification by Responsible Official (RO). In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Any responsible official who fails to submit any required information or who has submitted incorrect information shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary information or correct information.

[Rule 62-213.420(4), F.A.C.]

Section III. Emissions Units and Conditions.

Subsection A. This section addresses the following emissions unit.

E.U. ID No.	Brief Description
-001	Pulverized Coal Main Boiler

The pulverized coal main boiler is rated at 3,422 MMBtu/hour heat input, and has a nominal net electrical power output of approximately 330 megawatts (MW). It is permitted to fire coal, No. 2 fuel oil, natural gas, and propane. It commenced commercial operation in July, 1995.

The unit is equipped with low NO_x burners, overfire air, a steam coil air heater and air preheater, dual register burners and windbox design, a selective catalytic reduction (SCR) system, spray dryer absorber, and fabric filter baghouse. Because continuous emissions monitors (CEMS) are used to demonstrate compliance with the applicable standards for NO_x and SO₂, a compliance assurance monitoring (CAM) plan is not required for either the SCR system, or the spray dryer absorber. *A CAM plan is included for the fabric filter baghouse. See Appendix CAM.*

{Permitting note: the emissions unit is regulated under NSPS-40 CFR 60, Subpart Da, Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978, adopted and incorporated by reference in Rule 62-204.800(8), F.A.C.; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT), Compliance Assurance Monitoring (CAM), adopted and incorporated by reference in Rule 62-204.800, F.A.C.}

The following specific conditions apply:

General

A.1. Definitions. For the purposes of Rule 62-204.800(8), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.
[40 CFR 60.2; and Rule 62-204.800(8)(a), F.A.C.]

A.2. Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.
[40 CFR 60.12]

A.3. Coal shall not be burned in the unit unless the spray dryer scrubber, fabric filter baghouse, and other air pollution control devices are operating properly except as provided under 40 CFR 60, Subpart Da. Any malfunctions of these air pollution control devices are to be recorded, including duration, cause, and description of the repair.
[PSD-FL-168, Specific Condition No. 13]

A.4. No fraction of the flue gas shall be allowed to bypass the air pollution control devices (PCD) system to reheat the gases exiting from the PCD system, if the bypass will cause emissions above the limits specified in Specific Condition **A.12**. The percentage and amount of flue gas bypassing the PCD system shall be documented and records kept for a minimum of 5 (five) years and must be available for inspection by the Department.
[PSD-FL-168, Specific Condition No. 15]

Essential Potential to Emit (PTE) Parameters

A.5. Permitted Capacity. The maximum operation heat input rate allowed is as follows:

Emissions Unit No.	MMBtu/hr Heat Input	Fuel Type
-001	3422	Coal

[Rules 62-4.160(2), 62-210.200 (PTE), F.A.C.; and PSD-FL-168, Specific Condition No. 3]

A.6. Emissions Unit Operating Rate Limitation After Testing. See Specific Condition **A.49**.
[Rule 62-297.310(2), F.A.C.]

A.7. Methods of Operation. Fuels. The only fuels allowed to be burned are coal, No. 2 fuel oil, natural gas, and propane. The fuel oil to be fired shall be “new oil” which means an oil which has been refined from crude oil and has not been used.
[Rule 62-213.410, F.A.C.; PSD-FL-168, Specific Conditions No. 2 and No. 14; and, amendment dated 7/16/92]

A.8. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year.
[Rule 62-210.200 (PTE), F.A.C.; and PSD-FL-168, Specific Condition No. 4.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting note: Unless otherwise specified, the averaging times for Specific Conditions **A.9** through **A.17** are based on the specified averaging time of the applicable test method.}

A.9. Visible Emissions. Visible emissions from each baghouse exhaust shall not exceed 10 percent opacity (6 minute average), except for one 6-minute period per hour of not more than 27 percent opacity.

[PSD-FL-168, Specific Condition No. 8; and, amendment clerked 4/13/98]

A.10. Compliance with standards in 40 CFR 60, other than opacity standards, shall be determined in accordance with performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.

[40 CFR 60.11(a)]

A.11. Opacity. The opacity standards set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.

[40 CFR 60.11(c)]

A.12. Based on the maximum permitted heat input of 3422 MMBtu/hr, the stack emissions shall not exceed any of the following limitations:

Pollutant	Emission Limitation		
	Basis lb/MMBtu	lb/hr	TPY
Sulfur dioxide	0.170*	582*	2549
Nitrogen oxides	0.170*	582*	2549
Particulate matter	0.018	61.6	270
PM ₁₀	0.018	61.6	270
Carbon monoxide	0.110	376*	1649
Volatile organic compounds	0.0036	12.32	54.0
Sulfuric acid mist	0.0004	1.45	6.51
Beryllium	0.0000027	0.0094	0.041
Mercury	0.0000114	0.039	0.17
Lead	0.0000187	0.064	0.280
Fluorides	0.0015	5.08	22.3
Arsenic	0.000051	0.18	0.77

*24 hour daily block average (midnight to midnight)

[PSD-FL-168, Specific Condition No. 5.]

A.13. Ammonia (NH₃). Slip from exhaust gases shall not exceed 50 ppmv.

[PSD-FL-168, Specific Condition No. 7.]

A.14. Sulfur Dioxide - Coal Only. No owner or operator subject to the provisions of 40 CFR 60, Subpart Da, shall cause to be discharged into the atmosphere from any affected facility which combusts solid fuel or solid-derived fuel any gases which contain sulfur dioxide in excess of 30 percent of the potential combustion concentration (70 percent reduction).

[40 CFR 60.43a(a)(2)]

A.15. Sulfur Dioxide - Liquid Fuel Only. No owner or operator subject to the provisions of 40 CFR 60, Subpart Da, shall cause to be discharged into the atmosphere from any affected facility which combusts liquid fuel any gases which contain sulfur dioxide in excess of 100 percent of

the potential combustion concentration (zero percent reduction), when emissions are less than 0.20 lb/MMBtu heat input.
[40 CFR 60.43a(b)(2)]

A.16. Compliance with a sulfur dioxide percent reduction requirements is determined on a 30-day rolling average basis.
[40 CFR 60.43a(g)]

A.17. When different fuels are combusted simultaneously, the applicable standard of sulfur dioxide is determined by proration using the following formula:

$$\%Ps = (10x + 30y)/100$$

- $\%Ps$ = the percentage of potential sulfur dioxide emission allowed.
- x = the percentage of total heat input derived from the combustion of liquid fuel
- y = the percentage of total heat input derived from the combustion of solid fuel

[40 CFR 60.43a(h)]

Excess Emissions

{Permitting note: The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of an NSPS, NESHAP, or Acid Rain program provision.}

A.18. Excess emissions resulting from startup, shutdown, or malfunction of any emissions unit shall be permitted provided (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

A.19. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

A.20. All fuel oil and coal shipments shall have a shipment analysis for sulfur content, ash content, and heating value. In the event continuous emission monitoring of sulfur dioxide is not performed, a daily analysis of coal sulfur content for the purpose of establishing the percentage reduction in potential sulfur emissions shall be made. Such determination shall be in accordance with the EPA reference Method 19. Records of all the analyses shall be kept for Department inspection for a minimum of 5 (five) years after the data are recorded.
[PSD-FL-168, Specific Condition No. 16.]

A.21. Determination of Process Variables.

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in

conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

A.22. Fuel consumption shall be continuously measured and recorded by fuel type.

[PSD-FL-168, Specific Condition No. 4.]

Compliance Provisions

A.23. The particulate matter emission standards under Specific Condition **A.12.** and the nitrogen oxide standards under Specific Condition **A.12.** apply at all times except during periods of startup, shutdown, or malfunction. The sulfur dioxide emission standards under Specific Conditions **A.12.**, **A.14.**, **A.15.**, and **A.17.** apply at all times except during periods of startup, shutdown, or when both emergency conditions exist and the procedures under 40 CFR 60.46a(d) are implemented (see Specific Condition **A.24.**).

[40 CFR 60.46a(c); and PSD-FL-168]

A.24. During emergency conditions in the principal company, an affected facility with a malfunctioning flue gas desulfurization system may be operated if sulfur dioxide emissions are minimized by:

- (1) Operating all operable flue gas desulfurization modules, and bringing back into operation any malfunctioned module as soon as repairs are completed,
- (2) Bypassing flue gases around only those flue gas desulfurization system modules that have been taken out of operation because they were incapable of any sulfur dioxide emission reduction or which would have suffered significant physical damage if they had remained in operation.

[40 CFR 60.46a(d)(1) & (2)]

A.25. Compliance with the sulfur dioxide emission limitations under Specific Condition **A.12.** and the nitrogen oxides emissions limitations under Specific Condition **A.12.** is based on a 24 hour daily block average (midnight to midnight). The percentage reduction requirements under 40 CFR 60.43a is based on the average emission rate for 30 successive boiler operating days. A separate performance test is completed at the end of each boiler operating day and a new 30-day percent reduction for sulfur dioxide is calculated to show compliance with the standards.

[40 CFR 60.46a(e); and PSD-FL-168, Specific Condition No. 5]

A.26. Compliance is determined by calculating the 24 hour daily block average (midnight to midnight), except for data obtained during startup, shutdown, or malfunction (NO_x only), or emergency conditions (SO₂ only). Compliance with the percentage reduction requirement for SO₂ is determined based on the average inlet and average outlet SO₂ emissions rates for the 30 successive boiler operating days.

[40 CFR 60.46a(g); and PSD-FL-168]

A.27. If the owner or operator has not obtained the minimum quantity of emission data as required under 40 CFR 60.47a, compliance of the affected facility with the emission requirements under 40 CFR 60.43a and 60.44a for the day on which the 30-day period ends may be determined by the Administrator following the applicable procedures in section 7 of Method 19.

[40 CFR 60.46a(h)]

Compliance Assurance Monitoring (CAM) Requirements

A.27.1. This emissions unit is subject to the CAM requirements contained in the attached Appendix CAM. Failure to adhere to the monitoring requirements specified does not necessarily indicate an exceedance of a specific emissions limitation; however, it may constitute good reason to require compliance testing pursuant to Rule 62-297.310(7)(b), F.A.C.

[40 CFR 64; and Rules 62-204.800 and 62-213.440(1)(b)1.a., F.A.C.]

Continuous Monitoring Requirements

A.27.2. Use of SO₂ CEMS For Continuous Compliance. Pursuant to 40 CFR 64.2(b)(1)(vi), the applicant has elected to use the existing certified SO₂ continuous emissions monitor for continuous compliance in order to be exempted from the Compliance Assurance Monitoring (CAM) requirements contained in 40 CFR 64.

[40 CFR 64.2(b)(vi); and Applicant Request.]

A.28. Stack emissions monitoring shall include a flue gas oxygen meter to continuously monitor a representative sample of the flue gas. The oxygen monitor shall be used with automatic feedback controls to continuously maintain air/fuel ratio parameters at an optimum.

[PSD-FL-168, Specific Condition No. 23.]

A.29. Opacity. The owner or operator of an affected facility shall install, calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring the opacity of emissions discharges to the atmosphere. If opacity interference due to water droplets exists in the stack (for example, from the use of an FGD system), the opacity is monitored upstream of the interference (at the inlet to the FGD system). If opacity interference is experienced at all locations (both at the inlet and outlet of the sulfur dioxide control system), alternate parameters indicative of the particulate matter control system's performance are monitored (subject to the approval of the Administrator).

[40 CFR 60.47a(a)]

A.30. Sulfur Dioxide. The owner or operator of an affected facility shall install, calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring sulfur dioxide emissions as follows:

(1) Sulfur dioxide emissions are monitored at both the inlet and outlet of the sulfur dioxide control device.

[40 CFR 60.47a(b)(1)]

A.31. Nitrogen Oxides. The owner or operator of an affected facility shall install, calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere.

[40 CFR 60.47a(c)(1)]

A.32. The owner or operator of an affected facility shall install, calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring the oxygen or carbon dioxide content of the flue gases at each location where sulfur dioxide or nitrogen oxides emissions are monitored.

[40 CFR 60.47a(d)]

A.33. The continuous monitoring systems are operated and data recorded during all periods of operation at the affected facility including periods of startup, shutdown, malfunction, or emergency conditions, except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments.

[40 CFR 60.47a(e)]

A.34. The owner or operator shall obtain emission data for at least 18 hours in at least 22 out of 30 successive boiler operating days. If this minimum data requirement cannot be met with a continuous monitoring system, the owner or operator shall supplement emission data with other monitoring systems approved by the Administrator or the reference methods and procedures as described in 40 CFR 60.47a(h).

[40 CFR 60.47a(f)]

A.35. The 1-hour averages required under 40 CFR 60.13(h) are expressed in ng/J (lb/million Btu) heat input and used to calculate the average emission rates under 40 CFR 60.46a. The 1-hour averages are calculated using the data points required under 40 CFR 60.13(b). At least two data points must be used to calculate the 1-hour averages.

[40 CFR 60.47a(g)]

A.36. When it becomes necessary to supplement continuous monitoring system data to meet the minimum data requirements in 40 CFR 60.47a(f), the owner or operator shall use the reference methods and procedures as specified in this paragraph. Acceptable alternative methods are given in 40 CFR 60.47a(j).

(1) Method 6 shall be used to determine the SO₂ concentration at the same location as the SO₂ monitor. Samples shall be taken at 60-minute intervals. The sampling time and sample volume for each sample shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Each sample represents a 1-hour average.

(2) Method 7 shall be used to determine the NO_x concentration at the same location as the NO_x monitor. Samples shall be taken at 30-minute intervals. The arithmetic average of two consecutive samples represents a 1-hour average.

(3) The emission rate correction factor, integrated bag sampling and analysis procedure of Method 3B shall be used to determine the O₂ or CO₂ concentration at the same location as the O₂ or CO₂ monitor. Samples shall be taken for at least 30 minutes in each hour. Each sample represents a 1-hour average.

(4) The procedures in Method 19 shall be used to compute each 1-hour average concentration in ng/J (lb/million Btu) heat input.

[40 CFR 60.47a(h)(1), (2), (3) & (4)]

A.37. The owner or operator shall use methods and procedures in this paragraph to conduct monitoring system performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d). Acceptable alternative methods and procedures are given in 40 CFR 60.47a(j).

(1) Methods 6, 7, and 3B, as applicable, shall be used to determine O₂, SO₂, and NO_x concentrations.

(2) SO₂ or NO_x (NO), as applicable, shall be used for preparing the calibration gas mixtures (in N₂, as applicable) under Performance Specification 2 of appendix B of 40 CFR 60.

(3) For affected facilities burning only fossil fuel, the span value for a continuous monitoring system for measuring opacity is between 60 and 80 percent and for a continuous monitoring system measuring nitrogen oxides firing solid fuel is 1,000 ppm.

(5) For affected facilities burning fossil fuel, alone or in combination with non-fossil fuel, the span value of the sulfur dioxide continuous monitoring system at the inlet to sulfur dioxide control device is 125 percent of the maximum estimated hourly potential emissions of the fuel fired, and the outlet of the sulfur dioxide control device is 50 percent of maximum estimated hourly potential emissions of the fuel fired.

[40 CFR 60.47a(i)(1), (2), (3), & (5)]

A.38. The owner or operator may use the following as alternatives to the reference methods and procedures specified in 40 CFR 60.47a.

(1) For Method 6, Method 6A or 6B (whenever Methods 6 and 3 or 3B data are used) or 6C may be used. Each Method 6B sample obtained over 24 hours represents 24 1-hour averages. If Method 6A or 6B is used under 40 CFR 60.47a(i), the conditions under 40 CFR 60.46(d)(1) apply (see Specific Condition **A.72.**); these conditions do not apply under 40 CFR 60.47a(h).

(2) For Method 7, Method 7A, 7C, 7D, or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time is 1 hour.

(3) For Method 3, Method 3A or 3B may be used if the sampling time is 1 hour.

(4) For Method 3B, Method 3A may be used.

[40 CFR 60.47a(j)]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.39. Performance tests shall be conducted under such conditions as the Department shall specify based on representative performance of the facility. The permittee shall make available to the Department such records as may be necessary to determine the conditions of the performance tests.

[PSD-FL-168, Specific Condition No. 20]

A.40. Compliance with emissions limitation standards shall be demonstrated using EPA methods, as contained in 40 CFR Part 60, or 40 CFR Part 61, or any other method approved by the Department and EPA.

[PSD-FL-168, Specific Condition No. 19]

A.41. Compliance with emission limitation standards shall be demonstrated using EPA methods as described in the table below:

For determination of	EPA Method
Selection of sample site and velocity traverses	1
Stack gas flow rate when converting concentrations to or from mass emissions limits	2
Gas analysis when needed for calculation of molecular weight of or percent O ₂	3, 3A, & 3B
Moisture content when converting stack velocity to dry volumetric flow rate for use in converting concentrations in dry gases to or from mass emission limits.	4
Particulate matter concentration and mass emissions	5
Sulfur dioxide	6, 6C, or 19
Nitrogen oxides	7E
Sulfuric Acid Mist	8
Visible emissions	9
Fugitive emissions from transfer points	22
Carbon monoxide	10
Lead	29
Fluorides	13A or 13B
Volatile organic compounds	18 and 25A
Mercury	29
Beryllium	29
Arsenic	29
Ammonia (NH ₃)	EPA conditional test method (CTM-027), or other methods approved by the Department.

[40 CFR 60.48a; and PSD-FL-168, Specific Condition No. 19.; and applicant request dated March 5, 2004.]

A.42. In conducting performance tests, the owner or operator shall use as reference methods and procedures the methods in appendix A of 40 CFR 60 or the methods and procedures as specified in 40 CFR 60.48a, except as provided in 40 CFR 60.8(b). 40 CFR 60.8(f) does not apply for SO₂ and NO_x. Acceptable alternative methods are given in 40 CFR 60.48a(e).

[40 CFR 60.48a(a)]

A.43. Particulate Matter. The owner or operator shall determine compliance with the particulate matter standard as follows

- (1) The dry basis F factor (O₂) procedures in Method 19 shall be used to compute the emission rate of particulate matter.
- (2) For the particulate matter concentration, Method 5 shall be used at affected facilities without wet FGD systems and Method 5B shall be used after wet FGD systems.
 - (i) The sampling time and sample volume for each run shall be at least 120 minutes and 1.70 dscm (60 dscf). The probe and filter holder heating system in the sampling train may be set to provide an average gas temperature of no greater than 160 ± 14 °C (320 ±

25 °F).

(ii) For each particulate run, the emission rate correction factor, integrated or grab sampling and analysis procedures of Method 3B shall be used to determine the O₂ concentration. The O₂ sample shall be obtained simultaneously with, and at the same transverse points as, the particulate run. If the particulate run has more than 12 transverse points, the O₂ transverse points may be reduced to 12 provided that Method 1 is used to locate the 12 O₂ transverse points. If the grab sampling procedure is used, the O₂ concentration for the run shall be the arithmetic mean of all the individual O₂ concentrations at each transverse point.

(3) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.
[40 CFR 60.48a(b)(1), (2) & (3)]

A.44. Sulfur Dioxide. The owner or operator shall determine compliance with the sulfur dioxide standards as follows:

(1) The percent of potential SO₂ emissions (%P_S) to the atmosphere shall be computed using the following equation:

$$\%P_S = [(100 - \%R_F)(100 - \%R_S)]/100$$

where:

%P_S = percent of potential SO₂ emissions, percent.
%R_F = percent reduction from fuel pretreatment, percent.
%R_S = percent reduction by SO₂ control system, percent.

(2) The procedures in Method 19 may be used to determine percent reduction (%R_F) of sulfur by such processes as fuel pretreatment (physical coal cleaning, hydrodesulfurization of fuel oil, etc.), coal pulverizers, and bottom and flyash interactions. This determination is optional.

(3) The procedures in Method 19 shall be used to determine the percent SO₂ reduction (%R_S) of any SO₂ control system. Alternatively, a combination of an "as fired" fuel monitor and emission rates measured after the control system, following the procedures in Method 19, may be used if the percent reduction is calculated using the average emission rate from the SO₂ control device and the average SO₂ input rate from the "as fired" fuel analysis for 30 consecutive boiler operating days.

(4) The appropriate procedures in Method 19 shall be used to determine the emission rate.

(5) The continuous monitoring system in 40 CFR 60.47a(b) and (d) shall be used to determine the concentrations of SO₂ and CO₂ or O₂.

[40 CFR 60.48a(c)(1), (2), (3), (4) & (5)]

A.45. Nitrogen Oxides. The owner or operator shall determine compliance with the NO_x standard as follows:

(1) The appropriate procedures in Method 19 shall be used to determine the emission rate of NO_x.

(2) The continuous monitoring system in 40 CFR 60.47a(c) and (d) shall be used to determine the concentrations of NO_x and CO₂ or O₂.

[40 CFR 60.48a(d)(1) & (2)]

A.46. The owner or operator may use the following as alternatives to the reference methods and procedures specified in 40 CFR 60.48a:

(1) For Method 5 or 5B, Method 17 may be used at facilities with or without wet FGD systems if the stack temperature at the sampling location does not exceed the average temperature of 160 °C (320 °F). Procedures 2.1 and 2.3 of Method 5B in 40 CFR 60, Appendix A may be used in Method 17 only if it is used after wet FGD systems. Method 17 shall not be used after wet FGD systems if the effluent is saturated or laden with water droplets.

(2) The F_c factor (CO_2) procedures in Method 19 may be used to compute the emission rate of particulate matter under the stipulations of 40 CFR 60.46(d)(1). The CO_2 shall be determined in the same manner as the O_2 concentration.

[40 CFR 60.48a(e)(1) & (2)]

A.47. Carbon Monoxide. Compliance shall be demonstrated using EPA Method 10 in accordance with Chapter 62-297, F.A.C.

[Rules 62-213.440 and 62-297.401, F.A.C.; and PSD-FL-168, Specific Condition No. 19]

A.48. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

A.49. Operating Rate During Testing. Testing of emissions shall be conducted with each emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

A.50. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

A.51. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

- a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.
- b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.
- c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1.

TABLE 297.310-1
 CALIBRATION SCHEDULE

ITEM	MINIMUM CALIBRATION FREQUENCY	REFERENCE INSTRUMENT	TOLERANCE
Liquid in glass thermometer	Annually	ASTM Hg in glass reference thermometer or equivalent, or thermometric points	+/-2%
Bimetallic thermometer	Quarterly	Calibration liquid in glass thermometer	5 degrees F
Thermocouple	Annually	ASTM Hg in glass reference thermometer, NBS calibrated reference and potentiometer	5 degrees F
Barometer	Monthly	Hg barometer or NOAA station	+/-1% scale
Pitot Tube	When required or when damaged	By construction or measurements in wind tunnel D greater than 16" and standard pitot tube	See EPA Method 2, Figures 2-2 and 2-3
Probe Nozzles	Before each test, or when nicked, dented, or corroded	Micrometer	+/-0.001" mean of the last three readings; maximum deviation between readings .004"
Dry gas meter and Orifice Meter	1. Full scale: when received, when 5% change observed, annually. 2. One point: Semiannually. 3. Check after each test series.	Spirometer or calibrated wet test or dry gas test meter Comparison check	2% 5%

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]

A.52. Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit. [Rule 62-297.310(6), F.A.C.]

A.53. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid fuel for more than 400 hours other than during startup.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and

c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply. [Rule 62-297.310(7), F.A.C.; and SIP approved.]

A.54. Stack tests for particulate matter, nitrogen oxides, sulfur dioxide, visible emissions, and carbon monoxide shall be performed *annually*.
[PSD-FL-168, Specific Condition No. 22.]

A.55. The permittee shall provide written notice to the Department's Southeast District Office thirty (30) days prior to the tests in order to provide the Department the opportunity to have an observer present.
[PSD-FL-168, Specific Condition No. 21.]

Recordkeeping and Reporting Requirements

A.56. For sulfur dioxide and nitrogen oxides the following information is reported to the Administrator for each 24-hour period.

- (1) Calendar date.
- (2) The average sulfur dioxide and nitrogen oxides emission rates (ng/J or lb/million Btu) for each 30 successive boiler operating days, ending with the last 30-day period in the quarter; reasons for non-compliance with the standards; and, description of corrective actions taken.
- (3) Percent reduction of the potential combustion concentration of sulfur dioxide for each 30 successive boiler operating days, ending with the last 30-day period in the quarter; reasons for non-compliance with the standard; and, description of corrective actions taken.
- (4) Identification of the boiler operating days for which pollutant or diluent data have not been obtained by an approved method for at least 18 hours of operation of the facility; justification for not obtaining sufficient data; and, description of corrective actions taken.
- (5) Identification of the times when emissions data have been excluded from the calculation of average emission rates because of startup, shutdown, malfunction (NO_x only), emergency conditions (SO₂ only), or other reasons, and justification for excluding data other than startup, shutdown, malfunction, or emergency conditions.
- (6) Identification of "F" factor used for calculations, method of determination, and type of fuel combusted.

- (7) Identification of the times when hourly averages have been obtained based on manual sampling methods.
- (8) Identification of the times when the pollutant concentration exceeded full span of the continuous monitoring system.
- (9) Description of any modifications to the continuous monitoring system which could affect the ability of the continuous monitoring system to comply with Performance Specifications 2 or 3.
[40 CFR 60.49a(b)(1), (2), (3), (4), (5), (6), (7), (8) & (9)]

A.57. If the required quantity of emission data as required by 40 CFR 60.47a is not obtained for any 30 successive boiler operating days, the following information obtained under the requirements of 40 CFR 60.46a(h) is reported to the Administrator for that 30-day period:

- (1) The number of hourly averages available for outlet emission rates (n_o) and inlet emission rates (n_i) as applicable.
- (2) The standard deviation of hourly averages for outlet emission rates (s_o) and inlet emission rates (s_i) as applicable.
- (3) The lower confidence limit for the mean outlet emission rate (E_o^*) and the upper confidence limit for the mean inlet emission rate (E_i^*) as applicable.
- (4) The applicable potential combustion concentration.
- (5) The ratio of the upper confidence limit for the mean outlet emission rate (E_o^*) and the allowable emission rate (E_{std}) as applicable.
[40 CFR 60.49a(c)(1), (2), (3), (4) & (5)]

A.58. If any standards under 40 CFR 60.43a are exceeded during emergency conditions because of control system malfunction, the owner or operator of the affected facility shall submit a signed statement:

- (1) Indicating if emergency conditions existed and requirements under 40 CFR 60.46a(d) were met during each period, and
- (2) Listing the following information:
 - (i) Time periods the emergency condition existed;
 - (ii) Electrical output and demand on the owner or operator's electric utility system and the affected facility;
 - (iii) Amount of power purchased from interconnected neighboring utility companies during the emergency period;
 - (iv) Percent reduction in emissions achieved;
 - (v) Atmospheric emission rate (ng/J) of the pollutant discharged; and
 - (vi) Actions taken to correct control system malfunction.

[40 CFR 60.49a(d)(1) & (2)]

A.59. If fuel pretreatment credit toward the sulfur dioxide emission standard under 40 CFR 60.43a is claimed, the owner or operator of the affected facility shall submit a signed statement:

- (1) Indicating what percentage cleaning credit was taken for the calendar quarter, and whether the credit was determined in accordance with the provisions of 40 CFR 60.48a and Method 19 (appendix A); and
- (2) Listing the quantity, heat content, and date each pretreated fuel shipment was received during the previous quarter; the name and location of the pretreatment facility; and the total quantity and total heat content of all fuels received at the affected facility during the previous quarter.

[40 CFR 60.49a(e)(1) & (2)]

A.60. For any periods for which opacity, sulfur dioxide or nitrogen oxides emissions data are not available, the owner or operator of the affected facility shall submit a signed statement indicating if any changes were made in operation of the emission control system during the period of data unavailability. Operations of the control system and the affected facility during periods of data unavailability are to be compared with operation of the control system and the affected facility before and following the period of data unavailability.

[40 CFR 60.49a(f)]

A.61. The owner or operator of the affected facility shall submit a signed statement indicating whether:

- (1) The required continuous monitoring system calibration, span, and drift checks or other periodic audits have or have not been performed as specified.
- (2) The data used to show compliance was or was not obtained in accordance with approved methods and procedures of this part and is representative of plant performance.
- (3) The minimum data requirements have or have not been met; or, the minimum data requirements have not been met for errors that were unavoidable.
- (4) Compliance with the standards has or has not been achieved during the reporting period.

[40 CFR 60.49a(g)(1), (2), (3) & (4)]

A.62. For the purposes of the reports required under 40 CFR 60.7, periods of excess emissions are defined as all 6-minute periods during which the average opacity exceeds the applicable opacity standards under Specific Condition A.9. Opacity levels in excess of the applicable opacity standard and the date of such excesses are to be submitted to the Administrator each calendar quarter.

[40 CFR 60.49a(h); and PSD-FL-168]

A.63. The owner or operator of an affected facility shall submit the written reports required under 40 CFR 60.49a and 40 CFR 60, Subpart A, to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.

[40 CFR 60.49a(i)]

A.64. The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative.

[40 CFR 60.7(b)]

A.65. The permittee shall submit a quarterly report to the Department's Southeast District Office documenting a 12 month rolling average capacity factor. This factor shall be calculated by dividing the unit's megawatt hours output of generation by the product of the official megawatt rating of the unit times the number of hours in the 12 month period.

[PSD-FL-168, Specific Condition No. 1]

A.66. Stack monitoring, fuel usage, and fuel analysis data shall be reported to the Department's Southeast District Office on a quarterly basis.

[PSD-FL-168, Specific Condition No. 28]

A.67. The owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least **5 (five)** years following the date of such measurements, maintenance, reports, and records. [40 CFR 60.7(f); and Rule 62-213.440(1)(b)2.b., F.A.C.]

A.68. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]

A.69. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.

16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.

17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.

18. All measured and calculated data required to be determined by each applicable test procedure for each run.

19. The detailed calculations for one run that relate the collected data to the calculated emission rate.

20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.

21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

A.70. [Reserved.]

Miscellaneous

A.71. The permittee shall comply with the requirements contained in Appendix 40 CFR 60, Subpart A, attached to this permit.

[Rule 62-204.800(8)(d), F.A.C.]

A.72. The owner or operator may use the following as alternatives to the reference methods and procedures in 40 CFR 60.46 or in other sections as specified:

(1) The emission rate (E) of particulate matter, SO₂ and NO_x may be determined by using the F_c factor, provided that the following procedure is used:

(i) The emission rate (E) shall be computed using the following equation:

$$E = C F_c (100 / \% \text{ CO}_2)$$

where:

E = emission rate of pollutant, ng/J (lb/million Btu).

C = concentration of pollutant, ng/dscm (lb/dscf).

% CO₂ = carbon dioxide concentration, percent dry basis.

F_c = factor as determined in appropriate sections of Method 19.

(ii) If and only if the average F_c factor in Method 19 is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B shall be used to determine the O₂ and CO₂ concentration according to the procedures in 40 CFR 60.46(b) (2)(ii), (4)(ii), or (5)(ii). Then if F_o (average of three runs), as calculated from the equation in Method 3B, is more than ± 3 percent than the average F_o value, as determined from the average values of F_d and F_c in Method 19, i.e., $F_{oa} = 0.209 (F_{da} / F_{ca})$, then the following procedure shall be followed:

(A) When F_o is less than $0.97 F_{oa}$, then E shall be increased by that proportion under $0.97 F_{oa}$, e.g., if F_o is $0.95 F_{oa}$, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When F_o is less than $0.97 F_{oa}$ and when the average difference (\bar{d}) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under $0.97 F_{oa}$, e.g., if F_o is $0.95 F_{oa}$, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When F_o is greater than $1.03 F_{oa}$ and when \bar{d} is positive, then E shall be decreased by that proportion over $1.03 F_{oa}$, e.g., if F_o is $1.05 F_{oa}$, E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

[40 CFR 60.46(d)(1) and 40 CFR 60.47a(j)(1)]

A.73. In the event of a prolonged (thirty days or more) equipment malfunction or shutdown of air pollution control equipment, operation shall be allowed to resume and continue to take place under appropriate Department Order, provided that the permittee demonstrates such operation will be in compliance with all applicable ambient air quality standards and PSD increments. During such malfunction or shutdown, operation of the facility shall comply with all other requirements of this permit and all applicable state and federal emission standards not affected by the malfunction or shutdown which is the subject of the Order. Operational stoppages exceeding two hours for air pollution control systems shall be reported to the Department's Southeast District Office. Operational malfunctions which do not stop operation but may prevent compliance with emission limitations shall also be reported to the Department's Southeast District Office.

[PSD-FL-168, Specific Condition No. 31]

Subsection B. This section addresses the following emissions unit(s).

E.U. ID No.	Brief Description
	Temporary Package Boiler (unregulated)

The permittee may install and operate an unregulated temporary package boiler in the event that the pulverized coal (PC) boiler and at least one Auxiliary Boiler are inoperable.

The following specific conditions apply to the Temporary Package Boiler:

B.1. The temporary package boiler shall be operated such that:

- a. No visible emissions (5 percent opacity) are observed, except that visible emissions not exceeding 20 percent opacity are allowed for up to three minutes in any one-hour period.
- b. No objectionable odors are observed.
- c. Manufacturers' guidelines are followed.

[Department Specific Exemption, dated March 31, 2003, Condition 1.]

B.2. The package boiler shall fire natural gas or propane only, and throughput shall be measured and recorded. No more than 150 million standard cubic feet (combined) shall be fired annually and operating hours plus fuel usage shall be tracked, separately identified and attributed to the annual throughput of the auxiliary boilers.

[Department Specific Exemption, dated March 31, 2003, Condition 2.]

B.3. Indiantown Cogeneration, L.P., will notify the Department prior to the delivery of the temporary boiler and upon its removal. The notifications shall include proof that all other permit conditions identified herein can be or have been met.

[Department Specific Exemption, dated March 31, 2003, Condition 3.]

B.4. Under no circumstances shall the temporary package boiler be on-site for more than 90 calendar days, nor operated for more than 60 calendar days during any calendar year.

[Department Specific Exemption, dated March 31, 2003, Condition 4.]

B.5. The package boiler shall meet the ASME and Pressure Vessel Code Accreditation and utilize an ASME Code Symbol Stamp.

[Department Specific Exemption, dated March 31, 2003, Condition 5.]

B.6. The package boiler shall be guaranteed to be capable of meeting a NO_x emission limit of 0.15 lb/MMBtu.

[Department Specific Exemption, dated March 31, 2003, Condition 6.]

B.7. The package boiler shall not be operated at the same time as both auxiliary boilers.

[Department Specific Exemption, dated March 31, 2003, Condition 7.]

B.8. The package boiler shall be disconnected and removed from the plant site within 15 days of the date that either the main PC boiler or both auxiliary boilers become operable.
[Department Specific Exemption, dated March 31, 2003, Condition 8.]

Subsection C. This section addresses the following emissions unit.

E.U. ID No.	Brief Description
-004	Coal Handling System

The coal handling system includes transport, crushing, and storage equipment, and supports the operation of the pulverized coal main boiler. Particulate matter (PM) emissions are controlled by (a) the use of fabric filter baghouses on the unloading building, storage area, crusher, and the top of the silo, (b) enclosed conveyors and conveyor transfer points, and (c) wet suppression on the coal railcar unloading operation, drop onto pile in the coal storage building, and outdoor coal pile as needed. The overall maximum throughput rate is approximately 1,100 tons per hour. Because the potential to emit PM is below the major source threshold, this emissions unit is not subject to CAM.

{Permitting notes: The emissions unit is regulated under NSPS - 40 CFR 60, Subpart Y, Standards of Performance for Coal Preparation Plants, adopted and incorporated by reference in Rule 62-204.800(8), F.A.C.; Prevention of Significant Deterioration (PSD): PSD-FL-168; Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT).}

Essential Potential to Emit (PTE) Parameters

C.1. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year.
[Rule 62-210.200(PTE), F.A.C.; and PSD-FL-168]

C.2. Emissions Unit Operating Rate Limitation After Testing. See Specific Condition C.13.
[Rule 62-297.310(2), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting note: Unless otherwise specified, the averaging times for Specific Conditions C.3. through C.6. are based on the specified averaging time of the applicable test method.}

C.3. Visible Emissions. Visible emissions from the coal handling system baghouses shall not exceed 10% opacity, six-minute average.
[PSD-FL-168, Specific Condition No. 8.]

C.4. Particulate Matter. Particulate matter emissions from bag filter exhausts from the coal handling system shall be limited to 0.010 grains per actual cubic foot.
[PSD-FL-168, Specific Condition No. 11.]

C.5. Visible Emissions. A visible emission reading of 5% opacity or less may be used to establish compliance with the emission limit in Specific Condition C.4. A visible emission reading greater than 5% opacity will not create a presumption that the 0.010 grains per actual cubic foot emission limit is being violated. However, a visible emission reading greater than 5% opacity will require the permittee to perform a stack test. Emissions shall not be visible more than two minutes in any fifteen minute period.
[PSD-FL-168, Specific Conditions No. 11. and 12.]

C.6. Fugitive Emissions. Outdoor coal storage piles shall be shaped, compacted, and oriented to minimize wind erosion. Water sprays or chemical wetting agents and stabilizers shall be applied to uncovered storage piles, roads, handling equipment, etc., during dry periods and as necessary to all facilities to maintain an opacity of less than or equal to 5 percent. When adding, moving, or removing coal from the coal pile an opacity of 20% is allowed.
[PSD-FL-168, Specific Condition No. 10.; and 0850102-012-AC.]

Excess Emissions

C.7. Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

C.8. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

C.9. Determination of Process Variables.

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

C.10. Visible Emissions. EPA Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity compliance pursuant to Chapter 62-297, F.A.C., and 40 CFR 60, Appendix A. [40 CFR 60.254(b)(2); and PSD-FL-168, Specific Condition No. 19]

C.11. Particulate Matter. EPA Method 5 shall be used to determine the particulate matter concentration. The sampling time and the sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). Sampling shall begin no less than 30 minutes after startup and shall terminate before shutdown procedures begin. [PSD-FL-168, Specific Condition No. 19.]

C.12. Fugitive Emissions. Compliance with fugitive emissions limitations from all transfer points will be determined by EPA/DEP reference Method 22 and opacity Method 9. [PSD-FL-168, Specific Condition No. 12.]

C.13. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rules 62-297.310(2) & (2)(b), F.A.C.]

C.14. Applicable Test Procedures.

(a) Required Sampling Time.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

[Rule 62-297.310(4)(a)2.c., F.A.C.]

C.15. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not

require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate;

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.
[Rule 62-297.310(7), F.A.C.; and SIP approved]

Recordkeeping and Reporting Requirements

C.16. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

C.17. Verification and recording of Specific Condition C.4 and C.5 requirements for particulate matter emissions shall be done at least annually.

[PSD-FL-168, Specific Condition No. 11.]

C.18. Test Reports

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

[Rule 62-297.310(8), F.A.C.]

Miscellaneous Requirements.

C.19. The permittee shall comply with the requirements contained in Appendix 40 CFR 60, Subpart A, attached to this permit.
[Rule 62-204.800(8)(d), F.A.C.]

Subsection D. This section addresses the following emissions unit.

E.U. ID No.	Brief Description
-005	Ash Handling System

The ash handling system is comprised of several conveying and storage units. Ash from the PC boiler is processed and loaded into trucks and railcars. Overall maximum throughput rate is 250 tons per hour. The fly ash handling system, including transfer and silo storage (including a pneumatic system exhaust), is vented through fabric filters. The system is totally enclosed, and includes a separator on the silo prior to the fabric filter baghouse. A pug mill has been added to the ash handling system. The pug mill mixes water with the ash before the ash is transferred to truck or railcar for shipment offsite. The pug mill installation does not affect the particulate matter (PM) emission location, rate, or exhaust parameters. Because the potential to emit PM is below the major source threshold, this emissions unit is not subject to CAM. [PSD-FL-168, Specific Condition No. 10.]

{Permitting notes: This emissions unit is regulated under Rule 62-210.300, F.A.C., Permits Required; Prevention of Significant Deterioration (PSD): PSD-FL-168; Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT).}

The following specific conditions apply:

Essential Potential to Emit (PTE) Parameters

D.1. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200(PTE), F.A.C; and PSD-FL-168]

D.2. Emissions Unit Operating Rate Limitation After Testing. See Specific Condition **D.12.** [Rule 62-297.310(2), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting note: Unless otherwise specified, the averaging times for Specific Conditions **D.3.** through **D.5.** are based on the specified averaging time of the applicable test method.}

D.3. Visible Emissions. Visible emissions from the ash handling baghouse shall not exceed 5% opacity. [PSD-FL-168, Specific Condition No. 8]

D.4. Particulate Matter. Particulate matter emissions from bag filter exhausts from the ash handling system shall be limited to 0.010 grains per actual cubic foot. [PSD-FL-168, Specific Condition No. 11]

D.5. Visible Emissions. A visible emission reading of 5% opacity or less may be used to establish compliance with the emission limit in Specific Condition **D.4.** A visible emission reading greater than 5% opacity will not create a presumption that the 0.010 grains per actual cubic foot emission limit is being violated. However, a visible emission reading greater than 5% opacity will require the permittee to perform a stack test. Emissions shall not be visible more than two minutes in any fifteen minute period.
[PSD-FL-168, Specific Conditions No. 11 and 12]

Excess Emissions

D.6. Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

D.7. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

D.8. Determination of Process Variables.

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

D.9. Visible Emissions. EPA Method 9 shall be used to determine opacity compliance pursuant to Chapter 62-297, F.A.C.

[PSD-FL-168, Specific Condition No. 19.]

D.10. Visible Emissions. Emissions shall not be visible more than two minutes in any fifteen minute period. Compliance with fugitive emissions limitations from all transfer points will be determined by EPA/DEP reference Method 22 and opacity Method 9.
[PSD-FL-168, Specific Conditions No. 12 and 19]

D.11. Particulate Matter. EPA Method 5 shall be used to determine compliance with the particulate matter emissions limitation specified in Specific Condition **D.4**. At least three one hour runs are to be conducted simultaneously with opacity testing for the ash handling building baghouse.
[PSD-FL-168, Specific Condition No. 19]

D.12. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.
[Rules 62-297.310(2) & (2)(b), F.A.C.]

D.13. Applicable Test Procedures.

(a) Required Sampling Time.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

[Rule 62-297.310(4)(a)2.c., F.A.C.]

D.14. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate;

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; and, SIP approved]

Recordkeeping and Reporting Requirements

D.15. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

D.16. Verification and recording of Specific Condition D.4 requirements for particulate matter emissions shall be done at least annually.

[PSD-FL-168, Specific Condition No. 11]

D.17. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

[Rule 62-297.310(8), F.A.C.]

Subsection E. This section addresses the following emissions unit.

E.U. ID No.	Brief Description
-006	Lime Handling System

The lime handling system is comprised of different conveying and storage units. Lime arrives at the facility in powdered form. Lime is slaked into a slurry for use in the PC boiler spray dryer absorber. The lime silo has a bin vent fabric filter baghouse. The lime handling system is enclosed to the extent practical. The overall capacity is 25 tons per hour. Because the potential to emit PM is below the major source threshold, this emissions unit is not subject to CAM. {Permitting notes: This emissions unit is regulated under Rule 62-210.300, F.A.C., Permits Required; Prevention of Significant Deterioration (PSD): PSD-FL-168; Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT).}

The following specific conditions apply:

General

E.1. The lime handling system, including the lime silo, shall be maintained at a negative pressure while operating, and the exhaust vented to a control system.
[PSD-FL-168, Specific Condition No. 10.]

Essential Potential to Emit (PTE) Parameters

E.2. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year.
[Rule 62-210.200(PTE), PSD-FL-168]

E.3. Emissions Unit Operating Rate Limitation After Testing. See Specific Condition **E.13**.
[Rule 62-297.310(2), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting note: Unless otherwise specified, the averaging times for Specific Conditions **E.4** through **E.6** are based on the specified averaging time of the applicable test method.}

E.4. Visible Emissions. Visible emissions from the lime handling system baghouse shall not exceed 5% opacity.
[PSD-FL-168, Specific Condition No. 8.]

E.5. Particulate Matter. Particulate matter emissions from bag filter exhausts from the lime handling system shall be limited to 0.010 grains per actual cubic foot.
[PSD-FL-168, Specific Condition No. 11.]

E.6. Visible Emissions. A visible emission reading of 5% opacity or less may be used to establish compliance with the emission limit in Specific Condition **E.5**. A visible emission reading greater than 5% opacity will not create a presumption that the 0.010 grains per actual cubic foot emission limit is being violated. However, a visible emission reading greater than 5% opacity will require the permittee to perform a stack test.
[PSD-FL-168, Specific Condition No. 11.]

Excess Emissions

E.7. Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

E.8. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

E.9. Determination of Process Variables.

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

E.10. Visible Emissions. EPA Method 9 shall be used to determine opacity compliance pursuant to Chapter 62-297, F.A.C.
[PSD-FL-168, Specific Condition No. 19.]

Indiantown Cogeneration Plant

E.11. Opacity. Tests must be conducted with at least one lime vehicle unloading into the lime silo, from start to finish. Emissions shall not be visible more than two minutes in any fifteen minute period. Compliance with fugitive emissions limitations from all transfer points will be determined by EPA/DEP reference Method 22 and opacity Method 9.

[PSD-FL-168, Specific Conditions No. 12. and 19.]

E.12. Particulate Matter. EPA Method 5 shall be used to determine compliance with the particulate matter emissions limitation specified in Specific Condition **E.5.**

[PSD-FL-168, Specific Condition No. 19.]

E.13. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

E.14. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) **General Compliance Testing.**

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate;

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) **Special Compliance Tests.** When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.
[Rule 62-297.310(7), F.A.C.; and SIP approved.]

Recordkeeping and Reporting Requirements

E.15. Verification and recording of Specific Condition **E.5** requirements for particulate matter emissions shall be done at least annually.
[PSD-FL-168, Specific Condition No. 11.]

E.16. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.
[Rule 62-210.700(6), F.A.C.]

E.17. Test Reports.

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- (b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.
[Rule 62-297.310(8), F.A.C.]

Subsection F. This section addresses the following emissions unit.

E.U. ID No.	Brief Description
-007	(2) Victory Energy Model 23M Keystone packaged water-tube steam boilers with a combined maximum rated capacity of 350 MMBtu/hr when firing natural gas and 341 MMBtu/hr when firing propane.

{Permitting notes: These emissions units are regulated under Rule 62-210.300, F.A.C., Permits Required and NSPS-40 CFR 60, Subpart Db, Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units, adopted and incorporated by reference in Rule 62-204.800(8), F.A.C.; and Rule 62-296.406(1), F.A.C., Fossil Fuel Steam Generators with less than 250 Million Btu per hour Heat Input.}

Because these emissions units have no add-on control devices, they are not subject to compliance assurance monitoring (CAM).

The following specific conditions apply to the Auxiliary Boilers listed above:

General

F.1. Definitions. For the purposes of Rule 62-204.800(8), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.
[40 CFR 60.2; and Rule 62-204.800(8)(a), F.A.C.]

APPLICABLE STANDARDS AND REGULATIONS

F.2. NSPS Requirements. The emission unit shall comply with all applicable requirements of 40 CFR 60, adopted by reference in Rule 62-204.800(8)(b), F.A.C.

(a) Subpart A, General Provisions, including:

- 40 CFR 60.7, Notification and Record Keeping
- 40 CFR 60.8, Performance Tests
- 40 CFR 60.11, Compliance with Standards and Maintenance Requirements
- 40 CFR 60.12, Circumvention
- 40 CFR 60.13, Monitoring Requirements
- 40 CFR 60.19, General Notification and Reporting Requirements

(b) Subpart Db--Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units:

The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 MW (100 MMBtu/hour).

F.3. NESHAP Requirements. The auxiliary boilers shall comply with all applicable requirements of 40 CFR 63, Subpart DDDDD.

PERFORMANCE RESTRICTIONS

F.4. Auxiliary Boilers. The permittee is authorized to tune, operate and maintain two identically sized gas-fired package boilers (Victory Energy Model 23M Keystone).
[0850102-008-AC, Specific Condition 3.]

F.5. Permitted Capacity. The combined heat input to the identically sized auxiliary boilers shall not exceed 350 MMBtu per hour while firing natural gas, or 341 MMBtu per hour while firing propane.
[Rule 62-210.200, F.A.C. (Definition - PTE); and 0850102-008-AC, Specific Condition 4.]

F.6. Allowable Fuels. The identically sized auxiliary boilers shall be fired solely with pipeline-quality natural gas or liquid petroleum gas, as defined by the American Society for Testing and Materials in ASTM D1835-03a, "Standard Specification for Liquid Petroleum Gases".
[Rule 62-210.200, F.A.C. (Definition - PTE); and 0850102-008-AC, Specific Condition 5.]

F.7. Hours of Operation. The combined operation of the auxiliary boilers shall not exceed 5,000 hours during any consecutive 12-month period. The permittee shall calibrate, operate and maintain a monitoring system to measure and accumulate the amount of natural gas as well as propane fired and the hours of operation for each auxiliary boiler.
[Rule 62-210.200, F.A.C. (Definitions - PTE), Rule 62-212.400 (2)(g), F.A.C. (PSD Avoidance); and 0850102-008-AC, Specific Condition 6.]

F.7.1. Emissions Unit Operating Rate Limitation After Testing. See Specific Condition **F.34**.
[Rule 62-297.310(2), F.A.C.]

EMISSIONS CONTROLS

F.8. Air Pollution Control Equipment. Each boiler shall be fitted with Low NO_x burners and Flue Gas Recirculation (FGR) so as to ensure that NO_x emissions do not exceed 0.040 lb/MMBtu.
[Rule 62-212.400(2)(g), F.A.C.; PSD avoidance; and 0850102-008-AC, Specific Condition 9.]

F.9. Circumvention. The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly.
[Rule 62-210.650, F.A.C.; and 0850102-008-AC, Specific Condition 10.]

EMISSIONS LIMITATIONS AND STANDARDS

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting note: Unless otherwise specified, the averaging times for Specific Conditions **F.10** through **F.14**, are based on the specified averaging time of the applicable test method.}

F.10. Summary. The following table summarizes the emissions standards specified in this permit. Although these limits were not determined by BACT, they (along with other limitations described herein) form the basis for the Department's determination that PSD does not apply.

Pollutant	Emission limit	Annual Emissions (based upon a combined 5,000 hrs/yr)
NO _x	0.040 lb/MMBtu	35 TPY
CO	0.040 lb/MMBtu	35 TPY
VOC	0.70 lb/hr	1.8 TPY
SO ₂	2.1 lb/hr	5.3 TPY
PM ₁₀	1.4 lb/hr	3.5 TPY

[0850102-008-AC, Specific Condition 11.]

F.11. Carbon Monoxide (CO). After an initial demonstration that the manufacturer's guarantee (0.04 lb/MMBtu) can be met, CO emissions shall not exceed 400 ppm by volume corrected to 3 percent oxygen (30-day rolling average). Additionally, annual emissions of CO from this emission unit shall not exceed 35 TPY, based upon a 12-month rolling total.

The permittee shall demonstrate compliance with this standard by conducting performance tests and emissions monitoring in accordance with EPA Method 10 and the CEMS requirement of this permit. Method 10 testing is based on the average of three one-hour tests or other appropriate duration as approved in a testing protocol. Annual RATA testing may be utilized to satisfy the CO testing requirement, per Specific Conditions **F.18.** and **F.20.**, below.

[40 CFR 63, Subpart DDDDD; and 0850102-008-AC, Specific Condition 12.]

F.12. Nitrogen Oxides (NO_x). NO_x emissions from this emission unit shall not exceed 0.040 lb/MMBtu based upon a 30-day rolling average. Additionally, annual emissions of NO_x from this emission unit shall not exceed 35 TPY, based upon a 12-month rolling total.

The permittee shall demonstrate compliance with this standard by conducting performance tests and emissions monitoring in accordance with EPA Method 7 or 7E and the CEMS requirement of this permit. Method 7 or 7E testing is based on the average of three one-hour tests or other appropriate duration as approved in a testing protocol. Annual RATA testing may be utilized to satisfy the NO_x testing requirement, per Specific Conditions **F.18.** and **F.20.**, below.

[Rule 62-212.400, F.A.C. (PSD avoidance); and 0850102-008-AC, Specific Condition 13.]

F.13. Particulate Matter (PM/PM₁₀), Sulfuric Acid Mist (SAM) and Sulfur Dioxides (SO₂)

(a) **Fuel Specifications.** Emissions of PM, PM₁₀, SAM, and SO₂ shall be limited by the sole use of pipeline-quality natural gas and commercial propane meeting GPA Liquefied Petroleum Gas Specifications. The permittee shall demonstrate compliance with the sulfur limits of each fuel by maintaining the records specified by this permit. The fuel specification is a work practice standard established as a means of complying with the small Boiler BACT for PM and SO₂ under Rule 62-296.406, F.A.C. and as a synthetic minor limit for SAM/SO₂ emissions [Rule 62-4.070(3), F.A.C., Rule 62-212.400(2)(g), F.A.C. (PSD Avoidance)].

(b) **General Visible Emissions Standard.** Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer, or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the

density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20% opacity). The test method for visible emissions shall be EPA Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C. Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C.

[Rule 62-296.320(4)(b)1, F.A.C.; and 0850102-008-AC, Specific Condition 14.]

F.14. Volatile Organic Compounds (VOC). VOC emissions from this emission unit shall exceed neither 0.70 lb/hr nor 1.8 TPY, based upon a 12-month rolling total. The permittee shall demonstrate compliance with these standards by conducting an initial test in accordance with EPA Method 25A and the performance testing requirements of this permit. Testing is based on the average of three one-hour tests or other appropriate duration as approved in a testing protocol. Thereafter, compliance with the CO limits established in this permit shall be sufficient to demonstrate PSD avoidance and compliance with the 12-month rolling total VOC emission limit.

[Rule 62-212.400, F.A.C., Rule 62-212.400(2)(g), F.A.C. (PSD avoidance); and 0850102-008-AC, Specific Condition 15.]

EXCESS EMISSIONS

{Permitting note: The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of an NSPS, NESHAP, or Acid Rain program provision.}

F.15. Excess Emissions Prohibited. Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. These emissions shall be included in the calculation of the 12-month rolling and 30-day rolling averages to demonstrate compliance with the continuous emissions standards except as provided within this permit.

[Rule 62-210.700(4), F.A.C.; and 0850102-008-AC, Specific Condition 16.]

F.16. Excess Emissions Allowed. Providing the permittee adheres to best operational practices to minimize the amount and duration of excess emissions, the following conditions shall apply:

- (a) During startup and shutdown, visible emissions excluding water vapor shall not exceed 20% opacity for up to 2 hours in any 24-hour period. [Design; Rule 62-210.700(1) and (5), F.A.C.]
- (b) During all startups, shutdowns, and malfunctions, the continuous emissions monitor (CEM) shall monitor and record emissions. For the purpose of complying with the CO standard as set forth in the applicable NESHAP, data averaging and the exclusion of CEMS data shall comply with the applicable portions of 40 CFR 63 Subpart DDDDD. For the purpose of ensuring compliance with the NO_x standard as set forth in the applicable NSPS, data averaging and the exclusion of CEMS data shall comply with the applicable portions of 40 CFR 60 Subpart Db. For the purpose of ensuring the avoidance of PSD and resulting BACT Standards for NO_x and CO, no data may be excluded from the calculation of TPY emissions. In case of malfunctions, the permittee shall notify the Compliance Authorities within one working day. A full written report on the malfunctions shall be submitted in a quarterly report.

[Rules 62-210.700(1), (5), and 62-4.130, F.A.C.; and 0850102-008-AC, Specific Condition 17.]

EMISSIONS PERFORMANCE TESTING

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

F.17. Sampling Facilities. The permittee shall design the stack to accommodate adequate testing and sampling locations in order to determine compliance with the applicable emission limits specified by this permit. Permanent stack sampling facilities shall be installed in accordance with Rule 62-297.310(6), F.A.C.

[Rules 62-4.070 and 62-204.800, F.A.C., 40 CFR 60.40a(b); and 0850102-008-AC, Specific Condition 18.]

F.18. Performance Test Methods. Annual compliance tests (see exception for VOC, below) shall be performed in accordance with the following reference methods as described in 40 CFR 60, Appendix A, and adopted by reference in Chapter 62-204.800, F.A.C.

- (a) EPA Method 9 - Visual Determination of the Opacity of Emissions from Stationary Sources;
- (b) EPA Method 10 - Determination of Carbon Monoxide Emissions from Stationary Sources;
- (c) EPA Method 7 or 7E - Determination of Oxides of Nitrogen Oxide Emissions from Stationary Sources; and
- (d) EPA Method 25A - Determination of Volatile Organic Concentrations (initial test only).

Annual RATA testing at 100% output may be utilized to satisfy the above annual requirements for CO and NO_x tests. No other test methods may be used for compliance testing unless prior DEP approval is received, in writing, from the DEP Emissions Monitoring Section Administrator in accordance with an alternate sampling procedure specified in Rule 62-297.620, F.A.C. [0850102-008-AC, Specific Condition 19.]

F.19. Test Notification. The permittee shall notify the Compliance Authority in writing at least 15 days prior to any required tests.

[40 CFR 60.7, 40 CFR 60.8 and Rule 62-297.310(7)(a)9., F.A.C.; and 0850102-008-AC, Specific Condition 20.]

F.20. Annual Performance Tests. To demonstrate compliance with the emission standards specified in this permit, the permittee shall conduct annual performance tests for CO, NO_x and visible emissions from the emission unit. If conducted at permitted capacity, CO and NO_x emissions data collected during the required annual CO and NO_x continuous monitor RATA may be substituted for the required annual performance test. Tests required on an annual basis shall be conducted at least once during each federal fiscal year (October 1st to September 30th).

[Rule 62-297.310(7)(a)4., F.A.C.; and 0850102-008-AC, Specific Condition 22.]

F.21. Tests Prior to Permit Renewal. Prior to renewing the air operation permit, the permittee shall conduct performance tests for CO, NO_x, VOC, and visible emissions from the emission unit. These tests shall be conducted within the 12-month period prior to renewing the air operation permit. For pollutants that are required to be tested annually, the permittee may submit the most recent annual compliance test to satisfy the requirements of this provision.

[Rule 62-297.310(7)(a)3., F.A.C.; and 0850102-008-AC, Specific Condition 23.]

F.22. Tests After Substantial Modifications. All performance tests required for initial startup shall also be conducted after any substantial modification and appropriate shakedown period of air pollution control equipment. Shakedown periods shall not exceed 100 days after re-starting the emission unit.

[Rule 62-297.310(7)(a)4., F.A.C.; and 0850102-008-AC, Specific Condition 24.]

F.23. Calculation of Emission Rate. For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.; and 0850102-008-AC, Specific Condition 25.]

F.24. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. [Rule 62-297.310(4)(a)1., F.A.C.]
2. The minimum observation period for a visible emissions compliance test shall be sixty (60) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur. [Rule 62-297.310(4)(a)2., F.A.C.]

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet. [Rule 62-297.310(4)(b), F.A.C.]

(c) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C. [Rule 62-297.310(4)(d), F.A.C.]

[0850102-008-AC, Specific Condition 26.]

F.25. Determination of Process Variables.

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards. [Rule 62-297.310(5)(a), F.A.C.]

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value. [Rule 62-297.310(5)(b), F.A.C.]

[0850102-008-AC, Specific Condition 27.]

F.26. Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control

equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

[Rule 62-297.310(7)(b), F.A.C.; and 0850102-008-AC, Specific Condition 28.]

CONTINUOUS MONITORING REQUIREMENTS

F.27. Continuous Emission Monitoring System. The owner or operator shall install, calibrate, maintain, and operate a continuous emission monitoring (CEM) system in the exhaust stack of this emissions unit to measure and record the emissions of NO_x and CO from the emissions units, and the carbon dioxide (CO₂) content of the flue gas at the location where NO_x and CO are monitored, in a manner sufficient to demonstrate compliance with the emission limits of this permit. The CEM system shall be used to demonstrate compliance with the emission limits for NO_x and CO within this permit.

Compliance with the limits established herein for NO_x shall be based on 30-day and 12-month rolling totals starting at midnight of the first day of each calendar month. Each hourly value shall be computed using at least one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. Notwithstanding this requirement, an hourly value shall be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour). The owner or operator shall use all valid measurements or data points collected during an hour to calculate the hourly averages. All data points collected during an hour shall be, to the extent practicable, evenly spaced over the hour. If the CEM system measures concentration on a wet basis, the CEM system shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the owner or operator may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load for each allowable fuel, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Final results of the NO_x CEM system shall be expressed as lb/MMBtu and total pounds emitted.

For the CO emissions limits established herein, measurements shall be in parts per million corrected to 3% oxygen and be based on 30-day and 12-month rolling averages starting at midnight each calendar day. Each rolling average shall be calculated by adding each valid 24-hour block average from valid operating days within the calendar month.

Annual (12-month rolling) NO_x and CO emission totals shall be recalculated monthly and available on site for inspection purposes. Additionally, each year the facility shall submit all 12 months worth of calculations as part of the AOR submission.

[0850102-008-AC, Specific Condition 29.]

F.28. Certification. The NO_x monitor shall be certified and operated in accordance with the following requirements. The NO_x monitor shall be certified pursuant to 40 CFR Part 60, Appendix B and shall be operated and maintained in accordance with the applicable requirements. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F. The RATA tests required for the NO_x monitor shall be performed using EPA Method 7 or 7E of Appendix A of 40 CFR 60.

The CO monitor and CO₂ monitor shall be certified and operated in accordance with the following requirements. The CO monitor shall be certified pursuant to 40 CFR 60, Appendix B,

Performance Specification 4. The CO₂ monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 3. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F. The Data Assessment Report of section 7 shall be made each calendar quarter, and reported semi-annually to the Department's Southeast District Office. The RATA tests required for the CO monitor shall be performed using EPA Method 10, of Appendix A of 40 CFR 60. The Method 10 analysis shall be based on a continuous sampling train, and the ascarite trap may be omitted or the interference trap of section 10.1 may be used in lieu of the silica gel and ascarite traps. The RATA tests required for the CO₂ monitor shall be performed using EPA Method 3B, of Appendix A of 40 CFR 60.

[0850102-008-AC, Specific Condition 30.]

NO_x/CO CEMS Data Requirements: NO_x, CO and CO₂ emissions data shall be recorded by the CEM system during episodes of startup, shutdown and malfunction. Best operational practices shall be used to minimize hourly emissions that occur during episodes of startup, shutdown and malfunction. Emissions of any quantity or duration that occur entirely or in part from poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented, shall be prohibited. A summary report of data excluded from the block average calculation, and all instances of missing data from monitor downtime, shall be reported to the Department's Southeast District office semi-annually, and shall be consolidated with the report required pursuant to 40 CFR 60.7. The duration of excess emissions shall be the duration of the periods of data excluded for such episodes. Reports required by this paragraph and by 40 CFR 60.7 shall be submitted no less than semi-annually, including semi-annual periods in which no data is excluded or no instances of missing data occur.

[Rules 62-4.070(3) and 62-212.400., F.A.C., and PSD avoidance; and 0850102-008-AC, Specific Condition 31.]

COMPLIANCE DEMONSTRATIONS

F.29. Records Retention. All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request.

[Rules 62-4.160(14) and 62-213.440(1)(b)2., F.A.C.; and 0850102-008-AC, Specific Condition 32.]

REPORTS

F.30. Emissions Performance Test Reports. A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C.

[Rule 62-297.310(8), F.A.C.; and 0850102-008-AC, Specific Condition 33.]

F.31. Quarterly Excess Emissions Reports. If excess CO, NO_x or visible emissions occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident. Following the NSPS format in 40 CFR 60.7, Subpart A, periods

of startup, shutdown and malfunction, shall be monitored, recorded and reported as excess emissions when emission levels exceed the standards specified in this permit. Within thirty (30) days following each calendar quarter, the permittee shall submit a report on any periods of excess emissions that occurred during the previous calendar quarter to the Compliance Authority. [Rules 62-4.130, 62-204.800, 62-210.700(6), F.A.C., 40 CFR 60.7; and 0850102-008-AC, Specific Condition 34.]

F.32. Annual Operating Report. The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. This report shall include a summary of each of the prior year 12-month emission limitations, which are required for EU-007 by this permit.

[Rule 62-210.370(2), F.A.C.; and 0850102-008-AC, Specific Condition 35.]

F.33. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

F.34. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operating at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity (i.e., at less than 90 percent of the maximum operation rate allowed by the permit); in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted, provided however, operations do not exceed 100 percent of the maximum operation rate allowed by the permit. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

F.35. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal

fiscal year in which a fossil fuel steam generator does not burn liquid fuel for more than 400 hours other than during startup.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

- a. Did not operate; or
- b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

- a. Visible emissions, if there is an applicable standard;
- b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
- c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid fuel, other than during startup, for a total of more than 400 hours.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.
[Rule 62-297.310(7), F.A.C.; and SIP approved]

F.36. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

Appendix I-1. List of Insignificant Emissions Units and/or Activities.

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, or that meet the criteria specified in Rule 62-210.300(3)(b)1., F.A.C., Generic Emissions Unit Exemption, are exempt from the permitting requirements of Chapters 62-210, 62-212 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

	Brief Description of Emissions Units and/or Activities
1	Diesel Fire Pump
2	Portable Space Heaters
3	Parts Washer
4	Main Turbine Oil Tank
5	Dirty Turbine Oil Tank
6	Diesel Fuel Tank
7	Waste Oil Tank
8	Unleaded Gasoline Tank
9	Diesel Tank for Fire Pump
10	Water Treatment Lime Silo
11	Water Treatment Soda Ash Silo
12	Chemical Totes Plant-wide
13	Transformer Oil Storage
14	Hydrogen from Turbine Seal
15	Other Gas Cylinder Use
16	Oil Water Separator
17	Lab Fume Hoods
18	Transfer of Calcium Chloride Bags
19	Cooling Tower
20	Filter Press
21	Lube Oil Vent
22	Seal Oil Vent
23	Water Treatment Activated Carbon Tanks
24	Chlorine Dioxide Generation System
25	Portable Diesel Water Pump
26	Oil Mist from Turbine Seal
27	Emergency Diesel Generator

Appendix H-1. Permit History/ID Number Changes

Permit History (for tracking purposes):

E.U. ID No.	Description	Permit No.	Issue Date	Expiration Date	Revised Date(s)
-001	Pulverized Coal Main Boiler	PA90-31 PSD-FL-168 0850102-001-AV (Initial Title V Permit)	02/04/92 03/26/92 08/23/99	 08/22/04	07/16/92 07/11/95 04/13/98
-003	Two Auxiliary Boilers (removed)	PSD-FL-168 0850102-001-AV	03/26/92 08/23/99	 08/22/04	07/16/92 07/11/96 04/13/98
-004	Coal Handling System	PSD-FL-168 0850102-001-AV	03/26/92 08/23/99	 08/22/04	07/16/92 07/11/95 04/13/98
-005	Ash Handling System	PSD-FL-168 0850102-001-AV	03/26/92 08/23/99	 08/22/04	07/16/92 07/11/95 04/13/98
-006	Lime Handling System	PSD-FL-168 0850102-001-AV	03/26/92 08/23/99	 08/22/04	07/16/92 07/11/95 04/13/98
	Temporary Package Boiler (unregulated)	Specific Exemption 0850102-006-AC	03/31/03	03/31/03	
	All of the above.	0850102-007-AV	1/12/05	01/11/10	
-007	Two Auxiliary Boilers	0850102-008-AC		01/01/07	
-004	Coal Pile Operation	0850102-012-AC	09/14/07		
-007	Two Auxiliary Boilers	0850102-011-AV	10/14/07	01/11/10	

Appendix U-1, List of Unregulated Emissions Units and/or Activities.

Indiantown Cogeneration, L.P.
Indiantown Cogeneration Plant

Permit No. **0850102-013-AV**
Facility ID No. **0850102**

Unregulated Emissions Units and/or Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

For those unregulated emissions units subject to the *General Visible Emissions Standard* at Rule 62-296.320(4)(b), F.A.C., then the provisions of Rule 62-210.700, F.A.C., *Excess Emissions*, are available for purposes of compliance.

The below listed emissions units and/or activities are neither ‘regulated emissions units’ nor ‘insignificant emissions units’.

E.I.

<u>ID No.</u>	<u>Brief Description of Emissions Units and/or Activity</u>
	Temporary Package Boiler

Indiantown Cogeneration Plant

APPENDIX CAM

Compliance Assurance Monitoring Requirements

Compliance Assurance Monitoring Requirements

Pursuant to Rule 62-213.440(1)(b)1.a., F.A.C., the CAM plans that are included in this appendix contain the monitoring requirements necessary to satisfy 40 CFR 64. Conditions 1. – 17. are generic conditions applicable to all emissions units that are subject to the CAM requirements. Specific requirements related to each emissions unit are contained in the attached tables, as submitted by the applicant and approved by the Department.

40 CFR 64.6 Approval of Monitoring.

1. The attached CAM plan(s), as submitted by the applicant, is/are approved for the purposes of satisfying the requirements of 40 CFR 64.3.

[40 CFR 64.6(a)]

2. The attached CAM plan(s) include the following information:

(i) The indicator(s) to be monitored (such as temperature, pressure drop, emissions, or similar parameter);

(ii) The means or device to be used to measure the indicator(s) (such as temperature measurement device, visual observation, or CEMS); and

(iii) The performance requirements established to satisfy 40 CFR 64.3(b) or (d), as applicable.

[40 CFR 64.6(c)(1)]

3. The attached CAM plan(s) describe the means by which the owner or operator will define an exceedance of the permitted limits or an excursion from the stated indicator ranges and averaging periods for purposes of responding to (see **CAM Conditions 5. - 9.**) and reporting exceedances or excursions (see **CAM Conditions 10. – 14.**).

[40 CFR 64.6(c)(2)]

4. The permittee is required to conduct the monitoring specified in the attached CAM plan(s) and shall fulfill the obligations specified in the conditions below (see **CAM Conditions 5. - 17.**).

[40 CFR 64.6(c)(3)]

40 CFR 64.7 Operation of Approved Monitoring.

5. Commencement of operation. The owner or operator shall conduct the monitoring required under this appendix upon the effective date of this Title V permit.

[40 CFR 64.7(a)]

6. Proper maintenance. At all times, the owner or operator shall maintain the monitoring, including but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment.

[40 CFR 64.7(b)]

7. Continued operation. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the owner or operator shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of this part, including data averages and calculations, or fulfilling a minimum data availability requirement, if applicable. The owner or operator shall use all the data collected during all other periods in assessing the

operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

[40 CFR 64.7(c)]

8. Response to excursions or exceedances.

- a. Upon detecting an excursion or exceedance, the owner or operator shall restore operation of the pollutant-specific emissions unit (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions, if allowed by this permit). Such actions may include initial inspection and evaluation, recording that operations returned to normal without operator action (such as through response by a computerized distribution control system), or any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.
- b. Determination of whether the owner or operator has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include but is not limited to, monitoring results, review of operation and maintenance procedures and records, and inspection of the control device, associated capture system, and the process.

[40 CFR 64.7(d)(1) & (2)]

9. Documentation of need for improved monitoring. If the owner or operator identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the owner or operator shall promptly notify the permitting authority and, if necessary, submit a proposed modification to the Title V permit to address the necessary monitoring changes. Such a modification may include, but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting monitoring and collecting data, or the monitoring of additional parameters.

[40 CFR 64.7(e)]

40 CFR 64.8 Quality Improvement Plan (QIP) Requirements.

10. Based on the results of a determination made under **CAM Condition 8.a.**, above, the permitting authority may require the owner or operator to develop and implement a QIP. Consistent with **CAM Condition 4.**, an accumulation of exceedances or excursions exceeding 5 percent duration of a pollutant-specific emissions unit's operating time for a reporting period, may require the implementation of a QIP. The threshold may be set at a higher or lower percent or may rely on other criteria for purposes of indicating whether a pollutant-specific emissions unit is being maintained and operated in a manner consistent with good air pollution control practices.

[40 CFR 64.8(a)]

11. Elements of a QIP:

- a. The owner or operator shall maintain a written QIP, if required, and have it available for inspection.
- b. The plan initially shall include procedures for evaluating the control performance problems and, based on the results of the evaluation procedures, the owner or operator shall modify the plan to include procedures for conducting one or more of the following actions, as appropriate:

- (i) Improved preventive maintenance practices.
- (ii) Process operation changes.
- (iii) Appropriate improvements to control methods.
- (iv) Other steps appropriate to correct control performance.
- (v) More frequent or improved monitoring (only in conjunction with one or more steps under **CAM Condition 11.b(i)** through (iv), above).

[40 CFR 64.8(b)]

12. If a QIP is required, the owner or operator shall develop and implement a QIP as expeditiously as practicable and shall notify the permitting authority if the period for completing the improvements contained in the QIP exceeds 180 days from the date on which the need to implement the QIP was determined.

[40 CFR 64.8(c)]

13. Following implementation of a QIP, upon any subsequent determination pursuant to **CAM Condition 8.b.**, the permitting authority may require that an owner or operator make reasonable changes to the QIP if the QIP is found to have:

- a. Failed to address the cause of the control device performance problems; or
- b. Failed to provide adequate procedures for correcting control device performance problems as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions.

[40 CFR 64.8(d)]

14. Implementation of a QIP shall not excuse the owner or operator of a source from compliance with any existing emission limitation or standard, or any existing monitoring, testing, reporting or recordkeeping requirement that may apply under federal, state, or local law, or any other applicable requirements under the Act.

[40 CFR 64.8(e)]

40 CFR 64.9 Reporting And Recordkeeping Requirements.

15. General reporting requirements.

- a. On and after the date specified in **CAM Condition 5.** by which the owner or operator must use monitoring that meets the requirements of this appendix, the owner or operator shall submit monitoring reports semi-annually to the permitting authority in accordance with Rule 62-213.440(1)(b)3.a., F.A.C.
- b. A report for monitoring under this part shall include, at a minimum, the information required under Rule 62-213.440(1)(b)3.a., F.A.C., and the following information, as applicable:
 - (i) Summary information on the number, duration and cause (including unknown cause, if applicable) of excursions or exceedances, as applicable, and the corrective actions taken;
 - (ii) Summary information on the number, duration and cause (including unknown cause, if applicable) for monitor downtime incidents (other than downtime associated with zero and span or other daily calibration checks, if applicable); and
 - (iii) A description of the actions taken to implement a QIP during the reporting period as specified in **CAM Conditions 10.** through 14. Upon completion of a QIP, the owner or operator shall include in the next summary report documentation that the implementation of the plan has been completed and reduced the likelihood of similar levels of excursions or exceedances occurring.

[40 CFR 64.9(a)]

16. General recordkeeping requirements.

- a. The owner or operator shall comply with the recordkeeping requirements specified in Rule 62-213.440(1)(b)2., F.A.C. The owner or operator shall maintain records of monitoring data,

monitor performance data, corrective actions taken, any written quality improvement plan required pursuant to **CAM Conditions 10. through 14.** and any activities undertaken to implement a quality improvement plan, and other supporting information required to be maintained under this part (such as data used to document the adequacy of monitoring, or records of monitoring maintenance or corrective actions).

- b. Instead of paper records, the owner or operator may maintain records on alternative media, such as microfilm, computer files, magnetic tape disks, or microfiche, provided that the use of such alternative media allows for expeditious inspection and review, and does not conflict with other applicable recordkeeping requirements.

[40 CFR 64.9(b)]

40 CFR 64.10 Savings Provisions.

17. It should be noted that nothing in this appendix shall:

- a. Excuse the owner or operator of a source from compliance with any existing emission limitation or standard, or any existing monitoring, testing, reporting or recordkeeping requirement that may apply under federal, state, or local law, or any other applicable requirements under the Act. The requirements of this appendix shall not be used to justify the approval of monitoring less stringent than the monitoring which is required under separate legal authority and are not intended to establish minimum requirements for the purpose of determining the monitoring to be imposed under separate authority under the Act, including monitoring in permits issued pursuant to title I of the Act. The purpose of this part is to require, as part of the issuance of a permit under Title V of the Act, improved or new monitoring at those emissions units where monitoring requirements do not exist or are inadequate to meet the requirements of this part.
- b. Restrict or abrogate the authority of the Administrator or the permitting authority to impose additional or more stringent monitoring, recordkeeping, testing, or reporting requirements on any owner or operator of a source under any provision of the Act, including but not limited to sections 114(a)(1) and 504(b), or state law, as applicable.
- c. Restrict or abrogate the authority of the Administrator or permitting authority to take any enforcement action under the Act for any violation of an applicable requirement or of any person to take action under section 304 of the Act.

[40 CFR 64.10]

Indiantown Cogeneration, L.P.

Emissions Unit 001

**3,422 MMBtu/Hr Pulverized Coal-Fired Boiler
Particulate Matter Emissions Controlled By a Baghouse**

Monitoring Approach and Corrective Action Procedures

Table 1. Monitoring Approach

	<u>Indicator 1.</u>	<u>Indicator 2.</u>
I. Indicator	Duct opacity.	Change in duct opacity
Measurement Approach	Continuous opacity monitoring system (COMS).	Continuous opacity monitoring system (COMS).
II. Indicator Range	An excursion is defined as opacity greater than 6.0%, based on a one-hour block average (other than startup and shutdown periods).	An excursion is defined as any sudden and sustained step-change (increase) in opacity as documented by the trend of the one-hour block average (other than startup and shutdown periods).
III. Performance Criteria		
A. Data Representativeness	Based on available data under normal operation, the representative stack opacity of each unit is in the range of 2.5 to 6%. Based on past stack test results, a sustained opacity greater than 6% may indicate a potential problem with the baghouse.	Based on available data under normal operation, opacity varies with load and operating conditions. Variability is typically a gradual increase or decrease, with occasional sudden spikes and dips. A sudden and sustained step-increase in opacity could indicate a failure in one or more of the baghouse compartments.
B. Verification of Operational Status	Annual testing during normal operation is used to verify particulate mass loading. The COM system is audited quarterly.	The COM system is audited quarterly.
C. QA/QC Practices and Criteria	Install and operate COMS according to 40 CFR Part 60 Appendix B, Performance Specification 1 and general provisions 60.13.	Install and operate COMS according to 40 CFR Part 60 Appendix B, Performance Specification 1 and general provisions 60.13.
D. Monitoring Frequency	Continuous.	Continuous.
E. Data Collection Procedures	The COMS collects data that are reduced to one-hour block averages. Consecutive one-hour block averages are tracked through the Distributed Control System (DCS) and CEM software.	The COMS collects data that are reduced to one-hour block averages. Consecutive one-hour block averages are tracked through the Distributed Control System (DCS) and CEM software.
F. Averaging Period	One-hour block average.	None.

Table 2. Corrective Action Procedures Summary

	<u>Description</u>
I. Initiation of Corrective Action Procedures	<p>Corrective action shall be initiated with the discovery of opacity greater than 6.0%, based on a one-hour block average and that defines an excursion (as defined in CAM Table-1). The plant staff that made the discovery shall immediately notify the shift supervisor or responsible official. This action describes a corrective action trigger. {Note: A step-change in opacity for no known reason may also trigger the below actions, but does not necessarily represent an excursion as defined by this plan.}</p>
II. Time of Completion of Corrective Action Procedures	<p>As soon as practically possible.</p>
III. Corrective Action	<p>The shift supervisor or responsible official will implement the following as a corrective action.</p> <p>Procedures, as presented in the O&M Plan, include the following alternatives that will be initiated as necessary.</p> <ul style="list-style-type: none"> • Perform operational diagnostics to identify cause of the excursion. • If operational diagnostics indicate a malfunction of the baghouse, the reason for failure will be identified. • If isolation of the compartment can be accomplished to reduce opacity below the excursion level, such measures will be undertaken. • In the event of the need for the unit shutdown to bring opacity to below excursion levels, the task will be undertaken based on procedures described in the O&M Plan for the facility. <p>Regardless of the failure mechanism, baghouse operation will be restored such that the cause of excursion is identified and appropriate actions taken to ensure opacity below excursion levels.</p>