

Indiantown Cogeneration, L.P.

PO Box 1799
13303 SW Silver Fox Lane
Indiantown, FL 34956
P: (772) 597-6500
F: (772) 597-6210

August 27th, 2014

RECEIVED

AUG 23 2014

DIVISION OF AIR
RESOURCE MANAGEMENT

Lee Hoefert
Florida Department of Environmental Protection.
400 N Congress Ave.
Suite 200
West Palm Beach, FL 33416

VIA ELECTRONIC MAIL

**Re: 2014 COMPLIANCE TESTING FOR INDIANTOWN COGENERATION L.P
(TITLE V PERMIT # 0850102)**

Dear Mr. Hoefert:


Enclosed please find a report on 2014 Compliance testing for Indiantown Cogeneration's P.C. Boiler. Per your request the testing for Carbon Monoxide and Nitrogen Oxide were done simultaneously.

Summary of Test Results

| Parameter | Results % | Allowable Limit | Heat Input |
|--------------------------------|-----------|-----------------|------------|
| PARTICULATE MATTER (lb/hr) | 27.9 | 61.6 | 2860.2 |
| PARTICULATE MATTER (lb/mmbtu) | 0.008 | 0.018 | 2860.2 |
| NITROGEN OXIDE (lb/hr) | 491 | 582 | 2905.9 |
| NITROGEN OXIDE (lb/mmbtu) | 0.161 | 0.170 | 2905.9 |
| SULFUR DIOXIDE (lb/hr) | 342 | 582 | 2905.9 |
| SULFUR DIOXIDE (lb/mmbtu) | 0.112 | 0.170 | 2905.9 |
| CARBON MONOXIDE (lb/hr) | 274 | 376 | 2905.9 |
| CARBON MONOXIDE (lb/mmbtu) | 0.089 | 0.110 | 2905.9 |
| PC STACK(%VE) | 0 | 5 | |
| COAL UNLOADING JK-H 10 (%VE) | 0 | 5 | |
| COAL BUNKER JK-H 50 (%VE) | 0 | 5 | |
| COAL CRUSHER JK-H 41 (%VE) | 0 | 5 | |
| COAL RECLAIM JK-H 27(%VE) | 0 | 5 | |
| FLY ASH SILO DUST COLLECTOR BH | 0 | 5 | |
| RAIL LIME UNLOADING CARTRIDGE | 0 | 5 | |
| LIME SILO DUST COLLECTOR (%VE) | 0 | 5 | |

Attached are the Audit reports for your review. In accordance to Chapter 62-213-440(1)(b)3-c, F.A.C., I certify that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Should you have any questions please contact Nicholas Laryea at (772) 597-6535.

Sincerely,



Todd Shirley
Projects General Manager

cc: Nicholas Laryea
Errin Pichard
U.S. EPA Region IV
File 2.4.4.



245 West Ohio Ave. • Suite A • Lake Helen, FL 32744

Phone (386) 451-0169 • coastalair123@aol.com

COMPLETE EMISSIONS TESTING SERVICES • PERMITTING ASSISTANCE • CEMS CERTIFICATION • AMBIENT AIR MONITORING

Emissions Test Report

No. 122-038

INDIANTOWN COGENERATION PLANT

COMPLIANCE PARTICULATE, VE'S, NO_x, SO₂ & CO PC BOILER STACK

Prepared for:

Indiantown Cogeneration, LP
13303 SW Silver Fox Lane
Indiantown, FL 34956

Prepared by:

Coastal Air Consulting, Inc.
1531 Wyngate Dr.
DeLand, FL 32724
(386) 451-0169

Completed on:

July 18, 2014

STATEMENT OF VALIDITY

All testing activities and results represented herein were conducted and obtained in accordance with the approved EPA protocols listed in 40 CFR Part 60 & 75. The contents have been reviewed and verified, to the extent practical, to be valid and accurate representation of the source emissions at the time of testing.

Stephen C. Webb



President

Coastal Air Consulting, Inc.

1531 Wyngate Dr.

DeLand, FL 32724

(386) 451-0169

PROJECT STATISTICS

Client: Indiantown Cogeneration, LP

Facility: Indiantown Cogeneration Plant, L.P.

Location: 13303 SW Silver Fox Lane
Indiantown, FL 34956

Type of Process Tested: 330 MW Pulverized Coal Fired Boiler

**Test Protocols Performed:
(Compliance)** Particulate Emissions – EPA Method 5
Oxygen/Carbon Dioxide-EPA Method 3A
Sulfur Dioxide- EPA Method 6C
Nitrogen Oxide-EPA Method 7E
Visible Emissions - EPA Method 9
Carbon Monoxide – EPA Method 10
~~Visible Emissions - EPA Method 22~~

Testing Firm: Coastal Air Consulting, Inc.
1531 Wyngate Dr.
DeLand, FL 32724
(386) 451-0169

Test Personnel: Stephen Webb QSTI
Quin Revel
Troy Marlowe

Test Dates: July 15 -18, 2014

Client Representative: Nick Laryea

Observers: Lee Hoefert DEP Southeast District
Air Program

TABLE OF CONTENTS

LETTER OF TRANSMITTAL

TITLE PAGE

STATEMENT OF VALIDITY

PROJECT STATISTICS

TABLE OF CONTENTS

-
- 1 Introduction
 - 2 Test Program Summary
 - 3 Results of Testing
 - 4 Description of Source
 - 5 Sampling Procedures
 - 6 Operating Conditions
 - 7 Quality Assurance

APPENDICES

- 1 Reference Data
- 2 Plant Data
- 3 Quality Assurance
- 4 Sample Calculations
- 5 Figures
- 6 QSTI

1.0 Introduction

Coastal Air Consulting, Inc. (Coastal) was contracted by Indiantown Cogeneration, LP to determine the Compliance Testing at the Indiantown Cogeneration Plant located in Indiantown, Florida. Coastal performed the compliance testing for particulate emissions, visible emissions, sulfur dioxide and nitrogen oxides on the PC Boiler Stack.

The sampling program was conducted on July 15-18, 2014. The compliance testing was performed by Coastal personnel, with the assistance of personnel assigned by Indiantown Cogeneration.

2.0 Test Program Summary

A summary of test results developed by this source sampling program is presented in Tables 1, 2, 3, 4 & 5 as follows;

TABLE 1
Summary of Particulate Emissions EPA Method 5

| Source | Date | Particulate (lb/mmBtu) | Limit (lb/mmBtu) | Particulate (lb/hr) | Limit (lb/hr) | Particulate tpy | Limit tpy | mmBtu/hr |
|-----------|---------|------------------------|------------------|---------------------|---------------|-----------------|-----------|----------|
| PC Boiler | 7-17-14 | 0.008 | 0.018 | 27.9 | 61.1 | 122 | 270 | 2860.2 |

TABLE 2
Summary of Gaseous Emissions EPA Methods 6C & 7E

| Source | Date | NOx lb/mmBtu | SO2 lb/mmBtu | Limit lb/mmBtu | NOx lb/hr | SO2 lb/hr | Limit lb/hr | NOx tpy | SO2 tpy | Limit tpy | mmBtu/hr |
|-----------|---------|--------------|--------------|----------------|-----------|-----------|-------------|---------|---------|-----------|----------|
| PC Boiler | 7-16-14 | 0.161 | 0.112 | 0.170 | 491 | 342 | 582 | 2,151 | 1,498 | 2,549 | 2905.9 |

*24 hour daily block average (midnight to midnight)

TABLE 3
Summary of Gaseous Emissions EPA Method 10

| Source | Date | CO lb/hr | Limit lb/hr | mmBtu/hr |
|-----------|---------|----------|-------------|----------|
| PC Boiler | 7-16-14 | 274 | 376 | 2905.9 |

*24 hour daily block average (midnight to midnight)

TABLE 3
Summary of Visible Emissions EPA Method 9

| Source | Date | Average VE (%) | Highest 6 min (%) | Allowable (%) |
|-----------------------------------|---------|----------------|-------------------|---------------|
| PC Boiler Stack | 7-17-14 | 0.0 | 0.0 | 10 |
| Coal Pulverizer BH | 7-16-14 | 0.0 | 0.0 | 5 |
| Coal Crusher Dust Collector BH | 7-16-14 | 0.0 | 0.0 | 5 |
| Coal Transfer BH | 7-16-14 | 0.0 | 0.0 | 5 |
| Coal Unloading BH | 7-15-14 | 0.0 | 0.0 | 5 |
| Fly Ash Silo Dust Collector BH | 7-17-14 | 0.0 | 0.0 | 5 |
| Lime Transfer Cartridge Collector | 7-18-14 | 0.0 | 0.0 | 5 |
| Lime Transfer Bag Collector | 7-18-14 | 0.0 | 0.0 | 5 |

TABLE 4
Summary of Visible Emissions EPA Method 22

| Source | Date | Start Time | Observation Period (min:sec) | Emission Period (min:sec) | Allowable (min:sec) |
|--------------------------------|---------|------------|------------------------------|---------------------------|---------------------|
| Bunker Room Exhaust (JK-H50) | 7-16-14 | 14:08 | 20:00 | 0:00 | 2:00 |
| | | 14:33 | 20:00 | 0:00 | 2:00 |
| | | 14:58 | 20:00 | 0:00 | 2:00 |
| Crusher Building BH (JK-H41) | 7-16-14 | 11:50 | 20:00 | 0:00 | 2:00 |
| | | 12:15 | 20:00 | 0:00 | 2:00 |
| | | 12:40 | 20:00 | 0:00 | 2:00 |
| Coal Reclaim Building (JK-H27) | 7-17-14 | 11:20 | 20:00 | 0:00 | 2:00 |
| | | 11:45 | 20:00 | 0:00 | 2:00 |
| | | 12:10 | 20:00 | 0:00 | 2:00 |
| Coal Unloading (JK-H10) | 7-15-14 | 17:00 | 20:00 | 0:00 | 2:00 |
| | | 17:25 | 20:00 | 0:00 | 2:00 |
| | | 17:50 | 20:00 | 0:00 | 2:00 |

3.0 Results of Testing

These results indicate that the PC Boiler passed the compliance testing at the time of testing under normal operating conditions. The individual test run results are tabulated in Appendix 1.

4.0 Description of Source

Indiantown Cogeneration PC Boiler is a 330 MW pulverized coal fired boiler exporting 175,000 lb/hr of steam to a host facility. The boiler was supplied by Foster Wheeler Energy Corporation. Low-NOx reduction burners with over fired air and selective catalytic reduction using ammonia injection are used for NOx reduction. Particulate and sulfur dioxide emissions are controlled by an Aseav Brown Boveri (ABB) flue gas cleaning system (FGCS) comprised of two 50 percent capacity lime injection spray dryer absorbers followed by a fabric filter bag house.

The controlled emissions from the pulverized coal boiler exhausts into the atmosphere through the PC Boiler stack, which is 17.17 feet (206 inches) in diameter, contained in a reinforced cement shell. There are four six-inch test ports spaced at 90-degree intervals around the flue at an elevation of approximately 250 feet above grade.

5.0 Sampling Procedures

EPA testing protocols utilized during this test program include the following;

| | |
|---------------|--|
| EPA Method 1 | Sample and Velocity Traverse for Stationary Sources |
| EPA Method 2 | Determination of Stack Gas Velocity and Volumetric Flow Rate |
| EPA Method 3A | Gas Analysis for CO ₂ , O ₂ , Excess Air and Dry Molecular Weight (Instrumental Analyzer Method) |
| EPA Method 4 | Determination of Moisture Content in Stack Gas |
| EPA Method 5 | Determination of Particulate Emissions From Stationary Sources |
| EPA Method 6C | Determination of Sulfur Dioxide Emissions From Stationary Sources (Instrumental Analyzer Method) |
| EPA Method 7E | Determination of Nitrogen Oxides Emissions From Stationary Sources (Instrumental Analyzer Method) |
| EPA Method 8 | Determination of Sulfuric Acid Mist and Sulfur Dioxide Emissions from Stationary Sources |
| EPA Method 9 | Visual Determination of the Opacity of Emissions From Stationary Sources |
| EPA Method 10 | Determination of Carbon Monoxide Emissions from Stationary Sources (Instrumental Analyzer Method) |
| EPA Method 22 | Visual Determination of Fugitive Emissions From Material Sources |

6.0 Operating Conditions

The PC Boiler ran under normal operations during testing with no delays or interruptions. Indiantown Cogeneration personnel monitored operating conditions throughout the duration of the sampling program.

7.0 Quality Assurance Procedures

Quality assurance procedures followed during these testing activities were applied consistent with the requirements outlined by the EPA methods referenced in 40 CFR Parts 60 & 75. Analyzer calibrations, system bias and drift checks were completed before and after each sample run utilizing EPA Protocol 1 calibration gases.

APPENDIX 1
REFERENCE DATA
Particulate

COASTAL AIR CONSULTING, INC.

PARTICULATE EMISSION TEST SUMMARY

CLIENT: INDIANTOWN COGENERATION
 PLANT: INDIANTOWN COGENERATION PLANT
 UNIT: PC BOILER
 TEST: COMPLIANCE
 METHOD: 5

| | <u>RUN 1</u> | <u>RUN 2</u> | <u>RUN 3</u> |
|--|--------------|--------------|--------------|
| DATE OF RUN | 07/17/14 | 07/17/14 | 07/17/14 |
| HEAT INPUT (MMBTU/HR) | 3184.0 | 3151.2 | 3076.6 |
| STEAM FLOW (KLB/HR) | 2326.5 | 2333.6 | 2310.8 |
| GROSS LOAD (MW) | 330.8 | 331.6 | 331.1 |
| START TIME (24-HR CLOCK) | 1200 | 1419 | 1700 |
| END TIME (24-HR CLOCK) | 1408 | 1626 | 1907 |
| VOL DRY GAS SAMPLED METER COND (DCF) | 115.656 | 115.874 | 115.206 |
| BAROMETRIC PRESSURE (IN. HG) | 29.88 | 29.88 | 29.88 |
| AVG ORIFICE PRESSURE DROP (IN. H2O) | 2.692 | 2.642 | 2.683 |
| AVG GAS METER TEMP (F) | 103.7 | 109.5 | 113.5 |
| GAS METER CALIBRATION FACTOR | 0.9870 | 0.9870 | 0.9870 |
| VOL GAS SAMPLED STD COND (DSCF) | 107.451 | 106.538 | 105.195 |
| TOTAL WATER COLLECTED (G) | 340.6 | 342.1 | 306.4 |
| VOL WATER COLLECTED STD COND (SCF) | 16.06 | 16.13 | 14.45 |
| MOISTURE IN STACK GAS (% VOL) | 13.00 | 13.15 | 12.07 |
| MOLE FRACTION DRY GAS | 0.870 | 0.869 | 0.879 |
| CO2 VOL PERCENT DRY | 12.4 | 12.7 | 13.0 |
| O2 VOL PERCENT DRY | 6.7 | 6.6 | 6.3 |
| N2 VOL PERCENT DRY | 80.90 | 80.70 | 80.70 |
| MOL. WT. DRY STACK GAS (LB/LB-MOLE) | 30.25 | 30.30 | 30.33 |
| MOL. WT. WET STACK GAS (LB/LB-MOLE) | 28.66 | 28.68 | 28.84 |
| ELEV. DIFF. FROM MANOM. TO BAROM. (FT) | 0.00 | 0.00 | 0.00 |
| STACK GAS STATIC PRESSURE (IN. H2O GAGE) | -1.00 | -1.00 | -1.00 |
| STACK GAS STATIC PRESSURE (IN. HG ABS.) | 29.81 | 29.81 | 29.81 |
| AVERAGE SQUARE ROOT VELOCITY HEAD | 1.334 | 1.329 | 1.332 |
| PITOT TUBE COEFFICIENT | 0.84 | 0.84 | 0.84 |
| AVG STACK TEMP (F) | 191.9 | 192.3 | 190.2 |
| STACK GAS VELOCITY STACK COND (FT/SEC) | 83.68 | 83.35 | 83.16 |
| CROSS SECTION STACK AREA (SQ FT) | 231.5 | 231.5 | 231.5 |
| STACK GAS FLOW RATE STD COND (DSCFM) | 815893.9 | 810718.6 | 821618.1 |
| STACK GAS FLOW RATE STACK COND (ACFM) | 1162415.2 | 1157735.6 | 1155114.2 |
| NET TIME OF RUN (MIN) | 120 | 120 | 120 |
| NOZZLE DIAMETER (IN) | 0.215 | 0.215 | 0.215 |
| PERCENT ISOKINETIC | 100.83 | 100.61 | 98.03 |
| PARTICULATE COLLECTED (MG) | 38.2 | 17.6 | 26.6 |
| WEIGHTED AVERAGE F FACTOR (DSCF/MILL. BTU) | 9780.00 | 9780.00 | 9780.00 |
| HEAT INPUT COAL (%) | 100.0 | 100.0 | 100.0 |
| PARTICULATE EMISSIONS (GRAINS/SCF) | 0.0055 | 0.0025 | 0.0039 |
| PARTICULATE EMISSIONS (LB/MILL. BTU) | 0.0113 | 0.0052 | 0.0078 |
| PARTICULATE EMISSIONS (LB/HR) | 38.356 | 17.710 | 27.473 |
| AVERAGE PARTICULATE EMISSIONS (LB/MMBTU) | | 0.0081 | |
| AVERAGE PARTICULATE EMISSIONS (LB/HR) | | 27.846 | |

NOTE: STANDARD CONDITIONS -- 68F, 29.92 in. Hg

PARTICULATE TEST FIELD DATA SHEET

Plant & Unit: ICLP PC Boiler
 Type of test: Compliance
 Method: 5
 Run Number: 1
 Date: 07/17/14
 Sample Location: Stack
 Operators: TAM/SCW

| | | | |
|------------------------|---------|----------------------|--------|
| Reference: | 1.51 | Filter #: | 181 |
| Bar. Pressure (in.Hg): | 29.88 | Nozzle #: | T2 |
| Static Pressure (H2O): | -1.00 | Nozzle Dia.(in): | 0.211 |
| Meter Box #: | CAC 2 | ^H@ 1.615 Yi | 0.9870 |
| Ini. Pitot Leak Check: | OK @ 5" | Pitot # CAC 9 | 0.84 |
| Fin. Pitot Leak Check: | OK @ 5" | Thermocouple # CAC 9 | |
| Ini. Leak Rate:0.000@ | 15 " | Impinger Set: | A |
| Fin. Leak Rate:0.000@ | 10 " | Sample Head: | A |

| POINT # | CLOCK TIME | SAMPLE TIME | DRY GAS | VELOCITY | ORIFICE | METER | STACK | HOT BOX | IMPINGER | |
|---------|------------|-------------|---------|------------------|----------------|-------------|-------------|-------------|-----------------|-------------|
| | | | VOLUME | HEAD (in H2O) | ^H (in H2O) | TEMP (F) | TEMP (F) | TEMP (F) | VAC. (IN.HG) | TEMP (F) |
| | | | 263.642 | | | | | | | |
| N-1 | 1200 | 10 | 273.0 | 1.60 | 2.40 | 96 | 191 | 264 | 7.5 | 65 |
| N-2 | | 20 | 283.5 | 2.00 | 3.00 | 97 | 192 | 263 | 9.0 | 67 |
| N-3 | | 30 | 294.098 | 1.90 | 2.90 | 98 | 192 | 260 | 9.0 | 67 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| W-1 | | 10 | 303.5 | 1.70 | 2.60 | 100 | 193 | 265 | 6.5 | 66 |
| W-2 | | 20 | 312.8 | 1.80 | 2.70 | 101 | 193 | 267 | 7.0 | 67 |
| W-3 | | 30 | 321.891 | 1.60 | 2.40 | 103 | 192 | 265 | 6.5 | 67 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| S-1 | | 10 | 331.0 | 1.70 | 2.60 | 104 | 192 | 248 | 7.0 | 68 |
| S-2 | | 20 | 340.5 | 1.80 | 2.70 | 106 | 192 | 266 | 7.0 | 61 |
| S-3 | | 30 | 349.996 | 1.60 | 2.40 | 108 | 191 | 259 | 7.5 | 57 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| E-1 | | 10 | 359.5 | 1.80 | 2.70 | 109 | 191 | 265 | 7.0 | 57 |
| E-2 | | 20 | 369.7 | 2.20 | 3.30 | 111 | 192 | 257 | 7.5 | 58 |
| E-3 | 1408 | 30 | 379.298 | 1.70 | 2.60 | 111 | 192 | 262 | 7.0 | 59 |
| | | | | | | | | | | |
| | | | | | | | | | | |

| | | | | |
|---------|-------|-------|-------|-------|
| 115.656 | 1.334 | 2.692 | 103.7 | 191.9 |
|---------|-------|-------|-------|-------|

MOISTURE, PARTICULATE CATCH AND DRY MOLECULAR WEIGHT DATA

PLANT: ICLP PC Boiler
 DATE: 17-Jul-14

RUN 1

METHOD 4 MOISTURE DETERMINATION

| | | | | | |
|------------------|----------------|----------------------------|----------------|----------------|---------------|
| IMPG SET: | A | | | | |
| | IMPG.#1 | IMPG.#2 | IMPG.#3 | IMPG.#4 | WT. BY |
| FINAL WT. | 942.0 | 750.6 | 615.0 | 903.5 | SCW |
| INITIAL WT. | 710.5 | 688.8 | 600.2 | 871.0 | SCW |
| NET WT. | 231.5 | 61.8 | 14.8 | 32.5 | SCW |
| TOTAL WT. | 340.6 | note: all weights in grams | | | |

PARTICULATE FILTER CATCH

| | | | | | |
|---------------------|--------|-----------|-----------------|---------|-----------|
| FILTER # | 181 | BY | BEAKER # | 1 | BY |
| FINAL WT. | 0.4360 | SCW | FINAL WT. | 72.9542 | SCW |
| INITIAL WT. | 0.4110 | SCW | INITIAL WT. | 72.9410 | SCW |
| NET WT. | 0.0250 | SCW | NET WT. | 0.0132 | SCW |
| TOTAL CATCH (grams) | | | 0.0382 | | |
| TOTAL CATCH (mg) | | | 38.2 | | |

DRY MOLECULAR WEIGHT

| | | | | | |
|------------|------|------|------|------------|-------------------------|
| GAS | 1 | 2 | 3 | AVG | Fo: 1.145 |
| CO2 | 12.4 | 12.4 | 12.4 | 12.4 | ALLOWED Fo RANGE |
| O2+CO2 | 19.1 | 19.1 | 19.1 | ----- | OIL: 1.210 TO 1.370 |
| O2 | 6.7 | 6.7 | 6.7 | 6.7 | COAL: 1.083 TO 1.230 |

4 MINUTE ORSAT ANALYZER CHECK

| | | | |
|---------------------------|---------------|--------------|------------|
| | BEFORE | AFTER | |
| BURETTE MENISCUS READING: | 15 | 15 | <0.2 ? YES |
| CO2 CAPILLARY TUBE LEVEL: | OK | OK | |
| O2 CAPILLARY TUBE LEVEL: | OK | OK | |

PARTICULATE TEST FIELD DATA SHEET

Plant & Unit: ICLP PC Boiler
 Type of test: Compliance
 Method: 5
 Run Number: 2
 Date: 07/17/14
 Sample Location: Stack
 Operators: TAM

Reference: 1.36
 Bar. Pressure (in.Hg): 29.88
 Static Pressure (H2O): -1.00
 Meter Box #: CAC 2
 Ini. Pitot Leak Check: OK @ 5"
 Fin. Pitot Leak Check: OK @ 5"
 Ini. Leak Rate:0.000@ 15 "
 Fin. Leak Rate:0.003@ 5.5 "

Filter #: 182
 Nozzle #: T2
 Nozzle Diam.(in): 0.211
 ^H@ 1.615 Yi 0.9870
 Pitot # CAC 9 0.84
 Thermocouple # 9
 Impinger Set: B
 Sample Head: A

| POINT # | CLOCK TIME | SAMPLE TIME | DRY GAS VOLUME | VELOCITY | ORIFICE | METER | STACK | HOT BOX | VAC. | IMPINGER |
|---------|------------|-------------|----------------|---------------|-------------|----------|----------|----------|------|----------|
| | | | | HEAD (in H2O) | ^H (in H2O) | TEMP (F) | TEMP (F) | TEMP (F) | | TEMP (F) |
| | | | 379.649 | | | | | | | |
| E-1 | 1448 | 10 | 389.0 | 1.70 | 2.40 | 107 | 193 | 253 | 2.5 | 67 |
| E-2 | | 20 | 398.8 | 1.90 | 2.90 | 107 | 192 | 255 | 4.0 | 65 |
| E-3 | | 30 | 408.171 | 1.70 | 2.40 | 108 | 193 | 257 | 2.5 | 65 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| S-1 | | 10 | 417.9 | 1.80 | 2.70 | 108 | 193 | 256 | 2.5 | 65 |
| S-2 | | 20 | 427.7 | 1.90 | 2.90 | 109 | 193 | 256 | 3.5 | 66 |
| S-3 | | 30 | 437.451 | 1.80 | 2.70 | 109 | 192 | 256 | 4.0 | 66 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| W-1 | | 10 | 447.2 | 1.80 | 2.70 | 109 | 193 | 257 | 4.0 | 67 |
| W-2 | | 20 | 457.0 | 1.80 | 2.70 | 110 | 192 | 255 | 4.0 | 67 |
| W-3 | | 30 | 466.397 | 1.60 | 2.40 | 111 | 191 | 256 | 4.5 | 67 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| N-1 | | 10 | 476.0 | 1.70 | 2.60 | 112 | 193 | 259 | 4.0 | 65 |
| N-2 | | 20 | 486.1 | 1.90 | 2.90 | 112 | 192 | 259 | 4.5 | 66 |
| N-3 | 1652 | 30 | 495.523 | 1.60 | 2.40 | 112 | 191 | 257 | 4.0 | 66 |
| | | | | | | | | | | |
| | | | | | | | | | | |

| | | | | |
|---------|-------|-------|-------|-------|
| 115.874 | 1.329 | 2.642 | 109.5 | 192.3 |
|---------|-------|-------|-------|-------|

MOISTURE, PARTICULATE CATCH AND DRY MOLECULAR WEIGHT DATA

PLANT: ICLP PC Boiler
 DATE: 17-Jul-14

RUN 2

METHOD 4 MOISTURE DETERMINATION

| | | | | | |
|-------------|---------|----------------------------|---------|---------|--------|
| IMPG SET: | B | | | | |
| | IMPG.#1 | IMPG.#2 | IMPG.#3 | IMPG.#4 | WT. BY |
| FINAL WT. | 904.4 | 793.3 | 603.9 | 935.5 | SCW |
| INITIAL WT. | 702.3 | 684.5 | 600.6 | 907.6 | SCW |
| NET WT. | 202.1 | 108.8 | 3.3 | 27.9 | SCW |
| TOTAL WT. | 342.1 | note: all weights in grams | | | |

PARTICULATE FILTER CATCH

| | | | | | |
|---------------------|--------|-----------|-----------------|---------|-----------|
| FILTER # | 182 | BY | BEAKER # | 2 | BY |
| FINAL WT. | 0.4206 | SCW | FINAL WT. | 73.0737 | SCW |
| INITIAL WT. | 0.4149 | SCW | INITIAL WT. | 73.0618 | SCW |
| NET WT. | 0.0057 | SCW | NET WT. | 0.0119 | SCW |
| TOTAL CATCH (grams) | | | 0.0176 | | |
| TOTAL CATCH (mg) | | | 17.6 | | |

DRY MOLECULAR WEIGHT

| | | | | | |
|------------|----------|----------|----------|------------|--|
| GAS | 1 | 2 | 3 | AVG | Fo: 1.126 |
| CO2 | 12.7 | 12.7 | 12.7 | 12.7 | ALLOWED Fo RANGE OIL: 1.210 TO 1.370 COAL: 1.083 TO 1.230 |
| O2+CO2 | 19.3 | 19.3 | 19.3 | ----- | |
| O2 | 6.6 | 6.6 | 6.6 | 6.6 | |

4 MINUTE ORSAT ANALYZER CHECK

| | | | |
|---------------------------|---------------|--------------|------------|
| | BEFORE | AFTER | |
| BURETTE MENISCUS READING: | 15 | 15 | <0.2 ? YES |
| CO2 CAPILLARY TUBE LEVEL: | OK | OK | |
| O2 CAPILLARY TUBE LEVEL: | OK | OK | |

PARTICULATE TEST FIELD DATA SHEET

| | | |
|------------------------------|--------------------------------|-------------------------|
| Plant & Unit: ICLP PC Boiler | Reference: 1.36 | Filter #: 183 |
| Type of test: Compliance | Bar. Pressure (in.Hg): 29.88 | Nozzle #: T2 |
| Method: 5 | Static Pressure (H2O): -1.00 | Nozzle Diam.(in): 0.211 |
| Run Number: 3 | Meter Box #: CAC 2 | ^H@ 1.615 Yi 0.9870 |
| Date: 07/17/14 | Ini. Pitot Leak Check: OK @ 5" | Pitot # CAC 9 0.84 |
| Sample Location: Stack | Fin. Pitot Leak Check: OK @ 5" | Thermocouple # 9 |
| Operators: TAM/TQR | Ini. Leak Rate:0.000@ 15 " | Impinger Set: C |
| | Fin. Leak Rate:0.000@ 8.5 " | Sample Head: A |

| POINT # | CLOCK TIME | SAMPLE TIME | DRY GAS | VELOCITY | ORIFICE | METER | STACK | HOT BOX | VAC. (IN.HG) | IMPINGER |
|---------|------------|-------------|---------|---------------|-------------|----------|----------|----------|--------------|----------|
| | | | VOLUME | HEAD (in H2O) | ^H (in H2O) | TEMP (F) | TEMP (F) | TEMP (F) | | TEMP (F) |
| | | | 496.518 | | | | | | | |
| N-1 | 1700 | 10 | 505.5 | 1.60 | 2.40 | 108 | 191 | 236 | 6.0 | 67 |
| N-2 | | 20 | 515.5 | 1.90 | 2.90 | 109 | 190 | 258 | 7.5 | 66 |
| N-3 | | 30 | 525.162 | 1.80 | 2.70 | 111 | 190 | 256 | 7.0 | 67 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| W-1 | | 10 | 534.7 | 1.70 | 2.60 | 114 | 190 | 259 | 7.0 | 68 |
| W-2 | | 20 | 544.3 | 1.70 | 2.60 | 112 | 190 | 260 | 6.5 | 68 |
| W-3 | | 30 | 553.876 | 1.80 | 2.70 | 113 | 190 | 259 | 6.5 | 68 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| S-1 | | 10 | 563.5 | 1.80 | 2.70 | 114 | 190 | 258 | 7.0 | 65 |
| S-2 | | 20 | 572.7 | 1.60 | 2.40 | 115 | 190 | 259 | 7.0 | 65 |
| S-3 | | 30 | 582.255 | 1.70 | 2.60 | 115 | 190 | 261 | 6.0 | 66 |
| | | | | | | | | | | |
| | | | | | | | | | | |
| E-1 | | 10 | 591.7 | 1.80 | 2.70 | 116 | 190 | 260 | 7.0 | 65 |
| E-2 | | 20 | 601.6 | 1.90 | 2.90 | 117 | 190 | 260 | 7.0 | 64 |
| E-3 | 1907 | 30 | 611.724 | 2.00 | 3.00 | 118 | 191 | 260 | 7.5 | 65 |
| | | | | | | | | | | |
| | | | | | | | | | | |

| | | | | |
|---------|-------|-------|-------|-------|
| 115.206 | 1.332 | 2.683 | 113.5 | 190.2 |
|---------|-------|-------|-------|-------|

MOISTURE, PARTICULATE CATCH AND DRY MOLECULAR WEIGHT DATA

PLANT: ICLP PC Boiler
 DATE: 17-Jul-14

RUN 3

METHOD 4 MOISTURE DETERMINATION

| | | | | | |
|-------------|----------------|----------------------------|----------------|----------------|---------------|
| IMPG SET: | C | | | | |
| | IMPG.#1 | IMPG.#2 | IMPG.#3 | IMPG.#4 | WT. BY |
| FINAL WT. | 940.2 | 825.4 | 610.6 | 935.1 | SCW |
| INITIAL WT. | 778.0 | 715.8 | 603.8 | 907.3 | SCW |
| NET WT. | 162.2 | 109.6 | 6.8 | 27.8 | SCW |
| TOTAL WT. | 306.4 | note: all weights in grams | | | |

PARTICULATE FILTER CATCH

| | | | | | |
|---------------------|--------|-----------|-----------------|---------|-----------|
| FILTER # | 183 | BY | BEAKER # | 3 | BY |
| FINAL WT. | 0.4010 | SCW | FINAL WT. | 73.2929 | SCW |
| INITIAL WT. | 0.3865 | SCW | INITIAL WT. | 73.2808 | SCW |
| NET WT. | 0.0145 | SCW | NET WT. | 0.0121 | SCW |
| TOTAL CATCH (grams) | | | 0.0266 | | |
| TOTAL CATCH (mg) | | | 26.6 | | |

DRY MOLECULAR WEIGHT

| | | | | | |
|------------|------|------|------|------------|--|
| GAS | 1 | 2 | 3 | AVG | Fo: 1.123 |
| CO2 | 13.0 | 13.0 | 13.0 | 13.0 | ALLOWED Fo RANGE OIL: 1.210 TO 1.370 COAL: 1.083 TO 1.230 |
| O2+CO2 | 19.2 | 19.2 | 19.5 | ----- | |
| O2 | 6.2 | 6.2 | 6.5 | 6.3 | |

4 MINUTE ORSAT ANALYZER CHECK

| | | | |
|---------------------------|---------------|--------------|------------|
| | BEFORE | AFTER | |
| BURETTE MENISCUS READING: | 15 | 15 | <0.2 ? YES |
| CO2 CAPILLARY TUBE LEVEL: | OK | OK | |
| O2 CAPILLARY TUBE LEVEL: | OK | OK | |

**REFERENCE DATA
NO_x, SO₂ & CO**

NO_x LB/HR RELATIVE ACCURACY

PLANT: Indiantown Cogeneration
 UNIT: PC Boiler
 LOAD: High
 DATE: 7/16/2014

ANALYZER: TECO
 SERIAL # CM07260054

| RUN | TIME START | TIME END | REFERENCE METHOD (NO _x lb/hr) | CEM RESPONSE (NO _x lb/hr) | ARITHMATIC DIFFERENCE | DIFFERENCE SQUARED |
|-----|---------------|-------------|--|--|--------------------------|-----------------------|
| 1 | 1338 | 1358 | 485.38 | 526.38 | -40.999199 | 1680.93433 |
| 2 | 1410 | 1430 | 437.35 | 464.52 | -27.165964 | 737.98959 |
| 3 | 1440 | 1500 | 510.19 | 532.45 | -22.264472 | 495.70670 |
| 4 | 1510 | 1530 | 498.36 | 522.71 | -24.346268 | 592.74074 |
| 5 | 1540 | 1600 | 498.38 | 519.66 | -21.283515 | 452.98803 |
| 6 | 1610 | 1630 | 486.49 | 512.27 | -25.780217 | 664.61960 |
| 7 | 1640 | 1700 | 487.74 | 501.31 | -13.569897 | 184.14210 |
| 8 | 1721 | 1741 | 491.27 | 517.85 | -26.576904 | 706.33183 |
| 9 | 1750 | 1810 | 522.08 | 521.65 | 0.42648389 | 0.18189 |
| | | | AVERAGE | AVERAGE | SUM OF DIFF. | SUM OF THE SQUARES |
| | | | 490.8044 | 513.2000 | -201.55995 | 5515.63482 |

**MEAN DIFFERENCE, d (Eq. A-7) -22.5346
 **STANDARD DEVIATION, S_d (Eq. A-8) 11.1892
 **CONFIDENCE COEFFICIENT, $|CC|$ (Eq. A-9) 8.6008
 **PERCENT (%) RELATIVE ACCURACY, RA (Eq. A-10) 6.356

** 40 CFR 75, Appendix A

NOx LB/MMBTU RELATIVE ACCURACY

PLANT: Indiantown Cogeneration
 UNIT: PC Boiler
 LOAD: High
 DATE: 7/16/2014

ANALYZER: TECO
 SERIAL # CM07260054

| RUN | TIME START | TIME END | REFERENCE METHOD (NOxlb/mmBTU) | CEM RESPONSE (NOxlb/mmBTU) | ARITHMATIC DIFFERENCE | DIFFERENCE SQUARED |
|-----|------------|----------|-----------------------------------|-------------------------------|-----------------------|--------------------|
| 1 | 1338 | 1358 | 0.163 | 0.166 | -0.003 | 0.00001 |
| 2 | 1410 | 1430 | 0.144 | 0.146 | -0.0024 | 0.00001 |
| 3 | 1440 | 1500 | 0.165 | 0.168 | -0.003 | 0.00001 |
| 4 | 1510 | 1530 | 0.161 | 0.166 | -0.005 | 0.00003 |
| 5 | 1540 | 1600 | 0.162 | 0.163 | -0.0012 | 0.00000 |
| 6 | 1610 | 1630 | 0.159 | 0.162 | -0.0025 | 0.00001 |
| 7 | 1640 | 1700 | 0.157 | 0.157 | -0.0002 | 0.00000 |
| 8 | 1721 | 1741 | 0.167 | 0.162 | 0.0046 | 0.00002 |
| 9 | 1750 | 1810 | 0.167 | 0.163 | 0.004 | 0.00002 |
| | | | AVERAGE | AVERAGE | SUM OF DIFF. | SUM OF THE SQUARES |
| | | | 0.1606 | 0.1615 | -0.0087 | 0.00009 |

**MEAN DIFFERENCE, d (Eq. A-7) -0.0009
 **STANDARD DEVIATION, Sd (Eq. A-8) 0.0033
 **CONFIDENCE COEFFICIENT, |CC| (Eq. A-9) 0.0025

**PERCENT (%) RELATIVE ACCURACY, RA (Eq. A-10) 2.149

**BIAS ADJUSTMENT FACTOR, BAF (Eq. A-12) 1.000

** 40 CFR 75, Appendix A

SO2 LB/HR RELATIVE ACCURACY

PLANT: Indiantown Cogeneration
 UNIT: PC Boiler
 LOAD: High
 DATE: 7/16/2014

ANALYZER: TECO
 SERIAL # CM07260055

| RUN | TIME START | TIME END | REFERENCE METHOD (SO2 lb/hr) | CEM RESPONSE (SO2 lb/hr) | ARITHMATIC DIFFERENCE | DIFFERENCE SQUARED |
|-----|---------------|-------------|------------------------------------|--------------------------------|--------------------------|-----------------------|
| 1 | 1338 | 1358 | 324.79 | 349.50 | -24.715 | 610.809 |
| 2 | 1410 | 1430 | 323.31 | 351.02 | -27.707 | 767.703 |
| 3 | 1440 | 1500 | 412.73 | 443.15 | -30.420 | 925.368 |
| 4 | 1510 | 1530 | 407.19 | 424.65 | -17.456 | 304.705 |
| 5 | 1540 | 1600 | 330.05 | 350.76 | -20.714 | 429.077 |
| 6 | 1610 | 1630 | 297.26 | 312.87 | -15.612 | 243.738 |
| 7 | 1640 | 1700 | 310.54 | 322.89 | -12.352 | 152.570 |
| 8 | 1721 | 1741 | 335.92 | 355.44 | -19.519 | 381.006 |
| 9 | 1750 | 1810 | 336.78 | 340.85 | -4.067 | 16.542 |
| | | | AVERAGE | AVERAGE | SUM OF DIFF. | SUM OF THE SQUARES |
| | | | 342.0631 | 361.2367 | -172.56247 | 3831.5183 |

**MEAN DIFFERENCE, d (Eq. A-7) -18.9810

**STANDARD DEVIATION, S_d (Eq. A-8) 8.0845

**CONFIDENCE COEFFICIENT, $|CC|$ (Eq. A-9) 6.2143

**PERCENT (%) RELATIVE ACCURACY, RA (Eq. A-10)

7.333

**BIAS ADJUSTMENT FACTOR, BAF (Eq. A-12)

** 40 CFR 75, Appendix A

SO2 LB/MMBTU RELATIVE ACCURACY

PLANT: Indiantown Cogeneration
 UNIT: PC Boiler
 LOAD: High
 DATE: 7/16/2014

ANALYZER: TECO
 SERIAL # CM07260055

| RUN | TIME START | TIME END | REFERENCE METHOD (SO2 lb/mmbtu) | CEM RESPONSE (SO2 lb/mmbtu) | ARITHMATIC DIFFERENCE | DIFFERENCE SQUARED |
|-----|------------|----------|------------------------------------|--------------------------------|-----------------------|--------------------|
| 1 | 1338 | 1358 | 0.108 | 0.110 | -0.002 | 0.000004 |
| 2 | 1410 | 1430 | 0.106 | 0.111 | -0.005 | 0.000023 |
| 3 | 1440 | 1500 | 0.133 | 0.140 | -0.007 | 0.000042 |
| 4 | 1510 | 1530 | 0.131 | 0.134 | -0.003 | 0.000012 |
| 5 | 1540 | 1600 | 0.107 | 0.110 | -0.003 | 0.000010 |
| 6 | 1610 | 1630 | 0.097 | 0.099 | -0.002 | 0.000003 |
| 7 | 1640 | 1700 | 0.100 | 0.101 | -0.001 | 0.000002 |
| 8 | 1721 | 1741 | 0.114 | 0.112 | 0.003 | 0.000006 |
| 9 | 1750 | 1810 | 0.108 | 0.107 | 0.002 | 0.000002 |
| | | | AVERAGE | AVERAGE | SUM OF DIFF. | SUM OF THE SQUARES |
| | | | 0.1116 | 0.1137 | -0.019 | 0.000104 |

**MEAN DIFFERENCE, d (Eq. A-7) -0.0020
 **STANDARD DEVIATION, S_d (Eq. A-8) 0.002831078
 **CONFIDENCE COEFFICIENT, $|CC|$ (Eq. A-9) 0.002176155

**PERCENT (%) RELATIVE ACCURACY, RA (Eq. A-10) 3.702

**BIAS ADJUSTMENT FACTOR, BAF (Eq. A-12) 1.000

** 40 CFR 75, Appendix A

PC BOILER

DATE: 7/16/2014
 RUN: 1

| | |
|--------------------|-----------|
| CORRECTED O2 % | 6.78 |
| CORRECTED CO2 % | 12.81 |
| CORRECTED CO ppmvd | 64.33 |
| CO LB/DSCF | 4.877E-06 |
| CO LB/HR | 203.95 |

ANALYZER RESPONSE, SYSTEM BIAS AND SYSTEM DRIFT DATA

| RANGE SETTING | CAL GASES | CERTIFIED GAS VALUE | ANALYZER VALUE | DIFFERENCE PPM | % SPAN | ANALYZER PRETEST VALUE | % SPAN | ANALYZER POSTTEST VALUE | % SPAN | % DRIFT | ANALYZER SERIAL # |
|---------------|-----------|---------------------|----------------|----------------|--------|------------------------|--------|-------------------------|--------|---------|-------------------|
| 25 | % O2 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 01420/B425 |
| | | 11.90 | 11.90 | 0.00 | 0.00 | 11.90 | 0.00 | 11.90 | 0.00 | 0.00 | |
| | | 22.70 | 22.50 | -0.20 | -0.89 | | | | | | |
| 20 | % CO2 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | PO3048 |
| | | 8.42 | 8.40 | -0.02 | -0.12 | 8.40 | 0.00 | 8.40 | 0.00 | 0.00 | |
| | | 17.10 | 17.30 | 0.20 | 1.16 | | | | | | |
| 500 | PPM CO | 0.00 | 0.00 | 0.00 | 0.0 | 0.10 | 0.0 | 0.30 | 0.1 | 0.0 | 48C-71754-369 |
| | | 215.00 | 217 | 2.00 | 0.4 | 217 | 0.0 | 218.00 | 0.2 | 0.2 | |
| | | 497.00 | 494.00 | -3.00 | -0.6 | | | | | | |

UNCORRECTED RAW DATA

| DATE & TIME | O2 % | CO2 % | CO PPM |
|-----------------|------|-------|--------|
| 7/16/2014 13:38 | 7.15 | 12.06 | 33.63 |
| 7/16/2014 13:39 | 6.97 | 12.29 | 24.50 |
| 7/16/2014 13:40 | 7.00 | 12.26 | 32.88 |
| 7/16/2014 13:41 | 7.11 | 12.20 | 24.88 |
| 7/16/2014 13:42 | 7.06 | 12.27 | 34.25 |
| 7/16/2014 13:43 | 6.83 | 12.51 | 123.63 |
| 7/16/2014 13:44 | 6.71 | 12.63 | 182.50 |
| 7/16/2014 13:45 | 6.79 | 12.54 | 210.88 |
| 7/16/2014 13:46 | 6.54 | 12.79 | 74.00 |
| 7/16/2014 13:47 | 6.74 | 12.56 | 97.63 |
| 7/16/2014 13:48 | 6.97 | 12.34 | 23.50 |
| 7/16/2014 13:49 | 7.11 | 12.21 | 16.88 |
| 7/16/2014 13:50 | 7.03 | 12.35 | 12.25 |
| 7/16/2014 13:51 | 7.08 | 12.30 | 13.13 |
| 7/16/2014 13:52 | 6.81 | 12.53 | 11.75 |
| 7/16/2014 13:53 | 6.89 | 12.46 | 19.50 |
| 7/16/2014 13:54 | 6.89 | 12.49 | 26.75 |
| 7/16/2014 13:55 | 6.99 | 12.37 | 40.38 |
| 7/16/2014 13:56 | 7.10 | 12.28 | 28.63 |
| 7/16/2014 13:57 | 6.88 | 12.54 | 35.50 |
| 7/16/2014 13:58 | 6.59 | 12.74 | 69.50 |
| 7/16/2014 14:10 | 6.72 | 12.58 | 41.50 |
| 7/16/2014 14:11 | 6.64 | 12.69 | 50.13 |
| 7/16/2014 14:12 | 6.59 | 12.73 | 89.13 |
| 7/16/2014 14:13 | 6.67 | 12.69 | 102.38 |
| 7/16/2014 14:14 | 6.56 | 12.78 | 102.50 |
| 7/16/2014 14:15 | 6.65 | 12.70 | 94.13 |
| 7/16/2014 14:16 | 6.85 | 12.54 | 72.50 |
| 7/16/2014 14:17 | 6.79 | 12.58 | 56.63 |
| 7/16/2014 14:18 | 6.63 | 12.74 | 84.75 |
| 7/16/2014 14:19 | 6.70 | 12.70 | 98.25 |
| 7/16/2014 14:20 | 6.67 | 12.69 | 129.13 |
| 7/16/2014 14:21 | 6.70 | 12.71 | 85.38 |
| 7/16/2014 14:22 | 6.79 | 12.61 | 83.63 |
| 7/16/2014 14:23 | 6.68 | 12.73 | 47.38 |
| 7/16/2014 14:24 | 6.74 | 12.64 | 47.25 |
| 7/16/2014 14:25 | 6.81 | 12.59 | 62.13 |
| 7/16/2014 14:26 | 6.77 | 12.64 | 74.88 |
| 7/16/2014 14:27 | 6.62 | 12.80 | 95.63 |
| 7/16/2014 14:28 | 6.64 | 12.74 | 142.25 |
| 7/16/2014 14:29 | 6.71 | 12.70 | 116.25 |
| 7/16/2014 14:30 | 6.91 | 12.53 | 79.75 |
| 7/16/2014 14:40 | 6.69 | 12.58 | 100.63 |
| 7/16/2014 14:41 | 6.70 | 12.62 | 95.63 |
| 7/16/2014 14:42 | 6.77 | 12.59 | 57.75 |
| 7/16/2014 14:43 | 6.63 | 12.72 | 80.13 |
| 7/16/2014 14:44 | 6.71 | 12.67 | 63.88 |
| 7/16/2014 14:45 | 6.64 | 12.72 | 62.63 |
| 7/16/2014 14:46 | 6.61 | 12.76 | 69.63 |
| 7/16/2014 14:47 | 6.79 | 12.63 | 40.88 |
| 7/16/2014 14:48 | 6.63 | 12.75 | 62.13 |
| 7/16/2014 14:49 | 6.81 | 12.60 | 40.38 |
| 7/16/2014 14:50 | 6.71 | 12.71 | 40.50 |
| 7/16/2014 14:51 | 6.69 | 12.70 | 54.00 |
| 7/16/2014 14:52 | 6.53 | 12.88 | 52.13 |
| 7/16/2014 14:53 | 6.50 | 12.89 | 71.38 |
| 7/16/2014 14:54 | 6.80 | 12.63 | 40.88 |
| 7/16/2014 14:55 | 6.73 | 12.69 | 28.13 |
| 7/16/2014 14:56 | 6.86 | 12.54 | 30.50 |
| 7/16/2014 14:57 | 6.85 | 12.57 | 32.25 |

MEAN ANALYZER VALUES

| | |
|---------------|-------|
| Avg. % O2 | 6.78 |
| Avg. % CO2 | 12.58 |
| Avg. CO ppmvd | 65.22 |

PC BOILER

DATE: 7/16/2014
 RUN: 2

| | |
|--------------------|-----------|
| CORRECTED O2 % | 6.79 |
| CORRECTED CO2 % | 12.63 |
| CORRECTED CO ppmvd | 106.60 |
| CO LB/DSCF | 7.677E-06 |
| CO LB/HR | 341.64 |

ANALYZER RESPONSE, SYSTEM BIAS AND SYSTEM DRIFT DATA

| RANGE SETTING | CAL GASES | CERTIFIED GAS VALUE | ANALYZER VALUE | DIFFERENCE PPM | % SPAN | ANALYZER PRETEST VALUE | % SPAN | ANALYZER POSTTEST VALUE | % SPAN | % DRIFT | ANALYZER SERIAL # |
|---------------|-----------|---------------------|----------------|----------------|--------|------------------------|--------|-------------------------|--------|---------|-------------------|
| 25 | % O2 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 01420/B425 |
| | | 11.90 | 11.90 | 0.00 | 0.00 | 11.90 | 0.00 | 11.90 | 0.00 | 0.00 | |
| | | 22.70 | 22.50 | -0.20 | -0.89 | | | | | | |
| 20 | % CO2 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.10 | 0.58 | 0.58 | PC3048 |
| | | 8.42 | 8.40 | -0.02 | -0.12 | 8.40 | 0.00 | 8.40 | 0.00 | 0.00 | |
| | | 17.10 | 17.30 | 0.20 | 1.16 | | | | | | |
| 500 | PPM CO | 0.00 | 0.00 | 0.00 | 0.0 | 0.30 | 0.1 | 0.40 | 0.1 | 0.0 | 48C-71754-389 |
| | | 215.00 | 217.00 | 2.00 | 0.4 | 218.00 | 0.2 | 219.00 | 0.4 | 0.2 | |
| | | 497.00 | 494.00 | -3.00 | -0.6 | | | | | | |

UNCORRECTED RAW DATA

| DATE & TIME | O2 % | CO2 % | CO PPM |
|-----------------|------|-------|--------|
| 7/16/2014 15:10 | 6.79 | 12.63 | 47.38 |
| 7/16/2014 15:11 | 6.79 | 12.60 | 46.75 |
| 7/16/2014 15:12 | 6.03 | 12.81 | 45.75 |
| 7/16/2014 15:13 | 6.71 | 12.73 | 83.38 |
| 7/16/2014 15:14 | 6.64 | 12.82 | 65.13 |
| 7/16/2014 15:15 | 6.61 | 12.83 | 89.38 |
| 7/16/2014 15:16 | 6.64 | 12.80 | 236.00 |
| 7/16/2014 15:17 | 6.84 | 12.61 | 124.75 |
| 7/16/2014 15:18 | 6.76 | 12.68 | 117.50 |
| 7/16/2014 15:19 | 6.86 | 12.58 | 134.63 |
| 7/16/2014 15:20 | 6.68 | 12.71 | 140.50 |
| 7/16/2014 15:21 | 6.73 | 12.68 | 151.25 |
| 7/16/2014 15:22 | 6.73 | 12.68 | 110.88 |
| 7/16/2014 15:23 | 6.71 | 12.68 | 171.88 |
| 7/16/2014 15:24 | 6.71 | 12.69 | 151.63 |
| 7/16/2014 15:25 | 6.79 | 12.61 | 139.88 |
| 7/16/2014 15:26 | 6.73 | 12.66 | 161.50 |
| 7/16/2014 15:27 | 6.77 | 12.64 | 306.50 |
| 7/16/2014 15:28 | 6.71 | 12.71 | 166.88 |
| 7/16/2014 15:29 | 6.72 | 12.69 | 157.38 |
| 7/16/2014 15:30 | 6.77 | 12.66 | 209.38 |
| 7/16/2014 15:40 | 6.83 | 12.38 | 119.38 |
| 7/16/2014 15:41 | 6.69 | 12.45 | 235.38 |
| 7/16/2014 15:42 | 6.88 | 12.33 | 128.00 |
| 7/16/2014 15:43 | 6.65 | 12.54 | 154.63 |
| 7/16/2014 15:44 | 6.61 | 12.57 | 151.00 |
| 7/16/2014 15:45 | 6.76 | 12.42 | 165.63 |
| 7/16/2014 15:46 | 6.85 | 12.34 | 109.38 |
| 7/16/2014 15:47 | 6.64 | 12.33 | 83.38 |
| 7/16/2014 15:48 | 6.83 | 12.32 | 83.88 |
| 7/16/2014 15:49 | 6.87 | 12.26 | 106.50 |
| 7/16/2014 15:50 | 6.76 | 12.38 | 133.63 |
| 7/16/2014 15:51 | 6.68 | 12.47 | 88.38 |
| 7/16/2014 15:52 | 6.71 | 12.41 | 106.13 |
| 7/16/2014 15:53 | 6.88 | 12.24 | 113.63 |
| 7/16/2014 15:54 | 7.03 | 12.14 | 82.63 |
| 7/16/2014 15:55 | 6.79 | 12.38 | 83.00 |
| 7/16/2014 15:56 | 6.79 | 12.33 | 113.00 |
| 7/16/2014 15:57 | 6.86 | 12.29 | 94.25 |
| 7/16/2014 15:58 | 6.68 | 12.46 | 81.50 |
| 7/16/2014 15:59 | 6.76 | 12.39 | 77.63 |
| 7/16/2014 16:00 | 6.87 | 12.28 | 81.25 |
| 7/16/2014 16:10 | 6.75 | 12.42 | 93.63 |
| 7/16/2014 16:11 | 7.02 | 12.18 | 55.13 |
| 7/16/2014 16:12 | 6.94 | 12.25 | 34.75 |
| 7/16/2014 16:13 | 6.83 | 12.38 | 57.00 |
| 7/16/2014 16:14 | 6.79 | 12.37 | 57.25 |
| 7/16/2014 16:15 | 6.92 | 12.27 | 61.38 |
| 7/16/2014 16:16 | 7.01 | 12.19 | 52.75 |
| 7/16/2014 16:17 | 6.91 | 12.28 | 62.88 |
| 7/16/2014 16:18 | 6.96 | 12.25 | 66.38 |
| 7/16/2014 16:19 | 6.92 | 12.29 | 70.38 |
| 7/16/2014 16:20 | 6.77 | 12.45 | 112.50 |
| 7/16/2014 16:21 | 6.69 | 12.51 | 114.13 |
| 7/16/2014 16:22 | 6.74 | 12.49 | 55.00 |
| 7/16/2014 16:23 | 6.84 | 12.34 | 75.00 |
| 7/16/2014 16:24 | 7.02 | 12.23 | 46.88 |
| 7/16/2014 16:25 | 6.73 | 12.50 | 49.88 |
| 7/16/2014 16:26 | 6.81 | 12.41 | 57.25 |
| 7/16/2014 16:27 | 6.83 | 12.40 | 78.50 |

MEAN ANALYZER VALUES

| | |
|---------------|--------|
| Avg. % O2 | 6.79 |
| Avg. % CO2 | 12.47 |
| Avg. CO ppmvd | 107.50 |

PC BOILER

DATE: 7/16/2014
 RUN: 3

| | |
|--------------------|-----------|
| CORRECTED O2 % | 6.97 |
| CORRECTED CO2 % | 12.09 |
| CORRECTED CO ppmvd | 82.53 |
| CO LB/DSCF | 6.000E-06 |
| CO LB/HR | 276.39 |

ANALYZER RESPONSE, SYSTEM BIAS AND SYSTEM DRIFT DATA

| RANGE SETTING | CAL GASES | CERTIFIED GAS VALUE | ANALYZER VALUE | DIFFERENCE PPM | % SPAN | ANALYZER PRETEST VALUE | % SPAN | ANALYZER POSTTEST VALUE | % SPAN | % DRIFT | ANALYZER SERIAL # |
|---------------|-----------|---------------------|----------------|----------------|--------|------------------------|--------|-------------------------|--------|---------|-------------------|
| 25 | % O2 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 01420/B425 |
| | | 11.90 | 11.90 | 0.00 | 0.00 | 11.90 | 0.00 | 11.90 | 0.00 | 0.00 | |
| | | 22.70 | 22.50 | -0.20 | -0.89 | | | | | | |
| 20 | % CO2 | 0.00 | 0.00 | 0.00 | 0.00 | 0.10 | 0.58 | 0.10 | 0.58 | 0.00 | PC3048 |
| | | 8.42 | 8.40 | -0.02 | -0.12 | 8.40 | 0.00 | 8.50 | 0.58 | 0.58 | |
| | | 17.10 | 17.30 | 0.20 | 1.16 | | | | | | |
| 500 | PPM CO | 0.00 | 0.00 | 0.00 | 0.0 | 0.40 | 0.1 | 0.50 | 0.1 | 0.0 | 48C-71754-369 |
| | | 215.00 | 217.00 | 2.00 | 0.4 | 219.00 | 0.4 | 220.00 | 0.8 | 0.2 | |
| | | 497.00 | 494.00 | -3.00 | -0.6 | | | | | | |

UNCORRECTED RAW DATA

| DATE & TIME | O2 % | CO2 % | CO PPM |
|-----------------|------|-------|--------|
| 7/16/2014 16:40 | 6.93 | 12.34 | 163.50 |
| 7/16/2014 16:41 | 6.92 | 12.32 | 197.38 |
| 7/16/2014 16:42 | 7.07 | 12.20 | 120.00 |
| 7/16/2014 16:43 | 7.25 | 12.05 | 115.00 |
| 7/16/2014 16:44 | 6.99 | 12.20 | 88.00 |
| 7/16/2014 16:45 | 6.88 | 12.31 | 41.00 |
| 7/16/2014 16:46 | 6.96 | 12.27 | 53.88 |
| 7/16/2014 16:47 | 6.89 | 12.29 | 105.50 |
| 7/16/2014 16:48 | 6.94 | 12.28 | 55.63 |
| 7/16/2014 16:49 | 6.89 | 12.35 | 51.88 |
| 7/16/2014 16:50 | 6.88 | 12.33 | 60.75 |
| 7/16/2014 16:51 | 6.91 | 12.31 | 47.38 |
| 7/16/2014 16:52 | 7.01 | 12.20 | 58.38 |
| 7/16/2014 16:53 | 6.97 | 12.26 | 49.38 |
| 7/16/2014 16:54 | 6.81 | 12.38 | 62.38 |
| 7/16/2014 16:55 | 6.83 | 12.34 | 103.00 |
| 7/16/2014 16:56 | 7.00 | 12.20 | 94.00 |
| 7/16/2014 16:57 | 6.92 | 12.28 | 77.98 |
| 7/16/2014 16:58 | 6.97 | 12.24 | 47.00 |
| 7/16/2014 16:59 | 7.00 | 12.20 | 68.38 |
| 7/16/2014 17:00 | 6.96 | 12.23 | 56.63 |
| 7/16/2014 17:21 | 6.48 | 12.45 | 217.88 |
| 7/16/2014 17:22 | 6.99 | 11.06 | 214.63 |
| 7/16/2014 17:23 | 6.99 | 11.98 | 77.38 |
| 7/16/2014 17:24 | 6.89 | 12.08 | 109.88 |
| 7/16/2014 17:25 | 6.98 | 11.99 | 99.25 |
| 7/16/2014 17:26 | 6.88 | 12.08 | 156.50 |
| 7/16/2014 17:27 | 7.34 | 11.64 | 83.63 |
| 7/16/2014 17:28 | 7.41 | 11.63 | 25.25 |
| 7/16/2014 17:29 | 7.19 | 11.84 | 20.25 |
| 7/16/2014 17:30 | 6.74 | 12.18 | 103.13 |
| 7/16/2014 17:31 | 6.63 | 12.31 | 115.25 |
| 7/16/2014 17:32 | 6.76 | 12.13 | 201.38 |
| 7/16/2014 17:33 | 7.17 | 11.81 | 78.88 |
| 7/16/2014 17:34 | 6.92 | 12.05 | 56.50 |
| 7/16/2014 17:35 | 7.06 | 11.92 | 56.63 |
| 7/16/2014 17:36 | 6.98 | 12.01 | 36.50 |
| 7/16/2014 17:37 | 6.83 | 12.12 | 136.25 |
| 7/16/2014 17:38 | 6.95 | 12.04 | 81.50 |
| 7/16/2014 17:39 | 6.97 | 12.00 | 47.63 |
| 7/16/2014 17:40 | 6.81 | 12.14 | 102.98 |
| 7/16/2014 17:41 | 6.94 | 12.03 | 63.38 |
| 7/16/2014 17:50 | 7.03 | 11.95 | 31.75 |
| 7/16/2014 17:51 | 7.04 | 11.94 | 31.00 |
| 7/16/2014 17:52 | 7.16 | 11.83 | 27.13 |
| 7/16/2014 17:53 | 6.94 | 12.01 | 30.83 |
| 7/16/2014 17:54 | 6.99 | 11.98 | 49.63 |
| 7/16/2014 17:55 | 6.89 | 12.07 | 63.25 |
| 7/16/2014 17:56 | 6.87 | 12.04 | 122.13 |
| 7/16/2014 17:57 | 6.99 | 11.98 | 71.25 |
| 7/16/2014 17:58 | 6.91 | 12.04 | 31.38 |
| 7/16/2014 17:59 | 6.97 | 11.97 | 47.75 |
| 7/16/2014 18:00 | 6.83 | 12.16 | 71.75 |
| 7/16/2014 18:01 | 6.37 | 12.51 | 287.00 |
| 7/16/2014 18:02 | 7.14 | 11.84 | 131.50 |
| 7/16/2014 18:03 | 7.31 | 11.68 | 42.25 |
| 7/16/2014 18:04 | 7.39 | 11.63 | 31.50 |
| 7/16/2014 18:05 | 7.16 | 11.80 | 44.63 |
| 7/16/2014 18:06 | 7.06 | 11.90 | 95.13 |
| 7/16/2014 18:07 | 7.01 | 11.84 | 91.50 |

MEAN ANALYZER VALUES

| | |
|---------------|-------|
| Avg. % O2 | 6.97 |
| Avg. % CO2 | 12.08 |
| Avg. CO ppmvd | 84.53 |

REFERENCE DATA
Visible Emissions



Coastal Air Consulting, Inc.

(386) 451-0169

VISIBLE EMISSION TEST

Method (Circle One) Method B 203A 203B Report V-11

Company Name **Indiantown Cogeneration LP**

Facility Name **Indiantown Cogen**

Street Address **13303 Silver Fox Lane**

City **Indiantown** Zip **34956**

Phone No. **(772) 597-6500**

Process PC Boiler Unit # EU-004 Operating Mode Normal

Control Equipment Baghouses Operating Mode Normal

Describe Emission Point Circular Stack

Ht of Emis. Point 500 ft. Ht Ref to Observer 500 ft.

Distance to Emis. Pt. 1500 ft. Direction to Emis. Pt (Degrees) 130°

Vertical Angle to Obs. < 18° Direction to Obs. Pt. (Degrees) 130°

Distance and Direction to Obs. Pt from Emission Pt JAME

Describe Emissions None


Emission Color N/A Water Droplet Plume Attached Detached None X

Describe Plume Background Grey Sky

Background Color Grey Sky Conditions Overcast

Wind Speed 4 MPH Wind Direction West

Ambient Temp. 84 Wet Bulb Temp. % RH 77



Latitude 27° 2' 18" Longitude 80° 31' 15" Declination

Comments

| Observation Date <u>7.17.14</u> | | | | | Start Time <u>14:20</u> | | | | | Stop Time <u>15:20</u> | | | | |
|---------------------------------|---|----|----|----|-------------------------|---|----|----|----|------------------------|---|----|----|----|
| Min | 0 | 15 | 30 | 45 | Min | 0 | 15 | 30 | 45 | Min | 0 | 15 | 30 | 45 |
| 1 | 0 | 0 | 0 | 0 | 31 | 0 | 0 | 0 | 0 | | | | | |
| 2 | 0 | 0 | 0 | 0 | 32 | 0 | 0 | 0 | 0 | | | | | |
| 3 | 0 | 0 | 0 | 0 | 33 | 0 | 0 | 0 | 0 | | | | | |
| 4 | 0 | 0 | 0 | 0 | 34 | 0 | 0 | 0 | 0 | | | | | |
| 5 | 0 | 0 | 0 | 0 | 35 | 0 | 0 | 0 | 0 | | | | | |
| 6 | 0 | 0 | 0 | 0 | 36 | 0 | 0 | 0 | 0 | | | | | |
| 7 | 0 | 0 | 0 | 0 | 37 | 0 | 0 | 0 | 0 | | | | | |
| 8 | 0 | 0 | 0 | 0 | 38 | 0 | 0 | 0 | 0 | | | | | |
| 9 | 0 | 0 | 0 | 0 | 39 | 0 | 0 | 0 | 0 | | | | | |
| 10 | 0 | 0 | 0 | 0 | 40 | 0 | 0 | 0 | 0 | | | | | |
| 11 | 0 | 0 | 0 | 0 | 41 | 0 | 0 | 0 | 0 | | | | | |
| 12 | 0 | 0 | 0 | 0 | 42 | 0 | 0 | 0 | 0 | | | | | |
| 13 | 0 | 0 | 0 | 0 | 43 | 0 | 0 | 0 | 0 | | | | | |
| 14 | 0 | 0 | 0 | 0 | 44 | 0 | 0 | 0 | 0 | | | | | |
| 15 | 0 | 0 | 0 | 0 | 45 | 0 | 0 | 0 | 0 | | | | | |
| 16 | 0 | 0 | 0 | 0 | 46 | 0 | 0 | 0 | 0 | | | | | |
| 17 | 0 | 0 | 0 | 0 | 47 | 0 | 0 | 0 | 0 | | | | | |
| 18 | 0 | 0 | 0 | 0 | 48 | 0 | 0 | 0 | 0 | | | | | |
| 19 | 0 | 0 | 0 | 0 | 49 | 0 | 0 | 0 | 0 | | | | | |
| 20 | 0 | 0 | 0 | 0 | 50 | 0 | 0 | 0 | 0 | | | | | |
| 21 | 0 | 0 | 0 | 0 | 51 | 0 | 0 | 0 | 0 | | | | | |
| 22 | 0 | 0 | 0 | 0 | 52 | 0 | 0 | 0 | 0 | | | | | |
| 23 | 0 | 0 | 0 | 0 | 53 | 0 | 0 | 0 | 0 | | | | | |
| 24 | 0 | 0 | 0 | 0 | 54 | 0 | 0 | 0 | 0 | | | | | |
| 25 | 0 | 0 | 0 | 0 | 55 | 0 | 0 | 0 | 0 | | | | | |
| 26 | 0 | 0 | 0 | 0 | 56 | 0 | 0 | 0 | 0 | | | | | |
| 27 | 0 | 0 | 0 | 0 | 57 | 0 | 0 | 0 | 0 | | | | | |
| 28 | 0 | 0 | 0 | 0 | 58 | 0 | 0 | 0 | 0 | | | | | |
| 29 | 0 | 0 | 0 | 0 | 59 | 0 | 0 | 0 | 0 | | | | | |
| 30 | 0 | 0 | 0 | 0 | 60 | 0 | 0 | 0 | 0 | | | | | |

Number of Readings Above 0 were 0 Average Opacity for Highest 6 Min Period 0

Range of opacity Readings Min 0 Max 0 Average Opacity for 2nd Highest 6 Min 0

Observers Name (Print) Quin Tene

Observers Signature [Signature] Date 7.17.14

Organization Coastal Air Consulting, Inc.

Certified By Whitlow Enterprises Date 7.11.14



Coastal Air Consulting, Inc.

(386) 451-0169

VISIBLE EMISSION TEST

Method Used (Circle One) 9 203A 203B Report V-6

Company Name Indiantown Cogeneration LP

Facility Name Indiantown Cogen

Street Address 13303 Silver Fox Lane

City Indiantown Zip 34956

Phone No. (772) 597-6500

Process Coal Pulverizer Unit # 2U-004 Operating Mode Normal

Control Equipment Bashouse Operating Mode Normal

Describe Emission Point 9th Floor Walk Port

Ht of Emis. Point 130' Ht Rel to Observer 130'

Distance to Emis. Pt. 1400' Direction to Emis. Pt (Degrees) 30°

Vehicle Angle to Obs. < 18° Direction to Obs. Pt. (Degrees) 30°

Distance and Direction to Obs. Pt from Emission Pt Same

Describe Emissions NONE


Emission Color N/A Water Droplet Plume Attached Detached None X

Describe Plume Background Buildings

Background Color Blue Sky Conditions Scattered/overcast

Wind Speed 4 MPH Wind Direction SE

Ambient Temp. 74 Wet Bulb Temp. % RH 95



Latitude 27° 2' 19" Longitude 80° 31' 2" Declination

Comments

| Observation Date <u>7-16-14</u> | | | | | Start Time <u>1306</u> | | | | | Stop Time <u>1706</u> | | | | |
|---------------------------------|---|----|----|----|------------------------|---|----|----|----|-----------------------|--|--|--|--|
| Min | 0 | 15 | 30 | 45 | Min | 0 | 15 | 30 | 45 | | | | | |
| 1 | 0 | 0 | 0 | 0 | 31 | 0 | 0 | 0 | 0 | | | | | |
| 2 | 0 | 0 | 0 | 0 | 32 | 0 | 0 | 0 | 0 | | | | | |
| 3 | 0 | 0 | 0 | 0 | 33 | 0 | 0 | 0 | 0 | | | | | |
| 4 | 0 | 0 | 0 | 0 | 34 | 0 | 0 | 0 | 0 | | | | | |
| 5 | 0 | 0 | 0 | 0 | 35 | 0 | 0 | 0 | 0 | | | | | |
| 6 | 0 | 0 | 0 | 0 | 36 | 0 | 0 | 0 | 0 | | | | | |
| 7 | 0 | 0 | 0 | 0 | 37 | 0 | 0 | 0 | 0 | | | | | |
| 8 | 0 | 0 | 0 | 0 | 38 | 0 | 0 | 0 | 0 | | | | | |
| 9 | 0 | 0 | 0 | 0 | 39 | 0 | 0 | 0 | 0 | | | | | |
| 10 | 0 | 0 | 0 | 0 | 40 | 0 | 0 | 0 | 0 | | | | | |
| 11 | 0 | 0 | 0 | 0 | 41 | 0 | 0 | 0 | 0 | | | | | |
| 12 | 0 | 0 | 0 | 0 | 42 | 0 | 0 | 0 | 0 | | | | | |
| 13 | 0 | 0 | 0 | 0 | 43 | 0 | 0 | 0 | 0 | | | | | |
| 14 | 0 | 0 | 0 | 0 | 44 | 0 | 0 | 0 | 0 | | | | | |
| 15 | 0 | 0 | 0 | 0 | 45 | 0 | 0 | 0 | 0 | | | | | |
| 16 | 0 | 0 | 0 | 0 | 46 | 0 | 0 | 0 | 0 | | | | | |
| 17 | 0 | 0 | 0 | 0 | 47 | 0 | 0 | 0 | 0 | | | | | |
| 18 | 0 | 0 | 0 | 0 | 48 | 0 | 0 | 0 | 0 | | | | | |
| 19 | 0 | 0 | 0 | 0 | 49 | 0 | 0 | 0 | 0 | | | | | |
| 20 | 0 | 0 | 0 | 0 | 50 | 0 | 0 | 0 | 0 | | | | | |
| 21 | 0 | 0 | 0 | 0 | 51 | 0 | 0 | 0 | 0 | | | | | |
| 22 | 0 | 0 | 0 | 0 | 52 | 0 | 0 | 0 | 0 | | | | | |
| 23 | 0 | 0 | 0 | 0 | 53 | 0 | 0 | 0 | 0 | | | | | |
| 24 | 0 | 0 | 0 | 0 | 54 | 0 | 0 | 0 | 0 | | | | | |
| 25 | 0 | 0 | 0 | 0 | 55 | 0 | 0 | 0 | 0 | | | | | |
| 26 | 0 | 0 | 0 | 0 | 56 | 0 | 0 | 0 | 0 | | | | | |
| 27 | 0 | 0 | 0 | 0 | 57 | 0 | 0 | 0 | 0 | | | | | |
| 28 | 0 | 0 | 0 | 0 | 58 | 0 | 0 | 0 | 0 | | | | | |
| 29 | 0 | 0 | 0 | 0 | 59 | 0 | 0 | 0 | 0 | | | | | |
| 30 | 0 | 0 | 0 | 0 | 60 | 0 | 0 | 0 | 0 | | | | | |

Number of Readings Above were 0 Average Opacity for Highest 6 Min Period 0

Range of opacity Readings Min 0 Max 0 Average Opacity for 2nd Highest 6 Min 0

Observers Name (Print) Quin Revel

Observers Signature QR Date 7-16-14

Organization Coastal Air Consulting, Inc.

Certified By Whitlow Enterprises Date 7-11-14



Coastal Air Consulting, Inc.

(386) 451-0169

V-3

VISIBLE EMISSION TEST

Method (1) (Circle One)
 Method 9 203A 203B Report V-3

Company Name Indiantown Cogeneration LP

Facility Name Indiantown Cogen

Street Address 13303 Silver Fox Lane

City Indiantown Zip 34956

Phone No. (772) 597-6500

Process Power Calc / Lusher Unit # EU-004 Operating Mode Normal

Control Equipment Bag house Operating Mode Normal

Describe Emission Point Vertical Square Stack

Ht of Emiss. Point 15 ft. Ht Rel to Observer 15 ft.

Distance to Emiss. Pt. 45 ft. Direction to Emiss. Pt (Degrees) 248°

Vehicle Angle to Obs. < 18° Direction to Obs. Pt. (Degrees) 248°

Distance and Direction to Obs. Pt from Emission Pt 45 ft.

Describe Emissions NONE


Emission Color N/A Water Droplet Plume Attached Detached None X

Describe Plume Background Wall of Buildings

Background Color Grey/Blue Sky Conditions Scattered

Wind Speed 8 MPH Wind Direction VSW

Ambient Temp. 85° Wet Bulb Temp. % RH 30%



Latitude 27° 2' 21" N Longitude 80° 30' 59" W Declination

Comments

| Observation Date | | | | | Start Time | | | | | Stop Time | | | | |
|------------------|---|----|----|----|------------|---|----|----|----|-----------|---|----|----|----|
| 7-16-14 | | | | | 0:45 | | | | | 11:45 | | | | |
| Min | 0 | 15 | 30 | 45 | Min | 0 | 15 | 30 | 45 | Min | 0 | 15 | 30 | 45 |
| 1 | 0 | 0 | 0 | 0 | 31 | 0 | 0 | 0 | 0 | | | | | |
| 2 | 0 | 0 | 0 | 0 | 32 | 0 | 0 | 0 | 0 | | | | | |
| 3 | 0 | 0 | 0 | 0 | 33 | 0 | 0 | 0 | 0 | | | | | |
| 4 | 0 | 0 | 0 | 0 | 34 | 0 | 0 | 0 | 0 | | | | | |
| 5 | 0 | 0 | 0 | 0 | 35 | 0 | 0 | 0 | 0 | | | | | |
| 6 | 0 | 0 | 0 | 0 | 36 | 0 | 0 | 0 | 0 | | | | | |
| 7 | 0 | 0 | 0 | 0 | 37 | 0 | 0 | 0 | 0 | | | | | |
| 8 | 0 | 0 | 0 | 0 | 38 | 0 | 0 | 0 | 0 | | | | | |
| 9 | 0 | 0 | 0 | 0 | 39 | 0 | 0 | 0 | 0 | | | | | |
| 10 | 0 | 0 | 0 | 0 | 40 | 0 | 0 | 0 | 0 | | | | | |
| 11 | 0 | 0 | 0 | 0 | 41 | 0 | 0 | 0 | 0 | | | | | |
| 12 | 0 | 0 | 0 | 0 | 42 | 0 | 0 | 0 | 0 | | | | | |
| 13 | 0 | 0 | 0 | 0 | 43 | 0 | 0 | 0 | 0 | | | | | |
| 14 | 0 | 0 | 0 | 0 | 44 | 0 | 0 | 0 | 0 | | | | | |
| 15 | 0 | 0 | 0 | 0 | 45 | 0 | 0 | 0 | 0 | | | | | |
| 16 | 0 | 0 | 0 | 0 | 46 | 0 | 0 | 0 | 0 | | | | | |
| 17 | 0 | 0 | 0 | 0 | 47 | 0 | 0 | 0 | 0 | | | | | |
| 18 | 0 | 0 | 0 | 0 | 48 | 0 | 0 | 0 | 0 | | | | | |
| 19 | 0 | 0 | 0 | 0 | 49 | 0 | 0 | 0 | 0 | | | | | |
| 20 | 0 | 0 | 0 | 0 | 50 | 0 | 0 | 0 | 0 | | | | | |
| 21 | 0 | 0 | 0 | 0 | 51 | 0 | 0 | 0 | 0 | | | | | |
| 22 | 0 | 0 | 0 | 0 | 52 | 0 | 0 | 0 | 0 | | | | | |
| 23 | 0 | 0 | 0 | 0 | 53 | 0 | 0 | 0 | 0 | | | | | |
| 24 | 0 | 0 | 0 | 0 | 54 | 0 | 0 | 0 | 0 | | | | | |
| 25 | 0 | 0 | 0 | 0 | 55 | 0 | 0 | 0 | 0 | | | | | |
| 26 | 0 | 0 | 0 | 0 | 56 | 0 | 0 | 0 | 0 | | | | | |
| 27 | 0 | 0 | 0 | 0 | 57 | 0 | 0 | 0 | 0 | | | | | |
| 28 | 0 | 0 | 0 | 0 | 58 | 0 | 0 | 0 | 0 | | | | | |
| 29 | 0 | 0 | 0 | 0 | 59 | 0 | 0 | 0 | 0 | | | | | |
| 30 | 0 | 0 | 0 | 0 | 60 | 0 | 0 | 0 | 0 | | | | | |

Number of Readings Above 0 were 0 Average Opacity for Highest 6 Min Period 0

Range of opacity Readings Min 0 Max 0 Average Opacity for 2nd Highest 6 Min 0

Observers Name (Print) Quin Reuel

Observers Signature Quin Reuel Date 7/16/14

Organization Coastal Air Consulting, Inc.

Certified By Whitlow Enterprises Date 7/11/14



Coastal Air Consulting, Inc.

(386) 451-0169

VISIBLE EMISSION TEST

Method Used (Circle One)
 Method 2 203A 203B Report V-5

Company Name **Indiantown Cogeneration LP**

Facility Name **Indiantown Cogen**

Street Address **13303 Silver Fox Lane**

City **Indiantown** Zip **34956**

Phone No. **(772) 597-6500**

Process **Coal Transfer** Unit # **EU-004** Operating Mode **Normal**

Control Equipment **Rash house** Operating Mode **Normal**

Describe Emission Point **Vertical Spore Stack**

Ht of Emis. Point **15'** Ht Obs to Observer **15'**

Distance to Emis. Pt. **50'** Direction to Emis. Pt (Degrees) **280°**

Vertical Angle to Obs. **< 18°** Direction to Obs. Pt. (Degrees) **280°**

Distance and Direction to Obs. Pt from Emission Pt **Same**

Describe Emissions **None**


Emission Color **N/A** Water Droplet Plume Attached Detached **None**

Describe Plume Background **Grey Building**

Background Color **Grey** Sky Conditions **Scattered / overcast**

Wind Speed **4 MPH** Wind Direction **SE**

Ambient Temp. **74°** Wet Bulb Temp. % RH **95**



Latitude **27° 2' 19"** Longitude **80° 31' 2"** Declination

Comments

| Observation Date 7-16-14 | | | | Start Time 1305 | | | | Stop Time 1405 | | | |
|---------------------------------|---|----|----|------------------------|-----|---|----|-----------------------|----|--|--|
| Min | 0 | 15 | 30 | 45 | Min | 0 | 15 | 30 | 45 | | |
| 1 | 0 | 0 | 0 | 0 | 31 | 0 | 0 | 0 | 0 | | |
| 2 | 0 | 0 | 0 | 0 | 32 | 0 | 0 | 0 | 0 | | |
| 3 | 0 | 0 | 0 | 0 | 33 | 0 | 0 | 0 | 0 | | |
| 4 | 0 | 0 | 0 | 0 | 34 | 0 | 0 | 0 | 0 | | |
| 5 | 0 | 0 | 0 | 0 | 35 | 0 | 0 | 0 | 0 | | |
| 6 | 0 | 0 | 0 | 0 | 36 | 0 | 0 | 0 | 0 | | |
| 7 | 0 | 0 | 0 | 0 | 37 | 0 | 0 | 0 | 0 | | |
| 8 | 0 | 0 | 0 | 0 | 38 | 0 | 0 | 0 | 0 | | |
| 9 | 0 | 0 | 0 | 0 | 39 | 0 | 0 | 0 | 0 | | |
| 10 | 0 | 0 | 0 | 0 | 40 | 0 | 0 | 0 | 0 | | |
| 11 | 0 | 0 | 0 | 0 | 41 | 0 | 0 | 0 | 0 | | |
| 12 | 0 | 0 | 0 | 0 | 42 | 0 | 0 | 0 | 0 | | |
| 13 | 0 | 0 | 0 | 0 | 43 | 0 | 0 | 0 | 0 | | |
| 14 | 0 | 0 | 0 | 0 | 44 | 0 | 0 | 0 | 0 | | |
| 15 | 0 | 0 | 0 | 0 | 45 | 0 | 0 | 0 | 0 | | |
| 16 | 0 | 0 | 0 | 0 | 46 | 0 | 0 | 0 | 0 | | |
| 17 | 0 | 0 | 0 | 0 | 47 | 0 | 0 | 0 | 0 | | |
| 18 | 0 | 0 | 0 | 0 | 48 | 0 | 0 | 0 | 0 | | |
| 19 | 0 | 0 | 0 | 0 | 49 | 0 | 0 | 0 | 0 | | |
| 20 | 0 | 0 | 0 | 0 | 50 | 0 | 0 | 0 | 0 | | |
| 21 | 0 | 0 | 0 | 0 | 51 | 0 | 0 | 0 | 0 | | |
| 22 | 0 | 0 | 0 | 0 | 52 | 0 | 0 | 0 | 0 | | |
| 23 | 0 | 0 | 0 | 0 | 53 | 0 | 0 | 0 | 0 | | |
| 24 | 0 | 0 | 0 | 0 | 54 | 0 | 0 | 0 | 0 | | |
| 25 | 0 | 0 | 0 | 0 | 55 | 0 | 0 | 0 | 0 | | |
| 26 | 0 | 0 | 0 | 0 | 56 | 0 | 0 | 0 | 0 | | |
| 27 | 0 | 0 | 0 | 0 | 57 | 0 | 0 | 0 | 0 | | |
| 28 | 0 | 0 | 0 | 0 | 58 | 0 | 0 | 0 | 0 | | |
| 29 | 0 | 0 | 0 | 0 | 59 | 0 | 0 | 0 | 0 | | |
| 30 | 0 | 0 | 0 | 0 | 60 | 0 | 0 | 0 | 0 | | |

Number of Readings Above were **0** Average Opacity for Highest 6 Min Period **0**

Range of opacity Readings Min **0** Max **0** Average Opacity for 2nd Highest 6 Min **0**

Observers Name (Print) **Quin Revel**

Observers Signature **[Signature]** Date **7-16-14**

Organization **Coastal Air Consulting, Inc.**

Certified By **Whitlow Enterprises** Date **7-11-14**



Coastal Air Consulting, Inc.

(386) 451-0169

VISIBLE EMISSION TEST

Method Used (Circle One) Method B 203A 203B Report V-1

Company Name Indiantown Cogeneration LP

Facility Name Indiantown Cogen

Street Address 13303 Silver Fox Lane

City Indiantown Zip 34956

Phone No. (772) 597-6500

Process Power Unit # EU 004 Operating Mode Continuous

Control Equipment Bashouse Operating Mode Normal

Describe Emission Point Coal Unloading Stack - Square

Ht of Emis. Point 15' Ht Rel to Observer 15'

Distance to Emis. Pt. 451 Direction to Emis. Pt (Degrees) 235

Vehicle Angle to Obs. 818 Direction to Obs. Pt. (Degrees) 235

Distance and Direction to Obs. Pt from Emission Pt Same

Describe Emissions NONE


Emission Color N/A Water Droplet Plume Attached Detached None

Describe Plume Background Wall of Building

Background Color Blue Sky Conditions Overcast

Wind Speed 5 mph Wind Direction SW

Ambient Temp. 82° Wet Bulb Temp. % RH 92



Latitude 27° 2' 18" Longitude 80° 31' 13" Declination

Comments

| Observation Date <u>7-15-14</u> | | | | | Start Time <u>15:54</u> | | | | Stop Time <u>16:54</u> | | | |
|---------------------------------|---|----|----|----|-------------------------|---|----|----|------------------------|--|--|--|
| Min Sec | 0 | 15 | 30 | 45 | Min Sec | 0 | 15 | 30 | 45 | | | |
| 1 | 0 | 0 | 0 | 0 | 31 | 0 | 0 | 0 | 0 | | | |
| 2 | 0 | 0 | 0 | 0 | 32 | 0 | 0 | 0 | 0 | | | |
| 3 | 0 | 0 | 0 | 0 | 33 | 0 | 0 | 0 | 0 | | | |
| 4 | 0 | 0 | 0 | 0 | 34 | 0 | 0 | 0 | 0 | | | |
| 5 | 0 | 0 | 0 | 0 | 35 | 0 | 0 | 0 | 0 | | | |
| 6 | 0 | 0 | 0 | 0 | 36 | 0 | 0 | 0 | 0 | | | |
| 7 | 0 | 0 | 0 | 0 | 37 | 0 | 0 | 0 | 0 | | | |
| 8 | 0 | 0 | 0 | 0 | 38 | 0 | 0 | 0 | 0 | | | |
| 9 | 0 | 0 | 0 | 0 | 39 | 0 | 0 | 0 | 0 | | | |
| 10 | 0 | 0 | 0 | 0 | 40 | 0 | 0 | 0 | 0 | | | |
| 11 | 0 | 0 | 0 | 0 | 41 | 0 | 0 | 0 | 0 | | | |
| 12 | 0 | 0 | 0 | 0 | 42 | 0 | 0 | 0 | 0 | | | |
| 13 | 0 | 0 | 0 | 0 | 43 | 0 | 0 | 0 | 0 | | | |
| 14 | 0 | 0 | 0 | 0 | 44 | 0 | 0 | 0 | 0 | | | |
| 15 | 0 | 0 | 0 | 0 | 45 | 0 | 0 | 0 | 0 | | | |
| 16 | 0 | 0 | 0 | 0 | 46 | 0 | 0 | 0 | 0 | | | |
| 17 | 0 | 0 | 0 | 0 | 47 | 0 | 0 | 0 | 0 | | | |
| 18 | 0 | 0 | 0 | 0 | 48 | 0 | 0 | 0 | 0 | | | |
| 19 | 0 | 0 | 0 | 0 | 49 | 0 | 0 | 0 | 0 | | | |
| 20 | 0 | 0 | 0 | 0 | 50 | 0 | 0 | 0 | 0 | | | |
| 21 | 0 | 0 | 0 | 0 | 51 | 0 | 0 | 0 | 0 | | | |
| 22 | 0 | 0 | 0 | 0 | 52 | 0 | 0 | 0 | 0 | | | |
| 23 | 0 | 0 | 0 | 0 | 53 | 0 | 0 | 0 | 0 | | | |
| 24 | 0 | 0 | 0 | 0 | 54 | 0 | 0 | 0 | 0 | | | |
| 25 | 0 | 0 | 0 | 0 | 55 | 0 | 0 | 0 | 0 | | | |
| 26 | 0 | 0 | 0 | 0 | 56 | 0 | 0 | 0 | 0 | | | |
| 27 | 0 | 0 | 0 | 0 | 57 | 0 | 0 | 0 | 0 | | | |
| 28 | 0 | 0 | 0 | 0 | 58 | 0 | 0 | 0 | 0 | | | |
| 29 | 0 | 0 | 0 | 0 | 59 | 0 | 0 | 0 | 0 | | | |
| 30 | 0 | 0 | 0 | 0 | 60 | 0 | 0 | 0 | 0 | | | |

Number of Readings Above All were 0 Average Opacity for Highest 6 Min Period 0

Range of opacity Readings Min 0 Max 0 Average Opacity for 2nd Highest 6 Min 0

Observers Name (Print) Quin Revel

Observers Signature JOL Date 7/15/14

Organization Coastal Air Consulting, Inc.

Certified By Whitlow Enterprises Date 7/11/14



Coastal Air Consulting, Inc.

(386) 451-0169

VISIBLE EMISSION TEST

Method Used (Circle One)
 Method 9 203A 203B Report **V-10**

Company Name **Indiantown Cogeneration LP**
 Facility Name **Indiantown Cogen**
 Street Address **13303 Silver Fox Lane**
 City **Indiantown** Zip **34956**
 Phone No. **(772) 597-6500**


Process **Fly Ash** Unit # **EU-004** Operating Mode **Normal**
 Control Equipment **Dust Collector** Operating Mode **Normal**

Describe Emission Point **Square Stack**
 Ht of Emis. Point **136 ft.** Ht Rel to Observer **130 ft.**
 Distance to Emis. Pt. **800 ft.** Direction to Emis. Pt (Degrees) **50°**

Vertical Angle to Obs. **< 18°** Direction to Obs. Pt. (Degrees) **50°**
 Distance and Direction to Obs. Pt from Emission Pt **Same**

Describe Emissions **None**
 Emission Color **N/A** Water Droplet Plume Attached Detached None

Describe Plume Background **Blue Sky**
 Background Color **Blue** Sky Conditions **Scattered**
 Wind Speed **15-21 MPH** Wind Direction **WSW**
 Ambient Temp. **80** Wet Bulb Temp. % RH **100**



Latitude **27° 2' 77"** Longitude **80° 30' 92"** Declination

Comments

| Observation Date | | Start Time | | | | Stop Time | | | |
|------------------|---|------------|----|----|-----|-----------|----|----|----|
| 7.17.14 | | 1231 | | | | 1331 | | | |
| Min | 0 | 15 | 30 | 45 | Min | 0 | 15 | 30 | 45 |
| Sec | | | | | Sec | | | | |
| 1 | 0 | 0 | 0 | 0 | 31 | 0 | 0 | 0 | 0 |
| 2 | 0 | 0 | 0 | 0 | 32 | 0 | 0 | 0 | 0 |
| 3 | 0 | 0 | 0 | 0 | 33 | 0 | 0 | 0 | 0 |
| 4 | 0 | 0 | 0 | 0 | 34 | 0 | 0 | 0 | 0 |
| 5 | 0 | 0 | 0 | 0 | 35 | 0 | 0 | 0 | 0 |
| 6 | 0 | 0 | 0 | 0 | 36 | 0 | 0 | 0 | 0 |
| 7 | 0 | 0 | 0 | 0 | 37 | 0 | 0 | 0 | 0 |
| 8 | 0 | 0 | 0 | 0 | 38 | 0 | 0 | 0 | 0 |
| 9 | 0 | 0 | 0 | 0 | 39 | 0 | 0 | 0 | 0 |
| 10 | 0 | 0 | 0 | 0 | 40 | 0 | 0 | 0 | 0 |
| 11 | 0 | 0 | 0 | 0 | 41 | 0 | 0 | 0 | 0 |
| 12 | 0 | 0 | 0 | 0 | 42 | 0 | 0 | 0 | 0 |
| 13 | 0 | 0 | 0 | 0 | 43 | 0 | 0 | 0 | 0 |
| 14 | 0 | 0 | 0 | 0 | 44 | 0 | 0 | 0 | 0 |
| 15 | 0 | 0 | 0 | 0 | 45 | 0 | 0 | 0 | 0 |
| 16 | 0 | 0 | 0 | 0 | 46 | 0 | 0 | 0 | 0 |
| 17 | 0 | 0 | 0 | 0 | 47 | 0 | 0 | 0 | 0 |
| 18 | 0 | 0 | 0 | 0 | 48 | 0 | 0 | 0 | 0 |
| 19 | 0 | 0 | 0 | 0 | 49 | 0 | 0 | 0 | 0 |
| 20 | 0 | 0 | 0 | 0 | 50 | 0 | 0 | 0 | 0 |
| 21 | 0 | 0 | 0 | 0 | 51 | 0 | 0 | 0 | 0 |
| 22 | 0 | 0 | 0 | 0 | 52 | 0 | 0 | 0 | 0 |
| 23 | 0 | 0 | 0 | 0 | 53 | 0 | 0 | 0 | 0 |
| 24 | 0 | 0 | 0 | 0 | 54 | 0 | 0 | 0 | 0 |
| 25 | 0 | 0 | 0 | 0 | 55 | 0 | 0 | 0 | 0 |
| 26 | 0 | 0 | 0 | 0 | 56 | 0 | 0 | 0 | 0 |
| 27 | 0 | 0 | 0 | 0 | 57 | 0 | 0 | 0 | 0 |
| 28 | 0 | 0 | 0 | 0 | 58 | 0 | 0 | 0 | 0 |
| 29 | 0 | 0 | 0 | 0 | 59 | 0 | 0 | 0 | 0 |
| 30 | 0 | 0 | 0 | 0 | 60 | 0 | 0 | 0 | 0 |

Number of Readings Above were **0** Average Opacity for Highest 6 Min Period **0**

Range of opacity Readings Min **0** Max **0** Average Opacity for 2nd Highest 6 Min **0**

Observers Name (Print) **Quin Revell**

Observers Signature **JBL** Date **7.17.14**

Organization **Coastal Air Consulting, Inc.**

Certified By **Whitlow Enterprises** Date **7.11.14**



Arlington Environmental Services, Inc.

Post Office Box 657 Okeechobee, Florida 34973
605 Park Street, Suite 209, Okeechobee, Florida 34974
(863) 467-0555

VISIBLE EMISSION TEST

Method Used (Circle One) Method 9 203A 203B Report V-1

Company Name **Indiantown Cogeneration, LP**

Facility Name **Indiantown Plant** AIRS **0850102**

Street Address **P.O. Box 1799**

City **Indiantown** Zip **34956**

Phone No. **772-697-6500**

Process **Power** Unit # **Fu-006** Operating Mode **Normal**

Control Equipment **bag collector** Operating Mode **B-AT**

Describe Emission Point **DC outlet Pipe**

Ht of Emis. Point **10'** Ht Rel to Observer **10'**

Distance to Emis. Pt. **30'** Direction to Emis. Pt (Degrees) **206'**

Vertical Angle to Obs. **18'** Direction to Obs. Pt. (Degrees) **206'**

Distance and Direction to Obs. Pt from Emission Pt **Same**

Describe Emissions **None**


Emission Color **NA** Water Droplet Plume Attached Detached **None**

Describe Plume Background **Sky**

Background Color **blue** Sky Conditions **Clear**

Wind Speed **3-5 mph** Wind Direction **SE**

Ambient Temp. **81°F** Wet Bulb Temp. **77°F** % RH **89**



Latitude **27°02'12"** Longitude **80°29'15"** Declination **-6.35°**

Comments **Lime unloading from Rail Car**

| Observation Date | | 7-18-14 | | | | Start Time | | 10:00 | | | | Stop Time | | 11:00 | | | |
|------------------|-----|---------|----|----|----|------------|-----|-------|----|----|----|-----------|-----|-------|----|----|----|
| Sec | Min | 0 | 15 | 30 | 45 | Sec | Min | 0 | 15 | 30 | 45 | Sec | Min | 0 | 15 | 30 | 45 |
| 1 | | 0 | 0 | 0 | 0 | 31 | | 0 | 0 | 0 | 0 | 31 | | 0 | 0 | 0 | 0 |
| 2 | | 0 | 0 | 0 | 0 | 32 | | 0 | 0 | 0 | 0 | 32 | | 0 | 0 | 0 | 0 |
| 3 | | 0 | 0 | 0 | 0 | 33 | | 0 | 0 | 0 | 0 | 33 | | 0 | 0 | 0 | 0 |
| 4 | | 0 | 0 | 0 | 0 | 34 | | 0 | 0 | 0 | 0 | 34 | | 0 | 0 | 0 | 0 |
| 5 | | 0 | 0 | 0 | 0 | 35 | | 0 | 0 | 0 | 0 | 35 | | 0 | 0 | 0 | 0 |
| 6 | | 0 | 0 | 0 | 0 | 36 | | 0 | 0 | 0 | 0 | 36 | | 0 | 0 | 0 | 0 |
| 7 | | 0 | 0 | 0 | 0 | 37 | | 0 | 0 | 0 | 0 | 37 | | 0 | 0 | 0 | 0 |
| 8 | | 0 | 0 | 0 | 0 | 38 | | 0 | 0 | 0 | 0 | 38 | | 0 | 0 | 0 | 0 |
| 9 | | 0 | 0 | 0 | 0 | 39 | | 0 | 0 | 0 | 0 | 39 | | 0 | 0 | 0 | 0 |
| 10 | | 0 | 0 | 0 | 0 | 40 | | 0 | 0 | 0 | 0 | 40 | | 0 | 0 | 0 | 0 |
| 11 | | 0 | 0 | 0 | 0 | 41 | | 0 | 0 | 0 | 0 | 41 | | 0 | 0 | 0 | 0 |
| 12 | | 0 | 0 | 0 | 0 | 42 | | 0 | 0 | 0 | 0 | 42 | | 0 | 0 | 0 | 0 |
| 13 | | 0 | 0 | 0 | 0 | 43 | | 0 | 0 | 0 | 0 | 43 | | 0 | 0 | 0 | 0 |
| 14 | | 0 | 0 | 0 | 0 | 44 | | 0 | 0 | 0 | 0 | 44 | | 0 | 0 | 0 | 0 |
| 15 | | 0 | 0 | 0 | 0 | 45 | | 0 | 0 | 0 | 0 | 45 | | 0 | 0 | 0 | 0 |
| 16 | | 0 | 0 | 0 | 0 | 46 | | 0 | 0 | 0 | 0 | 46 | | 0 | 0 | 0 | 0 |
| 17 | | 0 | 0 | 0 | 0 | 47 | | 0 | 0 | 0 | 0 | 47 | | 0 | 0 | 0 | 0 |
| 18 | | 0 | 0 | 0 | 0 | 48 | | 0 | 0 | 0 | 0 | 48 | | 0 | 0 | 0 | 0 |
| 19 | | 0 | 0 | 0 | 0 | 49 | | 0 | 0 | 0 | 0 | 49 | | 0 | 0 | 0 | 0 |
| 20 | | 0 | 0 | 0 | 0 | 50 | | 0 | 0 | 0 | 0 | 50 | | 0 | 0 | 0 | 0 |
| 21 | | 0 | 0 | 0 | 0 | 51 | | 0 | 0 | 0 | 0 | 51 | | 0 | 0 | 0 | 0 |
| 22 | | 0 | 0 | 0 | 0 | 52 | | 0 | 0 | 0 | 0 | 52 | | 0 | 0 | 0 | 0 |
| 23 | | 0 | 0 | 0 | 0 | 53 | | 0 | 0 | 0 | 0 | 53 | | 0 | 0 | 0 | 0 |
| 24 | | 0 | 0 | 0 | 0 | 54 | | 0 | 0 | 0 | 0 | 54 | | 0 | 0 | 0 | 0 |
| 25 | | 0 | 0 | 0 | 0 | 55 | | 0 | 0 | 0 | 0 | 55 | | 0 | 0 | 0 | 0 |
| 26 | | 0 | 0 | 0 | 0 | 56 | | 0 | 0 | 0 | 0 | 56 | | 0 | 0 | 0 | 0 |
| 27 | | 0 | 0 | 0 | 0 | 57 | | 0 | 0 | 0 | 0 | 57 | | 0 | 0 | 0 | 0 |
| 28 | | 0 | 0 | 0 | 0 | 58 | | 0 | 0 | 0 | 0 | 58 | | 0 | 0 | 0 | 0 |
| 29 | | 0 | 0 | 0 | 0 | 59 | | 0 | 0 | 0 | 0 | 59 | | 0 | 0 | 0 | 0 |
| 30 | | 0 | 0 | 0 | 0 | 60 | | 0 | 0 | 0 | 0 | 60 | | 0 | 0 | 0 | 0 |

Number of Readings Above were **0** Average Opacity for Highest 6 Min Period **0**

Range of opacity Readings Min **0** Max **0** Average Opacity for 2nd Highest 6 Min **0**

Observers Name (Print) **William Arlington**

Observers Signature *W. Arlington* Date **7/18/14**

Organization **Arlington Environmental Services, Inc.**

Certified By **Whitlow Enterprises** Date **7/11/14**

Arlington Environmental Services, Inc.

Post Office Box 657 Okeechobee, Florida 34973
605 Park Street, Suite 209, Okeechobee, Florida 343974
(863) 467-0555

VISIBLE EMISSION TEST

| | | | | | |
|--|--|------|------|---------|-----|
| Method Used (Circle One) | | 203A | 203B | Report | V-2 |
| Company Name Indiantown Cogeneration, LP | | | | | |
| Facility Name | | AIRS | | 0850102 | |
| Street Address P.O. Box 1799 | | | | | |
| City | | Zip | | 34956 | |
| Phone No. 772-697-6500 | | | | | |


| | | |
|-------------------|---------------|----------------|
| Process | Unit # | Operating Mode |
| Power | EW-006 | Normal |
| Control Equipment | | Operating Mode |
| baghouse | | Normal |

| | |
|--|--|
| Describe Emission Point Lime Silo DC | |
| Hi of Emis. Point 110' | Hi Rel to Observer 110' |
| Distance to Emis. Pt. 275' | Direction to Emis. Pt (Degrees) 262° |

| | |
|---|--|
| Vertical Angle to Obs. 23° | Direction to Obs. Pt. (Degrees) 262° |
| Distance and Direction to Obs. Pt from Emission Pt Same | |

| | |
|-------------------------------|--|
| Describe Emissions | |
| Emission Color None | Water Droplet Plume None <input checked="" type="checkbox"/> |
| NA | Attached Detached <input type="checkbox"/> |

| | |
|---------------------------------|---|
| Describe Plume Background | |
| Background Color blue | Sky Conditions Scattered |
| Wind Speed 3.5 mph | Wind Direction North |
| Ambient Temp. 84°F | Wet Bulb Temp. 75°F % RH 74 |



| | | |
|------------------------------|-------------------------------|------------------------------|
| Latitude 27°02'12" | Longitude 80°29'15" | Declination -6.35° |
|------------------------------|-------------------------------|------------------------------|

| | |
|--|--|
| Comments Lime Transfer To Silo | |
| | |
| | |

| Observation | Date 7-18-14 | | | | Start Time 11:03 | | | | Stop Time 12:03 | | | |
|-------------|------------------------|---|----|----|----------------------------|-----|---|----|---------------------------|----|--|--|
| | Sec | 0 | 15 | 30 | 45 | Sec | 0 | 15 | 30 | 45 | | |
| 1 | 0 | 0 | 0 | 0 | 31 | 0 | 0 | 0 | 0 | 0 | | |
| 2 | 0 | 0 | 0 | 0 | 32 | 0 | 0 | 0 | 0 | 0 | | |
| 3 | 0 | 0 | 0 | 0 | 33 | 0 | 0 | 0 | 0 | 0 | | |
| 4 | 0 | 0 | 0 | 0 | 34 | 0 | 0 | 0 | 0 | 0 | | |
| 5 | 0 | 0 | 0 | 0 | 35 | 0 | 0 | 0 | 0 | 0 | | |
| 6 | 0 | 0 | 0 | 0 | 36 | 0 | 0 | 0 | 0 | 0 | | |
| 7 | 0 | 0 | 0 | 0 | 37 | 0 | 0 | 0 | 0 | 0 | | |
| 8 | 0 | 0 | 0 | 0 | 38 | 0 | 0 | 0 | 0 | 0 | | |
| 9 | 0 | 0 | 0 | 0 | 39 | 0 | 0 | 0 | 0 | 0 | | |
| 10 | 0 | 0 | 0 | 0 | 40 | 0 | 0 | 0 | 0 | 0 | | |
| 11 | 0 | 0 | 0 | 0 | 41 | 0 | 0 | 0 | 0 | 0 | | |
| 12 | 0 | 0 | 0 | 0 | 42 | 0 | 0 | 0 | 0 | 0 | | |
| 13 | 0 | 0 | 0 | 0 | 43 | 0 | 0 | 0 | 0 | 0 | | |
| 14 | 0 | 0 | 0 | 0 | 44 | 0 | 0 | 0 | 0 | 0 | | |
| 15 | 0 | 0 | 0 | 0 | 46 | 0 | 0 | 0 | 0 | 0 | | |
| 16 | 0 | 0 | 0 | 0 | 48 | 0 | 0 | 0 | 0 | 0 | | |
| 17 | 0 | 0 | 0 | 0 | 47 | 0 | 0 | 0 | 0 | 0 | | |
| 18 | 0 | 0 | 0 | 0 | 48 | 0 | 0 | 0 | 0 | 0 | | |
| 19 | 0 | 0 | 0 | 0 | 49 | 0 | 0 | 0 | 0 | 0 | | |
| 20 | 0 | 0 | 0 | 0 | 50 | 0 | 0 | 0 | 0 | 0 | | |
| 21 | 0 | 0 | 0 | 0 | 51 | 0 | 0 | 0 | 0 | 0 | | |
| 22 | 0 | 0 | 0 | 0 | 52 | 0 | 0 | 0 | 0 | 0 | | |
| 23 | 0 | 0 | 0 | 0 | 53 | 0 | 0 | 0 | 0 | 0 | | |
| 24 | 0 | 0 | 0 | 0 | 54 | 0 | 0 | 0 | 0 | 0 | | |
| 25 | 0 | 0 | 0 | 0 | 55 | 0 | 0 | 0 | 0 | 0 | | |
| 26 | 0 | 0 | 0 | 0 | 56 | 0 | 0 | 0 | 0 | 0 | | |
| 27 | 0 | 0 | 0 | 0 | 57 | 0 | 0 | 0 | 0 | 0 | | |
| 28 | 0 | 0 | 0 | 0 | 58 | 0 | 0 | 0 | 0 | 0 | | |
| 29 | 0 | 0 | 0 | 0 | 59 | 0 | 0 | 0 | 0 | 0 | | |
| 30 | 0 | 0 | 0 | 0 | 60 | 0 | 0 | 0 | 0 | 0 | | |

| | | | |
|-------------------------------|----------|--|----------|
| Number of Readings Above were | 0 | Average Opacity for Highest 6 Min Period | 0 |
| Range of opacity Readings | 0 | Average Opacity for 2nd Highest 6 Min | 0 |
| Min | | | |
| Max | 0 | | |

| | |
|---|------------------------|
| Observers Name (Print) William Arlington | |
| Observers Signature <i>W. Arlington</i> | Date 7/18/14 |
| Organization Arlington Environmental Services, Inc. | |
| Certified By Whillow Enterprises | Date 7/11/14 |

Have not received Quin Revels
VE Certification as of this
Report Prep.

Quin's VE Certification was July 11, 2014



Whitlow Enterprises, LLC

www.smokeschool.net

Certifies that

William Arlington of Arlington Environmental Services


Has passed the certification test required by EPA Method 9
40 CFR 60 Appendix A and is qualified as a visible emissions evaluator.

Certification Date: January 10, 2014 Location: Lakeland, FL

George Whitlow

President

Recertified
July 11, 2014
Cert Not Received
Yet




LFL011014-17

FUGITIVE OR SMOKE EMISSION INSPECTION OUTDOOR LOCATION

V-7

| | |
|--|--|
| Company: <u>ICLP</u> | Observer: <u>Quin Revel</u> |
| Location: <u>Indian town</u> | Affiliation: <u>Coast Air Consulting</u> |
| Company Rep.: <u>Nick Caryne</u> | Date: <u>7.16.14</u> |
| Sky Conditions: <u>Overcast</u> | Wind Direction: WSW <u>N</u> |
| Precipitation: Light <u>Light</u> | Wind Speed: 10 MPH <u>1 MPH</u> |
| Industry: <u>Power</u> | Process Unit: <u>Coal Storage/Transfer</u> EU-004 |

Sketch process unit: indicate observer position relative to source and sun, indicate potential emission points and/or actual emission points.



| OBSERVATIONS | Clock Time | Observation Period Duration, min:sec | Accumulated Emission Time, min:sec |
|-------------------|----------------------|--------------------------------------|------------------------------------|
| Begin Observation | 1408 1408 | <u>20:00</u> | <u>00:00</u> |
| | 1428 1428 | _____ | _____ |
| | _____ | _____ | _____ |
| | 1433 1433 | <u>20:00</u> | <u>00:00</u> |
| | 1453 1453 | _____ | _____ |
| | _____ | _____ | _____ |
| | 1458 1502 | <u>20:00</u> | <u>00:00</u> |
| | 1518 1522 | _____ | _____ |
| End Observation | _____ | _____ | _____ |


FUGITIVE OR SMOKE EMISSION INSPECTION OUTDOOR LOCATION

V-4

| | |
|-----------------------------------|---|
| Company <u>ICLP</u> | Observer <u>Quin Revel</u> |
| Location <u>Indian town Plant</u> | Affiliation <u>Coastal Air Consulting</u> |
| Company Rep. <u>Nick Laryea</u> | Date <u>7.16.14</u> |
| Sky Conditions <u>Scattered</u> | Wind Direction <u>SW</u> |
| Precipitation <u>None</u> | Wind Speed <u>8MPH</u> |
| Industry <u>Power</u> | Process Unit <u>Coal Crusher Building</u> |

Sketch process unit: indicate observer position relative to source and sun, indicate potential emission points and/or actual emission points.

EU-009




| OBSERVATIONS | Clock Time | Observation Period Duration, min:sec | Accumulated Emission Time, min:sec |
|-------------------|--------------|--------------------------------------|------------------------------------|
| Begin Observation | <u>11:50</u> | <u>20:00</u> | <u>00:00</u> |
| | <u>12:10</u> | _____ | _____ |
| | <u>12:15</u> | <u>20:00</u> | <u>0:00</u> |
| | <u>12:35</u> | _____ | _____ |
| | <u>12:40</u> | _____ | _____ |
| | <u>13:00</u> | <u>20:00</u> | <u>0:00</u> |
| | _____ | _____ | _____ |
| End Observation | _____ | _____ | _____ |

FUGITIVE OR SMOKE EMISSION INSPECTION OUTDOOR LOCATION

v-8

| | |
|-----------------------------------|---|
| Company <u>ICLP</u> | Observer <u>Quin Reed</u> |
| Location <u>Indian town Plant</u> | Affiliation <u>Coastal Air Consulting</u> |
| Company Rep. <u>Nick Loryae</u> | Date <u>7-17-14</u> |
| Sky Conditions <u>Overcast</u> | Wind Direction <u>WSW</u> W |
| Precipitation <u>NONE</u> | Wind Speed <u>15 MPH</u> |
| Industry <u>POVER</u> | Process Unit <u>Pulverizer - E0-004</u> |

Sketch process unit: indicate observer position relative to source and sun, indicate potential emission points and/or actual emission points.




| OBSERVATIONS | Clock Time | Observation Period Duration, min:sec | Accumulated Emission Time, min:sec |
|-------------------|--------------|--------------------------------------|------------------------------------|
| Begin Observation | <u>11:20</u> | | |
| | <u>11:40</u> | <u>20:00</u> | <u>00:00</u> |
| | <u>11:45</u> | | |
| | <u>12:05</u> | <u>20:00</u> | <u>00:00</u> |
| | <u>12:10</u> | | |
| | <u>12:30</u> | <u>20:00</u> | <u>00:00</u> |
| | _____ | | |
| End Observation | _____ | | |

FUGITIVE OR SMOKE EMISSION INSPECTION OUTDOOR LOCATION

V-2

| | |
|----------------------------------|---|
| Company <u>ICLP</u> | Observer <u>Quin Revel</u> |
| Location <u>Indiantown Plant</u> | Affiliation <u>Coastal Air Consulting</u> |
| Company Rep. <u>Nick Lacey</u> | Date <u>7.15.14</u> |
| Sky Conditions <u>Overcast</u> | Wind Direction <u>SW</u> |
| Precipitation <u>Light</u> | Wind Speed <u>5 MPH</u> |
| Industry <u>Power</u> | Process Unit <u>Coal Unloading Ev-004</u> |

Sketch process unit: indicate observer position relative to source and sun, indicate potential emission points and/or actual emission points.



| OBSERVATIONS | Clock Time | Observation Period Duration, min:sec | Accumulated Emission Time, min:sec |
|-------------------|--------------|--------------------------------------|------------------------------------|
| Begin Observation | <u>17:00</u> | <u>20:00</u> | <u>00:00</u> |
| | <u>17:20</u> | _____ | _____ |
| | <u>17:25</u> | <u>20:00</u> | <u>00:00</u> |
| | <u>17:45</u> | _____ | _____ |
| | <u>18:50</u> | <u>20:00</u> | <u>00:00</u> |
| | <u>18:10</u> | _____ | _____ |
| End Observation | _____ | _____ | _____ |

**APPENDIX 2
PLANT DATA**

PM

CeDAR 1-Hour Data
Indiantown CoGen
Data for 7/17/2014 12 PM thru 7/17/2014 5 PM

| Timestamp | (Main Boiler) Total Heat Input Rate 1-Hr mmBtu/hr |
|--------------------------------|--|
| 7/17/14 12 PM | 2943.9 |
| 7/17/14 1 PM | 2880.1 |
| 7/17/14 2 PM | 2837.6 |
| 7/17/14 3 PM | 2841.3 |
| 7/17/14 4 PM | 2832.7 |
| 7/17/14 5 PM | 2825.3 |
| Average (all) | 2860.2 |
| Total (all) | - |
| Minimum (all) | 2825.3 |
| Maximum (all) | 2943.9 |
| Average (valid values only) | 2860.2 |
| Total (valid values only) | - |
| Count (valid values only) | 6 |

NO_x, SO₂ & CO









CeDAR 1-Hour Data
Indiantown CoGen
Data for 7/16/2014 1 PM thru 7/16/2014 6 PM

| Timestamp | (Main Boiler) Total Heat Input Rate 1-Hr mmBtu/hr |
|--------------|--|
| 7/16/14 1 PM | 2941.8 |
| 7/16/14 2 PM | 2868.6 |
| 7/16/14 3 PM | 2876.1 |
| 7/16/14 4 PM | 2913.2 |
| 7/16/14 5 PM | 2925.0 |
| 7/16/14 6 PM | 2910.7 |

| | |
|-----------------------------|--------|
| Average (all) | 2905.9 |
| Total (all) | - |
| Minimum (all) | 2868.6 |
| Maximum (all) | 2941.8 |
| Average (valid values only) | 2905.9 |
| Total (valid values only) | - |
| Count (valid values only) | 6 |

**APPENDIX 3
QUALITY ASSURANCE**

TYPE "S" PITOT TUBE CALIBRATION

| PARAMETER | SPECIFICATION | EXAMPLE | MEASUREMENT INSTRUMENT |
|-----------------|---------------|---|-------------------------|
| IMPACT/ a1 | (< 10 DEG) |  | DEGREE INDICATING LEVEL |
| STATIC/ a2 | (< 10 DEG) |  | |
| STATIC/ B1 | (< 5 DEG) |  | DEGREE INDICATING LEVEL |
| IMPACT/ B2 | (< 5 DEG) |  | |
| γ | DEGREES |  | DEGREE INDICATING LEVEL |
| θ | DEGREES |  | |
| P_A | INCHES |  | RULER |
| P_B | INCHES | | |
| $P_A + P_B = A$ | INCHES | | |
| D_T | INCHES |  | MICROMETER |

$Z = A \sin \gamma$ (LIMIT < 0.125 INCHES)

$W = A \sin \theta$ (LIMIT < 0.03125 INCHES)

| PITOT # | a1 | a2 | B1 | B2 | γ | θ | P_A | P_B | A | D_T | Z | W | DAMAGE ? |
|---------|----|----|----|----|----------|----------|--------|--------|--------|--------|---|---|----------|
| Flow | 3 | 4 | 2 | 2 | 0 | 0 | 0.4120 | 0.4220 | 0.4510 | 0.3740 | 0 | 0 | None |
| CAC 9 | 4 | 4 | 2 | 2 | 0 | 0 | 0.4855 | 0.4855 | 0.4770 | 0.3770 | 0 | 0 | None |
| | | | | | | | | | | | | | |

CALIBRATED BY: *scw* DATE: *7-13-14*

| |
|--|
| THERMOCOUPLE POSTTEST CALIBRATION CHECK |
|--|

Standard: National Bureau of Standards Thermocouple

Reference: Q.A. sec 3.1.2

Procedure: Test thermocouple and NBS thermocouple are wrapped in a heating mat. The temperature is controlled by the current flow into the mat, and is stabilized at a point within 10% of the average stack temperature during the test.

Tolerance: +/- 1.5% of actual absolute temperature

| | |
|------------------------|----------------------|
| Test site: ICLP | Check date: 7/19/14 |
| Test date: 7/16-17/14 | Check by: S. C. Webb |
| Avg. stack temp. 190 F | |

| T/C # | LENGTH ft | REFERENCE TEMP. F | MEASURED TEMP. F | DIFFERENCE % |
|-------|-----------|-------------------|------------------|--------------|
| 9 | 9 | 220 | 221 | 0.15 |
| | | | | |
| Flow | 12 | 220 | 219 | -0.15 |

**APEX INSTRUMENTS METHOD 5 POST-TEST CONSOLE CALIBRATION
USING CALIBRATED CRITICAL ORIFICES
3-POINT ENGLISH UNITS**

| Meter Console Information | |
|---------------------------|-------|
| Console Model Number | CAC 2 |
| Console Serial Number | |
| DGM Model Number | |
| DGM Serial Number | |

| Calibration Conditions | | | |
|--|------|-----------|---------|
| Date | Time | 19-Jul-14 | 1:00 PM |
| Barometric Pressure | | 30.0 | in Hg |
| Theoretical Critical Vacuum ¹ | | 14.2 | in Hg |
| Calibration Technician | | | |

| Factors/Conversions | | |
|---------------------|--------|----------|
| Std Temp | 528 | °R |
| Std Press | 29.92 | in Hg |
| K _c | 17.647 | oR/in Hg |

¹For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

²The Critical Orifice Coefficient, K', must be entered in English units, (ft²·°R^{1/2})/(in·Hg·min).

| Calibration Data | | | | | | | | | | |
|-----------------------------|---|--|---|--|--|------------------|-------------------|---|---|---------------------------|
| Run Time | Metering Console | | | | Critical Orifice | | | | | |
| Elapsed (t_p) min | DGM Orifice ΔH (P_m) in H ₂ O | Volume Initial (V_m) cubic feet | Volume Final (V_{m1}) cubic feet | Outlet Temp Initial (t_{m1}) °F | Outlet Temp Final (t_{m2}) °F | Serial Number | Coefficient K' | Amb Temp Initial (t_{amb1}) °F | Amb Temp Final (t_{amb2}) °F | Actual Vacuum in Hg |
| 10.0 | 1.9 | 619.600 | 627.518 | 92 | 94 | 63 | 0.6000 | 95 | 95 | 16 |
| 10.0 | 1.9 | 627.518 | 635.450 | 94 | 97 | 63 | 0.6000 | 95 | 96 | 16 |
| 10.0 | 1.9 | 635.450 | 643.392 | 97 | 98 | 63 | 0.6000 | 96 | 96 | 16 |

| Results | | | | | | | | |
|--------------------------------|-------------------------|--------------------------------|-------------------------|--------------------|-----------------------------|---|--|--------------------------------------|
| Standardized Data | | | | Dry Gas Meter | | | | |
| Dry Gas Meter | | Critical Orifice | | Calibration Factor | | Flowrate | $\Delta H @$ | |
| ($V_{m(Std)}$) cubic feet | ($Q_{m(Std)}$) cfm | ($V_{C(Std)}$) cubic feet | ($Q_{C(Std)}$) cfm | Value (Y) | Variation (ΔY) | Std & Corr ($Q_{m(Std)Corr}$) cfm | 0.75 SCFM ($\Delta H @$) in H ₂ O | Variation ($\Delta \Delta H @$) |
| 7.618 | 0.762 | 7.643 | 0.764 | 1.003 | -0.002 | 0.764 | 1.770 | 0.006 |
| 7.597 | 0.760 | 7.640 | 0.764 | 1.006 | 0.000 | 0.764 | 1.763 | -0.001 |
| 7.579 | 0.758 | 7.636 | 0.764 | 1.007 | 0.002 | 0.764 | 1.759 | -0.005 |
| Pretest Gamma | | % Deviation | Enter Data | 1.005 | Y Average | | 1.764 | $\Delta H @$ Average |

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ± 0.02 .

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Methods, CFR Title 40, Part 60, Appendix A-3, Method 5, 16.2.3

Signature

Stephen C. Wells


Date

7-19-14

Calibration Date: 4-19-2013

Calibration Technician:

Meter Gamma vs Flowrate



Console Serial:

Console Model: CAC 2

**APEX INSTRUMENTS METHOD 5 PRE-TEST CONSOLE CALIBRATION
USING CALIBRATED CRITICAL ORIFICES
5-POINT ENGLISH UNITS**

| Meter Console Information | |
|---------------------------|-------|
| Console Model Number | CAC 2 |
| Console Serial Number | |
| DGM Model Number | |
| DGM Serial Number | |

| Calibration Conditions | | | |
|--|------|-----------|-------|
| Date | Time | 21-Oct-13 | 22:00 |
| Barometric Pressure | | 30.1 | in Hg |
| Theoretical Critical Vacuum ¹ | | 14.2 | in Hg |
| Calibration Technician | | SCW | |

| Factors/Conversions | | |
|---------------------|--------|-----------|
| Std Temp | 528 | °R |
| Std Press | 29.92 | in Hg |
| K ₁ | 17.647 | ccR/in Hg |

¹For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

²The Critical Orifice Coefficient, K', must be entered in English units, (ft³°R^{1/2})/(in.Hg*min).

| Calibration Data | | | | | | | | | | |
|------------------|--|--|--------------------------------------|---|---|------------------|------------------------|--|--|------------------|
| Run Time | Metering Console | | | | | Critical Orifice | | | | |
| Elapsed (@) | DGM Orifice ΔH (P _m) | Volume Initial (V _m) | Volume Final (V _m) | Outlet Temp Initial (t _m) | Outlet Temp Final (t _m) | Serial Number | Coefficient K | Amb Temp Initial (t _{amb}) | Amb Temp Final (t _{amb}) | Actual Vacuum |
| min | in H ₂ O | cubic feet | cubic feet | °F | °F | | see above ² | °F | °F | in Hg |
| 16.0 | 0.3 | 556.000 | 561.361 | 92 | 92 | 40 | 0.2430 | 85 | 85 | 16 |
| 10.0 | 0.6 | 563.700 | 568.490 | 88 | 89 | 48 | 0.3570 | 85 | 85 | 16 |
| 8.0 | 1.1 | 570.131 | 575.154 | 89 | 90 | 55 | 0.4710 | 85 | 86 | 16 |
| 7.0 | 1.8 | 575.800 | 581.427 | 90 | 91 | 63 | 0.6000 | 86 | 86 | 16 |
| 5.0 | 3.5 | 582.619 | 588.280 | 91 | 92 | 73 | 0.8410 | 86 | 86 | 16 |

| Results | | | | | | | | |
|---------------------|------------------------|-------------------------|-------------------------|--------------------|-------------------|--------------------------------------|---------------------|---------------------|
| Standardized Data | | | | Dry Gas Meter | | | | |
| Dry Gas Meter | | Critical Orifice | | Calibration Factor | | Flowrate | ΔH @ | |
| (V _{std}) | (Q _{m(Std)}) | (V _{cr(Std)}) | (Q _{cr(Std)}) | Value (Y) | Variation (ΔY) | Std & Corr (Q _{m(Std)}) | 0.75 SCFM (ΔH@) | Variation (ΔΔH@) |
| cubic feet | cfm | cubic feet | cfm | | | cfm | in H ₂ O | |
| 5.166 | 0.323 | 5.016 | 0.314 | 0.971 | -0.016 | 0.314 | 1.602 | -0.013 |
| 4.649 | 0.465 | 4.606 | 0.461 | 0.991 | 0.004 | 0.461 | 1.547 | -0.068 |
| 4.872 | 0.609 | 4.859 | 0.607 | 0.997 | 0.010 | 0.607 | 1.632 | 0.017 |
| 5.457 | 0.780 | 5.414 | 0.773 | 0.992 | 0.005 | 0.773 | 1.650 | 0.035 |
| 5.503 | 1.101 | 5.420 | 1.084 | 0.985 | -0.002 | 1.084 | 1.644 | 0.029 |
| | | | | 0.987 | Y Average | | 1.615 | ΔH@ Average |


Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.


I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Methods, CFR Title 40, Part 60, Appendix A-3, Method 5, 16.2.3

Signature *S. Stephen C. Welch*

Date *10-21-13*

Meter Gamma vs Flowrate





**DRY GAS METER
THERMOCOUPLE CALIBRATION DATA**

Frequency: Annual (two point) calibration.

Standard: ASTM Hg in glass thermometer, NBS ice point reference chamber, and potentiometer.

Reference: EPA Method 5, Section 2.1.8

Procedure: 1. Place ASTM thermometer and dry gas meter thermocouples (inlet and outlet) in hot water bath where the temperature is maintained between 100 F and 125 F. When the temperature has stabilized the thermocouple and ASTM thermometer are compared.

2. Remove ASTM thermometer and thermocouples from the warm bath, dry thoroughly, and place in a room with constant temperature and humidity. Allow a period of stabilization and record the readings.

Tolerance: +/- 5.4 F

| Therm ID No. | Location | Reference Temp. (F) | | Observed Temp. (F) | | Difference (F) | |
|--------------|--------------------|---------------------|------|--------------------|------|----------------|-----|
| | | 1 | 2 | 1 | 2 | 1 | 2 |
| 1 MB | Meter Box No. CAC1 | 113.0 | 70.0 | 113.0 | 70.0 | 0.0 | 0.0 |
| 2 MB | Meter Box No. CAC1 | 113.0 | 70.0 | 113.0 | 70.0 | 0.0 | 0.0 |
| 1 MB | Meter Box No. CAC2 | 113.0 | 70.0 | 113.0 | 70.0 | 0.0 | 0.0 |
| 2 MB | Meter Box No. CAC2 | 113.0 | 70.0 | 113.0 | 70.0 | 0.0 | 0.0 |
| 1 MB | Meter Box No. CAC3 | 113.0 | 70.0 | 113.0 | 69.0 | 0.0 | 1.0 |
| 2 MB | Meter Box No. CAC3 | 113.0 | 70.0 | 113.0 | 70.0 | 0.0 | 0.0 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

CALIBRATED BY: S. Webb
 DATE: 01/3/14
 DUE: 01/3/15
 Signature: *Stephen C. Webb*

**SAMPLE HEAD HOOK-UP THERMOCOUPLE
CALIBRATION PROCEDURES**

FREQUENCY: Quarterly (two point calibration)

1. Place ASTM thermometer and sample head hook-up thermocouple in ice bath, allow time for both to equilibrate. Compare and record readings after they have stabilized.
2. Remove both the ASTM thermometer and sample head hook-up thermocouple. Dry off thoroughly and place in a room with constant temperature and humidity. Allow a period of stabilization and record readings.

Acceptance Standard: The test thermocouple (sample head hook up) shall be acceptable if both temperatures are within ± 2 F of the ASTM standard thermometer.

Note: If the thermocouple is not within the tolerances, discard and calibrate one which will be satisfactory.

| Thermo. I.D. No. | Location | Reference Temp. (F) | | Observed Temp. (F) | | Difference Temp. (F) | |
|---------------------|----------|------------------------|------|-----------------------|------|-------------------------|------|
| | | 1 | 2 | 1 | 2 | 1 | 2 |
| A | SHH-A | 32.0 | 72.0 | 32.0 | 72.0 | 0.0 | 0.0 |
| B | SHH-B | 32.0 | 72.0 | 32.0 | 72.0 | 0.0 | 0.0 |
| C | SHH-C | 32.0 | 72.0 | 33.0 | 71.0 | 1.0 | -1.0 |
| | | | | | | 0.0 | 0.0 |
| | | | | | | 0.0 | 0.0 |
| | | | | | | 0.0 | 0.0 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

Calibrated by: S. C. Webb
Date: 1/3/14
Due: 1/3/15

Signature: *Stephen C. Webb*

THERMOCOUPLE CALIBRATION DATA

STANDARD: National Bureau of Standards Thermocouple

REFERENCE: EPA Method 2.

FREQUENCY: Annually

PROCEDURE: Thermocouple and NBS thermocouple are inserted into a thermostatically controlled oil bath. Temperatures are stabilized at approximately 230 & 340 F. Potentiometer and thermocouple readings are compared.

TOLERANCE: +/- 1.5% of actual absolute temperature.


REFERENCE TEMPERATURES

AMBIENT 70.0 MID 225.0 HIGH 350.0

| T/C. Number | Length (ft) | OBS TEMP (F) | DIFF (%) | OBS TEMP (F) | DIFF (%) | OBS TEMP (%) | DIFF (%) |
|-------------|-------------|--------------|----------|--------------|----------|--------------|----------|
| 4 | 4 | 70.0 | 0.00 | 224.0 | -0.15 | 349.0 | -0.12 |
| Inco 4 | 4 | 71.0 | 0.19 | 223.0 | -0.29 | 349.0 | -0.12 |
| 5 | 6 | 71.0 | 0.19 | 223.0 | -0.29 | 348.0 | -0.25 |
| 7 | 7 | 70.0 | 0.00 | 225.0 | 0.00 | 350.0 | 0.00 |
| 8 | 8 | 70.0 | 0.00 | 224.0 | -0.15 | 350.0 | 0.00 |
| 9 | 9 | 71.0 | 0.19 | 225.0 | 0.00 | 352.0 | 0.25 |
| 10 | 10 | 70.0 | 0.00 | 224.0 | -0.15 | 348.0 | -0.25 |
| 11G | 11 | 71.0 | 0.19 | 224.0 | -0.15 | 351.0 | 0.12 |
| Flow | 12 | 69.0 | -0.19 | 224.0 | -0.15 | 348.0 | -0.25 |
| 15 | 15 | 72.0 | 0.38 | 226.0 | 0.15 | 348.0 | -0.25 |
| Inco 11 | 11 | 71.0 | 0.19 | 223.0 | -0.29 | 252.0 | -12.10 |

Calibrated by: S. C. Webb
 Date: 1/3/14
 Due: 1/3/15

Signature: *S. C. Webb*



LIQUID TECHNOLOGY CORPORATION
"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis

Customer Coastal Air Consulting (Deland, FL)
Date June 04, 2014
Delivery Receipt DR-51892
Product: Nitrogen, CEMS Grade
Lot Number: LTE274-PG

Mixture Specifications

Cylinder Number EB-0040458

| <u>Components</u> | <u>Requested</u> | <u>Actual</u> |
|-------------------|------------------|---------------|
| Moisture | 2.0 ppm | < 2.0 ppm |
| Hydrocarbons | 0.1 ppm | < 0.1 ppm |
| Oxygen | 1.0 ppm | < 1.0 ppm |
| Carbon Monoxide | 1.0 ppm | < 1.0 ppm |
| Carbon Dioxide | 1.0 ppm | < 1.0 ppm |
| Nitrogen | 99.9995% | 99.9995% |

Cylinder Data

Cylinder Valve: CGA 580
Cylinder Volume: 140 Cubic Feet
Cylinder Pressure: 2000 psig, 70°F
Expiration Date: June 04, 2017

Certified by:

Cole Dylewski

"UNMATCHED EXCELLENCE"



LIQUID TECHNOLOGY CORPORATION

"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis - EPA PROTOCOL GAS -

Customer Coastal Air Consulting (Deland, FL)
Date November 07, 2013
Delivery Receipt DR-49129
Gas Standard 90-99 ppm NO, 90-99 ppm SO₂, 90-99 ppm CO/Nitrogen - EPA PROTOCOL
Final Analysis Date November 06, 2013
Expiration Date November 06, 2021 ✓

Components Nitric Oxide, Sulfur Dioxide, Carbon Monoxide
Balance Gas Nitrogen

Analytical Data: **DO NOT USE BELOW 100 psig**
 EPA Protocol, Section No. 2.2, Procedure G-1

Reported Concentrations
Nitric Oxide: 93.2 ppm +/- 0.22 ppm ✓
Sulfur Dioxide: 92.1 ppm +/- 0.90 ppm
Carbon Monoxide: 97.3 ppm +/- 0.30 ppm
Nitrogen: Balance
Total Oxides of Nitrogen: 93.2 ppm

** Total NOX for Reference Use Only **

Reference Standards:

| | | | |
|------------------|-----------------------|--|------------------------|
| SRM/GMIS: | GMIS | GMIS | GMIS |
| Cylinder Number: | CC-252014 | CC-54548 | EB-0015851 |
| Concentration: | 97.25 ppm NO/Nitrogen | 102.43 ppm SO ₂ :N ₂ | 104.90 ppm CO/Nitrogen |
| Expiration Date: | 03/21/21 | 12/01/14 | 10/21/14 |

Certification Instrumentation

| | | | |
|---------------------------|------------------|------------------|------------------|
| Component: | Nitric Oxide | Sulfur Dioxide | Carbon Monoxide |
| Make/Model: | Nicolet 6700 | Nicolet 6700 | Nicolet 6700 |
| Serial Number: | APW1100563 | APW1100563 | APW1100563 |
| Principal of Measurement: | FTIR | FTIR | FTIR |
| Last Calibration: | October 23, 2013 | October 23, 2013 | October 16, 2013 |

Cylinder Data

Cylinder Serial Number: CC-88806 ✓ Cylinder Outlet: CGA 660
 Cylinder Volume: 135 Cubic Feet Cylinder Pressure: 1925 psig, 70°F
 Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-12/531.

Certified by: *Cole Dylewski*
 Cole Dylewski

PGVP Vendor ID: E12013 ✓



LIQUID TECHNOLOGY CORPORATION

"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis - EPA PROTOCOL GAS -

Customer Coastal Air Consulting (Deland. FL)
Date April 03, 2013
Delivery Receipt DR-46482
Gas Standard 185-225 ppm NO. 185-225 ppm SO2. 185-225 ppm CO/Nitrogen - EPA PROTOCOL
Final Analysis Date April 02, 2013
Expiration Date April 02, 2021 ✓

Components Nitric Oxide. Sulfur Dioxide. Carbon Monoxide
Balance Gas Nitrogen

Analytical Data:
 EPA Protocol, Section No. 2.2, Procedure G-1

DO NOT USE BELOW 100 psig

Reported Concentrations
Nitric Oxide: 212 ppm +/- 1.0 ppm ✓
Sulfur Dioxide: 213 ppm +/- 1.4 ppm ✓
Carbon Monoxide: 215 ppm +/- 1.0 ppm ✓
Nitrogen: Balance
Total Oxides of Nitrogen: 213 ppm

** Total NOX for Reference Use Only **

Reference Standards:


| | | | |
|------------------|------------------------|-------------------------------|------------------------|
| SRM/GMIS: | GMIS | GMIS/GMIS | GMIS |
| Cylinder Number: | ND-45515 | CC-54548-CC-251490 | CC-185111 |
| Concentration: | 245.26 ppm NO:Nitrogen | 102.43 ppm SO2-507.88 ppm SO2 | 257.47 ppm CO/Nitrogen |
| Expiration Date: | 08/23/20 | 04-12-14 - 04-12-14 | 10/22/14 |

Certification Instrumentation

| | | | |
|---------------------------|----------------|----------------|-----------------|
| Component: | Nitric Oxide | Sulfur Dioxide | Carbon Monoxide |
| Make/Model: | Nicolet 6700 | Nicolet 6700 | Nicolet 6700 |
| Serial Number: | APW1100563 | APW1100563 | APW1100563 |
| Principal of Measurement: | FTIR | FTIR | FTIR |
| Last Calibration: | March 28, 2013 | March 28, 2013 | March 28, 2013 |

Cylinder Data

Cylinder Serial Number: CC-165576 ✓ Cylinder Outlet: CGA 660
 Cylinder Volume: 135 Cubic Feet Cylinder Pressure: 1925 psig, 70°F
 Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-12/531.

Certified by: 
 David Scott

PGVP Vendor ID: E12013 ✓

LIQUID TECHNOLOGY CORPORATION

"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis

- EPA PROTOCOL GAS -

Customer Coastal Air Consulting (Deland, FL)
Date August 08, 2012
Delivery Receipt DR-43385
Gas Standard 440-499 ppm NO, 440-499 ppm SO₂, 440-499 ppm CO/Nitrogen - EPA PROTOCOL
Final Analysis Date August 05, 2012
Expiration Date August 05, 2014

Components Nitric Oxide, Sulfur Dioxide, Carbon Monoxide
Balance Gas Nitrogen

Analytical Data: **DO NOT USE BELOW 150 psig**
EPA Protocol, Section No. 2.2, Procedure G-1

Reported Concentrations

Nitric Oxide: 495 ppm +/- 4.9 ppm
Sulfur Dioxide: 467 ppm +/- 4.6 ppm
Carbon Monoxide: 497 ppm +/- 4.9 ppm
Nitrogen: Balance
Total Oxides of Nitrogen: 495 ppm

** Total NOX for Reference Use Only **

Reference Standards:

| | | | |
|------------------|------------------------|--|------------------------|
| SRM/GMIS: | GMIS | GMIS | GMIS |
| Cylinder Number: | CC-184280 | EB-0017372 | CC-159116 |
| Concentration: | 494.05 ppm NO/Nitrogen | 520.89 ppm SO ₂ /N ₂ | 509.64 ppm CO/Nitrogen |
| Expiration Date: | 01/13/14 | 04/12/13 | 09/23/12 |


Certification Instrumentation

| | | | |
|---------------------------|---------------|----------------|-----------------|
| Component: | Nitric Oxide | Sulfur Dioxide | Carbon Monoxide |
| Make/Model: | Nicolet 6700 | Nicolet 6700 | Nicolet 6700 |
| Serial Number: | APW1100563 | APW1100563 | APW1100563 |
| Principal of Measurement: | FTIR | FTIR | FTIR |
| Last Calibration: | July 28, 2012 | July 28, 2012 | July 28, 2012 |

Cylinder Data

Cylinder Serial Number: EB-0021756 Cylinder Outlet: CGA 660
Cylinder Volume: 135 Cubic Feet Cylinder Pressure: 1925 psig, 70°F
Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by:


Adam Strickland

PGVP Vendor ID: E12012

"UNMATCHED EXCELLENCE"



LIQUID TECHNOLOGY CORPORATION

"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis - EPA PROTOCOL GAS -

Customer Coastal Air Consulting (Deland, FL)
Date June 04, 2014
Delivery Receipt DR-51892
Gas Standard 8.50% CO₂, 12.0% Oxygen/Nitrogen - EPA PROTOCOL
Final Analysis Date June 04, 2014
Expiration Date June 04, 2022

Component Carbon Dioxide, Oxygen
Balance Gas Nitrogen

Analytical Data:
 EPA Protocol, Section No. 2.2, Procedure G-1

DO NOT USE BELOW 100 psig

Reported Concentrations
Carbon Dioxide: 8.42% +/- 0.06%
Oxygen: 11.9% +/- 0.05%
Nitrogen: Balance

Reference Standards:

| | | |
|------------------|--|-----------------------|
| SRM/GMIS: | GMIS/GMIS | GMIS |
| Cylinder Number: | EB-0026839/EB-0051547 | CC-231332 |
| Concentration: | 6.847% CO ₂ /9.923% CO ₂ | 9.96% Oxygen/Nitrogen |
| Expiration Date: | 10/03/20 - 06/24/20 | 04/17/22 |

Certification Instrumentation

| | | |
|---------------------------|----------------|---------------|
| Component: | Carbon Dioxide | Oxygen |
| Make/Model: | Nicolet 6700 | Servomex 244a |
| Serial Number: | APW1100563 | 1847 |
| Principal of Measurement: | FTIR | Paramagnetic |
| Last Calibration: | May 15, 2014 | May 01, 2014 |

Cylinder Data

| | | | |
|-------------------------|----------------|--------------------|-----------------|
| Cylinder Serial Number: | CC-252000 | Cylinder Outlet: | CGA 590 |
| Cylinder Volume: | 136 Cubic Feet | Cylinder Pressure: | 1925 psig, 70°F |

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-12/531.

Certified by: *Cole Dylewski*
 Cole Dylewski

PGVP Vendor ID: E12014

"UNMATCHED EXCELLENCE"



LIQUID TECHNOLOGY CORPORATION

"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis - EPA PROTOCOL GAS -

Customer Coastal Air Consulting (Deland, FL)
Date November 01, 2011
Delivery Receipt DR-39306
Gas Standard 17.0-18.0% CO₂, 22.0-23.0% Oxygen/Nitrogen - EPA PROTOCOL
Final Analysis Date November 01, 2011
Expiration Date November 01, 2014 ✓

Component Carbon Dioxide, Oxygen
Balance Gas Nitrogen

Analytical Data: **DO NOT USE BELOW 150 psig**
 EPA Protocol, Section No. 2.2, Procedure G-1

Reported Concentrations
Carbon Dioxide: 17.1% +/- 0.17% ✓
Oxygen: 22.7% +/- 0.22% ✓
Nitrogen: Balance

Reference Standards:

| | | |
|------------------|--|------------------------|
| SRM/GMIS: | GMIS/GMIS | GMIS |
| Cylinder Number: | CC-252091 CC-184404 | CC-159090 |
| Concentration: | 15.816% CO ₂ 19.87% CO ₂ | 20.72% Oxygen/Nitrogen |
| Expiration Date: | 02/04/13 - 02/04/13 | 05/06/12 |

Certification Instrumentation


| | | |
|---------------------------|------------------|------------------|
| Component: | Carbon Dioxide | Oxygen |
| Make/Model: | Horiba - VIA 510 | Servomex 244a |
| Serial Number: | SN075GSF | 1847 |
| Principal of Measurement: | NDIR | Paramagnetic |
| Last Calibration: | October 10, 2011 | October 09, 2011 |

Cylinder Data

| | | | |
|-------------------------|----------------|--------------------|-----------------|
| Cylinder Serial Number: | CC-159134 ✓ | Cylinder Outlet: | CGA 590 |
| Cylinder Volume: | 140 Cubic Feet | Cylinder Pressure: | 2000 psig, 70°F |

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by:


 Adam Strickland

PGVP Vendor ID: E12011 ✓

"UNMATCHED EXCELLENCE"

APPENDIX 4
SAMPLE CALCULATIONS

CALCULATIONS FOR RUN 1

1. Volume of dry gas sampled at standard conditions, DSCF

$$V_{m \text{ std}} = 17.64 \cdot 115.656 \cdot 0.9870 \cdot 29.88 + 2.892 / 13.6 = 107.281$$

2. Volume of water vapor at standard conditions, SCF

$$V_{m \text{ gas}} = 0.04715 \cdot 340.6 = 16.06$$

3. Percent moisture in stack gas

$$\% M = 100 \cdot 18.06 / (107.451 + 18.06) = 13.00$$

4. Mole fraction dry gas

$$M_d = (100 - 13.00) / 100 = 0.870$$

5. Percent nitrogen in dry stack gas, lb/lb-mole

$$\% N_2 = 100 \cdot 12.40 - 6.70 = 80.90$$

6. Molecular weight of dry stack gas, lb/lb-mole

$$MW_d = (12.40 \cdot 0.44) + (6.70 \cdot 0.32) + (80.90 \cdot 0.28) = 20.25$$

7. Molecular weight of wet stack gas, lb/lb-mole

$$MW = (30.25 \cdot 0.870) + 18 \cdot (1 - 0.86998) = 28.68$$

8. Stack gas static pressure, in. Hg abs.

$$P_{sa} = (-1.00 / 13.6) + 29.88 - (0.001 \cdot 0.00) = 29.81$$

9. Stack gas velocity at standard conditions, fps

$$V_s = 85.49 \cdot 0.84 \cdot 1.334 \cdot \left(\frac{191.917 + 460}{29.81 \cdot 28.6589} \right)^{1/2} = 83.99$$

10. Stack gas volumetric flow rate at standard conditions, DSCFM

$$Q_s = \frac{(1058.82 \cdot 83.68 \cdot 231.50 \cdot 0.870 \cdot 29.81)}{(191.9 + 460)} = 815893.9$$

11. Stack gas volumetric flow rate at stack conditions, ACFM

$$Q_a = 0.05667 \cdot 815893.9 \cdot (191.9 + 460) / (29.81 \cdot 0.870) = 162416.2$$

12. Percent isokinetic

$$\% I = \frac{17.326 \cdot 107.451 \cdot (191.9 + 460)}{83.68 \cdot 120 \cdot 29.81 \cdot 0.870 \cdot (0.215)^2} = 100.83$$

13. Particulate emission rate, grains/SCF

$$E_g = 0.01543 \cdot (38.2 / 107.451) = 0.00549$$

14. Particulate emission rate, lbs/MMBTU

$$E_b = 9780 \cdot (0.0055 / 7000) \cdot [20.9 / (20.9 - 6.70)] = 0.0113$$

15. Particulate emission rate, lbs/hr

$$E_h = 0.00857 \cdot 0.0055 \cdot 815893.9 = 38.358$$

SAMPLE EQUATIONS FOR ISOKINETIC SAMPLING

CALCULATIONS FOR FLUE GAS VOLUME AND ISOKINETIC RATIO

| Time | Dry Gas Meter Ft ³ | Pitot | Orifice | Dry Gas | | Flue Gas | Stack Temp. °F |
|------|----------------------------------|----------------------------|----------------------------|----------------|-----------------|--|-------------------|
| | | ΔP In. H ₂ O | ΔH In. H ₂ O | Temp. °F In | Temp. °F Out | Static Pressure In. H ₂ O | |
| T | V _m | Δp | ΔH | TMI | TMO | P _g | t _s |

1. D_n = Nozzle Diameter (inches)

1a. A_n = Area of Nozzle (ft²)

2. P_{bar} = Barometric Pressure (in. Hg)

3. TT = Net Sampling Time (minutes)

4. V_m = V_m Final - V_m Initial = Sample Gas Volume (Ft³)

5. T_m = Average Dry Gas Temperature at Meter (°F)

$$T_m = \frac{\text{Avg. TMI} + \text{Avg. TMO}}{2}$$

6. Δp = Velocity head of stack gas (in. H₂O)

7. ΔH = Average Orifice Pressure Drop (in. H₂O)

8. Volume of dry gas sampled at standard conditions^a (DSCF)

$$V_{m(std)} = \frac{(17.64)(V_m)(Y) \left(P_{bar} + \frac{\Delta H}{13.6} \right)}{(T_m + 460)}$$

9. V_{lc} = Total Water Collected = gm H₂O Silica gel + ml Imp. H₂O = ml

10. Volume of water vapor at standard conditions^b (SCF)

$$V_{w(std)} = 0.0471(V_{lc}) = SCF$$

11. Percent moisture in flue gas

$$\% M = \frac{100(V_{w(std)})}{V_{m(std)} + V_{w(std)}}$$

12. Mole fraction of water vapor in flue gas

$$B_{ws} = \frac{\% M}{100}$$

13. Molecular Weight of dry flue gas

$$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2 + \%CO)$$

- 13a. %EA = % Excess Air =

$$\frac{[(\%O_2) - 0.5(\%CO)]}{[0.264(\%N_2)] - [(\%O_2) - 0.5(\%CO)]} \times 100$$

14. Molecular weight of wet flue gas

$$M_s = M_d(1 - B_{ws}) + 18(B_{ws})$$

15. A = Cross-sectional area of stack (Ft²)

$$\frac{\pi r^2}{144}$$

16. P_s = Flue gas pressure (in, Hg)

$$P_s = P_{bar} + P_g$$

NOTE:
$$P_g(Hg) = \frac{P_g(in. H_2O)}{13.6}$$

17. T_s = Absolute stack temperature (°R)

$$T_s = 460 + t_s$$

18. Flue velocity at stack conditions (FT/SEC)

$$V_s = (K_p)(C_p) \left[(\sqrt{\Delta p})_{avg} \right] \sqrt{\frac{T_s(avg)}{P_s * M_s}}$$

C_p = pitot tube coefficient

K_p = pitot tube constant = 85.49ft/sec

19. Flue gas volumetric flow rate at standard conditions^b (SCFM)

$$Q_s = (V_s)(A) \left(\frac{528}{T_s(avg.)} \right) \left(\frac{P_s}{29.92} \right) (60)$$

20. Flue gas volumetric flow rate at standard conditions^c (DSCFM)

$$Q_{sd} = (1 - B_{ws})(V_s)(A) \left(\frac{528}{T_s(avg.)} \right) \left(\frac{P_s}{29.92} \right) (60)$$

21. Flue gas volumetric flow rate at stack conditions (ACFM)

$$Q_a = (V_s)(A)(60)$$

22. Percent Isokinetic

$$\%I = \frac{K_4 (T_s)(V_{m(std)})}{P_s V_s A_n \Theta (1 - B_{ws})}$$

$K_4 = 0.09450$

$\Theta = \text{time}(\text{min})$

- NOTES: ^aDry standard cubic feet at 68°F, 29.92 in. Hg
^bStandard conditions at 68°F, 29.92 in. Hg
^cDry standard cubic feet per minute at 68°F, 29.92 in. Hg

II. Calculations for grain loading and emission rates

23. Particulate (gr/DSCF)

$$gr / DSCF = 0.01543 \left(\frac{mg}{V_{m(std)}} \right)$$

24. Particulate at stack conditions (gr/ACF)

$$gr / ACF = \frac{17.64 gr / DSCF (P_s) (M_d)}{(T_s + 460)}$$

25. Particulate (lbs/hr), concentration method

$$lbs / hr = 0.00857 * gr / DSCF * Q_{sd}$$

26. Particulate (lbs/hr), area method

$$lbs / hr = 0.132 * \frac{particulate(g) * A}{\frac{(D_n)^2}{2} * TT}$$

27. Particulate (lbs/mmBtu)

$$\frac{lbs / hr}{10^6 Btu / hr}$$

28. Particulate (lbs/ton)

$$lbs / ton = \frac{lbs / hr}{tons / hr}$$

29. Particulate (lbs/mmBtu), F-Factor Method

$$\text{Using } O_2 = \frac{(0.01543)(mg)(F - Factor)(20.9)}{(7000)(V_{m(std)})(20.9 - \%O_2)}$$

30. Particulate (gr/dscf) @ % Excess Air

$$gr/dscf @ \% EA = ((100 + \%EA)/150) (gr/dscf)$$

31. Particulate (lbs/mmBtu), F-Factor Method (Continued)

$$\text{Using CO}_2 = \frac{(0.01543)(mg)(F - \text{Factor})(100)}{(7000)(V_{m(std)})(\%CO_2)}$$

32. F-Factor (dscf/mmBtu)

Wet Basis (F_w)

$$F_w = \frac{10^6 \text{ Btu / mmBtu} [5.57(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2) + 0.21(\%H_2O)]}{GCV_w}$$

Dry Basis (F_d)

$$F_d = \frac{10^6 \text{ Btu / mmBtu} [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O_2)]}{GCV_d}$$

Carbon Basis (F_c)

$$F_c = \frac{10^6 \text{ Btu / mmBtu} [0.321(\%C)]}{GCV_d}$$

33. Particulate Emissions, (grams/DSCF)

$$Cs = \text{Particulate (mg)} / 1000 / \text{DSCF}$$


34. Particulate Emissions, (lb/ton) of Kiln Feed

$$(Cs) (\text{DSCFH}) / (130 \text{ tph}) (453.6 \text{ g/lb})$$

APPENDIX 5
FIGURES

INDIANTOWN COGENERATION, L.P.
INDIANTOWN, FLORIDA

SAMPLING POINT DETERMINATION (CONTINUED)



**PC Boiler Stack Sampling Point Determination
(Performance Specification 2)**

PROBE MARKINGS


Plant: Indiantown Cogeneration
 Unit: PC Boiler
 Diameter: 206 Inches
 Port Depth: 16"

PM Flow

| | Number of Points on a diameter | | | | |
|----|--------------------------------|--------|--------|--------|--------|
| | 4 | 6 | 8 | 10 | 12 |
| 1 | 13.80 | 9.06 | 6.80 | 5.15 | 4.33 |
| 2 | 51.50 | 30.28 | 21.63 | 16.89 | 13.80 |
| 3 | 154.50 | 60.77 | 39.96 | 30.08 | 24.31 |
| 4 | 192.20 | 145.23 | 66.54 | 46.56 | 36.46 |
| 5 | | 175.72 | 139.46 | 70.45 | 51.50 |
| 6 | | 196.94 | 166.04 | 135.55 | 73.13 |
| 7 | | | 184.37 | 159.44 | 132.87 |
| 8 | | | 199.20 | 175.92 | 154.50 |
| 9 | | | | 189.11 | 169.54 |
| 10 | | | | 200.85 | 181.69 |
| 11 | | | | | 192.20 |
| 12 | | PM | Flow | | 201.67 |

*Stacks having diameters > 24" no points within 1" from stack wall


*Stacks having diameters < 24" no points within 0.5" from stack wall



Coastal Air Consulting, Inc
 1001 Wyngate Drive, Deland FL
 (386) 943-9241 Fax (386) 943-9212

| | |
|-----------------------------|---|
| DRAWN BY R F Cobb | TITLE EPA Instrumental Sample Train |
| DATE 4/15/02 | DESCRIPTION Sample Train Schematic |
| SCALE NONE | |

APPENDIX 6
QSTI



Source Evaluation Society

P. O. Box 12124
Research Triangle Park
North Carolina 27709

May 1, 2012

Stephen C. Webb
Coastal Air Consulting
1531 Wyngate Dr.
DeLand, FL 32724

Subject: Qualified Source Tester Application No. 2012-670
**Qualification Notice - Manual Gas Volume Measurements and
Isokinetic Particulate Sampling Methods**
- **Manual Gaseous Pollutants Source Sampling Methods**
- **Gaseous Pollutants Instrumental Sampling Methods**
- **Hazardous Metals Measurement Sampling Methods**

Dear Mr. Webb:

It is my pleasure to inform you that you have satisfied the requirements of the Source Evaluation Society Qualified Source Test Individual program for group exam(s) listed above. As a member of the successful candidates in this SES program, you should be proud of this distinction within the source emissions testing community. I am confident that you will continue to uphold the standards of technical excellence and ethical conduct embodied in the SES mission statement.


The enclosed Qualification Notice(s) and SES identification card are your permanent record of this achievement. This status is valid for the period shown on the Qualification Notices.

Congratulations on your achievement and I wish you continued success in your future endeavors. Please see attached a permission letter if you wish to have your information posted on the SES web site.

Sincerely yours,

Peter R. Westlin
SES QSTI/QSTO Review Committee Chairman

cc: Roy Owens, SES QSTI/QSTO Review Board Member
Glenn England, SES QSTI/QSTO Review Board Member
C. David Bagwell, SES QSTI/QSTO Review Board Member
Karen D. Kajiya-Mills, SES QSTI/QSTO Review Board Member
Peter S. Pakalnis, SES QSTI/QSTO Review Board Member
Gail Westlin, SES QSTI/QSTO Review Committee Administrator



Source Evaluation Society

P. O. Box 12124
 Research Triangle Park
 North Carolina 27709

An idea was introduced at the 2006 SSSAAP conference to list those individuals who have received their QSTI qualification approvals on the SES web site. The SES Board of Directors determined that individuals would have to approve in writing before making public such information. The QSTI Committee would like your permission to post the information shown below on the SES web site for public view. This information will be provided on the website as a link to an Excel spreadsheet. Your information will be listed as below or with any changes you indicate:

| | | | |
|---------------------|------------------------|-------------------|---|
| Name | Stephen C. Webb | | |
| Company | Coastal Air Consulting | | |
| City/State/Zip: | DeLand, FL 32724 | | |
| Contact Info.: | Coastalair123@aol.com | | |
| Any Addit. Info: | qsti program@gmail.com | | |
| Passed: | Group 1 | Exam Date: 5/5/11 | Valid From - To: 2012/05/01 to 2017/04/30 |
| | Group 2 | Exam Date: 5/5/11 | Valid From - To: 2012/05/01 to 2017/04/30 |
| | Group 3 | Exam Date: 5/6/11 | Valid From - To: 2012/05/01 to 2017/04/30 |
| | Group 4 | Exam Date: 5/6/11 | Valid From - To: 2012/05/01 to 2017/04/30 |
| QSTI Certificate #: | 2012-670 | | |

You may view the current spreadsheet format at the SES website at www.sesnews.org. If you agree to your name and information being posted, please sign below and fax this page to Gail Westlin at 919-572-2203 or email to gail_westlin@yahoo.com. Also, if you wish to have your contact information listed other than your email address, please note any changes above (e.g., an address, telephone or a cell phone number, etc.). Any further changes or additions will need to be made in writing and emailed to Gail Westlin at gail_westlin@yahoo.com. If you have any questions concerning this matter, please contact the SES QSTI/QSTO Review Committee Chairman, Peter Westlin, at westlin.peter@epa.gov or myself.

Thank you,

Gail Westlin
 SES QSTI/QSTO Review Committee Administrator

I give the SES QSTI/QSTO Review Committee approval to have my name and information as outlined above to be posted on the SES web site. Any changes have been noted above. This approval extends to any future exams for which I receive a QSTI or QSTO Qualification Approval(s).

Signature: _____ Date: _____

NEW. DO YOU APPROVE SES RELEASING INFORMATION, UPON REQUEST, ABOUT WHETHER YOU HAVE PASSED A METHOD GROUP EXAM? (The Information released will be if you passed an exam and the date of the exam. This information is in support of ASTM D-7036-D.) YES NO IF YOU AGREE, PLEASE SIGN BELOW.

Signature: _____ Date: _____

SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

STEPHEN C. WEBB

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

MANUAL GAS VOLUME MEASUREMENTS AND ISOKINETIC PARTICULATE SAMPLING METHODS

ISSUED THIS 1ST DAY OF MAY 2012 AND EFFECTIVE UNTIL APRIL 30TH, 2017

Peter R. Westlin, QST/QSTO Review Board

Peter S. Pakalnis, QST/QSTO Review Board


Glenn C. England, QST/QSTO Review Board

C. David Bagwell, QST/QSTO Review Board

Karen D. Kajlya-Mills, QST/QSTO Review Board

Glenn C. England, QST/QSTO Review Board

APPLICATION
NO.
2012-670



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

STEPHEN C. WEBB

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

MANUAL GASEOUS POLLUTANTS SOURCE SAMPLING METHODS

ISSUED THIS 1ST DAY OF MAY 2012 AND EFFECTIVE UNTIL APRIL 30TH, 2017

Peter R. Westlin, QSTVQSTO Review Board

Peter S. Pakalnis, QSTVQSTO Review Board


Cary J. Owens, QSTVQSTO Review Board

C. David Bagwoj, QSTVQSTO Review Board

Karen D. Kalya-Mills, QSTVQSTO Review Board

Glenn C. England, QSTVQSTO Review Board

APPLICATION
NO.
2012-670



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

STEPHEN C. WEBB

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS

ISSUED THIS 1ST DAY OF MAY 2012 AND EFFECTIVE UNTIL APRIL 30TH, 2017

Peter R. Westlin, QST/QSTO Review Board

Peter S. Pakalnis, QST/QSTO Review Board


Greg I. Owens, QST/QSTO Review Board

C. David Bagwell, QST/QSTO Review Board

Karen D. Kallya-Mills, QST/QSTO Review Board

Glenn C. England, QST/QSTO Review Board

APPLICATION
NO.
2012-670



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

STEPHEN C. WEBB

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED
EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES
ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

HAZARDOUS METALS MEASUREMENT SAMPLING METHODS

ISSUED THIS 1ST DAY OF MAY 2012 AND EFFECTIVE UNTIL APRIL 30TH, 2017

Peter R. Westlin, QST/QSTO Review Board

Peter S. Pakalnis, QST/QSTO Review Board

LeRoy Owens, QST/QSTO Review Board

C. David Bagwell, QST/QSTO Review Board

Karen D. Kajiya-Mills, QST/QSTO Review Board

Glenn C. England, QST/QSTO Review Board

APPLICATION
NO.
2012-670

