

# Rayonier

*Performance Fibers*

*Fernandina Mill*

June 9, 2009

**Certified Mail, Return Receipt Requested**

Mr. Jeffery Koerner, P.E.  
Florida Dept. of Environmental Protection  
Bureau of Air Regulation  
Division of Air Resource Management  
2600 Blair Stone Road, M.S. 5505  
Tallahassee, FL 32399-2400

RECEIVED

JUN 11 2009

BUREAU OF AIR REGULATION


Re: Rayonier Permit No. 0890004-021-AC  
Follow-up Test Results on No. 6 Power Boiler while Burning Wastewater Treatment Solids

Attached are the results of the follow-up testing to the screening testing of the #6 power boiler while burning wastewater treatment solids. This test was conducted under the authority of Air Permit No. 0890004-021-AC Section G and under the Extension of this permit dated February 5, 2009. This testing was conducted only for particulate matter as the previous round of testing indicated acceptable results for all other tested parameters.

As indicated in the attached test report that includes the test program and procedures used, the data collection system, the tested configurations, and the analytical results; this test demonstrated the capability of the power boiler to operate well within its particulate matter emission permit limits while firing up to 60 ODTD of wastewater treatment solids at approximately 30% solids while producing approximately 280,000 #/hour of steam. The emissions impacts of the previous testing and this round of testing are currently being summarized in a construction permit application requesting the ability to burn wastewater treatment solids on a continuous basis in the #6 power boiler.

If you have any questions regarding the testing program, please contact me at 904-277-1346 or david.rogers@rayonier.com.

Sincerely,



David W. Rogers  
Manager, Environmental Operations

cc: Mr. Ray Barata, FDEP Jacksonville

Registered to ISO 9001:2000



Certificate No. A2072

10 Gum Street • P.O. Box 2002 • Fernandina Beach, FL 32035-2002  
Telephone (904) 261-3611 • Fax (904) 277-1411

---

Work Order No. 05565.008.010

**BFB Boiler  
Particulate Matter  
Emission Test Report  
Rayonier  
Fernandina Beach, Florida  
15-16 April 2009**

Prepared For


**RAYONIER**

Foot of Gum Street  
Fernandina Beach, Florida 31598-2070



---

Gregory R. Sims  
Senior Project Manager  
Approved for Transmittal



---

Natalie Vaught  
Report Coordinator  
Approved for Transmittal

Prepared By

**WESTON SOLUTIONS, INC.**

1625 Pumphrey Ave.  
Auburn, Alabama 36832-4303  
Phone: (334) 466-5600 Fax: (334) 466-5660

**6 May 2009**

---

**WESTON SOLUTIONS, INC. (WESTON®)**  
**EMISSION TESTING PRACTICE – AUBURN OPERATIONS**  
**ACCREDITATION STIPULATION**

<b>Laboratory:</b>	Weston Solutions, Inc.
<b>Accreditor(s):</b>	Louisiana Environmental Laboratory Accreditation Program (LELAP) – Laboratory and Emission Testing Practice
<b>Accreditation ID:</b>	LELAP – 03024
<b>Scope:</b>	Particulate Matter Sampling and Analysis
<b>Effective:</b>	LELAP – 21 December 2001
<b>Expires:</b>	LELAP – 30 June 2009

**Note:** These accreditation stipulations conform to the requirements of Georgia Rule 391-3-26-01.



## TABLE OF CONTENTS

<b>SECTION 1</b>	<b>INTRODUCTION.....</b>	<b>1-1</b>
<b>SECTION 2</b>	<b>RESULTS AND DISCUSSION.....</b>	<b>2-1</b>
<b>SECTION 3</b>	<b>SOURCE TESTING METHODOLOGY .....</b>	<b>3-1</b>
<b>APPENDIX A</b>	<b>SAMPLE CALCULATIONS</b>	
<b>APPENDIX B</b>	<b>TEST METHODOLOGY</b>	
<b>APPENDIX C</b>	<b>FIELD DATA – BFB BOILER CONDITION ONE BARK WITH 45 ODTD SLUDGE</b>	
<b>APPENDIX D</b>	<b>FIELD DATA – BFB BOILER CONDITION TWO BARK WITH 60 ODTD SLUDGE</b>	
<b>APPENDIX E</b>	<b>QUALITY CONTROL DATA</b>	
<b>APPENDIX F</b>	<b>PROCESS OPERATING DATA</b>	

### LIST OF TABLES

Table 2-1	Summary of Emission Test Results .....	2-1
Table 2-2	BFB Boiler Condition One Bark with 45 ODTD Sludge Summary of PM Emission Results.....	2-2
Table 2-3	BFB Boiler Condition Two Bark with 60 ODTD Sludge Summary of PM Emission Results.....	2-3
Table 3-1	Source Testing Methodology .....	3-1



## SECTION 1 INTRODUCTION

Weston Solutions, Inc. (WESTON®) was retained by Rayonier to conduct particulate matter (PM) emission testing on the Bubbling Fluidized Bed (BFB) Boiler at the mill in Fernandina Beach, Florida. The emission test results included from this study are for Rayonier's internal use only and not for demonstrating compliance with any regulation requirements or permit conditions.

WESTON performed the emission testing during 15-16 April 2009. The project team included the following individuals.

<b>Name</b>	<b>Project Role</b>
Gregory Sims	Project Manager/Technical Director
Melanie Wright	Quality Assurance Manager
William Routhier	Test Team Leader
Susan Brown	Test Team Member
Natalie Vaught	Report Coordinator

Mr. David Rogers of Rayonier coordinated the testing with facility operations and served as WESTON's technical contact throughout the effort.

The Louisiana Environmental Laboratory Accreditation Program (LELAP) accredits WESTON's emission testing practice. The stipulation associated with this accrediting authority precedes the table of contents of this report.



## SECTION 2 RESULTS AND DISCUSSION

Table 2-1 presents a summary of the emission testing results, and Tables 2-2 and 2-3 present detailed summaries of the emission testing results. Any differences between the calculated results in the appendices and the reported results in the summary tables are due to rounding the results for presentation.

**TABLE 2-1  
SUMMARY OF EMISSION TEST RESULTS**

	Condition One (Bark w/45 ODTD Sludge)	Condition Two (Bark w/60 ODTD Sludge)
<b>Particulate Matter</b>		
lb/hr	18	15
lb/MMBtu	0.037	0.032

**TABLE 2-2**  
**BFB BOILER**  
**CONDITION ONE**  
**BARK WITH 45 ODTD SLUDGE**  
**SUMMARY OF PM EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	4/15/09	4/15/09	4/15/09	----
Time Began	1157	1347	1535	----
Time Ended	1303	1455	1642	----
<b>Stack Gas Data</b>				
Temperature, °F	367	371	371	370
Velocity, ft/sec	50	50	48	49
Moisture, %	22	21	20	21
CO <sub>2</sub> Concentration, %	13.2	13.2	13.1	13.2
O <sub>2</sub> Concentration, %	6.9	7.0	6.9	6.9
VFR, x 10 <sup>5</sup> dscfm	1.17	1.19	1.13	1.16
<b>Particulate Matter</b>				
Isokinetic Sampling Rate, %	100	98	97	98
Concentration, gr/dscf	0.016	0.017	0.020	0.018
Emission Rate, lb/hr	16	18	19	18
Emission Factor, lb/MMBtu	0.034	0.035	0.041	0.037

**TABLE 2-3**  
**BFB BOILER**  
**CONDITION TWO**  
**BARK WITH 60 ODTD SLUDGE**  
**SUMMARY OF PM EMISSION RESULTS**

	Run 1	Run 2	Run 3	Mean
Date	4/16/09	4/16/09	4/16/09	----
Time Began	0922	1100	1239	----
Time Ended	1030	1207	1346	----
<b>Stack Gas Data</b>				
Temperature, °F	374	369	363	369
Velocity, ft/sec	50	49	48	49
Moisture, %	22	21	22	22
CO <sub>2</sub> Concentration, %	13.1	13.2	13.2	13.2
O <sub>2</sub> Concentration, %	7.1	6.9	6.9	7.0
VFR, x 10 <sup>5</sup> dscfm	1.15	1.17	1.14	1.15
<b>Particulate Matter</b>				
Isokinetic Sampling Rate, %	100	100	101	100
Concentration, gr/dscf	0.015	0.013	0.019	0.016
Emission Rate, lb/hr	14	13	18	15
Emission Factor, lb/MMBtu	0.031	0.027	0.038	0.032





## SECTION 3

### SOURCE TESTING METHODOLOGY

The emission testing program was conducted in accordance with the U.S. EPA Reference Methods summarized in Table 3-1. Method descriptions and quality assurance data are provided in the referenced appendices.

**TABLE 3-1**  
**SOURCE TESTING METHODOLOGY**

Parameter	Method Number	Appendix Reference		Comments
		Method Description	Quality Control Data	
Volumetric Flow Rate	1,2,3,4	B.1	E	
Particulate Matter	5	B.2	E	



**APPENDIX A**  
**SAMPLE CALCULATIONS**

---



## SAMPLE CALCULATIONS

### BFB Boiler

#### Run 1

**Meter Pressure (Pm), in. Hg**

$$Pm = Pb + \frac{\Delta H}{13.6 \text{ in. H}_2\text{O/in. Hg}}$$

where, PB = barometric pressure, in. Hg  
 $\Delta H$  = Pressure differential of orifice in. H<sub>2</sub>O

**Absolute Stack Gas Pressure (Ps), in. Hg**

$$Ps = Pb + \frac{Pg}{13.6 \text{ in. H}_2\text{O/in. Hg}}$$

where, PB = barometric pressure, in. Hg  
 Pg = Static Pressure, in. H<sub>2</sub>O

**Standard Meter Volume (Vmstd), dscf**

$$Vmstd = \frac{17.64^\circ R/\text{in. Hg} \times Y \times Vm \times Pm}{Tm}$$

where, Y = meter correction factor  
 Vm = meter volume, dscf  
 Pm = meter pressure, in. Hg  
 Tm = meter temperature, °R

**Standard Wet Volume (Vwstd), scf**

$$Vwstd = 0.04707 \text{ ft}^3/\text{mL} \times Vlc$$

where, Vlc = volume of H<sub>2</sub>O collected, mL

**Moisture Fraction (Measured), (Bws)**

$$Bws = \frac{Vwstd}{(Vwstd + Vmstd)}$$

where, Vwstd = standard wet volume, scf  
 Vmstd = standard meter volume, dscf


**Moisture Fraction (at saturation), (Bws)**

$$Bws = \frac{Vp}{Ps}$$

where, Vp = vapor pressure of H<sub>2</sub>O at stack gas temp., in. Hg  
Ps = absolute stack gas pressure, in. Hg

**Moisture %, (%)**

$$Bws = Bws \times 100$$

where, Bws = moisture fraction, measured or at saturation, whichever is lowest

**Molecular Weight (DRY) (Md), lb/lb-mole**

$$Md = (0.44 \times \% CO_2) + (0.32 \times \% O_2) + (0.28(100 - \% CO_2 - \% O_2))$$

**Molecular Weight (WET) (Ms), lb/lb-mole**

$$Ms = Md (1 - Bws) + 18(Bws)$$

where, Md = molecular weight (DRY), lb/lb-mole  
Bws = moisture fraction, dimensionless

**Average Velocity (Vs), ft/sec**

$$Vs = 85.49 \frac{ft}{sec} \sqrt{\frac{(lb/lb - mole)(in. Hg)}{(^{\circ}R)(in. H_2O)}} \times Cp \times \sqrt{\Delta P_{avg.}} \times \sqrt{\frac{Ts}{Ps \times Ms}}$$

where, Cp = pitot tube coefficient  
Delta P = velocity head of stack gas, in. H<sub>2</sub>O  
Ts = absolute stack temperature, °R  
Ps = absolute stack gas pressure, in. Hg  
Ms = molecular weight of stack gas, lb/lb-mole

**Average Stack Gas Flow at Stack Conditions (Qa), acfm**

$$Qa = 60 \text{ sec/min} \times Vs \times As$$

where, Vs = stack gas velocity, ft/sec  
As = cross-sectional area of stack, ft<sup>2</sup>



### Average Stack Gas Flow at Standard Conditions (Qs), dscfm

$$Q_s = 17.64 \frac{^{\circ}R}{\text{in. Hg}} \times Q_a \times (1 - B_{ws}) \times \frac{P_s}{T_s}$$

where,  $Q_a$  = average stack gas flow at stack conditions, ft<sup>3</sup>/min  
 $B_{ws}$  = moisture content (dimensionless)  
 $P_s$  = absolute stack gas pressure, in. Hg  
 $T_s$  = absolute stack temperature, °R

### Percent Isokinetic Sampling Rate (%I)

$$\% I = \frac{0.0945 (\text{in. Hg})(\text{min})(^{\circ}R)(\text{sec}) \times T_s \times V_{mstd}}{P_s \times V_s \times A_n \times \Theta \times (1 - B_{ws})}$$

where,  $T_s$  = avg. stack temperature, °R  
 $V_{mstd}$  = standard meter volume, dscf  
 $P_s$  = absolute stack gas pressure, in. Hg  
 $V_s$  = stack gas velocity, ft/sec  
 $A_n$  = cross-sectional area of nozzle, ft<sup>2</sup>  
 $\Theta$  = total sampling time, min  
 $B_{ws}$  = moisture content (dimensionless)

### Particulate Matter Concentration at Standard Conditions (Cs), gr/dscf

$$C_s = 15.43 \frac{\text{gr}}{\text{g}} \times \frac{M_n}{V_{mstd}}$$

where,  $M_n$  = particulate matter collected, g  
 $V_{mstd}$  = std. meter volume, dscf

### Particulate Matter Emission Rate (PMR), lb/hr

$$PMR = \frac{C_s \times Q_s \times 60 \frac{\text{min}}{\text{hr}}}{7000 \frac{\text{gr}}{\text{lb}}}$$

where,  $C_s$  = particulate conc. at std. cond., gr/dscf  
 $Q_s$  = avg. stack gas flow at std. cond., dscf/min

### PM Emission Factor (EMF), lb/MMBtu (correcting for O<sub>2</sub>)

$$EMF = PM \text{ conc.} \frac{\text{gr}}{\text{dscf}} \times \frac{\text{lb}}{7000 \text{ gr}} \times F \text{ factor,} \frac{\text{dscf}}{\text{MMBtu}} \times \frac{20.9}{20.9 - \% O_2}$$

where, PM conc. =  $C_s$   
 F factor = defined by client or CFR, scf/MMBtu



## APPENDIX B TEST METHODOLOGY

---

**B.1 VOLUMETRIC FLOW RATE**

**B.2 PARTICULATE MATTER**



## **B.1 VOLUMETRIC FLOW RATE**

Mass emission rates are calculated by multiplying measured target analyte concentrations by calculated volumetric flow rates. Volumetric flow rates are calculated using measurement data obtained by EPA Reference Methods 1-4.

The ductwork is measured at the sample location to the nearest 0.25 inch using a steel tape measure. Traverse points are selected in accordance with EPA Reference Method 1 on the basis of ductwork dimensions, geometry, and upstream and downstream disturbances. When a sample location does not meet EPA Reference Method 1 criteria, the maximum recommended number of traverse points is used.

### **Gas Velocity**

The velocity of the gas stream is measured in accordance with EPA Reference Method 2 by reading the instantaneous velocity pressure with an inclined manometer at each traverse point using either a standard "P" type or an "S" type pitot tube. The stack pressure is calculated from the measured static pressure of the stack and the ambient barometric pressure. The static pressure is measured by using the static side of the pitot tube, and the barometric pressure is measured using a calibrated aneroid barometer. Magnahelic® gauges with scales of 0 to 5 and 0 to 25 inches of water or an inclined manometer with a scale of 0 to 10 inches of water is used for velocity pressure measurements. Manometer selection is determined by the velocity pressure of the gas stream. A manometer with a 0 to 0.25 inch scale may be used when the velocity pressure of the gas stream is less than 0.02 inches of water. By convention, any measured velocity pressures of less than 0.005 inches of water are recorded and reported as less than 0.005 inches of water. The stack temperature is measured with a calibrated thermocouple and pyrometer.

For low velocity pressure measurements (less than 0.005 inches of water) a hot wire anemometer may be used to measure the velocity of the gas stream. The indicated velocity is used without correction when the gas stream is ambient air with a moisture content of less than 65%. The indicated velocity is corrected in accordance with procedures specified by the manufacturer when the moisture content exceeds 65% or when the dry gas fraction is something other than ambient air.

### **Gas Composition and Moisture Content**

The composition of the gas stream is measured in accordance with EPA Reference Method 3 using an Orsat or Fyrite Combustion Gas Analyzer. Gas composition determinations are conducted using either integrated or grab sampling techniques.

Grab samples are analyzed using a Fyrite analyzer by withdrawing a gas sample from the source and introducing the sample directly to a zeroed oxygen or carbon dioxide combustion gas analyzer.



After introduction of the gas sample, the analyzer is inverted the prescribed number of times and the analyzer fluid level is recorded giving a percent by volume determination of the oxygen or carbon dioxide concentrations.

Integrated samples are collected by withdrawing a sample from the source through a moisture condenser into a Tedlar® sample bag. The bag is then analyzed using an Orsat analyzer.

The moisture content of the gas stream is determined using one of the following procedures:

- For sources requiring testing by EPA Reference or Test Methods 5, 8, 12, 13, 17, 23, 26A, 29, 0010, or 0011, moisture is determined by EPA Reference Method 4. At the conclusion of each run the volume of condensed moisture in the impingers of the sampling train is measured and used to calculate the moisture content of the gas stream.
- For sources with temperatures greater than 212 °F, the approximation technique described in EPA Reference Method 4 may be used with midget impingers to condense moisture before dry gas volume measurement.
- For sources with a temperature of less than 212 °F, wet bulb/dry bulb temperature measurements may be made, and the moisture content calculated using vapor pressure tables.

When multiple methods are used for moisture determinations, the lowest moisture value is used for volumetric flow calculations.

The molecular weight of the gas stream is calculated using the measured moisture, oxygen, and carbon dioxide concentrations. The balance of the gas stream is assumed to be nitrogen. The volumetric flow is then calculated at stack and standard conditions using the calculated molecular weight, the measured stack temperature, and measured velocity, stack and barometric pressures. Standard conditions are 68 °F and 29.92 inches of mercury and 0% moisture.

### **Data Acquisition and Reporting**

Data are recorded at the time of collection on preprinted data sheets. Calculations are performed (where possible) with preprogrammed calculators or spreadsheet software.

### **Quality Control**

Quality control procedures for volumetric flow measurements involve leak checks of pitot tubes, pitot tube lines and manometers; periodic analysis of ambient air and duplicate analysis of source gas samples with the Fyrite analyzer; triplicate analysis with the Orsat analyzer; and periodic calibration checks of thermocouples and pyrometers.

Data transfers are minimized. Data sheets are checked for completeness and accuracy. Calculations are verified by a second person.





## B.2 PARTICULATE MATTER

Particulate matter (PM) emission testing is conducted using EPA Reference Method 5. EPA Reference Methods 1-4 are used, as appropriate, for traverse point selection, determination of stack gas molecular weight, stack gas moisture determination, and volumetric flow rate.

### Sampling Equipment and Procedures

The sampling train utilized to perform the PM sampling is an EPA Reference Method 5 train manufactured by Graseby-Nutech, Graseby-Anderson, or Apex Instruments (see Figure B-1). A measured borosilicate, quartz glass, or stainless steel (316) nozzle is attached to a heated ( $248 \pm 25$  °F) borosilicate or quartz glass, or stainless steel probe of appropriate length. The probe is connected to a heated ( $248 \pm 25$  °F) borosilicate glass filter holder containing a 9-cm glass fiber filter (preweighed to a constant 0.1 mg weight). The first and second impingers each contain 100 mL of distilled water, the third impinger is empty, and the fourth impinger contains 200 to 300 grams of dry preweighed silica gel. The second impinger is a standard Greenburg-Smith type. The first, third, and fourth impingers are of a modified design. All impingers are maintained in a crushed ice bath. A gas measuring control console with a leak-free vacuum pump, a calibrated dry gas meter, a calibrated orifice, and inclined manometers are connected to the final impinger, probe, heated filter holder, and pitot tube via an umbilical cord to complete the train.

Flue gas velocity is measured with a calibrated S-type pitot tube (provided with extensions) fastened alongside the sampling nozzle. Flue gas temperature is monitored with a calibrated direct readout pyrometer equipped with a chromel-alumel (Type K) thermocouple positioned near the sampling nozzle. The probe, filter box, and impinger exit gas temperatures are monitored with a calibrated direct readout pyrometer equipped with Type K thermocouples positioned in the probe, heated filter chamber, and in the sample gas stream after the last impinger. Stack gas stream composition (carbon dioxide and oxygen content) is determined as previously described. The sampling rate is adjusted, based on stack velocity, at each point to ensure the sample is collected isokinetically.

At the conclusion of each test, the sampling train is leak checked. Upon completion of a successful leak check, the sampling train is dismantled, openings are sealed, and the components recovered as described below.

- The glass fiber filter(s) is/are removed from its holder with tweezers and placed in its original container, along with any particulate and filter fragments (Sample Fraction 1).




Figure B-1 EPA Reference Method 5 Sampling Train

K:\05565\008\010\REPORT\TKRAY\ONIER FB APR 09 BFB BOILER EMISSION TEST REPORT.DOC  
 28 April 2009 2:30 p.m. Version



- The probe and nozzle are separated and the particulate rinsed with distilled water or acetone into a polyethylene container while brushing a minimum of three times. Particulate adhering to the brush is rinsed with the appropriate solvent into the same container. The front half of the filter holder and connecting glassware are also rinsed. These rinses are combined (Sample Fraction 2).
- The total liquid content of impingers one, two, and three are measured volumetrically for stack gas moisture content calculation. This liquid is discarded.
- The silica gel is removed from the last impinger and immediately weighed to the nearest 0.1 g for stack gas moisture content calculation.
- Aliquots of the appropriate solvents and a filter are retained for blank analyses.

Each sample bottle is labeled to clearly identify its contents. The liquid level is marked on each bottle. The samples are then secured for transport to a laboratory for analysis. Sample integrity is assured by maintaining chain-of-custody records.

### **Sample Analysis**

The particulate analysis proceeds as follows:

- The sample filters (Sample Fraction 1) and blank filter are desiccated for 24 hours and weighed to the nearest 0.1 mg to constant ( $\pm 0.5$  mg) weight.
- The nozzle, probe, and front half of the filter holder wash samples (Sample Fraction 2), along with the solvent blank, are evaporated in tared beakers, then desiccated and weighed to the nearest 0.1 mg to constant ( $\pm 0.5$  mg) weights.

The total weight of material measured in the front half wash in addition to the weight of material collected on the glass fiber filter represent the total PM catch for each train. Blank corrections are made where appropriate for all sample weights.

### **Data Acquisition and Reduction**

Data are recorded at the time of collection on preprinted data sheets. Calculations are performed with preprogrammed calculators or spreadsheet software. Data transfers are minimized. Field and laboratory data sheets are checked for completeness and accuracy. Calculations are verified by a second person.



### Quality Control

Dry gas meters are calibrated before and after sampling. Thermocouples are calibrated against mercury thermometers, and aneroid barometers are calibrated against a mercury barometer. WESTON participated satisfactorily in the most recent dry gas meter audit supplied by the EPA. Those data are on file at WESTON.

Prior to and following each run, the sampling train is leak checked. An acceptable leak rate does not exceed the lesser of 0.02 actual cubic feet per minute (acfm) or 4% of the actual sampling rate. The isokinetic sampling rate is calculated at the completion of each sample run. If the isokinetic sampling rate is not within  $100\% \pm 10\%$ , the sample run is repeated.

Samples are transported to the laboratory under chain-of-custody. Solvent blanks and filter blanks are analyzed at the same time as the samples. The mass collected on the filters and the mass in the probe wash are corrected by the blank measurements.

WESTON uses Class S weights during each stage of the analysis to verify the accuracy of the balance. The balance is repaired and recalibrated before proceeding if there is a significant difference in the actual mass and measured mass.



**APPENDIX C**  
**FIELD DATA – BFB BOILER**  
**CONDITION ONE**  
**BARK WITH 45 ODTD SLUDGE**

---

Rayonier  
Fernandina Beach

05565.008.010  
BFB Boiler

### Bark w/ 45 ODTD Sludge

#### ISOKINETIC CALCULATIONS

Run Number		1	2	3	Mean
Date		4/15/09	4/15/09	4/15/09	---
Time Began		1157 ✓	1347 ✓	1535 ✓	---
Time Ended		1303	1455 ✓	1642 ✓	---
INPUT DATA					
Sampling Time, min	(Theta)	60.0 ✓	60 ✓	60 ✓	60
Stack Diameter, in.	(Dia.)	120.00 ✓	120.00 ✓	120.00 ✓	120.00
Barometric Pressure, in. Hg	(Pb)	29.94 ✓	29.94 ✓	29.94 ✓	29.94
Static Pressure, in. H2O	(Pg)	-0.83 ✓	-0.81 ✓	-0.72 ✓	-0.79
Pitot Tube Coefficient	(Cp)	0.84 ✓	0.84 ✓	0.84 ✓	0.84
Meter Correction Factor	(Y)	1.0110 ✓	1.0110 ✓	1.0110 ✓	1.0110
Orifice Calibration Value	(Delta H@)	1.6700 ✓	1.6700 ✓	1.6700 ✓	1.6700
Nozzle Diameter, in.	(Dn)	0.270 ✓	0.270 ✓	0.270 ✓	0.270
Meter Volume, ft <sup>3</sup>	(Vm)	36.625 ✓	36.892 ✓	34.790 ✓	36.102
Meter Temperature, °F	(Tm)	93.6 ✓	97.1 ✓	96.4 ✓	95.7
Meter Temperature, °R	(Tm-R)	553.6	557.1	556.4	555.7
Meter Orifice Pressure, in. H2O	(Delta H)	1.159 ✓	1.176 ✓	1.053 ✓	1.129
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> avg)	1.067 ✓	1.072 ✓	1.017 ✓	1.052
Volume H2O Collected, mL	(Vlc)	211.9 ✓	198.1 ✓	180.9 ✓	197.0
CO2 Concentration, %	(CO2)	13.2 ✓	13.2 ✓	13.1 ✓	13.2
O2 Concentration, %	(O2)	6.9 ✓	7.0 ✓	6.9 ✓	6.9
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> avg)	0.695 ✓	0.699 ✓	0.663 ✓	0.686
Stack Temperature, °F	(Ts)	367.2 ✓	370.7 ✓	371.3 ✓	369.7
Stack Temperature, °R	(Ts-R)	827.2	830.7	831.3	829.7
Particulate Collected, g	(Mn)	0.0376 ✓	0.0394 ✓	0.0434 ✓	0.0401
Moisture Fraction (at Saturation)	(BWS)	NA	NA	NA	0.000
O2 F-Factor, dscf/MMBtu	(Fd)	9605	9608	9610	9608
CALCULATED DATA					
Nozzle Area, ft <sup>2</sup>	(An)	3.98E-04	3.98E-04	3.98E-04	3.98E-04
Stack Area, ft <sup>2</sup>	(As)	78.54	78.54	78.54	78.54
Stack Pressure, in. Hg	(Ps)	29.88	29.88	29.89	29.88
Meter Pressure, in. Hg	(Pm)	30.03	30.03	30.02	30.02
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	35.426	35.461	33.473	34.786
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	9.974	9.325	8.515	9.271
Moisture Fraction (Measured)	(BWS)	0.220	0.208	0.203	0.210
Moisture Fraction (lower sat/meas)	(BWS)	0.220	0.208	0.203	0.210
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	30.39	30.39	30.37	30.38
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	27.67	27.81	27.86	27.78
Average Stack Gas Velocity, ft/sec	(Vs)	49.95	50.21	47.58	49.25
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	235405	236599	224235	232080
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	117040	118869	113370	116426
Isokinetic Sampling Rate, %	(%I)	99.7	98.2	97.2	98.4
Particulate Conc @ Std Cond, gr/ft <sup>3</sup>	(Cs)	0.0164	0.0171	0.0200	0.0178
Particulate Emission, lb/hr	(PMR)	16.4	17.5	19.4	17.8
Particulate Emission Factor, lb/MMBtu	(Fd)	0.0335	0.0354	0.0410	0.0366
Calibration check	(Yqa)	1.0131	1.0142	1.0193	1.016
Percent difference from Y					0.45%

CLIENT	: Rayonier	Balance ID: Mettler AE163
WESTON W.O. No.	: 05565.008.010	Density of Acetone (g/mL): 0.7848
Date Analyzed	: 4/15/09	Lab Ambient Temp (F): 68.7
Analyst	: SBrown	Lab Rel Humidity (%): 48
		Barometric Pressure (Hg): 29.94

Source Operating Mode/Condition	BFB Boiler			
	Bark w/ 45 ODTD Sludge			
Field Run No.	ONE	TWO	THREE	FIELD BLANK
<b>LIQUID FRACTION</b>				
Probe Wash ID				
Beaker ID	42-03	43-03	44-03	40-03
Liquid Volume (mL)	75	74	76	200
Initial Beaker Weights (g)				
Weight #1	109.4891	99.2506	100.3428	100.9652
Weight #2	109.4888	99.2504	100.3429	100.9653
<b>Average Initial Weight (g)</b>	<b>109.4890</b>	<b>99.2505</b>	<b>100.3429</b>	<b>100.9653</b>
Final Beaker Weights (g)				
Weight #1	109.5086	99.2650	100.3656	100.9660
Weight #2	109.5081	99.2652	100.3651	100.9658
<b>Average Final Weight (g)</b>	<b>109.5084</b>	<b>99.2651</b>	<b>100.3654</b>	<b>100.9659</b>
Final-Initial Beaker Wts. (g)	0.0194	0.0146	0.0225	0.0006
Sample/Blank Volume Ratio	0.3750	0.3700	0.3800	
Liquid Blank Correction (g)	0.0002	0.0002	0.0002	
<b>Liquid Particulate Weight (g)</b>	<b>0.0192</b>	<b>0.0144</b>	<b>0.0223</b>	<b>0.0006</b>
<b>FILTER FRACTION</b>				
Filter ID	DA 0631	DA 0632	DA 0633	DA 0635
Initial Filter Weights (g)				
Weight #1	37.8385	37.4267	37.2939	36.4322
Weight #2	37.8389	37.4264	37.2936	36.4320
<b>Average Initial Weight (g)</b>	<b>37.8387</b>	<b>37.4266</b>	<b>37.2938</b>	<b>36.4321</b>
Final Filter Weights (g)				
Weight #1	37.8571	37.4514	37.3149	36.4318
Weight #2	37.8571	37.4517	37.3149	36.4321
<b>Average Final Weight (g)</b>	<b>37.8571</b>	<b>37.4516</b>	<b>37.3149</b>	<b>36.4320</b>
Final-Initial Filter Wts. (g)	0.0184	0.0250	0.0211	-0.0001
Filter Blank (g)	-0.0001	-0.0001	-0.0001	
<b>Filter Particulate Weight (g)</b>	<b>0.0184</b>	<b>0.0250</b>	<b>0.0211</b>	
<b>SUMMARY</b>				
<b>Filter Particulate Weight (g)</b>	<b>0.0184</b>	<b>0.0250</b>	<b>0.0211</b>	
<b>Liquid Particulate Weight (g)</b>	<b>0.0192</b>	<b>0.0144</b>	<b>0.0223</b>	
<b>Net Particulate Weight (g)</b>	<b>0.0376</b>	<b>0.0394</b>	<b>0.0434</b>	

**Sample Recovery Solution**      Acetone  
**Weight Percent of Blank**      0.0004%  
**Liquid Fraction**

Note: If the blank liquid fraction has a residue weight percent of greater than 0.001 percent, then the samples are not blank corrected.

DA0631

# ISOKINETIC FIELD DATA SHEET

# EPA Method 5

Client: Rayonier  
 W.O.#: 05565.008.010  
 Project ID: Ray  
 Mode/Source ID: N/A  
 Samp. Loc. ID: BFB  
 Run No. ID: 1  
 Test Method ID: M5  
 Date ID: 7/15/09  
 Source/Location: BFB  
 Sample Date: 4/15/09  
 Baro. Press (in Hg): 29.94  
 Operator: BR

Stack Conditions	
Assumed	Actual
22	20.3
7.5	13.2
13.2	6.9
-23	-6.3
72	

Meter Box ID: A013  
 Meter Box Y: 1.011  
 Meter Box Del H: 1.470  
 Probe ID / Length: R25L 51  
 Probe Material: SS  
 Pitot / Thermocouple ID: P18  
 Pitot Coefficient: 0.84  
 Nozzle ID: 27  
 Avg Nozzle Dia (in): 270  
 Area of Stack (ft²): 78.54  
 Sample Time: 60  
 Total Traverse Pts: 24

Leak Checks  
 Sample Train (ft³): 0.009  
 Leak Check @ (in Hg): 15  
 Pitot good: Yes  
 Orsat good: Yes  
 Temp Check  
 Meter Box Temp: 240  
 Reference Temp: 240  
 Pass/Fail (+/- 2°): Pass  
 Temp Change Response: yes

K Factor		
Initial	Mid-Point	Final
0.009		0.009
15		7
Yes / no	Yes / no	Yes / no
Pre-Test Set	Post-Test Set	
Pass / Fail	Pass / Fail	
yes / no	yes / no	

TRAVERSE POINT NO.	SAMPLE DIST (ft)	CLOCK TIME (min)	VELOCITY PRESSURE (in. H <sub>2</sub> O)	ORIFICE PRESSURE (in. H <sub>2</sub> O)	DRY GAS METER READING (ft³)	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	WIND DIR	WIND SPEED (ft/min)	SAMPLE VOLUME (ft³)	WIND DIR	WIND SPEED (ft/min)	COMMENTS
	0	1157			59.575										
A1	2.5	3A	32.66	1.56	61.6	370	90		240	240	66	5	240		
2	5	4-15	32	1.82	63.4	379	92		240	240	64	5	252		
3	7.5		45	1.53	65.1	380	93		240	240	62	5	253		
4	10		49	1.15	66.7	378	93		238	240	60	5	254		
5	12.5		53	1.25	68.2	379	93		240	240	60	5	254		
6	15		42	49	69.6	371	93		240	240	61	5	251		
B1	17.5		60	1.41	71.3	370	90		240	240	60	5	250		
2	20		59	1.39	72.9	373	93		240	240	63	5	247		
3	22.5		52	1.22	74.5	373	94		240	240	62	5	252		
4	25		49	1.15	76.1	371	95		241	240	63	5	256		
5	27.5		41	96	77.5	362	95		242	240	63	5	250		
6	30		33	78	78.833	340	95		240	241	64	5	251		
C1	32.5		63	1.48	80.5	368	90		241	242	68	6	249		
2	35		57	1.34	82.2	368	94		240	240	59	5	250		
3	37.5		40	94	83.6	368	95		240	241	57	5	251		
4	40		38	89	85.0	360	94		240	240	59	4	251		
5	42.5		36	85	86.4	351	95		240	241	61	4	246		
6	45		31	73	87.639	350	95		241	240	61	4	245		
D1	47.5		66	1.55	89.4	370	92		240	240	63	5	249		
2	50		57	1.34	91.0	372	95		240	241	60	5	249		
3	52.5		46	1.08	92.5	373	95		240	240	60	5	250		
4	55		36	85	93.9	369	96		241	241	60	5	250		
5	57.5		33	78	95.1	368	95		241	242	61	5	250		
6	60	1203	30	71	96.60	350	95		241	242	61	4	251		

1303 EST  
 Avg Sqrt Delta P: 6954  
 Avg Delta H: 1.1588  
 Total Volume: 36.625  
 Avg Ts: 367.2  
 Avg Tm: 93.6  
 Min/Max: 238/242  
 Min/Max: 240/242  
 Max Temp: 68  
 Max Vac: 6  
 Max Temp: 256  
 Comments: 1.0467  
 ISO = 100  
 moist = 22.1





D40632

# ISOKINETIC FIELD DATA SHEET

# EPA Method 5

Client: Rayonier  
 W.O.#: 05565:008:010  
 Project ID: Ray % Moisture  
 Mode/Source ID: N2 Impinger Vol (ml)  
 Samp. Loc. ID: BFB Silica gel (g)  
 Run No. ID: 2 CO2, % by Vol  
 Test Method ID: M5 O2, % by Vol  
 Date ID: 4/15/09 Temperature (°F)  
 Source/Location: BFB Meter Temp (°F)  
 Sample Date: 4/15/09 Static Press (in H2O)  
 Baro. Press (in Hg): 29.54  
 Operator: JN Ambient Temp (°F): 74

Stack Conditions  
 Assumed Actual  
 Meter Box ID: A-213  
 Meter Box Y: 1.011  
 Meter Box Del H: 1.670  
 Probe ID / Length: P250 / 5'  
 Probe Material: SS  
 Pitot / Thermocouple ID: P18  
 Pitot Coefficient: 0.84  
 Nozzle ID: 27  
 Avg Nozzle Dia (in): 2.70  
 Area of Stack (ft²): 78.54  
 Sample Time: 60  
 Total Traverse Pts: 24

Leak Checks  
 Sample Train (ft³): 0.05  
 Leak Check @ (in Hg): 15  
 Pitot good: Yes  
 Orsat good: Yes  
 Temp Check  
 Meter Box Temp: 240  
 Reference Temp: 241  
 Pass/Fail (+/- 2°): Pass  
 Temp Change Response: yes

K Factor <u>2.35</u>		
Initial	Mid-Point	Final
<u>0.05</u>	<u>0.05</u>	<u>0.05</u>
Fail / no:	yes / no:	(yes) / no:
yes / no:	yes / no:	yes / no:
Pre-Test Set		Post-Test Set
Pass / Fail	Pass / Fail	Pass / Fail
yes / no	yes / no	yes / no

TRAVERSE POINT NO	SAMPLE TIME (min)	CLOCK TIME (min:sec)	VELOCITY PRESSURE (in H2O)	ORIFICE PRESSURE (in H2O)	DRY GAS METER READING (ft³)	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	WIND	IMPINGEMENT	SAMPLE TRAIN (ft)	WIND	COMMENTS
	0	1347			97.888									
A1	2.5		.63	1.48	97.5	370	91		240	240	66	5	240	
2	5		.60	1.41	101.3	376	95		240	241	62	5	241	
3	7.5		.51	1.20	102.8	375	97		240	240	61	5	241	
4	10		.40	.94	104.3	372	98		240	241	59	5	247	
5	12.5		.30	.71	109.5	371	98		240	240	59	4	243	
6	15		.27	.63	106.676	362	97		240	240	59	4	249	
B1	17.5		.55	1.29	108.4	369	93		240	240	64	4	251	
2	20		.57	1.34	110.1	375	98		241	242	60	5	247	
3	22.5		.46	1.08	111.7	373	99		246	246	60	5	255	
4	25		.35	.82	112.9	367	99		244	242	60	5	256	
5	27.5		.33	.78	114.2	360	98		245	241	63	5	255	
6	30		.27	.63	115.362	350	99		240	240	63	4	252	
C1	32.5		.67	1.67	117.2	374	95		240	241	66	6	255	
2	35		.68	1.60	118.9	375	99		241	240	61	6	251	
3	37.5		.59	1.39	120.6	376	99		240	241	60	6	264	
4	40		.65	1.53	122.4	378	99		240	242	60	6	260	
5	42.5		.50	1.18	123.9	361	100		240	241	61	6	259	
6	45		.40	.94	125.416	350	98		241	240	62	5	258	
D1	47.5		.74	1.79	122.1	377	94		240	241	67	5	253	
2	50		.63	1.48	128.8	379	97		240	242	66	5	259	
3	52.5		.65	1.53	130.6	380	97		241	242	64	4	254	
4	55		.50	1.18	132.1	379	97		240	242	61	5	260	
5	57.5		.37	.87	133.5	377	97		241	241	61	5	260	
6	60	1455	.34	.80	134.780	370	97		240	241	61	5	260	

Avg Sqrt Delta P: 2.5000  
 Avg Delta H: 1.1758  
 Total Volume: 36.872  
 Avg Ts: 370.7  
 Avg Tm: 97.1  
 Min/Max: 240/246  
 Min/Max: 240/246  
 Max Temp: 67  
 Max Vac: 6  
 Max Temp: 264  
 Avg Sqrt Del H: 1.0723  
 Comments:



D20633

# ISOKINETIC FIELD DATA SHEET

# EPA Method 5

Client: Rayonier  
 W.O.#: 05565:008:010  
 Project ID: Ray  
 Mode/Source ID: -  
 Samp. Loc. ID: BFB  
 Run No. ID: 3  
 Test Method ID: M5  
 Date ID: 4/15/05  
 Source/Location: BFB  
 Sample Date: 4/15/05  
 Baro. Press (in Hg): 29.74  
 Operator: [Signature]

Stack Conditions	
Assumed	Actual
	122
	8.5
	13.1
	6.5
	-72
	72

Meter Box ID: M013  
 Meter Box Y: 1.511  
 Meter Box Del H: 1.070  
 Probe ID / Length: P252 / 5'  
 Probe Material: SS  
 Pitot / Thermocouple ID: P12  
 Pitot Coefficient: 0.84  
 Nozzle ID: 27  
 Avg Nozzle Dia (in): 270  
 Area of Stack (ft²): 78.54  
 Sample Time: 60  
 Total Traverse Pts: 24

Leak Checks  
 Sample Train (ft³): 0.05  
 Leak Check @ (in Hg): 7  
 Pitot good: Yes / no  
 Orsat good: Yes / no  
 Temp Check  
 Meter Box Temp  
 Reference Temp  
 Pass/Fail (+/- 2°)  
 Temp Change Response

K Factor 2.35		
Initial	Mid-Point	Final
0.05		0.05
15		7
Yes / no	Yes / no	Yes / no
Yes / no	Yes / no	Yes / no
Pre-Test Set		Post-Test Set
Pass / Fail		Pass / Fail
yes / no		yes / no

TRAVERSE POINT NO.	SAMPLE TIME (min)	BLOCK TIME (min)	VELOCITY PRESSURE (in H <sub>2</sub> O)	ORIFICE PRESSURE (in H <sub>2</sub> O)	DRY GAS METER READING (ml)	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VAC (in Hg)	COMMENTS
	0	15:35			135.26							
A1	2.5		.68	1.40	137.1	374	88		240	240	67	5 240
2	5		.55	1.29	138.7	376	94		240	240	65	5 240
3	7.5		.46	.94	140.1	376	95		240	240	64	5 244
4	10		.57	1.34	141.7	376	95		240	240	60	5 252
5	12.5		.53	1.24	143.2	376	95		240	240	60	5 250
6	15		.39	.92	144.6	370	96		241	242	58	5 251
B1	17.5		.55	1.28	146.2	370	90		242	244	67	5 250
2	20		.54	1.32	147.7	375	95		242	240	58	5 251
3	22.5		.58	1.36	149.3	375	96		241	240	56	5 258
4	25		.44	1.03	150.8	373	97		240	242	56	5 257
5	27.5		.37	.87	152.1	372	97		240	241	57	5 261
6	30		.30	.71	153.401	365	97		242	240	57	5 255
C1	32.5		.50	1.18	154.9	372	92		244	242	68	5 250
2	35		.46	1.08	156.4	373	99		240	241	65	4 265
3	37.5		.45	1.06	157.9	372	97		240	242	60	4 255
4	40		.35	.82	159.2	364	98		240	241	64	5 259
5	42.5		.34	.80	160.5	368	98		240	242	64	5 259
6	45		.27	.63	161.715	360	98		241	244	64	5 255
D1	47.5		.63	1.48	163.3	372	94		240	240	64	5 250
2	50		.57	1.34	165.0	376	100		240	270	68	5 251
3	52.5		.44	1.03	166.5	374	101		241	241	66	5 255
4	55		.31	.73	167.7	372	101		242	244	66	5 256
5	57.5		.27	.63	168.9	370	101		241	244	65	5 255
6	60	1642	.25	.59	170.053	361	100		241	242	65	5 260

Avg Sqrt Delta P	Avg Delta H	Total Volume	Avg Ts	Avg Tm	Min/Max	Min/Max	Max Temp	Max Vac	Max Temp
0.632	1.0533	34.790	371.3	94.4	240/242	240/244	68	6	261
Avg Sqrt Del H	Comments:								
1.0165									



Aug 3 41483

(8)

### SAMPLE RECOVERY FIELD DATA

EPA Method 5

Client Rayonier W.O. # 05565.008.010  
 Location/Plant Fernandina Beach, FL Source & Location BFB

Run No. 1 Sample Date 4-15-07 Recovery Date 4-15-07  
 Sample I.D. BFB Analyst BZ/SB Filter Number 22063

	Impinger							Imp.Total	8	Total
	1	2	3	4	5	6	7			
Contents	H2O	H2O	Empty						Silica Gel	
Final	296	104	3						327.9	
Initial	100	100	0						319.8	
Gain	196	4	3					203	8.9	211.9

Impinger Color Clear Labeled? Y  
 Silica Gel Condition Good Sealed? Y

Run No. 2 Sample Date 4-15-07 Recovery Date 4-15-07  
 Sample I.D. BFB Analyst BZ/SB Filter Number 22063

	Impinger							Imp.Total	8	Total
	1	2	3	4	5	6	7			
Contents	H2O	H2O	Empty						Silica Gel	
Final	282	103	3						330.3	
Initial	100	100	0						320.2	
Gain	182	3	3					188	10.1	198.1

Impinger Color Clear Labeled? Y  
 Silica Gel Condition Good Sealed? Y

Run No. 3 Sample Date 4-15-07 Recovery Date 4-15-07  
 Sample I.D. BFB Analyst BZ/SB Filter Number 220633

	Impinger							Imp.Total	8	Total
	1	2	3	4	5	6	7			
Contents	H2O	H2O	Empty						Silica Gel	
Final	264	104	4						336.2	
Initial	100	100	0						322.3	
Gain	164	4	4					172	8.9	180.9

Impinger Color Clear Labeled? Y  
 Silica Gel Condition Good Sealed? Y

Check COC for Sample IDs of Media Blanks



8

# Sample and Velocity Traverse Point Data Sheet - Method 1

Client Rayonier Operator TS  
 Location/Plant Fernandina Beach, FL Date 2-Oct-07  
 Source BFB Boiler W.O. Number 05565.008.007010



**Duct Type**     Circular     Rectangular Duct    Indicate appropriate type  
**Traverse Type**     Particulate Traverse     Velocity Traverse

Distance from far wall to outside of port (in.) = C	<b>126.00</b>
Port Depth (in.) = D	<b>6.00</b>
Depth of Duct, diameter (in.) = C-D	<b>120</b>
Area of Duct (ft <sup>2</sup> )	<b>78.54</b>
Total Traverse Points	<b>24</b>
Total Traverse Points per Port	<b>12</b>

**Rectangular Ducts Only**  
 Width of Duct, rectangular duct only (in.)  
 Total Ports (rectangular duct only)

Traverse Point Locations			
Traverse Point	% of Duct	Distance from Inside Duct Wall (in)	Distance from Outside of Port (in)
1	2.1	2 1/2	8 1/2
2	6.7	8	14
3	11.8	14	20
4	17.7	21	27
5	25.0	30	36
6	35.6	42 1/2	48 1/2
7	64.4	77 1/2	83 1/2
8	75.0	90	96
9	82.3	99	105
10	88.2	106	112
11	93.3	112	118
12	97.9	117 1/2	123 1/2

Flow Disturbances	
Upstream - A (ft)	<b>100.0</b>
Downstream - B (ft)	<b>30.0</b>
Upstream - A (duct diameters)	<b>10.0</b>
Downstream - B (duct diameters)	<b>3.0</b>



Equivalent Diameter =  $(2 \cdot L \cdot W) / (L + W)$

Traverse Point Location Percent of Stack -Circular												
	Number of Traverse Points											
	1	2	3	4	5	6	7	8	9	10	11	12
1		14.6		6.7		4.4		3.2		2.6		2.1
2		85.4		25		14.6		10.5		8.2		6.7
3			75		29.6		19.4		14.6		11.8	
4			93.3		70.4		32.3		22.6		17.7	
5				85.4		67.7		34.2		25		
6				95.6		80.6		65.8		35.6		
7					89.5		77.4		64.4			
8					96.8		85.4		75			
9						91.8		82.3				
10						97.4		88.2				
11							93.3					
12								97.9				

Traverse Point Location Percent of Stack -Rectangular												
	Number of Traverse Points											
	1	2	3	4	5	6	7	8	9	10	11	12
1		25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
2		75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3			83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
4				87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
5					90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
6						91.7	78.6	68.8	61.1	55.0	50.0	45.8
7							92.9	81.3	72.2	65.0	59.1	54.2
8								93.8	83.3	75.0	68.2	62.5
9									94.4	85.0	77.3	70.8
10										95.0	86.4	79.2
11											95.5	87.5
12												95.8

**Rectangular Stack Points & Matrix**

- 9 - 3 x 3
- 12 - 4 x 3
- 16 - 4 x 4
- 20 - 5 x 4
- 25 - 5 x 5
- 30 - 6 x 5
- 36 - 6 x 6
- 42 - 7 x 6
- 49 - 7 x 7



**RUN DATA**

Number 3

Client: **Rayonier**  
 Location: **Fernandina Beach, FL**  
 Source: **BFB**  
 Calibration: **1**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **15 Apr 2009**

Time	O2		CO2	
	mv	%	mv	%
Starting time 15:21				
Run 1 Compliance				
15:21:52	2364	6.9	4384	13.2
15:22:02	2363	6.9	4385	13.2
15:22:12	2367	6.9	4380	13.2
15:22:22	2363	6.9	4385	13.2
15:22:32	2367	6.9	4385	13.2
15:22:42	2366	6.9	4385	13.2
15:22:52	2370	6.9	4387	13.2
15:23:02	2366	6.9	4385	13.2
15:23:12	2366	6.9	4387	13.2
15:23:22	2367	6.9	4387	13.2
<b>Run Avg</b>	<b>2366</b>	<b>6.9</b>	<b>4385</b>	<b>13.2</b>

**RUN DATA**

Number 4

Client: **Rayonier**  
 Location: **Fernandina Beach, FI**  
 Source: **BFB**  
 Calibration: **1**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **15 Apr 2009**

---

Time	O2		CO2	
	mv	%	mv	%
Starting time 15:24				
Run 2 Compliance				
15:24:45	2405	7.0	4341	13.1
15:24:55	2396	7.0	4385	13.2
15:25:05	2395	7.0	4397	13.2
15:25:15	2400	7.0	4400	13.3
15:25:25	2392	7.0	4400	13.3
15:25:35	2404	7.0	4399	13.2
15:25:45	2394	7.0	4396	13.2
<b>Run Avg</b>	<b>2398</b>	<b>7.0</b>	<b>4388</b>	<b>13.2</b>

---

**RUN DATA**

Number 5

Client: **Rayonier**  
 Location: **Fernandina Beach, Fl**  
 Source: **BFB**  
 Calibration: **1**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **15 Apr 2009**

Time	O2		CO2	
	mv	%	mv	%
Starting time 17:09				
Run 3 Compliance				
17:09:44	2358	6.9	4360	13.1
17:09:54	2363	6.9	4362	13.1
17:10:04	2356	6.9	4362	13.1
17:10:14	2357	6.9	4359	13.1
17:10:24	2360	6.9	4362	13.1
17:10:34	2359	6.9	4361	13.1
17:10:44	2359	6.9	4361	13.1
17:10:54	2359	6.9	4357	13.1
17:11:04	2360	6.9	4363	13.1
17:11:14	2357	6.9	4361	13.1
17:11:24	2357	6.9	4362	13.1
<b>Run Avg</b>	<b>2359</b>	<b>6.9</b>	<b>4361</b>	<b>13.1</b>

**CALIBRATION**

Number 1

Client: **Rayonier**  
 Location: **Fernandina Beach, FL**  
 Source: **BFB**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **15 Apr 2009**

Starting Time: 11:39

**O2**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results		
%	Cylinder ID	Result, mv
Zero	-	-4
12.0	CC 159811	4117
25.9	SG0067	8853
Curve Coefficients		
Slope	Intercept	Corr. Coeff.
341.9	2.5	>0.9999

**CO2**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results		
%	Cylinder ID	Result, mv
Zero	-	-10
12.1	CC 159811	3969
24.4	SG0067	8152
Curve Coefficients		
Slope	Intercept	Corr. Coeff.
334.5	-32.7	>0.9999



**CALIBRATION ERROR**

Number 1

Client: **Rayonier**  
 Location: **Fernandina Beach, Fl**  
 Source: **BFB**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **15 Apr 2009**

Starting Time: 11:39

**O2**

Method: EPA 3A

Slope 341.9

Intercept 2.5

Standard, %	Response, mV	%	Error, %
Zero	-4	0.0	0.0
12.0	4117	12.0	0.0
25.9	8853	25.9	0.0

**CO2**

Method: EPA 3A

Slope 334.5

Intercept -32.7

Standard, %	Response, mV	%	Error, %
Zero	-10	0.1	0.4
12.1	3969	12.0	-0.4
24.4	8152	24.5	0.4

**ANALYZER INFORMATION**

Client: **Rayonier**  
Location: **Fernandina Beach, Fl**  
Source: **BFB**

Project Number: **05565.008.010**  
Operator: **BR**  
Date: **15 Apr 2009**

---

**File Name:** C:\DATA\Rayonier Fernandina\BFB O2Bags.cem  
**Computer:** WSAUB58 **Trailer:** 201

---

**Analog Input Device:** Keithley KPCMCIA 16AI Card

---

**Channel 1**

Analyte	<b>O2</b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Servomex 4900 SN: 652836</b>
Full-Scale Output, mv	<b>10000</b>
Span Concentration, %	<b>25.9</b>

**Channel 2**

Analyte	<b>CO2</b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Servomex 4900 SN: 652836</b>
Full-Scale Output, mv	<b>10000</b>
Span Concentration, %	<b>24.4</b>

## Determination of Stack Gas Velocity - Method 2

Client Rayonier Operator BR/SB Pitot Coeff (Cp) 0.84  
 Location/Plant Fernandina Beach, FL Date 4/15/09 Stack Area, ft<sup>2</sup> (As) 78.54  
 Source BFB W.O. Number 05565.008.010 Pitot Tube/Thermo ID P18

Run Number	Prelim	
Time	909	
Barometric Press, in Hg (Pb)	<del>29.74</del> 29.94	
Static Press, in H <sub>2</sub> O (Pstatic)	- 73	
Source Moisture, % (BWS)		
O <sub>2</sub> , %		
CO <sub>2</sub> , %		

Cyclonic Flow Determination		Traverse Location		Leak Check good ? Y/N		Leak Check good ? Y/N		Leak Check good ? Y/N	
Delta P at 0°	Angle yielding zero Delta P	Port	Point	Delta P	Source Temp, F° (Ts)	Delta P	Source Temp, F° (Ts)	Delta P	Source Temp, F° (Ts)
.07	15	A	1	.61	362				
.05	10		2	.59	368				
.05	10		3	.53	370				
.05	10		4	.45	370				
.06	12		5	.36	358				
.04	8		6	.25	355				
.04	10	B	1	.68.66	365	4/15/09			
.09	8		2	.56	367				
.04	7		3	.32	368				
.10	12		4	.25	367				
.12	15		5	.20	357				
.12	15		6	.16	354				
.12	12	C	1	.53	362				
.10	12		2	.45	363				
.10	10		3	.43	364				
.07	10		4	.45	364				
.09	4		5	.39	352				
.05	9		6	.33	349				
.05	14	D	1	.62	359				
.21	19		2	.58	364				
.14	15		3	.58	368				
.10	10		4	.56	370				
.10	11		5	.45	360				
.07	10		6	.26	359				
Avg Angle		Avg Delta P & Temp		.4404	362.5				
		and $\sqrt{\Delta P / \rho}$		.6536					
Average gas stream velocity, ft/sec.									
Vol. flow rate @ actual conditions, wacf/min									
Vol. flow rate at standard conditions, dscf/min									

$$MWd = (0.32 * O_2) + (0.44 * CO_2) + (0.28 * (100 - (CO_2 + O_2)))$$

$$MWs = (MWd * (1 - (BWS/100))) + (18 * (BWS/100))$$

$$1.29 = 1.2 + 4.0$$

$$Ps = Pb + (Pstatic / 13.6)$$

$$Vs = 85.49 * Cp * \text{avg} \sqrt{\Delta P} * \sqrt{Tsa / (Ps * MWs)}$$

$$Qs(\text{act}) = 60 * Vs * As$$

$$Qs(\text{std}) = 17.64 * (1 - (BWS/100)) * (Ps/Tsa) * Qs(\text{act})$$

where:

MWd = Dry molecular weight source gas, lb/lb-mole.

MWs = Wet molecular weight source gas, lb/lb-mole.

Tsa = Source Temperature, absolute (oR)

Ps = Absolute stack static pressure, inches Hg.

Vs = Average gas stream velocity, ft/sec.

Qs(act) = Volumetric flow rate of wet stack gas at actual, wacf/min

Qs(std) = Volumetric flow rate of dry stack gas at standard conditions, dscf/min



Comments \_\_\_\_\_  
method2



**APPENDIX D**  
**FIELD DATA – BFB BOILER**  
**CONDITION TWO**  
**BARK WITH 60 ODTD SLUDGE**

---

Rayonier  
Fernandina Beach

05565.008.010  
BFB Boiler

### Bark w/ 60 ODTD Sludge

#### ISOKINETIC CALCULATIONS

Run Number		1	2	3	Mean
Date		4/16/09	4/16/09	4/16/09	---
Time Began		922 ✓	1100 ✓	1239 ✓	---
Time Ended		1030 ✓	1207 ✓	1346 ✓	---
INPUT DATA					
Sampling Time, min	(Theta)	60.0 ✓	60 ✓	60 ✓	60
Stack Diameter, in.	(Dia.)	120.00 ✓	120.00 ✓	120.00 ✓	120.00
Barometric Pressure, in. Hg	(Pb)	30.06 ✓	30.06 ✓	30.06 ✓	30.06
Static Pressure, in. H2O	(Pg)	-0.75 ✓	-0.71 ✓	-0.71 ✓	-0.72
Pitot Tube Coefficient	(Cp)	0.84	0.84	0.84	0.84
Meter Correction Factor	(Y)	1.0110 ✓	1.0110 ✓	1.0110 ✓	1.0110
Orifice Calibration Value	(Delta H@)	1.6700 ✓	1.6700 ✓	1.6700 ✓	1.6700
Nozzle Diameter, in.	(Dn)	0.270 ✓	0.270 ✓	0.270 ✓	0.270
Meter Volume, ft <sup>3</sup>	(Vm)	34.744 ✓	35.019 ✓	34.405 ✓	34.723
Meter Temperature, °F	(Tm)	73.2 ✓	71.8 ✓	70.1 ✓	71.7
Meter Temperature, °R	(Tm-R)	533.2	531.8	530.1	531.7
Meter Orifice Pressure, in. H2O	(Delta H)	1.092 ✓	1.097 ✓	1.057 ✓	1.082
Ave Sq Rt Orifice Press, (in. H2O) <sup>1/2</sup>	((Delta H) <sup>1/2</sup> avg)	1.036 ✓	1.040 ✓	1.021 ✓	1.032
Volume H2O Collected, mL	(Vlc)	215.7 ✓	196.3 ✓	207.6 ✓	206.5
CO2 Concentration, %	(CO2)	13.1 ✓	13.2 ✓	13.2 ✓	13.2
O2 Concentration, %	(O2)	7.1 ✓	6.9 ✓	6.9 ✓	7.0
Ave Sq Rt Velo Head, (in. H2O) <sup>1/2</sup>	((Delta P) <sup>1/2</sup> avg)	0.687 ✓	0.685 ✓	0.673 ✓	0.682
Stack Temperature, °F	(Ts)	373.7 ✓	369.0 ✓	363.2 ✓	368.6
Stack Temperature, °R	(Ts-R)	833.7	829.0	823.2	828.6
Particulate Collected, g	(Mn)	0.0334 ✓	0.0302 ✓	0.0425 ✓	0.0354
Moisture Fraction (at Saturation)	(BWS)	NA	NA	NA	0.000
O2 F-Factor, dscf/MMBtu	(Fd)	9604	9608	9604	9605
CALCULATED DATA					
Nozzle Area, ft <sup>2</sup>	(An)	3.98E-04	3.98E-04	3.98E-04	3.98E-04
Stack Area, ft <sup>2</sup>	(As)	78.54	78.54	78.54	78.54
Stack Pressure, in. Hg	(Ps)	30.00	30.01	30.01	30.01
Meter Pressure, in. Hg	(Pm)	30.14	30.14	30.14	30.14
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	35.026	35.396	34.884	35.102
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	10.153	9.240	9.772	9.722
Moisture Fraction (Measured)	(BWS)	0.225	0.207	0.219	0.217
Moisture Fraction (lower sat/meas)	(BWS)	0.225	0.207	0.219	0.217
Mol. Wt. of Dry Gas, lb/lb-mole	(Md)	30.38	30.39	30.39	30.39
Mol. Wt. of Stack Gas, lb/lb-mole	(Ms)	27.60	27.82	27.68	27.70
Average Stack Gas Velocity, ft/sec	(Vs)	49.53	49.04	48.09	48.89
Stack Gas Flow, actual, ft <sup>3</sup> /min	(Qa)	233409	231118	226637	230388
Stack Gas Flow, Std, ft <sup>3</sup> /min	(Qs)	114882	117026	113843	115250
Isokinetic Sampling Rate, %	(%I)	100.4	99.6	100.9	100.3
Particulate Conc @ Std Cond, gr/ft <sup>3</sup>	(Cs)	0.0147	0.0132	0.0188	0.0156
Particulate Emission, lb/hr	(PMR)	14.5	13.2	18.3	15.3
Particulate Emission Factor, lb/MMBtu	(Fd)	0.0306	0.0270	0.0385	0.0320
Calibration check	(Yqa)	1.0161	1.0105	1.0078	1.011
Percent difference from Y					0.05%

CLIENT	: Rayonier	Balance ID: Mettler AE163
WESTON W.O. No.	: 05565.008.010	Density of Acetone (g/mL): 0.7848
Date Analyzed	: 4/16/09	Lab Ambient Temp (F): 68.7
Analyst	: SBrown	Lab Rel Humidity (%): 48
		Barometric Pressure (Hg): 30.06

Source	BFB Boiler			
Operating Mode/Condition	Bark w/ 60 ODTD Sludge			
Field Run No.	ONE	TWO	THREE	FIELD BLANK
<b>LIQUID FRACTION</b>				
Probe Wash ID				
Beaker ID	45-03	46-03	47-03	40-03
Liquid Volume (mL)	90	95	75	200
Initial Beaker Weights (g)				
Weight #1	123.5208	109.7059	116.3972	100.9652
Weight #2	123.5208	109.7060	116.3971	100.9653
<b>Average Initial Weight (g)</b>	<b>123.5208</b>	<b>109.7060</b>	<b>116.3972</b>	<b>100.9653</b>
Final Beaker Weights (g)				
Weight #1	123.5395	109.7187	116.4163	100.9660
Weight #2	123.5397	109.7188	116.4168	100.9658
<b>Average Final Weight (g)</b>	<b>123.5396</b>	<b>109.7188</b>	<b>116.4166</b>	<b>100.9659</b>
Final-Initial Beaker Wts. (g)	0.0188	0.0128	0.0194	0.0006
Sample/Blank Volume Ratio	0.4500	0.4750	0.3750	
Liquid Blank Correction (g)	0.0003	0.0003	0.0002	
<b>Liquid Particulate Weight (g)</b>	<b>0.0185</b>	<b>0.0125</b>	<b>0.0192</b>	<b>0.0006</b>
<b>FILTER FRACTION</b>				
Filter ID	DA 0634	DA 0636	DA 0637	DA 0635
Initial Filter Weights (g)				
Weight #1	33.5520	38.5703	38.9667	36.4322
Weight #2	33.5518	38.5699	38.9666	36.4320
<b>Average Initial Weight (g)</b>	<b>33.5519</b>	<b>38.5701</b>	<b>38.9667</b>	<b>36.4321</b>
Final Filter Weights (g)				
Weight #1	33.5667	38.5879	38.9899	36.4318
Weight #2	33.5669	38.5877	38.9901	36.4321
<b>Average Final Weight (g)</b>	<b>33.5668</b>	<b>38.5878</b>	<b>38.9900</b>	<b>36.4320</b>
Final-Initial Filter Wts. (g)	0.0149	0.0177	0.0233	-0.0001
Filter Blank (g)	-0.0001	-0.0001	-0.0001	
<b>Filter Particulate Weight (g)</b>	<b>0.0149</b>	<b>0.0177</b>	<b>0.0233</b>	
<b>SUMMARY</b>				
<b>Filter Particulate Weight (g)</b>	<b>0.0149</b>	<b>0.0177</b>	<b>0.0233</b>	
<b>Liquid Particulate Weight (g)</b>	<b>0.0185</b>	<b>0.0125</b>	<b>0.0192</b>	
<b>Net Particulate Weight (g)</b>	<b>0.0334</b>	<b>0.0302</b>	<b>0.0425</b>	

Sample Recovery Solution                      Acetone

Weight Percent of Blank                      0.0004%

Liquid Fraction

Note: If the blank liquid fraction has a residue weight percent of greater than 0.001 percent, then the samples are not blank corrected.

200634

# ISOKINETIC FIELD DATA SHEET

# EPA Method 5

Client: Rayonier  
 W.O.#: 05565/008.010  
 Project ID: Ray % Moisture  
 Mode/Source ID: Camp Impinger Vol (ml)  
 Samp. Loc. ID: BFB Silica gel (g)  
 Run No.ID: 1 CO2, % by Vol  
 Test Method ID: M5 O2, % by Vol  
 Date ID: 4/16/07 Temperature (°F)  
 Source/Location: BFB Meter Temp (°F)  
 Sample Date: 4/16/07 Static Press (in H2O)  
 Baro. Press (in Hg): 30.06  
 Operator: BA Ambient Temp (°F): 65

Stack Conditions	
Assumed	Actual
	<u>208</u>
	<u>7.7</u>
	<u>13.1</u>
	<u>7.1</u>
	<u>-7.5</u>
	<u>65</u>

Meter Box ID: A013  
 Meter Box Y: 1.011  
 Meter Box Del H: 1.670  
 Probe ID / Length: PR56 / 51  
 Probe Material: SS  
 Pitot / Thermocouple ID: P18  
 Pitot Coefficient: 0.84  
 Nozzle ID: 27  
 Avg Nozzle Dia (in): .270  
 Area of Stack (ft²): 78.54  
 Sample Time: 60  
 Total Traverse Pts: 24

Leak Checks  
 Sample Train (ft³): 0.5  
 Leak Check @ (in Hg): 7  
 Pitot good: yes / no  
 Orsat good: yes / no  
 Temp Check  
 Meter Box Temp: 208  
 Reference Temp: 65  
 Pass/Fail (+/- 2°): Pass / Fail  
 Temp Change Response: yes / no

K Factor	Initial	Mid-Point	Final
<u>2.27</u>	<u>0.5</u>	<u>0.5</u>	<u>0.5</u>
	<u>yes / no</u>	<u>yes / no</u>	<u>yes / no</u>
	<u>yes / no</u>	<u>yes / no</u>	<u>yes / no</u>
	<u>Pass / Fail</u>	<u>Pass / Fail</u>	<u>Pass / Fail</u>
	<u>yes / no</u>	<u>yes / no</u>	<u>yes / no</u>

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (start time)	VELOCITY PRESSURE Delta P (in H2O)	ORIFICE PRESSURE Delta P (in H2O)	DRY GAS METER READING (SCF)	STACK TEMPERATURE (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER TEMP	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VAC (in Hg)	ORSAT	COMMENTS
	<u>0</u>	<u>422</u>			<u>170.580</u>									
A1	2.5		<u>.65</u>	<u>1.48</u>	<u>172.4</u>	<u>378</u>	<u>68</u>	<u>70</u>	<u>240</u>	<u>240</u>	<u>60</u>	<u>4</u>	<u>258</u>	
2	5		<u>.52</u>	<u>1.18</u>	<u>174.0</u>	<u>378</u>	<u>70</u>		<u>240</u>	<u>240</u>	<u>60</u>	<u>4</u>	<u>255</u>	
3	7.5		<u>.43</u>	<u>.98</u>	<u>175.4</u>	<u>378</u>	<u>72</u>		<u>240</u>	<u>240</u>	<u>58</u>	<u>4</u>	<u>260</u>	
4	10		<u>.44</u>	<u>1.00</u>	<u>176.8</u>	<u>378</u>	<u>72</u>		<u>240</u>	<u>240</u>	<u>57</u>	<u>4</u>	<u>265</u>	
5	12.5		<u>.50</u>	<u>1.14</u>	<u>178.3</u>	<u>368</u>	<u>73</u>		<u>240</u>	<u>240</u>	<u>57</u>	<u>4</u>	<u>264</u>	
6	15		<u>.45</u>	<u>1.02</u>	<u>179.614</u>	<u>365</u>	<u>73</u>		<u>240</u>	<u>241</u>	<u>57</u>	<u>4</u>	<u>261</u>	
B1	17.5		<u>.72</u>	<u>1.63</u>	<u>181.3</u>	<u>375</u>	<u>72</u>		<u>240</u>	<u>240</u>	<u>58</u>	<u>5</u>	<u>250</u>	
2	20		<u>.68</u>	<u>1.54</u>	<u>183.0</u>	<u>381</u>	<u>73</u>		<u>240</u>	<u>240</u>	<u>57</u>	<u>5</u>	<u>263</u>	
3	22.5		<u>.55</u>	<u>1.25</u>	<u>184.6</u>	<u>381</u>	<u>74</u>		<u>240</u>	<u>240</u>	<u>55</u>	<u>5</u>	<u>261</u>	
4	25		<u>.60</u>	<u>1.36</u>	<u>186.1</u>	<u>381</u>	<u>74</u>		<u>240</u>	<u>240</u>	<u>55</u>	<u>5</u>	<u>260</u>	
5	27.5		<u>.44</u>	<u>1.00</u>	<u>187.5</u>	<u>378</u>	<u>74</u>		<u>240</u>	<u>241</u>	<u>54</u>	<u>5</u>	<u>261</u>	
6	30		<u>.33</u>	<u>.75</u>	<u>188.789</u>	<u>350</u>	<u>75</u>		<u>240</u>	<u>241</u>	<u>54</u>	<u>4</u>	<u>262</u>	
C1	32.5		<u>.64</u>	<u>1.45</u>	<u>190.4</u>	<u>378</u>	<u>71</u>		<u>242</u>	<u>241</u>	<u>57</u>	<u>6</u>	<u>260</u>	
2	35		<u>.54</u>	<u>1.23</u>	<u>192.0</u>	<u>377</u>	<u>74</u>		<u>241</u>	<u>242</u>	<u>55</u>	<u>6</u>	<u>262</u>	
3	37.5		<u>.46</u>	<u>1.04</u>	<u>193.4</u>	<u>376</u>	<u>74</u>		<u>241</u>	<u>242</u>	<u>55</u>	<u>5</u>	<u>260</u>	
4	40		<u>.40</u>	<u>.91</u>	<u>194.7</u>	<u>374</u>	<u>74</u>		<u>240</u>	<u>241</u>	<u>55</u>	<u>5</u>	<u>262</u>	
5	42.5		<u>.33</u>	<u>.75</u>	<u>195.9</u>	<u>368</u>	<u>74</u>		<u>240</u>	<u>242</u>	<u>55</u>	<u>5</u>	<u>260</u>	
6	45		<u>.29</u>	<u>.66</u>	<u>197.135</u>	<u>364</u>	<u>74</u>		<u>240</u>	<u>242</u>	<u>55</u>	<u>5</u>	<u>261</u>	
D1	47.5		<u>.65</u>	<u>1.48</u>	<u>198.8</u>	<u>373</u>	<u>71</u>		<u>240</u>	<u>242</u>	<u>55</u>	<u>5</u>	<u>262</u>	
2	50		<u>.54</u>	<u>1.23</u>	<u>200.3</u>	<u>378</u>	<u>75</u>		<u>240</u>	<u>241</u>	<u>54</u>	<u>6</u>	<u>262</u>	
3	52.5		<u>.35</u>	<u>.79</u>	<u>201.5</u>	<u>378</u>	<u>75</u>		<u>240</u>	<u>241</u>	<u>50</u>	<u>6</u>	<u>260</u>	
4	55		<u>.39</u>	<u>.89</u>	<u>202.9</u>	<u>376</u>	<u>75</u>		<u>240</u>	<u>242</u>	<u>50</u>	<u>5</u>	<u>259</u>	
5	57.5		<u>.34</u>	<u>.77</u>	<u>204.1</u>	<u>372</u>	<u>75</u>		<u>240</u>	<u>242</u>	<u>57</u>	<u>5</u>	<u>259</u>	
6	60	<u>1030</u>	<u>.30</u>	<u>.68</u>	<u>205.324</u>	<u>363</u>	<u>75</u>		<u>240</u>	<u>242</u>	<u>57</u>	<u>5</u>	<u>259</u>	

Avg Sqrt Delta P <u>.6874</u> <u>.4808</u>	Avg Delta H <u>1.0921</u>	Total Volume <u>34.744</u>	Avg Ts <u>373.7</u>	Avg Tm <u>73.2</u>	Min/Max <u>240/242</u> <u>240/242</u>	Min/Max <u>240/242</u> <u>240/242</u>	Max Temp <u>60</u>	Max Vac <u>6</u>	Max Temp <u>264</u>
Avg Sqrt Del H <u>1.0360</u>									

Comments:



D-3

ISA-100.4  
 m. 51 - 22.6

38

# ISOKINETIC FIELD DATA SHEET

# EPA Method 5

DA0636

Client: Rayonier  
 W.O.#: 05565.008.010  
 Project ID: Ray  
 Mode/Source ID: BFB  
 Samp. Loc. ID: 2  
 Run No. ID: M5  
 Test Method ID: 4-16-04  
 Date ID: BFB  
 Source/Location: 4-16-04  
 Sample Date: 34.26  
 Baro. Press (in Hg): 30  
 Operator: 131

Stack Conditions	
Assumed	Actual
	188
	8.3
	13.2
	6.9
	-71
	69

Meter Box ID: A013  
 Meter-Box Y: 1.011  
 Meter Box Del H: 1.670  
 Probe ID / Length: P125L 5'  
 Probe Material: SS  
 Pitot / Thermocouple ID: P125  
 Pitot Coefficient: 0.84  
 Nozzle ID: 27  
 Avg Nozzle Dia (in): 270  
 Area of Stack (ft²): 78.54  
 Sample Time: 60  
 Total Traverse Pts: 24

Leak Checks  
 Sample Train (ft³): 015  
 Leak Check @ (in Hg): 15  
 Pitot good: yes / no  
 Orsat good: yes / no  
 Temp Check  
 Meter Box Temp: 78.54  
 Reference Temp: 60  
 Pass/Fail (+/- 2°):  
 Temp Change Response: 24

K Factor 2.30		
Initial	Mid-Point	Final
015		010
15		7
yes / no	yes / no	yes / no
yes / no	yes / no	yes / no
Pre-Test Set		Post-Test Set
Pass / Fail		Pass / Fail
yes / no		yes / no

TRAVERSE POINT NO	SAMPLE TIME (min)	CLOCK TIME (min:sec)	VELOCITY PRESSURE Delta P (in H2O)	ORIFICE PRESSURE Delta P (in H2O)	DRY GAS METER READING (ft³)	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	IMPING EXIT TEMP (°F)	SAMPLE TRAIN VAC (in Hg)	COMMENTS
	0	1100			206.600							
A1	2.5		.64	1.47	208.3	374	69	N/A	240	240	68	Y 241
2	5		.57	1.31	210.1	374	72		240	240	62	Y 240
3	7.5		.61	1.01	211.4	373	73		240	240	61	Y 241
4	10		.35	.81	212.7	371	73		240	241	61	Y 242
5	12.5		.33	.76	213.9	367	72		240	240	61	Y 240
6	15		.31	.71	215.138	356	72		240	241	61	Y 242
B1	17.5		.60	1.38	216.7	371	69		240	240	61	Y 240
2	20		.50	1.15	218.2	371	72		240	240	62	Y 241
3	22.5		.47	1.01	219.7	370	73		240	241	59	Y 252
4	25		.35	.81	221.0	366	73		240	240	58	Y 255
5	27.5		.35	.81	222.2	366	73		240	241	58	Y 252
6	30		.32	.69	223.441	357	73		240	240	58	Y 251
C1	32.5		.65	1.50	225.1	372	70		241	240	59	Y 240
2	35		.57	1.31	226.8	374	72		238	240	57	Y 255
3	37.5		.55	1.27	228.5	374	72		238	240	56	Y 260
4	40		.50	1.15	229.9	372	72		242	239	56	Y 261
5	42.5		.47	1.08	231.6	366	72		242	239	57	Y 260
6	45		.31	.71	232.605	350	72		240	240	57	Y 261
D1	47.5		.63	1.45	234.3	374	70		272	241	58	Y 260
2	50		.60	1.38	235.9	375	71		240	241	57	Y 257
3	52.5		.55	1.27	237.6	375	72		241	239	57	Y 261
4	55		.48	1.10	239.1	375	72		240	240	57	Y 260
5	57.5		.50	1.15	240.5	373	72		240	241	56	Y 258
6	60	1247	.45	1.04	241.619	359	72		241	241	56	Y 257

Avg Sqrt Delta P	Avg Delta H	Total Volume	Avg Ts	Avg Tm	Min/Max	Min/Max	Max Temp	Max Vac	Max Temp
68.54	1.0971	35.019	3680	71.8	220/240	237/241	68	5	261
	Avg Sqrt Del H	Comments:							
	1.0399	369.0							

250 = 94.4  
 m.v. = 20.8







### SAMPLE RECOVERY FIELD DATA

EPA Method 5

Client Rayonier W.O. # 05565.008.010  
 Location/Plant Fernandina Beach, FL Source & Location BFB

Run No. 1 Sample Date 4/16/09 Recovery Date 4/14/09  
 Sample I.D. BFB Analyst BZ/SB Filter Number DA0034

	Impinger							Imp.Total	8	Total
	1	2	3	4	5	6	7			
Contents	H2O	H2O	Empty						Silica Gel	
Final	304	102	2						327.3	
Initial	100	100	0						319.6	
Gain	204	2	2					208	7.7	215.7

Impinger Color Clear Labeled? Y  
 Silica Gel Condition Good Sealed? Y

Run No. 2 Sample Date 4-16-09 Recovery Date 4-16-09  
 Sample I.D. BFB Analyst BZ/SB Filter Number DA0036

	Impinger							Imp.Total	8	Total
	1	2	3	4	5	6	7			
Contents	H2O	H2O	Empty						Silica Gel	
Final	282	104	2						333.1	
Initial	100	100	0						324.8	
Gain	182	4	2					188	8.3	190.3

Impinger Color Clear Labeled? Y  
 Silica Gel Condition Good Sealed? Y

Run No. 3 Sample Date 4-16-09 Recovery Date 4-16-09  
 Sample I.D. BFB Analyst BZ/SB Filter Number DA0037

	Impinger							Imp.Total	8	Total
	1	2	3	4	5	6	7			
Contents	H2O	H2O	Empty						Silica Gel	
Final	298	100	2						328.6	
Initial	100	100	0						321	
Gain	198	0	2					200	7.6	207.6

Impinger Color Clear Labeled? Y  
 Silica Gel Condition Good Sealed? Y

Check COC for Sample IDs of Media Blanks



*(Handwritten signature)*

**RUN DATA**

Number 1

Client: **Rayonier**  
 Location: **Fernandina Beach, FI**  
 Source: **BFB**  
 Calibration: **1**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **16 Apr 2009**

Time	O2		CO2	
	mv	%	mv	%
Starting time 11:12				
Run 1 Compliance				
11:12:18	2433	7.1	4354	13.1
11:12:28	2434	7.1	4351	13.1
11:12:38	2439	7.1	4353	13.1
11:12:48	2440	7.2	4356	13.1
11:12:59	2438	7.1	4356	13.1
11:13:09	2441	7.2	4354	13.1
11:13:19	2437	7.1	4358	13.1
11:13:29	2436	7.1	4354	13.1
11:13:39	2439	7.1	4355	13.1
11:13:49	2439	7.1	4353	13.1
11:13:59	2441	7.2	4352	13.1
<b>Run Avg</b>	<b>2438</b>	<b>7.1</b>	<b>4354</b>	<b>13.1</b>



**RUN DATA**

Number 2

Client: **Rayonier**  
 Location: **Fernandina Beach, Fl**  
 Source: **BFB**  
 Calibration: **1**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **16 Apr 2009**

Time	O2		CO2	
	mv	%	mv	%
	Starting time 12:48			
	Run 2 Compliance			
12:48:30	2357	6.9	4403	13.2
12:48:40	2355	6.9	4396	13.2
12:48:50	2353	6.9	4397	13.2
12:49:00	2360	6.9	4396	13.2
12:49:10	2359	6.9	4398	13.2
12:49:20	2356	6.9	4399	13.2
12:49:30	2358	6.9	4400	13.2
12:49:40	2355	6.9	4401	13.2
12:49:50	2353	6.9	4395	13.2
12:50:00	2355	6.9	4399	13.2
<b>Run Avg</b>	<b>2356</b>	<b>6.9</b>	<b>4398</b>	<b>13.2</b>

**RUN DATA**

Number 3

Client: **Rayonier**  
 Location: **Fernandina Beach, FL**  
 Source: **BFB**  
 Calibration: **1**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **16 Apr 2009**

Time	O2		CO2	
	mv	%	mv	%
Starting time 14:07				
Run 3 Compliance				
14:07:28	2369	6.9	4371	13.1
14:07:37	2360	6.9	4387	13.2
14:07:47	2363	6.9	4395	13.2
14:07:57	2365	6.9	4401	13.2
14:08:07	2361	6.9	4398	13.2
14:08:17	2361	6.9	4404	13.2
14:08:27	2369	6.9	4401	13.2
14:08:37	2361	6.9	4398	13.2
14:08:47	2369	6.9	4402	13.2
14:08:58	2362	6.9	4399	13.2
14:09:08	2361	6.9	4403	13.2
14:09:18	2362	6.9	4402	13.2
<b>Run Avg</b>	<b>2364</b>	<b>6.9</b>	<b>4397</b>	<b>13.2</b>

**CALIBRATION**

Number 1

Client: **Rayonier**  
 Location: **Fernandina Beach, FL**  
 Source: **BFB**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **16 Apr 2009**

Starting Time: 08:09

**O2**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results		
%	Cylinder ID	Result, mv
Zero	-	-4
12.0	CC 159811	4091
25.9	SG0067	8869
Curve Coefficients		
Slope	Intercept	Corr. Coeff.
342.6	-9.9	>0.9999

**CO2**

Method: EPA 3A

Calibration Type: Linear Regression

Calibration Results		
%	Cylinder ID	Result, mv
Zero	-	2
12.1	CC 159811	3966
24.4	SG0067	8169
Curve Coefficients		
Slope	Intercept	Corr. Coeff.
334.8	-26.9	0.9999

# CALIBRATION ERROR

Number 1

Client: **Rayonier**  
 Location: **Fernandina Beach, Fl**  
 Source: **BFB**

Project Number: **05565.008.010**  
 Operator: **BR**  
 Date: **16 Apr 2009**

Starting Time: 08:09

**O2**

Method: EPA 3A

Slope 342.6

Intercept -9.9

Standard, %	Response, mV	%	Error, %
Zero	-4	0.0	0.0
12.0	4091	12.0	0.0
25.9	8869	25.9	0.0

**CO2**

Method: EPA 3A

Slope 334.8

Intercept -26.9

Standard, %	Response, mV	%	Error, %
Zero	2	0.1	0.4
12.1	3966	11.9	-0.8
24.4	8169	24.5	0.4

**ANALYZER INFORMATION**

Client: **Rayonier**  
Location: **Fernandina Beach, FL**  
Source: **BFB**

Project Number: **05565.008.010**  
Operator: **BR**  
Date: **15 Apr 2009**

---

**File Name:** C:\DATA\Rayonier Fernandina\BFB O2Bags 16 April 2009.com  
**Computer:** WSAUB58 **Trailer:** 201

---

Analog Input Device: **Keithley KPCMCIA 16AI Card**

---

**Channel 1**

Analyte	<b>O2</b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Servomex 4900 SN: 652836</b>
Full-Scale Output, mv	<b>10000</b>
Span Concentration, %	<b>25.9</b>

**Channel 2**

Analyte	<b>CO2</b>
Method	<b>EPA 3A, Using Bias</b>
Analyzer Make, Model & Serial No.	<b>Servomex 4900 SN: 652836</b>
Full-Scale Output, mv	<b>10000</b>
Span Concentration, %	<b>24.4</b>





**APPENDIX E**  
**QUALITY CONTROL DATA**

---

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below, other columns are automatically calculated.

DATE: **12/16/08** METER SERIAL #: **971165** BAROMETRIC PRESSURE (in Hg): INITIAL **29.52** FINAL **29.52** AVG (P<sub>bar</sub>) **29.52**  
 METER PART #: **AO13** CRITICAL ORIFICE SET SERIAL #: **1331s** Calibrated by: **LoF**

ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )			AMBIENT F°	DGM F°			DGM AVG	ELAPSED TIME (MIN) θ	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	(4) ΔH <sub>⊗</sub>
				INITIAL	FINAL	NET (V <sub>m</sub> )		INITIAL	FINAL	AVG							
12	1	0.3275	22	606.135	617.641	11.506	64	65	65	65	27	0.52	11.434	11.407	0.998	1.639	
16	2	0.4379	25	654.328	680.262	25.934	66	70	67	69	46	0.93	25.627	25.935	1.012	1.646	
19	3	0.5175	19	682.245	703.330	21.085	65	67	68	68	32	1.30	20.894	21.342	1.021	1.644	
25	4	0.6784	17	704.732	727.517	22.785	65	68	70	69	26	2.30	22.571	22.731	1.007	1.693	
31	5	0.8269	15	623.122	653.738	30.616	64	67	71	69	29	3.50	30.418	30.934	1.017	1.730	
													AVG =		<b>1.011</b>	<b>1.670</b>	

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

Individual Y's .02 from average? YES  
 Individual ΔH<sub>⊗</sub> values 0.2 from average? YES

(1)  $V_m (std) = K_1 V_m \frac{P_{bar} + (\Delta H/13.6)}{T_m}$  = Net volume of gas sample passed through DGM, corrected to standard conditions  
 $K_1 = 17.64 \text{ } ^\circ R/in. Hg \text{ (English), } 0.3858 \text{ } ^\circ K/mm Hg \text{ (Metric)}$   
 $T_m = \text{Absolute DGM avg. temperature (} ^\circ R \text{ - English, } ^\circ K \text{ - Metric)}$

(2)  $V_{cr} (std) = K' \sqrt{\frac{P_{bar} \theta}{T_{amb}}}$  = Volume of gas sample passed through the critical orifice, corrected to standard conditions  
 $T_{amb} = \text{Absolute ambient temperature (} ^\circ R \text{ - English, } ^\circ K \text{ - Metric)}$   
 $K' = \text{Average K' factor from Critical Orifice Calibration}$

(3)  $Y = \frac{V_{cr} (std)}{V_m (std)}$  = DGM calibration factor

(4)  $\Delta H_{\otimes} = \left( \frac{0.75 \theta^2}{V_{cr}(std)} \right) \Delta H$

Next Calibration Due By: **12/16/2009**

## Post-Test Meter Calibration Check

Rayonier  
Fernandina Beach

05565.008.010

BFB Boiler

**Bark w/ 60 ODTD Sludge****POST-TEST METER Y CALIBRATION CHECK**

Meter ID: AO 13

Run Number		1	2	3	Mean
Sampling Time, min	(Theta)	60	60	60	60
Meter Volume, ft <sup>3</sup>	(Vm)	34.744	35.019	34.405	34.723
Meter Temperature, R	(tm)	533	532	530	532
Barometric Pressure, in. Hg	(Pb)	30.06	30.06	30.06	30.06
Meter Orifice Pressure, in. H <sub>2</sub> O	(dH)	1.092	1.097	1.057	1.082
Meter Pressure, in. Hg	(Pm)	30.14	30.14	30.14	30.14
Ave Sq Rt Meter Orifice Pressure, in. H <sub>2</sub> O	((sqrt. dH)ave)	1.036	1.040	1.021	1.032
Meter Orifice Calibraion Coefficient, in. H <sub>2</sub> O	(dH@)	1.67	1.67	1.67	1.670
Dry Mol. Wt. of Stack Gas, lb/lb-mole	(Md)	30.38	30.39	30.39	30.39
Dry Gas Meter Cal. Check Value	(Yqa)	1.0161	1.0105	1.0078	1.0115
Meter Correction Factor	(Y)	1.0110	1.0110	1.0110	1.0110
Mean Percent Difference, %	< +/- 5%				<b>0.05</b>

## Post-Test Meter Calibration Check

Rayonier  
Fernandina Beach

05565.008.010

BFB Boiler

**Bark w/ 45 ODTD Sludge****POST-TEST METER Y CALIBRATION CHECK**

Meter ID: AO 13

Run Number		1	2	3	Mean
Sampling Time, min	(Theta)	60	60	60	60
Meter Volume, ft <sup>3</sup>	(Vm)	36.625	36.892	34.790	36.102
Meter Temperature, R	(tm)	554	557	556	556
Barometric Pressure, in. Hg	(Pb)	29.94	29.94	29.94	29.94
Meter Orifice Pressure, in. H <sub>2</sub> O	(dH)	1.159	1.176	1.053	1.129
Meter Pressure, in. Hg	(Pm)	30.03	30.03	30.02	30.02
Ave Sq Rt Meter Orifice Pressure, in. H <sub>2</sub> O	((sqrt. dH)ave)	1.067	1.072	1.017	1.052
Meter Orifice Calibraion Coefficient, in. H <sub>2</sub> O	(dH@)	1.67	1.67	1.67	1.670
Dry Mol. Wt. of Stack Gas, lb/lb-mole	(Md)	30.39	30.39	30.37	30.38
Dry Gas Meter Cal. Check Value	(Yqa)	1.0131	1.0142	1.0193	1.0155
Meter Correction Factor	(Y)	1.0110	1.0110	1.0110	1.0110
Mean Percent Difference, %	< +/- 5%				<b>0.45</b>

# S - Type Pitot Tube Inspection Data Form

Pitot Tube ID NO. P18


Length 5'

Probe ID.No. AUB-PR-5L

If all Criteria PASS Cp is equal to 0.84

Inspection Date 12/19/2008 Individual Conducting Inspection MTF


PASS/FAIL



Distance to A Plane (PA) - inches 0.471 PASS  
 Distance to B Plane (PB) - inches 0.471 PASS  
 Pitot OD (D<sub>i</sub>) - inches 0.375


$1.05 D_i < P < 1.5 D_i$

PA must Equal PB



Are Open Faces Aligned Perpendicular to the Tube Axis  YES  NO


PASS



Angle of Q1 from vertical A Tube-degrees (absolute) 1 PASS

Angle of Q2 from vertical B Tube-degrees (absolute) 1 PASS

Q1 and Q2 must be  $\leq 10^\circ$



Angle of B1 from vertical A Tube-degrees (absolute) 1 PASS

Angle of B1 from vertical B Tube-degrees (absolute) 1 PASS

B1 or B2 must be  $\leq 5^\circ$

Y = 2 O = 1




A = 0.942

Z must be  $\leq 0.125$  inches

Z = A sin Y = 0.0329 PASS


W must be  $\leq 0.03125$  inches

W = A sin O = 0.0164 PASS




Distance between Sample Nozzle and Pitot (X) - inches 0.75 PASS

X must be  $\geq 0.75$  inches




Impact Pressure Opening Plane is above the Nozzle Entry Plane  YES  NO  NA

PASS



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA



Thermocouple meets the Distance Criteria in the adjacent figure  YES  NO  NA

PASS

## POSTTEST CHECK

Client \_\_\_\_\_ Work Order Number \_\_\_\_\_

Date \_\_\_\_\_ Damage Found? \_\_\_\_\_ YES \_\_\_\_\_ NO

Checked By \_\_\_\_\_



### STACK TEMPERATURE SENSOR CALIBRATION DATA

Thermocouple Number: AUB-PR-5L      Length: 5 FT  
 Date: 13-Dec-07      Pitot: P18  
 Ambient Temperature, °F: 73  
 Calibrator: KMR

Reference Point Number	Reference Temperature °F	Thermocouple Temperature °F	Temperature Difference %
1 - A	73	73	0.00
B	41	42	0.20
C	202	203	0.15
2 - A	73	73	0.00
B	41	42	0.20
C	202	203	0.15
3 - A	73	73	0.00
B	41	42	0.20
C	202	203	0.15

$$\text{Temp Diff (\%)} = \frac{(\text{Ref Temp, } ^\circ\text{F} + 460) - (\text{Therm Temp } ^\circ\text{F} + 460)}{\text{Ref Temp, } ^\circ\text{F} + 460} \times 100$$

Are all temperature differences less than +/- 1.5% ? YES

### POSTTEST STACK TEMPERATURE SENSOR CALIBRATION DATA

Client: \_\_\_\_\_  
 Work Order Number: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Calibrator: \_\_\_\_\_

Ambient Temp, °F	Reference Temp, °F	Thermocouple Temp, °F	Temperature Diff, %
------------------	--------------------	-----------------------	---------------------

Was a pretest temperature correction used ? \_\_\_\_yes \_\_\_\_no

Is temperature difference within +/- 1.5% \_\_\_\_yes \_\_\_\_no

If no, calculations done once with recorded values and once with corrected values \_\_\_\_\_



**APPENDIX F**  
**PROCESS OPERATING DATA**

---

# BFB BOTTLER

4-15-09

		<u>F Factor</u>	<u>Ave Steam</u>
1005-1107	ENG RUN 1	9602	282
1157-1303	Comp RUN 1	9605	279
1347-1455	Comp RUN 2	9608	283
1535-1642	Comp RUN 3	9610	281

4-16-09

0922-1030	Comp RUN 1	9604	274
1100-1207	Comp RUN 2	9608	285
1239-1346	Comp RUN 3	9604	277





### Power Boiler 6 Stack Test

Date: 4/15/2009  
 Time: 10:08:38 AM  
 Test Run Number: 1  
 Start or Finish: Start

**Boiler Data**

Bark Totalizer	219.71
Knots Totalizer	0.00
TDF Totalizer	0.00
Fuel Screw Speed	63.38
Boiler Steam Integrator	955.44
Boiler Steam Outlet Pres.	913.28
Boiler #6 Oil Integrator	0.00
Boiler Steam	273.78
Boiler O2	3.75
Boiler Steam Temp.	877.98
Boiler Gen Bank Temp.	846.38

**Scrubber Data**


Scrubber pH	8.46	pH
Scrubber Inlet Temp.	391.57	DegF
Scrubber Recirc Flow	678.28	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.09	Feet
Scrubber Media (Off, Effluent, Water)	NONE	


**CEMS Data**

Stack Flow	228.65	KSCFM
Stack Flow Adj.	98.70	DKSCFM
Stack Temp	373.46	DegF
Oxygen Adj. Value	6.56	PCT
CO Adj. Value	56.81	PPM
NOx Adj. Value	123.86	PPM
SO2 Adj. Value	59.75	PPM
OPACITY VALUE	2.47	PCT

**Precipitator Data**

T/R #1 Second voltage	29.00	KVDC
T/R #1 Second amps	305.00	mA
T/R #2 Second voltage	29.00	KVDC
T/R #2 Second amps	200.00	mA
T/R #3 Second voltage	36.00	KVDC
T/R #3 Second amps	760.00	mA
T/R #4 Second voltage	43.00	KVDC
T/R #4 Second amps	595.00	mA





### Power Boiler 6 Stack Test

Date: 4/15/2009  
 Time: 11:13:46 AM  
 Test Run Number: 1  
 Start or Finish: finish

#### Boiler Data

Bark Totalizer	283.11	Tons
Knots Totalizer	0.00	Tons
TDF Totalizer	0.00	Tons
Fuel Screw Speed	65.34	Pct
Boiler Steam Integrator	1262.04	
Boiler Steam Outlet Pres.	899.67	PSI
Boiler #6 Oil Integrator	0.00	Gals
Boiler Steam	266.01	KPPH
Boiler O2	4.35	%
Boiler Steam Temp.	869.93	DegF
Boiler Gen Bank Temp.	851.66	DegF

#### Scrubber Data

Scrubber pH	8.91	pH
Scrubber Inlet Temp.	396.18	DegF
Scrubber Recirc Flow	246.50	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.15	Feet
Scrubber Media (Off, Effluent, Water)	NONE	

#### CEMS Data

Stack Flow	231.62	KSCFM
Stack Flow Adj.	98.99	DKSCFM
Stack Temp	376.69	DegF
Oxygen Adj. Value	7.12	PCT
CO Adj. Value	59.59	PPM
NOx Adj. Value	134.38	PPM
SO2 Adj. Value	53.00	PPM
OPACITY VALUE	2.35	PCT

#### Precipitator Data

T/R #1 Second voltage	30.00	KVDC
T/R #1 Second amps	260.00	mA
T/R #2 Second voltage	29.00	KVDC
T/R #2 Second amps	155.00	mA
T/R #3 Second voltage	30.00	KVDC
T/R #3 Second amps	455.00	mA
T/R #4 Second voltage	37.00	KVDC
T/R #4 Second amps	415.00	mA





### Power Boiler 6 Stack Test

Date: 4/15/2009  
 Time: 12:02:37 PM  
 Test Run Number: 2  
 Start or Finish: Start

#### Boiler Data

Bark Totalizer 333.19  
 Knots Totalizer 0.00  
 TDF Totalizer 0.00  
 Fuel Screw Speed 69.79  
 Boiler Steam Integrator 1480.12  
 Boiler Steam Outlet Pres. 909.98  
 Boiler #6 Oil Integrator 0.00  
 Boiler Steam 260.51  
 Boiler O2 4.69  
 Boiler Steam Temp. 889.71  
 Boiler Gen Bank Temp. 842.22

Tons  
 Tons  
 Tons  
 Pct  
 PSI  
 Gals  
 KPPH  
 %  
 DegF  
 DegF

#### Scrubber Data

Scrubber pH 8.98  
 Scrubber Inlet Temp. 395.05  
 Scrubber Recirc Flow 186.34  
 Scrubber Caustic Flow 0.00  
 Scrubber Level 9.22  
 Scrubber Media (Off, Effluent, Water) NONE

pH  
 DegF  
 GPM  
 Kg/Min  
 Feet

#### CEMS Data

Stack Flow 245.77 KSCFM  
 Stack Flow Adj. 105.79 DKSCFM  
 Stack Temp 375.04 DegF  
 Oxygen Adj. Value 6.48 PCT  
 CO Adj. Value 70.09 PPM  
 NOx Adj. Value 152.84 PPM  
 SO2 Adj. Value 108.50 PPM  
 OPACITY VALUE 2.72 PCT

#### Precipitator Data

T/R #1 Second voltage 29.00 KVDC  
 T/R #1 Second amps 190.00 mA  
 T/R #2 Second voltage 34.00 KVDC  
 T/R #2 Second amps 295.00 mA  
 T/R #3 Second voltage 35.00 KVDC  
 T/R #3 Second amps 700.00 mA  
 T/R #4 Second voltage 42.00 KVDC  
 T/R #4 Second amps 620.00 mA



Over View	Air Sys	Ash Sys	Sand Sys	Wtr Strm	Schr Sys	Flue Gas	Fuel Feed	Bnr Sys	MFT Cond	SFT Cond	Pidge Cond	Bnr Diag	BFB ENV	SEC	PRI	RIC13	RIC14	USER: Operator
-----------	---------	---------	----------	----------	----------	----------	-----------	---------	----------	----------	------------	----------	---------	-----	-----	-------	-------	----------------

### Power Boiler 6 Stack Test

Date: 4/15/2009  
 Time: 1:06:45 PM  
 Test Run Number: 2  
 Start or Finish: finish

#### Boiler Data

Bark Totalizer	391.57
Knots Totalizer	0.00
TDF Totalizer	0.00
Fuel Screw Speed	72.25
Boiler Steam Integrator	1777.72
Boiler Steam Outlet Pres.	900.11
Boiler #6 Oil Integrator	0.00
Boiler Steam	287.72
Boiler O2	4.00
Boiler Steam Temp.	878.65
Boiler Gen Bank Temp.	849.85

#### Scrubber Data

Scrubber pH	9.01	pH
Scrubber Inlet Temp.	393.21	DegF
Scrubber Recirc Flow	917.61	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.29	Feet
Scrubber Media (Off, Effluent, Water)	NONE	

#### CEMS Data

Stack Flow	253.88	KSCFM
Stack Flow Adj.	109.19	DKSCFM
Stack Temp	374.59	DegF
Oxygen Adj. Value	6.82	PCT
CO Adj. Value	46.93	PPM
NOx Adj. Value	128.74	PPM
SO2 Adj. Value	105.00	PPM
OPACITY VALUE	2.72	PCT

#### Precipitator Data

T/R #1 Second voltage	30.00	KVDC
T/R #1 Second amps	215.00	mA
T/R #2 Second voltage	29.00	KVDC
T/R #2 Second amps	135.00	mA
T/R #3 Second voltage	32.00	KVDC
T/R #3 Second amps	410.00	mA
T/R #4 Second voltage	39.00	KVDC
T/R #4 Second amps	465.00	mA





### Power Boiler 6 Stack Test

Date: 4/15/2009  
 Time: 1:48:18 PM  
 Test Run Number: 3  
 Start or Finish: start

Bark Totalizer	433.16	Tons
Knots Totalizer	0.00	Tons
TDF Totalizer	0.00	Tons
Fuel Screw Speed	81.25	Pct
Boiler Steam Integrator	1961.36	PSI
Boiler Steam Outlet Pres.	884.54	Gals
Boiler #6 Oil Integrator	0.00	KPPH
Boiler Steam	259.71	%
Boiler O2	4.25	DegF
Boiler Steam Temp.	865.91	DegF
Boiler Gen Bank Temp.	818.01	DegF

Scrubber pH	8.89	pH
Scrubber Inlet Temp.	392.00	DegF
Scrubber Recirc Flow	0.00	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.11	Feet
Scrubber Media (Off, Effluent, Water)	NONE	

Stack Flow	228.14	KSCFM
Stack Flow Adj.	97.99	DKSCFM
Stack Temp	372.71	DegF
Oxygen Adj. Value	7.56	PCT
CO Adj. Value	84.09	PPM
NOx Adj. Value	121.61	PPM
SO2 Adj. Value	85.00	PPM
OPACITY VALUE	2.54	PCT

T/R #1 Second voltage	33.00	KVDC
T/R #1 Second amps	305.00	mA
T/R #2 Second voltage	34.00	KVDC
T/R #2 Second amps	250.00	mA
T/R #3 Second voltage	38.00	KVDC
T/R #3 Second amps	855.00	mA
T/R #4 Second voltage	45.00	KVDC
T/R #4 Second amps	710.00	mA



Over View	Air Sys	Ash Sys	Sand Sys	Wtr Stm	Scbr Sys	Flue Gas	Fuel Feed	Bnr Sys	MFT Cond	GFT Cond	Prge Cond	Bnr Diag	BFB ENV	E	PRI	RIC13	SEC	RIC14	User: Operator
-----------	---------	---------	----------	---------	----------	----------	-----------	---------	----------	----------	-----------	----------	---------	---	-----	-------	-----	-------	----------------

### Power Boiler 6 Stack Test

Date: 4/15/2009  
 Time: 3:14:26 PM  
 Test Run Number: 3  
 Start or Finish: finish

**Boiler Data**

Bark Totalizer	527.38	Tons
Knots Totalizer	0.00	Tons
TDF Totalizer	0.00	Tons
Fuel Screw Speed	66.06	Pct
Boiler Steam Integrator	2366.35	PSI
Boiler Steam Outlet Pres.	906.27	Gals
Boiler #6 Oil Integrator	0.00	KPPH
Boiler Steam	293.60	%
Boiler O2	4.45	DegF
Boiler Steam Temp.	876.64	DegF
Boiler Gen Bank Temp.	856.38	DegF

**Scrubber Data**


Scrubber pH	9.20	pH
Scrubber Inlet Temp.	393.14	DegF
Scrubber Recirc Flow	228.22	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.32	Feet
Scrubber Media	NONE	(Off, Effluent, Water)

**CEMS Data**

Stack Flow	251.05	KSCFM
Stack Flow Adj.	108.00	DKSCFM
Stack Temp	375.95	DegF
Oxygen Adj. Value	6.09	PCT
CO Adj. Value	96.78	PPM
NOx Adj. Value	128.00	PPM
SO2 Adj. Value	82.50	PPM
OPACITY VALUE	3.15	PCT

**Precipitator Data**

T/R #1 Second voltage	31.00	KVDC
T/R #1 Second amps	255.00	mA
T/R #2 Second voltage	33.00	KVDC
T/R #2 Second amps	165.00	mA
T/R #3 Second voltage	34.00	KVDC
T/R #3 Second amps	535.00	mA
T/R #4 Second voltage	40.00	KVDC
T/R #4 Second amps	520.00	mA



Over View	Air Sys	Ash Sys	Sand Sys	Wtr Stm	Scbr Sys	Flue Gas	Fuel Feed	Bnr Sys	MFT Cond	SFT Cond	Prge Cond	Bnr Diag	BFB ENV	SEC	RIC13	RIC14	Use Operator
-----------	---------	---------	----------	---------	----------	----------	-----------	---------	----------	----------	-----------	----------	---------	-----	-------	-------	--------------

### Power Boiler 6 Stack Test

Date: 4/15/2009  
 Time: 3:39:43 PM  
 Test Run Number: 4  
 Start or Finish: start ..

#### Boiler Data

Bark Totalizer	561.77	Tons
Knots Totalizer	0.00	Tons
TDF Totalizer	0.00	Tons
Fuel Screw Speed	51.63	Pct
Boiler Steam Integrator	2476.40	
Boiler Steam Outlet Pres.	898.79	PSI
Boiler #6 Oil Integrator	0.00	Gals
Boiler Steam	243.96	KPPH
Boiler O2	4.03	%
Boiler Steam Temp.	870.93	DegF
Boiler Gen Bank Temp.	824.63	DegF

#### Scrubber Data

Scrubber pH	9.03	pH
Scrubber Inlet Temp.	388.97	DegF
Scrubber Recirc Flow	0.00	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.05	Feet
Scrubber Media (Off, Effluent, Water)	NONE	


#### CEMS Data

Stack Flow	174.07	KSCFM
Stack Flow Adj.	74.38	DKSCFM
Stack Temp	371.94	DegF
Oxygen Adj. Value	7.74	PCT
CO Adj. Value	59.56	PPM
NOx Adj. Value	115.98	PPM
SO2 Adj. Value	72.50	PPM
OPACITY VALUE	2.22	PCT

#### Precipitator Data

T/R #1 Second voltage	29.00	KVDC
T/R #1 Second amps	170.00	mA
T/R #2 Second voltage	32.00	KVDC
T/R #2 Second amps	155.00	mA
T/R #3 Second voltage	35.00	KVDC
T/R #3 Second amps	625.00	mA
T/R #4 Second voltage	40.00	KVDC
T/R #4 Second amps	500.00	mA





## Power Boiler 6 Stack Test

Date: 4/15/2009  
 Time: 4:45:17 PM  
 Test Run Number: 4  
 Start or Finish: finish

### Boiler Data

Bark Totalizer	611.45	Tons
Knots Totalizer	0.00	Tons
TDF Totalizer	0.00	Tons
Fuel Screw Speed	67.00	Pct
Boiler Steam Integrator	2785.55	
Boiler Steam Outlet Pres.	897.26	PSI
Boiler #6 Oil Integrator	0.00	Gals
Boiler Steam	289.04	KPPH
Boiler O2	4.47	%
Boiler Steam Temp.	879.32	DegF
Boiler Gen Bank Temp.	865.10	DegF

### Scrubber Data


Scrubber pH	9.17	pH
Scrubber Inlet Temp.	395.16	DegF
Scrubber Recirc Flow	0.00	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.31	Feet
Scrubber Media (Of, Effluent, Water)	<u>NONE</u>	

### CEMS Data

Stack Flow	227.83	KSCFM
Stack Flow Adj.	161.86	DKSCFM
Stack Temp	138.80	DegF
Oxygen Adj. Value	6.01	PCT
CO Adj. Value	45.24	PPM
NOx Adj. Value	129.34	PPM
SO2 Adj. Value	73.50	PPM
OPACITY VALUE	2.73	PCT

### Precipitator Data

T/R #1 Second voltage	23.00	KVDC
T/R #1 Second amps	55.00	mA
T/R #2 Second voltage	29.00	KVDC
T/R #2 Second amps	50.00	mA
T/R #3 Second voltage	33.00	KVDC
T/R #3 Second amps	315.00	mA
T/R #4 Second voltage	40.00	KVDC
T/R #4 Second amps	430.00	mA







## Power Boiler 6 Stack Test

Date: 4/16/2009  
 Time: 9:26:15 AM  
 Test Run Number: 1  
 Start or Finish: start

### Boiler Data

Bark Totalizer	209.53
Knots Totalizer	4.15
TDF Totalizer	0.00
Fuel Screw Speed	67.64
Boiler Steam Integrator	758.98
Boiler Steam Outlet Pres.	924.64
Boiler #6 Oil Integrator	0.00
Boiler Steam	232.79
Boiler O2	4.62
Boiler Steam Temp.	871.93
Boiler Gen Bank Temp.	830.68

Tons	Scrubber pH	9.16	pH
Tons	Scrubber Inlet Temp.	394.24	DegF
Tons	Scrubber Recirc Flow	0.00	GPM
Pct	Scrubber Caustic Flow	0.00	Kg/Min
PSI	Scrubber Level	9.32	Feet
Gals	Scrubber Media	NONE	
KPPH	(Off, Effluent, Water)		
%			
DegF			
DegF			

### Scrubber Data

### CEMS Data

Stack Flow	211.23	KSCFM
Stack Flow Adj.	90.22	DKSCFM
Stack Temp	375.96	DegF
Oxygen Adj. Value	5.92	PCT
CO Adj. Value	62.25	PPM
NOx Adj. Value	136.96	PPM
SO2 Adj. Value	53.00	PPM
OPACITY VALUE	2.42	PCT

### Precipitator Data

T/R #1 Second voltage	33.00	KVDC
T/R #1 Second amps	460.00	mA
T/R #2 Second voltage	33.00	KVDC
T/R #2 Second amps	300.00	mA
T/R #3 Second voltage	36.00	KVDC
T/R #3 Second amps	700.00	mA
T/R #4 Second voltage	46.00	KVDC
T/R #4 Second amps	650.00	mA



Over View	Air Sys	Ash Sys	Sand Sys	Wtr Stm	Scrb Sys	Flue Gas	Fuel Feed	Bnr Sys	MFT Cond	SFI Cond	Prga Cond	Bnr Diag	SFB ENV	TE	PRI	RIC13	RIC14	Unit Generator
-----------	---------	---------	----------	---------	----------	----------	-----------	---------	----------	----------	-----------	----------	---------	----	-----	-------	-------	----------------

### Power Boiler 6 Stack Test

Date: 4/16/2009  
 Time: 10:33:42 AM  
 Test Run Number: 1  
 Start or Finish: finish

**Boiler Data**

Bark Totalizer	273.99
Knots Totalizer	4.15
TDF Totalizer	0.00
Fuel Screw Speed	75.61
Boiler Steam Integrator	1067.72
Boiler Steam Outlet Pres.	892.38
Boiler #6 Oil Integrator	0.00
Boiler Steam	264.49
Boiler O2	3.89
Boiler Steam Temp.	866.25
Boiler Gen Bank Temp.	834.28

**Scrubber Data**


Scrubber pH	9.47	pH
Scrubber Inlet Temp.	395.34	DegF
Scrubber Recirc Flow	551.20	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.13	Feet
Scrubber Media	NONE	(Off, Effluent, Water)

**CEMS Data**

Stack Flow	220.44	KSCFM
Stack Flow Adj.	94.14	DKSCFM
Stack Temp	376.29	DegF
Oxygen Adj. Value	5.50	PCT
CO Adj. Value	128.55	PPM
NOx Adj. Value	121.84	PPM
SO2 Adj. Value	63.50	PPM
OPACITY VALUE	2.60	PCT

**Precipitator Data**

T/R #1 Second voltage	31.00	KVDC
T/R #1 Second amps	295.00	mA
T/R #2 Second voltage	35.00	KVDC
T/R #2 Second amps	330.00	mA
T/R #3 Second voltage	40.00	KVDC
T/R #3 Second amps	970.00	mA
T/R #4 Second voltage	44.00	KVDC
T/R #4 Second amps	625.00	mA





## Power Boiler 6 Stack Test

Date: 4/16/2009  
 Time: 11:01:32 AM  
 Test Run Number: 2  
 Start or Finish: start

### Boiler Data

Bark Totalizer	310.18	Tons
Knots Totalizer	4.15	Tons
TDF Totalizer	0.00	Tons
Fuel Screw Speed	70.70	Pct
Boiler Steam Integrator	1202.69	
Boiler Steam Outlet Pres.	902.67	PSI
Boiler #6 Oil Integrator	0.00	Gals
Boiler Steam	290.43	KPPH
Boiler O2	3.63	%
Boiler Steam Temp.	877.31	DegF
Boiler Gen Bank Temp.	859.70	DegF

### Scrubber Data

Scrubber pH	9.34	pH
Scrubber Inlet Temp.	397.64	DegF
Scrubber Recirc Flow	208.33	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.22	Feet
Scrubber Media (Off, Effluent, Water)	NONE	

### CEMS Data

Stack Flow	254.57	KSCFM
Stack Flow Adj.	109.14	DKSCFM
Stack Temp	374.28	DegF
Oxygen Adj. Value	6.53	PCT
CO Adj. Value	202.37	PPM
NOx Adj. Value	124.75	PPM
SO2 Adj. Value	63.00	PPM
OPACITY VALUE	2.72	PCT

### Precipitator Data

T/R #1 Second voltage	30.00	KVDC
T/R #1 Second amps	180.00	mA
T/R #2 Second voltage	31.00	KVDC
T/R #2 Second amps	85.00	mA
T/R #3 Second voltage	32.00	KVDC
T/R #3 Second amps	295.00	mA
T/R #4 Second voltage	41.00	KVDC
T/R #4 Second amps	465.00	mA



Over View	Air Sys	Ash Sys	Sand Sys	Wtr Stm	Scbr Sys	Flue Gas	Fuel Feed	Bnr Sys	MFT Cond	SFT Cond	Prge Cond	Bnr Diag	BFD ENV	TE	PRI	RIC13	RIC14
-----------	---------	---------	----------	---------	----------	----------	-----------	---------	----------	----------	-----------	----------	---------	----	-----	-------	-------

### Power Boiler 6 Stack Test

Date: 4/16/2009  
 Time: 12:15:01 PM  
 Test Run Number: 2  
 Start or Finish: finish...

**Boiler Data**

Bark Totalizer	378.65	Tons
Knots Totalizer	4.15	Tons
TDF Totalizer	0.00	Tons
Fuel Screw Speed	67.28	Pct
Boiler Steam Integrator	1551.39	
Boiler Steam Outlet Pres.	897.52	PSI
Boiler #6 Oil Integrator	0.00	Gals
Boiler Steam	272.11	KPPH
Boiler O2	3.27	%
Boiler Steam Temp.	868.92	DegF
Boiler Gen Bank Temp.	845.47	DegF

**Scrubber Data**

Scrubber pH	9.25	pH
Scrubber Inlet Temp.	391.72	DegF
Scrubber Recirc Flow	263.52	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.27	Feet
Scrubber Media	NONE	(Off, Effluent, Water)


**CEMS Data**

Stack Flow	214.65	KSCFM
Stack Flow Adj.	91.90	DKSCFM
Stack Temp	370.25	DegF
Oxygen Adj. Value	7.54	PCT
CO Adj. Value	103.07	PPM
NOx Adj. Value	110.38	PPM
SO2 Adj. Value	47.00	PPM
OPACITY VALUE	2.79	PCT

**Precipitator Data**

T/R #1 Second voltage	30.00	KVDC
T/R #1 Second amps	220.00	mA
T/R #2 Second voltage	26.00	KVDC
T/R #2 Second amps	70.00	mA
T/R #3 Second voltage	34.00	KVDC
T/R #3 Second amps	555.00	mA
T/R #4 Second voltage	41.00	KVDC
T/R #4 Second amps	520.00	mA





## Power Boiler 6 Stack Test

Date: 4/16/2009  
 Time: 12:57:52 PM  
 Test Run Number: 3  
 Start or Finish: start

### Boiler Data

Bark Totalizer	425.11	Tons
Knots Totalizer	4.15	Tons
TDF Totalizer	0.00	Tons
Fuel Screw Speed	68.56	Pct
Boiler Steam Integrator	1751.27	
Boiler Steam Outlet Pres.	900.31	PSI
Boiler #6 Oil Integrator	0.00	Gals
Boiler Steam	273.68	KPPH
Boiler O2	3.48	%
Boiler Steam Temp.	863.90	DegF
Boiler Gen Bank Temp.	826.30	DegF

### Scrubber Data

Scrubber pH	7.84	pH
Scrubber Inlet Temp.	390.61	DegF
Scrubber Recirc Flow	0.00	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.08	Feet
Scrubber Media (Off, Effluent, Water)	NONE	

### CEMS Data

Stack Flow	217.61	KSCFM
Stack Flow Adj.	94.35	DKSCFM
Stack Temp	371.08	DegF
Oxygen Adj. Value	7.11	PCT
CO Adj. Value	67.00	PPM
NOx Adj. Value	119.38	PPM
SO2 Adj. Value	58.25	PPM
OPACITY VALUE	2.92	PCT

### Precipitator Data

T/R #1 Second voltage	29.00	KVDC
T/R #1 Second amps	165.00	mA
T/R #2 Second voltage	30.00	KVDC
T/R #2 Second amps	85.00	mA
T/R #3 Second voltage	32.00	KVDC
T/R #3 Second amps	355.00	mA
T/R #4 Second voltage	47.00	KVDC
T/R #4 Second amps	750.00	mA



Over View	Air Sys	Ash Sys	Sand Sys	Wtr Stm	Scbr Sys	Flue Gas	Fuel Feed	Bnr Sys	BFI Cond	SFT Cond	Prog Cond	Bnr Drag	NEB Env	TE	PRI SEC	RIC13	RIC14
-----------	---------	---------	----------	---------	----------	----------	-----------	---------	----------	----------	-----------	----------	---------	----	---------	-------	-------

### Power Boiler 6 Stack Test

Date: 4/16/2009  
 Time: 1:50:17 PM  
 Test Run Number: 3  
 Start or Finish: finish

#### Boiler Data

Bark Totalizer	465.15	Tons
Knots Totalizer	4.15	Tons
TDF Totalizer	0.00	Tons
Fuel Screw Speed	70.92	Pct
Boiler Steam Integrator	1992.34	PSI
Boiler Steam Outlet Pres.	901.93	Gals
Boiler #6 Oil Integrator	0.00	KPPH
Boiler Steam	286.32	%
Boiler O2	4.08	DegF
Boiler Steam Temp.	886.36	DegF
Boiler Gen Bank Temp.	840.44	DegF

#### Scrubber Data

Scrubber pH	9.23	pH
Scrubber Inlet Temp.	392.15	DegF
Scrubber Recirc Flow	0.00	GPM
Scrubber Caustic Flow	0.00	Kg/Min
Scrubber Level	9.32	Feet
Scrubber Media (Off, Effluent, Water)	NONE	

#### CEMS Data


Stack Flow	241.19	KSCFM
Stack Flow Adj.	104.02	DKSCFM
Stack Temp	370.64	DegF
Oxygen Adj. Value	7.04	PCT
CO Adj. Value	64.20	PPM
NOx Adj. Value	118.92	PPM
SO2 Adj. Value	75.00	PPM
OPACITY VALUE	3.46	PCT

#### Precipitator Data

T/R #1 Second voltage	30.00	KVDC
T/R #1 Second amps	195.00	mA
T/R #2 Second voltage	35.00	KVDC
T/R #2 Second amps	190.00	mA
T/R #3 Second voltage	28.00	KVDC
T/R #3 Second amps	195.00	mA
T/R #4 Second voltage	44.00	KVDC
T/R #4 Second amps	615.00	mA





# 4/15 -Comp Run 1





# 4/15 -Comp Run 2

Tag	Description	Min	Max	Current	Tag	Description	Min	Max	Current
BFB_23FI5206	SSH OUTLET STEAM FLOW	200	400	238	BFB_OPAC_VAL	OPACITY VALUE	0	6	2.5




Tag	Description	Min	Max	Current
BFB_FUEL_F	BFB FUEL FACTOR AS INTEGER	9550	9650	9609

Tag	Description	Min	Max	Current
PB6_ESP_Tot	T/R Total Watts Inst [W]	0	#####	79335






# 4/15 -Comp Run 3





# 4/16 -Comp Run 1





# 4/16 -Comp Run 2


Tag	Description	Min	Max	Current	Tag	Description	Min	Max	Current
BFB_23F15206	SSH OUTLET STEAM FLOW	200	400	261	BFB_OPAC_VAL	OPACITY VALUE	0	6	2.7



Tag	Description	Min	Max	Current	Tag	Description	Min	Max	Current
BFB_FUEL_F	BFB FUEL FACTOR AS INTEGER	9550	9650	9584	PB6_ESP_Tot	T/R Total Watts Inst [W]	0	#####	92580



# 4/16 -Comp Run 3



END  
OF  
DOCUMENT