

RECEIVED

APR 14 2003

April 8, 2003

BUREAU OF AIR REGULATION

Mr. Al Linero
Professional Engineer Administrator
New Source Review
Florida Department of Environmental Protection
2600 Blair Stone Road, MS5500
Tallahassee, Florida 32399-2400

Subject: Combined Cycle Gas Turbine with Duct Burner
FDEP Permit No. 0950111-021-AV, E.U. No. 088/CEP-1
New Source Review Meeting Re: Forney Controls Replacement

Dear Mr. Linero:

We appreciate you and your staff meeting with Ed Godwin, Rich Bumar and me Tuesday morning, March 18, 2003. We discussed our future plans to replace the obsolete Forney high-level digital control system with a like kind partial control system to keep the plant operating in its current condition. All present agreed this routine replacement could proceed as the system neither controls nor affects emissions, and therefore does not trigger New Source Review or any other permitting requirements.

It is the intention of the Reedy Creek Improvement District to proceed with this routine replacement of the Forney high-level digital control system in the next twelve to twenty-four months.

If you have any questions or comments, please call me at (407) 824-4184. My telefax number is (407) 824-4529.

Sincerely,



Bob Kindle
Administrator, Regulatory Compliance

BK:BK

cc: Ray Maxwell, RCID District Administrator
Len Kozlov, FDEP Central District

* Clarified by telecom on April 24th
that we had not determined project
is routine but would still agree
with conclusion.
we discussed definition of
modification and agree project
does not fit the definition.

AAZ 4/24/03

Don Godwin Al Linero
Bob Kindle Trina Vielhauer