Orlando Utilities Commission 500 South Orange Avenue P.O. Box 3193 Orlando, Florida 32802

Phone: 407.423.9100

Administrative Fax: 407.236.9616 Purchasing Fax: 407.384.4141

Website: www.ouc.com

Certified Mail No. Z-293-323-807 Return Receipt Requested



# RECEIVED

AUG 17 1999

August 12, 1999

BUREAU OF AIR REGULATION

Mr. Scott M. Sheplak, P. E., Administrator Title V Section Division of Air Resources Management MS 5500 Florida Department of Environmental Protection 2600 Blair Stone Road Tallahassee, FL 32399-2400

Re: Phase II NOx Compliance Plan (Revised)

Dear Mr. Sheplak:

Enclosed is the revised "NOx Compliance Plan" for the Stanton Energy Center as required under 40CFR76.9.

If you have any questions, please call me at 407/423-9133.

Very truly yours,

Robert F. Hicks

Sr. Environmental Engineer

RFH:rc Enclosures

xc:

F. F. Haddad

D. M. Scarlett

Acid Rain Program, Attn: Phase II NOx - EPA, Washington, D. C. -

(Certified Mail No. Z-293-323-808)

D. McNeal - EPA, Atlanta, GA - (Certified Mail No. Z-293-323-809)

I:\wpfiles\depcorr\phase2nxr.sec

# Florida Department of Environmental Protection

# Phase II $NO_X$ Compliance Plan For more information, see instructions and refer to 40 CFR 76.9

This submission is: New 🔀 Re	evised				Page	1 of 3
STEP 1 Indicate plant name, state, and ORIS code from NADB, if applicable.  STA	NTON ENE	ERGY CENT	ER	FL State		564
type: "CB" for c	ell burner, "CY"	for cyclone, "D	er using the boile BW" for dry botto ate the compliance	om wall-fired, "T"	for tangentially	ndicate boiler fired, "V" for
		•				
	ID# 1	ID#	ID#	ID#	ID#	ID#
	Type DWB	Туре	Туре	Туре	Туре	Туре
(a) Standard annual average emission limitation of 0.50 lb/mmBtu (for Phase I dry bottom wall-fired boilers)						
(b) Standard annual average emission limitation of 0.45 lb/mmBtu (for Phase I tangentially fired boilers)						. 🗆
(c) EPA-approved early election plan under 40 CFR 76.8 through 12/31/07 (also indicate above emission limit specified in plan)						
(d) Standard annual average emission limitation of 0.46 lb/mmBtu (for Phase II dry bottom wall-fired boilers)	X					
(e) Standard annual average emission limitation of 0.40 lb/mmBtu (for Phase II tangentially fired boilers)						
(f) Standard annual average emission limitation of 0.68 lb/mmBtu (for cell burner boilers)						
(g) Standard annual average emission limitation of 0.86 lb/mmBtu (for cyclone boilers)						
(h) Standard annual average emission limitation of 0.80 lb/mmBtu (for vertically fired boilers)						
(i) Standard annual average emission limitation of 0.84 lb/mmBtu (for wet bottom boilers)						
(j) $NO_x$ Averaging Plan (include $NO_x$ Averaging form)						
(k) Common stack pursuant to 40 CFR 75.17(a)(2)(i)(A) (check the standard emission limitation box above for most stringent limitation applicable to any unit utilizing stack)						

DEP	Form	No.	62-210.900(1)(a)4.	-	Form
Effec	tive		. ,, ,		

Plant Name (from Step 1) STANTON ENERGY CENTER	Page 2 of 3
--	-------------

STE	P 2,	cor	ıť	ď.
-----	------	-----	----	----

STEP 2, cont'd.						
	ID#1	ID#	ID#	ID#	ID#	ID#
	Type DWB	Туре	Туре	Туре	Туре	Туре
(I) Common stack pursuant to 40 CFR 75.17(a)(2)(i)(B) with NO <sub>x</sub> Averaging (check the NO <sub>x</sub> Averaging Plan box and include NO <sub>x</sub> Averaging Form)						
(m) EPA-approved common stack apportionment method pursuant to 40 CFR 75.17 (a)(2)(i)(C), (a)(2)(iii)(B), or (b)(2)						
(n) AEL (include Phase II AEL Demonstration Period, Final AEL Petition, or AEL Renewal form as appropriate)						
(o) Petition for AEL demonstration period or final AEL under review by U.S. EPA or demonstration period ongoing						. $\square$
(p) Repowering extension plan approved or under review						

#### STEP 3

Read the standard requirements and certification, enter the name of the designated representative, sign and date.

## Standard Requirements

General. This source is subject to the standard requirements in 40 CFR 72.9 (consistent with 40 CFR 76.8(e)(1)(i)). These requirements are listed in this source's Acid Rain Part of its Title V permit.

#### Special Provisions for Early Election Units

Nitrogen Oxides. A unit that is governed by an approved early election plan shall be subject to an emissions limitation for NO<sub>x</sub> as provided under 40 CFR 76.8(a)(2) except as provided under 40 CFR 76.8(e)(3)(iii).

Liability. The owners and operators of a unit governed by an approved early election plan shall be liable for any violation of the plan or 40 CFR 76.8 at that unit. The owners and operators shall be liable, beginning January 1, 2000, for fulfilling the obligations specified in 40 CFR Part 77.

Termination. An approved early election plan shall be in effect only until the earlier of January 1, 2008 or January 1 of the calendar year for which a termination of the plan takes effect. If the designated representative of the unit under an approved early election plan fails to demonstrate compliance with the applicable emissions limitation under 40 CFR 76.5 for any year during the period beginning January 1 of the first year the early election takes effect and ending December 31, 2007, the permitting authority will terminate the plan. The termination will take effect beginning January 1 of the year after the year for which there is a failure to demonstrate compliance, and the designated representative may not submit a new early election plan. The designated representative of the unit under an approved early election plan may terminate the plan any year prior to 2008 but may not submit a new early election plan. In order to terminate the plan, the designated representative must submit a notice under 40 CFR 72.40(d) by January 1 of the year for which the termination is to take effect. If an early election plan is terminated any year prior to 2000, the unit shall meet, beginning January 1, 2000, the applicable emissions limitation for NO<sub>x</sub> for Phase II units with Group 1 boilers under 40 CFR 76.7. If an early election plan is terminated on or after 2000, the unit shall meet, beginning on the effective date of the termination, the applicable emissions limitation for NO<sub>x</sub> for Phase II units with Group 1 boilers under 40 CFR 76.7.

DEP	Form	No.	62-210	900(1)	)(a)4.	- Form
Effec	tive			•		

STEP 3, cont'd.

## Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	Robert F. Hicks, Alternate	Designated	Representative
Signature	The Huly	Date	8/12/99