



Jeb Bush  
Governor

# Department of Environmental Protection

Central District  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767

David B. Struhs  
Secretary  
**RECEIVED**

AUG 21 2001

BUREAU OF AIR REGULATION

August 20, 2001

OCD-AP-01-140

A. K. Sharma, P.E.  
Director of Power Supply  
Kissimmee Utility Authority  
Post Office Box 423219  
Kissimmee, Florida 34742-3219

Osceola County - AP  
Roy B. Hansel Power Plant  
Combined Cycle Combustion Turbine  
Permit No. 0970001-004-AV

Dear Mr. Sharma:

In response to Mr. Mattern's August 17, 2001 e-mail request to conduct a test and, pursuant to Rule 62-210.210(1), F.A.C., the Department authorizes excess emissions not to exceed 8 hours within the 24-hour period of August 22, 2001. It is understood the test of the Siemens Westinghouse combustion turbine will be done without water injection, and the purpose of the test is to make adjustments and set operating curves.

If you have any questions, please call John Turner at 407-893-3306 or write to the above address.

Sincerely,

L.T. Kozlov, P.E.  
Program Administrator  
Air Resources Management

LTK/jt  
cc: Scott Sheplak, P. E.

"More Protection, Less Process"

Printed on recycled paper.