

Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

July 19, 2001

Certified Mail – Return Receipt Requested

Mr. Martin J. Drango
Plant Manager
Florida Power Corporation
P.O. Box 14042, IC44
St. Petersburg, Florida 33733-4042

Re: Title V Air Operation Permit Revision Application – Intercession City Plant
Facility ID: 0970014; ORIS Code: 8049


Dear Mr. Drango:

Thank you for your recent submission of the subject Title V permit revision application. However, we must deem your application *incomplete* due to the following concerns:

- The required Statement of Compliance was not included.
- If warranted, a Compliance Plan and Schedule must be included for any units not in compliance.
- Specific Conditions 11. and 12. in the most recent Air Construction Permit (0970014-003-AC) require manufacturers' emissions performance versus load diagrams for the specific dry low-NOx system and water injection system as part of the Title V permit revision application. Please provide these diagrams, since they were not included in the application.
- Please provide historic facts and data to justify the request to change the existing excess emissions language in the permit "to allow up to two hours of excess emissions for each startup and shutdown cycle" for combustion turbines P7 through P14.

When we receive your response to the above items, we will continue the processing of the permit revision application.

Sincerely,


Scott M. Sheplak, P.E.
Administrator
Title V Section

7/19/01 cc = Yona Cassio
Reaching Dale

"More Protection, Less Process"

Printed on recycled paper.

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:
 Mr. Martin J. Drango
 Plant Manager
 Florida Power Corporation
 P.O. Box 14042, IC44
 St. Petersburg, Florida
 33733-4042

2. Article Number (Copy from service label)
 7000 0600 0021 6524 3677

PS Form 3811, July 1999

Domestic Return Receipt

102595-99-M-1789

COMPLETE THIS SECTION ON DELIVERY

A. Received by (Please Print Clearly) B. Date of Delivery

C. Signature

X *Martin J. Drango* Agent Addressee

Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type

- Certified Mail Express Mail
- Registered Return Receipt for Merchandise
- Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

7000 0600 0021 6524 3677

**U.S. Postal Service
 CERTIFIED MAIL RECEIPT
 (Domestic Mail Only; No Insurance Coverage Provided)**

Article Sent To:
 Mr. Martin J. Drango

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark
 Here

Name (Please Print Clearly) (to be completed by mailer)
 Mr. Martin J. Drango
 Street, Apt. No. or PO Box No.
 P.O. Box 14042, IC44
 City, State, ZIP+4
 St. Petersburg, FL 33733-4042