

Date: 4/21/97 7:42:29 AM
From: Anatoliy Sobolevskiy ORL
Subject: Florida Power Permit (Title V) = FPC - Intercession City

Hi Bruce!

The status of the facility 0970014 is "in compliance" according to our inspections and stack test reviewing. At the same time, I would like to advise you that the facility staff use humidity sensors as a part of their water injection control system. Thus, the amount of water being injected into the turbines are always automatically corrected to the ambient air humidity. It is important to put in the permit conditions certain requirements to make sure that the company will periodically (once per Quarter, for instance) calibrate the humidity sensors.

Anatoly

Date: 11/13/96 2:53:23 PM
From: Andy Allen PEN
Subject: 0730003-001-AV COMPLETNESS REVIEW

This is in response to a request from Bruce Mitchell to please advise of any emission units not in compliance at the time the City of Tallahassee, Hopkins Generating Station, Title V application was submitted. Armando reviewed the compliance file and found no compliance issues.

Date: 2/3/97 2:14:28 PM
From: Lennon Anderson TAL
Subject: Compliance of Title V Facilities
To: Barbara Boutwell TAL

Of the three facilities assigned to me (Teco-Gannon, Orlando CoGen, and Polk Power Partners), only Teco-Gannon appears to be out of compliance. The issues pertaining to Teco-Gannon were addressed in the "request for additional information" letter.

Since the district offices for Orlando CoGen and Polk Power Partners did not respond to Bruce's memo, I am assuming both facilities are in compliance.

Date: 1/31/97 1:17:42 PM
From: Tom Cascio TAL
Subject: FP&L CUTLER RIDGE PLANT
To: Barbara Boutwell TAL

As we discussed, I followed up with Eva Alvarez (Dade County) as to a response to our 12/18/96 letter concerning compliance issues at the time of application submission for 0250001. She reported that Ray Gordon (enforcement office) indicated that there are no problems.

Date: 1/30/97 2:31:04 PM
From: Steve Welsh TAL
Subject: compliance status
To: Barbara Boutwell TAL

i have e-mailed the appropriate folks for)hookers point)stock island &)Suwannee river asking whether or not the facilities are operating "in compliance".

i already know that Indian river is not operating "in compliance". i'll let u know when i hear a response.