

From: Alvaro Linero TAL 850/921-9532 <LINERO_A@dep.state.fl.us>
To: KUA.Mail5(BSHARMA,JLING)
Date: 11/5/98 8:23AM
Subject: Air Construction Permit - Cane Island Unit 1

Attached is the Public Notice to extend the 15 ppm NOx compliance period by one year. The matter can probably be addressed in the certification of Cane Island Unit 3. I recommend developing some options such as limiting hours of operation if a technological solution is not in site. At the administrative hearing next summer, there will have to be a more concrete solution.

I will advise the Title V Section that they can revise their draft permit as soon as we complete the 30 day comment period after you publish the attached notice. Thanks. Al Linero.

CC: Mike Halpin TAL <HALPIN_M@dep.state.fl.us>

SCA
fig