

October 7, 2005

RECEIVED

OCT 07 2005

BUREAU OF AIR REGULATION

Mr. Ajaya Satyal
Palm Beach County Health Dept.
Air Section
901 Evernia Street
P.O. Box 29
West Palm Beach, Fl. 33402-0029

RE: Florida Power & Light Company

Riviera Power Plant

Monthly Fuel Analysis Report

Title V Permit No.: 0990042-001-AV

As required by the Title V Air Operation Permit for the units at the above facility, enclosed are the analyses of fuel oil fired for the month of September, 2005 sampling period.

Specific condition A.37.f.(1) of our Title V Air Operation Permit requires the reporting of used oil received and burned each month. No used oil was received or burned at this facility during this calendar month or in the previous 12-month period.

If you have any questions regarding the analyses, please call me at (561) 845-3154.

Sincerely,

Jeff Smith

Production Manager

Riviera Plant

Enclosures (1)

CC: Department of Environmental Protection

Testing Facility
FPL Central Laboratory
6001A Village Blvd.
West Palm Beach, Fl 33407
Phone # (561) 640-2055

State of Florida Certification Numbers Environmental Chemistry: E56078 CompQAP/QA Manual #: 920041 Customer Address
Riviera Power Plant

Report of Analyses For: Riviera Power Plant - Monthly #6 "As Fired" - Sept.

Lab Sample #	Field Sample #	Parameter	Sample Collection Date	Analysis Date	EPA Method	Result / Units	Qual.	MDL
05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001 05-PRV-09-0001		API Gravity @ 60 F Ash Content Heat of Combustion (per Barrel) Heat of Combustion (per pound) Metals: Calcium (in fuel) Metals: Magnesium (in fuel) Metals: Phosphorus (in fuel) Metals: Potassium (in fuel) Metals: Sodium (in fuel) Metals: Vanadium (in fuel) Metals: Zinc (in fuel) Sulfur content Sulfur Dioxide Emission Rate	09/30/2005 09/30/2005 09/30/2005 09/30/2005 09/30/2005 09/30/2005 09/30/2005 09/30/2005 09/30/2005 09/30/2005 09/30/2005 09/30/2005 09/30/2005	10/04/2005 10/04/2005 10/04/2005 10/04/2005 10/04/2005 10/04/2005 10/04/2005 10/04/2005 10/04/2005 10/04/2005 10/04/2005 10/04/2005	ASTMD4052 ASTMD473 ASTMD240 ASTM D240 ICP D5683 D5683 D5883 ASTMD5683 ASTMD5683 ICP ASTMD4294 Calc.	11.4 DEG. 0.04 % 6376 MBTU 18407 BTU 18 MG/KG <10 MG/KG <10 MG/KG <10 MG/KG <10 MG/KG <10 MG/KG <10 MG/KG <10 MG/KG	- - - - U U U U	N/A N/A N/A N/a n/a n/a n/a n/a N/A N/A

Samples Analyzed By: Elisa Ostertag
Samples Approved By: Bryon T. Billman
Result Comments: U - Analyzed but not detected.

Sample Comments: Parameter Comments:

Routing: Gary Moncrief PRV/PRV

File Index: A-PRV-1