

Department of Environmental Protection

Lawton Chiles Governor Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 32399-2400 December 18, 1997

Virginia B. Wetherell Secretary

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Ms. Jay Assaibene Plant General Manager FP&L Riviera Plant Post Office Box 14000 Juno Beach, Florida 33408

Re:

EPA Objection to PROPOSED Title V Permit No. 0990042-001-AV

Plant Name: FP&L - Riviera Beach

Dear Mr. Assaibene:

On December 12, the department received a timely written objection from the United States Environmental Protection Agency to the referenced proposed permit. A copy of EPA's objection is attached.

In accordance with Section 403.0872(8), Florida Statutes (F.S.), the department must not issue a final permit until the objection is resolved or withdrawn. Pursuant to Section 403.0872(8), F.S., the applicant may file a written reply to the objection within 45 days after the date on which the department serves the applicant with a copy of the objection. The written reply must include any supporting materials that the applicant desires to include in the record relevant to the issues raised by the objection. The written reply must be considered by the department in issuing a final permit to resolve the objection of EPA. Please submit any written comments you wish to have considered concerning the objection to Mr. Scott M. Sheplak, P.E., at the above letterhead address.

Pursuant to 40 CFR 70.8(c)(4) the department will have to resolve the objection by issuing a permit that satisfies EPA within 90 days of the objection, or EPA will assume authority for the permit. Since the department has been unable to resolve the issues associated with the objection, we recommend that you set up a meeting with EPA to resolve the objection. Please contact Mr. Douglas Neeley, Chief, Air & Radiation Technology Branch or Ms. Carla Pierce, Chief, Operating Source Section at 404/562-9105. Please advise us of the date and time of the meeting so that we can attend.

If you should have any other questions, please contact Mr. Scott M. Sheplak, P.E., at 850/921-9532.

Sincerely,

C. H. Fancy, P.E.

Chief

Bureau of Air Regulation

CHF/sms/k

Enclosurés

cc: 'Rich Piper, FPL w/enclosures
Pat Comer, OGC w/enclosures
Douglas Neeley, USEPA w/o enclosures
Carla Pierce, USEPA w/o enclosures
Lynda Crum, USEPA w/o enclosures



Department of Environmental Protection

Lawton Chiles Governor Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

Virginia B. Wetherell Secretary

Ms. Jay Asaibene Plant General Manager Florida Power and Light Company PO Box 14000 Juno Beach, FL 33408

ORDER EXTENDING PERMIT EXPIRATION DATE

Riviera Plant, Facility ID No.: 0990042

Section 403.0872(2)(b), Florida Statutes (F.S.), specifies that any facility which submits to the Department of Environmental Protection (Department) a timely and complete application for a Title V permit "is entitled to operate in compliance with its existing air permit pending the conclusion of proceedings associated with its application."

Section 403.0872(6), F.S., provides that a proposed Title V permit which is not objected to by the United States Environmental Protection Agency (EPA) "must become final no later than fifty-five (55) days after the date on which the proposed permit was mailed" to the EPA.

Pursuant to the Federal Acid Rain Program as defined in rule 62-210.200, Florida Administrative Code (F.A.C.), all Acid Rain permitting must become effective on January 1 of a given year.

This facility which will be permitted pursuant to section 403.0872, F.S., (Title V permit) will be required to have a permit effective date subsequent to the final processing date of the facility's Title V permit.

To prevent misunderstanding and to assure that the above identified facility continues to comply with existing permit terms and conditions until its Title V permit becomes effective, it is necessary to extend the expiration date(s) of its existing valid permit(s) until the effective date of its Title V permit. Therefore, under the authority granted to the Department by section 403.061(8), F.S., IT IS ORDERED:

- 1. The expiration date(s) of the existing valid permit(s) under which the above identified facility is currently operating is (are) hereby extended until the effective date of its permit issued pursuant to section 403.0872, F.S., (Title V permit);
- 2. The facility shall comply with all terms and conditions of its existing valid permit(s) until the effective date of its Title V permit;
- 3. The facility will continue to comply with the requirements of Chapter 62-214, F.A.C., and the Federal Acid Rain Program, as defined in rule 62-210.200, F.A.C., pending final issuance of its Title V permit.

PETITION FOR ADMINISTRATIVE REVIEW

The Department will take the action described in this Order unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 of the Florida Statutes (F.S.). Mediation under Section 120.573, F.S., will not be available for this proposed action.

A person whose substantial interests are affected by the Department's proposed decision may petition for an administrative hearing in accordance with sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. Petitions must be filed within 21 day. of receipt of this Order. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 of the Florida Statutes, or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

Riviera Plant, Facility ID No.: 0990042

Page 2 of 3

approval of the presiding officer upon the filing of a motion in compliance with rule 28-5.207 of the Florida Administrative Code.

A petition must contain the following information:

- (a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department File Number, and the county in which the project is proposed;
 - (b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
 - (d) A statement of the material facts disputed by the petitioner, if any;
- (e) A statement of the facts that the petitioner contends warrant reversal or modification of the Department's action or proposed action;
- (f) A statement identifying the rules or statutes that the petitioner contends require reversal or modification of the Department's action or proposed action; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wants the Department to take with respect to the action or proposed action addressed in this notice of intent.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this Order. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under section 120.542 of the Florida Statutes. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. The petition must specify the following information:

- (a) The name, address, and telephone number of the petitioner;
- (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;
- (c) Each rule or portion of a rule from which a variance or waiver is requested;
- (d) The citation to the statute underlying (implemented by) the rule identified in (c) above;
- (e) The type of action requested;
- (f) The specific facts that would justify a variance or waiver for the petitioner;
- (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and
- (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

This Order constitutes final agency action unless a petition is filed in accordance with the above paragraphs.

RIGHT TO APPEAL

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of

Riviera Plant, Facility ID No.: 0990042

Page 3 of 3

Appeal. The Notice of Appeal must be filed within 30 days from the date the Notice of Agency Action is filed with the Clerk of the Department.

DONE AND ORDERED this 12 day of Nov., 1997 in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

HOWARD L. RHODES, Director

Division of Air Resources Management

Twin Towers Office Building

Mail Station 5500

2600 Blair Stone Road

Tallahassee, Florida 32399-2400

850/488-0114

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this order was sent by certified mail before the close of business on ________ to the person(s) listed:

Ms. Jay Asaibene, FPL

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on

this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby

acknowledged.

(Clerk)

(Pate)

Copy By Regular Mail To:

Mr. William Reichel, FPL

Mr. Richard G. Piper, FPL

Mr. Ronnie L. Adams, P.E., FPL

Mr. Isidore Goldman, DEP SE District

Mr. James Stormer, Palm Beach County Health Dept.

P 265 301 575

US Postal Service Receipt for Certified Mail
No Insurance Coverage Provided. Do not use for International Mail (See reverse) Sent to Ms. Jay Asaibene Street & Number P. O. Box 14000 Post Office State & ZIP Code . Juno Beach, Florida 33408 Postage Certified Fee Special Delivery Fee Restricted Delivery Fee Return Receipt Showing to Whom & Date Delivered

Return Receipt Showing to Whom Date, & Addressee's Address Return Receipt Showing to Whom Date, & Addressee's Address TOTAL Postage & Fees Postmark or Date 11/14/97 FP&L - Riviera Plant ID#0990042

STATEMENT OF BASIS

Title V PROPOSED Permit No.: 0990042-001-AV
Florida Power & Light Company
Riviera Plant
Palm Beach County

This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

This facility consists of two fossil fuel steam generators, Unit 3 and Unit 4, each rated at 300 megawatts (MW). The steam generators each burn a variable combination of No. 6 fuel oil, No. 2 fuel oil, natural gas, propane, used oil from FPL operations, and expired fuel oil samples from FPL's Central laboratory, discharging pollutants through a stack 298 feet above ground level. Each unit is a Foster-Wheeler outdoor type boiler, equipped with low NOx burners and Research-Cotrell multiple cyclones with ash reinjection, with a General Electric steam turbine that drives an oil and hydrogen-cooled 300 MW class generator with capability of 315 MW.

The facility had at one time operated a 75 MW steam generating unit, Unit 2, which is no longer in service. This unit was last operated for power production in 1985. Its operating permit was surrendered by letter dated July 7, 1997.

These emissions units are regulated under Acid Rain, Phase II; and Rule 62-296.405, F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input. Fossil fuel fired steam generator Unit 3 began commercial operation in 1962 and fossil fuel fired steam generator Unit 4 began commercial operation in 1963. These emissions units may inject additives such as magnesium oxide, magnesium hydroxide and related compounds into each boiler.

Also included in this permit are miscellaneous unregulated/exempt emissions units and/or activities.

Based on the initial Title V permit application received June 12, 1996, this facility [is/not] is a major source of hazardous air pollutants (HAPs).

Florida's PROPOSED Permit Electronic Notification Cover Memorandum

TO: Yolanda Adams, U.S. EPA Region 4

CC: Carla E. Pierce, U.S, EPA Region 4

THRU: Scott M. Sheplak, P.E., Tallahassee Title V Section

FROM: Susan DeVore, Permit Engineer

DATE: November 10, 1997

RE: U.S. EPA Region 4 PROPOSED Title V Operation Permit Review

The following PROPOSED Title V operation permit and associated documents have been posted on the DEP World Wide Web Internet site for your review. Please provide any comments via Internet Email, within forty five (45) days of receiving this notice, to Scott M. Sheplak, P.E., at "Sheplak_S@dep.state.fl.us".

Applicant Name

County

Method of Transmittal

Electronic File Name(s)

Florida Power & Light Co./

Palm Beach

INTERNET

0990042p.zip

Riviera Plant

This zipped file contains the following electronic files:

propdet.doc 0990042p.doc 0990042p.sob

STATEMENT OF BASIS

Title V PROPOSED Permit No.: 0990042-001-AV
Florida Power & Light Company
Riviera Plant
Palm Beach County

This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

This facility consists of two fossil fuel steam generators, Unit 3 and Unit 4, each rated at 300 megawatts (MW). The steam generators each burn a variable combination of No. 6 fuel oil, No. 2 fuel oil, natural gas, propane, used oil from FPL operations, and expired fuel oil samples from FPL's Central laboratory, discharging pollutants through a stack 298 feet above ground level. Each unit is a Foster-Wheeler outdoor type boiler, equipped with low NOx burners and Research-Cotrell multiple cyclones with ash reinjection, with a General Electric steam turbine that drives an oil and hydrogen-cooled 300 MW class generator with capability of 315 MW.

The facility had at one time operated a 75 MW steam generating unit, Unit 2, which is no longer in service. This unit was last operated for power production in 1985. Its operating permit was surrendered by letter dated July 7, 1997.

These emissions units are regulated under Acid Rain, Phase II; and Rule 62-296.405, F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input. Fossil fuel fired steam generator Unit 3 began commercial operation in 1962 and fossil fuel fired steam generator Unit 4 began commercial operation in 1963. These emissions units may inject additives such as magnesium oxide, magnesium hydroxide and related compounds into each boiler.

Also included in this permit are miscellaneous unregulated/exempt emissions units and/or activities.

Based on the initial Title V permit application received June 12, 1996, this facility is a major source of hazardous air pollutants (HAPs).



Department of Environmental Protection

Lawton Chiles Governor Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 32399-2400

Virginia B. Wetherell Secretary

November 10, 1997

Ms. Jay Asaibene Plant General Manager Florida Power and Light Company PO Box 14000 Juno Beach, FL 33408

Re:

PROPOSED Title V Permit No.: 0990042-001-AV

Riviera Plant

Dear Ms. Asaibene:

One copy of the "PROPOSED PERMIT DETERMINATION" for the Riviera Plant located at 200-300 Broadway, Riviera Beach, Palm Beach County, is enclosed. This letter is only a courtesy to inform you that the DRAFT permit has become a PROPOSED permit.

An electronic version of this determination has been posted on the Division of Air Resource Management's world wide web site for the United States Environmental Protection Agency (USEPA) Region 4 office's review. The web site address is http://www.dep.state.fl.us/air.

Pursuant to Section 403.0872(6), Florida Statutes, if no objection to the PROPOSED permit is made by the USEPA within 45 days, the PROPOSED permit will become a FINAL permit no later than 55 days after the date on which the PROPOSED permit was mailed (posted) to USEPA. If USEPA has an objection to the PROPOSED permit, the FINAL permit will not be issued until the permitting authority receives written notice that the objection is resolved or withdrawn.

If you should have any questions, please contact Susan DeVore at 850/488-1344.

Sincerely,

C. H. Fancy, P.E.

Chief

Bureau of Air Regulation

CHF/sd

Enclosures

copy furnished to:

Mr. William M. Reichel, FPL

Mr. Kennard Kosky, P.E., Golder

Mr. Isidore Goldman, DEP SE District

Mr. Ronnie Adams, P.E., FPL

Mr. Richard G. Piper, FPL

Mr. James Stormer, Palm Beach County Health Dept.

Ms. Yolanda Adams & Ms. Carla E. Pierce, USEPA, Region 4 (INTERNET E-mail Memorandum)

11/10/97 cc - Susan DeVore

PROPOSED PERMIT DETERMINATION

PROPOSED Permit No.: 0990042-001-AV

Page 1 of 2

I. Public Notice.

An "INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" to Florida Power and Light Company for the Riviera Plant located at 200-300 Broadway, Riviera Beach, Palm Beach County was clerked on September 23, 1997. The "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" was published in the Palm Beach Post on October 8, 1997. The DRAFT Title V Air Operation Permit was available for public inspection at the Southeast District Office and Palm Beach County Health Department in West Palm Beach and the permitting authority's office in Tallahassee. Proof of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" was received.

II. Public Comments.

Comments were received and the DRAFT Title V Operation Permit was changed. The comments were not considered significant enough to reissue the DRAFT Title V Permit and require another Public Notice. Comments were received from one respondent during the 30 (thirty) day public comment period. Listed below is the response to the comments

A. Letter from Mr. Vito Giarrusso dated October 8, 1997.

For Facility-wide condition 10 electronic mail has been added as an option for submitting applicable correspondence. It has been noted that the Continuous Emission Monitoring data reported under the Acid Rain section is to be submitted to the Acid Rain Division in Washington.

10. <u>Submittals</u>. All reports, tests, notifications or other submittals required by this permit shall be submitted to the Palm Beach County Health Department, Air Section, and copies of those submittals shall be sent to the Department of Environmental Protection, Southeast District Office, Air Section. Certain correspondence may be submitted via electronic mail as appropriate. Certain Acid Rain Reports may be submitted to EPA's Acid Rain Division in Washington. Addresses and telephone numbers are:

In condition A.17 the wording "5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile" has been removed.

- **A.17.** Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.
- 4. During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:
 - a. Visible emissions, if there is an applicable standard;
- b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 100 tons per year or more of any other regulated air pollutant; and
 - c. Each NESHAP pollutant, if there is an applicable emission standard

Condition A.27 has been revised to refer to condition A.26.

PROPOSED PERMIT DETERMINATION

PROPOSED Permit No.: 0990042-001-AV

Page 2 of 2

Condition A.34 has been revised:

A.34. Fuel Analyses Report. The owner or operator shall, by the fifteenth day of each month, submit to the Palm Beach County Health Department, Air Section, a report of fuel analyses that are representative of each fuel fired in the preceding month. The report shall document the heating value, the density or specific gravity, and the percent sulfur content by weight of each fuel fired. [Rule 62-4.070(3) and 62-213.440, F.A.C., AO 50-206721 Specific Condition 3, AO 50-206722 Specific Condition 3]

Appendix E-1 has been revised per your request and now reads:

- 7. Hazardous waste accumulation building
- 8. Paint and lube buildings

We added to the footnote number 1 for Table 1-1 a statement that equivalent emissions are for each unit.

The enclosed PROPOSED Title V Air Operation Permit includes the aforementioned changes to the DRAFT Title V Air Operation Permit.

B. Documents on file with the permitting authority:

Change of Responsible Official Designation Letter received April 4, 1997, from Mr. Alfonso. Additional Information Response received July 14, 1997, from Mr. Rich Piper. Letter received October 8, 1997, from Mr. Giarrusso.

III. Conclusion.

The permitting authority will issue the PROPOSED Permit No.: 0990042-001-AV, with any changes noted above.

Florida Power & Light Company Riviera Plant Facility ID No.: 0990042 Palm Beach County

Initial Title V Air Operation Permit **PROPOSED Permit No.:** 0990042-001-AV

Permitting Authority:
State of Florida

Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
Title V Section

Mail Station #5505 2600 Blair Stone Road Tallahassee, Florida 32399-2400

Telephone: 850/488-1344 Fax: 850/922-6979

Initial Title V Air Operation Permit **PROPOSED Permit No.:** 0990042-001-AV

Table of Contents

Section	Page Number
Placard Page	
I. Facility Information A. Facility Description. B. Summary of Emissions Unit ID No(s). and Brief Description(s). C. Relevant Documents.	2 - 3
II. Facility-wide Conditions	4 - 5
III. Emissions Unit(s) and Conditions A. Emissions Units 3 & 4, Fossil Fuel Steam Generators	6 - 17
IV. Acid Rain Part A. Acid Rain, Phase II	18 - 19
Attachments	end

Permittee:

Florida Power & Light Company Riviera Plant PROPOSED Permit No.: 0990042-001-AV

Facility ID No.: 0990042

SIC Nos.: 49, 4911

Project: Initial Title V Air Operation Permit

This permit is for the operation of the Riviera Plant. This facility is located at 200-300 Broadway, Riviera Beach, Palm Beach County; UTM Coordinates: Zone 17, 594.249 km East and 2960.632 km North; Latitude: 26° 45' 55" North and Longitude: 80° 03' 09" West.

STATEMENT OF BASIS: This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

Appendix U-1, List of Unregulated Emissions Units and/or Activities Appendix E-1, List of Exempt Emissions Units and/or Activities Appendix TV-1, Title V Conditions (version dated 8/11/97)
Appendix SS-1, Stack Sampling Facilities (version dated 10/07/96)
Table 297.310-1, Calibration Schedule (version dated 10/07/96)
Phase II Acid Rain Application/Compliance Plan received 12/6/95
Alternate Sampling Procedure: ASP Number 97-B-01
Order Granting Petition for Reduced Frequency of Particulate Testing

Effective Date: January 1, 1998

Renewal Application Due Date: July 5, 2002

Expiration Date: December 31, 2002

Howard L. Rhodes, Director Division of Air Resources Management

HLR/sms/sd

Florida Power and Light Company Riviera Plant Page 2 of 19

PROPOSED Permit No.: 0990042-001-AV

Section I. Facility Information.

Subsection A. Facility Description.

This facility consists of two fossil fuel steam generators, Unit 3 and Unit 4, each rated at 300 megawatts (MW) (315 MW gross capacity) output. The steam generators each burn a variable combination of No. 6 fuel oil, No. 2 fuel oil, natural gas, propane, used oil from FPL operations, and expired fuel oil samples from FPL's Central laboratory, discharging pollutants through a stack 298 feet above ground level. Each unit is a Foster-Wheeler outdoor type boiler, equipped with low NOx burners and Research-Cotrell multiple cyclones with ash reinjection, with a General Electric steam turbine that drives an oil and hydrogen-cooled 300 MW class generator with capability of 315 MW.

Also included in this permit are miscellaneous unregulated/exempt emissions units and/or activities.

The facility had at one time operated a 75 MW steam generating unit, Unit 2, which is no longer in service. This unit was last operated for power production in 1985. Its operating permit was surrendered by letter dated July 7, 1997.

Based on the initial Title V permit application received June 12, 1996, this facility is a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID No(s). and Brief Description(s).

E.U. ID	
No.	Brief Description
003	Fossil Fuel Steam Generator, Unit 3
004	Fossil Fuel Steam Generator, Unit 4

Unregulated Emissions Units and/or Activities					
005	Painting and solvent cleaning				
006					

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.

Florida Power and Light Company Riviera Plant Page 3 of 19 PROPOSED Permit No.: 0990042-001-AV

Subsection C. Relevant Documents.

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only: Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers Appendix H-1, Permit History/ID Number Changes Table 1-1, Summary of Air Pollutant Standards and Terms Table 2-1, Summary of Compliance Requirements

These documents are on file with the permitting authority: Initial Title V Permit Application received June 12, 1996
Additional Information Request dated April 24, 1997
Additional Information Response received July 14, 1997
Letter dated March 31, 1997, changing the Responsible Official

Florida Power and Light Company Riviera Plant Page 4 of 19

Section II. Facility-wide Conditions.

The following conditions apply facility-wide:

1. APPENDIX TV-1, TITLE V CONDITIONS, is a part of this permit. {Permitting note: APPENDIX TV-1, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}

PROPOSED Permit No.: 0990042-001-AV

- **2.** Not Federally Enforceable. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor. [Rule 62-296.320(2), F.A.C.]
- 3. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. [Rule 62-296.320(4)(b)1. & 4, F.A.C.]
- **4.** Prevention of Accidental Releases (Section 112(r) of CAA). If required by 40 CFR 68, the permittee shall submit to the implementing agency:
- a. a risk management plan (RMP) when, and if, such requirement becomes applicable; and
 b. certification forms and/or RMPs according to the promulgated rule schedule.
 [40 CFR 68]
- 5. <u>Unregulated Emissions Units and/or Activities.</u> Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit. [Rule 62-213.440(1), F.A.C.]
- **6.** Exempt Emissions Units and/or Activities. Appendix E-1, List of Exempt Emissions Units and/or Activities, is a part of this permit. [Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]
- 7. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. The owner or operator shall:
 - a. Tightly cover or close all VOC or OS containers when they are not in use.
 - b. Tightly cover all open tanks which contain VOC or OS when they are not in use.
 - c. Maintain all pipes, valves, fittings, etc., which handle VOC or OS in good operating condition.
 - d. Immediately confine and clean up VOC or OS spills and make sure wastes are placed in closed containers for reuse, recycling or proper disposal.

[Rule 62-296.320(1)(a), F.A.C.]

Florida Power and Light Company Riviera Plant Page 5 of 19

8. Not Federally Enforceable. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include:

PROPOSED Permit No.: 0990042-001-AV

- a. The facility constructs temporary sandblasting enclosures when necessary, in order to perform sandblasting on fixed plant equipment.
- b. Maintenance of paved areas as needed.
- c. Regular mowing of grass and care of vegetation.
- d. Limiting access to plant property by unnecessary vehicles.
- e. Bagged chemical products are stored in weather-tight buildings until they are used.
- f. Spills of powdered chemical products are cleaned up as soon as practicable.
- g. Vehicles are restricted to slow speeds on the plant site.

[Rule 62-296.320(4)(c)2., F.A.C.; Proposed by applicant in the initial Title V permit application received June 12, 1996]

- **9.** When appropriate, any recording, monitoring or reporting requirements that are time-specific shall be in accordance with the effective date of this permit, which define day one. [Rule 62-213.440, F.A.C.]
- 10. <u>Submittals</u>. All reports, tests, notifications or other submittals required by this permit shall be submitted to the Palm Beach County Health Department's Air Section, and copies of those submittals shall be sent to the Department of Environmental Protection, Southeast District Office, Air Section. Certain correspondence may be submitted via electronic mail as appropriate. Certain Acid Rain Reports may be submitted to EPA's Acid Rain Division in Washington. Addresses and telephone numbers are:

Palm Beach County Health Department Air Section PO Box 29 West Palm Beach, FL 33401

Phone: 561/355-3070

Department of Environmental Protection Southeast District Office, Air Section PO Box 15425 West Palm Beach, FL 33416

Phone: 561/681-6600

Any reports, data, notifications, certifications and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency Region 4 Air, Pesticides & Toxics Management Division Operating Permits Section 61 Forsyth Street Atlanta, GA 30303 Phone: 404/562-9099

Fax: 404/562-9095

Section III. Emissions Unit(s) and Conditions.

Subsection A. This section addresses the following emissions unit(s).

E.U. ID	
No.	Brief Description
003	Fossil Fuel Steam Generator, Unit 3
004	Fossil Fuel Steam Generator, Unit 4

Fossil fuel fired steam generators Unit 3 and Unit 4 are each nominal 300 megawatt (315 MW gross capacity) (electric) steam generators designated as Riviera Plant Unit 3 and Unit 4, respectively. The emissions units are fired on a variable combination of No. 6 fuel oil, No. 2 fuel oil, natural gas, propane, used oil from FPL operations, and expired fuel oil samples from FPL's Central laboratory. When firing fuel oil, the maximum heat input for each boiler is 3050 mmBtu per hour, and when firing natural gas, the maximum heat input for each boiler is 3260 mmBtu per hour.

Each emissions unit consists of a boiler which drives a turbine generator. Emissions are controlled with low NOx burners and multiple cyclones with ash reinjection. Each unit is equipped with a 298 foot stack.

{Permitting note(s): These emissions units are regulated under Acid Rain, Phase II; and Rule 62-296.405, F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input. Fossil fuel fired steam generator Unit 3 began commercial operation in 1962 and fossil fuel fired steam generator Unit 4 began commercial operation in 1963. These emissions units may inject additives such as magnesium oxide, magnesium hydroxide and related compounds into each boiler.}

The following specific conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum operation heat input rates are as follows:

Unit No.	mmBtu/hr Heat Input*	Fuel Type	
3	3260	Natural Gas	
	3050	No. 2 or 6 Fuel Oil	
4	3260	Natural Gas	
	3050	No. 2 or 6 Fuel Oil	

^{*} When a blend of fuel oil and natural gas are burned, the heat input is prorated based upon the percent heat input of each fuel.

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C., Revised Operation Permits AO 50-206721 and AO 50-206722, Issued August 2, 1993]

A.2. Emissions Unit Operating Rate Limitation After Testing. Emissions units may be limited to the operating rate or conditions tested. See specific conditions **A.25** and **A.26** of this permit. [Rule 62-297.310(2), F.A.C.]

Florida Power and Light Company Riviera Plant Page 7 of 19

A.3. Methods of Operation. Fuels.

a. Startup: The only fuels allowed to be burned are any combination of natural gas or fuel oil, except propane may be utilized for ignition of the main fuel.

PROPOSED Permit No.: 0990042-001-AV

b. Normal: The only fuels allowed to be burned are any combination of No. 6 fuel oil, No. 2 fuel oil, natural gas, propane, on-specification used oil from FPL operations, and expired fuel oil samples from FPL's Central laboratory.

[Rule 62-213.410, F.A.C.; AO 50-206721, Specific Conditions 1 and 3; AO 50-206721, Specific Conditions 1 and 3]

A.4. Hours of Operation. The emissions units may operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.5. <u>Visible Emissions</u>. Visible emissions shall not exceed 40 percent opacity. Emissions units governed by this visible emissions standard shall compliance test for particulate matter emissions annually.

[Rule 62-296.405(1)(a), F.A.C.; and OGC Case No. 83-0587 & 83-0588, Order dated April 24, 1984.]

A.6. <u>Visible Emissions - Soot Blowing and Load Change</u>. Visible emissions shall not exceed 60 percent opacity during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.

Visible emissions above 60 percent opacity shall be allowed for not more than 4, six (6)-minute periods, during the 3-hour period of excess emissions allowed by this condition. [Rule 62-210.700(3), F.A.C., Note: these units have operational continuous opacity monitors.]

- **A.7.** Particulate Matter. Particulate matter emissions shall not exceed 0.1 pound per million Btu heat input, as measured by applicable compliance methods. [Rule 62-296.405(1)(b), F.A.C.]
- **A.8.** Particulate Matter Soot Blowing and Load Change. Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change. [Rule 62-210.700(3), F.A.C.]
- **A.9.** Sulfur Dioxide. Sulfur dioxide emissions shall not exceed 2.75 pounds per million Btu heat input, as measured by applicable compliance methods. Compliance shall be based on the total heat input from all liquid and gaseous fuels burned. The sulfur dioxide emission limitation shall apply at all times including startup, shutdown, and load change, but shall not apply during malfunction provided best operational practices to minimize emissions are adhered to and the duration of excess emissions are minimized and does not exceed two hours in any 24 hour period.

Florida Power and Light Company Riviera Plant Page 8 of 19

[Rules 62-213.440 and 62-296.405(1)(c)1.j., F.A.C.]

A.10. Nitrogen Oxides. Nitrogen oxides emissions shall not exceed 0.50 pounds per million Btu while firing natural gas, and 0.62 pounds per million Btu while firing oil. Compliance shall be demonstrated based on a 30-day rolling average as measured by a CEMS. The CEMS must meet the performance specifications contained in 40 CFR 60, Appendix B, or 40 CFR 75. [Rules 62-296.570(4)(a)4. and (4)(b)3., F.A.C., Revised Operation Permits AO 50-206721 and AO 50-206722, Issued August 2, 1993]

PROPOSED Permit No.: 0990042-001-AV

Excess Emissions

- **A.11.** Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]
- **A.12.** Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.

[Rule 62-210.700(2), F.A.C.]

A.13. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

A.14. Annual Tests Required. Except as provided in specific conditions **A.17** through **A.19** of this permit, emission testing for particulate emissions and visible emissions shall be performed annually, no later than September of each year, except for units that are not operating because of scheduled maintenance outages and emergency repairs, which will be tested within thirty days of returning to service.

[Rules 62-4.070(3) and 62-213.440, F.A.C.]

- **A.15.** <u>Sulfur Dioxide</u>. The owner or operator of the emission units shall demonstrate compliance with the sulfur dioxide limit of specific condition **A.9** of this permit by the following:
 - a. Through the use of a continuous emission monitoring system (CEMS) installed, calibrated, operated and maintained in accordance with the quality assurance requirements of 40 CFR 75, adopted and incorporated by reference in Rule 62-204.800, F.A.C. A Relative Accuracy Test Audit of the SO₂ CEMS shall be conducted no less than annually. Compliance shall be demonstrated based on a 3-hour rolling average.
 - b. In the event the CEMS becomes temporarily inoperable or interrupted, the fuels and the maximum fuel oil to natural gas firing ratio that shall be used is limited to that which was last used to demonstrate compliance prior to the loss of the CEMS, or the emissions units shall fuel switch and be fired with a fuel oil containing a maximum sulfur content of 2.5%, by weight, or less.

Florida Power and Light Company Riviera Plant Page 9 of 19

c. When burning 100% fuel oil, the emissions units shall be fired with a fuel oil containing a maximum sulfur content of 2.5%, by weight, or less.

PROPOSED Permit No.: 0990042-001-AV

[Rules 62-213.440, 62-204.800 and 62-296.405(1)(c)3., F.A.C.]

A.16. Determination of Process Variables.

- (a) <u>Required Equipment</u>. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- (b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

- **A.17.** Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required. (a) General Compliance Testing.
 - 2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid fuel for more than 400 hours other than during startup.
 - 3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:
 - a. Did not operate; or
 - b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.
 - 4. During each federal fiscal year (October 1 September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:
 - a. Visible emissions, if there is an applicable standard;
 - b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 100 tons per year or more of any other regulated air pollutant; and
 - c. Each NESHAP pollutant, if there is an applicable emission standard.
 - 5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid fuel, other than during startup, for a total of more than 400 hours.
 - 9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test,

Florida Power and Light Company Riviera Plant Page 10 of 19

conducted for the owner or operator.

and the test contact person who will be responsible for coordinating and having such test

PROPOSED Permit No.: 0990042-001-AV

- (b) <u>Special Compliance Tests</u>. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.
- (c) <u>Waiver of Compliance Test Requirements</u>. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply. [Rule 62-297.310(7), F.A.C., SIP Approved]
- **A.18.** When VE Tests Not Required. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:
 - a. only gaseous fuel(s); or
 - b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year. [Rule 62-297.310(7)(a)4., F.A.C.]
- **A.19.** When PM Tests Not Required. Annual and permit renewal compliance testing for particulate matter emissions is not required for these emissions units while burning:
 - a. only gaseous fuel(s); or
 - b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
 - c. only liquid fuel(s) for less than 400 hours per year.

[Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

Test Methods and Procedures

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

- **A.20.** <u>Visible emissions</u>. The test method for visible emissions shall be DEP Method 9, incorporated in Chapter 62-297, F.A.C. A transmissometer may be used and calibrated according to Rule 62-297.520, F.A.C. See specific condition **A.21** of this permit. [Rule 62-296.405(1)(e)1., F.A.C.]
- **A.21.** <u>DEP Method 9</u>. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:

Florida Power and Light Company Riviera Plant Page 11 of 19

1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.

PROPOSED Permit No.: 0990042-001-AV

- 2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:
 - a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
 - b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value. [Rule 62-297.401, F.A.C.]

- **A.22.** Particulate Matter. The test methods for particulate emissions shall be EPA Methods 17, 5, 5B, or 5F, incorporated by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet. EPA Method 5 may be used with filter temperature no more than 320 degrees Fahrenheit. For EPA Method 17, stack temperature shall be less than 375 degrees Fahrenheit. The owner or operator may use EPA Method 5 to demonstrate compliance. EPA Method 3 or 3A with Orsat analysis shall be used when the oxygen based F-factor, computed according to EPA Method 19, is used in lieu of heat input. Acetone wash shall be used with EPA Method 5 or 17. Particulate testing shall be conducted in accordance with the requirements of specific conditions **A.25** and **A.26** of this permit. [Rules 62-213.440, 62-296.405(1)(e)2., and 62-297.401, F.A.C.]
- A.23. Sulfur Dioxide. The test methods for sulfur dioxide emissions shall be EPA Methods 6, 6A, 6B, or 6C, incorporated by reference in Chapter 62-297, F.A.C. If the emissions unit obtains an alternate procedure under the provisions of Rule 62-297.620, F.A.C., the procedure shall become a condition of the emissions unit's permit. The Department will retain the authority to require EPA Method 6 or 6C if it has reason to believe that exceedences of the sulfur dioxide emissions limiting standard are occurring. The permittee may use the EPA test methods, referenced above, to demonstrate compliance; however, as an alternate sampling procedure authorized by permit, the permittee shall demonstrate compliance using CEMS for sulfur dioxide. See specific condition A.15 of this permit.

 [Rules 62-213.440 and 62-296.405(1)(c)3. and (1)(e)3., F.A.C.]
- **A.24.** Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which

Florida Power and Light Company Riviera Plant Page 12 of 19

the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

PROPOSED Permit No.: 0990042-001-AV

[Rule 62-297.310(1), F.A.C.]

A.25. Operating Rate During Testing. Testing of emissions shall be conducted with each emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rules 62-297.310(2) & (2)(b), F.A.C.]

A.26. Operating Conditions During Testing - PM and VE. Compliance testing during sootblowing and steady-state operation for particulate matter and visible emissions shall be conducted at least once annually, if liquid fuel is fired for more than 400 hours. A visible emissions test shall be conducted during one run of each particulate matter test. Testing shall be conducted as follows:

- a. When Burning Fuel Oil Up To 2.5% Sulfur. When only fuel oil containing less than or equal to 2.5% sulfur, by weight, is fired (or co-fired with natural gas) in an emissions unit, particulate matter and visible emissions tests during sootblowing and steady-state operation shall be performed on such emissions unit while firing solely fuel oil containing at least 90% of the average sulfur content of the fuel oils fired in the previous 12 month period, except that such test shall not be required to be performed during any year that testing is performed in accordance with specific condition **A.26.b**.
- b. When Burning Fuel Oil Greater Than 2.5% Sulfur. If fuel oil containing greater than 2.5% sulfur, by weight, is co-fired with natural gas in an emissions unit, particulate matter and visible emissions tests during sootblowing and steady-state operation shall be performed as soon as practicable, but in no event more than 60 days after firing such fuel oil, while co-firing such oil with the appropriate proportion of natural gas required to maintain SO₂ emissions between 90 to 100% of the SO₂ emission limit (corresponding to 2.475 and 2.75 lb/mmBtu heat input). Following successful completion of such PM and VE testing, further PM and VE testing shall not be required during the next 12 months unless fuel oil is fired that contains greater than 0.20% sulfur above the percentage sulfur concentration fired during the most recent co-firing test. If fuel oil is co-fired containing greater than 0.20% sulfur above the percentage sulfur concentration fired during the most recent co-firing test, additional PM and VE tests shall be performed as described above as soon as practicable, but in no event more than 60 days after firing such higher sulfur fuel oil.

[Rules 62-4.070(3), 62-213.440, 62-296.405(1)(c)3. and 62-297.310(7)(a)9., F.A.C.]

Florida Power and Light Company Riviera Plant Page 13 of 19

Record Keeping and Reporting Requirements

A.27. Fuel Records. The owner or operator shall create and maintain for each emission unit hourly records of the amount of each fuel fired, the ratio of fuel oil to natural gas if co-fired, and the heating value and sulfur content of each fuel fired. These records must be of sufficient detail to identify the testing requirements of specific condition **A.26**, and, when applicable, demonstrate compliance with the requirements of condition **A.15**, paragraphs b and c, of this permit. Fuel oil heating value and sulfur content shall be determined by taking a daily sample of the fuel fired, combining those samples into a monthly composite, and analyzing a representative sample of the composite. Analysis for sulfur content shall be performed using one of ASTM D2622-94, ASTM D4294-90(95), ASTM D1552-95, ASTM D1266-91, both ASTM D4057-88 and ASTM D129-95, or the latest edition(s). Comparison of the as-fired fuel oil sulfur content shall be made and recorded monthly upon receipt of each monthly composite analysis. [Rules 62-4.070(3), 62-213.410, 62-213.440 and 62-296.405(1)(c)3., F.A.C.]

PROPOSED Permit No.: 0990042-001-AV

A.28. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]

A.29. Applicable Test Procedures.

- (a) Required Sampling Time.
 - 1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.
 - 2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:
 - c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.
- (b) <u>Minimum Sample Volume</u>. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.
- (c) <u>Required Flow Rate Range</u>. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.
- (d) <u>Calibration of Sampling Equipment</u>. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1 (attached to this permit).
- (e) <u>Allowed Modification to EPA Method 5</u>. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]

Florida Power and Light Company Riviera Plant Page 14 of 19

A.30. Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit.

PROPOSED Permit No.: 0990042-001-AV

[Rule 62-297.310(6), F.A.C.]

Record Keeping and Reporting Requirements

- A.31. Excess Emissions Malfunctions. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Palm Beach County Health Department, Air Section, in accordance with Rule 62-4.130, F.A.C. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Palm Beach County Health Department, Air Section. [Rule 62-210.700(6), F.A.C.]
- **A.32.** Excess Emissions Reports. Submit to the Palm Beach County Health Department, Air Section, a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years. [Rules 62-213.440 and 62-296.405(1)(g), F.A.C.]

A.33. Test Reports.

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Palm Beach County Health Department, Air Section, on the results of each such test.
- (b) The required test report shall be filed with the Palm Beach County Health Department, Air Section, as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Palm Beach County Health Department, Air Section, to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
 - 1. The type, location, and designation of the emissions unit tested.
 - 2. The facility at which the emissions unit is located.
 - 3. The owner or operator of the emissions unit.
 - 4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
 - 5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
 - 6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
 - 7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
 - 8. The date, starting time and duration of each sampling run.

Florida Power and Light Company Riviera Plant Page 15 of 19

which option was used.

9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate

PROPOSED Permit No.: 0990042-001-AV

- 10. The number of points sampled and configuration and location of the sampling plane.
- 11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
- 12. The type, manufacturer and configuration of the sampling equipment used.
- 13. Data related to the required calibration of the test equipment.
- 14. Data on the identification, processing and weights of all filters used.
- 15. Data on the types and amounts of any chemical solutions used.
- 16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
- 17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
- 18. All measured and calculated data required to be determined by each applicable test procedure for each run.
- 19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
- 20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
- 21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rules 62-213.440 and 62-297.310(8), F.A.C.]

A.34. Fuel Analyses Report. The owner or operator shall, by the fifteenth day of each month, submit to the Palm Beach County Health Department, Air Section, a report of fuel analyses that are representative of each fuel fired in the preceding month. The report shall document the heating value, the density or specific gravity, and the percent sulfur content by weight of each fuel fired.

[Rule 62-4.070(3) and 62-213.440, F.A.C., AO 50-206721 Specific Condition 3, AO 50-206722 Specific Condition 3]

Florida Power and Light Company Riviera Plant Page 16 of 19

Miscellaneous Conditions

A.35. <u>Used Oil.</u> Burning of on-specification used oil is allowed at this facility in accordance with all other conditions of this permit and the following additional conditions:

a. On-specification Used Oil Allowed as Fuel: This permit allows the burning of used oil fuel meeting EPA "on-specification" used oil specifications, with a PCB concentration of less than 50 ppm, originating from FPL operations. Used oil that does not meet the specifications for on-specification used oil shall not be burned at this facility.

PROPOSED Permit No.: 0990042-001-AV

On-specification used oil shall meet the following specifications: [40 CFR 279, Subpart B.]

Arsenic shall not exceed 5.0 ppm; Cadmium shall not exceed 2.0 ppm; Chromium shall not exceed 10.0 ppm; Lead shall not exceed 100.0 ppm; Total halogens shall not exceed 1000 ppm; Flash point shall not be less than 100 degrees F.

- b. Quantity Limited: The maximum total quantity of used oil that may be burned in both emissions units is 1.5 million gallons in any consecutive 12-month period.
- c. <u>Used Oil Containing PCBs Not Allowed:</u> Used oil containing a PCB concentration of 50 or more ppm shall not be burned at this facility. Used oil shall not be blended to meet this requirement.
- d. PCB Concentration of 2 to less than 50 ppm: On-specification used oil with a PCB concentration of 2 to less than 50 ppm shall be burned only at normal source operating temperatures. On-specification used oil with a PCB concentration of 2 to less than 50 ppm shall not be burned during periods of startup or shutdown.
- e. <u>Testing Required</u>: The owner or operator shall sample and analyze each batch of used oil to be burned for the following parameters:

Arsenic, cadmium, chromium, lead, total halogens, flash point, and PCBs.

Testing (sampling, extraction and analysis) shall be performed using approved methods specified in EPA Publication SW-846 (Test Methods for Evaluating Solid Waste, Physical/Chemical Methods), latest edition.

- f. Record Keeping Required: The owner or operator shall obtain, make and keep the following records related to the use of used oil in a form suitable for inspection at the facility by the Department: [40 CFR 279.61 and 761.20(e)]
 - (1) The gallons of on-specification used oil received and burned each month. (This record shall be completed no later than the fifteenth day of the succeeding month.)

Florida Power and Light Company Riviera Plant Page 17 of 19 PROPOSED Permit No.: 0990042-001-AV

- (2) The total gallons of on-specification used oil burned in the preceding consecutive 12-month period. (This record shall be completed no later than the fifteenth day of the succeeding month.)
- (3) Results of the analyses required above.
- g. <u>Reporting Required</u>: The owner or operator shall submit, with the Annual Operation Report form, the analytical results and the total amount of on-specification used oil burned during the previous calendar year.

[Rule 62-4.070(3) and 62-213.440, F.A.C., 40 CFR 279 and 40 CFR 761, unless otherwise noted]

- **A.36.** Burning of Expired Fuel Oil Samples. The burning of bottles made from high density polyethylene (HDPE) containing expired fuel oil samples from FPL facilities that were retained after analysis by FPL's Central Laboratory shall be permitted under the following conditions:
 - a. The total annual amount of expired fuel oil samples burned shall not exceed 2.0 barrels of fuel oil.
 - b. The total annual amount of HDPE shall not exceed 80 pounds.
- c. The owner or operator shall submit, with the Annual Operation Report form, the total amount of expired fuel oil samples and HDPE burned during the previous calendar year. [Rule 62-4.070(3), F.A.C., AO 50-206721, AO 50-206722, and applicant request in Title V application received June 12, 1996]

Florida Power and Light Company Riviera Plant Page 18 of 19 PROPOSED Permit No.: 0990042-001-AV

Section IV. This section is the Acid Rain Part.

Operated by:

Florida Power and Light Company

ORIS code:

0619

Subsection A. This subsection addresses Acid Rain, Phase II.

The emissions unit(s) listed below are regulated under Acid Rain, Phase II.

E.U. ID	·
No.	Brief Description
002*	Fossil Fuel Steam Generator, Unit 2*
003	Fossil Fuel Steam Generator, Unit 3
004	Fossil Fuel Steam Generator, Unit 4

^{*} Note that Unit 2 is not permitted by this permit to operate. It is included in this section to account for allowance allocations assigned to Unit 2.

A.1. The Phase II permit application(s) submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain unit(s) must comply with the standard requirements and special provisions set forth in the application(s) listed below:

a. DEP Form No. 62-210.900(1)(a), dated July 1, 1995. [Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

A.2. Sulfur dioxide (SO₂) allowance allocations for each Acid Rain unit are as follows:

E.U. ID	EDAID	Vaan	2000	2001	2002
No.	EPA ID	Year	2000	2001	2002
002	ID No. 01	SO2			·
	PRV2	allowances,			
		under Table	92*	92*	92*
		2 or 3 of 40			
	•	CFR Part 73			
003	ID No. 02	SO2			
	PRV3	allowances,			
		under Table	3542*	3542*	3542*
		2 or 3 of 40			
		CFR Part 73			**
004	ID No. 03	SO2			
	PRV4	allowances,			
		under Table	3514*	3514*	3514*
		2 or 3 of 40			
		CFR Part 73			

^{*} The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the US EPA under Table 2 or 3 of 40 CFR 73.

Florida Power and Light Company Riviera Plant Page 19 of 19 PROPOSED Permit No.: 0990042-001-AV

- **A.3.** Emission Allowances. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.
 - 1. No permit revision shall be required for increase in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
 - 2. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
- 3. Allowances shall be accounted for under the Federal Acid Rain Program. [Rule 62-213.440(1)(c), F.A.C.]
- **A.4.** Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year. {See condition No. 51., Appendix TV-1, Title V Conditions} [Rule 62-214.420(11), F.A.C.]
- A.5. Comments, notes, and justifications: None

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers (version dated 02/05/97)

Abbreviations and Acronyms:

°F: Degrees Fahrenheit

BACT: Best Available Control Technology

CFR: Code of Federal Regulations

DEP: State of Florida, Department of Environmental Protection

DARM: Division of Air Resource Management

EPA: United States Environmental Protection Agency

F.A.C.: Florida Administrative Code

F.S.: Florida Statute

ISO: International Standards Organization

LAT: Latitude LONG: Longitude

MMBtu: million British thermal units

MW: Megawatt

ORIS: Office of Regulatory Information Systems

SOA: Specific Operating Agreement **UTM**: Universal Transverse Mercator

Citations:

The following examples illustrate the methods used in this permit to abbreviate and cite the references of rules, regulations, guidance memorandums, permit numbers, and ID numbers.

Code of Federal Regulations:

Example: [40 CFR 60.334]

Where: 40 reference to Title 40

CFR reference to Code of Federal Regulations

60 reference to Part 60

60.334 reference to Regulation 60.334

Florida Administrative Code (F.A.C.) Rules:

Example: [Rule 62-213, F.A.C.]

Where: 62 reference to Title 62

62-213 reference to Chapter 62-213

62-213.205 reference to Rule 62-213.205, F.A.C.

ISO: International Standards Organization refers to those conditions at 288 degrees K, 60 percent relative humidity, and 101.3 kilopascals pressure.

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers (continued)

Identification Numbers:

Facility Identification (ID) Number:

Example: Facility ID No.: 1050221

Where:

105 = 3-digit number code identifying the facility is located in Polk County

0221 = 4-digit number assigned by state database.

Permit Numbers:

Example: 1050221-002-AV, or

1050221-001-AC

Where:

AC = Air Construction Permit

AV = Air Operation Permit (Title V Source)

105 = 3-digit number code identifying the facility is located in Polk County

0221 = 4-digit number assigned by permit tracking database

001 or 002 = 3-digit sequential project number assigned by permit tracking database

Example: PSD-FL-185

PA95-01

AC53-208321

Where:

PSD= Prevention of Significant Deterioration Permit

PA = Power Plant Siting Act Permit

AC = old Air Construction Permit numbering

Facility ID No.: 0990042

Appendix E-1, List of Exempt Emissions Units and/or Activities

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Full Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining whether a facility containing such emissions units or activities would be subject to any applicable requirements. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., are also exempt from the permitting requirements of Chapter 62-213, F.A.C., provided such emissions units and activities also meet the exemption criteria of Rule 62-213.430(6)(b), F.A.C. The below listed emissions units and/or activities are hereby exempt pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities

- 1. Spent boiler chemical cleaning liquid evaporation
- 2. Natural gas metering area relief valves
- 3. Hydrazine mixing tank
- 4. Fuel oil storage tanks and related systems
- 5. Lube oil system
- 6. Oil/water separators and related equipment
- 7. Hazardous waste accumulation building
- 8. Paint and lube buildings
- 9. Misc. mobile vehicle operation

Florida Power and Light Company Riviera Plant PROPOSED Permit No.: 0990042-001-AV

Facility ID No.: 0990042

Appendix H-1, Permit History/ID Number Changes

Permit History (for tracking purposes):

E.U. ID No.	Description	Permit No.	Issue Date	Expiration Date	Extended Date ^{1, 2}	Revised Date(s)
003	Fossil Fuel Steam Generator, Unit 3	AO50-206721	03/06/92	03/15/97		
004	Fossil Fuel Steam	AO50-206722	03/06/92	03/15/97		
	Generator, Unit 4	•				

ID Number Changes (for tracking purposes):

From: Facility ID No.: 50PMB500042

To: **Facility ID No.:** 0990042

Notes:

- 1 AO permit(s) automatic extension(s) in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.
- 2 AC permit(s) automatic extension(s) in Rule 62-213.420(1)(a)4., F.A.C., effective 03/20/96. {Rule 62-213.420(1)(b)2., F.A.C., effective 03/20/96, allows Title V Sources to operate under existing valid permits}

Facility ID No.: 0990042

Appendix U-1, List of Unregulated Emissions Units and/or Activities

<u>Unregulated Emissions Units and/or Activities</u>. An emissions unit which emits no "emissions-limited pollutant" and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither 'regulated emissions units' nor 'exempt emissions units'.

E.U. ID	
No.	Brief Description of Emissions Units and/or Activity
005	Painting and solvent cleaning
006	Emergency diesel generator, and mobile equipment and engines

Facility ID No.: 099042

Appendix S Permit Summary Tables

Table 1-1, Summary of Air Pollutant Emission Standards

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Emissions Unit	Brief Description
003	Fossil Fuel Steam Generator, Unit 3, heat input of 3260 mmBtu/hr on natural gas and 3050 mmBtu/hr on fuel oil
004	Fossil Fuel Steam Generator, Unit 4, heat input of 3260 mmBtu/hr on natural gas and 3050 mmBtu/hr on fuel oil

			Allowable Emis	sions		Equivalent Emissions		
Pollutant	Fuel(s)	Hours per Year	Standard(s)	lb/hour	TPY	lb/hour TPY	Regulatory Citations	See Permit Condition(s)
VE Steady State	Oil, Natural Gas	87.60	40% opacity				Rule 62-296.405(1)(a), F.A.C.	A.5
VE Soot Blowing or Load Change	Oil, Natural Gas	8760	60 % opacity (>60% opacity for not more than 4, six- minute periods)				Rule 62-210.700(3), F.A.C.	A.6
PM Steady State	Oil, Natural Gas	8760	0.1 lb/mmBtu		٠	305 1,169	Rule 62-296.405(1)(b), F.A.C.	A.7
PM Soot Blowing or Load Change	Oil, Natural Gas	8760	0.3 lb/mmBtu			915 501	Rule 62-210.700(3), F.A.C.	A.8

Facility ID No.: 099042

Appendix S Permit Summary Tables

Table 1-1, Continued

Emissions Unit	Brief Description
003	Fossil Fuel Steam Generator, Unit 3, heat input of 3260 mmBtu/hr on natural gas and 3050 mmBtu/hr on fuel oil
004	Fossil Fuel Steam Generator, Unit 4, heat input of 3260 mmBtu/hr on natural gas and 3050 mmBtu/hr on fuel oil

			Allowable Emissions			Equivalent Emissions !		
Pollutant	Fuel(s)	Hours per Year	Standard(s)	lb/hour	TPY.	lb/hour TPÝ	Regulatory Citations	See Permit Condition(s)
SO ₂	Oil, Natural Gas	8760	2.75 lb/mmBtu			8,388 36,737	Rules 62-213.440 & 62-296.405(1)(c)1.j., F.A.C.	A.9
NO _x	Oil	8760	0.62 1b/mmBtu			1,891 8,283	Rules 62-296.570(4)(a)4. & (b)3, F.A.C.	A.10
NO _x	Natural Gas	8760	0.50 lb/mmBtu			1,630 7,139	Rule 62-296.570(4)(b)3, F.A.C.	A.10

Notes:

¹ The "Equivalent Emissions" listed are for each unit and informational purposes only. Equivalent emissions are for each unit. NA = not applicable

Facility ID No.: 099042

Appendix S **Permit Summary Tables**

Table 2-1, Summary of Compliance Requirements

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Emissions Unit	Brief Description
003	Fossil Fuel Steam Generator, Unit 3
004	Fossil Fuel Steam Generator, Unit 4

Pollutant or Parameter	Fuel(s)	Compliance Method	Testing Frequency	Frequency Base Date ¹	Minimum Compliance Test	CMS ²	See Permit Condition(s)
					Duration		
SO ₂	Oil,	Continuous Emissions Monitor	Continuous			Yes	A.9, A.15 &
	Natural		•				A.23
	Gas						
NO _x	Oil,	Continuous Emissions Monitor	Continuous			Yes	A.10
,	Natural						
	Gas						
PM	Oil,	Rule 62-296.405(1)(e)2	Annual	September	3 hours		A.22, A.25 &
	Natural			•	·		A.26
·	Gas						
VE	Oil,	DEP Method 9	Annual	September	1 hour	Yes	A.20, A.21,
	Natural			1			A.25 & A.26
	Gas						·
On-spec.		Record Keeping and Analysis	As fired				A.35
Used Oil							
Expired		Record Keeping					A.36
Fuel Oil							
Samples				·			

Notes:

¹ Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C. ² CMS = continuous monitoring system

Appendix TV-1, the Title V Core Conditions, has been provided only to the applicant. The most recent version of these conditions may be obtained from the Department's Internet Web site at:

http://www.dep.state.fl.us/air/

If you do not have access to the Internet and would like a copy of Appendix TV, please contact Susan DeVore, Department of Environmental Protection, Division of Air Resources Management, Bureau of Air Regulation, Mail Station 5505, 2600 Blair Stone Road, Tallahassee, FL 32399-2400, 850/488-1344.

An electronic version of this permit is also available from the Department's Internet Web site above.