

Bull, Robert

From: Vielhauer, Trina
Sent: Wednesday, June 16, 2004 1:06 PM
To: Bull, Robert
Subject: Progress Anclote

Bobby,
I'm looking over Progress Anclote. The AC referenced in the "permitting note" capacity section didn't say anything on capacity?
I'm just curious since I see they have one and it is referenced- could you doublecheck that for me? It is 1010017-004-AC. Thanks!

Trina

Vielhauer, Trina

From: Bull, Robert
Sent: Wednesday, June 16, 2004 2:40 PM
To: Vielhauer, Trina
Subject: RE: Progress Anclote

Trina,

1010017-004-AC
Sec III, A.2. is the following:

Unit 1 is authorized to fire fuel oils No. 1 through No. 6 with a maximum heat input of 4964 MMBtu per hour. Unit 2 is authorized to fire fuel oils No. 1 through No. 6 with a maximum heat input of 4850 MMBtu.....

Sec III, D.2. is referring to the cited permitting note:

Testing of emissions shall be conducted with each boiler operating at permitted capacity. Permitted capacity is defined as 90-100 percent of the maximum heat input rate allowed by permit. If it is impracticable to test at permitted capacity, the source may be tested at less than permitted capacity. In this case, subsequent operation is limited by adjusting the heat input limit to 110 percent of the value reached during the test until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purposes of additional compliance testing to regain the permitted capacity.

-----Original Message-----

From: Vielhauer, Trina
Sent: Wednesday, June 16, 2004 1:06 PM
To: Bull, Robert
Subject: Progress Anclote

Bobby,
I'm looking over Progress Anclote. The AC referenced in the "permitting note" capacity section didn't say anything on capacity? I'm just curious since I see they have one and it is referenced- could you doublecheck that for me? It is 1010017-004-AC. Thanks!

Trina