

Florida Department of  
Environmental Protection

Memorandum

TO: Buck Oven

THRU: Al Linero *Al Linero* 7/14

FROM: Syed Arif *SA*

DATE: July 9, 1996

SUBJECT: Pinellas County Resource Recovery Facility  
Conditions of Certification  
PA 78-11 and PA 83-18

The Bureau of Air Regulation has reviewed Exhibit "A" to the "Final Order modifying Conditions of Certification" for the Pinellas County Resource Recovery Facility (OGC No. 95-1442) and submits that Condition XV. A.6 be changed to read as follows:

The auxiliary boiler stack shall be tested for NO<sub>x</sub> during the initial performance test and thereafter at permit renewal time. The NO<sub>x</sub> emissions shall not exceed 8.95 lbs/hr and 39.20 tons/yr. Compliance with NO<sub>x</sub> emissions limits shall be determined by USEPA Method 7, 7E, or equivalent. Test reports shall be submitted to the Air Programs of the Southwest District Office of the Department and the Pinellas County Department of Environmental Management within 45 days of the testing. [ Rules 62-297.310(7)(a)1, and 62-297.310(8), F.A.C.]

The original Condition XV. A. 6 shall be renumbered XV. A. 7 and the remaining conditions shall be sequenced accordingly.

If there are any questions on the above, please give me a call at 488-1344.



# Department of Environmental Protection

Lawton Chiles  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Virginia B. Wetherell  
Secretary

July 2, 1996

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Russell Menke, Project Facilitator  
Pinellas County Resource Recovery Facility  
Air Pollution Control Retrofit Project  
14 South Fort Harrison Avenue, Fifth Floor  
Clearwater, Florida 34616

Re: Auxiliary Boiler - Pinellas County Resource Recovery Facility  
PA 78-11 and PA 83-18

Dear Mr. Menke:

This is to acknowledge that the Department has reviewed your application dated April 1 for the auxiliary boiler and determined that a PSD permit is not necessary and that the existing PSD permits do not need to be revised. This is because the emissions are less than significant with respect to PSD applicability. Additionally the unit is a minor source at a certified site. Therefore preconstruction review can be accomplished during the course of the site certification modification.

At this time, we are reviewing a draft Final Order prepared by the Power Plant Site Certification Office. We are incorporating some conditions in the Final Order to insure the emissions limits for the auxiliary boiler are enforceable to insure PSD does not apply. Approval of the Final Order will constitute issuance of the necessary authorizations with respect to preconstruction review for a minor source.

If there are future increases in emissions due to other projects, the increases from the auxiliary boiler would need to be considered in a netting calculation for contemporaneous emissions changes. At that time, the auxiliary boiler would need to be included in a PSD permit if the net contemporaneous emissions are significant.

If you have any questions regarding this matter, please call Syed Arif at (904)488-1344.

Sincerely,

A. A. Linero, P.E Administrator  
New Source review Section

AAL/aal/l

cc: H. Oven, DEP  
P. Hessling, PCDEM  
D. Dee, L&P

**SENDER:**  
 Complete item 1 and/or 2 for additional services.  
 Complete items 3 and 4a & b.  
 Print your name and address on the reverse of this form so that we can return this card to you.  
 Attach this form to the front of the mailpiece, or on the back if space does not permit.  
 Write "Return Receipt Requested" on the mailpiece below the article number.  
 The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):  
 1.  Addressee's Address  
 2.  Restricted Delivery  
 Consult postmaster for fee.

3. Article Addressed to:  
 Russell Menke  
 Pinellas Co. Res. Rec. Ctr.  
 Air Pollution Control B.P.  
 14 S. St. Harrison Ave - 5th Fl  
 Clearwater, FL 34616

4a. Article Number  
 P 339 251 120

4b. Service Type  
 Registered  Insured  
 Certified  COD  
 Express Mail  Return Receipt for Merchandise

7. Date of Delivery  
 7/4/96

5. Signature (Addressee)

6. Signature (Agent)  
 Sharon Balvas

8. Addressee's Address (Only if requested and fee is paid)

PS Form 3811, December, 1991 U.S. GPO: 1993-352-714

**DOMESTIC RETURN RECEIPT**

Is your RETURN ADDRESS completed on the reverse side?  
 Thank you for using Return Receipt Service.

P 339 251 120

US Postal Service  
**Receipt for Certified Mail**  
 No Insurance Coverage Provided.  
 Do not use for International Mail (See reverse)

Sent to	Russell Menke
Street & Number	Pinellas Co RRF
Post Office, State, & ZIP Code	Clearwater, FL
Postage	
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, & Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	7-2-96

PA 78-11  
 PA 83-18

PS Form 3800, April 1995