



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET, N.E.  
ATLANTA, GEORGIA 30365

JUN 18 1993

RECEIVED

JUN 23 1993

Division of Air  
Resources Management

4APT-AEB

Mr. Clair H. Fancy, P.E., Chief  
Bureau of Air Regulation  
Florida Department of Environmental  
Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

RE: Central Florida Power Limited Partnership,  
Tiger Bay Cogeneration Plant (PSD-FL-190)

Dear Mr. Fancy:

This is to acknowledge receipt of the final determination and Prevention of Significant Deterioration (PSD) permit for the above referenced facility, by your correspondence dated May 19, 1993. The proposed facility will be a 258 megawatt combined cycle cogeneration power plant. The proposed project consists of one advanced technology heavy-duty industrial gas turbine electric generating unit, with a duct burner-fired heat recovery steam generator, and a steam turbine generator.

Your determination proposes to limit NO<sub>x</sub> emissions from the combustion turbine through advanced dry low-NO<sub>x</sub> combustors and water injection, to limit NO<sub>x</sub> emissions from the duct burner through combustion design, to limit CO and VOC emissions from the combustion turbine and duct burner through combustion control, and to limit PM/PM<sub>10</sub>, Be, and As emissions from the combustion turbine through combustion control and the use of clean fuels. In addition, this facility will meet revised, lower NO<sub>x</sub> limits no later than December 31, 1997, through advanced combustor technology or the use of selective catalytic reduction.

We have reviewed the package as submitted and have no adverse comments. Thank you for the opportunity to review and comment on the package. If you have any questions or comments, please contact Mr. Scott Davis of my staff at (404) 347-5014.

Sincerely yours,

Brian L. Beals, Chief  
Source Evaluation Unit  
Air Enforcement Branch  
Air, Pesticides, and Toxics  
Management Division

40 TPA 530223  
Central Florida

cc: J. Neiron  
C. Allred  
D. Thomas, Sub. Dir.  
G. Bunyak, NPS  
X. Kosky, P.E., KBA  
Z. Novak, Pelt Co





March 11, 1993

Mr. Clair H. Fancy, P.E.  
Chief, Bureau of Air Regulation  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 3299-2400

RECEIVED

MAR 16 1993

Div  
Resources Management

RE: Central Florida Power Limited Partnership (CFPLP)  
Tiger Bay Cogeneration Plant  
AC 53-214903; PSD-FL-190

Dear Clair:

This correspondence provides technical information for the Department's consideration concerning the comments received from the U.S. Fish and Wildlife Service (USFWS) dated February 5, 1993 on the above referenced project. Specifically, the USFWS suggested the final permit for the project include a statement that selective catalytic reduction (SCR) be installed if the 15 ppmvd (corrected to 15 percent oxygen) emission limit is not met and that the Department re-establish an allowable emissions limit as best available control technology (BACT) if actual emissions are tested less than 15 ppmvd. The information contained herein and in the permit record clearly suggest that the final permit should not contain the suggestions made by the USFWS. The rationale is presented below.

### **Mandating SCR**

Modifying the proposed language of the permit to include a provision mandating SCR is unwarranted. The condition as proposed by the Department clearly recognizes that it will be at the determination of the Department whether SCR will be installed. This allows flexibility to incorporate other design features to meet the 15 ppmvd NOx emission limit if desired by the Department. As "pollution prevention" technology progresses over the next several years there may be other options of lowering NOx to meet emission limits. For example, the combined use of dry-low NOx combustion and wet injection may prove to be a viable technique. Research is also being performed in the area of fuel additives. Mandating the installation of SCR, if a permit limit is not met, does not recognize the development of future technologies and does not provide the Department or CFPLP the inherent flexibility to make an appropriate decision.

### **Lowering the Permit/BACT Limit**

Incorporating a provision in the permit that will require the lowering the BACT limit is not appropriate for several reasons. First, there have been no criteria proposed for establishing such a lower limit. While the initial performance tests may find a NOx emission rate lower than 15 ppmvd corrected, this tested rate will only be an accurate representation of NOx emissions that occurred during the specific conditions observed during the tests. Combustion turbines are sensitive to ambient meteorological

12018A1/15

**KBN ENGINEERING AND APPLIED SCIENCES, INC.**  
1034 Northwest 57th Street Gainesville, Florida 32605 904/331-9000 FAX: 904/332-4189



conditions such as temperature and relative humidity. Changes in meteorological conditions, for which CFPLP will have no control, may cause changes in NOx emissions. Such conditions are recognized in the margins incorporated into the design features of the control equipment. An example of how operational conditions can affect NOx emissions was previously supplied to the Department for the Orlando CoGen Limited, L.P. Project. Information was supplied to the Department that indicated that actual NOx tested as low as 9 to 13 ppmvd for the combustion turbine proposed for the project. However, the vendor would only guarantee 15 ppmvd since margins are required to assure compliance with the permit limits under all operating scenarios. The Department accepted this rationale in this permit decision.

Second, the proposed project is being designed for operation in late 1994 to early 1995. While it is recognized that combustion turbine units proposed for operation in the future (> 1997) have proposed lower limits, equipment proposed for these projects may not be applicable to the proposed project. The earlier commercial operation date for the CFPLP facility suggests that differences in equipment may result.

Third, all equipment degrades whether it be dry low-NOx combustors, SCR or a fabric filter. The emission margins built into all control equipment recognizes this fact and an appropriate emission limit must be established to account for emission changes as a result of equipment degradation.

#### **Apparent Preference for Technology Comments by USFWS**

The State of Florida has full authority for implementing the federally mandated Prevention of Significant Deterioration program through approval of its regulations and State Implementation Plan (SIP). The federal agencies comment on the PSD applications and have differing authority. The USFWS which is the designated Federal Land Manager for National Wilderness Areas Class I areas has review authority of air quality related values in such areas. The Environmental Protection Agency has authority in establishing the implementing regulations for PSD review and approval, and establishing guidelines for modeling and control technology review. For the CFPLP project, the EPA comments (see letter dated February 16, 1993), suggest that the Department's permitting decision was appropriate. The EPA is clearly the appropriate agency regarding control technology issues. In contrast, the USFWS which is the appropriate agency for air quality related values, had no adverse comments regarding the NOx impacts in the Class I area. Indeed, the USFWS indicated that the NOx impacts at the emission limits proposed by the Department were not significant. The USFWS comments should be viewed in this context; i.e., lowering the NOx emission limit will not change the conclusion reached regarding impacts (i.e., impacts will still not be significant). Moreover, the EPA comments concerning control technology (as well as emission limits) should take preference over USFWS comments.

#### **Conclusion**

The technical information presented herein and the permit record clearly indicate that the emission limits proposed by the Department in the draft permit are appropriate. Taken together with the commercial concerns expressed by CFPLP (see letter of March 10, 1993, from Destec Energy the controlling partner), we respectively request the Department not incorporate the comments made by the USFWS into the final permit.



As always, the assistance of you and your staff are greatly appreciated. Please call if you have any questions.

Sincerely,

*Kennard F. Kosky*

Kennard F. Kosky, P.E.  
President and Principal Engineer  
Florida Registration No. 14996

cc: Terrsa Heron  
Preston Lewis  
R. Chatham

attachment *C. Halladay*  
*J. Harper, EPA*  
KFK/mlb *J. Bumpah, NPS*  
*B. Thomas, SWD*



March 10, 1993

DESTEC ENERGY, INC.  
2500 CITYWEST BLVD., SUITE 150  
P.O. BOX 4411  
HOUSTON, TEXAS 77210-4411  
(713) 735-4000

Mr. C. H. Fancy  
Chief, Bureau of Air Regulation  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

VIA FEDERAL EXPRESS

**Re: Central Florida Power, L.P. - DER No. AC53-214903 & PSD-FL-190**

Dear Mr. Fancy:

On behalf of Central Florida Power, L.P. (CFPLP), I respectfully request the following comments be entered into the Department's record:

We have given serious consideration to the issue of revising emission limits after performance testing and emission data if such a lower rate is achievable. Our experience with lenders indicates that they would be unlikely to commit funds to a project with such a permit condition. We, as well as the financial community, are well aware that the regulatory agencies have the authority to impose new requirements on existing facilities. This "regulatory risk" is taken into account during the development of the project financing. A specific condition in the permit stating the Department's authority to revise the allowable emission limit would bring the "reliance on" the permit into question. Therefore, we request that no such condition be in the final permit for a change in the emission limits based on actual emission rates and that the Department rely on the regulation to provide for revision to the allowable limits.

We respectfully request that you consider our comment and would be pleased to address any other questions or concerns you might have. We appreciate the efforts on the part of the Department in reviewing our permit application and we look forward to receiving our permit.

Sincerely,

Frost W. Cochran  
Project Finance Manager

FWC/nl

cc: Bob Taylor  
Ken Kosky  
*J. Nelson*  
FWC/nlC. *Nolladay*

RECEIVED

MAR 11 1993

Division of Air  
Resources Management



Pattley



UNITED STATES  
ENVIRONMENTAL PROTECTION AGENCY  
REGION IV - ATLANTA, GEORGIA  
AIR, PESTICIDES & TOXICS MANAGEMENT DIVISION

AIR ENFORCEMENT BRANCH  
FACSIMILE TRANSMISSION SHEET

DATE: 2/15/93 # OF PAGES: 2  
TO: Clair H. Fancy PHONE #: \_\_\_\_\_  
ADDRESS: EDER FAX: \_\_\_\_\_  
FROM: Scott Davis

If the following pages are received poorly, please  
call Andrew at (404) 347-5014

SPECIAL INSTRUCTIONS FOR RECEIVER:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

345 COURTLAND STREET, N.E.  
ATLANTA, GEORGIA 30365  
FAX (404) 347-3059



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET, N.E.  
ATLANTA, GEORGIA 30365

4APT-AEB

FEB 16 1993

Mr. Clair H. Fancy, P.E., Chief  
Bureau of Air Regulation  
Florida Department of Environmental  
Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

RE: Central Florida Power Limited Partnership,  
Tiger Bay Cogeneration Plant (PSD-FL-190)


Dear Mr. Fancy:

This is to acknowledge receipt of the preliminary determination and draft Prevention of Significant Deterioration (PSD) permit for the above referenced facility, by your letter dated January 15, 1993. The proposed facility will be a 258 megawatt combined cycle cogeneration power plant. The proposed project consists of one advanced technology heavy-duty industrial gas turbine electric generating unit, with a duct burner-fired heat recovery steam generator, and a steam turbine generator.

Your determination proposes to limit NO<sub>x</sub> emissions from the combustion turbine through advanced dry low-NO<sub>x</sub> combustors and water injection, to limit NO<sub>x</sub> emissions from the duct burner through combustion design, to limit CO and VOC emissions from the combustion turbine and duct burner through combustion control, and to limit PM/PM<sub>10</sub>, Be, and As emissions from the combustion turbine through combustion control and the use of clean fuels. In addition, this facility will meet revised, lower NO<sub>x</sub> limits no later than December 31, 1997, through advanced combustor technology or the use of selective catalytic reduction.

We have reviewed the package as submitted and have no adverse comments. Thank you for the opportunity to review and comment on the package. If you have any questions or comments, please contact Mr. Scott Davis of my staff at (404) 347-5014.

Sincerely yours,

  
Brian L. Beals, Chief  
Source Evaluation Unit  
Air Enforcement Branch  
Air, Pesticides, and Toxics  
Management Division

cc: J. Began

C. Holladay

B. Thomas, SW Dist

D. Bunnak, WPS

K. Kosky, KIBN

J. Novak, P. Cramer

RECEIVED

FEB 22 1993

DIVISION OF AIR  
resources Management



February 8, 1993

RECEIVED

FEB 09 1993

Division of Air  
resources Management

Mr. Clair H. Fancy  
Bureau of Air Regulation  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

Re: Central Florida Power Limited Partnership  
Tiger Bay Cogeneration Plant  
PSD-FL-190  
AC 53-214903

Dear Mr. Fancy:

Enclosed please find the Affidavit of Publication for advertisement of the Notice of Intent to Issue Permit for this project. As shown, the advertisement was published in The Polk County Democrat on February 4, 1993 and satisfies the publication requirements of the Intent to Issue.

If you have any questions concerning this material, please call me at your earliest convenience.

Sincerely,

Kennard F. Kosky, P.E.  
President

Enclosure

cc: Robert I. Taylor, Central Florida Power, L.P.  
Robert Chatham, Destec Energy, Inc.  
Teresa Heron, FDER  
Project File

*C. Halladay*  
*B. Thomas, Su Dist.*  
*J. Harper, EPA*  
*J. Campbell, OPS*  
*K. Kosky, P.E.*

12018A1/14

KBN ENGINEERING AND APPLIED SCIENCES, INC.

1034 Northwest 57th Street Gainesville, Florida 32605 904/331-9000 FAX: 904/332-4189



AFFIDAVIT OF PUBLICATION  
The Polk County Democrat

Published Semi-Weekly  
Bartow, Polk County, Florida

Case No. \_\_\_\_\_

STATE OF FLORIDA  
COUNTY OF POLK

Before the undersigned authority personally appeared

Linda K. Holcomb

, who on oath says that (s)he is

Ad Manager

of The Polk County Democrat, a newspaper

published at Bartow, Polk County, Florida; that the attached copy of advertisement,

being a Notice of Intent to Issue Permit in the

matter of Central Florida Power

in the \_\_\_\_\_ Court, was published in said newspaper in the issues  
of February 4, 1993

Affiant further says that The Polk County Democrat is a newspaper published at Bartow, in said Polk County, Florida, and that said newspaper has heretofore been continuously published in said Polk County, Florida, each Monday and Thursday, and has been entered as second class matter at the post office in Bartow, in said Polk County, Florida, for a period of one year next preceeding the first publication of the attached copy of advertisement; and affiant further says that he has neither paid nor promised any person, firm, or corporation any discount, rebate, commission, or refund for the purpose of securing this advertisement for publication in said newspaper.

Signed Linda K. Holcomb

The foregoing instrument was acknowledged before me this 5th day of Feb.

1993, by Linda K. Holcomb

who is personally known to me.

Teresa M. Pacetti

(Signature of Notary Public)

Teresa M. Pacetti

(Printed or typed name of Notary Public)

Notary Public

My Commission Expires:



Notary Public, State of Florida  
TERESA M. PACETTI  
My Comm. Exp. Dec. 19, 1995  
Comm. No. CC 168408

quent intervention will only be at the approval of the presiding officer upon motion filed pursuant to Rule 28-5.207, F.A.C.  
The application is available for public inspection during normal business hours, 8:00 a. m. to 5:00 p. m., Monday through Friday, except legal holidays, at Department of Environmental Regulation, Bureau of Air Regulation, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, Department of Environmental Regulation, Southwest District, 3804 Coconut Palm Drive, Tampa, Florida 33619-8218.  
Any person may send written comments on the proposed action to Mr. Preston Lewis at the Department's Tallahassee address. All comments received within 30 days of the publication of this notice will be considered in the Department's final determination.  
Further, a public hearing can be requested by any person(s). Such requests must be submitted within 30 days of this notice.  
Feb. 4, 1993-0301

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION  
NOTICE OF INTENT TO ISSUE PERMIT  
The Department of Environmental Regulation gives notice of its intent to issue a PSD permit to Central Florida Power, Limited Partnership (CFPLP), County Road 630, 5 miles west of Ft. Meade, Polk County, Florida, to construct a 258 MW cogeneration facility. A determination of Best Available Control Technology (BACT) was required. The Department is issuing this Intent to Issue for the reasons stated in the Technical Evaluation and Preliminary Determination.  
A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) in accordance with Section 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, within (14) days of publication of this notice. Petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. Failure to file a petition within this time period shall constitute a waiver of any right such person may have to request an administrative determination (hearing) under Section 120.57, Florida Statutes.  
The Petition shall contain the following information; (a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department Permit File Number and the county in which the project is proposed; (b) A statement of how and when each petitioner received notice of the Department's action or proposed action; (c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action; (d) A statement of the material facts disputed by Petitioner, if any; (e) A statement of facts which petitioner contends warrant reversal or modification of the Department's action or proposed action; (f) A statement of which rules or statutes petitioner contends require reversal or modification of the Department's action or proposed action; and (g) A statement of the relief sought by petitioner, stating precisely the action petitioner wants the Department to take with respect to the Department's action or proposed action.  
If a petition is filed, the administrative hearing process is designed to formulate agency action. Accordingly, the Department's final action may be different from the position taken by it in this Notice. Persons whose substantial interests will be affected by any decision of the Department with regard to the application have the right to petition to become a party to the proceeding. The petition must conform to the requirements specified above and be filed (received) within 14 days of publication of this notice in the Office of General Counsel at the above address of the Department. Failure to petition within the allowed time frame constitutes a waiver of any right such person has to request a hearing under Section 120.57, F.S., and to participate as a party to this proceeding. Any subse-



# United States Department of the Interior



FISH AND WILDLIFE SERVICE  
75 Spring Street, S.W.  
Atlanta, Georgia  
30303

February 5, 1993

Mr. C. H. Fancy  
Chief, Bureau of Air Regulation  
Florida Department of  
Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

RECEIVED

FEB 08 1993

Division of Air  
Resources Management

Dear Mr. Fancy:

We have completed our review of Central Florida Power's (CFP) permit application and the Florida Department of Environmental Regulation's (FDER) Technical Evaluation and Preliminary Determination document regarding the proposed 258 MW Tiger Bay cogeneration project. This facility would be located near Ft. Meade, approximately 120 km southeast of the Chassahowitzka Wilderness Area (WA), a Class I air quality area administered by the Fish and Wildlife Service. The proposed project would be a significant emitter of particulate matter (PM), beryllium (Be), carbon monoxide (CO), arsenic (As), and nitrogen oxides (NO<sub>x</sub>). In addition, small amounts of sulfur dioxide (SO<sub>2</sub>), volatile organic compounds (VOC), mercury (Hg), lead (Pb), and sulfuric acid mist (H<sub>2</sub>SO<sub>4</sub>) would be emitted. We are pleased to see that CFP would minimize SO<sub>2</sub> and H<sub>2</sub>SO<sub>4</sub> emissions by burning natural gas as the primary fuel, and fuel oil with a maximum sulfur content of 0.05 percent as the backup fuel. This fuel choice allows CFP to avoid the Class I SO<sub>2</sub> increment consumption issue faced by new, high sulfur fuel-burning projects in the vicinity of the Chassahowitzka WA.

CFP proposes to further minimize emissions from the combustion turbine by using proper combustion controls, water injection, and advanced dry low-NO<sub>x</sub> combustors. We agree that using proper combustion controls and burning a low sulfur fuel represent best available control technology (BACT) for PM, Be, As, CO, VOC, SO<sub>2</sub>, and H<sub>2</sub>SO<sub>4</sub>. For NO<sub>x</sub>, we still believe that either dry low-NO<sub>x</sub> combustors, or water injection in combination with Selective Catalytic Reduction (SCR), is BACT for new combined cycle combustion turbine projects. Dry low-NO<sub>x</sub> combustors can reduce NO<sub>x</sub> levels to less than 15 parts per million (ppm) when firing natural gas, while SCR can achieve flue gas NO<sub>x</sub> concentrations as low as 6 ppm when burning gas and 9 ppm when burning oil.

→ P 3/31

Check Sheet

Company Name: Central Florida Power CP  
Permit Number: AC-53-214903  
PSD Number: PSD-FL-90  
County: Polk  
Permit Engineer: Teresa  
Others involved:

~~Albuquerque~~

DER letter 2/14/92 ?

Application:

- Initial Application
- Incompleteness Letters
- Responses
- Final Application (if applicable)
- Waiver of Department Action
- Department Response

Intent:

- Intent to Issue
- Notice to Public
- Technical Evaluation
- BACT Determination
- Unsigned Permit

Attachments:

- 
- 
- 
- Correspondence with:
  - EPA
  - Park Services
  - County
  - Other

- Proof of Publication
- Petitions - (Related to extensions, hearings, etc.)

Final Determination:

- Final Determination
- Signed Permit
- BACT Determination

Post Permit Correspondence:

- Extensions
- Amendments/Modifications
- Response from EPA
- Response from County
- Response from Park Services
- Other


It is evident that the BACT process is driving emissions from combustion turbines downward, and that applicants are looking for ways to inherently lower emissions, rather than opting for add-on flue gas cleaning technologies. The advantages of this approach are obvious. For example, with dry low-NO<sub>x</sub> combustors, the potential problems often cited with SCR (i.e., ammonia slip, disposal of spent catalyst, accidental release of stored ammonia, etc.) would not be a factor. Assuming this process continues, and inherently lower emitting systems are developed, such an approach may be preferred from a total environmental standpoint.

Regardless of which control technology is used, we believe that permit conditions should reflect the minimum achievable NO<sub>x</sub> emission rates. The Technical Evaluation and Preliminary Determination document for the Tiger Bay project mentions that General Electric (GE) is developing processes, using either steam/water injection or dry-low NO<sub>x</sub> combustor technology, to achieve a NO<sub>x</sub> control level of 15 ppm when firing natural gas. Accordingly, the FDER proposes to accept CFP's low-NO<sub>x</sub> burner design with a maximum NO<sub>x</sub> emission limit of 25 ppm (while burning gas) until December 31, 1997. After that date, the maximum permitted limit would be lowered to 15 ppm. In fact, it is our understanding that GE is hoping to design combustors that achieve an even lower rate, 9 ppm. Therefore, while we do not object to the FDER allowing CFP to emit at the 25 ppm NO<sub>x</sub> rate until GE develops the combustors, we feel that draft permit condition Number 15 should be revised. As written now, it suggests that SCR may be required if the lower NO<sub>x</sub> emission limit of 15 ppm cannot be met. We recommend that this permit condition require CFP to install SCR if the dry low-NO<sub>x</sub> combustors cannot meet the 15 ppm rate, and also that it include the statement that the FDER may revise and lower the allowable BACT limit to less than 15 ppm if such a lower rate is achievable.

Regarding CFP's analyses of Tiger Bay's potential impacts on the Chassahowitzka WA, CFP performed a Level I VISCREEN analysis and showed that there would be low potential for plume impacts in the wilderness area. In addition, CFP addressed potential effects on aquatic and terrestrial resources in the Chassahowitzka WA from increased nitrogen input. As we discussed in detail in our recent letter on the Kissimmee project, we are concerned about increased nitrogen input into the wilderness area and potential problems associated with nutrient enrichment in the aquatic ecosystem. However, because CFP's modeling shows that the annual average nitrogen dioxide impacts in the wilderness area from the Tiger Bay facility alone would be 0.014 micrograms per cubic meter (ug/m<sup>3</sup>), less than our proposed significant impact level of 0.025 ug/m<sup>3</sup>, we would not expect the project to contribute significantly to this problem.

If you have any questions regarding this matter, please contact Ms. Tonnie Maniero of our Air Quality office in Denver at 303/969-2071.

Sincerely yours,

*for*   
James W. Pulliam, Jr.  
Regional Director

cc: J. Gordon  
C. Holladay  
D. Thomas, SWDust  
G. Bunyak, NPS  
L. Novak, Park Co.  
K. Kaskey, KBN  
G. Harper, EPA

P 230 524 382




### Receipt for Certified Mail

No Insurance Coverage Provided  
Do not use for International Mail  
(See Reverse)

PS Form 3800, June 1991

Sent to	
Mr. Robert S. Chatam, P.E.	
Street and No.	
2500 Citywest Blvd.	
P.O., State and ZIP Code	
P.O. Box 4411 Houston, TX	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, and Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	
mailed - 8/10/93	
Permit No. - A-C53-214903,	
PSD-FL-190	

Is your RETURN ADDRESS completed on the reverse side?	<b>SENDER:</b> • Complete items 1 and/or 2 for additional services. • Complete items 3, and 4a & b. • Print your name and address on the reverse of this form so that we can return this card to you. • Attach this form to the front of the mailpiece, or on the back if space does not permit. • Write "Return Receipt Requested" on the mailpiece below the article number. • The Return Receipt will show to whom the article was delivered and the date delivered.		I also wish to receive the following services (for an extra fee): 1. <input type="checkbox"/> Addressee's Address 2. <input type="checkbox"/> Restricted Delivery Consult postmaster for fee.	
	3. Article Addressed to: Mr. Robert S. Chatam, P.E. DESTEC ENERGY, INC. 2500 Citywest Blvd., Suite 150 P. O. Box 4411 Houston, Texas 77210-4411		4a. Article Number P 230524382	
5. Signature (Addressee)		4b. Service Type <input type="checkbox"/> Registered <input type="checkbox"/> Insured <input checked="" type="checkbox"/> Certified <input type="checkbox"/> COD <input type="checkbox"/> Express Mail <input type="checkbox"/> Return Receipt for Merchandise		
6. Signature (Agent) 		7. Date of Delivery <b>AUG 13 1993</b>		
		8. Addressee's Address (Only if requested and fee is paid)		

Thank you for using Return Receipt Service



# Florida Department of Environmental Protection

Lawton Chiles  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Virginia B. Wetherell  
Secretary

August 5, 1993

Mr. Robert S. Chatam, P.E.  
DESTEC ENERGY, INC.  
2500 Citywest Blvd., Suite 150  
P.O. Box 4411  
Houston, Texas 77210-4411

Dear Mr. Chatam:

RE: Central Florida Power L.P.  
Permit No. AC53-214903, PSD -FL-190

The Department is in receipt of your letter dated July 30, 1993 regarding several design changes to your proposed Tiger Bay Cogeneration facility.

We have reviewed your letter and have no adverse comments. An "as built" plot and site plan should be included with the Certificate of Completion when you apply for an operation permit for this facility. Thank you for the opportunity to review and comment on this letter.

Sincerely,

C. H. Fancy, P.E.  
Chief  
Bureau of Air Regulation

CHF/TH/bjb



Lawton Chiles  
Governor

# Florida Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Virginia B. Wetherell  
Secretary

October 11, 1993


Mr. Kennard F. Kosky, P.E.  
President  
KBN Engineering and Applied Sciences, Inc.  
1034 N.W. 57th Street  
Gainesville, Florida 32605

Dear Mr. Kosky:

This in response to your recent letter notifying the Department of a design change for the Tiger Bay Cogeneration Facility (PSD-FL-190) consisting of a lower operating load of 60 percent. This design change will neither increase emissions nor result in a substantially different ambient impact. This operation will have no impact as far as the construction permit emission limits are concerned. Consequently, a construction permit modification is not required for this design change. However, it is required that this and all other substantive changes in the final design and construction be reported in the operation permit application.

If you have further questions, please contact Preston Lewis, Teresa Heron or Cleve Holladay at (904-488-1344).

Sincerely,

  
C. H. Fandy, P.E.  
Chief  
Bureau of Air Regulation

CHF/CH

cc: Robert Chatham, Destec Energy, Inc.  
Robert I. Taylor, Tiger Bay L.P.  
Bill Thomas, SWD





January 30, 1993

Mr. Clair H. Fancy  
Bureau of Air Regulation  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

RECEIVED

FEB 01 1993

DIVISION OF Air  
Resources Management

Re: Central Florida Power Limited Partnership  
Tiger Bay Cogeneration Plant  
PSD-FL-190  
AC 53-214903

Dear Mr. Fancy:

After review of the Technical Evaluation and Preliminary Determination (TEPD) for this project, dated January 15, 1993, several items in the draft permit were discussed with Ms. Teresa Heron for clarifications or corrections. These items, which were sent by facsimile to Teresa on January 21, 1993, are included as an attachment to this letter. From those discussions, the revisions, which were not considered significant by Teresa, are summarized as follows:

1. Specific Condition No. 5, page 5 of 10, TEPD- the operating parameters are for the 184 MW Combustion Turbine. Therefore, the wording, 74 MW Steam Turbine, can be eliminated from the heading.
2. Specific Condition No. 8, page 7 of 10, TEPD- Method 201, Method 12, Method 101A, and Method 8, as referenced, are either not applicable or were inadvertently inserted in this condition. These methods should be deleted.

Method 202, Determination of Condensable Particulate Emissions from Stationary Sources, should be inserted and will be used with Method 201A.

3. Specific Condition No. 9, page 7 of 10, TEPD- Method 201A and Method 201 are listed for determining the initial compliance status of particulate matter emissions. This should be changed to Method 201A and Method 202.

4. Specific Condition No. 13, page 7 of 10, TEPD- Reference to the "proposed" NOx standard should be revised to the "NSPS" NOx standard since the standard is a final regulation.

12018-0400

**KBN ENGINEERING AND APPLIED SCIENCES, INC.**

1034 Northwest 57th Street Gainesville, Florida 32605 904/331-9000 FAX: 904/332-4189

EQUAL EMPLOYMENT OPPORTUNITY / AN AFFIRMATIVE ACTION EMPLOYER

FEDERAL EXPRESS

QUESTIONS? CALL 800-238-5335 TOLL FREE

1028822362

1196M

AIRBILL PACKAGE TRACKING NUMBER

1028822362

RECIPIENT'S COPY

Date: 1-30-93

From (Your Name) Please Print: BERT MCCANN/K. KOSKY  
Your Phone Number (Very Important): 904-331-9000  
Company: ENG & APPLIED SCIENCES  
Street Address: 74 NW 57TH ST  
City: GAINESVILLE FL  
State: FL  
ZIP Required: 32605

To (Recipient's Name) Please Print: CLAIR FANCY  
Recipient's Phone Number (Very Important): 904-488-1344  
Company: FLORIDA DEPT. OF ENVIRON. REGUL.  
Department/Floor No.: TWIN TOWER  
Exact Street Address (We Cannot Deliver to P.O. Boxes or P.O. Zip Codes): 2600 BLAIR STONE RD, 4TH OFFICE  
City: TALLAHASSEE FL  
State: FL  
ZIP Required: 32319-2111

YOUR INTERNAL BILLING REFERENCE INFORMATION (First 24 characters will appear on invoice.)

2018-0400

IF HOLD FOR PICK-UP, Print FEDEX Address Here

Street Address: \_\_\_\_\_  
City: \_\_\_\_\_ State: \_\_\_\_\_ ZIP Required: \_\_\_\_\_

PAYMENT 1  Bill Sender 2  Bill Recipient's FedEx Acct No 3  Bill 3rd Party FedEx Acct No 4  Bill Credit Card

5  Cash/Check

4 SERVICES (Check only one box)

11  YOUR PACKAGING  
16  FEDEX LETTER  
12  FEDEX PAK  
13  FEDEX BOX  
14  FEDEX TUBE

51  YOUR PACKAGING  
56  FEDEX LETTER  
52  FEDEX PAK  
53  FEDEX BOX  
54  FEDEX TUBE

30  ECONOMY  
46  GOVT LETTER  
41  GOVT PACKAGE

70  OVERNIGHT FREIGHT  
80  TWO-DAY FREIGHT

5 DELIVERY AND SPECIAL HANDLING (Check services required)

1  HOLD FOR PICK-UP (Bill in Box #1)  
2  DELIVER WEEKDAY  
3  DELIVER SATURDAY (Extra charge)  
4  DANGEROUS GOODS (Extra charge)  
5   
6  DRY ICE Lbs  
7  OTHER SPECIAL SERVICE  
8   
9  SATURDAY PICK-UP (Extra charge)  
10   
11  DESCRIPTION  
12  HOLIDAY DELIVERY (11 offers) (Extra charge)

PACKAGES: \_\_\_\_\_ WEIGHT in Pounds: \_\_\_\_\_

Total: \_\_\_\_\_ Total: \_\_\_\_\_

DIM SHIPMENT (Chargeable Weight) \_\_\_\_\_ lbs.

Received At:  
1  Regular Stop 3  Drop Box  
2  On-Call Stop 4  BSC 5  Station

Emp. No: \_\_\_\_\_ Date: \_\_\_\_\_

Cash Received  
 Return Shipment  
 Third Party  Chg To Del  Chg To Hold

Street Address: \_\_\_\_\_  
City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Received By: \_\_\_\_\_  
Date/Time Received: \_\_\_\_\_ FedEx Employee Number: \_\_\_\_\_

Release Signature: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
FedEx Emp. No.: \_\_\_\_\_

Federal Express Use  
Base Charges: \_\_\_\_\_  
Declared Value Charge: \_\_\_\_\_  
Other 1: \_\_\_\_\_  
Other 2: \_\_\_\_\_  
Total Charges: \_\_\_\_\_

REVISION DATE 4/91  
PART #137204 FXEM 6/91  
FORMAT #082

082

1990-91 F.E.C. PRINTED IN U.S.A.



5. Table 1, TEPD- Several corrections regarding the emission rates and wording:

- a. For CO(CT), oil- change 98 lbs/hr to 98.4 lbs/hr
- b. For opacity, oil- insert footnote D
- c. For Hg, As, Be, Pb- include emission rate in lb/hr and TPY
- d. For Hg, As, Be, Pb- change factor of  $10^{-12}$  to  $10^{-6}$
- e. In footnote A- delete No. 2 in reference to distillate oil
- f. In footnote B- include emission rate of 97.2 lb/hr in reference to the NOx emission limit of 15 ppmvd; 15 ppmv should be ppmvd

6. Best Available Control Technology (BACT) Determination, Table on page 9:

- a. For NOx(CT)- include lb/hr emission rates and correct ppmv to ppmvd
- b. For CO(CT)- change 98 lbs/hr to 98.4 lbs/hr
- c. For Hg, As, Be, Pb- include emission rate in lb/hr and TPY
- d. For Hg, As, Be, Pb- change factor of  $10^{-12}$  to  $10^{-6}$
- e. In footnote b- delete No. 2 in reference to distillate oil
- f. in footnote c- change 8460 hours per year to 8760
- g. in footnote c- delete 300 hours per year and insert 3,742,327 gallons per calendar year

Items that remained as issues to be addressed include the following.

1. The PM10 emission limits for the CT firing natural gas and oil are currently expressed in units of lbs/MMBtu. However, based on the manufacturer's guarantee, the emission limits were presented in the application in units of lb/hr (see recommended changes in Table 1 of the TEPD; page 3 and table on page 9 of the BACT Determination). As shown in the attached KBN Table 1, the PM emission rate may exceed 0.01 lbs/MMBtu for oil-firing at base load and high temperature conditions and at 70 percent load for the range of temperatures. Although the emission limit of 0.01 lbs/MMBtu is based on base load and ambient temperature of 27 °F in the tables, the text does not mention the operating condition or temperature. To avoid this potential confusion, it is recommended that the CT emission limit for firing natural gas and fuel oil be expressed as 9 and 17 lb/hr, respectively.
2. On page 7 of the BACT Determination, it is stated that General Electric (GE) is currently developing programs using both steam/water injection and dry low NOx combustor to achieve NOx emission control level of 9 ppm when firing natural gas. From recent discussions with GE, it is our understanding that the emission control level that they are attempting to achieve is 15 ppm.
3. To be consistent with emission rates presented for most pollutants, it is recommended that the limits for sulfuric acid mist ( $H_2SO_4$ ) should be expressed to 3 three significant digits (see Table 1 of the TEPD and the table on page 9 of the BACT Determination).

Mr. Clair H. Fancy  
January 30, 1993  
Page 3



We appreciate your efforts in preparing the draft permit and reviewing our comments. Please call me if there are any further questions on the material submitted.

Sincerely,

A handwritten signature in black ink that reads "Kennard F. Kosky". The signature is written in a cursive, flowing style.

Kennard F. Kosky, P.E.  
President

Enclosure

cc: Robert I. Taylor, Central Florida Power, L.P.  
Robert Chatham, Destec Energy, Inc.  
Teresa Heron, FDER

A handwritten signature in black ink that reads "C. Holladay". The signature is written in a cursive, flowing style.

P 062 922 005



### Receipt for Certified Mail

No Insurance Coverage Provided  
Do not use for International Mail  
(See Reverse)

PS Form 3800, June 1991

Sent to Mr. Robert I. Taylor,	
Street and No. Central FL Power 2500 City West Blvd.	
P.O., State and ZIP Code Houston, TX 77042	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, and Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date Mailed: 10-9-92 Permit: AC 53-214903 PSD-FL-190	

#### SENDER:

- Complete items 1 and/or 2 for additional services.
- Complete items 3, and 4a & b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt Fee will provide you the signature of the person delivered to and the date of delivery.

I also wish to receive the following services (for an extra fee):

- 1  Addressee's Address
- 2  Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:  
Mr. Robert I. Taylor, Proj. Mgr.  
Central Florida Power, L.P.  
2500 City West Blvd., Suite 150  
Houston, TX 77042

4a. Article Number  
P 062 922 005

4b. Service Type  
 Registered       Insured  
 Certified       COD  
 Express Mail       Return Receipt for Merchandise


7. Date of Delivery  
10-13-92

5. Signature (Addressee)

8. Addressee's Address (Only if requested and fee is paid)

6. Signature (Agent)

*[Handwritten Signature]*



# Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

October 9, 1992

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Robert I. Taylor, Project Manager  
Central Florida Power, L.P.  
2500 City West Blvd., Suite 150  
Houston, Texas 77042

Dear Mr. Taylor:

This letter is to confirm the Department's conversation with Mr. Ken Kosky that additional information (updated process flow diagram showing the volumetric flow rates) is needed to complete your application for permit to construct the Tiger Bay Cogeneration Plant (File No. AC53-214903/PSD-FL-190). We are working directly with Mr. Kosky to obtain the needed information and will resume processing this application when it is complete.

If you have any questions on this matter, please write to me or call Mirza Baig, review engineer, at (904) 488-1344.

Sincerely,

*for* *John C. Browner*  
John C. Browner, P.E.  
Chief  
Bureau of Air Regulation

CHF/MB/plm

cc: Ken Kosky, KBN  
*B. Thomas, SW Dist.*  
*G. Harper, EPA*  
*B. Mitchell, UPS*



DESTEC ENGINEERING, INC.  
2500 CITYWEST BLVD., SUITE 150  
P. O. BOX 4411  
HOUSTON, TEXAS 77210-4411  
(713) 735-4000

October 23, 1992

Mr. G. Preston Lewis, P.E.  
Bureau of Air Regulation  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

RE: Central Florida Power Limited Partnership  
Tiger Bay cogeneration plant  
PSD-FL-190  
AC 53-214903

Dear Mr. Lewis,

Per our conversation on October 22, I want to personally thank you for your involvement and decision to determine our application as administratively complete as of October 9, 1992 and your commitment to issue the draft permit by December 9, 1992. KBN and I look forward to working with Mr. Mirza Baig and your department in the review and processing of our application and final issuance of the permit.

Please call me at (713) 735-4087 should you or your department have questions or comments about our application.

Sincerely,

*Robert S. Chatham*

Robert S. Chatham, P.E.  
Senior Environmental Engineer

RSC:tk

plewis.wpr

cc:Mr. Mirza Baig - FDER, Tallahassee

*Deven*  
*MIRZA*  
*is this true?*  
*Did he talk*  
*to you?* *(FYI & File)*  
*Preston*  
*10/28/92*

RECEIVED

OCT 24 1992

Division of Air  
Resources Management



October 9, 1992

Mr. Clair H. Fancy, Chief  
Bureau of Air Regulation  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Attention: Mirza Baig

RE: Central Florida Power Limited Partnership  
Tiger Bay (formerly Central Florida) Cogeneration Plant  
PSD-FL-190  
AC 53-214903

Dear Mirza:

As we discussed today, we will be sending to you information relating to the volumetric flow rates in the process flow diagrams sent in our letter of August 26, 1992.

Sincerely,

A handwritten signature in black ink, appearing to read "Kennard F. Kosky".

Kennard F. Kosky, P.E.  
Principal Engineer

KFK/mlb

RECEIVED

OCT 16 1992

Division of Air  
Resources Management

Mirza.ltr/Kosky

**KBN ENGINEERING AND APPLIED SCIENCES, INC.**  
1034 Northwest 57th Street Gainesville, Florida 32605 904/331-9000 FAX: 904/332-4189





September 9, 1992

Mr. Clair H. Fancy, Chief  
Bureau of Air Regulation  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

RECEIVED  
SEP 10 1992  
Division of Air  
Resources Management

Re: Central Florida Power Limited Partnership  
Tiger Bay (formerly Central Florida) Cogeneration Plant  
PSD-FL-190  
AC 53-214903

Dear Mr. Fancy:

This correspondence presents a clarification of Attachment 1, Manufacturer's Design Specifications for the Combustion Turbine, provided in my letter of August 26, 1992, and discussed between Mr. Robert McCann, KBN, and Mirza Baig on August 27, 1992. In that attachment, design specifications were given for GE PG7221(FA) and Westinghouse 501F combustion turbines. In August, more recent information was obtained, and the Westinghouse data are slightly different from the information presented in the permit application submitted on June 12, 1992.

As shown in Tables 1 through 4, the changes in maximum emission rates for the Westinghouse turbine are minor and generally are within approximately 2 percent of the rates specified in the permit application (see Tables 5 through 8). The emission rates for other regulated and non-regulated pollutants increase slightly due to the slight increase in the heat input rate (i.e., MMBtu/hr) which generally is the basis of the emission factor for those pollutants. Comparisons of the maximum emissions for the Westinghouse and GE turbines as presented in the permit application and for the revised Westinghouse turbine are presented in Tables 9 through 12. As shown, the emission data, in tons per year (TPY), for the GE machine at 72°F ambient temperature are higher for all pollutants except VOC when compared to the Westinghouse data. The revised maximum VOC emission rate for the Westinghouse turbine is slightly higher than that presented in the permit application (45.6 TPY compared to 45.3 TPY).

Table 3-1 from the support document to the PSD permit application has been revised to reflect the worst-case emission rates for each pollutant from either turbine. The worst-case emission rates are used to determine pollutant applicability under PSD regulations by comparing the maximum allowable emissions for the project to the PSD significant emission rates.

The modeling analysis presented as part of the permit application also does not significantly change and still provides a conservative estimate of short-term and annual impacts. The impacts were based on the the worst-case emission rates from either the GE emission data or the previous Westinghouse emission data which are still higher than the updated Westinghouse emission data.

12018A1/4

**KBN ENGINEERING AND APPLIED SCIENCES, INC.**

1034 Northwest 57th Street Gainesville, Florida 32605 904/331-9000 FAX: 904/332-4189

EQUAL EMPLOYMENT OPPORTUNITY / AN AFFIRMATIVE ACTION EMPLOYER



Therefore, the updated design specifications for the Westinghouse turbine are not a significant change from the material presented in the original application and should not materially affect any conclusions drawn from original application.

Please call me if there any further questions on the material submitted.

Sincerely,

A handwritten signature in cursive script that reads "Kennard F. Kosky".

Kennard F. Kosky, P.E.  
President

KFK/dmpm

Enclosure

cc: Robert I. Taylor, Central Florida Power, L.P.  
Robert Chatham, Destec Engineering, Inc.  
Mirza Baig, FDER  
File (2)

*C. Holladay*  
*B. Thomas, SW Dist*  
*G. Harper, EPA*  
*B. Mitchell, WPS*

Table 3-1. Net Increase in Emissions Due To the Central Florida Cogeneration Facility Compared to the PSD Significant Emission Rates (REVISED)

Pollutant	Emissions (TPY)				Significant Emission Rate	PSD Review
	Potential Emissions From Proposed Facility <sup>a</sup>		Permit Application	Revised		
	Permit Application	Revised				
Sulfur Dioxide <sup>b</sup>	33.1 (GE)	33.1 (GE)	40	No		
Particulate Matter (TSP)	45.0 (GE)	45.0 (GE)	25	Yes		
Particulate Matter (PM10)	45.0 (GE)	45.0 (GE)	15	Yes		
Nitrogen Dioxide	702.1 (GE)	702.1 (GE)	40	Yes		
Carbon Monoxide	243.1 (GE)	243.1 (GE)	100	Yes		
Volatile Organic Compounds	45.3 (W)	45.6 (W)	40	Yes		
Lead	0.00219 (GE)	0.00219 (GE)	0.6	No		
Sulfuric Acid Mist	4.2 (GE)	4.2 (GE)	7	No		
Total Fluorides	0.00802 (GE)	0.00802 (GE)	3	No		
Total Reduced Sulfur	NEG	NEG	10	No		
Reduced Sulfur Compounds	NEG	NEG	10	No		
Hydrogen Sulfide	NEG	NEG	10	No		
Asbestos	NEG	NEG	0.007	No		
Beryllium	0.000616 (GE)	0.000616 (GE)	0.0004	Yes		
Mercury	0.000739 (GE)	0.000739 (GE)	0.1	No		
Vinyl Chloride	NEG	NEG	1	No		
Benzene	NEG	NEG	0	No		
Radionuclides	NEG	NEG	0	No		
Inorganic Arsenic	0.00104 (GE)	0.00104 (GE)	0	Yes		

Note: GE = General Electric.  
NEG = Negligible.  
W = Westinghouse.

All calculations based on 72°F base load condition.

<sup>a</sup> Maximum annual emissions based on the gas turbine firing distillate oil and natural gas for 300 and 8,460 hours, respectively, and duct burner firing natural gas for 8,760 hours. Tables A-15 through A-18 present emissions for the GE machine while Tables A-33 through A-36 present emissions for the Westinghouse machine.

<sup>b</sup> Based on a maximum sulfur content specification of 0.05 percent in fuel oil.

Table 1. Difference in Maximum Emissions for Criteria Pollutants for Tiger Bay Cogeneration Facility-  
Westinghouse 501F, Base Load, Permit Application Compared to Revised Values

Pollutant	Gas Turbine- Distillate Oil			Gas Turbine- Natural Gas			Duct Burner- Natural Gas			Maximum Emissions		
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of
Hours of Operation	300			8460			8760					
Particulate:												
lb/hr	-9.00E-01	-1.00E-01	0.00E+00	2.00E-01	1.00E-01	1.00E-01	0.00E+00	0.00E+00	0.00E+00	-9.00E-01	-1.00E-01	0.00E+00
TPY	-1.35E-01	-1.50E-02	0.00E+00	8.46E-01	4.23E-01	4.23E-01	0.00E+00	0.00E+00	0.00E+00	7.11E-01	4.08E-01	4.23E-01
Sulfur Dioxide:												
lb/hr	-1.70E+00	-7.94E-01	-6.95E-01	3.93E-02	3.78E-02	3.64E-02	0.00E+00	0.00E+00	0.00E+00	-1.70E+00	-7.94E-01	-6.95E-01
TPY	-2.55E-01	-1.19E-01	-1.04E-01	1.66E-01	1.60E-01	1.54E-01	0.00E+00	0.00E+00	0.00E+00	-8.86E-02	4.06E-02	4.95E-02
Nitrogen Oxides:												
lb/hr	-7.98E-01	4.82E+00	4.27E+00	-6.21E+00	2.49E+00	2.69E+00	0.00E+00	0.00E+00	0.00E+00	-7.98E-01	4.82E+00	4.27E+00
TPY	-1.20E-01	7.22E-01	6.40E-01	-2.63E+01	1.05E+01	1.14E+01	0.00E+00	0.00E+00	0.00E+00	-2.64E+01	1.13E+01	1.20E+01
Carbon Monoxide:												
lb/hr	-2.58E+00	1.36E+00	1.67E+00	1.27E+00	2.70E-01	2.65E-01	0.00E+00	0.00E+00	0.00E+00	-2.58E+00	1.36E+00	1.67E+00
TPY	-3.87E-01	2.05E-01	2.51E-01	5.37E+00	1.14E+00	1.12E+00	0.00E+00	0.00E+00	0.00E+00	4.98E+00	1.34E+00	1.37E+00
VOCs (as methane):												
lb/hr	-1.21E-01	1.59E-01	1.62E-01	6.16E-02	6.13E-02	6.39E-02	0.00E+00	0.00E+00	0.00E+00	-1.21E-01	1.59E-01	1.62E-01
TPY	-1.82E-02	2.38E-02	2.43E-02	2.61E-01	2.59E-01	2.70E-01	0.00E+00	0.00E+00	0.00E+00	2.43E-01	2.83E-01	2.94E-01
Lead:												
lb/hr	4.54E-06	1.37E-04	1.37E-04	NA	NA	NA	NA	NA	NA	4.54E-06	1.37E-04	1.37E-04
TPY	6.81E-07	2.06E-05	2.05E-05	NA	NA	NA	NA	NA	NA	6.81E-07	2.06E-05	2.05E-05

Note: NA = not applicable

Table 2. Difference in Maximum Emissions of Other Regulated Pollutants for Tiger Bay Cogeneration Facility Westinghouse 501F, Base Load, Permit Application Compared to Revised Values

Pollutant	Gas Turbine- Distillate Oil			Gas Turbine- Natural Gas			Duct Burner- Natural Gas			Maximum Emissions			
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	
Arsenic	lb/hr	2.14E-06	6.47E-05	6.44E-05	NA	NA	NA	NA	NA	NA	2.14E-06	6.47E-05	6.44E-05
	TPY	3.21E-07	9.71E-06	9.67E-06	NA	NA	NA	NA	NA	NA	3.21E-07	9.71E-06	9.67E-06
Beryllium	lb/hr	1.27E-06	3.85E-05	3.84E-05	NA	NA	NA	NA	NA	NA	1.27E-06	3.85E-05	3.84E-05
	TPY	1.91E-07	5.78E-06	5.75E-06	NA	NA	NA	NA	NA	NA	1.91E-07	5.78E-06	5.75E-06
Mercury	lb/hr	1.53E-06	4.62E-05	4.60E-05	NA	NA	NA	NA	NA	NA	1.53E-06	4.62E-05	4.60E-05
	TPY	2.29E-07	6.94E-06	6.91E-06	NA	NA	NA	NA	NA	NA	2.29E-07	6.94E-06	6.91E-06
Fluoride	lb/hr	1.66E-05	5.01E-04	4.99E-04	NA	NA	NA	NA	NA	NA	1.66E-05	5.01E-04	4.99E-04
	TPY	2.49E-06	7.52E-05	7.49E-05	NA	NA	NA	NA	NA	NA	2.49E-06	7.52E-05	7.49E-05
Sulfuric Acid Mist	lb/hr	-2.08E-01	-9.73E-02	-8.52E-02	5.07E-03	4.87E-03	4.69E-03	0.00E+00	0.00E+00	0.00E+00	-2.08E-01	-9.73E-02	-8.52E-02
	TPY	-3.12E-02	-1.46E-02	-1.28E-02	2.14E-02	2.06E-02	1.98E-02	0.00E+00	0.00E+00	0.00E+00	-9.78E-03	6.01E-03	7.06E-03

Note: NA = not applicable

Table 3. Difference in Maximum Emissions of Non-Regulated Pollutants for Tiger Bay Cogeneration Facility-  
Westinghouse 501F, Base Load, Permit Application Compared to Revised Values

Pollutant	Gas Turbine- Distillate Oil			Gas Turbine- Natural Gas			Duct Burner- Natural Gas			Maximum Emissions		
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of
Manganese												
lb/hr	7.14E-06	2.16E-04	2.15E-04	NA	NA	NA	NA	NA	NA	7.14E-06	2.16E-04	2.15E-04
TPY	1.07E-06	3.24E-05	3.22E-05	NA	NA	NA	NA	NA	NA	1.07E-06	3.24E-05	3.22E-05
Nickel												
lb/hr	8.67E-05	2.62E-03	2.61E-03	NA	NA	NA	NA	NA	NA	8.67E-05	2.62E-03	2.61E-03
TPY	1.30E-05	3.93E-04	3.91E-04	NA	NA	NA	NA	NA	NA	1.30E-05	3.93E-04	3.91E-04
Cadmium												
lb/hr	5.35E-06	1.62E-04	1.61E-04	NA	NA	NA	NA	NA	NA	5.35E-06	1.62E-04	1.61E-04
TPY	8.03E-07	2.43E-05	2.42E-05	NA	NA	NA	NA	NA	NA	8.03E-07	2.43E-05	2.42E-05
Chromium												
lb/hr	2.42E-05	7.32E-04	7.29E-04	NA	NA	NA	NA	NA	NA	2.42E-05	7.32E-04	7.29E-04
TPY	3.63E-06	1.10E-04	1.09E-04	NA	NA	NA	NA	NA	NA	3.63E-06	1.10E-04	1.09E-04
Copper												
lb/hr	1.43E-04	4.32E-03	4.30E-03	NA	NA	NA	NA	NA	NA	1.43E-04	4.32E-03	4.30E-03
TPY	2.14E-05	6.47E-04	6.44E-04	NA	NA	NA	NA	NA	NA	2.14E-05	6.47E-04	6.44E-04
Vanadium												
lb/hr	3.54E-05	1.07E-03	1.07E-03	NA	NA	NA	NA	NA	NA	3.54E-05	1.07E-03	1.07E-03
TPY	5.32E-06	1.61E-04	1.60E-04	NA	NA	NA	NA	NA	NA	5.32E-06	1.61E-04	1.60E-04
Selenium												
lb/hr	1.19E-05	3.61E-04	3.59E-04	NA	NA	NA	NA	NA	NA	1.19E-05	3.61E-04	3.59E-04
TPY	1.79E-06	5.41E-05	5.39E-05	NA	NA	NA	NA	NA	NA	1.79E-06	5.41E-05	5.39E-05
Polycyclic Organic Matter												
lb/hr	1.42E-07	4.28E-06	4.27E-06	1.45E-05	1.40E-05	1.35E-05	0.00E+00	0.00E+00	0.00E+00	1.45E-05	1.40E-05	1.35E-05
TPY	2.13E-08	6.43E-07	6.40E-07	6.15E-05	5.91E-05	5.69E-05	0.00E+00	0.00E+00	0.00E+00	6.15E-05	5.98E-05	5.76E-05
Formaldehyde												
lb/hr	2.07E-04	6.24E-03	6.21E-03	1.15E-03	1.11E-03	1.07E-03	0.00E+00	0.00E+00	0.00E+00	2.07E-04	6.24E-03	6.21E-03
TPY	3.10E-05	9.36E-04	9.32E-04	4.87E-03	4.68E-03	4.51E-03	0.00E+00	0.00E+00	0.00E+00	4.90E-03	5.62E-03	5.44E-03

Note: NA = not applicable

Table 4. Difference in Maximum Emissions for Additional Non-Regulated Pollutant for Tiger Bay Cogeneration Facility-  
Westinghouse 501F, Base Load, Permit Application Compared to Revised Values

Pollutant	Gas Turbine- Distillate Oil			Gas Turbine- Natural Gas			Duct Burner- Natural Gas			Maximum Emissions			
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	
Antimony	lb/hr	1.11E-05	3.37E-04	3.35E-04	NA	NA	NA	NA	NA	NA	1.11E-05	3.37E-04	3.35E-04
	TPY	1.67E-06	5.05E-05	5.03E-05	NA	NA	NA	NA	NA	NA	1.67E-06	5.05E-05	5.03E-05
Barium	lb/hr	9.95E-06	3.01E-04	3.00E-04	NA	NA	NA	NA	NA	NA	9.95E-06	3.01E-04	3.00E-04
	TPY	1.49E-06	4.51E-05	4.49E-05	NA	NA	NA	NA	NA	NA	1.49E-06	4.51E-05	4.49E-05
Cobalt	lb/hr	4.62E-06	1.40E-04	1.39E-04	NA	NA	NA	NA	NA	NA	4.62E-06	1.40E-04	1.39E-04
	TPY	6.93E-07	2.10E-05	2.09E-05	NA	NA	NA	NA	NA	NA	6.93E-07	2.10E-05	2.09E-05
Zinc	lb/hr	3.48E-04	1.05E-02	1.05E-02	NA	NA	NA	NA	NA	NA	3.48E-04	1.05E-02	1.05E-02
	TPY	5.23E-05	1.58E-03	1.57E-03	NA	NA	NA	NA	NA	NA	5.23E-05	1.58E-03	1.57E-03
Chlorine	lb/hr	-8.22E-04	-3.88E-04	-3.36E-04	NA	NA	NA	NA	NA	NA	-8.22E-04	-3.88E-04	-3.36E-04
	TPY	-1.23E-04	-5.81E-05	-5.04E-05	NA	NA	NA	NA	NA	NA	-1.23E-04	-5.81E-05	-5.04E-05

Table 5. Percent Change in Maximum Emissions for Criteria Pollutants for Tiger Bay Cogeneration Facility-  
Westinghouse 501F, Base Load, Permit Application Compared to Revised Values

Pollutant	Gas Turbine- Distillate Oil			Gas Turbine- Natural Gas			Duct Burner- Natural Gas			Maximum Emissions		
	27 oF	72 oF	97 oF	27 oF	72 oF	97 oF	27 oF	72 oF	97 oF	27 oF	72 oF	97 oF
Hours of Operation	300			8460			8760					
Particulate:												
lb/hr	-2.23%	-0.26%	0.00%	3.12%	1.69%	1.79%	0.00%	0.00%	0.00%	-2.17%	-0.25%	0.00%
TPY	-2.23%	-0.26%	0.00%	3.13%	1.69%	1.79%	0.00%	0.00%	0.00%	1.90%	1.16%	1.26%
Sulfur Dioxide:												
lb/hr	-1.87%	-0.91%	-0.85%	0.82%	0.88%	0.91%	0.00%	0.00%	0.00%	-1.86%	-0.91%	-0.84%
TPY	-1.87%	-0.91%	-0.85%	0.82%	0.88%	0.91%	0.00%	0.00%	0.00%	-0.25%	0.13%	0.16%
Nitrogen Oxides:												
lb/hr	-0.27%	1.81%	1.72%	-3.67%	1.75%	2.02%	0.00%	0.00%	0.00%	-0.27%	1.74%	1.65%
TPY	-0.27%	1.81%	1.72%	-3.67%	1.75%	2.02%	0.00%	0.00%	0.00%	-3.29%	1.64%	1.87%
Carbon Monoxide:												
lb/hr	-1.58%	0.87%	1.14%	3.79%	0.87%	0.92%	0.00%	0.00%	0.00%	-1.49%	0.82%	1.07%
TPY	-1.58%	0.87%	1.14%	3.79%	0.87%	0.92%	0.00%	0.00%	0.00%	2.37%	0.68%	0.73%
VOCs (as methane):												
lb/hr	-0.64%	0.87%	0.94%	0.77%	0.87%	0.92%	0.00%	0.00%	0.00%	-0.56%	0.75%	0.81%
TPY	-0.64%	0.87%	0.94%	0.77%	0.87%	0.92%	0.00%	0.00%	0.00%	0.49%	0.63%	0.66%
Lead:												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%

Note: NA = not applicable



W501DIFF  
9/03/92

Table 6. Percent Change in Maximum Emissions of Other Regulated Pollutants for Tiger Bay Cogeneration Facility Westinghouse 501F, Base Load, Permit Application Compared to Revised Values

Pollutant	Gas Turbine- Distillate Oil			Gas Turbine- Natural Gas			Duct Burner- Natural Gas			Maximum Emissions			
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	
Arsenic	lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
	TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Beryllium	lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
	TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Mercury	lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
	TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Fluoride	lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
	TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Sulfuric Acid Mist	lb/hr	-1.87%	-0.91%	-0.85%	0.82%	0.88%	0.91%	0.00%	0.00%	0.00%	-1.86%	-0.91%	-0.84%
	TPY	-1.87%	-0.91%	-0.85%	0.82%	0.88%	0.91%	0.00%	0.00%	0.00%	-0.22%	0.15%	0.18%

Note: NA = not applicable

Table 7. Percent Change in Maximum Emissions of Non-Regulated Pollutants for Tiger Bay Cogeneration Facility- Westinghouse 501F, Base Load, Permit Application Compared to Revised Values

Pollutant	Gas Turbine- Distillate Oil			Gas Turbine- Natural Gas			Duct Burner- Natural Gas			Maximum Emissions		
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of
Manganese												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Nickel												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Cadmium												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Chromium												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Copper												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Vanadium												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Selenium												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Polycyclic Organic Matter												
lb/hr	0.03%	1.00%	1.07%	0.82%	0.88%	0.91%	0.00%	0.00%	0.00%	0.77%	0.83%	0.85%
TPY	0.03%	1.00%	1.07%	0.82%	0.88%	0.91%	0.00%	0.00%	0.00%	0.76%	0.83%	0.85%
Formaldehyde												
lb/hr	0.03%	1.00%	1.07%	0.82%	0.88%	0.91%	0.00%	0.00%	0.00%	0.03%	0.99%	1.05%
TPY	0.03%	1.00%	1.07%	0.82%	0.88%	0.91%	0.00%	0.00%	0.00%	0.67%	0.85%	0.88%

Note: NA = not applicable

W501DIFF  
9/03/92

Table 8. Percent Change in Maximum Emissions for Additional Non-Regulated Pollutant for DESTEC Central Florida Cogeneration Facility-  
Westinghouse 501F, Base Load, Permit Application Compared to Revised Values

Pollutant	Gas Turbine- Distillate Oil			Gas Turbine- Natural Gas			Duct Burner- Natural Gas			Maximum Emissions		
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of
Antimony												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Barium												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Cobalt												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Zinc												
lb/hr	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
TPY	0.03%	1.00%	1.07%	NA	NA	NA	NA	NA	NA	0.03%	1.00%	1.07%
Chlorine												
lb/hr	-1.87%	-0.91%	-0.85%	NA	NA	NA	NA	NA	NA	-1.87%	-0.91%	-0.85%
TPY	-1.87%	-0.91%	-0.85%	NA	NA	NA	NA	NA	NA	-1.87%	-0.91%	-0.85%

W501DIFF  
9/03/92

Table 9. Comparison of Maximum Emissions for Criteria Pollutants for Tiger Bay Cogeneration Facility-  
Permit Application for GE and Westinghouse Turbines and Revised Westinghouse Data, Base Load

Pollutant	Permit Application GE PG7221(FA)			Permit Application Westinghouse 501F			Revised Data Westinghouse 501F		
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of
<b>Particulate:</b>									
lb/hr	18.00	18.00	18.00	41.40	40.10	37.70	40.50	40.00	37.70
TPY	45.00	45.00	45.00	37.51	35.20	33.57	38.22	35.61	34.00
<b>Sulfur Dioxide:</b>									
lb/hr	100.02	88.87	82.11	91.35	87.31	82.32	89.65	86.52	81.63
TPY	36.82	33.05	30.74	35.24	32.46	30.52	35.15	32.50	30.57
<b>Nitrogen Oxides:</b>									
lb/hr	336.22	300.19	278.04	300.93	276.05	258.65	300.13	280.87	262.92
TPY	777.46	702.11	655.15	802.48	685.75	644.03	776.09	697.01	656.07
<b>Carbon Monoxide:</b>									
lb/hr	108.41	98.62	93.20	173.49	167.04	156.99	170.91	168.40	158.66
TPY	265.12	243.12	230.91	209.97	198.55	187.82	214.95	199.90	189.19
<b>VOCs (as methane):</b>									
lb/hr	10.40	9.48	9.40	21.76	21.18	20.06	21.64	21.34	20.22
TPY	25.63	24.46	23.66	49.53	45.29	44.66	49.77	45.57	44.95
<b>Lead:</b>									
lb/hr	1.65E-02	1.46E-02	1.35E-02	1.42E-02	1.37E-02	1.28E-02	1.42E-02	1.38E-02	1.29E-02
TPY	2.47E-03	2.19E-03	2.03E-03	2.13E-03	2.05E-03	1.91E-03	2.13E-03	2.07E-03	1.94E-03

Note: Based on firing natural gas and distillate oil for 8470 and 300 hours, respectively.  
Total emissions include emissions from the combustion turbine and duct burner.

Table 10. Comparison of Maximum Emissions of Other Regulated Pollutants for Tiger Bay Cogeneration Facility-  
Permit Application for GE and Westinghouse Turbines and Revised Westinghouse Data, Base Load

Pollutant	Maximum Emissions			Maximum Emissions			Maximum Emissions			
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	
Arsenic	lb/hr	7.77E-03	6.90E-03	6.37E-03	6.70E-03	6.45E-03	6.02E-03	6.70E-03	6.52E-03	6.09E-03
	TPY	1.17E-03	1.04E-03	9.56E-04	1.01E-03	9.68E-04	9.04E-04	1.01E-03	9.78E-04	9.13E-04
Beryllium	lb/hr	4.62E-03	4.11E-03	3.79E-03	3.99E-03	3.84E-03	3.59E-03	3.99E-03	3.88E-03	3.62E-03
	TPY	6.94E-04	6.16E-04	5.69E-04	5.98E-04	5.76E-04	5.38E-04	5.98E-04	5.82E-04	5.44E-04
Mercury	lb/hr	5.55E-03	4.93E-03	4.55E-03	4.79E-03	4.61E-03	4.30E-03	4.79E-03	4.66E-03	4.35E-03
	TPY	8.32E-04	7.39E-04	6.83E-04	7.18E-04	6.91E-04	6.45E-04	7.18E-04	6.98E-04	6.52E-04
Fluoride	lb/hr	6.02E-02	5.35E-02	4.94E-02	5.19E-02	5.00E-02	4.67E-02	5.19E-02	5.05E-02	4.72E-02
	TPY	9.03E-03	8.02E-03	7.41E-03	7.79E-03	7.50E-03	7.00E-03	7.79E-03	7.57E-03	7.08E-03
Sulfuric Acid Mist	lb/hr	1.23E+01	1.09E+01	1.01E+01	1.12E+01	1.07E+01	1.01E+01	1.10E+01	1.06E+01	1.00E+01
	TPY	4.65E+00	4.18E+00	3.89E+00	4.46E+00	4.10E+00	3.86E+00	4.45E+00	4.11E+00	3.86E+00

Note: Based on firing natural gas and distillate oil for 8470 and 300 hours, respectively.  
Total emissions include emissions from the combustion turbine and duct burner.

Table 11. Comparison of Maximum Emissions of Non-Regulated Pollutants for Tiger Bay Cogeneration Facility-  
Permit Application for GE and Westinghouse Turbines and Revised Westinghouse Data, Base Load

Pollutant	Maximum Emissions			Maximum Emissions			Maximum Emissions		
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of
Manganese									
lb/hr	2.59E-02	2.30E-02	2.12E-02	2.23E-02	2.15E-02	2.01E-02	2.23E-02	2.17E-02	2.03E-02
TPY	3.88E-03	3.45E-03	3.19E-03	3.35E-03	3.23E-03	3.01E-03	3.35E-03	3.26E-03	3.04E-03
Nickel									
lb/hr	3.14E-01	2.79E-01	2.58E-01	2.71E-01	2.61E-01	2.44E-01	2.71E-01	2.64E-01	2.46E-01
TPY	4.72E-02	4.19E-02	3.87E-02	4.07E-02	3.92E-02	3.66E-02	4.07E-02	3.96E-02	3.70E-02
Cadmium									
lb/hr	1.94E-02	1.73E-02	1.59E-02	1.68E-02	1.61E-02	1.51E-02	1.68E-02	1.63E-02	1.52E-02
TPY	2.91E-03	2.59E-03	2.39E-03	2.51E-03	2.42E-03	2.26E-03	2.51E-03	2.44E-03	2.28E-03
Chromium									
lb/hr	8.79E-02	7.80E-02	7.21E-02	7.58E-02	7.30E-02	6.81E-02	7.58E-02	7.37E-02	6.89E-02
TPY	1.32E-02	1.17E-02	1.08E-02	1.14E-02	1.09E-02	1.02E-02	1.14E-02	1.11E-02	1.03E-02
Copper									
lb/hr	5.18E-01	4.60E-01	4.25E-01	4.47E-01	4.30E-01	4.02E-01	4.47E-01	4.35E-01	4.06E-01
TPY	7.77E-02	6.90E-02	6.37E-02	6.70E-02	6.45E-02	6.02E-02	6.70E-02	6.52E-02	6.09E-02
Vanadium									
lb/hr	1.29E-01	1.14E-01	1.05E-01	1.11E-01	1.07E-01	9.97E-02	1.11E-01	1.08E-01	1.01E-01
TPY	1.93E-02	1.71E-02	1.58E-02	1.66E-02	1.60E-02	1.50E-02	1.66E-02	1.62E-02	1.51E-02
Selenium									
lb/hr	4.33E-02	3.85E-02	3.55E-02	3.74E-02	3.60E-02	3.36E-02	3.74E-02	3.63E-02	3.40E-02
TPY	6.50E-03	5.77E-03	5.33E-03	5.60E-03	5.40E-03	5.04E-03	5.61E-03	5.45E-03	5.09E-03
Polycyclic Organic Matter									
lb/hr	1.91E-03	1.73E-03	1.61E-03	1.88E-03	1.69E-03	1.59E-03	1.90E-03	1.71E-03	1.60E-03
TPY	8.17E-03	7.38E-03	6.90E-03	8.05E-03	7.25E-03	6.80E-03	8.11E-03	7.31E-03	6.86E-03
Formaldehyde									
lb/hr	7.58E-01	6.74E-01	6.23E-01	6.55E-01	6.31E-01	5.90E-01	6.55E-01	6.37E-01	5.96E-01
TPY	7.53E-01	6.79E-01	6.33E-01	7.29E-01	6.62E-01	6.21E-01	7.34E-01	6.68E-01	6.26E-01

Note: Based on firing natural gas and distillate oil for 8470 and 300 hours, respectively.  
Total emissions include emissions from the combustion turbine and duct burner.

W501DIFF  
9/03/92

Table 12. Comparison of Maximum Emissions for Additional Non-Regulated Pollutant for Tiger Bay Facility-  
Permit Application for GE and Westinghouse Turbines and Revised Westinghouse Data, Base Load

Pollutant	Maximum Emissions			Maximum Emissions			Maximum Emissions			
	27 of	72 of	97 of	27 of	72 of	97 of	27 of	72 of	97 of	
Antimony	lb/hr	4.04E-02	3.59E-02	3.32E-02	3.49E-02	3.36E-02	3.13E-02	3.49E-02	3.39E-02	3.17E-02
	TPY	6.06E-03	5.38E-03	4.97E-03	5.23E-03	5.03E-03	4.70E-03	5.23E-03	5.09E-03	4.75E-03
Barium	lb/hr	3.61E-02	3.21E-02	2.96E-02	3.11E-02	3.00E-02	2.80E-02	3.12E-02	3.03E-02	2.83E-02
	TPY	5.42E-03	4.81E-03	4.44E-03	4.67E-03	4.50E-03	4.20E-03	4.67E-03	4.54E-03	4.25E-03
Cobalt	lb/hr	1.68E-02	1.49E-02	1.38E-02	1.45E-02	1.39E-02	1.30E-02	1.45E-02	1.41E-02	1.31E-02
	TPY	2.51E-03	2.23E-03	2.06E-03	2.17E-03	2.09E-03	1.95E-03	2.17E-03	2.11E-03	1.97E-03
Zinc	lb/hr	1.26E+00	1.12E+00	1.04E+00	1.09E+00	1.05E+00	9.80E-01	1.09E+00	1.06E+00	9.91E-01
	TPY	1.90E-01	1.68E-01	1.56E-01	1.64E-01	1.57E-01	1.47E-01	1.64E-01	1.59E-01	1.49E-01
Chlorine	lb/hr	4.99E-02	4.43E-02	4.09E-02	4.41E-02	4.24E-02	3.96E-02	4.32E-02	4.21E-02	3.93E-02
	TPY	7.48E-03	6.64E-03	6.14E-03	6.61E-03	6.37E-03	5.94E-03	6.49E-03	6.31E-03	5.89E-03

Note: Based on firing natural gas and distillate oil for 8470 and 300 hours, respectively.  
Total emissions include emissions from the combustion turbine and duct burner.



August 26, 1992

Mr. Clair H. Fancy, Chief  
Bureau of Air Regulation  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

RECEIVED

AUG 27 1992

Division of Air  
Resources Management

Re: Central Florida Power Limited Partnership  
Tiger Bay (formerly Central Florida) cogeneration plant  
PSD-FL-190  
AC 53-214903

Dear Mr. Fancy:

This correspondence presents the information requested by the Department's July 14, 1992, letter. The responses have been prepared based on phone conversations held on July 15, 1992, with Mr. Mirza Baig, and subsequent discussions held with Mr. Cleve Holladay and Mr. John Glunn.

- 1. COMMENT: Section 1-1 states the electrical output of the cogeneration facility is 206 MW. The gas turbine (GT) is rated at 147 MW and the duct burner is rated at 74 MW, giving a total of 221 MW. What is the maximum electrical output you would like to be permitted for this facility?

RESPONSE: The maximum electrical output of the cogeneration facility is 258 MW (GE machine) and 246 MW (Westinghouse machine), based on the following conditions: fuel oil firing and an ambient temperature of 27°F. The breakdown of the maximum electrical output for both machines for fuel oil is as follows:

Fuel/Unit	Maximum Rated Electrical Output (MW)	
	GE	Westinghouse
Combustion Turbine	184	172
Steam Turbine	74	74

- 2. COMMENT: According to Section 1-1, two types of advanced GTs are being considered for this project. The Department must know the exact type of gas turbine you propose to install so that a BACT determination can be made. Accordingly, please submit detailed information of the unit selected. We will also need any available stack test data for that unit.





**RESPONSE:** The combustion turbine for the project has not been selected. The candidate turbines are currently being evaluated for performance and commercial terms. The air construction application for the project was based on the advanced class of turbines, and performance and emissions are similar for the two turbines under consideration. The information on both turbines is presented in Attachment 1. The information presented in the application was based on performance and emissions characteristics that enveloped these two turbines. Since the performance and emission characteristics are similar for the turbines under consideration, a decision regarding BACT would not be substantially different regardless of which turbine was selected. A similar decision was made by the Department in the BACT determination for the Hardee Power Station. In that project, four combustion turbines were proposed by the applicant, with the Department's BACT determination made on an envelope of performance and emission characteristics.

3. **COMMENT:** What is the maximum sulfur content of the natural gas you propose to burn? Provide a copy of any sulfur content guarantee that you may have from the supplier.

**RESPONSE:** The maximum sulfur content of the natural gas proposed in the application was 1 grain of sulfur per 100 cubic feet (1 gr/100 cf). This was based on an evaluation of 9 months of sulfur content data supplied by Florida Gas Transmission (FGT). FGT is the only supplier of pipeline natural gas in Florida. The results of the evaluation are presented in Table 1. As shown in this table, the average sulfur content of natural gas was 0.43 gr/100 cf. A 130 percent contingency was used to develop the proposed emission rate of 1 gr/100 cf from the average sulfur content of 0.43 gr/100 cf reported by FGT in natural gas and would statistically account for potentially higher sulfur contents. Sulfur content information supplied by FGT for four sample analyses performed in April and May 1992 indicated a maximum sulfur content of 0.4 gr/100 cf which is within the previously supplied data (see Attachment 2).

There is no guaranteed sulfur content for natural gas that is supplied by FGT.

4. **COMMENT:** Submit an updated process flow diagram showing steam turbine and volumetric air flow rates.

**RESPONSE:** Updated process flow diagrams showing the steam turbine and the mass energy balance around the steam turbine and gas turbine are presented in Attachment 3 for natural gas and fuel oil firing.

5. **COMMENT:** In Section 4-12, Table 4-2, the emissions (25 ppmvd) for advance GT with dry low-NO<sub>x</sub> technology appears to be incorrect. Also, Table 4-2 should state the turbine size on which these figures are based.

**RESPONSE:** The 25 ppmvd listed for the dry low-NO<sub>x</sub> technology in both the conventional and advanced machines is correct. This is the actual level that would be emitted from each machine. The 22.5 ppmvd listed on page 4-11 of the report is for the advanced machine when the emission rate is adjusted based on the same amount of generation (i.e., megawatt-hours) as a conventional gas turbine. As described in the preceding paragraph, the advanced



machine is more efficient and will result in lower  $\text{NO}_x$  emissions for each megawatt generated. This comparison would be analogous to the amount of particulate per ton of clinker produced by a cement plant.

The sizes of the turbines in Table 4-2 are: conventional--82 MW gas and 84 MW oil; advanced--147.1 MW gas and 159.2 MW oil [for GE PG7221(FA) machine at ambient temperature of 72 °F].

6. COMMENT: Submit all emission calculations and not just an example calculation. These emission calculations shall be based on the selected turbine for this project.

RESPONSE: The detailed emission calculations for the turbine proposed for this project are presented in Attachment 4 to this letter.

7. COMMENT: What is the expected maximum ambient concentrations for the metals emitted?

RESPONSE: The expected maximum ambient concentrations for toxic air pollutants, including metals, are presented in Table 7-5, page 7-9, in the PSD analysis that supports the air construction permit application. Based on the results presented in the table, the highest predicted impacts were below the no-threat levels for all pollutants and averaging times.

8. COMMENT: Please provide an air quality related analysis (AQRV) of the impact this project will have on the Chassahowitzka National Wilderness Area (CNWA) for the pollutant  $\text{NO}_2$ . The AQRV analysis includes impacts to soil, vegetation, and wildlife. This analysis also includes an assessment of impacts to the aquatic environment. Since the modeling information already provided with this application shows that the predicted  $\text{NO}_2$  impact at the CNWA Class I area is less than the National Park Service (NPS) recommended significance level, the NPS has verbally stated that only a literature review is needed in order to comply with the AQRV analysis requirement.

RESPONSE: KBN has performed air quality analyses to determine the Prevention of Significant Deterioration (PSD) Class I increment consumption and Air Quality Related Values (AQRV) Analyses for the Chassahowitzka National Wilderness Area (NWA) due to emissions from the Tiger Bay cogeneration facility. The facility is located approximately 120 km from the closest part of the Chassahowitzka National Wilderness Area (NWA), a PSD Class I area. The proposed facility alone had a maximum predicted annual average nitrogen dioxide ( $\text{NO}_2$ ) impact of  $0.014 \mu\text{g}/\text{m}^3$ , which is less than the National Park Service (NPS) significant impact level of  $0.025 \mu\text{g}/\text{m}^3$ .

Based on verbal communications between the Florida Department of Environmental Regulation (FDER) and NPS, the AQRV analyses for the PSD Class I area of the Chassahowitzka NWA need only address the impacts of increased  $\text{NO}_2$  emissions for this project.

The Chassahowitzka NWA is characterized by vegetation which includes flatwoods, brackish-water, marine, and halophytic terrestrial species. Predominant tree species are slash pine,



laurel oak, sweetgum, and palm. Other plants in the preserve include needlegrass rush, seashore saltgrass, marsh hay, and red mangrove.  $\text{NO}_2$  concentrations can injure plant tissue with symptoms usually appearing as irregular white to brown collapsed lesions between the leaf veins and near the margins. Conversely, non-injurious levels of  $\text{NO}_2$  can be absorbed by plants, enzymatically transformed into ammonia, and incorporated into plant constituents such as amino acids (Matsumaru et al., 1979).

Plant damage can occur through either acute (short-term, high concentration) or chronic (long-term, relatively low concentration) exposure. For plants that have been determined to be more sensitive to  $\text{NO}_2$  exposure than others, acute (1, 4, 8 hours) exposure caused 5 percent predicted foliar injury at concentrations ranging from 3,800 to 15,000  $\mu\text{g}/\text{m}^3$  (Heck and Tingey, 1979). Chronic exposure of selected plants (some considered  $\text{NO}_2$ -sensitive) to  $\text{NO}_2$  concentrations of 2,000 to 4,000  $\mu\text{g}/\text{m}^3$  for 213 to 1,900 hours caused reductions in yield of up to 37 percent and some chlorosis (Zahn, 1975).

By comparison of published toxicity values for  $\text{NO}_2$  exposure to short-term (i.e., 1-, 3-, and 8-hour averaging times) and long-term (annual averaging time) modeled concentrations, the possibility of plant damage in the preserve can be examined for both acute and chronic exposure situations, respectively. The 1-, 3-, and 8-hour estimated  $\text{NO}_2$  concentrations at the point of maximum impact are 3.65, 2.14, and 1.00  $\mu\text{g}/\text{m}^3$ , respectively. These concentrations are approximately  $6.7 \times 10^{-5}$  to  $9.6 \times 10^{-4}$  of the levels that could potentially injure 5 percent of the plant foliage. For a chronic exposure, the annual estimated  $\text{NO}_2$  concentration at the point of maximum impact in the preserve (0.014  $\mu\text{g}/\text{m}^3$ ) is  $3.5 \times 10^{-6}$  to  $7.0 \times 10^{-6}$  of the levels that caused minimal yield loss and chlorosis in plant tissue.

The majority of the soil in the Class I area is classified as Weekiwachee--Durbin muck. This is an euic, hyperthermic typic sulfhemist that is characterized by high levels of sulfur and organic matter. This soil is flooded daily with the advent of high tide, and the pH ranges between 6.1 and 7.8. The upper level of this soil may contain as much as 4 percent sulfur (USDA, 1991).

The greatest threat to soils from increased  $\text{NO}_2$  deposition is a decrease in pH or an increase of sulfur to levels considered unnatural or potentially toxic. Although ground deposition was not calculated, it is evident that the amount of  $\text{NO}_2$  deposited would be inconsequential in light of the inherent sulfur content. The regular flooding of these soils by the Gulf of Mexico regulates the pH, and any rise in acidity in the soil would be buffered by this activity.

The predicted  $\text{NO}_2$  concentrations are well below the lowest observed effects levels in animals (Newman and Schreiber, 1988). Given these conditions, the proposed source's emissions pose no risk to wildlife. Because predicted levels are below those known to cause effects to vegetation, there is also no risk.



**References**

Heck, W.W. and D.T. Tingey. 1979. Nitrogen Dioxide: Time-Concentration Model to Predict Acute Foliar Injury. EPA-600/3-79-057, U.S. Environmental Protection Agency, Corvallis, OR.

Matsumaru, T., T. Yoneyama, T. Totsuka, and K. Shiratori. 1979. Absorption of Atmospheric NO<sub>2</sub> by Plants and Soils. Soil Sci. Plant Nutr. 25:255-265.

Newman, J.R. and Schreiber. 1988. Air Pollution and Wildlife Toxicology. Environmental Toxicology and Chemistry 7:381-390.

U.S. Department of Agriculture. 1991. Surveys of Hernando and Citrus Counties, Florida. USDA Soil Conservation Service in cooperation with University of Florida, Institute of Food and Agricultural Sciences, Agricultural Experiment Stations, and Soil Science Department.

Zahn, R. 1975. Gassing Experiments with NO<sub>2</sub> in Small Greenhouses. Staub Reinhalt. Luft 35:194-196.

9. COMMENT: Section 4.3.1.2, page 4-10, states that "While the increased firing temperature increases the thermal NO<sub>x</sub> generated, this NO<sub>x</sub> increase is controlled through combustion design." How much additional thermal NO<sub>x</sub> is generated due to higher temperature?

RESPONSE: The increased thermal NO<sub>x</sub> emissions, due to the higher firing temperature of the advanced combustion turbine, is about 20 percent higher than a conventional turbine when firing natural gas (from Table 4-2, 150 ppmvd, conventional, compared to 179 ppmvd, advanced) and about 13 percent higher than a conventional turbine when firing oil (from Table 4-2, 245 ppmvd, conventional, compared to 276 ppmvd, advanced).

10. COMMENT: On page 4-3, the estimated cost of SCR is reported to be about \$7,400 per ton of NO<sub>x</sub> removed and it exceeds \$10,000 per ton of pollutant removed when the net emissions of all pollutants (exclusive of CO<sub>2</sub>) are considered. Provide us with the names and addresses of all manufacturers that were contacted while developing capital and annualized cost estimates for this project.

RESPONSE: The cost for SCR was obtained from a database developed by KBN from this and other projects. The manufacturers contacted were:

Steuler International Corporation  
P.O. Box 38  
Mertztown, PA 19539-0038  
215-682-7171

Hitachi Zosen U.S.A. Ltd.  
150 East 52 nd Street  
New York, NY 10022  
212-355-5650



Mitsubishi International Corporation  
2 Houston Center, Suite 3800  
Houston, TX 77010  
713-652-9200

W. R. Grace & Co.  
P.O. Box 2117  
Baltimore, MD 21203-2117  
410-659-9000

Norton Company  
P.O. Box 350  
Arkon, OH 44309-0350  
216-673-5860

11. COMMENT (via July 15, 1992, telephone conversation): Provide a large-scale site plan similar to Figure 2-2 of the air permit application.

RESPONSE: A full-scale revised plot plan is included in Attachment 5.

12. COMMENT (via July 15, 1992, telephone conversation): Please provide a diagram indicating the proposed location of the sample ports for source sampling purposes. Show these locations with respect to the proposed stack and HRSG unit.

RESPONSE: The stack sample port location is depicted in Figure 1. The sample port will be accessible by ladder from the top of the HRSG to a platform assembly near the port location.

Submittal of this information should clarify all questions raised by the Department in the completeness determination for this project. Please call me at 904-331-9000 if there are any further questions on the material submitted.

Sincerely,

A handwritten signature in cursive script that reads "Robert C. McCann Jr." with a flourish at the end.

Kennard F. Kosky, P.E.  
President

Enclosures  
KFK/dmm

cc: Mirza Baig, FDER  
Robert I. Taylor, Central Florida Power, L.P.  
Robert Chatham, Destec Engineering, Inc.  
File (2)

Table 1. Sulfur Content, Heat Content, and SO<sub>2</sub> Emission Factors for Natural Gas

Date	Sulfur Content (gr/100 cf)	Heat Content (Btu)	SO <sub>2</sub> Emission Factor (lb/10 <sup>6</sup> Btu)	SO <sub>2</sub> Emission Factor (lb/10 <sup>6</sup> cf)
2/6/90	0.30	1,031	0.00083	0.857
2/13/90	0.05	1,028	0.00014	0.143
2/20/90	0.35	1,025	0.00098	1.000
2/27/90	0.45	1,024	0.00126	1.286
3/6/90	0.45	1,025	0.00125	1.286
3/13/90	0.30	1,026	0.00084	0.857
3/20/90	0.35	1,026	0.00097	1.000
3/27/90	0.35	1,025	0.00098	1.000
4/3/90	0.60	1,026	0.00167	1.714
4/10/90	0.25	1,022	0.00070	0.714
4/17/90	0.40	1,026	0.00111	1.143
4/24/90	0.30	1,022	0.00084	0.857
5/1/90	0.40	1,020	0.00112	1.143
5/8/90	0.25	1,034	0.00069	0.714
5/15/90	0.20	1,023	0.00056	0.571
6/5/90	0.45	1,020	0.00126	1.286
6/12/90	0.40	1,018	0.00112	1.143
6/19/90	0.70	1,017	0.00197	2.000
6/26/90	0.45	1,019	0.00126	1.286
7/3/90	0.55	1,022	0.00154	1.571
7/10/90	0.35	1,022	0.00098	1.000
7/17/90	0.45	1,021	0.00126	1.286
7/30/90	0.30	1,021	0.00084	0.857
8/7/90	0.50	1,024	0.00140	1.429
8/14/90	0.45	1,022	0.00126	1.286
8/21/90	0.40	1,022	0.00112	1.143
8/28/90	0.70	1,022	0.00196	2.000
9/4/90	0.55	1,029	0.00153	1.571
9/11/90	0.40	1,025	0.00111	1.143
9/18/90	0.45	1,026	0.00125	1.286
9/25/90	0.40	1,026	0.00111	1.143
10/2/90	0.45	1,029	0.00125	1.286
10/9/90	0.45	1,025	0.00125	1.286
10/16/90	0.70	1,028	0.00195	2.000
10/28/90	0.80	1,024	0.00223	2.286
Average:	0.43	1,024	0.00119	1.216
Maximum:	0.80	1,034	0.00223	2.286
Minimum:	0.05	1,017	0.00014	0.143
Std. Dev.	0.15	4	0.00042	0.427

Source: Florida Gas Transmission Company, 1990.




Figure 1 TIGER BAY CONCEPTUAL DRAWING OF STACK AND ADJOINING STRUCTURE



**ATTACHMENT 1**

**MANUFACTURER'S DESIGN SPECIFICATIONS  
FOR THE COMBUSTION TURBINE**





# 1.1 ESTIMATED PERFORMANCE – PG7221(FA)

LOAD CONDITION		BASE	90%	80%	70%	60%
AMBIENT TEMP.	- Deg F	27	27	27	27	27
OUTPUT	- kW	170700.	153200.	135300.	119900.	101400.
HEAT RATE (LHV)	- Btu/kWh	9460.	9770.	10240.	10770.	11600.
HEAT CONS. (LHV) X10-6	- Btu/h	1614.8	1496.8	1385.5	1291.3	1176.2
EXHAUST FLOW X10-3	- lb/h	3582.0	3228.0	2958.0	2744.0	2521.0
EXHAUST TEMP	- Deg F.	1078.	1118.	1150.	1177.	1200.
EXHAUST ENERGY X10-6	- Btu/h	976.4	922.1	875.5	836.9	788.6
NOX	- ppmvd @ 15% O2	25.	25.	25.	25.	25.
NOX AS NO2	- lb/h	162	149.	138.	128.	116.
CO	- ppmvd	15.	*	*	*	*
CO	- lb/h	49.	*	*	*	*
UHC	- ppmvw	7.	*	*	*	*
UHC	- lb/h	14.	*	*	*	*
VOC	- ppmvw	1.4	*	*	*	*
VOC	- lb/h	2.8	*	*	*	*
PART	- lb/h	9.0	9.0	9.0	9.0	9.0
<b>EXHAUST ANALYSIS % VOL.</b>						
ARGON		0.90	0.90	0.90	0.90	0.90
NITROGEN		75.04	74.97	74.95	74.95	74.98
OXYGEN		12.71	12.52	12.46	12.46	12.56
CARBON DIOXIDE		3.74	3.83	3.85	3.85	3.81
WATER		7.61	7.78	7.84	7.84	7.75
<b>SITE CONDITIONS</b>						
ELEVATION	- ft	160				
SITE PRESSURE	- psia	14.62				
INLET LOSS	- in. Water	4				
EXHAUST LOSS	- in. Water	12				
RELATIVE HUMIDITY	- %	40				
FUEL TYPE	-	METHANE				
FUEL LHV	- Btu/lb	21515				
APPLICATION	-	317S HYDROGEN COOLED GENERATOR				
COMBUSTION SYSTEM	-	DRY LOW NOX II				

EMISSION INFORMATION BASED ON GE RECOMMENDED MEASUREMENT METHODS.  
 NO<sub>x</sub> EMISSIONS ARE CORRECTED TO 15% O<sub>2</sub> WITHOUT HEAT RATE CORRECTION AND ARE NOT CORRECTED TO ISO REFERENCE CONDITIONS PER 40CFR 60.335(a)(1)(i).  
 NO<sub>x</sub> LEVELS SHOWN WILL BE CONTROLLED BY ALGORITHMS WITHIN THE SPEEDTRONIC CONTROL SYSTEM.  
 COMPRESSOR BLEED HEAT IS USED FOR 70% AND 60% PART LOAD OPERATION.  
 APPROXIMATELY 10% OF THE VOC'S ARE NON-METHANE AND ETHANE.  
 \* DATA NOT AVAILABLE  
 IPS-8707  
 JPT 3/19/92



1.1 ESTIMATED PERFORMANCE – PG7221(FA)

LOAD CONDITION		BASE	90%	80%	70%	60%
AMBIENT TEMP.	- Deg F .	64	64	64	64	64
OUTPUT	- kW	151900.	136000.	124400.	106500.	89900.
HEAT RATE (LHV)	- Btu/kWh	9750.	10060.	10340.	11070.	11860.
HEAT CONS. (LHV) X10-6	- Btu/h	1481.0	1368.2	1286.3	1179.0	1066.2
EXHAUST FLOW X10-3	- lb/h	3322.0	3010.0	2810.0	2595.0	2413.0
EXHAUST TEMP	- Deg F.	1110.	1145.	1168.	1195.	1200.
EXHAUST ENERGY X10-6	- Btu/h	911.3	856.4	816.8	773.9	721.3
NOX	- ppmvd @ 15% O2	25.	25.	25.	25.	25.
NOX AS NO2	- lb/h	149	137.	129.	118.	107.
CO	- ppmvd	15.	*	*	*	*
CO	- lb/h	45.	*	*	*	*
UHC	- ppmvw	7.	*	*	*	*
UHC	- lb/h	13.	*	*	*	*
VOC	- ppmvw	1.4	*	*	*	*
VOC	- lb/h	2.6	*	*	*	*
PART	- lb/h	9.0	9.0	9.0	9.0	9.0
EXHAUST ANALYSIS % VOL.						
ARGON		0.89	0.89	0.88	0.88	0.89
NITROGEN		74.04	73.98	73.97	73.98	74.05
OXYGEN		12.56	12.41	12.35	12.41	12.62
CARBON DIOXIDE		3.68	3.75	3.78	3.75	3.65
WATER		8.83	8.97	9.02	8.98	8.79
SITE CONDITIONS						
ELEVATION	- ft.	160				
SITE PRESSURE	- psia	14.62				
INLET LOSS	- in. Water	4				
EXHAUST LOSS	- in. Water	12				
RELATIVE HUMIDITY	- %	78				
FUEL TYPE	-	METHANE				
FUEL LHV	- Btu/lb	21515				
APPLICATION	-	317S HYDROGEN COOLED GENERATOR				
COMBUSTION SYSTEM	-	DRY LOW NOX II				

EMISSION INFORMATION BASED ON GE RECOMMENDED MEASUREMENT METHODS.  
 NO<sub>x</sub> EMISSIONS ARE CORRECTED TO 15% O<sub>2</sub> WITHOUT HEAT RATE CORRECTION AND ARE NOT CORRECTED TO ISO REFERENCE CONDITIONS PER 40CFR 60.335(a)(1)(i).  
 NO<sub>x</sub> LEVELS SHOWN WILL BE CONTROLLED BY ALGORITHMS WITHIN THE SPEEDTRONIC CONTROL SYSTEM.

COMPRESSOR BLEED HEAT IS USED FOR 70% AND 60% PART LOAD OPERATION.  
 APPROXIMATELY 10% OF THE VOC'S ARE NON-METHANE AND ETHANE.

\* DATA NOT AVAILABLE

IPS-8707

JPT 3/19/92



# 1.1 ESTIMATED PERFORMANCE – PG7221(FA)

LOAD CONDITION		BASE	90%	80%	70%	60%
AMBIENT TEMP.	- Deg F	72	72	72	72	72
OUTPUT	- kW	147100.	131800.	120500.	103100.	86800.
HEAT RATE (LHV)	- Btu/kWh	9860.	10210.	10550.	11340.	12220.
HEAT CONS. (LHV) X10-6	- Btu/h	1450.4	1345.7	1271.3	1169.2	1060.7
EXHAUST FLOW X10-3	- lb/h	3262.0	2960.0	2768.0	2560.0	2383.0
EXHAUST TEMP	- Deg F.	1117.	1151.	1173.	1199.	1200.
EXHAUST ENERGY X10-6	- Btu/h	898.1	849.0	815.5	776.0	726.5
NOX	- ppmvd @ 15% O2	25.	25.	25.	25.	25.
NOX AS NO2	- lb/h	145	134.	126.	116.	105.
CO	- ppmvd	15.	*	*	*	*
CO	- lb/h	44.	*	*	*	*
UHC	- ppmvw	7.	*	*	*	*
UHC	- lb/h	13.	*	*	*	*
VOC	- ppmvw	1.4	*	*	*	*
VOC	- lb/h	2.6	*	*	*	*
PART	- lb/h	9.0	9.0	9.0	9.0	9.0
<b>EXHAUST ANALYSIS % VOL.</b>						
ARGON		0.89	0.88	0.89	0.87	0.88
NITROGEN		73.73	73.68	73.67	73.68	73.76
OXYGEN		12.51	12.37	12.32	12.39	12.63
CARBON DIOXIDE		3.66	3.73	3.75	3.72	3.61
WATER		9.21	9.34	9.38	9.34	9.12
<b>SITE CONDITIONS</b>						
ELEVATION	- ft	160				
SITE PRESSURE	- psia	14.62				
INLET LOSS	- in. Water	4				
EXHAUST LOSS	- in. Water	12				
RELATIVE HUMIDITY	- %	75				
FUEL TYPE	-	METHANE				
FUEL LHV	- Btu/lb	21515				
APPLICATION	-	317S HYDROGEN COOLED GENERATOR				
COMBUSTION SYSTEM	-	DRY LOW NOX II				

EMISSION INFORMATION BASED ON GE RECOMMENDED MEASUREMENT METHODS.  
 NO<sub>x</sub> EMISSIONS ARE CORRECTED TO 15% O<sub>2</sub> WITHOUT HEAT RATE CORRECTION AND ARE NOT CORRECTED TO ISO REFERENCE CONDITIONS PER 40CFR 60.335(a)(1)(i).  
 NO<sub>x</sub> LEVELS SHOWN WILL BE CONTROLLED BY ALGORITHMS WITHIN THE SPEEDTRONIC CONTROL SYSTEM.  
 COMPRESSOR BLEED HEAT IS USED FOR 70% AND 60% PART LOAD OPERATION.  
 APPROXIMATELY 10% OF THE VOC'S ARE NON-METHANE AND ETHANE.

\* DATA NOT AVAILABLE

IPS-8707  
 JPT 3/19/92



# 1.1 ESTIMATED PERFORMANCE – PG7221(FA)

LOAD CONDITION		BASE	90%	80%	70%	60%
AMBIENT TEMP.	- Deg F .	79	79	79	79	79
OUTPUT	- kW	142700.	127900.	116500.	99500.	83900.
HEAT RATE (LHV)	- Btu/kWh	9970.	10330.	10700.	11510.	12390.
HEAT CONS. (LHV) X10-6	- Btu/h	1422.7	1321.2	1246.6	1145.2	1039.5
EXHAUST FLOW X10-3	- lb/h	3202.0	2910.0	2725.0	2524.0	2352.0
EXHAUST TEMP	- Deg F.	1124.	1157.	1179.	1200.	1200.
EXHAUST ENERGY X10-6	- Btu/h	886.3	838.6	805.2	765.1	715.8
NOX	- ppmvd @ 15% O2	25.	25.	25.	25.	25.
NOX AS NO2	- lb/h	143	132.	124.	114.	103.
CO	- ppmvd	15.	*	*	*	*
CO	- lb/h	43.	*	*	*	*
UHC	- ppmvw	7.	*	*	*	*
UHC	- lb/h	13.	*	*	*	*
VOC	- ppmvw	1.4	*	*	*	*
VOC	- lb/h	2.6	*	*	*	*
PART	- lb/h	9.0	9.0	9.0	9.0	9.0
<b>EXHAUST ANALYSIS % VOL.</b>						
ARGON		0.87	0.88	0.87	0.88	0.87
NITROGEN		73.07	73.02	73.01	73.02	73.10
OXYGEN		12.36	12.22	12.19	12.28	12.52
CARBON DIOXIDE		3.65	3.71	3.73	3.68	3.58
WATER		10.05	10.17	10.20	10.14	9.93
<b>SITE CONDITIONS</b>						
ELEVATION	- ft.	160				
SITE PRESSURE	- psia	14.62				
INLET LOSS	- in. Water	4				
EXHAUST LOSS	- in. Water	12				
RELATIVE HUMIDITY	- %	86				
FUEL TYPE	-	METHANE				
FUEL LHV	- Btu/lb	21515				
APPLICATION	-	317S HYDROGEN COOLED GENERATOR				
COMBUSTION SYSTEM	-	DRY LOW NOX II				

EMISSION INFORMATION BASED ON GE RECOMMENDED MEASUREMENT METHODS.  
 NO<sub>x</sub> EMISSIONS ARE CORRECTED TO 15% O<sub>2</sub> WITHOUT HEAT RATE CORRECTION AND ARE NOT CORRECTED TO ISO REFERENCE CONDITIONS PER 40CFR 60.335(a)(1)(i).  
 NO<sub>x</sub> LEVELS SHOWN WILL BE CONTROLLED BY ALGORITHMS WITHIN THE SPEEDTRONIC CONTROL SYSTEM.  
 COMPRESSOR BLEED HEAT IS USED FOR 70 AND 60% PART LOAD OPERATION APPROXIMATELY 10% OF THE VOC'S ARE NON-METHANE AND ETHANE.  
 \* DATA NOT AVAILABLE  
 IPS-8707  
 JPT 3/19/92



# 1.1 ESTIMATED PERFORMANCE – PG7221(FA)

LOAD CONDITION		BASE	90%	80%	70%	60%
AMBIENT TEMP.	- Deg F	97	97	97	97	97
OUTPUT	- kW	131800.	118400.	106800.	90900.	77100.
HEAT RATE (LHV)	- Btu/kWh	10230.	10600.	11070.	11890.	12780.
HEAT CONS. (LHV) X10-6	- Btu/h	1348.3	1255.0	1182.3	1080.8	985.3
EXHAUST FLOW X10-3	- lb/h	3077.0	2808.0	2640.0	2454.0	2293.0
EXHAUST TEMP	- Deg F.	1140.	1170.	1190.	1200.	1200.
EXHAUST ENERGY X10-6	- Btu/h	851.5	807.0	776.1	732.0	686.5
NOX	- ppmvd @ 15% O2	25.	25.	25.	25.	25.
NOX AS NO2	- lb/h	135	125.	118.	107.	97.
CO	- ppmvd	15.	*	*	*	*
CO	- lb/h	41.	*	*	*	*
UHC	- ppmvw	7.	*	*	*	*
UHC	- lb/h	12.	*	*	*	*
VOC	- ppmvw	1.4	*	*	*	*
VOC	- lb/h	2.4	*	*	*	*
PART	- lb/h	9.0	9.0	9.0	9.0	9.0
EXHAUST ANALYSIS % VOL.						
ARGON		0.88	0.87	0.87	0.88	0.89
NITROGEN		73.13	73.09	73.10	73.13	73.20
OXYGEN		12.48	12.36	12.37	12.52	12.74
CARBON DIOXIDE		3.60	3.66	3.65	3.58	3.48
WATER		9.91	10.02	10.01	9.89	9.70
SITE CONDITIONS						
ELEVATION	- ft	160				
SITE PRESSURE	- psia	14.62				
INLET LOSS	- in. Water	4				
EXHAUST LOSS	- in. Water	12				
RELATIVE HUMIDITY	- %	48				
FUEL TYPE	-	METHANE				
FUEL LHV	- Btu/lb	21515				
APPLICATION	-	317S HYDROGEN COOLED GENERATOR				
COMBUSTION SYSTEM	-	DRY LOW NOX II				

EMISSION INFORMATION BASED ON GE RECOMMENDED MEASUREMENT METHODS.  
 NO<sub>x</sub> EMISSIONS ARE CORRECTED TO 15% O<sub>2</sub> WITHOUT HEAT RATE CORRECTION AND ARE NOT CORRECTED TO ISO REFERENCE CONDITIONS PER 40CFR 60.335(a)(1)(i).  
 NO<sub>x</sub> LEVELS SHOWN WILL BE CONTROLLED BY ALGORITHMS WITHIN THE SPEEDTRONIC CONTROL SYSTEM.  
 COMPRESSOR BLEED HEAT IS USED FOR 70% AND 60% PART LOAD OPERATION. APPROXIMATELY 10% OF THE VOC'S ARE NON-METHANE AND ETHANE.

\* DATA NOT AVAILABLE

IPS-8707  
 JPT 3/19/92

05/06/1992 14:36 FROM GE-TURBINE TECHNOLOGY DPT TO

55128 P.02

DESTEC - GATOR COGEN  
\*\*\*\*\*

ESTIMATED PERFORMANCE - PG7221(FA)

LOAD CONDITION		BASE	70%
AMBIENT TEMP.	- Deg F.	27	27
OUTPUT	- kW	183700.	129200.
HEAT RATE (LHV)	- Btu/kWh	10070.	11430.
HEAT RATE (HHV)	- Btu/kWh	10674.	12115.
HEAT CONS. (LHV) X10-6	- Btu/h	1849.9	1476.8
EXHAUST FLOW X10-3	- lb/h	3743.0	2837.0
EXHAUST TEMP	- Deg F.	1060.	1166.
EXHAUST HEAT X10-6	- Btu/h	1021.8	876.8
WATER FLOW	- lb/h	135390.	105120.

NOX	- ppmvd @ 15% O2	42.	42.
NOX AS NO2	- lb/h	327.	258.
CO	- ppmvd	30.	*
CO	- lb/h	98.	*
UHC	- ppmvv	7.	*
UHC	- lb/h	15.	*
VOC	- ppmvv	3.5	*
VOC	- lb/h	7.5	*
SO2	- ppmvv	11.	12.
SO2	- lb/h	95.	76.
SO3	- ppmvv	1.	1.
SO3	- lb/h	6.	5.
SULFUR MIST	- lb/h	10.	8.
PART	- lb/h	17.0	17.0

EXHAUST ANALYSIS % VOL.

ARGON	0.86	0.85
NITROGEN	71.27	71.08
OXYGEN	10.96	10.57
CARBON DIOXIDE	5.32	5.54
WATER	11.59	11.96

SITE CONDITIONS

\*\*\*\*\*

ELEVATION	- ft.	160
SITE PRESSURE	- psia	14.62
INLET LOSS	- in. Water	4
EXHAUST LOSS	- in. Water	12
RELATIVE HUMIDITY	- %	40
FUEL TYPE	-	DISTILLATE
FUEL LHV	- Btu/lb	18550
APPLICATION	-	317S HYDROGEN COOLED GENERATOR
COMBUSTION SYSTEM	-	DRY LOW NOX II

EMISSION INFORMATION BASED ON GE RECOMMENDED MEASUREMENT METHODS.

NOx EMISSIONS ARE CORRECTED TO 15% O2 WITHOUT HEAT RATE CORRECTION AND ARE NOT CORRECTED TO ISO REFERENCE CONDITIONS PER 40CFR 60.335(a)(1)(i).

NOx LEVELS SHOWN WILL BE CONTROLLED BY ALGORITHMS WITHIN THE

SPEEDTRONIC CONTROL SYSTEM.

DISTILLATE FUEL IS ASSUMED TO HAVE .015% FUEL BOUND NITROGEN, OR LESS.

PM AMOUNTS GREATER THAN .015% WILL ADD TO THE REPORTED NOx VALUE.

SULFUR EMISSIONS BASED ON .05 WT% SULFUR CONTENT IN THE FUEL.

P.O. BOX 4411

DATA NOT AVAILABLE  
FOR THIS UNIT  
DURING THIS PERIOD

GENERATOR HEAT USED FOR PART LOAD OPERATION.

SULFUR EMISSIONS ARE BASED ON A TOTAL FUEL SULFUR CONTENT OF 0.0015%.

IPS-8707  
10/19/92



### 1.1 ESTIMATED PERFORMANCE - PG7221(FA)

LOAD CONDITION		BASE	70%
AMBIENT TEMP.	- Deg F.	72	72
OUTPUT	- kW	159200.	111000.
HEAT RATE (LHV)	- Btu/kWh	10320.	11800.
HEAT CONS. (LHV) X10-6	- Btu/h	1642.9	1309.8
EXHAUST FLOW X10-3	- lb/h	3390.0	2619.0
EXHAUST TEMP	- Deg F.	1102.	1192.
EXHAUST HEAT X10-6	- Btu/h	932.2	801.6
WATER FLOW	- lb/h	107070.	80490.

NOX	- ppmvd @ 15% O2	42.	42.
NOX AS NO2	- lb/h	290.	229.
CO	- ppmvd	30.	*
CO	- lb/h	89.	*
UHC	- ppmvw	7.	*
UHC	- lb/h	13.	*
VOC	- ppmvw	3.5	*
VOC	- lb/h	6.5	*
PART	- lb/h	17.0	17.0

#### EXHAUST ANALYSIS % VOL.

ARGON	0.86	0.86
NITROGEN	70.59	70.63
OXYGEN	10.95	10.81
CARBON DIOXIDE	5.21	5.31
WATER	12.40	12.40

#### SITE CONDITIONS

ELEVATION	- ft.	100
SITE PRESSURE	- psia	14.62
INLET LOSS	- in. Water	4
EXHAUST LOSS	- in. Water	12
RELATIVE HUMIDITY	- %	75
FUEL TYPE	-	DISTILLATE
FUEL LHV	- Btu/lb	18550
APPLICATION	-	317S HYDROGEN COOLED GENERATOR
COMBUSTION SYSTEM	-	DRY LOW NOX II

EMISSION INFORMATION BASED ON GE RECOMMENDED MEASUREMENT METHODS.  
 NOx EMISSIONS ARE CORRECTED TO 15% O2 WITHOUT HEAT RATE CORRECTION AND ARE NOT CORRECTED TO ISO REFERENCE CONDITIONS PER 40CFR 60.333(a)(1)(D).  
 NOx LEVELS SHOWN WILL BE CONTROLLED BY ALGORITHMS WITHIN THE SPEEDTRONIC CONTROL SYSTEM.

DISTILLATE FUEL IS ASSUMED TO HAVE 0.015% FUEL BOUND NITROGEN, OR LESS. FUEL BOUND NITROGEN AMOUNTS GREATER THAN 0.015% WILL ADD TO THE REPORTED NOx VALUE.

\* DATA NOT AVAILABLE

COMPRESSOR BLEED HEAT IS USED FOR PART LOAD OPERATION.

IPS-8707

JPT 4/14/92



# 1.1 ESTIMATED PERFORMANCE – PG7221(FA)

LOAD CONDITION		BASE	70%
AMBIENT TEMP.	-- Deg F.	97	97
OUTPUT	-- kW	142500.	98500.
HEAT RATE (LHV)	-- Btu/kWh	10650.	12280.
HEAT CGNS. (LHV) X10-6	-- Btu/h	1517.6	1209.6
EXHAUST FLOW X10-3	-- lb/h	3189.0	2510.0
EXHAUST TEMP	-- Deg F.	1127.	1200.
EXHAUST HEAT X10-6	-- Btu/h	881.7	758.7
WATER FLOW	-- lb/h	92890.	68760.

NOX	-- ppmvd @ 15% O2	42.	42.
NOX AS NO2	-- lb/h	268.	211.
CO	-- ppmvd	30.	*
CO	-- lb/h	83.	*
UHC	-- ppmvw	7.	*
UHC	-- lb/h	13.	*
VOC	-- ppmvw	3.5	*
VOC	-- lb/h	6.5	*
PART	-- lb/h	17.0	17.0

### EXHAUST ANALYSIS % VOL.

ARGON	0.85	0.85
NITROGEN	70.31	70.49
OXYGEN	11.03	11.07
CARBON DIOXIDE	5.11	5.11
WATER	12.71	12.48

### SITE CONDITIONS

ELEVATION	-- ft	160
SITE PRESSURE	-- psia	14.62
INLET LOSS	-- in. Water	4
EXHAUST LOSS	-- in. Water	12
RELATIVE HUMIDITY	-- %	48
FUEL TYPE	--	DISTILLATE
FUEL LHV	-- Btu/lb	18550
APPLICATION	--	317S HYDROGEN COOLED GENERATOR
COMBUSTION SYSTEM	--	DRY LOW NOX II

EMISSION INFORMATION BASED ON GE RECOMMENDED MEASUREMENT METHODS.  
 NOx EMISSIONS ARE CORRECTED TO 15% O2 WITHOUT HEAT RATE CORRECTION AND ARE NOT CORRECTED TO ISO REFERENCE CONDITIONS PER 40CFR 60.335(a)(1)(i).  
 NOx LEVELS SHOWN WILL BE CONTROLLED BY ALGORITHMS WITHIN THE SPEEDTRONIC CONTROL SYSTEM.

DISTILLATE FUEL IS ASSUMED TO HAVE 0.015% FUEL BOUND NITROGEN, OR LESS.  
 FUEL BOUND NITROGEN AMOUNTS GREATER THAN 0.015% WILL ADD TO THE REPORTED NOx VALUE.

\* DATA NOT AVAILABLE

COMPRESSOR BLEED HEAT IS USED FOR PART LOAD OPERATION.

IPS-8707

IPT 4/14/92



SENT BY: DESTEC ENGINEERING ; 8-26-92 ; 13:45 ;  
 AUG-19-1992 11:07 FROM WESTINGHOUSE

7137354092-

9043324189

# 2

DESTEC ENGINEERING - USER SAT PRODUCE  
 DRY LOW NOx COMBUSTOR  
 EXPECTED 501F COMBUSTION TURBINE PERFORMANCE AND EMISSIONS

Rev. 2  
 8/18/92

SITE CONDITIONS:

	GAS	GAS	GAS	GAS	GAS
	BASE	BASE	BASE	BASE	BASE
FUEL TYPE					
LOAD LEVEL					
FUEL HEATING VALUE, BTU/LB LHV	20900	20900	20900	20900	20900
FUEL HEATING VALUE, BTU/LB HHV	23200	23200	23200	23200	23200
AMBIENT TEMPERATURE, F	27	64	72	79	97
RELATIVE HUMIDITY	40	78	75	75	48
BAROMETRIC PRESSURE, PSIA	14.815	14.815	14.815	14.815	14.815
INLET PRESSURE LOSS, IN-WATER	4.0	3.7	3.6	3.3	3.4
EXHAUST PRESSURE LOSS, IN-WATER	11.0	9.6	9.3	9.0	8.4
INJECTION FLUID	NONE	NONE	NONE	NONE	NONE
INJECTION RATIO, LB/LB	0	0	0	0	0
GENERATOR POWER FACTOR	0.85	0.85	0.85	0.85	0.85
GENERATOR HYDROGEN PRESSURE, PSIA	30	30	30	30	30
GENERATOR FRAME (97 X 114)					

COMBUSTION TURBINE PERFORMANCE:

NET POWER OUTPUT, KW	169210	147950	143450	139560	128370
HEAT RATE, BTU/KWH LHV	9490	9900	10000	10100	10360
HEAT RATE, BTU/KWH HHV	10530	10990	11100	11210	11500
EXHAUST FLOW, LB/HR	3702540	3431310	3369010	3311770	3180510
EXHAUST TEMPERATURE, F	1063	1036	1032	1038	1111
FUEL FLOW, LB/HR	76830	70080	68640	67440	64130
INJECTION RATE, LB/HR	0	0	0	0	0
AUXILIARY LOAD, KW	400	400	400	400	400
HEAT INPUT, MMBTU/HR (LHV)	1608	1465	1435	1409	1340
HEAT INPUT, MMBTU/HR (HHV)	1782	1626	1592	1565	1488
EXHAUST ENERGY, MMBTU/HR	1053.5	1004.8	994.1	985.4	959.0

EXHAUST GAS COMPOSITION (BY PCT VOL):

OXYGEN	13.08	12.97	12.91	12.82	12.84
CARBON DIOXIDE	3.61	3.53	3.52	3.51	3.47
WATER	7.26	8.45	8.82	9.32	9.56
NITROGEN	75.09	74.11	73.81	73.41	73.20
ARGON	0.94	0.93	0.93	0.92	0.92
MOLECULAR WEIGHT	28.50	28.38	28.32	28.26	28.23

EMISSIONS

NOx, PPMVD @ 15% O2	25	25	25	25	25
NOx, LB/HR	163	148	145	143	136
CO, PPMVD	10	10	10	10	10
CO, LB/HR	35	32	31	31	29
SO2, PPMVD	1	1	1	1	1
SO2, LB/HR	2	1	1	1	1
TOTAL UHC, PPMVD	8	8	8	8	8
TOTAL UHC, LB/HR	16	15	14	14	13
VOC, PPMVD	4	4	4	4	4
VOC, LB/HR	8	7	7	7	7
PARTICULATES (PM10/TSP), LB/HR (TOTAL)	6.6	6.1	6.0	5.9	5.7
SOOT, LB/HR	6.3	6.0	5.8	5.7	5.5
ASH, LB/HR	0.0	0.0	0.0	0.0	0.0
H2SO4 MIST, LB/HR	0.2	0.2	0.2	0.2	0.2
CO2, PPMVD	40055	39729	39758	39894	39524
CO2, LB/HR	212418	193677	189813	186588	177228
OPACITY, %	<=10	<=10	<=10	<=10	<=10

NOTES:

1. The net power output is the power at the generator terminals minus turbine auxiliary loads.
2. The fuel composition for natural gas is per customer's specification.
3. Exhaust energy is referenced to 400 degrees Rankine.

SITE CONDITIONS:

	GAS	GAS	GAS	GA3	GAS
FUEL TYPE					
LOAD LEVEL	70%	70%	70%	70%	70%
FUEL HEATING VALUE, BTU/LB LHV	20900	20900	20900	20900	20900
FUEL HEATING VALUE, BTU/LB HHV	23200	23200	23200	23200	23200
AMBIENT TEMPERATURE, F	27	64	72	79	97
RELATIVE HUMIDITY	40	70	75	75	48
BAROMETRIC PRESSURE, PSIA	14.615	14.615	14.615	14.615	14.615
INLET PRESSURE LOSS, IN-WATER	2.3	2.3	2.3	2.3	2.2
EXHAUST PRESSURE LOSS, IN-WATER	6.7	6.1	5.9	5.8	5.5
INJECTION FLUID	NONE	NONE	NONE	NONE	NONE
INJECTION RATIO, LB/LB	0	0	0	0	0
GENERATOR POWER FACTOR	0.85	0.85	0.85	0.85	0.85
GENERATOR HYDROGEN PRESSURE, PSIA	30	30	30	30	30
GENERATOR FRAME (97 X 114)					

COMBUSTION TURBINE PERFORMANCE:

NET POWER OUTPUT, KW	118330	103390	100210	97490	90340
HEAT RATE, BTU/KWH LHV	10490	11020	11150	11270	11600
HEAT RATE, BTU/KWH HHV	11650	12230	12370	12510	12680
EXHAUST FLOW, LB/HR	2754000	2678720	2647790	2619850	2554960
EXHAUST TEMPERATURE, F	1130	1130	1130	1130	1130
FUEL FLOW, LB/HR	59390	54520	53460	52570	50140
INJECTION RATE, LB/HR	0	0	0	0	0
AUXILIARY LOAD, KW	400	400	400	400	400
HEAT INPUT, MMBTU/HR (LHV)	1241	1139	1117	1099	1048
HEAT INPUT, MMBTU/HR (HHV)	1378	1265	1240	1220	1163
EXHAUST ENERGY, MMBTU/HR	634.4	616.3	608.4	601.9	582.8

EXHAUST GAS COMPOSITION (BY PCT VOL):

OXYGEN	13.04	13.10	13.09	13.04	13.15
CARBON DIOXIDE	3.62	3.47	3.44	3.41	3.33
WATER	7.30	6.32	6.66	9.12	9.29
NITROGEN	75.08	74.18	73.87	73.50	73.30
ARGON	0.94	0.93	0.93	0.92	0.92
MOLECULAR WEIGHT	28.49	28.37	28.33	28.28	28.25

EMISSIONS

NOx, PPMVD @ 15% O2	25	25	25	25	25
NOx, LB/HR	121	113	111	109	104
CO, PPMVD	10	10	10	10	10
CO, LB/HR	26	25	25	24	24
SO2, PPMVD	1	1	1	1	1
SO2, LB/HR	1	1	1	1	1
TOTAL UHC, PPMVD	8	8	8	6	6
TOTAL UHC, LB/HR	12	11	11	11	11
VOC, PPMVD	4	4	4	4	4
VOC, LB/HR	6	6	6	6	5
PARTICULATES (PM10/TSP), LB/HR (TOTAL)	4.9	4.8	4.7	4.7	4.6
SOOT, LB/HR	4.7	4.6	4.6	4.5	4.4
ASH, LB/HR	0.0	0.0	0.0	0.0	0.0
H2SO4 MIST, LB/HR	0.2	0.2	0.2	0.2	0.2
CO2, PPMVD	40247	39014	38766	38626	37815
CO2, LB/HR	158710	148643	145662	143145	136547
OPACITY, %	<=10	<=10	<=10	<=10	<=10

NOTES:

1. The net power output is the power at the generator terminals minus turbine auxiliary loads.
2. The fuel composition for natural gas is per customer's specification.
3. Exhaust energy is referenced to 400 degrees Rankine.
4. Part loads are achieved by modulating igns.

SITE CONDITIONS:

	OIL	OIL	OIL
	PART	BASE	BASE
FUEL TYPE			
LOAD LEVEL			
FUEL HEATING VALUE, BTU/LB LHV	18450	18450	18450
FUEL HEATING VALUE, BTU/LB HHV	19680	19680	19680
AMBIENT TEMPERATURE, F	27	72	97
RELATIVE HUMIDITY	40	75	48
BAROMETRIC PRESSURE, PSIA	14.615	14.615	14.615
INLET PRESSURE LOSS, IN-WATER	3.5	3.8	3.6
EXHAUST PRESSURE LOSS, IN-WATER	10.3	10.0	9.0
INJECTION FLUID	STEAM	STEAM	STEAM
INJECTION RATIO, LB/LB	1.5	1.5	1.5
GENERATOR POWER FACTOR	0.85	0.85	0.85
GENERATOR HYDROGEN PRESSURE, PSIA	30	30	30
GENERATOR FRAME (97 X 114)			

COMBUSTION TURBINE PERFORMANCE:

NET POWER OUTPUT, KW	171970	162330	147180
HEAT RATE, BTU/KWH LHV	9280	9560	9850
HEAT RATE, BTU/KWH HHV	9900	10190	10510
EXHAUST FLOW, LB/HR	3502180	3509380	3311800
EXHAUST TEMPERATURE, F	1104	1104	1121
FUEL FLOW, LB/HR	86500	84110	78580
INJECTION RATE, LB/HR	129750	128170	117870
AUXILIARY LOAD, KW	600	600	600
HEAT INPUT, MMBTU/HR (LHV)	1596	1552	1450
HEAT INPUT, MMBTU/HR (HHV)	1702	1655	1548
EXHAUST ENERGY, MMBTU/HR	1054.5	1064.2	1024.3

EXHAUST GAS COMPOSITION (BY PCT VOL):

OXYGEN	11.92	11.88	11.83
CARBON DIOXIDE	5.00	4.83	4.76
WATER	10.60	11.91	12.57
NITROGEN	71.56	70.47	69.94
ARGON	0.90	0.89	0.88
MOLECULAR WEIGHT	28.33	28.17	28.08

EMISSIONS

NOx, PPMVD @ 15% O2	42	42	42
NOx, LB/HR	279	271	253
CO, PPMVD	50	50	50
CO, LB/HR	159	158	149
SO2, PPMVD	13	12	12
SO2, LB/HR	89	87	81
TOTAL UHC, PPMVD	20	20	20
TOTAL UHC, LB/HR	35	38	34
VOC, PPMVD	10	10	10
VOC, LB/HR	18	18	17
PARTICULATES (PM10/TSP), LB/HR (TOTAL)	39.6	39.0	36.7
SOOT, LB/HR	16.6	16.7	15.8
ASH, LB/HR	8.9	8.7	8.1
H2SO4 MIST, LB/HR	14.1	13.7	12.6
CO2, PPMVD	57653	56431	56099
CO2, LB/HR	280388	272545	254472
OPACITY, %	<=20	<=20	<=20

NOTES:

1. The net power output is the power at the generator terminals minus turbine auxiliary loads.
2. The fuel composition for distillate oil is per customer's specification.
3. Exhaust energy is referenced to 400 degrees Rankine.
4. Part loads are achieved by modulating lqvs.
5. Power output at 27 deg. F is limited to 172 MW.

DESTEC ENGINEERING - TIGER BAY PROJECT  
 DRY LOW NOx COMBUSTOR  
 EXPECTED 501F COMBUSTION TURBINE PERFORMANCE AND EMISSIONS

SITE CONDITIONS:

	OIL	OIL	OIL
FUEL TYPE	70%	70%	70%
LOAD LEVEL	18450	18450	18450
FUEL HEATING VALUE, BTU/LB LHV	19680	19680	19680
FUEL HEATING VALUE, BTU/LB HHV			
AMBIENT TEMPERATURE, F	27	72	97
RELATIVE HUMIDITY	40	75	48
BAROMETRIC PRESSURE, PSIA	14.615	14.615	14.615
INLET PRESSURE LOSS, IN-WATER	2.3	2.3	2.2
EXHAUST PRESSURE LOSS, IN-WATER	7.2	8.4	5.9
INJECTION FLUID	STEAM	STEAM	STEAM
INJECTION RATIO, LB/LB	1.5	1.5	1.5
GENERATOR POWER FACTOR	0.85	0.85	0.85
GENERATOR HYDROGEN PRESSURE, PSIA	30	30	30
GENERATOR FRAME (97 X 114)			

COMBUSTION TURBINE PERFORMANCE:

NET POWER OUTPUT, KW	133020	113400	102810
HEAT RATE, BTU/KWH LHV	9770	10310	10680
HEAT RATE, BTU/KWH HHV	10420	10890	11380
EXHAUST FLOW, LB/HR	2934960	2757580	2662180
EXHAUST TEMPERATURE, F	1130	1130	1130
FUEL FLOW, LB/HR	70440	63370	59510
INJECTION RATE, LB/HR	105660	95060	89270
AUXILIARY LOAD, KW	600	600	600
HEAT INPUT, MMBTU/HR (LHV)	1300	1169	1098
HEAT INPUT, MMBTU/HR (HHV)	1388	1247	1171
EXHAUST ENERGY, MMBTU/HR	904.4	855.3	828.0

EXHAUST GAS COMPOSITION (BY PCT VOL):

OXYGEN	12.08	12.17	12.26
CARBON DIOXIDE	4.91	4.67	4.53
WATER	10.43	11.58	12.09
NITROGEN	71.65	70.68	70.23
ARGON	0.90	0.88	0.88
MOLECULAR WEIGHT	28.34	28.19	28.12

EMISSIONS

NOx, PPMVD @ 15% O2	42	42	42
NOx, LB/HR	229	205	193
CO, PPMVD	50	50	50
CO, LB/HR	134	125	120
SO2, PPMVD	12	12	12
SO2, LB/HR	73	65	61
TOTAL UHC, PPMVD	20	20	20
TOTAL UHC, LB/HR	31	29	27
VOC, PPMVD	10	10	10
VOC, LB/HR	15	14	14
PARTICULATES (PM10/TSP), LB/HR (TOTAL)	32.6	30.0	28.5
SCOT, LB/HR	13.9	13.1	12.7
ASH, LB/HR	7.3	6.5	6.1
H2SO4 MIST, LB/HR	11.4	10.3	9.7
CO2, PPMVD	56460	54374	53041
CO2, LB/HR	230464	206946	194263
OPACITY, %	<=20	<=20	<=20

NOTES:

1. The net power output is the power at the generator terminals minus turbine auxiliary loads.
2. The fuel composition for distillate oil is per customer's specification.
3. Exhaust energy is referenced to 400 degrees Rankine.
4. Part loads are achieved by modulating igns.

**ATTACHMENT 2**

**FLORIDA GAS TRANSMISSION  
NATURAL GAS SAMPLE ANALYSES**

ANALYSIS

DATE: 04/28/92 ANALYSIS TIME: 345 STREAM SEQUENCE: 12  
 TIME: 11:22 CYCLE TIME: 360 STREAM#: 2  
 ANALYZER#: 1 MODE: RUN CYCLE START TIME: 11:16

COMP NAME	COMP CODE	MOLE %	GAL/MCF**	B.T.U.*	SP. GR.
HEXANE +	151	0.022	0.0096	1.13	0.000
PROPANE	152	0.162	0.0446	4.08	0.002
I-BUTANE	153	7892.15-6	0.0026	0.26	0.000
N-BUTANE	154	7528.58-6	0.0024	0.25	0.000
IPENTANE	155	4220.48-6	0.0015	0.17	0.000
NPENTANE	156	4062.01-6	0.0015	0.16	0.000
NITROGEN	157	0.418	0.0000	0.00	0.004
METHANE	158	96.588	0.0000	977.78	0.5349 0.538
CO2	159	0.804	0.0000	0.00	0.012
ETHANE	160	1.982	0.5302	35.15	0.020
TOTALS		100.000	0.5923	1018.97	0.579

\* @ 14.730 PSIA DRY & UNCORRECTED FOR COMPRESSIBILITY

\*\* @ 14.730 & 60 DEG. F

COMPRESSIBILITY FACTOR (1/Z) = 1.0021  
 DRY B.T.U. @ 14.730 PSIA & 60 DEG. F CORRECTED FOR (1/Z) = 1021.1  
 SAT B.T.U. @ 14.730 PSIA & 60 DEG. F CORRECTED FOR (1/Z) = 1003.3  
 REAL SPECIFIC GRAVITY = 0.5764  
 UNNORMALIZED TOTAL = 99.86

ACTIVE ALARMS

NONE

COMM  
 1041.8 / 0.5939  
 1041.9 @ 0.5939  
 → TOTAL SULFUR 0.35 G/G H<sub>2</sub>S 0.05 G/GCF  
 0.8 *Bill Johnson*

ANALYSIS

DATE: 05/03/92 ANALYSIS TIME: 345 STREAM SEQUENCE: 12  
 TIME: 11:25 CYCLE TIME: 360 ~~STREAM# 11112~~  
 ANALYZER# ~~11111~~ MODE: RUN CYCLE START TIME: 11:19

COMP NAME	COMP CODE	MOLE %	GAL/MCF**	B.T.U.*	SP. GR.
HEXANE +	151	0.024	0.0106	1.25	0.000
PROPANE	152	0.172	0.0474	4.34	0.000
I-BUTANE	153	9949.88-6	0.0033	0.32	0.000
N-BUTANE	154	7610.23-6	0.0024	0.25	0.000
IPENTANE	155	3393.25-6	0.0012	0.14	0.000
NPENTANE	156	2694.51-6	0.0010	0.11	0.000
NITROGEN	157	0.348	0.0000	0.00	0.000
METHANE	158	96.786	0.0000	979.77	0.530
CO2	159	0.726	0.0000	0.00	0.010
ETHANE	160	1.919	0.5134	34.04	0.010
TOTALS		100.000	0.5793	1020.22	0.570

\* @ 14.730 PSIA DRY & UNCORRECTED FOR COMPRESSIBILITY

\*\* @ 14.730 & 60 DEG. F

COMPRESSIBILITY FACTOR (1/Z) = 1.0021  
 DRY B.T.U. @ 14.730 PSIA & 60 DEG. F CORRECTED FOR (1/Z) = 1022.4  
 SAT B.T.U. @ 14.730 PSIA & 60 DEG. F CORRECTED FOR (1/Z) = 1004.6  
 REAL SPECIFIC GRAVITY = 0.5752  
 UNNORMALIZED TOTAL = 99.80

ACTIVE ALARMS

NONE

FLORIDA GAS TRANSMISSION CO.

21558 LAB - COMM

1041.8 / 0.5939

1041.9 " " 0.5939

→ TOTAL SULFUR 0.30 GR/1000 H<sub>2</sub>S 0.00 GR/1000

1.0 " " Bill Benson

ANALYSIS

DATE: 05/12/92  
 TIME: 12:17  
 ANALYZER#: 1

ANALYSIS TIME: 345  
 CYCLE TIME: 360  
 MODE: RUN

STREAM SEQUENCE: 12  
 STREAM#: 2  
 CYCLE START TIME: 12:11

COMP NAME	COMP CODE	MOLE %	GAL/MCF**	B.T.U.*	SP. GR.*
HEXANE +	151	0.021	0.0090	1.06	0.0007
PROPANE	152	0.177	0.0487	4.46	0.0027
I-BUTANE	153	0.014	0.0045	0.45	0.0003
N-BUTANE	154	0.012	0.0039	0.41	0.0003
IPENTANE	155	5825.91-6	0.0021	0.23	0.0001
NPENTANE	156	3664.47-6	0.0013	0.15	0.0001
NITROGEN	157	0.398	0.0000	0.00	0.0038
METHANE	158	96.669	0.0000	978.59	0.5355
CO2	159	0.748	0.0000	0.00	0.0114
ETHANE	160	1.952	0.5221	34.62	0.0203
TOTALS		100.000	0.5916	1019.95	0.5750

\* @ 14.730 PSIA DRY & UNCORRECTED FOR COMPRESSIBILITY

\*\* @ 14.730 & 60 DEG. F

COMPRESSIBILITY FACTOR (1/Z) = 1.0021  
 DRY B.T.U. @ 14.730 PSIA & 60 DEG. F CORRECTED FOR (1/Z) = 1022.1  
 SAT B.T.U. @ 14.730 PSIA & 60 DEG. F CORRECTED FOR (1/Z) = 1004.3  
 REAL SPECIFIC GRAVITY = 0.5760  
 UNNORMALIZED TOTAL = 99.62

ACTIVE ALARMS

NONE

*Comm.*  
 1041.8 / 0.5939  
 1041.9 / 0.5938  
 → ~~Force Sample 0.35 GPM / CF~~ H.S. QOS: 0.9 / CF  
 1.1 *Bill Stinson*



ANALYSIS

DATE: 05/19/92  
 TIME: 13:02  
 ANALYZER# 1

ANALYSIS TIME: 345  
 CYCLE TIME: 360  
 MODE: RUN

STREAM SEQUENCE: 12  
~~STREAM# 2~~  
 CYCLE START TIME: 12:56

COMP NAME	COMP CODE	MOLE %	GAL/MCF**	B.T.U.*	SP. GR.*
HEXANE +	151	0.024	0.0105	1.24	0.0008
PROPANE	152	0.189	0.0521	4.77	0.0029
I-BUTANE	153	0.015	0.0048	0.47	0.0003
N-BUTANE	154	0.012	0.0038	0.39	0.0002
IPENTANE	155	4932.21-6	0.0018	0.20	0.0001
NPENTANE	156	3461.10-6	0.0013	0.14	0.0001
NITROGEN	157	0.405	0.0000	0.00	0.0039
METHANE	158	96.505	0.0000	976.92	0.5345
CO2	159	0.725	0.0000	0.00	0.0110
ETHANE	160	2.117	0.5662	37.54	0.0220
TOTALS		100.000	0.6404	1021.68	0.5758

\* @ 14.730 PSIA DRY & UNCORRECTED FOR COMPRESSIBILITY

\*\* @ 14.730 & 60 DEG. F

COMPRESSIBILITY FACTOR (1/Z) = 1.0021  
 DRY B.T.U. @ 14.730 PSIA & 60 DEG. F CORRECTED FOR (1/Z) = 1023.8  
 SAT B.T.U. @ 14.730 PSIA & 60 DEG. F CORRECTED FOR (1/Z) = 1006.0  
 REAL SPECIFIC GRAVITY = 0.5768  
 UNNORMALIZED TOTAL = 99.83

ACTIVE ALARMS

NONE

FLORIDA GAS TRANSMISSION CO.

BROOKER LAB- Comm.

STANDARD GAS 1041.8 / 0.5939

CERTIFIED VALUE BTU 1041.9 GRAI. 0.5939


→ TOTAL SULFUR 0.30 GR/CCF H<sup>2</sup>S 0.05 GR/CCF

H<sup>2</sup>O 1.1 #/MMCF BY Bill Johnson

**ATTACHMENT 3**

**PROCESS FLOW DIAGRAMS  
FOR THE COMBUSTION TURBINE  
FIRING NATURAL GAS AND OIL**

DESTEC CONFIDENTIAL  
 This drawing is the property of DESTEC Engineering, Inc. Neither this drawing nor reproductions of it  
 nor information contained hereon should be divulged to others without the express written consent of DESTEC  
 Engineering, Inc. No use is to be made of it which is, or may be, injurious to DESTEC Engineering, Inc.



TOTAL FUEL - 1737 X MM BTU/HR  
 PLANT GROSS POWER - 236 330 KW

NO.	DATE	REVISION	BY	APPV.	SCALE :	NONE	
					CALC.	TCE	DATE 8-25-92
					DWN.	RDP	DATE 8-25-92
					CHK.		DATE
					APPV.		DATE

**W501F  
FLOW DIAGRAM  
CASE: AVG AMB OIL FIRED**


PROJECT NO: 1253

CLIENT: TIGER BAY COGEN

DWG. NO: 1253-M-017.01

REV. 0

DWG NO. 062392



TOTAL FUEL - 1702 X MM BTU/HR  
 PLANT GROSS POWER - 239 936 KW

**LEGEND**  
 P = PSIG  
 H = BTU/LB  
 F = °F  
 KW = KILOWATTS  
 W = LB/HR

NO.	DATE	REVISION	BY	APPV.	SCALE :
					NONE
					CALC. TCE DATE 8-25-92
					OWN. RDP DATE 8-25-92
					CHK. DATE
					APPV. DATE




W501F  
 FLOW DIAGRAM  
 CASE: WINTER DES OIL UNFIRED

PROJECT NO.:	1253
CLIENT:	TIGER BAY COGEN
DWG. NO.:	1253-M-017.02
REV.	0

DESTEC CONFIDENTIAL  
 This drawing is the property of DESTEC Engineering, Inc. Neither this drawing, nor reproductions of it, nor information derived from it, shall be given to others without the expressed written consent of DESTEC Engineering, Inc. No use is to be made of it which is, or may be, injurious to DESTEC Engineering, Inc.

DWG. NO. 082592



TOTAL FUEL - 1782 X MM BTU/HR  
 PLANT GROSS POWER - 243 210 KW

**LEGEND**  
 P = PSIG  
 H = BTU/LB  
 F = °F  
 KW = KILOWATTS  
 W = LB/HR

NO.	DATE	REVISION	BY	APPV.	SCALE:
					NONE
					CALC. TCE DATE 8-25-92
					DWN. ROP DATE 8-25-92
					CHK. DATE
					APPV. DATE




**W501F  
 FLOW DIAGRAM  
 CASE: WINTER DES GAS UNFIRED**

PROJECT NO:	1253
CLIENT:	TIGER BAY COGEN
DWG NO:	1253-M-017.03
REV.	0

SCALE: COPY EXAMINE.  
 This drawing is the property of DESTEC Engineering, Inc. No part of this drawing may be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the expressed written consent of DESTEC Engineering, Inc. No use is to be made of it which is, or may be, injurious to DESTEC Engineering, Inc.

DWG NO. 1253  
 REV. 0

DESTEC CONFIDENTIAL  
 This drawing is the property of DESTEC Engineering, Inc. Neither this drawing, nor reproductions of it, nor information derived from it, shall be given to others without the expressed written consent of DESTEC Engineering, Inc. No use is to be made of it which is, or may be, injurious to DESTEC Engineering, Inc.



TOTAL FUEL - 1615 X MM BTU/HR  
 PLANT GROSS POWER - 217 450 KW

**LEGEND**  
 P = PSIG  
 H = BTU/LB  
 F = °F  
 KW = KILOWATTS  
 W = LB/HR

NO.	DATE	REVISION	BY	APPV.	SCALE :
					NONE
					CALC. TCE DATE 8-25-92
					DWNL RDP DATE 8-25-92
					CHK. DATE
					APPV. DATE




W501F  
 FLOW DIAGRAM  
 CASE: AVG AMB GAS UNFIRED

PROJECT NO:	1253
CLIENT:	TIGER BAY COGEN
DWG. NO.:	1253-M-017.04
REV.	0

DWG. NO. 00232

DESTEC CONFIDENTIAL  
 This drawing is the property of DESTEC Engineering, Inc. Neither this drawing, nor reproductions of it, nor information derived from it, shall be given to others without the expressed written consent of DESTEC Engineering, Inc. No use is to be made of it, in whole or in part, without the written consent of DESTEC Engineering, Inc.



**LEGEND**

P = PSIG  
 H = BTU/LB  
 F = °F  
 KW = KILOWATTS  
 W = LB/HR


NO.	DATE	REVISION	BY	APPV.	SCALE
					NONE
					CALC. TCE DATE 8-25-92
					DWN. BHG DATE 8-25-92
					CHK. DATE
					APPV. DATE

**DESTEC ENGINEERING**

**GE PG72221 (FA)**  
**FLOW DIAGRAM**  
**CASE: AVG. AMB. OIL, UNFIRED**

PROJECT NO:	-1253
CLIENT:	TIGER BAY COGEN
DWG. NO.:	1253-M-017.05
REV.	0

DWG NO. 082392



TOTAL FUEL - 2053 X MM BTU/HR  
 PLANT GROSS POWER - 256 425 KW

**LEGEND**  
 P = PSIG  
 H = BTU/LB  
 F = °F  
 KW = KILOWATTS  
 W = LB/HR

NO.	DATE	REVISION	BY	APPV	SCALE :
					NONE
					CALC. TCE DATE 8-25-92
					DWN. BHG DATE 8-25-92
					CHK. DATE
					APPV. DATE



GE PG721 (FA)  
 FLOW DIAGRAM  
 CASE: WINTER DES. OIL UNFIRED


PROJECT NO:	1253
CLIENT:	TIGER BAY COGEN
DWG. NO:	1253-M-017.06
REV.	0

THIS DRAWING IS THE PROPERTY OF DESTEC ENGINEERING, INC. NEITHER THIS DRAWING, NOR REPRODUCTIONS OF IT, NOR INFORMATION DERIVED FROM IT, SHALL BE GIVEN TO OTHERS WITHOUT THE EXPRESSED WRITTEN CONSENT OF DESTEC ENGINEERING, INC. NO USE IS TO BE MADE OF IT WHICH IS, OR MAY BE, INJURIOUS TO DESTEC ENGINEERING, INC.

DWG NO. 082592



This drawing is the property of DESTEC Engineering, Inc. Neither this drawing nor reproductions of it, nor information derived from it, shall be given to others without the expressed written consent of DESTEC Engineering, Inc. No use is to be made of it which is, or may be, injurious to DESTEC Engineering, Inc.



TOTAL FUEL - 1791 X MM BTU/HR  
 PLANT GROSS POWER - 244 225 KW

**LEGEND**  
 P = PSIG  
 H = BTU/LB  
 F = °F  
 KW = KILOWATTS  
 W = LB/HR

NO.	DATE	REVISION	BY	APPV.	SCALE :
					NONE
					CALC. TCE DATE 8-25-92
					DWN. BHG DATE 8-25-92
					CHK. DATE
					APPV. DATE




GE PG7221 (FA)  
 FLOW DIAGRAM  
 CASE: WINTER DES GAS UNFIRED

PROJECT NO:	1253
CLIENT:	TIGER BAY COGEN
DWG. NO.:	1253-M-017.07
REV.	0

BHC 11 000 AT  
 BHC

This drawing is the property of DESTEC Engineering, Inc. Neither this drawing, nor representation of the information derived from it, shall be given to others without the expressed written consent of DESTEC Engineering, Inc. No use is to be made of it which is, or may be, injurious to DESTEC Engineering, Inc.



TOTAL FUEL - 1625 X MM BTU/HR  
 PLANT GROSS POWER - 220 725 KW


**LEGEND**  
 P = PSIG  
 H = BTU/LB  
 F = °F  
 KW = KILOWATTS  
 W = LB/HR

NO.	DATE	REVISION	BY	APPV.	SCALE :
					NONE
					CALC. TCE
					DATE 8-25-92
					OWN. BHG
					DATE 8-25-92
					CHK. DATE
					APPV. DATE

**GE PG721 (FA)  
 FLOW DIAGRAM  
 CASE: AVG. AMB. GAS FIRED**

PROJECT NO:	1253
CLIENT:	TIGER BAY COGEN
DWG. NO:	1253-M-017.08
REV.	0

DWG. NO. 03252



# Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

June 22, 1992

Mrs. Chris Shaver, Chief  
Permit Review and Technical Support Branch  
National Park Service-Air Quality Division  
Post Office Box 25287  
Denver, Colorado 80225

Dear Mrs. Shaver:

RE: Central Florida Power Limited Partnership  
206 MW Cogeneration Facility  
Polk County, PSD-FL-190

The Department has received the above referenced PSD application. Please review this package for completeness and forward your comments to the Bureau of Air Regulation by July 10, 1992. The Bureau's FAX number is (904)922-6979.

If you have any questions, please call Mirza Baig or Cleve Holladay at (904)488-1344 or write to me at the above address.

Sincerely,


*for* C. H. Fancy, P.E.

Chief

Bureau of Air Regulation

CHF/pa

Enclosures



# Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

June 22, 1992

Ms. Jewell A. Harper, Chief  
Air Enforcement Branch  
U.S. EPA, Region IV  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

Dear Ms. Harper:

RE: Central Florida Power Limited Partnership  
206 MW Cogeneration Facility  
Polk County, PSD-FL-190

The Department has received the above referenced PSD application package. Please review this package and forward your comments to the Department's Bureau of Air Regulation by July 10, 1992. The Bureau's FAX number is (904)922-6979.

If you have any questions, please contact Mirza Baig or Cleve Holladay at (904)488-1344 or write to me at the above address.

Sincerely,

*Patricia G. Adams*

*for* C. H. Fancy, P.E.

Chief

Bureau of Air Regulation

CHF/pa

Enclosures



RECEIVED

DESTEC ENGINEERING, INC.  
2500 CITYWEST BLVD., SUITE 1700  
P.O. BOX 4411  
HOUSTON, TEXAS 77210-4411  
(713) 974-8200

JUN 25 1992

Division of Air  
Resources Management

June 23, 1992

Mr. Clair Fancy  
Bureau of Air Regulation  
Florida Department of Environmental Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Re: Central Florida Power Limited Partnership

Dear Clair:

Please find enclosed a copy of the "Letter of Authorization" which was not included in our permit application and prevention of significant deterioration analysis for a 206-MW cogeneration facility. The application was submitted on June 12, 1992.

I will be contacting you in a week to review the initial comments your staff may have. In the meantime, please call if you have any questions.

Sincerely,

Robert S. Chatham, P.E.  
Senior Environmental Engineer

RSC:tk

cc: Kennard F. Kosky, KBN  
Barry Andrews, FDER  
Mirza Baig, FDER  
File


June 12, 1992

TO WHOM IT MAY CONCERN:

**Subject: Letter of Authorization**

Please be advised that Robert I. Taylor, Project Manager, is authorized to represent Central Florida Power Limited Partnership in matters relating to necessary permits and approvals required from federal, state, county, and local regulatory authorities in the areas of air, water and land issues.

Sincerely,



Robert O. Rogers  
President, Central Florida DGE Inc.  
Managing General Partner of  
Central Florida Power Limited Partnership

tk

**SENDER:**

- Complete items 1 and/or 2 for additional services.
- Complete items 3, and 4a & b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece next to the article number.

I also wish to receive the following services (for an extra fee):

- 1.  Addressee's Address
  - 2.  Restricted Delivery
- Consult postmaster for fee.

3. Article Addressed to:  
 Mr. Robert I. Taylor  
 Project Manager  
 Central Florida Power, L.P.  
 2500 City West Blvd., Suite 1502  
 Houston, TX 77042

4a. Article Number  
 P 710 058 545

- 4b. Service Type
- Registered  Insured
  - Certified  COD
  - Express Mail  Return Receipt for Merchandise

7. Date of Delivery  
 7-22-92

8. Addressee's Address (Only if requested and fee is paid)

5. Signature (Addressee)  
 [Signature]

6. Signature (Agent)  
 [Signature]

PS Form 3811, October 1990

U.S. GPO: 1990-273-861

**DOMESTIC RETURN RECEIPT**

P 710 058 545



**Certified Mail Receipt**  
 No Insurance Coverage Provided  
 Do not use for International Mail  
 (See Reverse)

Send to	Mr. Robert I. Taylor, Cent
Street & No	PH-Power, P. 2500 City West Blvd.
(City, State & ZIP Code)	Houston, TX 77042
Postage	
Certified Fee	\$
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom Date, & Address of Delivery	
TOTAL Postage & Fees	\$
Postmark or Date	

PS Form 3800, June 1990

Mailed: 7-14-92  
 Permit: AC 53-214903  
 PSD-FL-190



# Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

July 14, 1992

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Robert I. Taylor, Project Manager  
Central Florida Power, L.P.  
2500 City West Blvd., Suite 150  
Houston, Texas 77042

Dear Mr. Taylor:

On June 15, 1992, the Department received a PSD permit application to construct a 206 MW cogeneration power plant at the U.S. Agri-Chemicals Complex near Ft. Meade, Florida and deemed it incomplete. Please provide the following information:

1. Section 1-1 states the electrical output of the cogeneration facility is 206 MW. The gas turbine (GT) is rated at 147 MW and the duct burner is rated at 74 MW giving a total of 221 MW. What is the maximum electrical output you would like to be permitted for this facility?
2. According to Section 1-1, two types of advanced GTs are being considered for this project. The Department must know the exact type of gas turbine you propose to install so that a BACT determination can be made. Accordingly, please submit detailed information of the unit selected. We will also need any available stack test data for that unit.
3. What is the maximum sulfur content of the natural gas you propose to burn? Provide a copy of any sulfur content guarantee that you may have from the supplier.
4. Submit an updated process flow diagram showing steam turbine and volumetric air flow rates.
5. In Section 4-12, Table 4-2, the emissions (25 ppmvd) for advance GT with dry low-NO<sub>x</sub> technology appears to be incorrect. Also Table 4-2 should state the turbine size on which these figures are based.
6. Submit all emission calculations and not just an example calculation. These emission calculations shall be based on the selected turbine for this project.



Mr. Robert I. Taylor  
Page 2 of 2

7. What is the expected maximum ambient concentrations for the metals emitted?
8. Please provide an air quality related analysis (AQRV) of the impact this project will have on the Chassahowitzka National Wilderness Area (CNWA) for the pollutant NO<sub>2</sub>. The AQRV analysis includes impacts to soil, vegetation, and wild life. This analysis also includes an assessment of impacts to the aquatic environment. Since the modeling information already provided with this application shows that the predicted NO<sub>2</sub> impact at the CNWA Class I area is less than the National Park Service (NPS) recommended significance level, the NPS has verbally stated that only a literature review is needed in order to comply with the AQRV analysis requirement.
9. Section 4.3.1.2, page 4-10, states that "While the increased firing temperature increases the thermal NO<sub>x</sub> generated, this NO<sub>x</sub> increase is controlled through combustion design." How much additional thermal NO<sub>x</sub> generated is due to higher temperature?
10. On page 4-3, the estimated cost of SCR is reported to be about \$7400 per ton of NO<sub>x</sub> removed and it exceeds \$10,000 per ton of pollutant removed when the net emissions of all pollutants (exclusive of CO<sub>2</sub>) are considered. Provide us with the names and addresses of all manufacturers that were contacted while developing capital and annualized cost estimates for this project.

The processing of your application will continue upon receipt of the above requested information. If you have any questions, please contact Mr. Mirza P. Baig at (904) 488-1344.

Sincerely,

*For [Signature]*

C. H. Fancy, P.E.  
Chief  
Bureau of Air Regulation

CHF/MB/plm

cc: Bill Thomas, SWD  
Ken Kosky, P.E., KBN Eng.  
Robert Chatham, Destec Eng.  
Jewell Harper, EPA, Atlanta  
Chris Shaver, NPS



CCV MIRZA BAIG  
LELEVE HOLADAY  
Plan to attend  
Tuesday 10 am MTC

DESTEC ENGINEERING, INC.  
2500 CITYWEST BLVD., SUITE 1700  
P.O. BOX 4411  
HOUSTON, TEXAS 77210-4411  
(713) 974-8200

Preston  
4/10/92

April 9, 1992

APIS No 020 40TPA53023801

Mr. Preston Lewis  
Bureau of Air Regulations  
Florida Department of Environmental Regulations  
2600 Blairstone Road  
Tallahassee, FL - 32399-2400

**Subject: Central Florida Cogeneration Plant  
Fort Meade, Polk County  
Preliminary Information and Pre-Application Meeting**

Dear Mr. Lewis:

The Central Florida Power Limited Partnership is planning a 210 MWe (nominal) cogeneration project (at) the U.S. Agri Chemicals Complex near Ft. Meade, Florida. The project will be called the Central Florida Cogeneration Plant. Destec Energy, Inc. is one of the partners, and is the developer of the project. Destec Operating Company will operate and maintain the cogeneration plant under contract to the Partnership. All pollution-emitting activities, including emission controls, will be under Destec control. Destec Engineering, Inc., an affiliate of Destec Energy, is under contract to the limited partnership to perform engineering services for the project, including air permitting.

The project will consist of one gas turbine (GT) electric generating unit, equipped with a duct burner-fired heat recovery steam generator (HRSG). The GT/HRSG unit will be primarily fired with natural gas, distillate oil will be used as the emergency backup fuel for the GT.

This letter presents a brief overview of the project, our preliminary analysis of the air emissions due to the project, and our understanding of the air permitting requirements and air regulations which apply to the project. We have concluded that a FDER construction permit will be required, and that certain NSPS will apply. We have also concluded that a PSD permit will be required for carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>), volatile organic compounds (VOC), particulate matter (PM), and particulate matter less than 10 microns (PM-10).

We understand that PSD review will not apply for sulfur dioxide (SO<sub>2</sub>) and other PSD-regulated pollutants, because the project will not cause significant emissions for these pollutants. We further understand that Nonattainment New Source Review (NNSR) will not apply to the project's emissions, because the project is not located in a nonattainment area.

We look forward to meeting at the FDER on Tuesday, April 14, 1992 at 10:00 AM to discuss the project and confirm the project's permitting requirements, procedures, and timing. We are especially interested in obtaining FDER input regarding BACT considerations for NO<sub>x</sub>, CO, VOC, PM, PM-10 and the timing of air dispersion modeling submittals. Destec Engineering,

Mr. Preston Lewis  
April 9, 1992  
Page 2

Inc. has engaged the services of KBN Engineering (KBN) to prepare the air permit applications. Representatives of Destec, General Peat Resources and KBN will be present at the meeting.

### **Project Schedule**

Contingent upon receipt of the necessary pre-construction approvals, construction of the Cogeneration Plant is scheduled to be financed by December 1992, construction begin by June 1993, and be operational by January 1995.

### **Project Overview**

Attachment 1 to this letter shows the general location of the project in Florida and Polk County. Polk County is classified as "attainment" or "cannot be classified" for all criteria pollutants.

Attachment 2 shows the specific project location in the U.S. Agri Chemicals Complex near Ft. Meade. The project will provide process steam to the U.S. Agri Chemicals complex. Electric power will be supplied to the public utility grid.

Destec personnel will operate and maintain the cogeneration plant under contract to the Partnership. The cogeneration plant manager will be a Destec employee. The plant will be owned by the limited partnership. An affiliate of Destec Energy, Inc., General Peat Resources and EcoEnergy will have ownership interest in the partnership.

The project is evaluating different manufacturers of gas-fired turbines. The gas turbine unit will have a nominal electrical output of about 150 MWe, a maximum heat input of about 1900 MMBtu/hr (HHV), and will be equipped with dry low NO<sub>x</sub> combustors. The gas turbine's exhaust will be routed to a duct burner-fired HRSG unit, normally unfired. The natural gas-fired duct burner for the HRSG unit is expected to have a maximum heat input of about 125 MMBtu/hr (HHV). The steam from the HRSG unit will power a steam turbine electrical generator, with a maximum output of about 74 MWe.

Approximately 40,000 lb/hr of low pressure steam will be exported to the U.S. Agri Chemical complex for use as thermal energy.

Electrical power will be sold to the public utility grid.

### **Project Emissions**

By firing natural gas the gas turbine exhaust (entering the HRSG) will be limited to 25 ppmvd NO<sub>x</sub>, at 15% oxygen, and 15 ppmvd CO. Advanced dry low NO<sub>x</sub> technology combustors and other measures will be used to control the NO<sub>x</sub> emissions from the project's gas turbine and duct burner while firing natural gas. The duct burners will be only fired on natural gas. The duct

burner NO<sub>x</sub> emissions will be about 0.10 lb/MMBtu.

When firing distillate oil, the gas turbine exhaust entering the HRSG will be limited to 42 ppmvd NO<sub>x</sub> at 15% oxygen and 30 ppmvd CO. Steam or water injection will be utilized for NO<sub>x</sub> control when firing distillate oil. The annual distillate oil usage is anticipated to be approximately 350 hours per year.

The planned permit application will present calculations of maximum hourly and annual emission rates for all regulated pollutants for each emitting unit. For purposes of evaluating how PSD regulations may apply to the project, Destec has performed preliminary, worst-case emissions calculations of annual emissions. These calculations are summarized and discussed below.

Destec may present slightly different calculated emissions in the planned permit application, based on operational limitations that may be proposed to FDER as part of the requested permit.

In the preliminary, worst-case emissions calculations the single GT/HRSG is assumed to operate at maximum rated heat input, year-round. This calculational basis considerably over estimates the emissions that will actually occur, since (1) the gas turbine will at times be operated at less than maximum capacity and (2) the duct burner in the HRSG will not normally be operated. The following table summarizes the preliminary, worst-case emissions calculations and compares the calculated emissions to the PSD significance levels:

	<b>Worst Case Project Emissions (T/yr)</b>	<b>PSD Significance Level (T/yr)</b>
Carbon monoxide (CO)	324	100
Nitrogen oxides (NO <sub>x</sub> )	750	40
Sulfur dioxide (SO <sub>2</sub> )	39	40
Particulate matter (PM) <sup>a</sup> and PM-10	48	25/15
Volatile organic compounds (VOC)	58	40
Non-criteria PSD regulated pollutants	None or Negligible	Project emissions will be insignificant

<sup>a</sup> The permit application will conservatively assume that PM will consist 100% of PM-10.

### Applicability of PSD and NNSR Review

Destec's understanding of the PSD regulations is that the planned Cogeneration Plant is not one of the 28 source types, therefore, the criterion of "major source" is 250 T/yr of any regulated pollutant. On that basis, and based on the preliminary emissions calculations summarized above, the cogeneration plant will be a major stationary source, since the plant will emit 250 T/yr or more CO and NO<sub>x</sub>. Destec understands, therefore, that PSD is applicable to all PSD-regulated pollutants which the plant will emit in significant amounts. Destec further understands that, because the cogeneration plant will be a new "stationary source" under separate control from the U.S. Agri Chemical complex, netting of contemporaneous increases and decreases is not applicable. Therefore, Destec has concluded that PSD will apply to all pollutants for which significant emissions will occur from the new cogeneration plant. As shown on the table in the preceding section, the plant will be significant for CO, NO<sub>x</sub>, VOC, PM and PM-10. Therefore, we understand that PSD review will apply to the project for CO, NO<sub>x</sub>, VOC, PM and PM-10.

The plant will have insignificant emissions of SO<sub>2</sub>, lead, and non-criteria PSD regulated pollutants. Therefore, we understand that the project will not be subject to PSD review for SO<sub>2</sub>, lead, and non-criteria PSD-regulated pollutants. Also, we understand that the project will not be subject to NNSR review.

### Applicability of NSPS Regulations

Based upon the preliminary project plans, we understand that the Cogeneration Plant will be subject to some of the New Source Performance Standards contained in:

- 40 CFR 60 Subpart GG: Stationary Gas Turbines
- 40 CFR 60 Subpart Db: Industrial - Commercial - Institutional Steam Generating Units

In addition, the project's duct burner-fired HRSG unit does not appear to not be subject to Subpart D or Da since the duct burners' maximum heat input capacity of 125 MMBtu/hr does not exceed the applicability level of 250 MMBtu/hr.

Regarding the NSPS for a gas turbine in 40 CFR 60 Subpart GG, the turbines will be subject to the Subpart GG limits for sulfur dioxide, which require that the exhaust gases do not exceed 150 ppmv SO<sub>2</sub> (at 15% O<sub>2</sub>, dry basis) and that the fuel does not contain more than 0.8 percent sulfur by weight. The turbine and fuels will easily comply with these limits. We understand that the cogeneration plant will be required to periodically monitor and report fuel sulfur content in accordance with the Subpart GG NSPS.

Regarding the NSPS for steam generating units in 40 CFR 60 Subpart Db., the project's duct burner-fired HRSG unit will be subject to the NSPS, because the maximum fuel firing rate (about 125 MMBtu/hr/duct burner (HHV)) is greater than the NSPS applicability threshold of 29 MWe (100 MMBtu/hr). The Subpart Db NSPS requires that affected duct burners meet a NO<sub>x</sub> emission limit of 0.2 lb/MMBtu heat input, which is applicable to firing natural gas in duct burners of combined cycle systems (see 40 CFR 60.44b(e)). The planned duct burners will have

no difficulty in meeting the NSPS. The duct burners will be fired only on natural gas.

### CO BACT Considerations

The gas turbines dry low NO<sub>x</sub> combustors are guaranteed to limit CO to 15 ppmvd, natural gas, and limit CO to 30 ppmvd, firing distillate oil and injecting steam or water. At the CO emission rates which correspond to this low concentration, the ambient CO impacts of the project are expected to be negligible (i.e., well below FDER and EPA significance thresholds). Given the low CO emissions and negligible impacts, we currently anticipate proposing the low NO<sub>x</sub> controls as BACT for CO. We would like to obtain FDER input prior to preparing our BACT analysis and permit applications.

### Contents of Air Permit Applications

We plan to submit two separate permit application documents for the Cogeneration Plant:

- FDER construction permit application
- PSD application

Destec Engineering and KBN are now beginning to assemble the information and perform the analysis to be included in the permit applications.

The FDER permit application is expected to include the following information:

- Completed FDER permit application forms
- Certifications (i.e. professional engineers certification)
- Description of the project and the process, with an area map, plot plant and process flow diagram. Emphasis will be placed on sources of emissions and emission control measures.
- BACT analysis for CO, NO<sub>x</sub>, SO<sub>2</sub>, PM, PM-10 and VOC
- Description of applicable air regulatory requirements
- Appendicized emission rate calculations, along with the inputs and assumptions used.
- Dispersion modeling analysis in accordance with protocols agreed upon with FDER.

The PSD permit application will include much of the same information included in the state application, except that the PSD BACT analysis and any dispersion modeling analysis will address only CO, NO<sub>x</sub>, PM, VOC, and PM-10. The PSD application's BACT analysis for NO<sub>x</sub> and CO will be quite brief, because we understand that our planned BACT measures for NO<sub>x</sub> and CO represent the "top" level of BACT, consistent with current FDER and EPA policies. The PSD application's BACT analysis for PM and PM-10 is also expected to be quite brief, because we are aware of no control techniques (aside from modern design and good combustion

Mr. Preston Lewis  
April 9, 1992  
Page 6

practices) for PM/PM-10 emissions from gas-fired/oil-fired gas turbines and gas-fired duct burners.

With respect to dispersion modeling, we currently anticipate submitting modeling analysis when the permit applications are submitted to FDER. We anticipate that a separate modeling protocol meeting with FDER modelers will be required to confirm specific procedures prior to performing the modeling.

We look forward to meeting with you on April 14th to confirm the air permitting requirements and timing for the project. In the interim, if there are any questions regarding the project or this letter, please call me at (713) 735-4087.

Sincerely,  
DESTEC ENGINEERING, INC.

A handwritten signature in black ink that reads "Robert S. Chatham". The signature is written in a cursive style with a large initial "R" and "C".


Robert S. Chatham  
Environmental Engineer


Mr. Preston Lewis  
April 9, 1992  
Page 7

cc: Mr. J. W. Kenny, General Peat Resources  
Mr. Ken Kosky, KBN

Attachments:           1 - Project Location in Florida and Polk County  
                          2 - Project Location within U.S. Agri Chemicals Complex







**ATTACHMENT 2  
PROJECT LOCATION MAP**

SOURCES: USGS, 1987; KBN, 1992.



WAIVER OF 90 DAY TIME LIMIT  
UNDER SECTIONS 120.60(2) and 403.0876, FLORIDA STATUTES

License (Permit, Certification) Application No. AC 53-214903

PSD-FL-190


Applicant's Name: Central Florida Power, L.P.

Tiger Bay Cogeneration Plant

With regard to the above referenced application, the applicant hereby with full knowledge and understanding of applicant's rights under Sections 120.60(2) and 403.0876, Florida Statutes, waives the right to have the application approved or denied by the State of Florida Department of Environmental Regulation within the 90 day time period prescribed by law. Said waiver is made freely and voluntarily by the applicant, with full knowledge, and without any pressure or coercion by anyone employed by the State of Florida Department of Environmental Regulation.

This waiver shall expire on the 15th day of January 1993.

The undersigned is authorized to make this waiver on behalf of the applicant.

  
\_\_\_\_\_  
Signature

Robert I. Taylor, Project Manager  
Name (Please Type or Print)

Date: December 30, 1992  
To: Preston Lewis  
From: Robert Chatham

Page 1 of 2

	Document	Date/ Revision	Job No./ Project	Note
1.	<u>Waiver of 90 Day Time Limit</u>		<u>1253</u>	
2.				
3.				
4.				

Notes:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Cover

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Package

cc: Teresa Heron (FDER)  
Patricia Adams (FDER)

File

1253