

Florida Department of  
Environmental Protection

---

Memorandum

TO: C. H. Fancy  
THRU: Scott Sheplak *SS*  
FROM: Ed Svec *ES*  
DATE: September 12, 2001  
SUBJECT: PROPOSED Title V Permit Revision

Attached is the PROPOSED Title V Permit Revision 1050233-009-AV for the Tampa Electric Company's Polk Power Station for your review and approval. Comments on the DRAFT Permit Revision were received from EPA Region 4 and the appropriate changes were made to the PROPOSED permit and the Statement of Basis.

I recommend your approval of this PROPOSED permit.

attachments

**Florida's DRAFT Permit Electronic Notification Cover Memorandum**

**TO:** Elizabeth Bartlett, U.S. EPA Region 4  
**CC:** Gregg Worley, U.S. EPA Region 4  
**THRU:** Scott Sheplak P.E., Bureau of Air Regulation *SMS*  
**FROM:** Edward J. Svec, Permit Engineer *[Signature]*  
**DATE:** 09/14/01  
**RE:** U.S. EPA Region 4 PROPOSED Title V Operation Permit Revision Review

The following PROPOSED Title V operation permit(s) and associated documents have been posted on the DEP World Wide Web Internet site for your review. Please provide any comments via Internet E-mail, within forty five (45) days of receiving this notice, to Scott Sheplak, at "SHEPLAK\_S@dep.state.fl.us".

<u>Applicant Name</u>	<u>County</u>	<u>Method of Transmittal</u>	<u>Electronic File Name(s)</u>
Tampa Electric Company Polk Power Station	Polk	INTERNET	1050233R2p.zip

This zipped file contains the following electronic files:

sob.doc  
1050233R2p.doc  
10502331.xls  
10500032.xls  
1050233g.doc  
1050233u.doc  
1050233h.doc



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

## PROPOSED Permit Electronic Posting Courtesy Notification

Tampa Electric Company  
Polk Power Station  
**Facility ID No.:** 1050233  
Polk County

Title V Air Operation Permit Revision  
**PROPOSED Permit Revision No.:** 1050233-009-AV

The electronic version of the PROPOSED permit was posted on the Division of Air Resources Management's world wide web site for the United States Environmental Protection Agency (USEPA) Region 4 office's review on September 14, 2001.

USEPA's review period ends on the 45th day after the permit posting date. Day 45 is October 28, 2001. If an objection (veto) is received from USEPA, the permitting authority will provide a copy of the objection to the applicant.


Provided an objection is not received from USEPA, the PROPOSED permit will become a FINAL permit by operation of law on the 55th day after the permit posting date. Day 55 is November 7, 2001.

The web site address is:

<http://www8.myflorida.com/licensingpermitting/learn/environment/air/tv/TitleVSearch.asp>

*"More Protection, Less Process"*

*Printed on recycled paper.*



# Department of Environmental Protection

Jeb Bush  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

September 13, 2001

Mr. Mark J. Hornick  
General Manager, Polk Power Station  
Tampa Electric Company  
P. O. Box 775  
Tampa, Florida 33680-0775

Re: PROPOSED Title V Operation Permit Revision No.: 1050233-009-AV  
Polk Power Station

Dear Mr. Hornick:


One copy of the "PROPOSED Title V Air Operation Permit Revision" for the Polk Power Station located at 9995 State Route 37 South, Mulberry, Polk County, is enclosed. This letter is only a courtesy to inform you that the DRAFT permit has become a PROPOSED permit.

An electronic version of this determination has been posted on the Division of Air Resources Management's world wide web site for the United States Environmental Protection Agency (USEPA) Region 4 office's review. The web site address is <http://www.dep.state.fl.us/air>.

Pursuant to Section 403.0872(6), Florida Statutes, if no objection to the PROPOSED permit is made by the USEPA within 45 days, the PROPOSED permit will become a FINAL permit no later than 55 days after the date on which the PROPOSED permit was mailed (posted) to USEPA. If USEPA has an objection to the PROPOSED permit, the FINAL permit will not be issued until the permitting authority receives written notice that the objection is resolved or withdrawn.

If you have any other questions, please contact Edward J. Svec at 850/921-8985.

Sincerely,

  
for C. H. Fancy, P.E.  
Chief  
Bureau of Air Regulation

CHF/es

Enclosures

copy furnished to:  
Mr. Bill Thomas, P.E., FDEP, SWD  
U.S. EPA, Region 4 (INTERNET E-mail Memorandum)

Mailed on 9/18/01  
cc: Ed Svec  
Reading File

"More Protection, Less Process"

Printed on recycled paper.

## PROPOSED PERMIT DETERMINATION

PROPOSED Permit Revision No.: 1050233-009-AV

Page 1 of 3

### **I. Public Notice.**

An "INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION" to Tampa Electric Company for the Polk Power Station located at 9995 State Route 37 South, Mulberry, Polk County was clerked on July 19, 2001. The "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION" was published in the Lakeland Ledger on August 8, 2001. The DRAFT Title V Air Operation Permit Revision was available for public inspection at the Southwest District office in Tampa and the permitting authority's office in Tallahassee. Proof of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION" was received on August 14, 2001.

### **II. Public Comment(s).**

Comments were received and the DRAFT Title V Operation Permit Revision was changed. The comments were not considered significant enough to reissue the DRAFT Title V Operation Permit Revision and require another Public Notice. Comments were received from one respondent during the 30 (thirty) day public comment period. Listed below is each comment letter in the chronological order of receipt and a response to each comment in the order that the comment was received. The comment(s) will not be restated. Where duplicative comments exist, the original response is referenced.

**A.** Electronic mail from Ms. Gracy Danois dated and received August 6, 2001.

*1. I just received the draft revision for this source addressing the removal of the COM for unit 1. In reviewing this revision, I noticed that you addressed the comments that we sent you on May 23, 2001, with the exception of correcting the citation in facility-wide condition 8. Could it be that I have an outdated version of Appendix TV-3? Let me know so we don't make this comment again in future reviews.*

**Response:** The Department discovered an error in the permitting note following Facility-wide Condition 8 and the following change will be made.

**From:** {Note: This condition implements the requirements of Rules 62-296.320(4)(c)1., 3., & 4. F.A.C. (condition 58. of APPENDIX TV-3, TITLE V CONDITIONS.)}

**To:** {Note: This condition implements the requirements of Rules 62-296.320(4)(c)1., 3., & 4. F.A.C. (condition 57. of APPENDIX TV-3, TITLE V CONDITIONS.)}

2. *Regarding the latest changes to this permit, we are concerned with the explanation for the COM change given in the statement of basis.*

*On Dec. 18, 1998, we objected to the title V permit for this facility because, among other things, inadequate periodic monitoring for visible emissions (VE). The permit had only a once per year testing requirement and we requested that the State either provide an explanation supporting this approach or add adequate periodic monitoring requirements to the permit. The State and the facility chose the second option given the fact that the unit had a COM required by the Acid Rain regulations.*

*Now, the permit is being modified to remove specific condition A.52, the periodic monitoring requirement for VE, by calling it "obsolete" without any additional explanation to address how the facility will meet the periodic monitoring requirements for VE for this unit. The May 9, 2001, CAMD letter provides a very good explanation for the exemption from the requirement to have a COM, which supports the annual testing approach for VE for unit 1. I strongly suggest that the explanation be included in the statement of basis. By not doing so it looks as if the State was somehow circumventing the system. The permit does not appear to provide a different approach from the one that EPA already objected to and the statement of basis does not provide adequate documentation to support the approach in the permit. Having deja-vu already? By including a few sentences about how this unit operates in a similar way as those burning natural gas and diesel fuel and that VE data from this unit supports the once per year testing, the permit change will be adequately documented in the statement of basis. Please understand that is not sufficient that we know why your doing things, the public also needs to know, even if they have not been actively participating in the title V process.*

**Response:** The Department will change the language in the Statement of Basis as follows:

**From:** This permit revision is to incorporate a petition for exemption from the opacity monitoring requirements of Part 75 (Acid Rain) of the Clean Air Act. The petition was approved by USEPA on May 9, 2001. Approval of this petition by the EPA renders the use of the continuous opacity monitor for periodic monitoring, as required by specific condition A.52. of the initial Title V permit, obsolete. The permit also incorporates the ability to utilize the nitrogen oxides continuous emissions monitor to satisfy the requirement to monitor the fuel bound nitrogen of the liquid fuel authorized by permit PSD-FL-194G by changing Specific Condition A.14., as follows:

**To:** This permit revision is to incorporate a petition for exemption from the opacity monitoring requirements of Part 75 (Acid Rain) of the Clean Air Act. Since Polk Unit 1 is officially defined as a coal fired unit, Tampa Electric Company was required to install and operate a continuous opacity monitor on the Unit. Based on historical opacity measurements collected when firing syngas, opacity levels from Polk Unit 1 (seldom exceeding 5% opacity) are very similar to those experienced by a comparable unit firing natural gas or diesel fuel because of the absence of particulate matter in the flue gas. On February 29, 2001, Tampa Electric Company (TEC) petitioned USEPA for an exemption from Part 75 monitoring requirements, and the petition was approved by USEPA on May 9, 2001. Approval of this petition by the EPA renders the use of the continuous opacity monitor for periodic monitoring, as required by specific condition **A.52.** of the initial Title V permit, obsolete. The permit also incorporates the ability to utilize the nitrogen oxides continuous emissions monitor to satisfy the requirement to monitor the fuel bound nitrogen of the liquid fuel authorized by permit PSD-FL-194G by changing Specific Condition A.14., as follows:

### **III. Conclusion.**

The permitting authority hereby issues the PROPOSED Title V Operation Permit Revision, No. 1050233-009-AV, with any changes noted above.

## STATEMENT OF BASIS

Tampa Electric Company  
Polk Power Station  
**Facility ID No.:** 1050233  
Polk County

### Title V Air Operation Permit Revision **PROPOSED Permit Revision No.:** 1050233-009-AV

The initial Title V air operation permit went final on March 19, 1999, and effective on January 1, 2000. This Title V air operation permit with revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit with revision.

This permit revision is to incorporate a petition for exemption from the opacity monitoring requirements of Part 75 (Acid Rain) of the Clean Air Act. Since Polk Unit 1 is officially defined as a coal fired unit, Tampa Electric Company was required to install and operate a continuous opacity monitor on the Unit. Based on historical opacity measurements collected when firing syngas, opacity levels from Polk Unit 1 (seldom exceeding 5% opacity) are very similar to those experienced by a comparable unit firing natural gas or diesel fuel because of the absence of particulate matter in the flue gas. On February 29, 2001, Tampa Electric Company (TEC) petitioned USEPA for an exemption from Part 75 monitoring requirements, and the petition was approved by USEPA on May 9, 2001. Approval of this petition by the EPA renders the use of the continuous opacity monitor for periodic monitoring, as required by specific condition A.52. of the initial Title V permit, obsolete. The permit also incorporates the ability to utilize the nitrogen oxides continuous emissions monitor to satisfy the requirement to monitor the fuel bound nitrogen of the liquid fuel authorized by permit PSD-FL-194G by changing Specific Condition A.14., as follows:

**From: A.14.** The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG shall monitor sulfur content and nitrogen content of the fuel being fired in the turbine. The frequency of determination of these values shall be as follows:

- (1) If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source
- (2) If the turbine is supplied its fuel without intermediate bulk storage the values shall be determined and recorded daily. Owners, operators or fuel vendors may develop custom schedules for determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with 40 CFR 60.334(b).  
[40 CFR 60.334(b)(1) & (2); and, PSD-FL-194(A)]

**To: A.14.** The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG shall monitor sulfur content and nitrogen content of the fuel being fired in the turbine. The frequency of determination of these values shall be as follows:

- (1) If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source. Nitrogen oxide continuous emissions monitors may be used to determine the fuel bound nitrogen content of fuel oil combusted in gas turbines subject to this requirement.



(2) If the turbine is supplied its fuel without intermediate bulk storage the values shall be determined and recorded daily. Owners, operators or fuel vendors may develop custom schedules for determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with 40 CFR 60.334(b). [40 CFR 60.334(b)(1) & (2); and, PSD-FL-194(G)]

Tampa Electric Company  
Polk Power Station  
**Facility ID No.:** 1050233  
Polk County

Title V Air Operation Permit Revision  
**PROPOSED Permit Revision No.:** 1050233-009-AV

Permitting Authority:

State of Florida  
Department of Environmental Protection  
Division of Air Resources Management  
Bureau of Air Regulation  
Title V Section

Mail Station #5505  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Telephone: 850/488-1344  
Fax: 850/922-6979


Compliance Authority:

Department of Environmental Protection  
Southwest District Office  
3804 Coconut Palm Drive  
Tampa, Florida 33619-8218  
Telephone: 813/744-6100  
Fax: 813/744-6084

Title V Air Operation Permit Revision  
**PROPOSED Permit Revision No.: 1050233-009-AV**

**Table of Contents**

<b>Section</b>	<b>Page Number</b>
Placard Page .....	1
I. Facility Information .....	2 - 3
A. Facility Description.	
B. Summary of Emissions Unit ID No(s). and Brief Description(s).	
C. Relevant Documents.	
II. Facility-wide Conditions .....	4 - 5
III. Emissions Units and Conditions	
A. Emissions Unit -001 260 MW Combined Cycle Gas Turbine .....	6 - 23
B. Emissions Unit -003 102 Million Btu per Hour Auxiliary Boiler .....	24 - 36
C. Emissions Unit -004 Sulfuric Acid Plant .....	37 - 44
D. Emissions Unit -005 Solid Fuel Handling System .....	45 - 48
E. Emissions Unit -006 Solid Fuel Gasification System .....	49 - 50
IV. Acid Rain Part	
A. Acid Rain, Phase II .....	51 - 52



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

**Permittee:**  
Tampa Electric Company  
P. O. Box 111  
Tampa, Florida 33601-0111

**PROPOSED Permit Revision No.:** 1050233-009-AV  
**Facility ID No.:** 1050233  
**SIC Nos.:** 49, 4911  
**Project:** Title V Air Operation Permit Revision

This permit revision is to remove the requirement to utilize the continuous opacity monitor previously required on the 260 MW Combined Cycle Combustion Turbine at the Polk Power Station and to utilize the nitrogen oxides continuous emissions monitor to determine fuel bound nitrogen of liquid fuel. This facility is located at 9995 State Route 37 South, Mulberry, Polk County; UTM Coordinates: Zone 17, 402.45 km East and 3067.35 km North; Latitude: 27° 43' 43" North and Longitude: 81° 59' 23" West.

**STATEMENT OF BASIS:** This Title V air operation permit revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

**Referenced attachments made a part of this permit:**

Appendix U-1, List of Unregulated Emissions Units and/or Activities  
Appendix I-1, List of Insignificant Emissions Units and/or Activities  
APPENDIX TV-3, TITLE V CONDITIONS (version dated 04/30/99)  
APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)  
APPENDIX 40 CFR 60 Subpart A-General Provisions (version dated 07/23/97)  
TABLE 297.310-1, CALIBRATION SCHEDULE (version dated 10/07/96)  
FIGURE 1 - SUMMARY REPORT-GASEOUS AND OPACITY EXCESS EMISSION  
AND MONITORING SYSTEM PERFORMANCE REPORT (version dated 07/96)  
PHASE II ACID RAIN APPLICATION/COMPLIANCE PLAN (received January 21, 1998)  
STATEMENT OF BASIS  
APPENDIX H-1, PERMIT HISTORY/ID NUMBER CHANGES  
EPA LETTER GRANTING THE PETITION FOR EXEMPTION FROM THE OPACITY MONITORING  
REQUIREMENTS OF PART 75 FOR POLK UNIT 1 (dated May 9, 2001)

**Effective Date:** January 1, 2000  
**Title V Permit Revision Effective Date:**  
**Renewal Application Due Date:** July 5, 2004  
**Expiration Date:** December 31, 2004

---

Howard L. Rhodes, Director  
Division of Air Resources  
Management

HLR/sms/ejs

"More Protection, Less Process"

Printed on recycled paper.

**Section I. Facility Information.**

**Subsection A. Facility Description.**

The regulated emissions units at the solid fuel gasification facility include a 260 megawatt (electric) combined cycle combustion turbine which fires syngas or No. 2 fuel oil; an auxiliary boiler which fires No. 2 fuel oil; a sulfuric acid plant; a solid fuel handling system; and a solid fuel gasification system.

Also included in this permit are miscellaneous unregulated/insignificant emissions units and/or activities.

Based on the initial Title V permit application received October 4, 1996, this facility is not a major source of hazardous air pollutants (HAPs).

**Subsection B. Summary of Emissions Unit ID No(s). and Brief Description(s).**

**E.U.**

<b><u>ID No.</u></b>	<b><u>Brief Description</u></b>
-001	260 MW Combined Cycle Combustion Turbine
-003	120 Million Btu per Hour Auxiliary Boiler
-004	Sulfuric Acid Plant
-005	Solid Fuel Handling System
-006	Solid Fuel Gasification System

**Unregulated Emissions Units and/or Activities**

- 007 One or more emergency generators which are not subject to the Acid Rain Program and have a total fuel consumption, in the aggregate, of 32,000 gallons per year or less of diesel fuel, 4,000 gallons per year or less of gasoline, 4.4 million cubic feet per year or less of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.
- 008 One or more heating units and general purpose internal combustion engines which are not subject to the Acid Rain Program and have a total fuel consumption, in the aggregate, of 32,000 gallons per year or less of diesel fuel, 4,000 gallons per year or less of gasoline, 4.4 million cubic feet per year or less of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.

***Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.***

**Subsection C. Relevant Documents.**

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:

Table 1-1, Summary of Air Pollutant Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

These documents are on file with the permitting authority:

Initial Title V Permit effective January 1, 2000

Request to revise the initial Title V permit dated May 24, 2001

## Section II. Facility-wide Conditions.

### The following conditions apply facility-wide:

1. APPENDIX TV-3, TITLE V CONDITIONS, is a part of this permit.  
{Permitting note: APPENDIX TV-3, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}
2. **Not federally enforceable. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited.** No person shall cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.  
[Rule 62-296.320(2), F.A.C.]
3. **General Particulate Emission Limiting Standards. General Visible Emissions Standard.**  
Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.  
[Rules 62-296.320(4)(b)1. & 4., F.A.C.]
4. **Prevention of Accidental Releases (Section 112(r) of CAA).**
  - a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable; and,
  - b. The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.  
[40 CFR 68]
5. **Unregulated Emissions Units and/or Activities.** Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.  
[Rule 62-213.440(1), F.A.C.]
6. **Insignificant Emissions Units and/or Activities.** Appendix I-1, List of Insignificant Emissions Units and/or Activities, is a part of this permit.  
[Rules 62-213.440(1), 62-213.430(6) and 62-4.040(1)(b), F.A.C.]
7. **General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions.** The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department.  
[Rule 62-296.320(1)(a), F.A.C.]

**8.** Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include: enclosing all solid fuel storage, conveyors, and conveyor transfer points; chemical or water application to unpaved road and unpaved yard areas; paving and maintenance of roads, parking areas, and yards; landscaping or planting of vegetation; confining abrasive blasting where possible; and other techniques, as necessary, to all facilities to maintain an opacity of less than or equal to five percent.  
[Rule 62-296.320(4)(c)2., F.A.C.; PSD-FL-194E]

{Note: This condition implements the requirements of Rules 62-296.320(4)(c)1., 3., & 4. F.A.C. (condition 57. of APPENDIX TV-3, TITLE V CONDITIONS.)}

**9.** When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.  
[Rule 62-213.440, F.A.C.]

**10.** The permittee shall submit all compliance related notifications and reports required of this permit to the Department's Southwest District office:

Department of Environmental Protection  
Southwest District Office  
3804 Coconut Palm Drive  
Tampa, Florida 33619-8218  
Telephone: 813/744-6100, Fax: 813/744-6084

**11.** Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency  
Region 4  
Air, Pesticides & Toxics Management Division  
Air and EPCRA Enforcement Branch, Air Enforcement Section  
61 Forsyth Street  
Atlanta, Georgia 30303-8960  
Telephone: 404/562-9155, Fax: 404/562-9164

**12. Statement of Compliance.** The annual statement of compliance pursuant to Rule 62-213.440(3)(a)2., F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year using DEP Form number 62-213.900(7), F.A.C.  
[Rule 62-213.440(3), F.A.C.]

{Permitting note: See Condition 51 of APPENDIX TV-3, TITLE V CONDITIONS.}



**Section III. Emissions Unit(s) and Conditions.**

**Subsection A. This section addresses the following emissions unit(s).**

**E.U.**

<b><u>ID No.</u></b>	<b><u>Brief Description</u></b>
-001	260 MW Combined Cycle Combustion Turbine

The integrated solid fuel gasification combined cycle combustion turbine is a General Electric Model Number 7F, 260 megawatt (electric) unit capable of firing syngas or No. 2 fuel oil. The maximum heat input at 59° F is 1,755 million Btu per hour when firing syngas and 1,765 million Btu per hour when firing No. 2 fuel oil. The combustion turbine uses nitrogen diluent injection when firing syngas and water injection when firing No. 2 fuel oil to control emissions of nitrogen oxides.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.; Rule 62-212.400(5), F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination, dated February 24, 1994. The combined cycle combustion turbine began operation in April, 1996.}

**The following specific conditions apply to the emissions unit(s) listed above:**

**Essential Potential to Emit (PTE) Parameters**

**A.1. Permitted Capacity.** The maximum heat input rate (higher heating value) is 1,755 million Btu per hour when firing syngas and 1,765 million Btu per hour when firing No. 2 fuel oil at an ambient temperature of 59° F. Manufacturer's curves approved by the Department for the heat input correction to other temperatures may be utilized to establish heat input rates over a range of temperatures for compliance determination. Monitoring required under condition **A.13.** shall satisfy periodic monitoring requirements for heat input.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; PSD-FL-194, and, applicant agreement with EPA on January 22, 1999]

**A.2. Emissions Unit Operating Rate Limitation After Testing.** See specific condition **A.28.**

[Rule 62-297.310(2), F.A.C.]

**A.3. Methods of Operation. Fuels.**

- a. This emissions unit fires syngas as the primary fuel.
- b. This emissions unit fires No. 2 distillate oil. The firing of No. 2 fuel oil is limited to a 10 percent annual capacity factor to be determined as follows:

$$[\text{Load (\%)}] / 100\% * \text{hrs. of operation} \leq 876 \text{ hrs}$$

[Rules 62-212.400, 62-212.410, and 62-213.410, F.A.C.; and, PSD-FL-194]

**A.4. Hours of Operation.** This emissions unit may operate continuously, i.e., 8,760 hours/year.

[Rule 62-210.200(PTE), F.A.C.]

**Emission Limitations and Standards**

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**A.5.** The maximum allowable emissions for the post demonstration period shall not exceed the following:

POLLUTANT	FUEL	BASIS <sup>a</sup>	LB / HR <sup>*</sup>	TPY <sup>b</sup>
NO <sub>x</sub>	Oil	42 ppmvd <sup>**</sup>	311	N/A
	Syngas	25 ppmvd	220.25	1,032.9
VOC <sup>c</sup>	Oil	0.028 lb/MMBtu	32	N/A
	Syngas	0.0017 lb/MMBtu	3	38.5
CO	Oil	40 ppmvd	99	N/A
	Syngas	25 ppmvd	98	430.1
PM / PM <sub>10</sub> <sup>d</sup>	Oil	0.009 lb/MMBtu	17	N/A
	Syngas	0.013 lb/MMBtu	17	74.5
Pb	Oil	5.30E-5 lb/MMBtu	0.101	N/A
	Syngas	2.41E-6 lb/MMBtu	0.0035	0.067
SO <sub>2</sub>	Oil	0.048 lb/MMBtu	92.2	N/A
	Syngas	0.17 lb/MMBtu	357	1,563.7
Sulfuric Acid <sup>e</sup>	Syngas		55	241
Inorganic Arsenic	Syngas		0.0006	0.019
Beryllium	Syngas		0.0001	0.0029
Mercury	Syngas		0.0034	0.017

( \*) Emission limitations in lb/hr are 30 day rolling averages.

( \*\*) The emission limit for NO<sub>x</sub> is adjusted as follows for higher fuel bound nitrogen contents up to a maximum of 0.030 percent, by weight:

FUEL BOUND NITROGEN ( % by weight )	NO <sub>x</sub> EMISSION LEVELS ( ppmvd @ 15% O <sub>2</sub> )
0.015 or less	42
0.020	44
0.025	46
0.030	48

Using the formula:  $STD = 0.0042 + F$

where:

STD = allowable NO<sub>x</sub> emissions (% by volume at 15% O<sub>2</sub> and on a dry basis)

F = NO<sub>x</sub> emission allowance for fuel bound nitrogen (FBN) defined by the following table:

FUEL BOUND NITROGEN ( % by weight )	F (NO <sub>x</sub> % by volume )
0 < N < 0.015	0
0.015 < N < 0.03	0.04 ( N - 0.015 )

where:

N = nitrogen content of the fuel ( % by weight )

The permittee shall submit fuel bound nitrogen content data for the low sulfur fuel oil to the Southwest District office in Tampa on each occasion that fuel oil is transferred to the storage tanks from any other source. The percent FBN (Z) following each delivery of fuel shall be determined by the following equation:

$$x(Y) + m(n) = (x+m)(Z)$$

where:

x = amount of fuel in the storage tank

Y = % FBN in the storage tank

m = amount of fuel added

n = % FBN of the fuel added

Z = % FBN of composite fuel

- ( a ) Syngas lb/MMBtu values are based on heat input (HHV) to the solid fuel gasifier and includes emissions from the sulfuric acid plant thermal oxidizer. Pollutant concentrations in ppmvd are corrected to 15 percent oxygen.
- ( b ) Annual emission limits ( TPY ) are based on 10 percent annual capacity factor firing fuel oil.
- ( c ) Exclusive of background concentrations.
- ( d ) Excluding sulfuric acid mist.
- ( e ) Sulfuric acid mist emissions assume a maximum of 0.05 percent sulfur, by weight, in the fuel oil.

[PSD-FL-194(E)]

**A.6.** After the demonstration period, the permittee shall operate the combustion turbine in a manner to achieve the lowest possible NO<sub>x</sub> emission rate, but this rate shall not exceed 25 ppmvd corrected to 15 percent oxygen and ISO conditions.

[PSD-FL-194]

A.7. The maximum allowable emissions during the two year demonstration period shall not exceed the following:

POLLUTANT	FUEL	LB / HR *	TPY <sup>a</sup>
NO <sub>x</sub>	Oil <sup>**</sup>	311	N/A
	Syngas	664.2	2,908.3
VOC <sup>b</sup>	Oil	32	N/A
	Syngas	3	38.5
CO	Oil	99	N/A
	Syngas	99	430.1
PM / PM <sub>10</sub> <sup>c</sup>	Oil	17	N/A
	Syngas	17	74.5
Pb	Oil	0.101	N/A
	Syngas	0.023	0.13
SO <sub>2</sub>	Oil	92.2	N/A
	Syngas	518	2,269
Sulfuric Acid <sup>d</sup>	Syngas	55	241
Inorganic Arsenic	Syngas	0.08	0.35
Beryllium	Syngas	0.0001	0.0029
Mercury	Syngas	0.025	0.11

( \*) Emission limitations in lb/hr are 30 day rolling averages.

( \*\*) The emission limit for NO<sub>x</sub> is adjusted as follows for higher fuel bound nitrogen contents up to a maximum of 0.030 percent, by weight:

FUEL BOUND NITROGEN ( % by weight )	NO <sub>x</sub> EMISSION LEVELS ( ppmvd @ 15% O <sub>2</sub> )
0.015 or less	42
0.020	44
0.025	46
0.030	48

Using the formula:  $STD = 0.0042 + F$

where:

STD = allowable NO<sub>x</sub> emissions (% by volume at 15% O<sub>2</sub> and on a dry basis)

F = NO<sub>x</sub> emission allowance for fuel bound nitrogen (FBN) defined by the following table:

FUEL BOUND NITROGEN ( % by weight )	F (NO <sub>x</sub> % by volume )
0 < N < 0.015	0
0.015 < N < 0.03	0.04 ( N - 0.015 )

where:

N = nitrogen content of the fuel ( % by weight )

The permittee shall submit fuel bound nitrogen content data for the low sulfur fuel oil to the Southwest District office in Tampa on each occasion that fuel oil is transferred to the storage tanks from any other source. The percent FBN (Z) following each delivery of fuel shall be determined by the following equation:

$$x(Y) + m(n) = (x+m)(Z)$$

where:

x = amount of fuel in the storage tank

Y = % FBN in the storage tank

m = amount of fuel added

n = % FBN of the fuel added

Z = % FBN of composite fuel

- (a) Annual emission limits ( TPY ) are based on 10 percent annual capacity factor firing fuel oil.
- (b) Exclusive of background concentrations.
- (c) Excluding sulfuric acid mist.
- (d) Sulfuric acid mist emissions assume a maximum of 0.05 percent sulfur, by weight, in the fuel oil.

[PSD-FL-194(A)]

**A.8. Sulfur Dioxide - Sulfur Content.** The maximum sulfur content of the No. 2 fuel oil shall not exceed 0.05 percent, by weight. See specific condition A.51.

[PSD-FL-194]

**A.9. Visible Emissions.** Visible emissions shall not exceed 10 percent opacity when firing syngas and 20 percent opacity when firing No. 2 fuel oil.

[PSD-FL-194]

### **Excess Emissions**

**A.10.** Excess emissions from this emissions unit resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. Best operational practices shall be documented in writing and submitted to the Department. The documentation shall include limitations on excess emissions caused by turbine startup and shall be updated within thirty (30) days of implementation of any changes.

[Rule 62-210.700(1), F.A.C.; and, PSD-FL-194]

**A.11.** Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

{Permitting note: The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS, NESHAP, or Acid Rain program provision.}

**Monitoring of Operations**

**A.12.** At all times, including periods of startup, shutdown and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.

[40 CFR 60.11(d)]

**A.13.** The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG and using water injection to control NO<sub>x</sub> emissions shall operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water to fuel being fired in the turbine. This system shall be accurate to within  $\pm 5.0$  percent and shall be approved by the Administrator.  
[40 CFR 60.334(a); and , PSD-FL-194(A)]

**A.14.** The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG shall monitor sulfur content and nitrogen content of the fuel being fired in the turbine. The frequency of determination of these values shall be as follows:

(1) If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source. Nitrogen oxide continuous emissions monitors may be used to determine the fuel bound nitrogen content of fuel oil combusted in gas turbines subject to this requirement.

(2) If the turbine is supplied its fuel without intermediate bulk storage the values shall be determined and recorded daily. Owners, operators or fuel vendors may develop custom schedules for determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with 40 CFR 60.334(b).

[40 CFR 60.334(b)(1) & (2); and, PSD-FL-194(G)]

**A.15. Determination of Process Variables.**

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

**Test Methods and Procedures**

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**A.16.** To compute the nitrogen oxides emissions, the owner or operator shall use analytical methods and procedures that are accurate to within 5 percent and are approved by the Department to determine the nitrogen content of the fuel being fired.

[40 CFR 60.335(a); and , PSD-FL-194(A)]

**A.17.** During performance tests to determine compliance, measured NO<sub>x</sub> emissions at 15 percent oxygen will be adjusted to ISO ambient atmospheric conditions by the following correction factor:

$$\text{NO}_x = [\text{NO}_x \text{ obs}] [(P_{\text{ref}})^{0.5} / P_{\text{obs}}] e^{19 [H_{\text{obs}} - 0.00633]} [288^\circ \text{K} / T_{\text{amb}}]^{1.53}$$

where:

NO<sub>x</sub> = Emissions of NO<sub>x</sub> at 15 percent oxygen and ISO standard ambient conditions.

NO<sub>x</sub> obs = Measured NO<sub>x</sub> emission at 15 percent oxygen, ppmv.

P<sub>ref</sub> = Reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure.

P<sub>obs</sub> = Measured combustor inlet absolute pressure at test ambient pressure.

e = Transcendental constant ( 2.718 )

H<sub>obs</sub> = Specific humidity of ambient air at test.

T<sub>amb</sub> = Temperature of ambient air at test.

[40 CFR 60.335(c)(1); and, PSD-FL-194(A)]

**A.18.** When determining compliance with 40 CFR 60.332, Subpart GG - Standards of Performance for Stationary Gas Turbines, the monitoring device of 60.334(a) shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with the permitted NO<sub>x</sub> standard at 30, 50, 75, and 100 percent of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer.

[40 CFR 60.335(c)(2); and, PSD-FL-194(A)]

**A.19.** The owner or operator shall determine compliance with the nitrogen oxides and sulfur dioxide standards in 40 CFR 60.332 as follows:

c. U.S. EPA Method 20 (40 CFR 60, Appendix A) shall be used to determine the nitrogen oxides, sulfur dioxide, and oxygen concentrations. The span values shall be 300 ppm of nitrogen oxide and 21 percent oxygen. The NO<sub>x</sub> emissions shall be determined at each of the load conditions specified in 40 CFR 60.335(c)(2).

[40 CFR 60.335(c)(3)]

**A.20. Volatile Organic Compounds.** The test method for volatile organic compounds shall be EPA Method 18, incorporated by reference in Chapter 62-297, F.A.C.

[PSD-FL-194]

**A.21. Carbon Monoxide.** The test method for carbon monoxide shall be EPA Method 10, incorporated by reference in Chapter 62-297, F.A.C.

[PSD-FL-194]

**A.22. PM/PM<sub>10</sub>.** The test method for PM / PM<sub>10</sub> when firing oil shall be EPA Method 5B, incorporated by reference in Chapter 62-297, F.A.C.

[PSD-FL-194]

**A.23.** The owner or operator may determine compliance with the sulfur dioxide standard by calculations based on the fuel analysis for sulfur content. Certified analyses by the appropriate test method from the fuel supplier is acceptable. See specific condition **A.24.**

[PSD-FL-194]

**A.24.** The owner or operator shall determine compliance with the liquid fuel sulfur content standard of 0.05 percent, by weight, and the gaseous fuel sulfur dioxide standard as follows: ASTM D 2880-96, or the latest edition shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-90(94)E-1, D 3031-81(86), D 4084-94, or D 3246-92, or the latest edition, shall be used for the sulfur content of gaseous fuels (incorporated by reference-see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator. See specific conditions **A.5.**, **A.7.** and **A.8.**

[40 CFR 60.335(d); and, PSD-FL-194]

**A.25.** To meet the requirements of 40 CFR 60.334(b), the owner or operator shall use the methods specified in 40 CFR 60.335 (a) and 40 CFR 60.335(d) to determine the nitrogen and sulfur contents of the fuel being burned. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency. See specific condition **A.14.**

[40 CFR 60.335(e)]



**A.26. Visible Emissions.** The test method for visible emissions shall be EPA Method 9, incorporated by reference in Chapter 62-297, F.A.C.

[PSD-FL-194]

**A.27. Lead, Sulfuric Acid Mist, Inorganic Arsenic, Beryllium, and Mercury.** The initial compliance test requirement for these pollutants has been satisfied and no further tests are required.

[PSD-FL-194]

**A.28. Operating Rate During Testing.** Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity (i.e., at less than 90 percent of the maximum operation rate allowed by the permit); in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted, provided however, operations do not exceed 100 percent of the maximum operation rate allowed by the permit. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rule 62-297.310(2), F.A.C.; and, PSD-FL-194(A)]

**A.29. Required Number of Test Runs.** For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

**A.30. Calculation of Emission Rate.** The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

**A.31. Applicable Test Procedures.**

**(a) Required Sampling Time.**

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

**(b) Minimum Sample Volume.** Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

**(c) Required Flow Rate Range.** For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

**(d) Calibration of Sampling Equipment.** Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached to this permit.

**(e) Allowed Modification to EPA Method 5.** When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.

[Rule 62-297.310(4), F.A.C.]

**A.32.** The permittee shall comply with the requirements contained in APPENDIX SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

**A.33. Frequency of Compliance Tests.** The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

**(a) General Compliance Testing.**

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not

require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and

c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

8. Any combustion turbine that does not operate for more than 400 hours per year shall term of its air operation permit.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; and, SIP approved]

**Continuous Monitoring Requirements**

**A.34.** A continuous emission monitoring system (CEMS) shall be installed, operated, and maintained in accordance with 40 CFR 60, Appendix F, and shall meet the performance specifications of 40 CFR 60, Appendix B, to monitor nitrogen oxides and a diluent gas (carbon dioxide or oxygen).  
[PSD-FL-194(A)]

**A.35.** A performance evaluation of the CEMS shall be conducted during any required performance test or within 30 days thereafter in accordance with the applicable performance specifications of 40 CFR 60, Appendix B and at other times as required by the Administrator.  
[40 CFR 60.13(c); and, PSD-FL-194(A)]

**A.36.** The zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts shall be checked at least once daily in accordance with a written procedure. The zero and span shall, at a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications of 40 CFR 60, Appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified.  
[40 CFR 60.13(d)(1); and, PSD-FL-194(A)]

**A.37.** Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d)(1), all continuous monitoring systems shall be in continuous operation and shall meet the minimum frequency of operation as follows:  
(2) All continuous monitoring systems for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.  
[40 CFR 60.13(e); and, PSD-FL-194(A)]

**A.38.** All continuous monitoring systems or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained.  
[40 CFR 60.13(f); and, PSD-FL-194(A)]

**A.39.** For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorded during periods of continuous monitoring system breakdown, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non-reduced form (e.g. ppm pollutant and percent O<sub>2</sub> or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in the subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit. (e.g. rounded to the nearest 1 percent opacity).  
[40 CFR 60.13(h); and, PSD-FL-194(A)]

### Record Keeping and Reporting Requirements

**A.40.** For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions that shall be reported are defined as follows:

a. Nitrogen oxides. Any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with the permitted nitrogen oxide standard by the initial performance test required in 40 CFR 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the initial performance test. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under 40 CFR 60.335(a).

[Rule 62-296.800, F.A.C.; and, 40 CFR 60.334(c)(1)]

**A.41.** The owner or operator required to install a continuous monitoring system (CMS) or monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form [see 40 CFR 60.7(d)] to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or, the CMS data are to be used directly for compliance determination, in which case quarterly reports shall be submitted; or, the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate). Written reports of excess emissions shall include the following information:

(1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.

(2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.

(3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.

(4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)(1), (2), (3), & (4)]

**A.42.** The summary report form shall contain the information and be in the format shown in Figure 1 (attached) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

(1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.

(2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.  
[40 CFR 60.7(d)(1) & (2)]

**A.43.** (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

- (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;
- (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and
- (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).  
[40 CFR 60.7(e)(1)]

**A.44. Malfunction Reporting.** In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]

**A.45.** All recorded data shall be maintained on file by the Source for a period of five years. [Rule 62-213.440, F.A.C.]

**A.46. Test Reports.**

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- (b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
1. The type, location, and designation of the emissions unit tested.
  2. The facility at which the emissions unit is located.
  3. The owner or operator of the emissions unit.
  4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
  5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
  6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
  7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
  8. The date, starting time and duration of each sampling run.
  9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
  10. The number of points sampled and configuration and location of the sampling plane.
  11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
  12. The type, manufacturer and configuration of the sampling equipment used.
  13. Data related to the required calibration of the test equipment.
  14. Data on the identification, processing and weights of all filters used.

15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rules 62-213.440 and 62-297.310(8), F.A.C.]

#### **Miscellaneous Requirements.**

**A.47. Definitions.** For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.  
[40 CFR 60.2; and, Rule 62-204.800(7)(a), F.A.C.]

**A.48. Circumvention.** No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.  
[40 CFR 60.12]

**A.49.** The combustion turbine shall be operated for 12 to 18 months after the demonstration period (estimated to be from Mid-1998 until December 31, 1999) as described in the previous specific condition. During this period, NO<sub>x</sub> emission testing will be performed on the turbine at a regular interval of every two months. The Department shall be provided with the test protocol, including a time schedule, 15 days prior to the initial test. The permittee will provide the Department the emissions test results 30 days after the test is performed. These results are not for compliance purposes. The Department shall be notified and the reasons provided if a scheduled test is delayed or canceled.  
[PSD-FL-194]



**A.50.** One month after the test period ends (estimated to be by February, 2000), the permittee shall submit to the Department a NO<sub>x</sub> recommended BACT Determination as if it were a new source, using the data gathered on this facility, other similar facilities and the manufacturer's research. The Department will make a determination of BACT for NO<sub>x</sub> only and adjust the NO<sub>x</sub> emission limits accordingly.

[PSD-FL-194]

**A.51. Sulfur Content of Fuel.** The maximum sulfur content of the low sulfur fuel oil shall not exceed 0.05 percent, by weight. Compliance shall be demonstrated in accordance with the requirements of 40 CFR 60.334 by testing for sulfur content of the fuel oil in the storage tanks once per day when firing oil. Testing for fuel oil heating value shall also be conducted on the same schedule. See specific condition

**A.8.**

[PSD-FL-194]

**A.52.** [Reserved]

**A.53.** During syngas firing, the SO<sub>2</sub> emission rate shall be monitored by the CEM for purposes of periodic monitoring.

[Applicant agreement with EPA on January 22, 1999]

**A.54. Additional Monitoring for Nitrogen Oxides.** The permittee shall maintain and submit to the Department, on an annual basis for a period of five years from the date the unit begin firing syngas produced from blends of petroleum coke and coal, CEMS data demonstrating that the operational changes did not result in a significant emissions increase of nitrogen oxides when compared to the past actual coal levels. The CEMS data shall be of the periods when the unit is burning syngas produced from petcoke/coal blends containing a maximum amount of petcoke of up to 60 percent, by weight.

[PSD-FL-194(E)]

**A.55. Additional Monitoring for Sulfur Dioxide.** The permittee shall maintain and submit to the Department on an annual basis for a period of five years from the date the unit begin firing syngas produced from blends of petroleum coke and coal, CEMS data demonstrating that the operational changes did not result in a significant emissions increase of sulfur dioxide when compared to the past actual coal levels. The CEMS data shall be of the periods when the unit is burning syngas produced from petcoke/coal blends containing a maximum amount of petcoke of up to 60 percent, by weight.

[PSD-FL-194(E)]

**A.56. Additional Monitoring for Sulfuric Acid Mist.** The permittee shall maintain and submit to the Department on an annual basis for a period of five years from the date the unit begin firing syngas produced from blends of petroleum coke and coal, test results demonstrating that the operation changes did not result in a significant emissions increase of sulfuric acid mist when compared to the past actual coal levels. The sulfuric acid mist emissions shall be based on test results using EPA Method 8. The test shall be conducted when the unit is burning syngas produced from petcoke/coal blends containing a maximum amount of petcoke of up to 60 percent, by weight.

[PSD-FL-194(E)]

**A.57. Recordkeeping.** To determine compliance with the syngas and fuel oil firing heat input limitation, the permittee shall maintain daily records of syngas and fuel oil consumption for the turbine and heating value for each fuel. All records shall be maintained for a minimum of five years after the date of each record and shall be made available to representatives of the Department upon request.

The permittee shall maintain and submit to the Department, on an annual basis for a period of five years from the date the unit begin firing syngas produced from blends of petroleum coke and coal, data demonstrating that the operational change associated with the use of petroleum coke did not result in a significant emission increase pursuant to Rule 62-210.200(12)(d), F.A.C.

[PSD-FL-194(E)]

**Section III. Emissions Unit(s) and Conditions.**

**Subsection B. This section addresses the following emissions unit(s).**

**E.U.**

<b><u>ID No.</u></b>	<b><u>Brief Description</u></b>
-003	120 Million Btu per Hour Auxiliary Boiler

The Auxiliary Boiler produces steam for in-plant use and has a maximum heat input of 120.0 million Btu per hour. The boiler is fired with only very low sulfur fuel oil and has a capacity factor of less than or equal to 35 percent. The boiler can be continuously fired in a standby mode with full operation limited to a maximum of 3,000 hours per year. No add-on emissions control devices are employed by the emissions unit.

{Permitting note(s): The emissions unit is regulated under NSPS - 40 CFR 60, Subpart Db, Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.; Rule 62-212.400(5), F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination, dated February 24, 1994; Rule 62-296.406, F.A.C., Fossil Fuel Steam Generators with less than 250 Million Btu per Hour Heat Input, New and Existing Units. The Auxiliary Boiler began operation in April, 1996.}

**The following specific conditions apply to the emissions unit(s) listed above:**

**Essential Potential to Emit (PTE) Parameters**

**B.1. Permitted Capacity.** The maximum process/operation rate heat input (higher heating value) is 120.0 million Btu per hour.  
[Rules 62-4.160(2), F.A.C. and 62-210.200(PTE), F.A.C.]

**B.2. Emissions Unit Operating Rate Limitation After Testing.** See specific condition **B.25.**  
[Rule 62-297.310(2), F.A.C.]

**B.3. Methods of Operation. Fuels.** This emissions unit fires only very low sulfur No. 2 distillate oil.  
[Rules 62-212.400, 62-212.410, and 62-213.410, F.A.C.; and, PSD-FL-194]

**B.4. Hours of Operation.**  
a. Standby Mode: This emissions unit may operate in a standby mode continuously, i.e., 8,760 hours/year.  
b. Non-Standby Modes: The hours of operation for this emissions unit shall not exceed 3,000 hours/year.  
[Rule 62-210.200(PTE), F.A.C.; and, PSD-FL-194(A)]

**Emission Limitations and Standards**

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**B.5. Sulfur Dioxide.** Sulfur dioxide emissions shall not exceed 0.80 pound per million Btu heat input.  
[40 CFR 60.42b(a) & (j)]

**B.6. Sulfur Dioxide.** Percent reduction requirements are not applicable to affected facilities combusting only very low sulfur oil. The owner or operator of an affected facility combusting very low sulfur oil shall demonstrate that the oil meets the definition of very low sulfur oil by: (1) Following the performance testing procedures as described in 40 CFR 60.45b(c) or 40 CFR 60.45b(d), and following the monitoring procedures as described in 40 CFR 60.47b(a) or 40 CFR 60.47b(b) to determine sulfur dioxide emission rate or fuel oil sulfur content; or (2) maintaining fuel receipts as described in 40 CFR 60.49b(r).  
[40 CFR 60.42b(j)]

**B.7. Sulfur Dioxide - Sulfur Content.** The maximum sulfur content of the very low sulfur No. 2 fuel oil shall not exceed 0.05 percent, by weight. See specific condition **B.52**.  
[PSD-FL-194]

**B.8. Sulfur Dioxide.** Compliance with the emission limits and the fuel oil sulfur limits are determined on a 30-day rolling average basis.  
[40 CFR 60.42b(e)]

**B.9. Particulate Matter.** Particulate matter emissions shall not exceed 43 ng/J (0.10 pound per million Btu) heat input.  
[40 CFR 60.43b(b)]

**B.10. Visible Emissions.** Visible emissions shall not exceed 20 percent opacity (six-minute average), except for one six-minute period per hour during which opacity shall not exceed 27 percent.  
[40 CFR 60.43b(f); and, PSD-FL-194(A)]

**B.11. Nitrogen Oxides.** Emissions of nitrogen oxides (expressed as NO<sub>2</sub>) shall not exceed 0.10 pound per million Btu heat input.  
[40 CFR 60.44b(a); and, PSD-FL-194(A)]

**B.12. Nitrogen Oxides.** Compliance with the emission limits is determined on a 30-day rolling average basis.  
[40 CFR 60.44b(i)]

**Excess Emissions**

**B.13. Sulfur Dioxide.** The sulfur dioxide emission limitations apply at all times, including periods of startup, shutdown and malfunction.  
[40 CFR 60.42b(g)]

**B.14. Particulate Matter and Opacity.** The particulate matter and opacity standards apply at all times, except during periods of startup, shutdown or malfunction.  
[40 CFR 60.43b(g)]

**B.15. Nitrogen Oxides.** The nitrogen oxide standards apply at all times, including periods of startup, shutdown, or malfunction.  
[40 CFR 60.44b(4)]

**B.16.** Excess emissions resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.  
[Rule 62-210.700(1), F.A.C.]

**B.17.** Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.  
[Rule 62-210.700(4), F.A.C.]

{Permitting note: The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS, NESHAP, or Acid Rain program provision.}

**Monitoring of Operations**

**B.18. Determination of Process Variables.**

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.  
[Rule 62-297.310(5), F.A.C.]

**Test Methods and Procedures**

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**B.19. Sulfur Dioxide.** The owner or operator shall determine compliance with the fuel sulfur limit of specific condition **B.7.** by using method ASTM D 2880-71, or the latest edition.  
[PSD-FL-194]

**B.20. Particulate Matter.** The test methods for particulate matter are as follows:

- (1) Method 3B is used for gas analysis when applying Method 5 or Method 17.
- (2) Method 5 or Method 17 shall be used to measure the concentration of particulate matter as follows:
  - (i) Method 5 shall be used at affected facilities without wet flue gas desulfurization (FGD) systems; and
  - (ii) Method 17 may be used at facilities with or without wet scrubber systems provided the stack gas temperature does not exceed a temperature of 160°C (320°F).
- (3) Method 1 is used to select the sampling site and the number of traverse sampling points. The sampling time for each run is at least 120 minutes and the minimum sampling volume is 1.7 dscm (60 dscf) except that smaller sampling times or volumes may be approved by the Administrator when necessitated by process variables or other factors.
- (4) For Method 5, the temperature of the sample gas in the probe and filter holder is monitored and maintained at 160°C (320°F).
- (5) For determination of particulate matter emissions, the oxygen or carbon dioxide sample is obtained simultaneously with each run of Method 5 or Method 17 by traversing the duct at the same sample location.
- (6) For each run using Method 5 or Method 17, the emission rate expressed in nanograms per joule heat input is determined using:
  - (i) The oxygen or carbon dioxide measurements and the particulate matter measurements obtained under this section,
  - (ii) The dry basis F factor, and
  - (iii) The dry basis emission rate calculation procedure contained in Method 19 (appendix A).

[40 CFR 60.46b(d)(1) - (6)]

**B.21. Visible Emissions.** The test method for visible emissions shall be EPA Method 9, incorporated by reference in Chapter 62-297, F.A.C.

[40 CFR 60.46b(d)(7); and, PSD-FL-194]

**B.22. Nitrogen Oxides.** The test method for nitrogen oxides shall be EPA Method 7, 7A, 7C, 7D, or 7E, incorporated by reference in Chapter 62-297, F.A.C.

[PSD-FL-194]

**B.23. Nitrogen Oxides.** The owner or operator of the affected facility shall upon request determine compliance with the nitrogen oxides standard through use of a 30-day performance test. During periods when performance tests are not requested, nitrogen oxides emissions data collected pursuant to 40 CFR 60.48b(g)(1) or 40 CFR 60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emissions reports, but will not be used to determine compliance with the nitrogen oxides emission standards. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly nitrogen oxides emission data for the preceding 30 steam generating unit operating days.  
[40 CFR 60.46b(e)(4)]

**B.24. Required Number of Test Runs.** For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.  
[Rule 62-297.310(1), F.A.C.]

**B.25. Operating Rate During Testing.** Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.  
[Rules 62-297.310(2) & (2)(b), F.A.C.]

**B.26. Calculation of Emission Rate.** The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule.  
[Rule 62-297.310(3), F.A.C.]

**B.27. Applicable Test Procedures.**

**(a) Required Sampling Time.**

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

**(b) Minimum Sample Volume.** Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

**(d) Calibration of Sampling Equipment.** Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached to this permit.

[Rule 62-297.310(4), F.A.C.]

**B.28. Required Stack Sampling Facilities.** When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

**B.29. Frequency of Compliance Tests.** The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

**(a) General Compliance Testing.**

2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid for more than 400 hours other than during startup.



3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

- a. Did not operate; or
- b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

- a. Visible emissions, if there is an applicable standard;
- b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
- c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; and, SIP approved]

**B.30.** By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rule 62-297.310(7)(a)4., F.A.C.]

{Permitting note: Any operational mode where liquid fuel(s) are burned are used to determine the annual hours of operation while burning liquid fuel(s).}

### **Continuous Monitoring Requirements**

**B.31. Sulfur Dioxide.** The owner or operator of an affected facility that combusts very low sulfur oil is not subject to the emission monitoring requirements of 40 CFR 60.47b if the owner or operator obtains fuel receipts as described in 40 CFR 60.49b(r).

[40 CFR 60.45b(j) and 40 CFR 60.47b(f)]

**B.32. Particulate Matter.** The owner or operator of an affected facility shall install, calibrate, maintain, and operate a continuous monitoring system for measuring opacity of emissions discharged to the atmosphere and record the output of the system.

[40 CFR 60.48b(a)]

**B.33. Nitrogen Oxides.** The owner or operator of an affected facility subject to the nitrogen oxides standards under 40 CFR 60.44b shall install, calibrate, maintain, and operate a continuous monitoring system for measuring nitrogen oxides emissions discharged to the atmosphere and record the output of the system.

[40 CFR 60.48b(b)]

**B.34. Nitrogen Oxides.** The continuous monitoring system shall be operated and data recorded during all periods of operation of the affected facility except for continuous monitoring system breakdowns and repairs. Data is recorded during calibration checks, and zero and span adjustments.

[40 CFR 60.48b(c)]

**B.35. Nitrogen Oxides.** The 1-hour average nitrogen oxides emission rates measured by the continuous nitrogen oxides monitor required by 40 CFR 60.48b(b) and required under 40 CFR 60.13(h) shall be expressed in ng/J or lb/million Btu heat input and shall be used to calculate the average emission rates under 40 CFR 60.44b. The 1-hour averages shall be calculated using the data points required under 40 CFR 60.13(b). At least 2 data points must be used to calculate each 1-hour average.

[40 CFR 60.48b(d)]

**B.36. Nitrogen Oxides.** For affected facilities combusting oil, the span value for nitrogen oxides is 500 ppm.  
[40 CFR 60.48b(e)(2)]

**B.37. Nitrogen Oxides.** When nitrogen oxides emission data are not obtained because of continuous monitoring system breakdowns, repairs, calibration checks and zero and span adjustments, emission data will be obtained by using standby monitoring system, Method 7, Method 7A, or other approved reference methods to provide emission data for a minimum of 75 percent of the operating hours in each steam generating unit operating day, in at least 22 out of 30 successive steam generating unit operating days.  
[40 CFR 60.48b(f)]

### **Recordkeeping and Reporting Requirements**

**B.38.** The owner or operator of an affected facility shall record and maintain records of the amount of fuel combusted during each day and calculate the annual capacity factor for the fuel for each calendar quarter. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month.  
[40 CFR 60.49b(d)]

**B.39.** For facilities subject to the opacity standard under 40 CFR 60.43b, the owner or operator shall maintain records of opacity.  
[40 CFR 60.49b(f)]

**B.40. Nitrogen Oxides.** The owner or operator of an affected facility subject to the nitrogen oxides standards shall maintain records of the following information for each steam generating unit operating day:

- (1) Calendar date.
- (2) The average hourly nitrogen oxides emission rates (expressed as NO<sub>2</sub>) (ng/J or lb/million Btu heat input) measured or predicted.
- (3) The 30-day average nitrogen oxides emission rates (ng/J or lb/million Btu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days.
- (4) Identification of the steam generating unit operating days when the calculated 30-day average nitrogen oxides emission rates are in excess of the nitrogen oxides emissions standards under 40 CFR 60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken.
- (5) Identification of the steam generating unit operating days for which pollutant data have not been obtained, including the reasons for not obtaining sufficient data and a description of corrective actions taken.
- (6) Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data.
- (7) Identification of "F" factor used for calculations, method of determination, and type of fuel combusted.

- (8) Identification of the times when pollutant concentration exceeded full span of the continuous monitoring system.
- (9) Descriptions of any modifications to the continuous monitoring system that could affect the ability of the continuous monitoring system to comply with Performance Specification 2 or 3.
- (10) Results of daily CEMS drift tests and quarterly accuracy assessments as required under 40 CFR 60 Appendix F, Procedure 1.  
[40 CFR 60.49b(g)]

**B.41. Excess Emissions.** The owner or operator of any affected facility in any category listed in paragraphs (1) or (2) below is required to submit excess emission reports for any calendar quarter during which there are excess emissions from the affected facility. If there are no excess emissions during the calendar quarter, the owner or operator shall submit a report semiannually stating that no excess emissions occurred during the semiannual reporting period.

- (1) Any affected facility subject to the opacity standards under 40 CFR 60.43b(e) or to the operating parameter monitoring requirements under 40 CFR 60.13(I)(1).
- (2) Any affected facility that is subject to the nitrogen oxides standard under 40 CFR 60.44b, and that
  - (i) Combusts natural gas, distillate oil, or residual oil with a nitrogen content of 0.3 weight percent or less, or
  - (ii) Has a heat input capacity of 73 MW (250 million Btu/hour) or less and is required to monitor nitrogen oxides emissions on a continuous basis under 40 CFR 60.48b(g)(1) or steam unit operating conditions under 40 CFR 60.48b(g)(2).
- (3) For the purpose of 40 CFR 60.43b, excess emissions are defined as all 6-minute periods during which the average opacity exceeds the opacity standards under 40 CFR 60.43b(f).
- (4) For purposes of 40 CFR 60.48b(g)(1), excess emissions are defined as any calculated 30-day rolling average nitrogen oxides emission rate, as determined under 40 CFR 60.46b(e), which exceeds the applicable emission limits in 40 CFR 60.44b.  
[40 CFR 60.49b(h)]

**B.42.** The owner or operator of any affected facility subject to the continuous monitoring requirements for nitrogen oxides under 40 CFR 60.48b shall submit a quarterly report containing the information recorded under 40 CFR 60.49b(g). All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.  
[40 CFR 60.49b(i)]

**B.43.** The owner or operator of any affected facility subject to the sulfur dioxide standards under 40 CFR 60.42b shall submit quarterly reports to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.  
[40 CFR 60.49b(j)]

**B.44.** The owner or operator of any affected facility who elects to demonstrate that the affected facility combusts only very low sulfur oil under 40 CFR 60.42b(j)(2) shall obtain and maintain at the affected facility fuel receipts from the fuel supplier which certify that the oil meets the definition of distillate oil as defined in 40 CFR 60.41b. For the purposes of this section, the oil need not meet the fuel nitrogen content specification in the definition of distillate oil. Quarterly reports shall be submitted to the Administrator certifying that only very low sulfur oil meeting this definition was combusted in the affected facility during the preceding quarter.

[40 CFR 60.49b(r)]

**B.45.** In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

**B.46.** All recorded data shall be maintained on file by the Source for a period of five years.

[Rule 62-213.440, F.A.C.]

**B.47.** Submit to the Department a written report of emissions in excess of emission limiting standards for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years.

[Rules 62-213.440, F.A.C.]

**B.48. Test Reports.**

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.

7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rules 62-213.440 and 62-297.310(8), F.A.C.]

**B.49.** Records of the hours of non-standby operation of the auxiliary boiler will be kept for purposes of periodic monitoring.

[Applicant agreement with EPA on January 22, 1999]

#### **Miscellaneous Requirements.**

**B.50. Definitions.** For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.

[40 CFR 60.2; and, Rule 62-204.800(7)(a), F.A.C.]

**B.51. Circumvention.** No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.  
[40 CFR 60.12]

**B.52. Sulfur Content of Fuel.** The maximum sulfur content of the low sulfur fuel oil shall not exceed 0.05 percent, by weight. Compliance shall be demonstrated by testing for sulfur content of the fuel oil in the storage tanks once per day when firing oil. Testing for fuel oil heating value shall also be conducted on the same schedule. See specific condition **B.7.**  
[PSD-FL-194]

**B.53.** The permittee shall comply with the requirements contained in Appendix 40 CFR 60, Subpart A, attached to this permit.  
[Rule 62-204.800(7)(d), F.A.C.]

**Section III. Emissions Unit(s) and Conditions.**

**Subsection C. This section addresses the following emissions unit(s).**

**E.U.**

<b><u>ID No.</u></b>	<b><u>Brief Description</u></b>
-004	Sulfuric Acid Plant

The sulfuric acid plant takes a sulfur gas stream from the solid fuel gasification plant's hot gas cleanup or cold gas cleanup systems and converts it to sulfuric acid using the double contact process. The sulfuric acid plant has a 15 million Btu per hour, propane fired, H<sub>2</sub>S to SO<sub>2</sub> conversion furnace which vents to the atmosphere only during warm-up; and a 9 million Btu per hour, propane fired, non-contact SO<sub>2</sub> to SO<sub>3</sub> converter preheater which is vented to the atmosphere. The sulfuric acid plant has a maximum production rate of 77,640 tons per year of 100 percent sulfuric acid.

{Permitting note(s): The emissions unit is regulated under Rule 62-296.402, F.A.C., Sulfuric Acid Plants}

**The following specific conditions apply to the emissions unit(s) listed above:**

**Essential Potential to Emit (PTE) Parameters**

**C.1. Permitted Capacity.** Plant production shall not exceed 77,640 tons per year of 100 percent sulfuric acid.

[Rules 62-4.160(2), F.A.C. and 62-210.200(PTE), F.A.C.]

{Permitting note: The maximum hourly production rate indicated in the permit application is 8.90 tons per hour of 100 percent sulfuric acid.}

**C.2. Emissions Unit Operating Rate Limitation After Testing.** See specific condition C.16.

[Rule 62-297.310(2), F.A.C.]

**C.3. Methods of Operation. Fuels.** The conversion furnace fires only propane.

[Rule 62-213.410, F.A.C.]

**C.4. Hours of Operation.** This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year.

[Rule 62-210.200(PTE), F.A.C.]



**Emission Limitations and Standards**

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**C.5. Visible Emissions.** Visible emissions shall not exceed ten percent opacity.  
[Rule 62-296.402(2)(a), F.A.C.]

**C.6. Sulfur Dioxide.** Sulfur dioxide emissions shall not exceed four pounds per ton of 100 percent acid produced.  
[Rule 62-296.402(2)(b), F.A.C.]

**C.7. Acid Mist.** Acid mist shall not exceed 0.15 pound per ton of 100 percent acid produced.  
[Rule 62-296.402(2)(c), F.A.C.]

**Excess Emissions**

**C.8.** Excess emissions from this emissions unit resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. Best operational practices shall be documented in writing and submitted to the Department.  
[Rule 62-210.700(1), F.A.C.]

**C.9.** Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.  
[Rule 62-210.700(4), F.A.C.]

**Monitoring of Operations**

**C.10. Determination of Process Variables.**

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value. [Rule 62-297.310(5), F.A.C.]

**C.11.** The owner or operator shall observe and record a quantified visible emission observation, six minutes in duration, for the sulfuric acid plant on a daily basis, for the purpose of periodic monitoring. [Applicant agreement with EPA on January 22, 1999]

### **Test Methods and Procedures**

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**C.12.** Visible Emissions. The test method for visible emissions shall be DEP Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C. See specific condition C.12. [Rule 62-296.402(3)(a), F.A.C.]

**C.13.** DEP Method 9. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:

1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.
2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:
  - a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
  - b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value.

[Rule 62-297.401, F.A.C.]

**C.14. Acid Mist/Sulfur Dioxide.** The test method for acid mist/sulfur dioxide shall be EPA Method 8, incorporated and adopted by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 40 dry standard cubic feet.

[Rule 62-296.402(3)(b), F.A.C.]

**C.15. Required Number of Test Runs.** For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

**C.16. Operating Rate During Testing.** Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

**C.17. Calculation of Emission Rate.** The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

**C.18. Applicable Test Procedures.**

**(a) Required Sampling Time.**

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. **Opacity Compliance Tests.** When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

**(d) Calibration of Sampling Equipment.** Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached to this permit.

[Rule 62-297.310(4), F.A.C.]

**C.19. Required Stack Sampling Facilities.** When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

**C.20. Frequency of Compliance Tests.** The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

**(a) General Compliance Testing.**

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

- a. Visible emissions, if there is an applicable standard;
- b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
- c. Each NESHAP pollutant, if there is an applicable emission standard.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; and, SIP approved]

### **Record keeping and Reporting Requirements**

**C.21.** In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

**C.22.** All recorded data shall be maintained on file by the Source for a period of five years.

[Rule 62-213.440, F.A.C.]

**C.23. Test Reports.**

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- (b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
1. The type, location, and designation of the emissions unit tested.
  2. The facility at which the emissions unit is located.
  3. The owner or operator of the emissions unit.
  4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
  5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
  6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
  7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
  8. The date, starting time and duration of each sampling run.
  9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
  10. The number of points sampled and configuration and location of the sampling plane.
  11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
  12. The type, manufacturer and configuration of the sampling equipment used.
  13. Data related to the required calibration of the test equipment.
  14. Data on the identification, processing and weights of all filters used.
  15. Data on the types and amounts of any chemical solutions used.
  16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
  17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.

18. All measured and calculated data required to be determined by each applicable test procedure for each run.

19. The detailed calculations for one run that relate the collected data to the calculated emission rate.

20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.

21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rules 62-213.440 and 62-297.310(8), F.A.C.]

**C.24.** Record, in tons, the daily production of 100 percent sulfuric acid for purposes of periodic monitoring.

[Applicant agreement with EPA on January 22, 1999]

**Section III. Emissions Unit(s) and Conditions.**

**Subsection D. This section addresses the following emissions unit(s).**

**E.U.**

<b><u>ID No.</u></b>	<b><u>Brief Description</u></b>
-005	Solid Fuel Handling System

The solid fuel handling system consists of a bottom unloading station where water/surfactant spray is applied to the incoming fuel as needed for dust control. The system also includes enclosed conveying systems, rubber skirted drop points from bins, two fuel silos with an associated baghouse, a fuel surge bin with associated baghouse, and two rod mill crushers for slurry production.

Solid fuel is received by truck and is bottom unloaded to the fuel unloading bin. Fugitive emissions are controlled by water spray with surfactant applied at the unloading bin as needed. Fuel is conveyed via enclosed conveyor from the unloading bin to the fuel storage silos. The transfer points from the bin to the belts are rubber skirted. Fugitive emissions from the fuel silos are controlled by an associated baghouse. Fuel is then reclaimed from the silos via enclosed conveyors to the surge bin inside the slurry preparation building. Fugitive emissions from the surge bin are controlled by an associated baghouse. Fuel and water are then mixed in the rod mill crushers to produce a coal slurry.

{Permitting note(s): The emissions unit is regulated under 40 CFR 60, Subpart Y, Standards of Performance for Coal Preparation Plants; and, Rule 212.400(5), F.A.C., Prevention of Significant Deterioration (PSD)}

**The following specific conditions apply to the emissions unit(s) listed above:**

**Essential Potential to Emit (PTE) Parameters**

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**D.1. Methods of Operation.** Particulate matter emissions from the handling of solid fuels shall be controlled by enclosing all solid fuel storage, conveyors and conveyor transfer points. Water sprays or chemical wetting agents and stabilizers shall be applied to uncovered storage piles, roads, handling equipment, etc. during dry periods, as necessary, to all facilities to maintain the opacity specified in specific condition **D.3.**

[Rule 62-213.410, F.A.C.; and, PSD-FL-194(E)]

**D.2. Hours of Operation.** This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200(PTE), F.A.C.]



**Emission Limitations and Standards**

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**D.3. Visible Emissions.** Visible emissions shall be less than or equal to five percent opacity.  
[PSD-FL-194(A)]

**Test Methods and Procedures**

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**D.4. Visible Emissions.** The test method for visible emissions shall be EPA Method 9, incorporated by reference in Chapter 62-297, F.A.C. The test shall be conducted annually.  
[PSD-FL-194 and 40 CFR 60.254(b)(2)]

**D.5. Frequency of Compliance Tests.** The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

**(a) General Compliance Testing.**

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate;

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

**(b) Special Compliance Tests.** When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.  
[Rule 62-297.310(7), F.A.C.; and, SIP approved]

**Recordkeeping and Reporting Requirements**

**D.6.** All recorded data shall be maintained on file by the Source for a period of five years.  
[Rule 62-213.440, F.A.C.]

**D.7. Test Reports.**

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- (b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
  - 1. The type, location, and designation of the emissions unit tested.
  - 2. The facility at which the emissions unit is located.
  - 3. The owner or operator of the emissions unit.
  - 4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
  - 5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
  - 6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
  - 7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.

8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rules 62-213.440 and 62-297.310(8), F.A.C.]

### **Section III. Emissions Unit(s) and Conditions.**

#### **Subsection E. This section addresses the following emissions unit(s).**

##### **E.U.**

<b><u>ID No.</u></b>	<b><u>Brief Description</u></b>
-006	Solid Fuel Gasification System

The solid fuel gasification system converts solid fuel {coal or blends of up to 60 percent petroleum coke (petcoke) and 40 percent bituminous coal} into syngas for the purpose of electric generation.

{Permitting note(s): The emissions unit is regulated under Rule 212.400(5), F.A.C., Prevention of Significant Deterioration (PSD)}

#### **The following specific conditions apply to the emissions unit(s) listed above:**

##### **Essential Potential to Emit (PTE) Parameters**

**E.1. Permitted Capacity.** Solid fuels input to the solid fuel gasification plant shall consist of coal or coal/petroleum coke blends containing a maximum of 60.0 percent petroleum coke by weight. The maximum input of solid fuels to the solid fuel gasification plant shall not exceed 2,325 tons per day, on a dry basis. The maximum weight of the petroleum coke blended shall not exceed 1,395 tons per day, on a dry basis. The maximum sulfur content of the blended fuel shall not exceed 3.5 percent by weight. [Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; and, PSD-FL-194(E)]

**E.2. Hours of Operation.** This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200(PTE), F.A.C.]

##### **Monitoring of Operations**

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

**E.3.** Compliance with the solid fuel sulfur content standard of 3.5 percent, by weight, will be determined by sampling each unique fuel blend prior to gasification by the owner/operator or the vendor as follows: using appropriate ASTM methods such as, ASTM D2013-72, ASTM D3177-75, and ASTM D4239-85, or latest ASTM edition methods. See Specific Condition **E.1.** [40 CFR 60.335(d); and, PSD-FL-194(E)]

**E.4.** Record daily the actual solid fuel input to the emissions unit, in tons per day. [Rule 62-213.440(1)(b), F.A.C.]

**Recordkeeping and Reporting Requirements**

**E.5. Recordkeeping.** Written or electronic records verifying that the coal/petroleum coke blends input to the solid fuel gasification system have not exceeded the 60.0 percent (1,395 tons per day) maximum petroleum coke by weight limit and the blended fuel sulfur content of 3.5 percent by weight limit specified by Specific Condition **E.1.**, shall be maintained and submitted to the Department's Southwest District Office with each annual report. These records shall be generated each time a new shipment of coal/petroleum coke fuel is received or solid fuel is gasified.

[PSD-FL-194(E)]

**E.6.** All recorded data shall be maintained on file by the Source for a period of five years.

[Rule 62-213.440, F.A.C.]

**Section IV. This section is the Acid Rain Part.**

**Operated by:** Tampa Electric Company  
**ORIS code:** 7242

**Subsection A. This subsection addresses Acid Rain, Phase II.**

The emissions unit listed below is regulated under Acid Rain, Phase II.

**E.U.**

<u><b>ID No.</b></u>	<u><b>Brief Description</b></u>
-001	260 MW Combined Cycle Combustion Turbine

**A.1.** The Phase II permit application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain unit must comply with the standard requirements and special provisions set forth in the application listed below:

- a. DEP Form No. 62-210.900(1)(a), dated 7-1-95  
 [Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

**A.2.** Sulfur dioxide (SO<sub>2</sub>) allowance allocations requirements for each Acid Rain unit are as follows:

<u><b>E.U. ID No.</b></u>	<u><b>EPA ID</b></u>	<u><b>Year</b></u>	<b>2000</b>	<b>2001</b>	<b>2002</b>	<b>2003</b>	<b>2004</b>
-001	**1	SO <sub>2</sub> allowances, under Table 2 or 3 of 40 CFR Part 73	0*	0*	0*	0*	0*

\* The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 or 3 of 40 CFR 73.

**A.3. Emission Allowances.** Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

1. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
2. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
3. Allowances shall be accounted for under the Federal Acid Rain Program.  
 [Rule 62-213.440(1)(c), F.A.C.]

**A.4. Fast-Track Revisions of Acid Rain Parts.** Those Acid Rain sources making a change described at Rule 62-214.370(4), F.A.C., may request such change as provided in Rule 62-213.413, F.A.C., Fast-Track Revisions of Acid Rain Parts.  
[Rules 62-213.413 and 62-214.370(4), F.A.C.]

**A.5. Comments, notes, and justifications:**  
None

**Appendix U-1, List of Unregulated Emissions Units and/or Activities.**

Tampa Electric Company      **PROPOSED Permit Revision No.:** 1050233-009-AV  
Polk Power Station            **Facility ID No.:** 1050233

---

Unregulated Emissions Units and/or Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither ‘regulated emissions units’ nor ‘insignificant emissions units’.

**E.U. ID**

<b><u>No.</u></b>	<b><u>Brief Description of Emissions Units and/or Activity</u></b>
-007	One or more emergency generators which are not subject to the Acid Rain Program and have a total fuel consumption, in the aggregate, of 32,000 gallons per year or less of diesel fuel, 4,000 gallons per year or less of gasoline, 4.4 million cubic feet per year or less of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.
-008	One or more heating units and general purpose internal combustion engines which are not subject to the Acid Rain Program and have a total fuel consumption, in the aggregate, of 32,000 gallons per year or less of diesel fuel, 4,000 gallons per year or less of gasoline, 4.4 million cubic feet per year or less of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.

[electronic file name: 1050233u.doc]



## Appendix I-1, List of Insignificant Emissions Units and/or Activities.

Tampa Electric Company  
Polk Power Station

**PROPOSED Permit Revision No.:** 1050233-009-AV  
**Facility ID No.:** 1050233

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62.210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

### Brief Description of Emissions Units and/or Activities

1. Brazing, soldering and welding
2. Parts cleaning and degreasing at work stations with lids closed when not in use
3. Storage tanks <550 gallons
4. Non-HAP inorganic substance storage tanks >550 gallons
5. No. 2 fuel oil storage tanks >550 gallons
6. Laboratory equipment used exclusively for chemical or physical analyses
7. Vehicle refueling operations
8. Fire and safety equipment
9. Turbine vapor extractor
10. Covered belt conveyors transferring wet material
11. Sand blasting and grit blasting where temporary total enclosures are used to contain particulate
12. Equipment used for steam cleaning
13. Vacuum pumps used for steam cleaning
14. Equipment used exclusively for space heating, excluding boilers
15. Surface coatings operations utilizing 6.0 gallons per day or less, averaged monthly, of coatings containing greater than 5.0 percent VOC, by volume
16. Surface coating operations utilizing only coatings containing 5.0 percent or less VOCs, by volume
17. Degreasing units using heavier-than-air vapors exclusively, except any unit using or emitting any substance classified as a hazardous air pollutant

## Appendix H-1, Permit History/ID Number Changes

Tampa Electric Company  
Polk Power Station

**PROPOSED Permit Revision No.:** 1050233-009-AV  
**Facility ID No.:** 1050233

---

**Permit History (for tracking purposes):**

E.U.

<u>ID No</u>	<u>Description</u>	<u>Permit No.</u>	<u>Effective Date</u>	<u>Expiration Date</u>	<u>Extended Date</u>	<u>Project Type<sup>3</sup></u>
-001	260 MW Coal Gasification Combined Cycle CT	PSD-FL-194 PA 92-32	02/24/94 11/29/93			
-001	260 MW Coal Gasification Combined Cycle CT	1050233-001-AV 1050233-008-AV 1050233-009-AV	01/01/00 09/03/01	12/31/04 12/31/04 12/31/04		Initial Revision Revision
-003	102 Million Btu per Hour Auxiliary Boiler	1050233-001-AV	01/01/00	12/31/04		Initial
-004	Sulfuric Acid Plant	1050233-001-AV	01/01/00	12/31/04		Initial
-005	Solid Fuel Handling System	1050233-001-AV 1050233-008-AV	01/01/00 09/03/01	12/31/04 12/31/04		Initial Revision
-006	Solid Fuel Gasification System	1050233-001-AV 1050233-008-AV	01/01/00 09/03/01	12/31/04 12/31/04		Initial Revision

---

**(if applicable) ID Number Changes (for tracking purposes):**

From: **Facility ID No.:** 40TPA050233  
To: **Facility ID No.:** 1050233

---

**Notes:**

- 1 - AO permit(s) automatic extension(s) in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.
- 2 - AC permit(s) automatic extension(s) in Rule 62-213.420(1)(a)4., F.A.C., effective 03/20/96.  
{Rule 62-213.420(1)(b)2., F.A.C., allows Title V Sources to operate under existing valid permits that were in effect at the time of application until the Title V permit becomes effective}
- 3 - Project Type (select one): Initial; Revision; Renewal; Administrative Correction; or, No Change.

**Table 1-1, Summary of Air Pollutant Standards and Terms**

Tampa Electric Company  
Polk Power Station

PROPOSED Permit Revision No.: 1050233-009-AV  
Facility ID No.: 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.      Brief Description  
[001]            260 MW Combined Cycle Combustion Turbine

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
SO <sub>2</sub>	Oil	10% Capacity	0.05% sulfur by weight					PSD-FL-194	III.A.3. & III.A.8.
VE	Oil	10% Capacity	20 % opacity					PSD-FL-194	III.A.3. & III.A.9.
VE	Syngas	8,760	10% opacity					PSD-FL-194	III.A.9.
<b>2 YEAR DEMONSTRATION PERIOD</b>									
NO <sub>x</sub>	Oil	10% Capacity	42 to 48 ppmvd	311	N/A			PSD-FL-194(A)	III.A.3. & III.A.7.
NO <sub>x</sub>	Syngas	8,760		664.2	2,908.3			PSD-FL-194(A)	III.A.7.
VOC	Oil	10% Capacity		32	N/A			PSD-FL-194(A)	III.A.3. & III.A.7.
VOC	Syngas	8,760		3	38.5			PSD-FL-194(A)	III.A.7.
CO	Oil	10% Capacity		99	N/A			PSD-FL-194(A)	III.A.3. & III.A.7.
CO	Syngas	8,760		98	430.1			PSD-FL-194(A)	III.A.7.
PM / PM <sub>10</sub>	Oil	10% Capacity		17	N/A			PSD-FL-194(A)	III.A.3. & III.A.7.
PM / PM <sub>10</sub>	Syngas	8,760		17	74.5			PSD-FL-194(A)	III.A.7.
Pb	Oil	10% Capacity		0.101	N/A			PSD-FL-194(A)	III.A.3. & III.A.7.
Pb	Syngas	8,760		0.023	0.13			PSD-FL-194(A)	III.A.7.
SO <sub>2</sub>	Oil	10% Capacity		92.2	N/A			PSD-FL-194(A)	III.A.3. & III.A.7.
SO <sub>2</sub>	Syngas	8,760		518	2269			PSD-FL-194(A)	III.A.7.
Sulfuric Acid	Syngas	8,760		55	241			PSD-FL-194(A)	III.A.7.
Inorganic Arsenic	Syngas	8,760		0.08	0.35			PSD-FL-194(A)	III.A.7.
Beryllium	Syngas	8,760		0.0001	0.0029			PSD-FL-194(A)	III.A.7.
Mercury	Syngas	8,760		0.025	0.11			PSD-FL-194(A)	III.A.7.
<b>POST DEMONSTRATION PERIOD</b>									
NO <sub>x</sub>	Oil	10% Capacity	42 to 48 ppmvd	311	N/A			PSD-FL-194(A)	III.A.3., III.A.5. & III.A.6.
NO <sub>x</sub>	Syngas	8,760	25 ppmvd	220.25	1,032.9			PSD-FL-194(A)	III.A.5. & III.A.6.
VOC	Oil	10% Capacity	0.028 lb / MMBtu	32	N/A			PSD-FL-194(A)	III.A.3. & III.A.5.
VOC	Syngas	8,760	0.0017 lb / MMBtu	3	38.5			PSD-FL-194(A)	III.A.5.
CO	Oil	10% Capacity	40 ppmvd	99	N/A			PSD-FL-194(A)	III.A.3. & III.A.5.
CO	Syngas	8,760	25 ppmvd	98	430.1			PSD-FL-194(A)	III.A.5.
PM / PM <sub>10</sub>	Oil	10% Capacity	0.009 lb / MMBtu	17	N/A			PSD-FL-194(A)	III.A.3. & III.A.5.
PM / PM <sub>10</sub>	Syngas	8,760	0.013 lb / MMBtu	17	74.5			PSD-FL-194(A)	III.A.5.
Pb	Oil	10% Capacity	5.30E-5 lb / MMBtu	0.101	N/A			PSD-FL-194(A)	III.A.3. & III.A.5.
Pb	Syngas	8,760	2.41E-6 lb / MMBtu	0.0035	0.067			PSD-FL-194(A)	III.A.5.
SO <sub>2</sub>	Oil	10% Capacity	0.048 lb / MMBtu	92.2	N/A			PSD-FL-194(A)	III.A.3. & III.A.5.
SO <sub>2</sub>	Syngas	8,760	0.17 lb / MMBtu	357	1,563.7			PSD-FL-194(A)	III.A.5.
Sulfuric Acid	Syngas	8,760		55	241			PSD-FL-194(A)	III.A.5.
Inorganic Arsenic	Syngas	8,760		0.0006	0.019			PSD-FL-194(A)	III.A.5.
Beryllium	Syngas	8,760		0.0001	0.0029			PSD-FL-194(A)	III.A.5.
Mercury	Syngas	8,760		0.0034	0.017			PSD-FL-194(A)	III.A.5.

Notes:  
\* The "Equivalent Emissions" listed are for informational purposes only.

**Table 1-1, Summary of Air Pollutant Standards and Terms**

Tampa Electric Company  
Polk Power Station

PROPOSED Permit Revision No.: 1050233-008-AV  
Facility ID No.: 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

**E.U. ID No.**      **Brief Description**  
I-003              120 Million Btu per Hour Auxiliary Boiler

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
SO <sub>2</sub>	Oil	8,760	0.80 lb / MMBtu			95.0	392.8**	40CFR60.42b(a)&(i)	III.B.1., III.B.4. & III.B.5.
SO <sub>2</sub>	Oil	8,760	0.05% sulfur by weight					PSD-FL-194	III.B.7.
PM	Oil	8,760	0.10 lb / MMBtu			12.0	12.0	40CFR60.43b(b)	III.B.1., III.B.4. & III.B.9.
VE	Oil	8,760	20% except 27% one six-min. / hr					40CFR60.43b(f) & PSD-FL-194(A)	III.B.10.
NO <sub>x</sub>	Oil	8,760	0.10 lb / MMBtu			12.0	12.0	40CFR60.44b(a) & PSD-FL-194(A)	III.B.1., III.B.4. & III.B.11.

Notes:  
 \* The "Equivalent Emissions" listed are for informational purposes only.  
 \*\* Based on 3,000 hrs. at capacity and 5,760 hrs. at less than capacity (capacity is defined as 90-100% of maximum operation rate)

{electronic file name: 10502331.xls}

**Table 1-1, Summary of Air Pollutant Standards and Terms**

Tampa Electric Company  
Polk Power Station

PROPOSED Permit Revision No.: 1050233-009-AV  
Facility ID No.: 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.      **Brief Description**  
[-004]              Sulfuric Acid Plant

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
VE	Propane	8,760	10% opacity					62-296.402(2)(a)	III.C.5.
SO <sub>2</sub>	Propane	8,760	4 lb / ton 100% acid			35.6	155.3	62-296.402(2)(b)	III.C.1. & III.C.6.
Acid Mist	Propane	8,760	0.15 lb / ton 100% acid			1.34	5.9	62-296.402(2)(c)	III.C.1. & III.C.7.

Notes:  
\* The "Equivalent Emissions" listed are for informational purposes only.

[electronic file name: 10502331.xls]

**Table 1-1, Summary of Air Pollutant Standards and Terms**

Tampa Electric Company  
Polk Power Station

PROPOSED Permit Revision No.: 1050233-009-AV  
Facility ID No.: 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.      Brief Description  
[ -005]            Solid Fuel Handling System

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
VE		8,760	5% opacity					PSD-FL-194(A)	III.D.3.

Notes:  
\* The "Equivalent Emissions" listed are for informational purposes only.

[electronic file name: 10502331.xls]

**Table 1-1, Summary of Air Pollutant Standards and Terms**

Tampa Electric Company  
Polk Power Station

PROPOSED Permit Revision No.: 1050233-009-AV  
Facility ID No.: 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

**E.U. ID No.**      **Brief Description**  
[-006]              Solid Fuel Gasification System

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
	coal/petcoke	8,760	2.325 tons / day coal 3.5% Sulfur, by weight					PSD-FL-194 PSD-FL-194(E)	III.E.1. III.E.1.

Notes:  
\* The "Equivalent Emissions" listed are for informational purposes only.

[electronic file name: 10502331.xls]

**Table 2-1, Summary of Compliance Requirements**

Tampa Electric Company  
Polk Power Station

PROPOSED Permit Revision No.: 1050233-009-AV  
Facility ID No.: 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

**E.U. ID No.**            **Brief Description**  
[-001]                    260 MW Combined Cycle Combustion Turbine

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	Compliance	
						CMS**	See permit condition(s)
NO <sub>x</sub>	All	EPA Method 20	Annual	1-Jun-96	1-hour	Yes	III.A.19. & III.A.34.
SO <sub>2</sub>	All	EPA Method 20	Annual	1-Jun-96	1-hour		III.A.19. & III.A.23.
VOC	All	EPA Method 18	Renewal	1-Jun-96	1-hour		III.A.20.
CO	All	EPA Method 10	Annual	1-Jun-96	1-hour		III.A.21.
PM / PM <sub>10</sub>	Oil	EPA Method 5B	Renewal	1-Jun-96	1-hour		III.A.22.
SO <sub>2</sub> % Sulfur	All	ASTM Methods	Daily / Transfer	1-Jun-96			III.A.24.
VE	All	EPA Method 9	Annual	1-Jun-96	30-minutes		III.A.26.
Pb	All		Initial Only	1-Jun-96			III.A.27.
Sulfuric Acid Mist	Syngas		Initial Only	1-Jun-96			III.A.27.
Inorganic Arsenic	Syngas		Initial Only	1-Jun-96			III.A.27.
Beryllium	Syngas		Initial Only	1-Jun-96			III.A.27.
Mercury	Syngas		Initial Only	1-Jun-96			III.A.27.

Notes:  
 \* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.  
 \*\*CMS [=] continuous monitoring system

[electronic file name: 10502332.xls]



**Table 2-1, Summary of Compliance Requirements**

Tampa Electric Company  
Polk Power Station

**PROPOSED Permit Revision No.:** 1050233-009-AV  
**Facility ID No.:** 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

**E.U. ID No.**      **Brief Description**

[-003]              120 Million Btu per Hour Auxiliary Boiler

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
PM	Oil	EPA Method 5 or 17	Renewal	1-Jun-96	120 minutes		III.B.20.
VE	Oil	EPA Method 9	Annual	1-Jun-96	30-minutes	Yes	III.B.21.
NO <sub>x</sub>	Oil	EPA Method 7, 7A, 7C, 7D, or 7E	Renewal	1-Jun-96	1-hour	Yes	III.B.22.

**Notes:**  
 \* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.  
 \*\* CMS [=] continuous monitoring system

[electronic file name: 10502332.xls]

**Table 2-1, Summary of Compliance Requirements**

Tampa Electric Company  
Polk Power Station

PROPOSED Permit Revision No.: 1050233-009-AV  
Facility ID No.: 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

**E.U. ID No.**            **Brief Description**  
[-004]                    Sulfuric Acid Plant

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
SO <sub>2</sub>	Propane	EPA Method 8	Annual		1-hour		III.C.14.
Sulfuric Acid Mist	Propane	EPA Method 8	Renewal		1-hour		III.C.14.

Notes:  
 \* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.  
 \*\* CMS [=] continuous monitoring system

[electronic file name: 10502332.xls]

**Table 2-1, Summary of Compliance Requirements**

Tampa Electric Company  
Polk Power Station

**PROPOSED Permit Revision No.:** 1050233-009-AV  
**Facility ID No.:** 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

**E.U. ID No.**      **Brief Description**  
[-005]              Solid Fuel Handling System

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
VE		EPA Method 9	Annual		30-minutes		III.D.4.

**Notes:**  
 \* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.  
 \*\*CMS [=] continuous monitoring system

{electronic file name: 10502332.xls}

**Table 2-1, Summary of Compliance Requirements**

Tampa Electric Company  
Polk Power Station

PROPOSED Permit Revision No.: 1050233-009-AV  
Facility ID No.: 1050233

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

**E.U. ID No.**      **Brief Description**  
[-006]              Solid Fuel Gasification System

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)

**Notes:**  
 \* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.  
 \*\*CMS [=] continuous monitoring system

[electronic file name: 10502332.xls]