



**TAMPA ELECTRIC**

April 10, 2007

Mr. Scott Sheplak, P.E.  
Administrator - Title V  
Florida Department Environmental Protection  
111 South Magnolia Drive, Suite 4  
Tallahassee, FL 32301

**Re: Tampa Electric Company  
Polk Power Station Unit 5  
Notification of Actual Startup Date  
Project No. 1050233-018-AC, PSD-FL-363**

Dear Mr. Sheplak:

Tampa Electric Company (TEC) is submitting a notification to the Environmental Protection Agency (EPA) and Florida Department of Environmental Protection (FDEP) of the actual date of initial start-up as required by 40 CFR Part 60.7(a)(3), which states that a notification of the actual date of initial start-up of an affected facility shall be furnished within 15 days after such date. TEC hereby gives notice that the actual startup of Polk Power Station (PPS) Unit 5 was March 31, 2007 and was synchronized to the grid temporarily on April 2, 2007. PPS Unit 5 is a General Electric PG7241(FA) simple cycle natural gas turbine generator with a nominal output of 165 megawatt (MW) and a 114 foot stack.

TEC appreciates your cooperation in this matter and if you have any questions, please call me at (813) 228-4433.

Sincerely,

Byron T. Burrows, P.E., BCEE  
Manager - Air Programs  
Environmental, Health & Safety

ENVP\Admin\UDE119 PPS 4 - Part 60 - First Fire Notification.doc

cc: Mr. J. Koerner - FDEP  
Ms. M. G. Nasca, FDEP SW District

TAMPA ELECTRIC COMPANY  
P. O. BOX 111 TAMPA, FL 33601-0111

AN EQUAL OPPORTUNITY COMPANY  
TAMPAELECTRIC.COM

4/14  
**RECEIVED**

APR 11 2007

BUREAU OF AIR REGULATION

Via FedEx  
Airbill No. 7991 1948 1055

CUSTOMER SERVICE:  
HILLSBOROUGH COUNTY (813) 223-0800  
POLK COUNTY (863) 299-0800  
ALL OTHER COUNTIES 1 (888) 223-0800