



TAMPA ELECTRIC

June 21, 2002

Mr. Bill Proses  
Florida Department of Environmental Protection  
Southwest District  
3804 Coconut Palm Drive  
Tampa, FL 33619

RECEIVED

JUL 15 2002

Via FedEx  
BUREAU OF AIR REGULATION No. 7904 6034 3119

**Re: Tampa Electric Company (TEC)  
Polk Power Station Unit 3  
Initial Natural Gas and No. 2 Fuel Oil Compliance Stack Test  
FDEP File No. PSD-FL-263 (PA92-32)**

Dear Mr. Proses:

As required by 62-297.310(8) and Condition 3 and 6 of permit PSD-FL-263, TEC is required to submit the initial compliance test results to the DEP's Southwest District no later than 45 days after completion of the last test run. Please find enclosed the test report addressing the initial compliance test of Polk Unit 3 while firing natural gas and No. 2 fuel oil.

If you have any questions or comments, please telephone Raiza Calderon or me at (813) 641-5261.

Sincerely,

Laura R. Crouch  
Manager - Air Programs  
Environmental Affairs

EA/bmr/RC131

c/enc: Mr. J. Kissel - FDEP SW  
Mr. A. Linero - FDEP  
Mr. H. Oven - FDEP  
Mr. S. Sheplak - FDEP

PERMIT COMPLIANCE  
TEST REPORT

For  
TURBINE STACK EMISSIONS

On  
UNIT 3, A GENERAL ELECTRIC MODEL PG7241FA  
COMBUSTION GAS TURBINE GENERATOR SET

At the  
POLK POWER STATION

In  
MULBERRY, POLK COUNTY, FLORIDA

Prepared for  
**TAMPA ELECTRIC COMPANY**

Test Date: May 7<sup>th</sup>-9<sup>th</sup>, 2002  
Report Preparation Date: June 19<sup>th</sup>, 2002

Cubix Project No. 6949-FL1

Prepared by

1050233  
PSD-FL-  
263

6-19-02



Cubix  
Corporation

<http://www.cubixcorp.com>

**CORPORATE HEADQUARTERS**

9225 US Hwy. 183 South, Austin, TX 78747  
(512) 243-0202 TEL (512) 243-0222 FAX

## TABLE OF CONTENTS

<b>INTRODUCTION</b>	1
Table 1 Background Data	2
<b>SUMMARY OF RESULTS</b>	5
Table 2: Executive Summary	6
Table 3: Summary of Results, Full Load Testing, Unit 3 Natural Gas	8
Table 4: Summary of Results, Reduced Load Testing, Unit 3 Natural Gas	9
Table 5: Summary of Results, Full Load Testing, Unit 3 Distillate Oil	10
Table 6: Summary of Results, Reduced Load Testing, Unit 3 Distillate Oil	11
<b>PROCESS DESCRIPTION</b>	12
<b>ANALYTICAL TECHNIQUES</b>	13
Table 7: Analytical Instrumentation	17
Figure 1: Instrumental Sample System Diagram	18
<b>QUALITY ASSURANCE ACTIVITIES</b>	19
<b>APPENDICES:</b>	
A. Field Data Sheets	
B. Example Calculations	
C. Fuel Analyses	
D. Quality Assurance Activities	
E. Calibration Certifications	
F. Records of Logged Data	
G. Opacity Observations	
H. Operational Data	
Unit Operational and Emission Curves	
Natural Gas Tests	
Fuel Oil Tests	
I. FDEP PSD Permit	


## INTRODUCTION

Emission testing was conducted on a 165-megawatt (MW) General Electric (GE) PG7241FA combustion gas turbine generator set. The unit consists of a simple-cycle combustion turbine directly coupled to a 60-Hertz generator and may be fueled by either natural gas or distillate oil. This unit, used to generate power, was recently installed at the Polk Power Station located in Mulberry, Polk County, Florida. Tampa Electric Company (Tampa Electric) owns and operates this facility. Cubix Corporation, Southeast Regional Office conducted this testing on May 7<sup>th</sup> through May 9<sup>th</sup>, 2002.

The purpose of this testing was to determine the status of initial compliance for Polk Unit 3 combustion turbine emissions with environmental limits. The environmental limits for emissions are US EPA "Standards of Performance for Stationary Gas Turbines" set forth in the Code of Federal Regulations, Title 40, Part 60 (40 CFR 60), Subpart GG and the permit limits set forth by the Florida Department of Environmental Protection (FDEP) Permit Numbers PSD-FL-263 and PA92-32. The tests followed the procedures set forth in 40 CFR 60, Appendix A, Methods 1, 3a, 9, 10, 19, 20, and 25a.

The turbine exhaust was analyzed for oxides of nitrogen ( $\text{NO}_x$ ), oxygen ( $\text{O}_2$ ), and carbon dioxide ( $\text{CO}_2$ ) using continuous instrumental monitors. Twenty-four test runs were conducted on the turbine, three test runs at each of four operating load conditions consisting of three reduced loads and full load for both natural gas and distillate oil fuels. Carbon monoxide (CO), and total unburned hydrocarbon compounds (UHC or THC) emissions were also monitored during the full load testing on each fuel using continuous instrumental monitors. UHC emissions were used to report concentrations of volatile organic compounds (VOC). Additionally, a visible emissions (VE) test was conducted to determine opacity during one of the full load test runs on each fuel. Core Laboratories of Houston, Texas performed analyses on the natural gas and distillate oil fuel samples. Table 1 provides background data pertinent to these tests.

This test report has been reviewed and is approved for submittal by the following representatives:

  
Cubix Corporation

  
Tampa Electric Company

**TABLE 1  
BACKGROUND DATA**

<u>Owner/Operator:</u>	<b>Tampa Electric Company</b> 5010 Causeway Boulevard Tampa, Florida 33619 Attn: David A. Smith (813) 630-7382 Phone (813) 630-7350 Facsimile Email: <a href="mailto:dasmith@tecoenergy.com">dasmith@tecoenergy.com</a>
<u>Testing Organization:</u>	<b>Cubix Corporation, SE Regional Office</b> 3709 SW 42 <sup>nd</sup> Avenue, Suite 2 Gainesville, Florida 32608 Attn: Leonard Brenner, Project Manager (352) 378-0332 Phone (352) 378-0354 Facsimile Email: <a href="mailto:lbrenner@cubixcorp.com">lbrenner@cubixcorp.com</a>
<u>Test Participants:</u>	<b>Tampa Electric Company</b> Robert Barthelette, Jr. Ted Wenning Raiza Calderon Ray McDarby  <b>Florida Dept. of Environmental Protection</b> Russeu A. Wider  <b>Cubix Corporation</b> Leonard Brenner Roger Paul Osier Sean Barrett
<u>Test Dates:</u>	May 7 <sup>th</sup> through May 9 <sup>th</sup> , 2002
<u>Facility Location:</u>	Tampa Electric Company Polk Power Station 9995 State Road 37 South Mulberry, Florida 33860

Process Description:

A dual-fuel, simple-cycle combustion turbine (CT) is used to generate electrical power. The unit, a General Electric Model 7EA PG7241FA gas turbine generator, consists of a single-shaft gas combustion turbine directly connected to a 60 Hz power generator. The facility is designed and permitted to provide natural gas fuel or distillate oil (No. 2 fuel oil or better) to the combustion turbine. The turbine uses dry, low-NO<sub>x</sub> combustors for natural gas firing and water injection for distillate oil firing to control NO<sub>x</sub> emissions.

Regulatory Application:

The Polk Unit 3 turbine is operated under the State of Florida, Florida Department of Environmental Protection (FDEP) Permit Nos. PSD-FL-263 and PA92-32 and federally regulated under EPA New Source Performance Standards (NSPS) 40 CFR 60, Subpart GG.

Emission Sampling Points:

Tampa Electric designates this emissions source as Polk Unit 3, designated by FDEP as ARMS Emissions Unit 010(CTG-3). The exhaust stack is a circular stack, approximately 114 feet tall with an internal diameter of 216 inches. Four 6-inch diameter sample ports are located perpendicular to each other in a horizontal plane of the stack at approximately 106 feet above grade; see Appendix A for a diagram. Access to the sample ports was provided through caged safety ladders to a permanently installed platform.

Test Methods:

EPA Method 1 was used to select oxygen (O<sub>2</sub>) traverse point locations.

EPA Method 3a was used to measure carbon dioxide (CO<sub>2</sub>) concentrations.

EPA Method 4 was used to determine stack gas moisture content.

EPA Method 9 was used to determine visible emissions (VE) measurements determined as opacity from a certified observer.

EPA Method 10 was used to measure carbon monoxide (CO) concentrations.

Test Methods (Continued):

EPA Method 19 was used for calculation of stack flow and pollutant mass emission rates.

EPA Method 20 was used to measure oxides of nitrogen (NO<sub>x</sub>) and oxygen (O<sub>2</sub>) concentrations.

EPA Method 25a was used to measure total unburned hydrocarbon compound (UHC or THC) concentrations.

American Society of Testing and Materials (ASTM) Method D3246 was used to determine the total reduced sulfur in the natural gas fuel.

Gas Processors Association (GPA) Method 2261 was used to determine the composition of the natural gas fuel.

ASTM Method D3588 was used to determine heating value and specific gravity of the natural gas fuel.

ASTM Method D4294 was used to determine the total sulfur in the distillate oil fuel.

ASTM Method D4629 was used to determine the fuel bound nitrogen in the distillate oil fuel.

ASTM Method D5291 was used to determine the carbon, hydrogen, and oxygen (by difference) in the distillate oil fuel.

ASTM Method D240 was used to determine the heating value of the distillate oil fuel.

## SUMMARY OF RESULTS

Tampa Electric Company owns and operates the Polk Power Station in Mulberry, Florida. At this facility a recently installed General Electric simple-cycle combustion turbine is used to generate electrical power. Tampa Electric designates the combustion turbine as Polk Unit 3. Stack emissions from this unit, while fueled with natural gas and then distillate oil, are the subject of this report.

The first step in the test matrix for the unit consisted of conducting an initial sampling traverse of the combustion turbine (CT) exhaust stack. The purpose of this sampling traverse was to check for changes in O<sub>2</sub> concentration (stratification) within the exhaust stack. O<sub>2</sub> concentrations were measured at 48 traverse points within the CT stack to determine the eight points of lowest O<sub>2</sub> concentration. All subsequent tests were conducted at the eight traverse points of lowest O<sub>2</sub> on the CT stack. This initial traverse was conducted on the CT stack while firing with both natural gas and distillate oil fuel.

Following the O<sub>2</sub>-traverse on Polk Unit 3, Cubix conducted three test runs at each of four load conditions, expressed as electrical output in MW, across the operational range of the combustion turbine for both natural gas and distillate oil fuel. The loads were approximately 80 MW, 105 MW, 130 MW, and base load at 156 MW while operating with natural gas. The loads were approximately 80 MW, 110 MW, 137 MW, and base load at 166 MW while operating with distillate oil. Each reduced load test run was 20 minutes in duration (8 sample points, 150 seconds per point) and included measurements of NO<sub>x</sub>, O<sub>2</sub>, and CO<sub>2</sub> concentrations using continuous instrumental monitors. Additional full load measurements included measurements of CO and UHC as volatile organic compounds (VOC) concentrations using continuous instrumental monitors. The full load test runs were 1 hour in duration for all gaseous constituents. A one-hour VE test was conducted with one of the full load test runs while firing with each fuel.

Table 2, the executive summary, signifies the performance for the unit during the testing. These performance results are an average of the three test runs at each load condition. Unit load is expressed as percent of the maximum heat input of the fuel to the turbine as based upon ambient conditions, expressed as compressor inlet temperature. Mass emission rates of NO<sub>x</sub>, CO, VOC, and SO<sub>2</sub> are compared to applicable environmental limits as based upon ambient conditions. Performance and emission curves for both natural gas and distillate oil fuels are in Appendix H.



**TABLE 2**  
**Executive Summary**

Parameter	Unit 3 - ARMS Emissions Unit 010(CTG-3) GE Frame 7FA Combustion Turbine				EPA GG/FDEP Emissions and Permit Limits†
	Natural Gas Fuel Testing				
Generator Output (MW)	79.6	105.1	129.4	156.0	na
Load (% of Capacity as Heat Input, LHV)	69.0%	77.6%	86.8%	99.7%	1600 MMBtu/hr, ISO
NO <sub>x</sub> (ppmv @ 15% excess O <sub>2</sub> )	7.84	7.16	6.86	7.75	9.0
NO <sub>x</sub> (ppmv @ 15% excess O <sub>2</sub> ISO Day)	7.77	7.17	6.93	8.20	109.8
NO <sub>x</sub> (lbs/hr)	30.9	32.7	35.6	46.4	54.5
CO (ppmv)	na	na	na	0.23	12.0
CO (lbs/hr)	na	na	na	0.69	45.3
UHC as VOC (ppmv, wet as methane)	na	na	na	0.51	1.4
UHC as VOC (lbs/hr, includes methane)	na	na	na	0.97	2.66
Total Sulfur in Fuel (grains S/100 scf fuel)	< 0.032	< 0.032	< 0.032	< 0.032	2.0
SO <sub>2</sub> (lbs/hr)	< 0.093	< 0.11	< 0.12	< 0.14	8.52
Visible Emissions (% opacity)	na	na	na	0%	10%
Parameter	Distillate Oil Testing (No. 2 Fuel Oil)				
Generator Output (MW)	80.5	110.5	137.1	166.3	na
Load (% of Capacity as Heat Input, LHV)	66.3	76.8	84.6	98.1%	1800 MMBtu/hr, ISO
NO <sub>x</sub> (ppmv @ 15% excess O <sub>2</sub> )	36.5	36.3	36.6	36.8	42.0
NO <sub>x</sub> (ppmv @ 15% excess O <sub>2</sub> ISO Day)	36.5	37.0	37.9	37.8	104.2
NO <sub>x</sub> (lbs/hr)	156	187	213	247	291
CO (ppmv)	na	na	na	0.58	33.0
CO (lbs/hr)	na	na	na	1.68	96.8
UHC as VOC (ppmv, wet as methane)	na	na	na	0.09	3.5
UHC as VOC (lbs/hr, includes methane)	na	na	na	0.18	6.42
Total Sulfur in Fuel (% weight)	0.039%	0.039%	0.039%	0.039%	0.05%
SO <sub>2</sub> (lbs/hr)	43.9	52.8	59.7	69.0	89.8
Visible Emissions (% opacity)	na	na	na	0%	10%

† Permit limits in lbs/hr for NO<sub>x</sub>, CO, VOC, and SO<sub>2</sub> are based upon ambient conditions from full load tests.

Tables 3 through 6 represent the full load (base load) and reduced load tests results while firing with natural gas and distillate oil, respectively. These tabular summaries contain all pertinent operational parameters, ambient conditions, measured emissions, corrected concentrations, and calculated emission rates. NO<sub>x</sub> emissions are reported in units of parts per million by volume (ppmv) on a dry basis, ppmv corrected to 15% excess O<sub>2</sub>, and ppmv corrected to 15% excess O<sub>2</sub> and ISO conditions. The EPA defines ISO conditions as ambient atmospheric conditions of 59 degrees Fahrenheit (°F) temperature, 101.3 kilopascals (kPa) pressure, and 60% relative humidity. CO concentrations were determined on ppmv, dry basis. Volatile organic compound (VOC) concentrations were determined from UHC measurements and were determined on a ppmv wet basis as methane. Mass emission rates for NO<sub>x</sub>, CO, and UHC as VOC are reported in terms of pounds per hour (lbs/hr).

Volumetric flow and mass emission rates were determined by stoichiometric

calculation (EPA Method 19) based on measurements of diluent gas ( $O_2$  or  $CO_2$ ) concentrations, "F-factors" and fuel heating values determined from fuel composition, and unit fuel flow rates. Examples of emission rate calculations and other calculations necessary for the presentation of the results of this section are contained in Appendix B. The fuel meters, used to measure fuel flow to the turbine, were calibrated prior to testing. A report of this calibration is included with the fuel analyses in Appendix C.

The fuel analyses are contained in Appendix C of this report. Core Laboratories of Houston, Texas conducted the analyses using ASTM and GPA test methods. Both natural gas and fuel oil samples were collected and analyzed for various components. Two samples were collected during the natural gas testing and one sample was collected during the distillate oil testing. The natural gas total sulfur content was reported in terms of ppmv weight and grains of sulfur per 100 standard cubic feet of natural gas fuel. The distillate oil total sulfur content was reported in terms of % weight. Stack emissions of  $SO_2$ , reported in terms of lbs/hr in the summary tables, were determined using fuel flow rates and fuel sulfur content data. Reports of these fuel analyses as well as fuel composition and heating value analysis sheets are in Appendix C.

EPA Method 9 observers, certified by Eastern Technical Associates of Raleigh, North Carolina, performed visible emission observations of the CT exhaust stack. Roger Osier with Cubix Corporation conducted the natural gas VE test. Ray McDarby with Tampa Electric conducted the distillate oil VE test. A one-hour visible emissions test run was conducted at full load with the turbine firing on each fuel per EPA Method 9. VE were an average of 0% opacity in the highest six-minute average for each test and no VE greater than 0% opacity was observed during the tests.

Appendix A contains all field data sheets used during these tests. Appendix B contains examples of all calculations necessary for the reduction of the data presented in this report. Appendix C contains the fuel analyses and Cubix's fuel calculation worksheet. Quality Assurance Activities are documented in Appendix D. Certificates of calibrations are contained in Appendix E of this report. Appendix F contains the records of logged data in one-minute intervals used to record the  $NO_x$ , CO, UHC,  $O_2$ , and  $CO_2$  concentrations; it also includes a running and final average of raw data. Appendix G contains the "Visible Emissions Observation Forms" and the observer certifications. Appendix H contains the operational data provided by Tampa Electric personnel during the test runs. The FDEP permit is presented in Appendix I for reference purposes.

Company: Tampa Electric Company  
 Plant: Polk Power Station  
 Location: Mulberry, Polk County, Florida  
 Technicians: LJB, RPO, SBB  
 Source: Unit 3, a GE Frame 7FA Combustion Turbine

**TABLE 3: Summary of Results**  
**Full Load Testing**  
**Unit 3 Natural Gas**

Test Number	U3-NG-100%-1	U3-NG-100%-2	U3-NG-100%-3			
Date	5/7/02	5/7/02	5/7/02			
Start Time (CEMS Time)	10:17	11:30	12:47			
Stop Time (CEMS Time)	11:17	12:30	13:47			
<b>Power Turbine Operation</b>	<b>Base Load</b>			<b>Averages</b>	<b>FDEP Permit Limits†</b>	
Generator Output (MW, DWATT)	157.3	155.9	154.8	<b>156.0</b>	<b>1481</b>	
Turbine Capacity (MMBtu/hr, LHV)	1489.9	1479.5	1472.9	<b>1480.8</b>		
Turbine Load (% of maximum site rated capacity)	99.6%	99.7%	99.7%	<b>99.7%</b>		
Barometric Pressure ("Hg, AFPAP)	30.01	30.00	30.00	<b>30.00</b>		
Compressor Inlet Temperature (°F, CTIM)	85.0	87.2	88.6	<b>86.9</b>		
Air Inlet Duct Losses ("H <sub>2</sub> O)	2.29	2.30	2.30	<b>23.61</b>		
Inlet Guide Vane Angle (degrees, CSGV)	82.0	82.0	82.0	<b>82.0</b>		
Engine Compressor Discharge Pressure (psia, CPD)	202.5	201.6	200.6	<b>201.6</b>		
Compressor Discharge Temperature (°F, CTD)	762.3	764.6	765.8	<b>764.2</b>		
Mean Turbine Exhaust Temperature (°F, TTXM)	1132.8	1134.3	1135.7	<b>1134.3</b>		
<b>Turbine Fuel Data (Natural Gas)</b>						
Fuel Heating Value (Btu/lb, Gross)	23068	23068	23068	<b>23068</b>	<b>2.0</b>	
Fuel Specific Gravity	0.5901	0.5901	0.5901	<b>0.5901</b>		
Sulfur in Fuel (grains S/100 scf of gas)	< 0.032	< 0.032	< 0.032	<b>&lt; 0.032</b>		
O <sub>2</sub> "F <sub>d</sub> Factor" (DSCFex/MMBtu @ 0% excess air)	8645	8645	8645	<b>8645</b>		
CO <sub>2</sub> "F <sub>c</sub> Factor" (DSCFex/MMBtu @ 0% excess air)	1029	1029	1029	<b>1029</b>		
Gas Fuel Flow (FQG, lbs/hr)	71379	70912	70565	<b>70952</b>		
Heat Input (MMBtu/hr, Higher Heating Value)	1646.6	1635.8	1627.8	<b>1636.7</b>		
Heat Input (MMBtu/hr, Lower Heating Value)	1484.7	1475.0	1467.7	<b>1475.8</b>		
<b>Ambient Conditions</b>						
Atmospheric Pressure ("Hg)	29.99	29.97	29.96	<b>29.97</b>		
Temperature (°F): Dry bulb	86.3	90.3	90.9	<b>89.2</b>		
(°F): Wet bulb	73.2	73.4	73.3	<b>73.3</b>		
Humidity (lbs moisture/lb of air)	0.0141	0.0133	0.0131	<b>0.0135</b>		
<b>Measured Emissions</b>						
NO <sub>x</sub> (ppmv, dry basis)	9.43	9.42	9.39	<b>9.41</b>	<b>9.0</b>	
NO <sub>x</sub> (ppmv, dry @ 15% excess O <sub>2</sub> )	<b>7.75</b>	<b>7.74</b>	<b>7.75</b>	<b>7.75</b>		
NO <sub>x</sub> (ppmv @ 15% O <sub>2</sub> , ISO Day)	8.33	8.16	8.10	<b>8.20</b>		
CO (ppmv, dry basis)	<b>0.26</b>	<b>0.22</b>	<b>0.21</b>	<b>0.23</b>	<b>12.0</b>	
UHC as VOC (ppmv, wet basis)	<b>0.57</b>	<b>0.57</b>	<b>0.40</b>	<b>0.51</b>	<b>1.4</b>	
VE (% opacity)	-	-	0	<b>0</b>	<b>10</b>	
O <sub>2</sub> (% volume, dry basis)	13.72	13.72	13.75	<b>13.73</b>		
CO <sub>2</sub> (% volume, dry basis)	4.19	4.16	4.16	<b>4.17</b>		
F <sub>d</sub> (fuel factor, range = 1.600-1.836 for NG)	1.71	1.73	1.72	<b>1.72</b>		
H <sub>2</sub> O (% volume)	8.71	8.59	8.53	<b>8.61</b>		
<b>Stack Volumetric Flow Rates (via EPA Method 19)</b>						
via O <sub>2</sub> "F <sub>d</sub> Factor" (SCFH, dry basis)	4.14E+07	4.12E+07	4.11E+07	<b>4.12E+07</b>		
via CO <sub>2</sub> "F <sub>c</sub> Factor" (SCFH, dry basis)	4.04E+07	4.05E+07	4.03E+07	<b>4.04E+07</b>		
<b>Calculated Emission Rates (via M-19 O<sub>2</sub> or CO<sub>2</sub> "F-factor")</b>						
NO <sub>x</sub> (lbs/hr)	<b>46.7</b>	<b>46.3</b>	<b>46.1</b>	<b>46.4</b>	<b>54.5</b>	
CO (lbs/hr)	<b>0.78</b>	<b>0.66</b>	<b>0.63</b>	<b>0.69</b>	<b>45.3</b>	
UHC as VOC (lbs/hr)	<b>1.08</b>	<b>1.07</b>	<b>0.75</b>	<b>0.97</b>	<b>2.66</b>	
SO <sub>2</sub> (lbs/hr, based on fuel flow and fuel sulfur)	<b>&lt; 0.14</b>	<b>&lt; 0.14</b>	<b>&lt; 0.14</b>	<b>&lt; 0.14</b>	<b>8.52</b>	

† Permitted capacity and lbs/hr emission permit limits for NO<sub>x</sub>, CO, VOC, and SO<sub>2</sub> have been converted from ISO to ambient conditions.

Company: Tampa Electric Company  
 Plant: Polk Power Station  
 Location: Mulberry, Polk County, Florida  
 Technicians: LJB, RPO  
 Source: Unit 3, a GE Frame 7FA Combustion Turbine

**TABLE 4: Summary of Results**  
**Reduced Load Testing**  
**Unit 3 Natural Gas**

Test Number	U3-50%-1	U3-50%-2	U3-50%-3	U3-65%-1	U3-65%-2	U3-65%-3	U3-80%-1	U3-80%-2	U3-80%-3
Date	5/9/02	5/9/02	5/9/02	5/9/02	5/9/02	5/9/02	5/9/02	5/9/02	5/9/02
Start Time	10:11	10:39	11:07	11:34	12:01	12:28	12:56	13:22	13:49
Stop Time	10:31	10:59	11:27	11:54	12:21	12:48	13:16	13:42	14:09
<b>Turbine Operation</b>	<b>Low Load, ~80 MW</b>			<b>Mid-Low Load, ~105 MW</b>			<b>Mid-High Load, ~130 MW</b>		
Generator Output (MW, DWATT)	79.0	79.2	80.5	105.2	104.9	105.1	130.0	129.4	128.8
Turbine Capacity (MMBtu/hr, LHV)	1418.5	1410.8	1405.2	1458.9	1454.7	1450.8	1480.9	1475.3	1473.2
Turbine Load (% of maximum site rated capacity)	68.4%	68.9%	69.7%	77.5%	77.5%	77.8%	86.8%	86.9%	86.9%
Barometric Pressure ("Hg, AFPAP)	29.98	29.98	29.97	29.98	29.98	29.98	29.98	29.97	29.97
Compressor Inlet Temperature (°F, CTIM)	99.3	100.7	101.8	91.4	92.3	93.1	86.9	88.1	88.5
Air Inlet Duct Losses ("H <sub>2</sub> O)	1.63	1.61	1.77	1.79	1.82	1.82	1.86	1.73	1.66
Inlet Guide Vane Angle (degrees, CSGV)	50.9	50.9	51.4	56.6	56.8	57.1	64.4	64.2	63.8
Compressor Discharge Pressure (psia, CPD)	129.9	129.9	130.9	149.9	149.5	149.9	173.1	172.4	172.0
Compressor Discharge Temperature (°F, CTD)	686.1	687.6	690.3	705.3	706.1	707.4	726.7	727.2	727.9
Mean Turbine Exhaust Temperature (°F, TTXM)	1199.9	1200.0	1199.8	1184.0	1184.8	1184.6	1157.2	1158.3	1158.7
<b>Turbine Fuel Data (Natural Gas)</b>									
Fuel Heating Value (Btu/lb, Gross)	23067	23067	23067	23067	23067	23067	23067	23067	23067
Fuel Specific Gravity	0.5923	0.5923	0.5923	0.5923	0.5923	0.5923	0.5923	0.5923	0.5923
Sulfur in Fuel (grains S/100 scf of gas)	< 0.032	< 0.032	< 0.032	< 0.032	< 0.032	< 0.032	< 0.032	< 0.032	< 0.032
O <sub>2</sub> "F <sub>2</sub> Factor" (DSCFex/MMBtu @ 0% excess air)	8646	8646	8646	8646	8646	8646	8646	8646	8646
CO <sub>2</sub> "F <sub>2</sub> Factor" (DSCFex/MMBtu @ 0% excess air)	1030	1030	1030	1030	1030	1030	1030	1030	1030
Gas Fuel Flow (FQG, lbs/hr)	46548	46633	46979	54225	54085	54128	61671	61469	61382
Heat Input (MMBtu/hr, Higher Heating Value)	1073.7	1075.7	1083.7	1250.8	1247.6	1248.6	1422.6	1417.9	1415.9
Heat Input (MMBtu/hr, Lower Heating Value)	970.4	972.2	979.4	1130.5	1127.6	1128.5	1285.7	1281.5	1279.7
<b>Ambient Conditions</b>									
Atmospheric Pressure ( "Hg)	29.92	29.92	29.92	29.93	29.93	29.93	29.92	29.92	29.91
Temperature (°F): Dry bulb	82.2	84.0	86.0	86.5	87.7	89.0	90.3	90.8	92.1
(°F): Wet bulb	69.6	70.0	70.1	69.7	70.2	70.5	71.1	70.7	71.1
Humidity (lbs moisture/lb of air)	0.0123	0.0122	0.0118	0.0113	0.0115	0.0114	0.0115	0.0111	0.0111
<b>Measured Emissions</b>									
NO <sub>x</sub> (ppmv, dry basis)	9.17	9.04	9.12	8.65	8.63	8.67	8.30	8.28	8.28
O <sub>2</sub> (% volume, dry basis)	14.05	14.05	14.02	13.76	13.78	13.78	13.77	13.77	13.78
CO <sub>2</sub> (% volume, dry basis)	4.02	4.01	4.01	4.15	4.16	4.14	4.15	4.15	4.14
F <sub>2</sub> (fuel factor, range = 1.600-1.836 for NG)	1.70	1.71	1.72	1.72	1.71	1.72	1.72	1.72	1.72
<b>Stack Volumetric Flow Rates (via EPA Method 19)</b>									
via O <sub>2</sub> "F <sub>2</sub> Factor" (SCFH, dry basis)	2.83E+07	2.84E+07	2.85E+07	3.17E+07	3.17E+07	3.17E+07	3.61E+07	3.59E+07	3.59E+07
via CO <sub>2</sub> "F <sub>2</sub> Factor" (SCFH, dry basis)	2.75E+07	2.76E+07	2.78E+07	3.10E+07	3.09E+07	3.11E+07	3.53E+07	3.52E+07	3.52E+07
<b>Calculated Emission Rates (via M-19 O<sub>2</sub> "F-factor")</b>									
NO <sub>x</sub> (ppmv, dry @ 15% excess O <sub>2</sub> )	<b>7.90</b>	<b>7.79</b>	<b>7.82</b>	<b>7.15</b>	<b>7.15</b>	<b>7.18</b>	<b>6.87</b>	<b>6.85</b>	<b>6.86</b>
NO <sub>x</sub> (ppmv @ 15% O <sub>2</sub> , ISO Day)	7.88	7.73	7.68	7.16	7.17	7.17	7.00	6.90	6.90
NO <sub>x</sub> (lbs/hr)	<b>31.0</b>	<b>30.6</b>	<b>31.0</b>	<b>32.7</b>	<b>32.6</b>	<b>32.8</b>	<b>35.7</b>	<b>35.5</b>	<b>35.5</b>
SO <sub>2</sub> (lbs/hr, based on fuel flow and fuel sulfur)	< 0.093	< 0.093	< 0.094	< 0.11	< 0.11	< 0.11	< 0.12	< 0.12	< 0.12

**TABLE 5: Summary of Results  
Full Load Testing  
Unit 3 Distillate Oil**

Company: Tampa Electric Company  
 Plant: Polk Power Station  
 Location: Mulberry, Polk County, Florida  
 Technicians: LJB, RPO  
 Source: Unit 3, a GE Frame 7FA Combustion Turbine

Test Number	U3-Oil-100%-1	U3-Oil-100%-2	U3-Oil-100%-3		
Date	5/8/02	5/8/02	5/8/02		
Start Time	15:55	17:10	18:22		<b>FDEP Permit Limits†</b>
Stop Time	16:55	18:10	19:22		
<b>Power Turbine Operation</b>				<b>Averages</b>	
Generator Output (MW, DWATT)	166.2	165.9	166.8	<b>166.3</b>	
Turbine Capacity (Mfg.'s Curve, Heat Input vs. T-1)	1,641.9	1,642.6	1,649.3	<b>1,644.6</b>	<b>1645</b>
Percent Load (% of maximum heat input at inlet temp)	98.0%	97.9%	98.4%	<b>98.1%</b>	
Barometric Pressure ("Hg, AFPAP)	29.93	29.91	29.91	<b>29.92</b>	
Compressor Inlet Temperature (°F, CTIM)	91.3	91.2	90.0	<b>90.8</b>	
Air Inlet Duct Losses ("H <sub>2</sub> O)	2.31	2.32	2.34	<b>2.33</b>	
Engine Compressor Discharge Pressure (psia, CPD)	205.9	205.8	206.4	<b>206.0</b>	
Compressor Discharge Temperature (°F, CTD)	781.1	780.8	779.1	<b>780.3</b>	
Mean Turbine Exhaust Temperature (°F, TTXM)	1125.4	1125.4	1124.4	<b>1125.1</b>	
Inlet Guide Vane Angle (degrees, CSGV)	82.0	82.0	82.0	<b>82.0</b>	
Water Injection Rate (WQ, lbs/sec)	33.6549	33.4534	33.4536	<b>33.5206</b>	
Water to Fuel Ratio (WQJ, unitless)	1.37	1.36	1.35	<b>1.36</b>	
<b>Turbine Fuel Data (Distillate Oil Fuel)</b>					
Fuel Heating Value (Btu/lb, Gross)	19366	19366	19366	<b>19366</b>	
Fuel Heating Value (Btu/lb, Net)	18210	18210	18210	<b>18210</b>	
Sulfur in Fuel (% weight, from ASTM D4294 analysis)	0.039	0.039	0.039	<b>0.039</b>	<b>0.05</b>
O <sub>2</sub> "F <sub>a</sub> Factor" (DSCFex/MMBtu @ 0% excess air)	9257	9257	9257	<b>9257</b>	
CO <sub>2</sub> "F <sub>c</sub> Factor" (DSCFex/MMBtu @ 0% excess air)	1443	1443	1443	<b>1443</b>	
Oil Fuel Flow (FQG, lbs/sec)	24.5480	24.5299	24.7623	<b>24.6134</b>	
Heat Input (MMBtu/hr, Higher Heating Value)	1711.4	1710.2	1726.4	<b>1716.0</b>	
Heat Input (MMBtu/hr, Lower Heating Value)	1,609.3	1,608.1	1,623.3	<b>1,613.6</b>	
<b>Ambient Conditions</b>					
Atmospheric Pressure ("Hg)	29.87	29.86	29.86	<b>29.86</b>	
Temperature (°F): Dry bulb	92.4	92.6	89.9	<b>91.6</b>	
(°F): Wet bulb	72.6	73.0	72.6	<b>72.7</b>	
Humidity (lbs moisture/lb of air)	0.0122	0.0125	0.0128	<b>0.0125</b>	
<b>Measured Emissions</b>					
NO <sub>x</sub> (ppmv, dry basis)	52.14	52.08	51.80	<b>52.01</b>	
NO <sub>x</sub> (ppmv, dry @ 15% excess O <sub>2</sub> )	<b>36.8</b>	<b>36.9</b>	<b>36.6</b>	<b>36.8</b>	<b>42.0</b>
NO <sub>x</sub> (ppmv @ 15% O <sub>2</sub> , ISO Day)	37.6	37.9	38.0	<b>37.8</b>	
CO (ppmv, dry basis)	<b>0.54</b>	<b>0.59</b>	<b>0.61</b>	<b>0.58</b>	<b>33.0</b>
UHC as VOC (ppmv, wet basis)	<b>0.12</b>	<b>0.12</b>	<b>0.04</b>	<b>0.09</b>	<b>3.5</b>
Visible Emissions (% opacity)	<b>0</b>	-	-	<b>0</b>	<b>10</b>
O <sub>2</sub> (% volume, dry basis)	12.54	12.57	12.55	<b>12.55</b>	
CO <sub>2</sub> (% volume, dry basis)	6.34	6.33	6.34	<b>6.34</b>	
F <sub>o</sub> (fuel factor, range = 1.260 to 1.413 for FO)	1.32	1.32	1.32	<b>1.32</b>	
H <sub>2</sub> O (% volume)	12.53	12.51	12.53	<b>12.52</b>	
<b>Stack Volumetric Flow Rates</b>					
via O <sub>2</sub> "F <sub>a</sub> Factor" (SCFH, dry basis)	3.96E+07	3.97E+07	4.00E+07	<b>3.98E+07</b>	
via CO <sub>2</sub> "F <sub>c</sub> Factor" (SCFH, dry basis)	3.90E+07	3.90E+07	3.93E+07	<b>3.91E+07</b>	
<b>Calculated Emission Rates (via M-19 O<sub>2</sub> "F-factor")</b>					
NO <sub>x</sub> (lbs/hr)	<b>247</b>	<b>247</b>	<b>247</b>	<b>247</b>	<b>291</b>
CO (lbs/hr)	<b>1.56</b>	<b>1.70</b>	<b>1.77</b>	<b>1.68</b>	<b>96.8</b>
UHC as VOC (lbs/hr)	<b>0.23</b>	<b>0.23</b>	<b>0.08</b>	<b>0.18</b>	<b>6.42</b>
SO <sub>2</sub> (lbs/hr, based on fuel flow and fuel sulfur)	<b>68.9</b>	<b>68.8</b>	<b>69.5</b>	<b>69.0</b>	<b>89.8</b>

† Permitted capacity and lbs/hr emission permit limits for NO<sub>x</sub>, CO, VOC, and SO<sub>2</sub> have been converted from ISO to ambient conditions.

Company: Tampa Electric Company  
Plant: Polk Power Station  
Location: Mulberry, Polk County, Florida  
Technicians: LJB, RPO  
Source: Unit 3, a GE Frame 7FA Combustion Turbine

**TABLE 6: Summary of Results  
Reduced Load Testing  
Unit 3 Distillate Oil**

Test Number	U3-Oil-50%-1	U3-Oil-50%-2	U3-Oil-50%-3	U3-Oil-65%-1	U3-Oil-65%-2	U3-Oil-65%-3	U3-Oil-80%-1	U3-Oil-80%-2	U3-Oil-80%-3
Date	5/8/02	5/8/02	5/8/02	5/8/02	5/8/02	5/8/02	5/8/02	5/8/02	5/8/02
Start Time	11:25	11:53	12:24	12:53	13:21	13:49	14:18	14:47	15:17
Stop Time	11:45	12:13	12:44	13:13	13:41	14:09	14:38	15:07	15:37
<b>Turbine Operation</b>	<b>Low Load, ~80 MW</b>			<b>Mid Load-1, ~110 MW</b>			<b>Mid Load-2, ~137 MW</b>		
Generator Output (MW, DWATT)	79.9	80.2	81.3	110.6	110.3	110.7	136.2	136.7	138.4
Turbine Capacity (MMBtu/hr LHV, heat input vs. inlet temp)	1,548.2	1,544.6	1,542.1	1,606.9	1,606.5	1,607.0	1,654.0	1,649.3	1,645.2
Percent Load (% of maximum heat input at inlet temp)	65.1	66.2	67.8	76.1	76.8	77.7	84.1	84.9	84.8
Barometric Pressure ("Hg, AFPAP)	29.97	29.96	29.96	29.96	29.96	29.95	29.94	29.94	29.94
Compressor Inlet Temperature (°F, CTIM)	107.2	107.7	108.1	97.5	97.5	97.4	89.1	90.0	90.7
Air Inlet Duct Losses ("H <sub>2</sub> O)	0.82	1.15	1.27	1.33	1.47	1.60	1.91	2.05	2.20
Engine Compressor Discharge Pressure (psia, CPD)	128.1	128.3	129.4	150.8	150.6	151.0	173.1	173.6	175.0
Compressor Discharge Temperature (°F, CTD)	696.2	697.3	699.1	720.4	720.3	720.8	736.1	738.2	741.1
Mean Turbine Exhaust Temperature (°F, TTXM)	1200.0	1200.2	1199.8	1185.6	1186.3	1185.8	1158.1	1158.0	1157.0
Inlet Guide Vane Angle (degrees, CSGV)	50.2	50.5	50.7	55.6	55.7	56.1	62.5	62.9	63.8
Water Injection Rate (WQ, lbs/sec)	17.7909	17.9332	18.2066	22.8568	23.0341	23.2735	27.4031	27.3201	28.1869
Water to Fuel Ratio (WQI, unitless)	1.16	1.15	1.14	1.23	1.22	1.22	1.29	1.28	1.32
<b>Turbine Fuel Data (Distillate Oil Fuel)</b>									
Fuel Heating Value (Btu/lb, Gross)	19366	19366	19366	19366	19366	19366	19366	19366	19366
Fuel Heating Value (Btu/lb, Net)	18210	18210	18210	18210	18210	18210	18210	18210	18210
Sulfur in Fuel (% weight, from ASTM D4294 analysis)	0.039	0.039	0.039	0.039	0.039	0.039	0.039	0.039	0.039
O <sub>2</sub> "F <sub>2</sub> Factor" (DSCFex/MMBtu @ 0% excess air)	9257	9257	9257	9257	9257	9257	9257	9257	9257
CO <sub>2</sub> "F <sub>2</sub> Factor" (DSCFex/MMBtu @ 0% excess air)	1443	1443	1443	1443	1443	1443	1443	1443	1443
Oil Fuel Flow (FQL1, lbs/sec)	15.3732	15.5890	15.9461	18.6422	18.8244	19.0382	21.2169	21.3660	21.2822
Heat Input (MMBtu/hr, Higher Heating Value)	1071.8	1086.8	1111.7	1299.7	1312.4	1327.3	1479.2	1489.6	1483.7
Heat Input (MMBtu/hr, Lower Heating Value)	1007.8	1022.0	1045.4	1222.1	1234.1	1248.1	1390.9	1400.7	1395.2
<b>Ambient Conditions</b>									
Atmospheric Pressure ("Hg)	29.94	29.94	29.94	29.94	29.93	29.92	29.90	29.90	29.89
Temperature (°F): Dry bulb	86.2	87.0	89.7	91.8	91.0	91.4	92.1	92.6	92.9
(°F): Wet bulb	72.6	72.9	73.2	74.1	72.6	73.4	73.8	73.4	72.9
Humidity (lbs moisture/lb of air)	0.0136	0.0137	0.0133	0.0136	0.0125	0.0131	0.0132	0.0128	0.0124
<b>Measured Emissions</b>									
NO <sub>x</sub> (ppmv, dry basis)	48.84	48.61	48.54	51.00	51.03	50.88	51.62	52.28	52.20
O <sub>2</sub> (% volume, dry basis)	13.05	13.02	13.05	12.61	12.64	12.63	12.52	12.51	12.51
CO <sub>2</sub> (% volume, dry basis)	5.94	5.93	5.94	6.28	6.27	6.27	6.34	6.35	6.35
F <sub>2</sub> (fuel factor, range = 1.260 to 1.413 for FO)	1.32	1.33	1.32	1.32	1.32	1.32	1.32	1.32	1.32
<b>Stack Volumetric Flow Rates</b>									
via O <sub>2</sub> "F <sub>2</sub> Factor" (SCFH, dry basis) (Mark V meter)	2.64E+07	2.67E+07	2.74E+07	3.03E+07	3.07E+07	3.11E+07	3.42E+07	3.43E+07	3.42E+07
via CO <sub>2</sub> "F <sub>2</sub> Factor" (SCFH, dry basis) (Mark V meter)	2.60E+07	2.64E+07	2.70E+07	2.99E+07	3.02E+07	3.05E+07	3.37E+07	3.39E+07	3.37E+07
<b>Calculated Emission Rates (via M-19 O<sub>2</sub> "F-factor")</b>									
NO <sub>x</sub> (ppmv, dry @ 15% excess O <sub>2</sub> )	36.7	36.4	36.5	36.3	36.5	36.3	36.3	36.8	36.7
NO <sub>x</sub> (ppmv @ 15% O <sub>2</sub> , ISO Day)	36.8	36.5	36.3	37.3	36.8	37.0	38.0	38.1	37.6
NO <sub>x</sub> (lbs/hr)	154	155	159	185	187	189	211	215	213
SO <sub>2</sub> (lbs/hr, based on fuel flow and fuel sulfur)	43.1	43.7	44.7	52.3	52.8	53.4	59.5	59.9	59.7

## PROCESS DESCRIPTION

Tampa Electric owns and operates the Polk Power Station in Mulberry, Florida. A recently installed simple-cycle power generation unit, manufactured by General Electric, consists of a dual fuel combustion turbine directly coupled to an electric generator. Emission testing was conducted on the unit to determine the compliance status with state and federal regulations. This section of the test report provides a brief description of the unit.

Polk Unit 3 is designed to produce a nominal 165 MW of electrical power. The State of Florida designates this unit as ARMS Emissions Unit 010(CTG-3). The main body of the unit consists of single shaft General Electric Frame 7FA combustion turbine directly coupled to a 60 Hz synchronous generator. The FDEP permitted capacity for the unit is 1600 million British thermal units per hour (MMBtu/hr) of heat input from firing natural gas or 1800 MMBtu/hr of heat input from firing low sulfur distillate oil. Based upon performance curves, the turbine can produce 171.57 MW of power while firing with natural gas and 183.05 MW of power while firing with distillate oil. The rated heat input and power output is based upon the lower heating value (LHV) of each fuel while operating at a compressor inlet temperature of 59°F, a relative humidity of 60%, an absolute ambient air pressure of 14.7 pounds per square inch (psi), and 100% of base load. Performance and emission curves for differing ambient conditions are in Appendix H. The turbine uses water injection to control NO<sub>x</sub> emissions while firing with No. 2 fuel oil (or a superior grade). GE dry, low-NO<sub>x</sub> DLN combustion technology is used to control NO<sub>x</sub> emissions while firing with natural gas.

Unit 3 exhaust gases are vented to the atmosphere through a 114-foot tall stack. The sampling ports are approximately 86 feet (~ 4.8 stack diameters) downstream from the nearest flow disturbance, i.e., the horizontal portion of the exhaust duct. The sampling ports are approximately 8 feet (~ 0.4 stack diameters) upstream from the nearest flow disturbance, i.e., before venting to atmosphere. Access to the stack was made available via a permanent steel frame platform equipped with a caged safety ladder. The internal diameter of the stack at the sample port location was 216 inches.

Tampa Electric personnel obtained operational data from control panel instrumentation. Data was collected from the control system in one-minute intervals into a text file, converted into a Microsoft Excel spreadsheet, and averaged over each test run. All operational data sheets are located in Appendix H.

## ANALYTICAL TECHNIQUES

Emissions from a combustion turbine were measured at the Tampa Electric Polk Power Station located in Mulberry, Florida. Cubix Corporation performed these tests on May 7<sup>th</sup> through 9<sup>th</sup>, 2002 in order to determine the status of compliance with regard to permitted emission limits. This section of the report describes the analytical techniques and procedures used during these tests.

The sampling and analysis procedures used during these tests conformed with those outlined in The Code of Federal Regulations, 40 CFR 60, Appendix A, Methods 1, 3a, 9, 10, 19, 20, and 25a. The stack gas analyses for NO<sub>x</sub>, CO, UHC/THC, O<sub>2</sub> and CO<sub>2</sub> were performed using continuous instrumental monitors. Exhaust gas analyses were performed on a dry basis for all compounds except UHC/THC. Table 7 lists the instruments and detection principles used for these analyses.

The test matrix for the turbine consisted of three sixty-minute test runs at full load and three twenty-minute test runs at each of three reduced loads for each fuel fired in the turbine. Per EPA Method 20 requirements, an initial O<sub>2</sub>-traverse was conducted prior to the tests on the CT stack for each fuel used to fire the turbine. Forty-eight points in the stack cross section, twelve sample points in each of four ports, were measured for 150 seconds at each point. The sampling time at each point was determined from the sampling systems response time (see *Quality Assurance Activities*). No significant stratification was present in the CT stack; therefore, eight representative sample points used in the original traverse were sampled in the subsequent test runs. Stack gases were analyzed for NO<sub>x</sub>, O<sub>2</sub>, and CO<sub>2</sub> by continuous instrumental monitors during each test run. Additionally, CO, UHC concentrations were continuously monitored during each full load test run. A 60-minute VE test was conducted concurrently with one of the full load test runs for both fuels tested.

Provisions were made to introduce the calibration gases to the instrumental monitors via two paths: 1) directly to the instruments via the sample manifold quick-connects and rotameters, and 2) through the complete sampling system including the sample probe, filter, heat trace, condenser, manifold, and rotameters. The former method was used for quick, convenient calibration checks. The latter method was used to demonstrate that the sample was not altered due to leakage, reactions, or adsorption within the sampling system (sample system bias check). A NO<sub>x</sub> standard calibration gas was introduced into the NO<sub>x</sub> analyzer directly. Then the response from the NO<sub>x</sub> analyzer was noted as the calibration gas was introduced at the probe. Any difference between the two responses in the instrument was attributed to the bias of the sample system. Following the span gas bias check, a



zero gas bias check was performed on the NO<sub>x</sub> analyzer using nitrogen, or another calibration gas as a zero, to check for any zero bias of the sample system. In accordance with EPA Method 3a this span and zero bias check procedure was repeated for the CO<sub>2</sub> and O<sub>2</sub> analyzers. This procedure was also used for CO and UHC (although not required by their respective EPA methods).

As shown in Figure 1, a 1-inch diameter stainless steel probe was inserted into the sample port of the stack. The gas sample was continuously pulled through the probe and transported via a 220-foot long, 3/8-inch diameter heat-traced Teflon® tubing to the mobile laboratory through Teflon® tubing via a stainless steel/Teflon® diaphragm pump and into a heated sample manifold. From the heated manifold, the sample was partitioned to the hydrocarbon analyzer through heated lines. The bulk of the gas stream then passed to a stainless steel minimum contact condenser to dry the sample stream and into the (dry) sample manifold. From the manifold, the sample was partitioned to the analyzers through glass and stainless steel rotameters for flow control of the sample.

All instruments were housed in an air-conditioned trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e., NO<sub>x</sub> calibration gases).

EPA Method 1 procedures were used to determine the O<sub>2</sub>-traverse point locations for sampling per the requirements of EPA Method 20. The stack diagram in Appendix A denotes the location of the sample ports and the traverse point distances for the turbine.

The stack gas analyses for CO<sub>2</sub> and O<sub>2</sub> concentrations were performed in accordance with procedures set forth in EPA Method 3a and Method 20, respectively. Instrumental analyses were used in lieu of an Orsat or a Fyrite procedure due to the greater accuracy and precision provided by the instruments. The CO<sub>2</sub> analyzer was based on the principle of infrared absorption; the O<sub>2</sub> analyzer operated using a paramagnetic cell detector.

The F<sub>o</sub> calculation of EPA Method 3b (Section 3.4.1.1) was used to verify that the ratio of O<sub>2</sub> to CO<sub>2</sub> were within an acceptable range during the test runs. In all cases, the F<sub>o</sub> fell within the expected values for natural gas and distillate oil.

Opacity was determined via EPA Method 9. A one-hour opacity test run was performed on the unit for each fuel type by a visible emissions observer who was certified by Eastern Technical Associates of Raleigh, North Carolina. Appendix G provides both the opacity observation sheets as well as observer certification documentation.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous non-dispersive infrared (NDIR) analyzer

was used for this purpose. This reference method analyzer was equipped with a gas correlation filter that removes most interference from moisture, CO<sub>2</sub>, and other combustion products.

EPA Method 20 procedures were used to determine concentrations of NO<sub>x</sub> (via chemiluminescence). NO<sub>x</sub> mass emission rates were calculated as if all the NO<sub>x</sub> was in the form of NO<sub>2</sub>. This approach corresponds to EPA's convention, however, it tends to overestimate the actual NO<sub>x</sub> mass emission rates since the majority of NO<sub>x</sub> is in the form of NO which has less mass per unit volume (i.e., lbs. of emissions per ppmv concentration) than NO<sub>2</sub>.

UHC/THC concentrations were quantified during the testing using Method 25a. These UHC concentrations were used for determination of VOC; therefore, the methane fraction was included in these results. Unburned hydrocarbons were continuously measured using a flame ionization detector (FID). The UHC continuous analyzer was calibrated on methane standards in an air matrix. Thus, the results included in this report are presented on a methane basis. Having the calibration standards in an air basis (i.e., 20.9% O<sub>2</sub>) more closely matches the background matrix of the turbine exhaust and helps to reduce the effect of O<sub>2</sub> synergism on flame ionization detectors.

All data from the continuous monitoring instruments were logged into a computer file in one-minute intervals. A data logger with a computer generated display screen monitored, recorded and averaged the emission concentrations. The program controlling the logging of data was also used to log QA data. See Appendix F of this report for copies of the raw data and Appendix D for the QA data.

Fuel samples were collected daily during the emissions test. Two natural gas samples were collected in duplicate into 300-milliliter Teflon® lined stainless steel sample cylinders. These samples were collected downstream of the fuel system scrubbers and heaters. In addition, onsite fuel analyses were conducted for hydrogen sulfide and moisture content of the natural gas using a Sensidyne™ pump sampler. A distillate oil sample was collected into a 1-liter amber glass sample bottle in duplicate.

The stoichiometric calculations of EPA Method 19 were used to calculate the stack volumetric flow rates and mass emission rates. These calculations are based on the heating value and the O<sub>2</sub> and CO<sub>2</sub> "F-factors" (DSCF of exhaust per MMBtu of fuel burned) for natural gas. Method 19 flow rate determinations are also based on the excess air (as measured from the exhaust diluent concentrations) and the fuel flow rates. Core Laboratories of Houston, Texas analyzed the fuel samples for composition and heating value. Appendix C contains these analyses as well as Cubix's fuel calculations for the O<sub>2</sub> and CO<sub>2</sub> "F Factors". Due to high

levels of turbulence typically present in gas turbines, pitot tube flow rates are unsuitable for determining volumetric flow and mass emissions.

The state and federal permits required additional analyses of the turbine fuels. Core Laboratories of Houston, Texas determined the natural gas total reduced sulfur concentration on a ppm by weight basis and converted to grains of sulfur per 100-scf of natural gas using the American Society of Testing and Materials (ASTM) Method D3246. The distillate oil sulfur was determined on a % weight basis using ASTM Method D4294. The distillate oil fuel bound nitrogen was determined on a ppm by weight basis using ASTM Method D4629. Copies of the fuel analyses are located in Appendix C of this report.

Cubix personnel collected ambient absolute pressure, temperature, and humidity data during each test run. A battery-operated psychrometer that used a fan to continuously pull air through the system was used to determine ambient temperature and humidity conditions. An aircraft-type aneroid barometer (altimeter) was used to measure atmospheric pressure.


All emission calculations were conducted by a computer spreadsheet as shown in Tables 2 through 6 of this report. Example calculations were performed manually using a hand-held calculator in order to verify the spreadsheet formulas. Example calculations are in Appendix B of this report.

**TABLE 7**  
**ANALYTICAL INSTRUMENTATION**

<u>Parameter</u>	<u>Model and Manufacturer</u>	<u>Common Use Ranges</u>	<u>Sensitivity</u>	<u>Response Time (sec.)</u>	<u>Detection Principle</u>
NO <sub>x</sub>	TECO Model 42CHL	0-10 ppm 0-25 ppm 0-50, 0-100 ppm 0-200, 500 ppm 0-1,000 ppm 0-5,000 ppm	0.1 ppm	1.7	Thermal reduction of NO <sub>2</sub> to NO. Chemiluminescence of reaction of NO with O <sub>3</sub> . Detection by PMT. Inherently linear within 1% of full scale.
CO	TECO Model 48C	0-1 ppm 0-10 ppm 0-30 ppm 0-50, 0-100 ppm 0-200 ppm 0-500 ppm 0-1000 ppm	0.1 ppm	60	Infrared absorption, gas filter correlation detector, micro-processor based linearization.
CO <sub>2</sub>	Servomex 1400	0-5% 0-10% 0-15%	0.025% 0.05% 0.075%	< 10	Non-dispersive infrared absorption, electronic linearization of a logarithmic signal (Beer's Law)
O <sub>2</sub>	Servomex 1400	0-5% 0-10% 0-25%	0.02% 0.02% 0.02%	< 10	Paramagnetic cell detector, inherently linear.
THC	JUM Model 3-300	0-10, 0-100, 0-1000, 0-10000 0-100,000 ppm	10 ppb	2.0	Flame ionization of hydrocarbons inherently linear within 1% over the range of the analyzer.

**NOTE:** Higher ranges available by sample dilution.  
Other ranges available via signal attenuation.

**FIGURE 1**  
**INSTRUMENTAL SAMPLE SYSTEM DIAGRAM**



## QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendices D and E describe each of those activities.

A multi-point calibration was performed for each instrument in the field prior to the collection of data. The instrument's linearity was checked by first adjusting the instrument's zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration. The instrument's response was accepted as being linear if the response of the other calibration gases agreed within  $\pm 2$  percent of range from the predicted values. The response of the infrared absorption type CO and CO<sub>2</sub> analyzers is made linear through electronic suppression.

System bias checks were performed both before and after the sampling system was used for emissions testing. The sampling system's integrity was tested by comparing the responses of the NO<sub>x</sub> analyzer to a calibration gas (and a zero gas) introduced via two paths as previously described in the *Analytical Techniques* section of this report. This system bias test was performed to assure that no alteration of the sample had occurred during the test due to leakage, reactions, or absorption. Similarly, system bias checks were performed with UHC/THC, CO, O<sub>2</sub>, and CO<sub>2</sub> for added assurance of sample system integrity. The results of the system bias checks are available in Appendix D.

The efficiency of the NO<sub>2</sub> to NO converter in the NO<sub>x</sub> analyzer was checked by monitoring a mixture of NO in N<sub>2</sub> standard gas and zero grade air from a Tedlar® bag. When this bag is mixed and exposed to sunlight, the NO is oxidized to NO<sub>2</sub>. If the NO<sub>x</sub> instrument's converter is 100% efficient, then the total NO<sub>x</sub> response does not decrease as the NO in the bag is converted to NO<sub>2</sub>. The criterion for acceptability is demonstrable NO<sub>x</sub> converter efficiency greater than 90%; this is demonstrated if the concentration of NO<sub>x</sub> does not decrease by more than 2% of the highest read value over a 30-minute period. This test was conducted both before the start of the natural gas and the distillate oil tests although not specified by the method. Quality assurance worksheets, found in Appendix D, summarize the results of the converter efficiency test.

The residence time of the sampling and measurement system was estimated using the pump flow rate and the sampling system volume. The pump's rated flow rate is 0.8 scfm at 5 psig. The sampling system volume was approximately 0.34 scf. Therefore, the minimum sample residence time was ~ 26 seconds.

The NO<sub>x</sub> and O<sub>2</sub> sampling and analysis system was checked for response time per the procedures outlined in EPA's Method 20, Section 5.5. The average NO<sub>x</sub> analyzer's response times were 74 seconds upscale and 63 seconds downscale. The O<sub>2</sub> analyzer's average response times were 43 seconds upscale and 46.7 seconds downscale. The results of these response time tests are contained in Appendix D.

Cubix Corporation and instrument vendors conducted interference response tests on the NO<sub>x</sub>, CO, and O<sub>2</sub> analyzers. The sum of the interference responses for H<sub>2</sub>O, C<sub>3</sub>H<sub>8</sub>, CO, CO<sub>2</sub> and O<sub>2</sub> is less than 2 percent of the applicable full-scale span value. The instruments used for the tests meet the performance specifications for EPA Methods 3a, 7e, 10, and 20. The results of the interference tests are available in Appendix D of this report.

The sampling system was leak checked by demonstrating that it could hold a vacuum greater than 15 inches of mercury ("Hg) (>22 "Hg actual) for at least 1 minute with a decline of less than 1 "Hg. A leak test was conducted after the sample system was set up and before testing began, at the beginning and end of each test day, and after testing was completed before dismantling the system. This test was conducted to insure that ambient air was not diluting the sampling system. No leakage was detected.

As a minimum, before and after each test run, the analyzers were checked for zero and span drift. This allows test runs to be bracketed by calibrations and documents the precision of the data just collected. Calibration gases were introduced to the analyzers through the entire sampling system. Appendix D contains quality assurance tables that summarize the zero and span checks that were performed for each test run. The worksheets also contain the data used to correct the data for drift per EPA Method 6c, Equation 6c-1. NO<sub>x</sub>, O<sub>2</sub>, and CO<sub>2</sub> data were corrected for drift as required by the test methods. Although not required by the test methods, UHC/THC and CO concentrations were also corrected for drift to maintain consistency in results reporting.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to ±1 % accuracy for all calibration gases. EPA Protocol No. 1 was used, where applicable (i.e., NO<sub>x</sub> gases), to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix E.

Appendix E also contains calibration data ancillary equipment used during this testing. An altimeter/barometer was used for determination of barometric pressure. A fan-operated psychrometer with NIST traceable thermometers was used to determine ambient and dew point temperatures.

During the testing, fuel samples were collected in duplicate as insurance. The

samples were shipped to Core Laboratories of Houston, Texas with a chain-of-custody form. Sample custody was maintained from the sampling location to the analytical lab. Only one of the duplicate samples was analyzed. After the sample analysis, Cubix reviewed the sample results. Since results of the fuel samples were within the expected values for the fuels sampled, the duplicate samples were not analyzed.

Cubix collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Cubix makes no warranty as to the suitability of the test methods. Cubix assumes no liability relating to the interpretation and use of the test data by others.



**APPENDIX A:  
FIELD DATA SHEETS**




# Circular Stack Sampling Traverse Point Layout (EPA Method 1, Stratification Traverse Points)

Date: May 6th, 2002  
 Client: Tampa Electric Company  
 Plant: Polk Power Station  
 Source: Unit 3, a GE Frame 7FA  
 Technician(s): LJB, RPO, SBB

Port + Stack ID (in): 236  
 Port Extension (in): 20  
 Stack ID (in): 216.00  
 Stack Area (ft<sup>2</sup>): 254.46  
 Duct Diameters **upstream** from flow disturbance (A): 0.40  
 Duct Diameters **downstream** from flow disturbance (B): 4.78  
 Total Required Traverse Points: 48  
 No. of Traverse Points per Diameter: 24

## Stack Diagram (Draw side view showing major components, dimensions, upstream/downstream flow disturbances)





### CEMS Information

**Spectrum CEMS Package**  
 Spectrum Systems Inc. DAHS  
 Model 20/20, S/N 2020POLK3  
 Thermo Environmental NO<sub>x</sub> Analyzer  
 Model 42C, S/N 42C-70630-366  
 Siemens CO<sub>2</sub> Analyzer, Model  
 Ultramat 6E, S/N F-NR.N1-N5-0675  
 M&C Gas Dilution Probe, Model  
 SP2000-H, S/N 7314/10026611

### Unit Information

General Electric Power Systems  
 Simple-Cycle Model PG7241  
 Combustion Gas Turbine Generator Set  
 CT Serial No. 297956  
 Generator Serial No. 337X252  
 Nominally rated to produce 165-MW.  
 Nominally permitted to fire with 1600  
 MMBtu/hr (LHV) Natural Gas or with  
 1800 MMBtu/hr (LHV) No. 2 Fuel Oil.

Traverse Point Number	Number of Traverse Points on a Diameter					*Calculated Traverse Point	*Traverse Point with Port Extension
	4	6	8	12	*Other		
1	6.7	4.4	3.2	2.1	1.1	2.38	22.38
2	25.0	14.6	10.5	6.7	3.2	6.91	26.91
3	75.0	29.6	19.4	11.8	5.5	11.88	31.88
4	93.3	70.4	32.3	17.7	7.9	17.06	37.06
5		85.4	67.7	25.0	10.5	22.68	42.68
6		95.6	80.6	35.6	13.2	28.51	48.51
7			89.5	64.4	16.1	34.78	54.78
8			96.8	75.0	19.4	41.90	61.90
9				82.3	23.0	49.68	69.68
10				88.2	27.2	58.75	78.75
11				93.3	32.3	69.77	89.77
12				97.9	39.8	85.97	105.97



\*Stack diameters > 24 in shall have no traverse points located within 1-inch of the stack wall  
 \*Stack diameters ≤ 24 in shall have no traverse points located within 0.5-inch of the stack wall  
 † 24 traverse points per diameter used for sampling with 12 points used in each of 4 ports

# Cubix Corporation

## Air Emission Testing Job Safety Analysis

Date: May 6-9, 2002  
 Mobile Lab/Cubix Crew: FL1/LJB, RPO, SBB  
 Client: Tampa Electric Company  
 Job #/Contact: 6949-Mike Perkins  
 Plant Name: Polk Power Station  
 Unit Name(s): Unit 3  
 Location (city/state): Mulberry, Florida

### Description of Testing Activities:

Compliance emissions testing on Unit 3, a newly installed GE Frame 7FA combustion turbine. Natural Gas and Fuel Oil Testing. Additionally, some brief tuning was conducted for GE due to low load NG emission problems.

Permits/Required		Comments	Personal Protective Equipment Required			
Hot Work	<input type="checkbox"/> Check	Additionally required was CO monitors in the area we were testing. CO monitors and escape packs were supplied by Polk Power Station. 1 hour safety orientation.	hard hat	<input checked="" type="checkbox"/> Check	acid suit	<input type="checkbox"/> Check
Cold Work	<input type="checkbox"/> Check		ear plugs/muffs	<input checked="" type="checkbox"/> Check	rubber boots	<input type="checkbox"/> Check
Lock & Tag	<input type="checkbox"/> Check		safety glasses	<input checked="" type="checkbox"/> Check	monogoggles	<input type="checkbox"/> Check
Scaffolding	<input type="checkbox"/> Check		steel toed shoes	<input checked="" type="checkbox"/> Check	face shield	<input type="checkbox"/> Check
Crane/Lift	<input type="checkbox"/> Check		gloves	<input checked="" type="checkbox"/> Check	safety harness	<input type="checkbox"/> Check
Live Break	<input type="checkbox"/> Check		hot gloves	<input checked="" type="checkbox"/> Check	respirator	<input type="checkbox"/> Check

Emergency Response	Phone No.'s & Alarm Knowledge (list type of sound)	
Safe Haven: assembly point and South West gate (Control room? Plant office?)	Plant Contact Ph.: 863-428-5132 Evacuate: continuous blast	
Wind Direction: SE (N NE E SE S SW W NW)	Control Room Ph.: 39132 Fire: _____	
Evacuation Route: South West Gate front gate? Back gate? Crosswind?	Emergency Ph.: control room All Clear: continuous warbel	
Assembly Points: by CM trailer and 1st aid building office? Down the road?	Other: _____ Poison Gas: _____	
Plant Map Reviewed: YES Yes or No or Not Applicable	<i>If facility has no alarms, verify communication with control room</i>	

Emergency Equipment Locations Identified	
Emergency Shut Off <input type="checkbox"/> Located <input checked="" type="checkbox"/> Not Applicable manual emergency trip	
Fire Extinguisher <input checked="" type="checkbox"/> Located <input type="checkbox"/> Not Applicable Cubix Mobile Lab & Plant Ext.	
Safety Showers <input checked="" type="checkbox"/> Located <input type="checkbox"/> Not Applicable required for plant?	
Escape Air Pack <input checked="" type="checkbox"/> Located <input type="checkbox"/> Not Applicable required for plant?	

JOB HAZARD IDENTIFIED	PRECAUTIONS TO BE IMPLEMENTED
Hazardous Material (in plant area) hydrogen sulfide, carbon monoxide, sulfur oxides, syngas, compressed gases, natural gas (compressed), fuel oil, coal dust	Cubix MSDS in Mobile Lab <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
(flammability, reactivity, health hazards)	Plant MSDS reviewed??? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> Not Available

Environmental Hazards		Comments:	Protective Equipment	Protective Actions
airborne particulate <input checked="" type="checkbox"/>	<input type="checkbox"/>	Unseasonably warm weather. Sean Barrett couldn't handle the weather and quit after 2 days.	respirator <input type="checkbox"/>	OTHER <input type="checkbox"/>
burn hazard <input checked="" type="checkbox"/>	<input type="checkbox"/>		work gloves <input checked="" type="checkbox"/>	shade/cool breaks <input checked="" type="checkbox"/>
rain / fog <input checked="" type="checkbox"/>	<input type="checkbox"/>		rain protect elect. equip. <input type="checkbox"/>	rain gear <input type="checkbox"/>
electrical shock <input checked="" type="checkbox"/>	<input type="checkbox"/>		inspect extension cords <input type="checkbox"/>	secure/protect ext. cords <input type="checkbox"/>
heat stress <input checked="" type="checkbox"/>	<input type="checkbox"/>		hot gloves <input checked="" type="checkbox"/>	warm up breaks <input type="checkbox"/>
cold weather/frostbite <input checked="" type="checkbox"/>	<input type="checkbox"/>		cold weather clothing <input type="checkbox"/>	liquid intake <input type="checkbox"/>
inadequate lighting <input checked="" type="checkbox"/>	<input type="checkbox"/>		flash light/head lamp <input type="checkbox"/>	night lighting <input type="checkbox"/>
noise <input checked="" type="checkbox"/>	<input type="checkbox"/>		hearing protection <input type="checkbox"/>	hard hat liner <input type="checkbox"/>
poor access/egress <input checked="" type="checkbox"/>	<input type="checkbox"/>	housekeeping <input checked="" type="checkbox"/>	alternate route <input checked="" type="checkbox"/>	

Chemical Hazards (check hazards that are present at jobsite)		Respiratory Safety Equip	Protective Clothing
asfixiation <input checked="" type="checkbox"/> Check	carcinogen <input checked="" type="checkbox"/>	supplied fresh air <input type="checkbox"/> Check	fire suit <input type="checkbox"/>
poison gas <input checked="" type="checkbox"/> Check	chemical burns <input type="checkbox"/>	SCBA <input type="checkbox"/> Check	acid suit <input type="checkbox"/>
chemical eye exposure <input checked="" type="checkbox"/> Check	chemical skin exposure <input type="checkbox"/>	respirator (correct type?) <input type="checkbox"/> Check	rubber boots <input type="checkbox"/>
flammable gas <input checked="" type="checkbox"/> Check	flammable liquid <input checked="" type="checkbox"/>	escape pack <input checked="" type="checkbox"/> Check	monogoggles <input type="checkbox"/>
strong acid <input type="checkbox"/> Check	strong base <input type="checkbox"/>	exposure dosimeter <input type="checkbox"/> Check	face shield <input type="checkbox"/>
OTHER, coal dust <input checked="" type="checkbox"/> Check		OTHER <input type="checkbox"/> Check	OTHER <input type="checkbox"/>

Equipment Lifting & Fall Hazard	Inspections and Protective Actions
test equipment hoisting (pulley/boom) <input checked="" type="checkbox"/> Required <input type="checkbox"/> Not Applicable	equipment secure <input checked="" type="checkbox"/> Check
portable ladder <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Applicable	operator certification <input type="checkbox"/> Check
man lift (cherry picker) <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Applicable	guy lines <input type="checkbox"/> Check
personnel basket (crane) <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Applicable	radios/handsignals <input checked="" type="checkbox"/> Check
Plant Stairs & Ladders <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Applicable	housekeeping <input type="checkbox"/> Check
rigging sample lines, umbilic <input checked="" type="checkbox"/> Required <input type="checkbox"/> Not Applicable	lines secure <input checked="" type="checkbox"/> Check
scaffold <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Applicable	secure tools <input checked="" type="checkbox"/> Check
	clear lift zone <input checked="" type="checkbox"/> Check
	rope inspection <input checked="" type="checkbox"/> Check
	body harness <input type="checkbox"/> Check
	guard rails, toe plates <input checked="" type="checkbox"/> Check
	ladder tie-off <input type="checkbox"/> Check
	monorails secure <input type="checkbox"/> Check
	hard hats <input checked="" type="checkbox"/> Check

**APPENDIX B:  
EXAMPLE CALCULATIONS**

## EXAMPLE TURBINE GASEOUS CALCULATIONS NATURAL GAS EMISSIONS TESTING

### Moisture Content (via Humidity and H<sub>2</sub>O F Factor)

*Refers to Test Run #U3-NG-100%-1*

H<sub>amb</sub> = ambient humidity (lbs H<sub>2</sub>O/ lb air) = 0.0141 lbs/lb air  
 CO<sub>2</sub> = concentration of O<sub>2</sub> = 13.72% (from analyzer)  
 F<sub>stoi</sub> = stoichiometric moisture @ 0% O<sub>2</sub> = 18.78% vol.  
 F<sub>hum.</sub> = humidity moisture = H<sub>amb</sub> x 1.61 x 100  
 F<sub>com.</sub> = combustion moisture (% volume)

F<sub>w</sub> = moisture fraction by % volume

F<sub>w</sub> = F<sub>com.</sub> + F<sub>hum.</sub>

$$F_w = F_{stoi} \times \left( \frac{20.9 - \%O_2}{20.9} \right) + (H_{amb} \times 1.61 \times 100)$$

$$F_w = 18.78 \times \left( \frac{20.9 - 13.72}{20.9} \right) + (0.0141 \times 1.61 \times 100)$$

F<sub>w</sub> = 8.72 % moisture (differences due to rounding)

### Stack Gas Flow Rates via F-factors (Q<sub>d</sub>)

*refers to Test Run #U3-NG-100%-1*

Convert mass fuel flow to volumetric fuel flow:

H<sub>g</sub> = heating value of nat. gas = 23068 Btu/lb (gross) from fuel analysis  
 F = fuel flow = 71379 (lbs/hr) from Control Panel  
 H = heat input (MMBTU/hr)  
 = H<sub>g</sub> x F / (1 x 10<sup>6</sup>) = 1646.57 MMBtu/hr

Calculate flow rate using O<sub>2</sub> F-factor:

CO<sub>2</sub> = O<sub>2</sub> concentration in exhaust = 13.72 by vol, dry

O<sub>2</sub> F<sub>d</sub> Factor = 8645 DSCF of Exhaust/MMBtu of fuel burned @ 0% excess air

Q<sub>d1</sub> = Stack Exhaust Gas Flow Rate via O<sub>2</sub> F-factor

$$Q_{d1} = \frac{H \times O_2 \text{ F}_d \text{ Factor} \times 20.9}{20.9 - CO_2}$$

$$Q_{d1} = \frac{1646.57 \times 8645 \times 20.9}{20.9 - 13.72}$$

Q<sub>d1</sub> = 4.14(3) x 10<sup>7</sup> DSCFH

Calculate flow rate using **CO<sub>2</sub> F-factor**:

Using same data as above, except:

CCO<sub>2</sub> = Concentration of CO<sub>2</sub> in exhaust = 4.19 % vol,dry (stack ave)

CO<sub>2</sub> F<sub>c</sub> Factor = 1029 DSCF of CO<sub>2</sub>/ MMBtu of fuel burned @ 0% excess air

Qd<sub>2</sub> = Stack Exhaust Gas Flow Rate via CO<sub>2</sub> F-factor

$$Qd_2 = \frac{H \times CO_2 F_c \text{ Factor} \times 100}{CCO_2}$$

$$Qd_2 = \frac{1646.57 \times 1029 \times 100}{4.19}$$

$$Qd_2 = 4.04(4) \times 10^7 \text{ DSCFH}$$

### F<sub>o</sub> Calculation to Verify O<sub>2</sub>/CO<sub>2</sub> Measurements

*refers to Test Run #U3-NG-100%-1*

CCO<sub>2</sub> = concentration of carbon dioxide = 4.19% (from analyzer, ave.)

CO<sub>2</sub> = concentration of oxygen = 13.72% (from analyzer, ave.)

F<sub>o</sub> = fuel factor for natural gas combustion by-products

$$= \frac{20.9 - \% O_2}{\% CO_2}$$

$$F_o = \frac{20.9 - 13.72}{4.19}$$

F<sub>o</sub> = 1.71(acceptable F<sub>o</sub> values for nat gas = 1.600 to 1.836)

### Correction of NO<sub>x</sub> Gas Concentrations, CNO<sub>x</sub>

*Refers to Test Run #U3-NG-100%-1*

The logged data records were used for continuous instrumental monitor data. Analytical instruments tend to drift in their calibrations over time and with changes in atmospheric conditions. Span and zero gas bias drift checks (calibrations) were conducted prior to and following each test. The results of these calibrations were used to bracket and thus correct the raw gas concentrations into corrected (more accurate) gas concentrations. The calculation used for these correction is 40 CFR 60, Appendix A, Method 6c, Equation 6c-1. This correction is required for NO<sub>x</sub>, O<sub>2</sub>, and CO<sub>2</sub> exhaust concentrations. Cubix also conducts this correction for EPA Methods 10 and 25a, CO and THC monitoring, in order to present more accurate and consistent test results.

UNO<sub>x</sub> = 9.22 ppmv, uncorrected

C<sub>o</sub> = Average of initial/final zero gas concentrations  
= 0.10 ppmv

C<sub>m</sub> = Average of initial/final span gas concentrations  
= 8.415 ppmv

C<sub>ma</sub> = Actual upscale cylinder span gas concentrations  
= 8.60 ppmv

$C_{NO_x}$  = Effluent  $NO_x$  gas concentration, ppmv corrected

$$= (U_{NO_x} - C_o) \times \frac{C_{ma}}{C_m - C_o}$$
$$= (9.22 - (0.10)) \times \frac{8.60}{8.415 - (0.10)}$$

$C_{NO_x} = 9.43(3)$  ppmv  $NO_x$ , dry basis corrected

**NO<sub>x</sub> Correction to 15% O<sub>2</sub>**

*refers to Test Run #U3-NG-100%-1*

$C_{NO_x}$  = observed  $NO_x$  concentration = 9.433 ppmv (from analyzer)  
 $C_{O_2}$  = concentration of oxygen = 13.72 % volume (from analyzer)

$NO_x @ 15\% O_2$  =  $NO_x$  emission concentration, corrected to 15% excess oxygen

$$= \frac{(C_{NO_x} \times (20.9 - 15.0\% O_2))}{20.9 - C_{O_2}}$$
$$= \frac{9.433 \times 5.9}{20.9 - 13.72}$$

$NO_x @ 15\% O_2 = 7.75(1)$  ppmv @ 15% excess  $O_2$

**EPA ISO-day Correction for NO<sub>x</sub>**

*refers to Test Run #U3-NG-100%-1*

$H_{obs}$  = observed humidity of ambient air = 0.0141 (lbs / lb air)  
 $NO_x(@15\%O_2)$  = concentration of  $NO_x @ 15\% O_2$  = 7.751 ppmv @ 15%  $O_2$   
 $P_{ref}$  = reference combustor inlet pressure = 101.3 kpa  
 $P_{obs}$  = observed combustor inlet pressure  
=  $P_{bar}$  - Inlet Air Duct Loss/13.6  
= 30.01 - 2.29/13.6  
= 29.842 "Hg x 3.3864 kpa/"Hg = 101.057 kpa  
 $T_{CTIM}$  = compressor inlet temperature  
= (85.0 °F - 32 °F) x (5/9) + 273.15 °C = 302.59 °K

$NO_x(EPA)$  =  $NO_x$  emission concentration, corrected to ISO conditions

$$= NO_x(@15\%O_2) \times \sqrt{\frac{P_{ref}}{P_{obs}}} \times \left(\frac{288^{\circ}K}{T_{CTIM}}\right)^{1.53} \times 2.718^{19(H - 0.00633)}$$
$$= 7.751 \times \sqrt{\frac{101.3}{101.057}} \times \left(\frac{288}{302.59}\right)^{1.53} \times 2.718^{19(0.0141 - 0.00633)}$$

$NO_x(EPA) = 8.34$  ppmv @ ISO Day Conditions (Differences due to rounding)



**NOx Mass Emission Rate (lbs/hr)**

*Refers to Test Run #U3-NG-100%-1*

$C_{NOx}$  = observed concentration of NOx = 9.433 ppmv (average)

$MW_{NOx}$  = 46.01 lb/lb-mole for nitrogen dioxide  
for an ideal gas, 385.15 SCF = 1.0 lb/mole

$Q_{d1}$  =  $4.143 \times 10^7$  SCFH, dry (from O<sub>2</sub>, higher "F-factor" calculated from ex. flow)

$E_{NOx}$  = mass emission rate of NOx in (lb/hr)

$$= C_{NOx} \times 10^{-6} \times Q_{d1} \times \frac{MW_{NOx}}{385.15}$$

$$= 9.433 \times 10^{-6} \times 4.143 \times 10^7 \times \frac{46.01}{385.15}$$

$E_{NOx}$  = 46.7 lbs/hr

**CO Mass Emission Rate (lbs/hr)**

*Refers to Test Run #U3-NG-100%-1*

$C_{CO}$  = observed concentration of CO = 0.26 ppmv (average)

$MW_{CO}$  = 28.01 lb/lb-mole for carbon monoxide  
using same formula as for NOx mass emission rate

$Q_{d1}$  =  $4.143 \times 10^7$  SCFH, dry (from O<sub>2</sub>, higher "F-factor" calculated from ex. flow)

$E_{CO}$  = mass emission rate of CO in (lb/hr)

$$= 0.26 \times 10^{-6} \times 4.143 \times 10^7 \times \frac{28.01}{385.15}$$

$E_{CO}$  = 0.78 lbs/hr

**UHC as VOC Mass Emission Rate (lbs/hr)**

*Refers to Test Run #U3-NG-100%-1*

$C_{UHC}$  = observed concentration of UHC = 0.57 ppmv as CH<sub>4</sub>, wet

$B_{ws}$  = stack gas moisture mole fraction = 0.0872

$Q_{d1}$  =  $4.143 \times 10^7$  SCFH, dry (from O<sub>2</sub>, higher "F-factor" calculated from ex. flow)

$MW_{CH_4}$  = 16.04 lb/lb-mole for methane  
using same formula as for NOx mass emission rate (w/ moisture correction)

$E_{VOC}$  = mass emission rate of VOC in (lb/hr), including UHC (e.g, methane)

$$= C_{UHC} \times 10^{-6} \times \frac{1}{1 - B_{ws}} \times Q_{d1} \times \frac{MW_{CH_4}}{385.15}$$

$$= 0.57 \times 10^{-6} \times \frac{1}{1 - 0.0872} \times 4.143 \times 10^7 \times \frac{16.04}{385.15}$$

$E_{VOC}$  = 1.08 lbs/hr

**SO<sub>2</sub> Mass Emission Rate (lbs/hr)**

*Refers to Test Run #U3-NG-100%-1*

S	= concentration of sulfur	= < 1.0 ppm, weight
F	= fuel flow from fuel meter	= 71,379 lbs/hr
MW <sub>S</sub>	= molecular weight of sulfur	= 32.06 g/mol
MW <sub>SO<sub>2</sub></sub>	= molecular weight of sulfur dioxide	= 64.06 g/mol

Note: Formula assumes all sulfur in fuel is converted to SO<sub>2</sub>

**ESO<sub>2</sub>** = mass emission rate of SO<sub>2</sub> in (lbs/hr)

$$= S \times F \times \left( \frac{MW_{SO_2}}{MW_S} \right)$$

$$= < 1.0 \times 10^{-6} \times 71379 \text{ lbs/hr} \times \left( \frac{64.06}{32.06} \right)$$

**ESO<sub>2</sub>** = < 0.14 lbs/hr

## EXAMPLE TURBINE GASEOUS CALCULATIONS DISTILLATE OIL EMISSIONS TESTING

### Stack Gas Flow Rates via F-factors (Qd)

*refers to Test Run #U3-Oil-100%-1*

Convert mass fuel flow to volumetric fuel flow:

H<sub>g</sub> = heating value of Fuel Oil = 19366 Btu/lb (gross) from fuel analysis

F = fuel flow = 24.5480 lbs/sec from Control Panel

H = heat input (MMBTU/hr)

$$= H_g \times F \times 3600 / (1 \times 10^6) = 1711.43 \text{ MMBtu/hr}$$

Calculate flow rate using **O<sub>2</sub> F-factor**:

CO<sub>2</sub> = O<sub>2</sub> concentration in exhaust = 12.54% vol, dry (stack ave)

O<sub>2</sub> F<sub>d</sub> Factor = 9257 DSCF of Exhaust/MMBtu of fuel burned @ 0% excess air

**Qd<sub>1</sub>** = Stack Exhaust Gas Flow Rate via O<sub>2</sub> F-factor

$$Q_{d1} = \frac{H \times O_2 \text{ F}_d \text{ Factor} \times 20.9}{20.9 - CO_2}$$

$$Q_{d1} = \frac{1711.43 \times 9257 \times 20.9}{20.9 - 12.54}$$

$$Q_{d1} = 3.96(1) \times 10^7 \text{ DSCFH}$$

Calculate flow rate using **CO<sub>2</sub> F-factor**:

Using same data as above, except:

CCO<sub>2</sub> = Concentration of CO<sub>2</sub> in exhaust = 6.34% vol, dry (stack ave)

CO<sub>2</sub> F<sub>c</sub> Factor = 1443 DSCF of CO<sub>2</sub>/MMBtu of fuel burned @ 0% excess air

**Qd<sub>2</sub>** = Stack Exhaust Gas Flow Rate via CO<sub>2</sub> F-factor

$$Q_{d2} = \frac{H \times CO_2 \text{ F}_c \text{ Factor} \times 100}{CCO_2}$$

$$Q_{d2} = \frac{1711.43 \times 1443 \times 100}{6.34}$$

$$Q_{d2} = 3.89(5) \times 10^7 \text{ DSCFH}$$

### F<sub>o</sub> Calculation to Verify O<sub>2</sub>/CO<sub>2</sub> Measurements

*refers to Test Run #U3-Oil-100%-1*

CCO<sub>2</sub> = concentration of carbon dioxide = 6.34% (from analyzer, ave.)  
CO<sub>2</sub> = concentration of oxygen = 12.54% (from analyzer, ave.)

F<sub>o</sub> = fuel factor for fuel oil combustion by-products

$$= \frac{20.9 - \% O_2}{\% CO_2}$$

$$F_o = \frac{20.9 - 12.54}{6.34}$$

F<sub>o</sub> = 1.32 (acceptable F<sub>o</sub> values for distillate oil = 1.260 to 1.413)

### Correction of NO<sub>x</sub> Gas Concentrations, CNO<sub>x</sub>

*Refers to Test Run #U3-Oil-100%-1*

The logged data records were used for continuous instrumental monitor data. Analytical instruments tend to drift in their calibrations over time and with changes in atmospheric conditions. Span and zero gas drift checks (calibrations) were conducted prior to and following each test. The results of these calibrations were used to bracket and thus correct the raw gas concentrations into corrected (more accurate) gas concentrations. The calculation used for these correction is 40 CFR 60, Appendix A, Method 6c, Equation 6c-1.

UNO<sub>x</sub> = 50.30 ppmv, uncorrected

C<sub>o</sub> = Average of initial/final zero gas concentrations  
= 0.20 ppmv

C<sub>m</sub> = Average of initial/final span gas concentrations  
= 44.595 ppmv

C<sub>ma</sub> = Actual upscale cylinder span gas concentrations  
= 46.20 ppmv

CNO<sub>x</sub> = Effluent NO<sub>x</sub> gas concentration, ppmv corrected

$$= (UNO_x - C_o) \times \frac{C_{ma}}{C_m - C_o}$$

$$= (50.30 - (0.20)) \times \frac{46.20}{44.595 - (0.20)}$$

CNO<sub>x</sub> = 52.13(7) ppmv NO<sub>x</sub>, dry basis corrected

### NOx Correction to 15% O2

*refers to Test Run #U3-Oil-100%-1*

CNO<sub>x</sub> = observed NO<sub>x</sub> concentration = 52.137 ppmv (from analyzer)  
CO<sub>2</sub> = concentration of oxygen = 12.54% volume (from analyzer)

NO<sub>x</sub> @15% O<sub>2</sub> = NO<sub>x</sub> emission concentration, corrected to 15% excess oxygen

$$= \frac{(C_{NO_x} \times (20.9 - 15.0\% O_2))}{20.9 - CO_2}$$

$$= \frac{52.137 \times 5.9}{20.9 - 12.54}$$

NO<sub>x</sub> @15% O<sub>2</sub> = 36.8(0) ppmv @ 15% excess O<sub>2</sub>

### EPA ISO-day Correction for NOx

*refers to Test Run #U3-Oil-100%-1*

H<sub>obs</sub> = humidity at compressor inlet = 0.0122 (lbs / lb air)  
NO<sub>x</sub>(@15%O<sub>2</sub>) = concentration of NO<sub>x</sub> @ 15% O<sub>2</sub> = 36.80 ppmv @15% O<sub>2</sub>

P<sub>ref</sub> = reference combustor inlet pressure = 101.3 psia

P<sub>obs</sub> = observed combustor inlet pressure

= P<sub>bar</sub> - Inlet Air Duct Loss/13.6

= 29.93 - 2.31/13.6

= 29.760 "Hg x 3.3864 kpa/"Hg = 100.779 kpa

T<sub>CTIM</sub> = compressor inlet temperature

= (91.3 °F - 32 °F) x (5/9) + 273.15 °C = 306.09 °K

NO<sub>x</sub>(EPA) = NO<sub>x</sub> emission concentration, corrected to ISO conditions

$$= NO_x(@15\%O_2) \times \sqrt{\frac{P_{ref}}{P_{obs}}} \times \left(\frac{288^{\circ}K}{T_{CTIM}}\right)^{1.53} \times 2.718^{19(H - 0.00633)}$$

$$= 36.80 \times \sqrt{\frac{101.3}{100.779}} \times \left(\frac{288}{306.09}\right)^{1.53} \times 2.718^{19(0.0122 - 0.00633)}$$

NO<sub>x</sub>(EPA) = 37.6 ppmv @ ISO Day Conditions

**NOx Mass Emission Rate (lbs/hr)**

*Refers to Test Run #U3-Oil-100%-1*

CNO<sub>x</sub> = observed concentration of NO<sub>x</sub> = 52.137 ppmv  
KNO<sub>x</sub> = conversion factor for NO<sub>x</sub> from ppmv to lbs/dscf  
= 1.194 x 10<sup>-7</sup> (from EPA Method 19)  
Qd1 = 3.961 x 10<sup>7</sup> SCFH, dry (from O<sub>2</sub>, higher "F-factor" calculated from ex. flow)  
ENO<sub>x</sub> = mass emission rate of NO<sub>x</sub> in (lb/hr)  
= CNO<sub>x</sub> x Qd1 x KNO<sub>x</sub>  
= 52.137 x 3.961 x 10<sup>7</sup> x 1.194 x 10<sup>-7</sup>  
ENO<sub>x</sub> = 247 lbs/hr

**CO Mass Emission Rate (lbs/hr)**

*Refers to Test Run #U3-Oil-100%-1*

CCO = observed concentration of CO = 0.54 ppmv (average)  
MWCO = 28.01 lb/lb•mole for carbon monoxide  
385.15 = volume one lb•mole of gas occupies in scf, dry  
Qd1 = 3.961 x 10<sup>7</sup> SCFH, dry (from O<sub>2</sub>, higher "F-factor" calculated from ex. flow)  
ECO = mass emission rate of CO in (lb/hr)  
= CCO x 10<sup>-6</sup> x Qd1 x  $\frac{MWCO}{385.15 \text{ scf/lb}\cdot\text{mol}}$   
= 0.54 x 10<sup>-6</sup> x 3.961 x 10<sup>7</sup> x  $\frac{28.01 \text{ lb/lb}\cdot\text{mol}}{385.15 \text{ scf/lb}\cdot\text{mol}}$   
ECO = 1.56 lbs/hr

**Stack Gas Moisture by H2O factor**

*refers to Test Run #U3-Oil-100%-1*

FH<sub>2</sub>O = "F Factor" for combustion moisture = 1263 (SCF H<sub>2</sub>O/ MMBtu Fuel)  
FO<sub>2</sub> = "F Factor" for dry combustion products = 9257 (DSCF exhaust/ MMBtu Fuel)  
CO<sub>2</sub> = concentration of O<sub>2</sub> in stack = 12.54% (dry basis)  
H<sub>a</sub> = combustion air humidity = 0.0122 (lbs water/ lb dry air)  
W<sub>i</sub> = water injection rate = 121,158 (lbs/hr)  
Qd1 = stack volumetric flow = 3.961 x 10<sup>7</sup> (DSCFH)  
Molecular weight of H<sub>2</sub>O = 18.01 (lb/lb-mole)  
Molecular weight of dry air = 28.95 (lb/lb-mole)  
Concentration of O<sub>2</sub> in dry air = 20.9 (volume %)

$$\begin{aligned} \% \text{ Combustion Moisture} &= \frac{F_{H_2O}}{(F_{H_2O} + F_{O_2})} \times \frac{(20.9 - C_{O_2})}{20.9} \times 100 \\ &= \frac{1263}{(1263 + 9257)} \times \frac{(20.9 - 12.54)}{20.9} \times 100 \\ &= 4.802 \end{aligned}$$

$$\begin{aligned} \% \text{ Ambient Moisture} &= \frac{28.95}{18.01} \times H_a \times 100 \\ &= 1.61 \times 0.0122 \times 100 \\ &= 1.964 \end{aligned}$$

$$\begin{aligned} \% \text{ Water Injection} &= \frac{100 \times 385.15 \text{ ft}^3/\text{lb-mole} \times W_i \times F_{O_2}}{18.01 \text{ lbs/lb-mole} \times Q_{d1} \times (F_{H_2O} + F_{O_2})} \\ &= \frac{100 \times 385.15 \text{ ft}^3/\text{lb-mole} \times 121158 \times 9257}{18.01 \text{ lbs/lb-mole} \times 3.961 \times 10^7 \times (1263 + 9257)} \\ &= 5.756 \end{aligned}$$

$$FW = (\% \text{ Combustion Moisture}) + (\% \text{ Ambient Moisture}) + (\% \text{ Water Injection})$$

$$FW = 4.802 + 1.964 + 5.756$$

$$FW = 12.52 \% \text{ Moisture (Differences due to rounding)}$$

### UHC as VOC Mass Emission Rate (lbs/hr)

*Refers to Test Run #U3-Oil-100%-1*

$$CUHC = \text{observed concentration of UHC (THC)} = 0.12 \text{ ppmv as CH}_4, \text{ wet}$$

$$F_w = \text{stack gas moisture content} = 12.52 \% \text{ volume}$$

$$MW_{CH_4} = 16.04 \text{ lb/lb-mole for methane}$$

$$Q_{d1} = 3.961 \times 10^7 \text{ SCFH, dry (from O}_2, \text{ higher "F-factor" calculated from ex. flow) using same formula as for NO}_x \text{ mass emission rate (w/ moisture correction)}$$

$$E_{VOC} = \text{mass emission rate of VOC in (lb/hr), including methane}$$

$$= CUHC \times 10^{-6} \times Q_{d1} \times \frac{MW_{CH_4}}{385.15}$$

$$= 0.12 \times 10^{-6} \times 3.961 \times 10^7 \times \frac{16.04}{385.15} \times \frac{100}{(100 - 12.52)}$$

$$E_{VOC} = 0.23 \text{ lbs/hr}$$

**SO<sub>2</sub> Mass Emission Rate (lbs/hr)**

*Refers to Test Run #U3-Oil-100%-1*

S	= concentration of sulfur	= 0.039 % by weight
F	= fuel flow from fuel meter	= 88372.8 lbs/hr
MW <sub>SO<sub>2</sub></sub>	= molecular weight of sulfur dioxide	= 64.06 lb/lb•mol
MW <sub>S</sub>	= molecular weight of sulfur	= 32.06 lb/lb•mol

Note: Equation assumes at sulfur in fuel is converter to SO<sub>2</sub> in the stack

**ESO<sub>2</sub>** = mass emission rate of SO<sub>2</sub> in (lbs/hr)

$$= \frac{S}{100} \times F \times \left( \frac{MW_{SO_2}}{MW_S} \right)$$

$$= \frac{0.039}{100} \times 88372.8 \times \left( \frac{64.06}{32.06} \right)$$

**ESO<sub>2</sub>** = 68.09 lbs/hr



**APPENDIX C:  
FUEL ANALYSES**

Client: Tampa Electric Company

Facility: Polk Power Station

Location: Mulberry, Florida

Project: Rubix Job #6949-FL1

5-7-02

Natural Gas Water Vapor

① 5 lbs/MMCF

② 5 lbs/MMCF

Natural Gas Hydrogen Sulfide

① Non-detected after 5 draws on sampler

② Non-detected after 5 draws on sampler

Sampled by: Roger Paul Osier

5-9-02

Natural Gas Water Vapor

① 6 lbs/MMCF

② 7 lbs/MMCF

Natural Gas Hydrogen Sulfide

① Non-detected after 5 draws on sampler

② Non-detected after 5 draws on sampler

Sampled by: Robert Barthelette, Jr.

Note: minimum detectable limit is 0.3 ppmv  
for  $H_2S$  with 1 draw on sampler. Therefore,  
 $H_2S$  concentration was  $\leq 0.06$  ppm



8210 Mosley Rd.  
Houston, TX 77075  
713 943-9776 Telephone  
713 943-3846 Facsimile

# CORE LABORATORIES

LEONARD BRENNER  
CUBIX CORPORATION


4536 NW 20TH DRIVE  
GAINSVILLE, FL 32605

Sample Number: 122081-001  
Sample Date: 5/7/02  
Date Reported: 5/23/02  
Date Received: 5/15/02  
Sample ID: Sample # 1A  
Description: Natural Gas  
#1696/1793

## Analytical Report

Test	Result	Units	Method	Date	Analyst
<b>Natural Gas Analysis</b>					
Nitrogen	0.292	Mol %	GPA 2261	5/22/02	TH
Oxygen	0.008	Mol %			
Carbon Dioxide	0.876	Mol %			
Methane	95.303	Mol %			
Ethane	2.499	Mol %			
Propane	0.597	Mol %			
Isobutane	0.162	Mol %			
n-Butane	0.088	Mol %			
Isopentane	0.046	Mol %			
n-Pentane	0.026	Mol %			
Hexanes Plus	0.103	Mol %			
Total	100.00	Mol %			
Molar Mass Ratio	0.58924		ASTM D-3588		
Relative Density	0.59015				
Compressibility Factor	0.99778				
Gross Heating Value (Dry)	1038.0	BTU/CF (Ideal)			
Gross Heating Value (Dry)	1040.4	BTU/CF (Real)			
Net Heating Value (Dry)	936.0	BTU/CF (Ideal)			
Net Heating Value (Dry)	938.1	BTU/CF (Real)			
Pressure Base	14.696	psia			
Sulfur, Total in Gas by Micro.	<1	ppm wt	ASTM D-3246	5/16/02	JT

Approved By: \_\_\_\_\_

  
Jean Waits  
Supervising Chemist

# Gas Fuel F Factor & Heating Value Calculation

**Company:** Tampa Electric Company  
**Location:** Mulberry, Polk County, Florida  
**Sample Identification:** Unit 3 Sample 1A, Core Sample No. 122081-001  
**Sample Date:** May 7, 2002  
**Analysis Date:** May 22, 2002

## CALCULATION OF DENSITY AND HEATING VALUE @ 60°F and 30 in Hg

Component	% Volume	Molecular Wt.	Density (lb/ft <sup>3</sup> )	% volume		Component Gross Btu/lb	Weight Fract. Btu	Gross Heating Value (Btu/SCF)	Volume Fract. Btu
				Density	x weight %				
Hydrogen		2.016	0.0053	0.00000	0.0000	61100	0.00	319.1	0
Oxygen	0.008	32.000	0.0846	0.00001	0.0150	0	0.00	0.0	0
Nitrogen	0.292	28.016	0.0744	0.00022	0.4812	0	0.00	0.0	0
CO <sub>2</sub>	0.876	44.010	0.1170	0.00102	2.2703	0	0.00	0.0	0
CO		28.010	0.0740	0.00000	0.0000	4347	0.00	322.0	0
Methane	95.303	16.041	0.0424	0.04041	89.5083	23879	21373.70	996.7	949.895
Ethane	2.499	30.067	0.0803	0.00201	4.4450	22320	992.13	1756.1	43.8837
Ethylene		28.051	0.0746	0.00000	0.0000	21644	0.00	1614.0	0
Propane	0.597	44.092	0.1196	0.00071	1.5816	21661	342.59	2518.4	15.0346
propylene		42.077	0.1110	0.00000	0.0000	21041	0.00	2336.0	0
Isobutane	0.162	58.118	0.1582	0.00026	0.5677	21308	120.96	3303.3	5.35136
n-butane	0.088	58.118	0.1582	0.00014	0.3084	21257	65.55	3318.1	2.91991
Isobutene		56.102	0.1480	0.00000	0.0000	20840	0.00	3068.0	0
Isopentane	0.046	72.144	0.1904	0.00009	0.1940	21091	40.92	3940.5	1.81264
n-pentane	0.026	72.144	0.1904	0.00005	0.1097	21052	23.08	3948.4	1.02659
n-hexane	0.103	86.169	0.2274	0.00023	0.5188	20940	108.64	4684.1	4.82464
n-heptane		86.169	0.2274	0.00000	0.0000	20940	0.00	5419.8	0
H <sub>2</sub> S		34.076	0.0911	0.00000	0.0000	7100	0.00	647.0	0
total	100.00								
				Average Density		Gross Heating Value		Gross Heating Value	
				0.04514		Btu/lb		23068	
				Specific Gravity		Btu/SCF		1040.6	
				0.59013					

## CALCULATION OF F FACTORS

Component	Mol. Wt.	C Factor	H Factor	% volume	Fract. Wt.	Weight Percents			
						Carbon	Hydrogen	Nitrogen	Oxygen
Hydrogen	2.016	0	1	0.00	0.0000				
Oxygen	32.000	0	0	0.01	0.2560				0.01509
Nitrogen	28.016	0	0	0.29	8.1807			0.482086853	
CO <sub>2</sub>	44.010	0.272273	0	0.88	38.5528	0.618580691			1.65168
CO	28.010	0.42587	0	0.00	0.0000	0			0
Methane	16.041	0.75	0.25	95.30	1528.7554	67.56714708	22.5223824		
Ethane	30.067	0.8	0.2	2.50	75.1374	3.542278054	0.88556951		
Ethylene	28.051	0.85714	0.14286	0.00	0.0000	0	0		
Propane	44.092	0.81818	0.181818	0.60	26.3229	1.269168536	0.2820378		
Propene	42.077	0.85714	0.14286	0.00	0.0000	0	0		
Isobutane	58.118	0.82759	0.17247	0.16	9.4151	0.459173924	0.09569198		
n-butane	58.118	0.82759	0.17247	0.09	5.1144	0.249427811	0.05198083		
Isobutene	56.102	0.85714	0.14286	0.00	0.0000	0	0		
Isopentane	72.144	0.83333	0.16667	0.05	3.3186	0.162971392	0.03259506		
n-pentane	72.144	0.83333	0.16667	0.03	1.8757	0.092114265	0.0184233		
n-hexane	86.169	0.83721	0.16279	0.00	0.0000	0	0		
H <sub>2</sub> S	34.076	0	0.058692	0.00	0.0000	0	0		
Totals				99.89700	1696.9291	73.96086175	23.89	0.482086853	1.66677

CALCULATED VALUES		
O <sub>2</sub> F Factor (dry)	8645	DSCF of Exhaust/MM Btu of Fuel Burned @ 0% excess air
O <sub>2</sub> F Factor (wet)	10644	SCF of Exhaust/MM Btu of Fuel Burned @ 0% excess air
Moisture F Factor	1999	SCF of Water/MM Btu of Fuel Burned @ 0% excess air
Combust. Moisture	18.78	volume % water in flue gas @ 0% excess air
CO <sub>2</sub> F Factor	1029	DSCF of CO <sub>2</sub> /MM Btu of Fuel Burned @ 0% excess air
Carbon Dioxide	11.91	volume % CO <sub>2</sub> in flue gas @ 0% O <sub>2</sub>
Predicted Fo Factor	1.76	EPA Method 3a Fo value
Fuel VOC % (non-C1)	7.95%	non-methane fuel VOC content
Fuel VOC % (non-C1,C2)	3.43%	non-methane non-ethane fuel VOC content



8210 Mosley Rd.  
Houston, TX 77075  
713 943-9776 Telephone  
713 943-3846 Facsimile

# CORE LABORATORIES

LEONARD BRENNER  
CUBIX CORPORATION


4536 NW 20TH DRIVE  
GAINSVILLE, FL 32605

Sample Number: 122081-002  
Sample Date: 5/9/02  
Date Reported: 5/23/02  
Date Received: 5/15/02  
Sample ID: Sample # 2A  
Description: Natural Gas  
#1841/1600

## Analytical Report

Test	Result	Units	Method	Date	Analyst
<b>Natural Gas Analysis</b>					
Nitrogen	0.321	Mol %	GPA 2261		
Oxygen	0.010	Mol %			
Carbon Dioxide	0.840	Mol %			
Methane	94.999	Mol %			
Ethane	2.695	Mol %		5/22/02	TH
Propane	0.647	Mol %			
Isobutane	0.173	Mol %			
n-Butane	0.140	Mol %			
Isopentane	0.048	Mol %			
n-Pentane	0.025	Mol %			
Hexanes Plus	0.101	Mol %			
Total	100.00	Mol %			
Molar Mass Ratio	0.59134		ASTM D-3588		
Relative Density	0.59226				
Compressibility Factor	0.99777				
Gross Heating Value (Dry)	1041.7	BTU/CF (Ideal)			
Gross Heating Value (Dry)	1044.0	BTU/CF (Real)			
Net Heating Value (Dry)	939.4	BTU/CF (Ideal)			
Net Heating Value (Dry)	941.5	BTU/CF (Real)			
Pressure Base	14.696	psia			
Sulfur, Total in Gas by Micro.	<1	ppm wt	ASTM D-3246	5/16/02	JT

Approved By: \_\_\_\_\_

  
Jean Waits  
Supervising Chemist

# Gas Fuel F Factor & Heating Value Calculation

**Company:** Tampa Electric Company  
**Location:** Mulberry, Polk County, Florida  
**Sample Identification:** Unit 3 Sample 2A, Core Sample No. 122081-002  
**Sample Date:** May 9, 2002  
**Analysis Date:** May 22, 2002

## CALCULATION OF DENSITY AND HEATING VALUE @ 60°F and 30 in Hg

Component	% Volume	Molecular Wt.	% volume			Component Gross Btu/lb	Weight Fract. Btu	Gross Heating Value (Btu/SCF)	Volume Fract. Btu
			Density (lb/ft3)	x Density	weight %				
Hydrogen		2.016	0.0053	0.00000	0.0000	61100	0.00	319.1	0
Oxygen	0.010	32.000	0.0846	0.00001	0.0187	0	0.00	0.0	0
Nitrogen	0.321	28.016	0.0744	0.00024	0.5271	0	0.00	0.0	0
CO2	0.840	44.010	0.1170	0.00098	2.1690	0	0.00	0.0	0
CO		28.010	0.0740	0.00000	0.0000	4347	0.00	322.0	0
Methane	94.999	16.041	0.0424	0.04028	88.8950	23879	21227.25	996.7	946.865
Ethane	2.695	30.067	0.0803	0.00216	4.7760	22320	1066.01	1756.1	47.3255
Ethylene		28.051	0.0746	0.00000	0.0000	21644	0.00	1614.0	0
Propane	0.647	44.092	0.1196	0.00077	1.7078	21661	369.92	2518.4	16.2938
propylene		42.077	0.1110	0.00000	0.0000	21041	0.00	2336.0	0
Isobutane	0.173	58.118	0.1582	0.00027	0.6040	21308	128.70	3303.3	5.71473
n-butane	0.140	58.118	0.1582	0.00022	0.4888	21257	103.90	3318.1	4.64531
Isobutene		56.102	0.1480	0.00000	0.0000	20840	0.00	3068.0	0
Isopentane	0.048	72.144	0.1904	0.00009	0.2017	21091	42.54	3940.5	1.89145
n-pentane	0.025	72.144	0.1904	0.00005	0.1051	21052	22.12	3948.4	0.9871
n-hexane	0.101	86.169	0.2274	0.00023	0.5069	20940	106.14	4684.1	4.73096
n-heptane		86.169	0.2274	0.00000	0.0000	20940	0.00	5419.8	0
H2S		34.076	0.0911	0.00000	0.0000	7100	0.00	647.0	0
total	100.00		Average Density	0.04531	100.0000	Gross Heating Value		Gross Heating Value	
			Specific Gravity	0.59231		Btu/lb	23067	Btu/SCF	1044.3

## CALCULATION OF F FACTORS

Component	Mol. Wt.	C Factor	H Factor	% volume	Fract. Wt.	Weight Percents			
						Carbon	Hydrogen	Nitrogen	Oxygen
Hydrogen	2.016	0	1	0.00	0.0000		0		
Oxygen	32.000	0	0	0.01	0.3200				0.01879
Nitrogen	28.016	0	0	0.32	8.9931			0.528021522	
CO2	44.010	0.272273	0	0.84	36.9684	0.590983961			1.57799
CO	28.010	0.42587	0	0.00	0.0000	0			0
Methane	16.041	0.75	0.25	95.00	1523.8790	67.10458573	22.3681952		
Ethane	30.067	0.8	0.2	2.70	81.0306	3.806092316	0.95152308		
Ethylene	28.051	0.85714	0.14286	0.00	0.0000	0	0		
Propane	44.092	0.81818	0.181818	0.65	28.5275	1.370419098	0.30453795		
Propene	42.077	0.85714	0.14286	0.00	0.0000	0	0		
Isobutane	58.118	0.82759	0.17247	0.17	10.0544	0.488553874	0.10181477		
n-butane	58.118	0.82759	0.17247	0.14	8.1365	0.395361517	0.08239346		
Isobutene	56.102	0.85714	0.14286	0.00	0.0000	0	0		
Isopentane	72.144	0.83333	0.16667	0.05	3.4629	0.169433365	0.03388749		
n-pentane	72.144	0.83333	0.16667	0.03	1.8036	0.088246544	0.01764973		
n-hexane	86.169	0.83721	0.16279	0.00	0.0000	0	0		
H2S	34.076	0	0.058692	0.00	0.0000	0	0		
Totals				99.89800	1703.1760	74.01367641	23.86	0.528021522	1.59678

## CALCULATED VALUES

O2 F Factor (dry)	8646	DSCF of Exhaust/MM Btu of Fuel Burned @ 0% excess air
O2 F Factor (wet)	10642	SCF of Exhaust/MM Btu of Fuel Burned @ 0% excess air
Moisture F Factor	1996	SCF of Water/MM Btu of Fuel Burned @ 0% excess air
Combust. Moisture	18.76	volume % water in flue gas @ 0% excess air
CO2 F Factor	1030	DSCF of CO2/MM Btu of Fuel Burned @ 0% excess air
Carbon Dioxide	11.91	volume % CO2 in flue gas @ 0% O2
Predicted Fo Factor	1.75	EPA Method 3a Fo value
Fuel VOC % (non-C1)	8.63%	non-methane fuel VOC content
Fuel VOC % (non-C1,C2)	3.78%	non-methane non-ethane fuel VOC content

# Chain Of Custody Record

Report To: Cubix Corporation, SE Regional Office  
 Lab Contact: Leonard Brenner  
3709 SW 42nd Avenue, Suite 2  
Gainesville, Florida 32608  
 Telephone: (352) 378-0332

Bill To: Cubix Corporation Page 1 of 1  
9225 Lockhart Highway  
Austin, Texas 78747  
 Project Reference: 6574-FL1  
 P.O. No.: 2002185

Sample ID	Sample Description	Date Collected	Container Type	Required Analyses	Special Instructions
Sample #1A Cylinder # 1696	Natural Gas	5/7/02	300ml S.S. Cylinder	ASTM D3246, D4888 & GPA 2261 <i>3588 JAW 5/15/02</i>	<b>ONLY RUN THE DUPLICATES IF THERE IS A PROBLEM WITH THE ORIGINAL SAMPLE</b>
Sample #1B Duplicate Cylinder # 1793	Natural Gas	5/7/02	300ml S.S. Cylinder	ASTM D3246, D4888 & GPA 2261 <i>3588 JAW 5/15/02</i>	
Sample #2A Cylinder # 1841	Natural Gas	5/9/02	300ml S.S. Cylinder	ASTM D3246, D4888 & GPA 2261 <i>3588 JAW 5/15/02</i>	
Sample #2B Duplicate Cylinder # 1600	Natural Gas	5/9/02	300ml S.S. Cylinder	ASTM D3246, D4888 & GPA 2261 <i>3588 JAW 5/15/02</i>	

Turnaround Time Required: <input checked="" type="radio"/> Normal <input type="radio"/> Rush      Report By: _____	Hazard Identification:
Relinquished by: <u><i>[Signature]</i></u> Date: <u>5/13/02</u> Affiliation: <u>Cubix Corporation, SE Regional Office</u>	Other Instructions:
Received by: <u><i>A.M. Solato</i></u> Date: <u>5-15-02</u> Affiliation: <u><i>Core</i></u>	



9225 Lockhart Highway, Austin, Texas 78747  
 (512) 243-0202  
 4536 NW 20th Drive, Gainesville, Florida 32605  
 (352) 378-0332

# FISHER-ROSEMOUNT

Managing The Process Better™

Rosemount Measurement  
8200 Market Boulevard  
Chaska, MN 55317-9687  
Phone: 1-800-999-9307

May 13, 2002

## Calibration Certificate Consistent with ISO 10474 3.1B

Sales Order: 913731 Line Item: 2  
Equipment Name: Multi Variable Transmitter  
Model No: 3095MA2CA0A12AA000ABC2Q4N508  
Serial No: 0072748  
Tag No: 3-FGS-FT-904  
Purchase Order: 91509  
Calibration Range DP (Differential Pressure): 0 To 250 IN H2O  
Calibration Range SP (Static Pressure): 0 To 800 PSI  
Calibration Range PT (Process Temperature): 0 To 500 DEG F  
Date of Calibration: 1/21/2002

Polk Unit 3  
Natural Gas

### Calibration Data - DP

% of Span	Target Pressure	Measured Pressure
100	250	250.002
80	200	200.046
60	150	150.000
40	100	100.114
20	50	50.050
0	0	0.020

### Calibration Data - SP

% of Span	Target Pressure	Measured Pressure
100	800	800.023
80	640	638.997
60	480	479.958
40	320	320.028
20.001	160.008	160.112
0	0	0.068

### Calibration Data - PT

% of Span	Target Temperature	Measured Temperature
100	499.898	500.040
80	399.899	399.962
60	300.000	299.886
40	199.997	199.807
20	100.000	99.815
0	0.001	-0.021

## CERTIFICATION



JUN-10-2002 10:39


P. 06

# **FISHER-ROSEMOUNT**

**Managing The Process Better™**

**Rosemount Measurement**  
8200 Market Boulevard  
Chaska, MN 55317-9687  
Phone: 1-800-999-9307

This is to certify that the listed above product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the above product listed are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



---

Desiree Anderson  
ROSEMOUNT REPRESENTATIVE



8210 Mosley Rd.  
Houston, TX 77075  
713 943-9776 Telephone  
713 943-3846 Facsimile

# CORE LABORATORIES

LEONARD BRENNER  
CUBIX CORPORATION

4536 NW 20TH DRIVE  
GAINSVILLE, FL 32605

Sample Number: 122081-003  
Sample Date: 5/8/02  
Date Reported: 5/23/02  
Date Received: 5/15/02  
Sample ID: Sample # Unit 3  
Description: Fuel Oil

## Analytical Report

Test	Result	Units	Method	Date	Analyst
BTU, Gross	19366	BTU/lb	ASTM D-240	5/17/02	VS
<b>Carbon/Hydrogen Content</b>					
Carbon Content	87.07	WT %	ASTM D-5291	5/17/02	JT
Hydrogen Content	12.67	WT %		5/17/02	JT
Nitrogen Total by Chemilum.	126	ppm wt	ASTM D-4629	5/17/02	JT
Sulfur, Total by X-Ray Fluoresc.	0.039	WT %	ASTM D-4294	5/16/02	CB

Approved By: \_\_\_\_\_

Jean Waits  
Supervising Chemist

The analytical results, opinions or interpretations contained in this report are based upon information and material supplied by the client for whose exclusive and confidential use this report has been made. The analytical results, opinions or interpretations expressed represent the best judgment of Core Laboratories. Core Laboratories, however, makes no warranty or representation, express or implied, of any type, and expressly disclaims same as to the productivity, proper operations or profitability of any oil, gas, coal, or other mineral, property, well or sand in connection with which such report is used or relied upon for any reason whatsoever. This report shall not be reproduced, in whole or in part, without the written approval of Core Laboratories

## Fuel Oil F Factor Calculation

**Client:** Tampa Electric Company  
**Sample ID:** Unit 3, Polk Power Station  
**Laboratory ID:** 122081-003  
**Date Collected:** May 8, 2002  
**Date Analyzed:** May 16-17, 2002  
**Lab:** Core Laboratories

Heating Value	19,366	Btu/lb gross
Heating Value	18,210	Btu/lb, net

Component	Fuel Analysis Data		K (scf/lb-%)	Fractional K (wt.% x K)
	ppm weight	Weight %		
Carbon	-	87.07	1.53	133.217
Hydrogen	-	12.67	3.64	46.119
Nitrogen	-	0.01	0.14	0.000
Oxygen	-	0.21	0.46	0.096
Sulfur	-	0.039	0.57	0.022
<b>Total Volume</b>	-	100.0		

<b>O<sub>2</sub> F<sub>d</sub>-factor</b>	<b>9257</b>	<b>DSCF of Flue Gas/MMBtu @ 0% excess air</b>
<b>O<sub>2</sub> F<sub>w</sub>-factor</b>	<b>10519</b>	<b>SCF of Flue Gas (wet)/MMBtu @ 0% excess air</b>
<b>CO<sub>2</sub> F<sub>c</sub>-factor</b>	<b>1443</b>	<b>SCF of CO<sub>2</sub>/MMBtu @ 0% excess air</b>
<b>H<sub>2</sub>O F factor</b>	<b>1263</b>	<b>SCF of H<sub>2</sub>O/MMBtu @ 0% excess air</b>

# Chain Of Custody Record


Report To: Cubix Corporation, SE Regional Office  
 Lab Contact: Leonard Brenner  
3709 SW 42nd Avenue, Suite 2  
Gainesville, Florida 32608  
 Telephone: (352) 378-0332

Bill To: Cubix Corporation  
9225 Lockhart Highway  
Austin, Texas 78747  
 Project Reference: 6574-FL1  
 P.O. No.: 2002185

Page 1 of 1

Sample ID	Sample Description	Date Collected	Container Type	Required Analyses	Special Instructions
Sample #Unit 3	Fuel Oil	5/8/02	1 liter glass jar	ASTM D4294, D4629, D5291, D240	

<b>Turnaround Time Required:</b> <input checked="" type="radio"/> Normal <input type="radio"/> Rush      Report By: _____ Relinquished by: <u>[Signature]</u> Date: _____ Affiliation: <u>Cubix Corporation, SE Regional Office</u> Received by: <u>A-M. [Signature]</u> Date: <u>5-15-02</u> Affiliation: <u>Low</u>	<b>Hazard Identification:</b>  <b>Other Instructions:</b>
--	---



**Cubix Corporation**

9225 Lockhart Highway, Austin, Texas 78747  
 (512) 243-0202  
 4536 NW 20th Drive, Gainesville, Florida 32605  
 (352) 378-0332

*[Handwritten signature]*

Bob Barthollette  
fax 38220



FUEL OIL, Polk Unit 3

Vortex Flowmeter Calibration Test Report

Sales Order No.:306965	Date :3 OCT 2001
Serial No.:01W034112	Line Item:2
Meter Size :4 inch	Model No.:10VM1111B0
Sec. Serial No.:01W034113	Sec Model No.:50VM1301
Flow: 44.100 to 1100.000 GPM	
SP.CR.: 1.000	
Viscosity : 1 CPS	Temp.: 70°F
Starting K	1300 Cyc/m3
Middle K	1348 Cyc/m3 @ 70°F
Max Freq.	101.03 Kz
Total Linearity	1.3495

Calibration Data

Run#	Rig Std.	Hertz	K-Cyc/Gal	Actual GPM	4-20ma	Ind GPM	Kz/cSt	K-Cyc/m3	Rate
01	3-T1-C44	433.55	51.269	507.390	17.90	521.34	40.574	1335.7	-0.913
02	3-T1-C44	247.49	51.301	289.458	12.04	301.69	23.480	1354.9	+0.516
03	3-T1-C44	152.61	51.347	178.322	8.98	186.77	14.536	1361.5	+1.000
04	2-T1-C46	290.50	126.370	137.926	7.85	144.20	11.224	1359.1	+0.023
05	2-T1-C46	140.00	126.322	66.498	5.85	69.40	5.402	1356.8	+0.653
06	2-T1-C46	93.38	126.381	44.331	5.24	46.37	3.609	1359.7	+0.865

Note: Test Meter K-Cyc/m3 are @ 70°F

Rig Visc. :1.05366 cSt Test Performed by :G. Myers.

Linearization Factors At Operating Temperature

F1=	1.0	K1=	1367.2
F2=	5.0	K2=	1357.0
F3=	14.0	K3=	1361.7
F4=	40.0	K4=	1336.5
F5=	550.0	K5=	1236.5

Comparison of Calibration K-factors to Linearization K-factors

Run#	Hertz	K-Cyc/m3	Est. k	Rate
01	40.61	1335.7	1336.5	+0.056
02	29.50	1354.9	1352.5	-0.182
03	14.55	1361.5	1361.1	-0.030
04	11.23	1359.1	1360.2	+0.083
05	5.41	1356.8	1357.2	+0.033
06	3.61	1359.7	1360.6	+0.063

The Measurement and Test equipment, used in the calibration of this meter, is traceable to NIST and is controlled by a Quality System designed to meet the requirements of ANSI/Z540 and ISO 9001. This Calibration report may not be reproduced, except in full, without written permission.

Customer's Tag(s) : (3) 10V

```

#####
|
| 3-POY-FOIT-901
|
#####

```

TEST EQUIPMENT

QC # Description  
E3222 VOLTMETER  
E3072 4K FREQ. COUNTER

E3233 RELAY MULTIMETER  
T+137 THERMISTOR

ABB Inc.

Automation Technology  
Product Division  
Business Unit Instrumentation

125 East County Line Road  
Warminster, PA 18974-4995  
USA

Telephone  
(215) 874-6900  
Fax  
(215) 874-7183

Internet  
www.abb.com/instrumentation  
E-mail  
instrumentation@us.abb.com

TOTAL P.01

**APPENDIX D:  
QUALITY ASSURANCE ACTIVITIES**

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Linearity Check	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>	THC
Analyzer Range (ppmv), O <sub>2</sub> & CO <sub>2</sub> in % vol	16.00	30.00	25.00	15.00	30.00
Strip Chart Offset	2.0	5.0	10.0	2.0	5.0
Low Level Certified Value (ppm or % vol)	5.05	8.92	4.53	4.54	9.06
Mid Level Certified Value (ppm or % vol)	8.60	15.26	11.91	8.00	15.36
High Level Certified Value (ppm or % vol)	14.82	25.80	20.90	12.62	25.60
Zero Target (% Chart)	2.0	5.0	10.0	2.0	5.0
Low Level Target (% Chart)	33.6	34.7	28.1	32.3	35.2
Mid Level Target (% Chart)	55.8	55.9	57.6	55.4	56.2
High Level Target (% Chart)	94.6	91.0	93.6	86.1	90.3
Zero Observed (% Chart)	2.1	5.0	10.0	2.0	5.0
Low Level Observed (% Chart)	32.9	35.4	28.1	32.3	35.9
Mid Level Observed (% Chart)	55.2	55.8	57.8	55.5	56.3
High Level Observed (% Chart)	94.9	91.1	93.6	86.1	90.5
Zero Observed (ppm or % vol)	0.02	0.00	0.00	0.00	0.01
Low Level Observed (ppm or % vol)	4.94	9.11	4.52	4.55	9.26
Mid Level Observed (ppm or % vol)	8.51	15.23	11.95	8.03	15.38
High Level Observed (ppm or % vol)	14.86	25.82	20.91	12.62	25.65
% Difference From Zero to Target	-0.1	0.0	0.0	0.0	0.0
% Difference From Low to Target	0.7	-0.6	0.0	-0.1	-2.2
% Difference From Mid to Target	0.6	0.1	-0.2	-0.2	-0.1
% Difference From High to Target	-0.3	-0.1	0.0	0.0	-0.2
EPA Allowable % Difference from Target	±2% Span	±2% Span	±2% Span	±2% Span	±5% Cal Gas
Run U3-NG-O <sub>2</sub> -Traverse	NO <sub>x</sub>		O <sub>2</sub>	CO <sub>2</sub>	
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0		25.00	15.00	
Calibration Gas Certified Value (ppm or %)	8.60		20.90	4.54	
Strip Chart Offset	2.0		10.0	2.0	
Target Calibration Gas (Chart %)	55.8		93.6	32.3	
Actual Zero Gas from Direct (Chart %)	2.1		10.0	2.0	
Actual Calibration Gas from Direct (Chart %)	55.2		93.6	32.3	
<b>Initial Readings</b>					
Zero Gas (chart %)	2.5		10.1	2.0	
Calibration Gas (chart %)	55.6		93.3	32.1	
Zero Gas (ppmv)	0.08		0.03	0.00	
Calibration Gas (ppmv)	8.57		20.82	4.51	
<b>Final Readings</b>					
Zero Gas (chart %)	2.8		10.1	2.1	
Calibration Gas (chart %)	54.7		93.2	32.1	
Zero Gas (ppmv)	0.12		0.03	0.01	
Calibration Gas (ppmv)	8.43		20.81	4.52	
<b>Bias and Drift Calculations</b>					
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.6		0.1	0.1	
Calibration Bias (% Chart) ≤5%	-0.5		-0.4	-0.2	
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	-0.3		0.0	-0.1	
Calibration Drift (Chart %) ≤2 or 3%	0.9		0.0	-0.1	
<b>Run Results</b>					
Raw Results (chart %)	72.7		65.2	29.2	
Raw Results (ppmv or % vol)	11.31		13.80	4.09	
Corrected Results (ppmv or % vol) from % chart	11.47		13.85	4.11	

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-NG-100%-1/U3-RA-1	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>	THC
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	30.0	25.00	15.00	30.00
Calibration Gas Certified Value (ppm or %)	8.60	15.26	20.90	4.54	15.36
Strip Chart Offset	2.0	5.0	10.0	2.0	5.0
Target Calibration Gas (Chart %)	55.8	55.9	93.6	32.3	56.2
Actual Zero Gas from Direct (Chart %)	2.1	5.0	10.0	2.0	5.0
Actual Calibration Gas from Direct (Chart %)	55.2	55.8	93.6	32.3	56.3
Initial Readings					
Zero Gas (chart %)	2.8	5.6	10.1	2.1	4.9
Calibration Gas (chart %)	54.7	56.2	93.2	32.1	55.5
Zero Gas (ppmv)	0.12	0.18	0.03	0.01	-0.02
Calibration Gas (ppmv)	8.43	15.35	20.81	4.52	15.16
Final Readings					
Zero Gas (chart %)	2.5	5.5	10.1	2.1	4.8
Calibration Gas (chart %)	54.5	56.2	93.2	32.2	56.3
Zero Gas (ppmv)	0.08	0.15	0.02	0.01	-0.05
Calibration Gas (ppmv)	8.40	15.35	20.79	4.53	15.38
Bias and Drift Calculations					
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.4	0.5	0.1	0.1	-0.2
Calibration Bias (% Chart) ≤5%	-0.7	0.4	-0.5	-0.1	0.0
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.3	0.1	0.0	0.0	0.1
Calibration Drift (Chart %) ≤2 or 3%	0.2	0.0	0.1	-0.1	-0.7
Run Results					
Raw Results (chart %)	59.6	6.4	64.6	29.9	6.8
Raw Results (ppmv or % vol)	9.22	0.42	13.66	4.18	0.53
Corrected Results (ppmv or % vol) from % chart	9.43	0.26	13.72	4.19	0.57
Run U3-NG-100%-2/U3-RA-2	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>	THC
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	30.0	25.00	15.00	30.00
Calibration Gas Certified Value (ppm or %)	8.60	15.26	20.90	4.54	15.36
Strip Chart Offset	2.0	5.0	10.0	2.0	5.0
Target Calibration Gas (Chart %)	55.8	55.9	93.6	32.3	56.2
Actual Zero Gas from Direct (Chart %)	2.1	5.0	10.0	2.0	5.0
Actual Calibration Gas from Direct (Chart %)	55.2	55.8	93.6	32.3	56.3
Initial Readings					
Zero Gas (chart %)	2.5	5.5	10.1	2.1	4.8
Calibration Gas (chart %)	54.5	56.2	93.2	32.2	56.3
Zero Gas (ppmv)	0.08	0.15	0.02	0.01	-0.05
Calibration Gas (ppmv)	8.40	15.35	20.79	4.53	15.38
Final Readings					
Zero Gas (chart %)	2.4	5.6	10.0	2.0	5.2
Calibration Gas (chart %)	53.7	56.1	93.0	32.1	55.0
Zero Gas (ppmv)	0.07	0.18	0.01	0.00	0.07
Calibration Gas (ppmv)	8.27	15.32	20.75	4.52	15.01
Bias and Drift Calculations					
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.3	0.6	0.0	0.0	0.2
Calibration Bias (% Chart) ≤5%	-1.5	0.3	-0.6	-0.2	-1.2
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.1	-0.1	0.0	0.1	-0.4
Calibration Drift (Chart %) ≤2 or 3%	0.8	0.1	0.2	0.1	1.2
Run Results					
Raw Results (chart %)	59.0	6.3	64.6	29.7	6.9
Raw Results (ppmv or % vol)	9.12	0.38	13.64	4.15	0.57
Corrected Results (ppmv or % vol) from % chart	9.42	0.22	13.72	4.16	0.57



**Quality Assurance Activities**  
**Calibration Error, Bias, and Drift Checks**

Unit 3

<b>Run U3-NG-100%-3/U3-RA-3</b>	<b>NO<sub>x</sub></b>	<b>CO</b>	<b>O<sub>2</sub></b>	<b>CO<sub>2</sub></b>	<b>THC</b>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	30.0	25.00	15.00	30.00
Calibration Gas Certified Value (ppm or %)	8.60	15.26	20.90	4.54	15.36
Strip Chart Offset	2.0	5.0	10.0	2.0	5.0
Target Calibration Gas (Chart %)	55.8	55.9	93.6	32.3	56.2
Actual Zero Gas from Direct (Chart %)	2.1	5.0	10.0	2.0	5.0
Actual Calibration Gas from Direct (Chart %)	55.2	55.8	93.6	32.3	56.3
<b>Initial Readings</b>					
Zero Gas (chart %)	2.4	5.6	10.0	2.0	5.2
Calibration Gas (chart %)	53.7	56.1	93.0	32.1	55.0
Zero Gas (ppmv)	0.07	0.18	0.01	0.00	0.07
Calibration Gas (ppmv)	8.27	15.32	20.75	4.52	15.01
<b>Final Readings</b>					
Zero Gas (chart %)	2.3	5.5	10.0	2.0	5.2
Calibration Gas (chart %)	53.3	55.9	93.0	32.1	54.5
Zero Gas (ppmv)	0.05	0.15	0.01	0.00	0.05
Calibration Gas (ppmv)	8.20	15.26	20.75	4.51	14.86
<b>Bias and Drift Calculations</b>					
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.2	0.5	0.0	0.0	0.1
Calibration Bias (% Chart) ≤5%	-1.9	0.1	-0.6	-0.3	-1.7
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.1	0.1	0.0	0.0	0.1
Calibration Drift (Chart %) ≤2 or 3%	0.4	0.2	0.0	0.1	0.5
<b>Run Results</b>					
Raw Results (chart %)	58.2	6.2	64.6	29.6	6.5
Raw Results (ppmv or % vol)	8.99	0.37	13.65	4.14	0.45
Corrected Results (ppmv or % vol) from % chart	9.39	0.21	13.75	4.16	0.40
<b>Linearity Check</b>	<b>NO<sub>x</sub></b>		<b>O<sub>2</sub></b>	<b>CO<sub>2</sub></b>	
Analyzer Range (ppmv), O <sub>2</sub> & CO <sub>2</sub> in % vol	16.00		25.00	15.00	
Strip Chart Offset	2.0		10.0	2.0	
Low Level Certified Value (ppm or % vol)	5.05		4.53	4.54	
Mid Level Certified Value (ppm or % vol)	8.60		11.91	8.00	
High Level Certified Value (ppm or % vol)	14.82		20.90	12.62	
Zero Target (% Chart)	2.0		10.0	2.0	
Low Level Target (% Chart)	33.6		28.1	32.3	
Mid Level Target (% Chart)	55.8		57.6	55.4	
High Level Target (% Chart)	94.6		93.6	86.1	
Zero Observed (% Chart)	2.1		10.0	2.0	
Low Level Observed (% Chart)	32.8		28.2	32.3	
Mid Level Observed (% Chart)	55.8		57.8	55.3	
High Level Observed (% Chart)	94.0		93.6	86.1	
Zero Observed (ppm or % vol)	0.02		0.00	0.00	
Low Level Observed (ppm or % vol)	4.93		4.54	4.54	
Mid Level Observed (ppm or % vol)	8.60		11.95	8.00	
High Level Observed (ppm or % vol)	14.72		20.91	12.62	
% Difference From Zero to Target	-0.1		0.0	0.0	
% Difference From Low to Target	0.8		0.0	0.0	
% Difference From Mid to Target	0.0		-0.2	0.0	
% Difference. From High to Target	0.6		0.0	0.0	
EPA Allowable % Difference from Target	±2% Span		±2% Span	±2% Span	

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-NG-50%-1	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	8.60	20.90	4.54
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	55.8	93.6	32.3
Actual Zero Gas from Direct (Chart %)	2.1	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	55.2	93.6	32.3
Initial Readings			
Zero Gas (chart %)	2.2	10.0	2.1
Calibration Gas (chart %)	53.4	93.2	32.1
Zero Gas (ppmv)	0.03	0.00	0.02
Calibration Gas (ppmv)	8.23	20.80	4.51
Final Readings			
Zero Gas (chart %)	2.5	10.1	2.1
Calibration Gas (chart %)	53.1	93.2	32.2
Zero Gas (ppmv)	0.08	0.02	0.02
Calibration Gas (ppmv)	8.17	20.79	4.53
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.4	0.1	0.1
Calibration Bias (% Chart) ≤5%	-2.1	-0.5	-0.1
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	-0.3	-0.1	0.0
Calibration Drift (Chart %) ≤2 or 3%	0.4	0.0	-0.1
Run Results			
Raw Results (chart %)	56.6	65.9	28.7
Raw Results (ppmv or % vol)	8.74	13.98	4.00
Corrected Results (ppmv or % vol) from % chart	9.17	14.05	4.02
Run U3-NG-50%-2	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	8.60	20.90	4.54
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	55.8	93.6	32.3
Actual Zero Gas from Direct (Chart %)	2.1	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	55.2	93.6	32.3
Initial Readings			
Zero Gas (chart %)	2.5	10.1	2.1
Calibration Gas (chart %)	53.1	93.2	32.2
Zero Gas (ppmv)	0.08	0.02	0.02
Calibration Gas (ppmv)	8.17	20.79	4.53
Final Readings			
Zero Gas (chart %)	2.6	10.0	2.1
Calibration Gas (chart %)	53.3	93.3	32.1
Zero Gas (ppmv)	0.10	0.01	0.02
Calibration Gas (ppmv)	8.20	20.83	4.52
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.5	0.0	0.1
Calibration Bias (% Chart) ≤5%	-1.9	-0.3	-0.2
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	-0.1	0.0	0.0
Calibration Drift (Chart %) ≤2 or 3%	-0.2	-0.2	0.1
Run Results			
Raw Results (chart %)	55.8	66.0	28.7
Raw Results (ppmv or % vol)	8.60	13.99	4.00
Corrected Results (ppmv or % vol) from % chart	9.04	14.05	4.01

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-NG-50%-3	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	8.60	20.90	4.54
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	55.8	93.6	32.3
Actual Zero Gas from Direct (Chart %)	2.1	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	55.2	93.6	32.3
Initial Readings			
Zero Gas (chart %)	2.6	10.0	2.1
Calibration Gas (chart %)	53.3	93.3	32.1
Zero Gas (ppmv)	0.10	0.01	0.02
Calibration Gas (ppmv)	8.20	20.83	4.52
Final Readings			
Zero Gas (chart %)	2.5	10.1	2.2
Calibration Gas (chart %)	52.9	93.3	32.2
Zero Gas (ppmv)	0.08	0.02	0.03
Calibration Gas (ppmv)	8.14	20.82	4.53
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.4	0.1	0.2
Calibration Bias (% Chart) ≤5%	-2.3	-0.4	-0.1
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.1	0.0	-0.1
Calibration Drift (Chart %) ≤2 or 3%	0.4	0.0	-0.1
Run Results			
Raw Results (chart %)	56.1	65.9	28.7
Raw Results (ppmv or % vol)	8.66	13.97	4.00
Corrected Results (ppmv or % vol) from % chart	9.12	14.02	4.01
Run U3-NG-65%-1	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	8.60	20.90	4.54
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	55.8	93.6	32.3
Actual Zero Gas from Direct (Chart %)	2.1	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	55.2	93.6	32.3
Initial Readings			
Zero Gas (chart %)	2.5	10.1	2.2
Calibration Gas (chart %)	52.9	93.3	32.2
Zero Gas (ppmv)	0.08	0.02	0.03
Calibration Gas (ppmv)	8.14	20.82	4.53
Final Readings			
Zero Gas (chart %)	2.4	10.0	2.1
Calibration Gas (chart %)	52.3	93.2	32.1
Zero Gas (ppmv)	0.07	0.01	0.02
Calibration Gas (ppmv)	8.04	20.80	4.52
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.3	0.0	0.1
Calibration Bias (% Chart) ≤5%	-2.9	-0.4	-0.2
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.1	0.0	0.1
Calibration Drift (Chart %) ≤2 or 3%	0.6	0.1	0.1
Run Results			
Raw Results (chart %)	52.9	64.8	29.6
Raw Results (ppmv or % vol)	8.14	13.71	4.14
Corrected Results (ppmv or % vol) from % chart	8.65	13.76	4.15

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-NG-65%-2	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	8.60	20.90	4.54
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	55.8	93.6	32.3
Actual Zero Gas from Direct (Chart %)	2.1	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	55.2	93.6	32.3
<b>Initial Readings</b>			
Zero Gas (chart %)	2.4	10.0	2.1
Calibration Gas (chart %)	52.3	93.2	32.1
Zero Gas (ppmv)	0.07	0.01	0.02
Calibration Gas (ppmv)	8.04	20.80	4.52
<b>Final Readings</b>			
Zero Gas (chart %)	2.4	10.0	2.1
Calibration Gas (chart %)	51.9	93.2	32.1
Zero Gas (ppmv)	0.07	0.01	0.02
Calibration Gas (ppmv)	7.99	20.81	4.52
<b>Bias and Drift Calculations</b>			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.3	0.0	0.1
Calibration Bias (% Chart) ≤5%	-3.3	-0.4	-0.2
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	0.0	0.0
Calibration Drift (Chart %) ≤2 or 3%	0.3	0.0	0.0
<b>Run Results</b>			
Raw Results (chart %)	52.3	64.9	29.6
Raw Results (ppmv or % vol)	8.04	13.72	4.14
Corrected Results (ppmv or % vol) from % chart	8.63	13.78	4.16
Run U3-NG-65%-3	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	8.60	20.90	4.54
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	55.8	93.6	32.3
Actual Zero Gas from Direct (Chart %)	2.1	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	55.2	93.6	32.3
<b>Initial Readings</b>			
Zero Gas (chart %)	2.4	10.0	2.1
Calibration Gas (chart %)	51.9	93.2	32.1
Zero Gas (ppmv)	0.07	0.01	0.02
Calibration Gas (ppmv)	7.99	20.81	4.52
<b>Final Readings</b>			
Zero Gas (chart %)	2.5	10.0	2.2
Calibration Gas (chart %)	52.1	93.2	32.2
Zero Gas (ppmv)	0.08	0.01	0.03
Calibration Gas (ppmv)	8.01	20.80	4.53
<b>Bias and Drift Calculations</b>			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.4	0.0	0.2
Calibration Bias (% Chart) ≤5%	-3.1	-0.4	-0.1
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	-0.1	0.0	-0.1
Calibration Drift (Chart %) ≤2 or 3%	-0.1	0.0	-0.1
<b>Run Results</b>			
Raw Results (chart %)	52.4	64.9	29.5
Raw Results (ppmv or % vol)	8.06	13.72	4.13
Corrected Results (ppmv or % vol) from % chart	8.67	13.78	4.14

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-NG-80%-1	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	8.60	20.90	4.54
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	55.8	93.6	32.3
Actual Zero Gas from Direct (Chart %)	2.1	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	55.2	93.6	32.3
Initial Readings			
Zero Gas (chart %)	2.5	10.0	2.2
Calibration Gas (chart %)	52.1	93.2	32.2
Zero Gas (ppmv)	0.08	0.01	0.03
Calibration Gas (ppmv)	8.01	20.80	4.53
Final Readings			
Zero Gas (chart %)	2.3	10.0	2.2
Calibration Gas (chart %)	52.1	93.2	32.1
Zero Gas (ppmv)	0.05	0.01	0.03
Calibration Gas (ppmv)	8.02	20.81	4.52
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.2	0.0	0.2
Calibration Bias (% Chart) ≤5%	-3.1	-0.4	-0.2
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.2	0.0	0.0
Calibration Drift (Chart %) ≤2 or 3%	-0.1	0.0	0.1
Run Results			
Raw Results (chart %)	50.4	64.8	29.6
Raw Results (ppmv or % vol)	7.74	13.71	4.14
Corrected Results (ppmv or % vol) from % chart	8.30	13.77	4.15
Run U3-NG-80%-2	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	8.60	20.90	4.54
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	55.8	93.6	32.3
Actual Zero Gas from Direct (Chart %)	2.1	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	55.2	93.6	32.3
Initial Readings			
Zero Gas (chart %)	2.3	10.0	2.2
Calibration Gas (chart %)	52.1	93.2	32.1
Zero Gas (ppmv)	0.05	0.01	0.03
Calibration Gas (ppmv)	8.02	20.81	4.52
Final Readings			
Zero Gas (chart %)	2.3	10.0	2.1
Calibration Gas (chart %)	51.6	93.1	32.1
Zero Gas (ppmv)	0.05	0.01	0.02
Calibration Gas (ppmv)	7.93	20.77	4.52
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.2	0.0	0.1
Calibration Bias (% Chart) ≤5%	-3.6	-0.6	-0.2
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	0.0	0.1
Calibration Drift (Chart %) ≤2 or 3%	0.6	0.2	0.0
Run Results			
Raw Results (chart %)	50.0	64.8	29.5
Raw Results (ppmv or % vol)	7.68	13.70	4.13
Corrected Results (ppmv or % vol) from % chart	8.28	13.77	4.15

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-NG-80%-3	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	16.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	8.60	20.90	4.54
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	55.8	93.6	32.3
Actual Zero Gas from Direct (Chart %)	2.1	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	55.2	93.6	32.3
<b>Initial Readings</b>			
Zero Gas (chart %)	2.3	10.0	2.1
Calibration Gas (chart %)	51.6	93.1	32.1
Zero Gas (ppmv)	0.05	0.01	0.02
Calibration Gas (ppmv)	7.93	20.77	4.52
<b>Final Readings</b>			
Zero Gas (chart %)	2.2	10.0	2.1
Calibration Gas (chart %)	51.6	93.2	32.1
Zero Gas (ppmv)	0.03	0.00	0.01
Calibration Gas (ppmv)	7.94	20.79	4.51
<b>Bias and Drift Calculations</b>			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.1	0.0	0.1
Calibration Bias (% Chart) ≤5%	-3.6	-0.5	-0.3
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.1	0.0	0.1
Calibration Drift (Chart %) ≤2 or 3%	-0.1	-0.1	0.1
<b>Run Results</b>			
Raw Results (chart %)	49.8	64.8	29.5
Raw Results (ppmv or % vol)	7.64	13.70	4.12
Corrected Results (ppmv or % vol) from % chart	8.28	13.78	4.14

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Linearity Check	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>	THC
Analyzer Range (ppmv), O <sub>2</sub> & CO <sub>2</sub> in % vol	100.00	30.00	25.00	15.00	30.00
Strip Chart Offset	2.0	5.0	10.0	2.0	5.0
Low Level Certified Value (ppm or % vol)	23.0	8.92	4.53	4.54	9.06
Mid Level Certified Value (ppm or % vol)	46.2	15.26	11.91	8.00	15.36
High Level Certified Value (ppm or % vol)	85.1	25.80	20.90	12.62	25.60
Zero Target (% Chart)	2.0	5.0	10.0	2.0	5.0
Low Level Target (% Chart)	25.0	34.7	28.1	32.3	35.2
Mid Level Target (% Chart)	48.2	55.9	57.6	55.4	56.2
High Level Target (% Chart)	87.1	91.0	93.6	86.1	90.3
Zero Observed (% Chart)	2.0	5.0	10.0	2.0	4.9
Low Level Observed (% Chart)	24.8	35.5	28.1	32.3	35.7
Mid Level Observed (% Chart)	48.2	55.8	57.7	55.3	56.2
High Level Observed (% Chart)	88.4	91.0	93.6	86.0	90.3
Zero Observed (ppm or % vol)	0.01	0.00	0.00	0.00	-0.02
Low Level Observed (ppm or % vol)	22.84	9.14	4.53	4.54	9.21
Mid Level Observed (ppm or % vol)	46.15	15.25	11.93	7.99	15.35
High Level Observed (ppm or % vol)	86.39	25.81	20.89	12.60	25.59
% Difference From Zero to Target	0.0	0.0	0.0	0.0	0.1
% Difference From Low to Target	0.2	-0.7	0.0	0.0	-1.7
% Difference From Mid to Target	0.1	0.0	-0.1	0.1	0.1
% Difference. From High to Target	-1.3	0.0	0.0	0.1	0.0
EPA Allowable % Difference from Target	±2% Span	±2% Span	±2% Span	±2% Span	±5% Cal Gas
Run U3-Oil-O <sub>2</sub> -Traverse	NO <sub>x</sub>		O <sub>2</sub>	CO <sub>2</sub>	
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0		25.00	15.00	
Calibration Gas Certified Value (ppm or %)	46.20		20.90	4.54	
Strip Chart Offset	2.0		10.0	2.0	
Target Calibration Gas (Chart %)	48.2		93.6	32.3	
Actual Zero Gas from Direct (Chart %)	2.0		10.0	2.0	
Actual Calibration Gas from Direct (Chart %)	48.2		93.6	32.3	
Initial Readings					
Zero Gas (chart %)	2.2		10.1	2.2	
Calibration Gas (chart %)	48.1		93.0	32.1	
Zero Gas (ppmv)	0.21		0.02	0.03	
Calibration Gas (ppmv)	46.05		20.75	4.52	
Final Readings					
Zero Gas (chart %)	2.2		10.1	2.3	
Calibration Gas (chart %)	47.8		93.1	32.2	
Zero Gas (ppmv)	0.21		0.03	0.05	
Calibration Gas (ppmv)	45.75		20.78	4.53	
Bias and Drift Calculations					
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.2		0.1	0.3	
Calibration Bias (% Chart) ≤5%	-0.4		-0.4	-0.1	
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0		0.0	-0.1	
Calibration Drift (Chart %) ≤2 or 3%	0.3		-0.1	-0.1	
Run Results					
Raw Results (chart %)	50.3		61.9	41.6	
Raw Results (ppmv or % vol)	48.26		12.96	5.94	
Corrected Results (ppmv or % vol) from % chart	48.58		13.04	5.97	

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-Oil-50%-1	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	46.20	11.91	8.00
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	48.2	57.6	55.3
Actual Zero Gas from Direct (Chart %)	2.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	48.2	57.7	55.3
<b>Initial Readings</b>			
Zero Gas (chart %)	2.2	10.1	2.3
Calibration Gas (chart %)	47.8	57.4	55.0
Zero Gas (ppmv)	0.21	0.03	0.05
Calibration Gas (ppmv)	45.75	11.85	7.95
<b>Final Readings</b>			
Zero Gas (chart %)	2.2	10.1	2.4
Calibration Gas (chart %)	47.6	57.5	55.2
Zero Gas (ppmv)	0.21	0.02	0.06
Calibration Gas (ppmv)	45.55	11.87	7.98
<b>Bias and Drift Calculations</b>			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.2	0.1	0.4
Calibration Bias (% Chart) ≤5%	-0.6	-0.2	-0.1
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	0.0	-0.1
Calibration Drift (Chart %) ≤2 or 3%	0.2	-0.1	-0.2
<b>Run Results</b>			
Raw Results (chart %)	50.3	62.0	41.5
Raw Results (ppmv or % vol)	48.25	12.99	5.93
Corrected Results (ppmv or % vol) from % chart	48.84	13.05	5.94
Run U3-Oil-50%-2	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	46.20	11.91	8.00
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	48.2	57.6	55.3
Actual Zero Gas from Direct (Chart %)	2.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	48.2	57.7	55.3
<b>Initial Readings</b>			
Zero Gas (chart %)	2.2	10.1	2.4
Calibration Gas (chart %)	47.6	57.5	55.2
Zero Gas (ppmv)	0.21	0.02	0.06
Calibration Gas (ppmv)	45.55	11.87	7.98
<b>Final Readings</b>			
Zero Gas (chart %)	2.2	10.0	2.3
Calibration Gas (chart %)	47.4	57.4	55.1
Zero Gas (ppmv)	0.21	0.01	0.05
Calibration Gas (ppmv)	45.35	11.86	7.97
<b>Bias and Drift Calculations</b>			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.2	0.0	0.3
Calibration Bias (% Chart) ≤5%	-0.8	-0.3	-0.1
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	0.0	0.1
Calibration Drift (Chart %) ≤2 or 3%	0.2	0.0	0.1
<b>Run Results</b>			
Raw Results (chart %)	49.8	61.9	41.5
Raw Results (ppmv or % vol)	47.81	12.97	5.93
Corrected Results (ppmv or % vol) from % chart	48.61	13.02	5.93



Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-Oil-50%-3	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	46.20	11.91	8.00
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	48.2	57.6	55.3
Actual Zero Gas from Direct (Chart %)	2.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	48.2	57.7	55.3
Initial Readings			
Zero Gas (chart %)	2.2	10.0	2.3
Calibration Gas (chart %)	47.4	57.4	55.1
Zero Gas (ppmv)	0.21	0.01	0.05
Calibration Gas (ppmv)	45.35	11.86	7.97
Final Readings			
Zero Gas (chart %)	2.2	10.2	2.5
Calibration Gas (chart %)	47.2	57.4	55.1
Zero Gas (ppmv)	0.21	0.04	0.07
Calibration Gas (ppmv)	45.15	11.86	7.96
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.2	0.2	0.5
Calibration Bias (% Chart) ≤5%	-1.0	-0.3	-0.2
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	-0.1	-0.1
Calibration Drift (Chart %) ≤2 or 3%	0.2	0.0	0.1
Run Results			
Raw Results (chart %)	49.5	62.0	41.5
Raw Results (ppmv or % vol)	47.53	12.99	5.93
Corrected Results (ppmv or % vol) from % chart	48.54	13.05	5.94
Run U3-Oil-65%-1	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	46.20	11.91	8.00
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	48.2	57.6	55.3
Actual Zero Gas from Direct (Chart %)	2.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	48.2	57.7	55.3
Initial Readings			
Zero Gas (chart %)	2.2	10.2	2.5
Calibration Gas (chart %)	47.2	57.4	55.1
Zero Gas (ppmv)	0.21	0.04	0.07
Calibration Gas (ppmv)	45.15	11.86	7.96
Final Readings			
Zero Gas (chart %)	2.3	10.2	2.6
Calibration Gas (chart %)	47.2	57.4	55.0
Zero Gas (ppmv)	0.31	0.05	0.09
Calibration Gas (ppmv)	45.16	11.85	7.95
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.3	0.2	0.6
Calibration Bias (% Chart) ≤5%	-1.0	-0.3	-0.3
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	-0.1	0.0	-0.1
Calibration Drift (Chart %) ≤2 or 3%	0.0	0.0	0.1
Run Results			
Raw Results (chart %)	51.8	60.2	43.7
Raw Results (ppmv or % vol)	49.82	12.55	6.26
Corrected Results (ppmv or % vol) from % chart	51.00	12.61	6.28

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-Oil-65%-2	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	46.20	11.91	8.00
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	48.2	57.6	55.3
Actual Zero Gas from Direct (Chart %)	2.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	48.2	57.7	55.3
<b>Initial Readings</b>			
Zero Gas (chart %)	2.3	10.2	2.6
Calibration Gas (chart %)	47.2	57.4	55.0
Zero Gas (ppmv)	0.31	0.05	0.09
Calibration Gas (ppmv)	45.16	11.85	7.95
<b>Final Readings</b>			
Zero Gas (chart %)	2.3	10.2	2.5
Calibration Gas (chart %)	46.9	57.3	55.0
Zero Gas (ppmv)	0.31	0.04	0.07
Calibration Gas (ppmv)	44.85	11.83	7.95
<b>Bias and Drift Calculations</b>			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.3	0.2	0.5
Calibration Bias (% Chart) ≤5%	-1.3	-0.4	-0.3
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	0.0	0.1
Calibration Drift (Chart %) ≤2 or 3%	0.3	0.1	0.0
<b>Run Results</b>			
Raw Results (chart %)	51.7	60.2	43.7
Raw Results (ppmv or % vol)	49.68	12.56	6.25
Corrected Results (ppmv or % vol) from % chart	51.03	12.64	6.27
Run U3-Oil-65%-3	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	46.20	11.91	8.00
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	48.2	57.6	55.3
Actual Zero Gas from Direct (Chart %)	2.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	48.2	57.7	55.3
<b>Initial Readings</b>			
Zero Gas (chart %)	2.3	10.2	2.5
Calibration Gas (chart %)	46.9	57.3	55.0
Zero Gas (ppmv)	0.31	0.04	0.07
Calibration Gas (ppmv)	44.85	11.83	7.95
<b>Final Readings</b>			
Zero Gas (chart %)	2.3	10.1	2.4
Calibration Gas (chart %)	47.2	57.3	55.0
Zero Gas (ppmv)	0.31	0.02	0.06
Calibration Gas (ppmv)	45.15	11.83	7.95
<b>Bias and Drift Calculations</b>			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.3	0.1	0.4
Calibration Bias (% Chart) ≤5%	-1.0	-0.4	-0.3
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	0.1	0.1
Calibration Drift (Chart %) ≤2 or 3%	-0.3	0.0	0.0
<b>Run Results</b>			
Raw Results (chart %)	51.5	60.2	43.6
Raw Results (ppmv or % vol)	49.53	12.54	6.24
Corrected Results (ppmv or % vol) from % chart	50.88	12.63	6.27

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-Oil-80%-1	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	46.20	11.91	8.00
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	48.2	57.6	55.3
Actual Zero Gas from Direct (Chart %)	2.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	48.2	57.7	55.3
<b>Initial Readings</b>			
Zero Gas (chart %)	2.3	10.1	2.4
Calibration Gas (chart %)	47.2	57.3	55.0
Zero Gas (ppmv)	0.31	0.02	0.06
Calibration Gas (ppmv)	45.15	11.83	7.95
<b>Final Readings</b>			
Zero Gas (chart %)	2.3	10.0	2.3
Calibration Gas (chart %)	47.4	57.4	54.9
Zero Gas (ppmv)	0.33	0.00	0.05
Calibration Gas (ppmv)	45.35	11.84	7.94
<b>Bias and Drift Calculations</b>			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.3	0.0	0.3
Calibration Bias (% Chart) ≤5%	-0.8	-0.4	-0.3
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	0.1	0.1
Calibration Drift (Chart %) ≤2 or 3%	-0.2	0.0	0.1
<b>Run Results</b>			
Raw Results (chart %)	52.5	59.8	44.1
Raw Results (ppmv or % vol)	50.52	12.44	6.31
Corrected Results (ppmv or % vol) from % chart	51.62	12.52	6.34
Run U3-Oil-80%-2	NO <sub>x</sub>	O <sub>2</sub>	CO <sub>2</sub>
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	46.20	11.91	8.00
Strip Chart Offset	2.0	10.0	2.0
Target Calibration Gas (Chart %)	48.2	57.6	55.3
Actual Zero Gas from Direct (Chart %)	2.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	48.2	57.7	55.3
<b>Initial Readings</b>			
Zero Gas (chart %)	2.3	10.0	2.3
Calibration Gas (chart %)	47.4	57.4	54.9
Zero Gas (ppmv)	0.33	0.00	0.05
Calibration Gas (ppmv)	45.35	11.84	7.94
<b>Final Readings</b>			
Zero Gas (chart %)	2.3	10.0	2.4
Calibration Gas (chart %)	46.7	57.4	54.9
Zero Gas (ppmv)	0.31	0.01	0.06
Calibration Gas (ppmv)	44.74	11.84	7.94
<b>Bias and Drift Calculations</b>			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.3	0.0	0.4
Calibration Bias (% Chart) ≤5%	-1.4	-0.4	-0.3
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	0.0	-0.1
Calibration Drift (Chart %) ≤2 or 3%	0.6	0.0	0.0
<b>Run Results</b>			
Raw Results (chart %)	52.9	59.8	44.1
Raw Results (ppmv or % vol)	50.93	12.44	6.31
Corrected Results (ppmv or % vol) from % chart	52.28	12.51	6.35

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-Oil-80%-3	NO <sub>x</sub>		O <sub>2</sub>	CO <sub>2</sub>	
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0		25.00	15.00	
Calibration Gas Certified Value (ppm or %)	46.20		11.91	8.00	
Strip Chart Offset	2.0		10.0	2.0	
Target Calibration Gas (Chart %)	48.2		57.6	55.3	
Actual Zero Gas from Direct (Chart %)	2.0		10.0	2.0	
Actual Calibration Gas from Direct (Chart %)	48.2		57.7	55.3	
Initial Readings					
Zero Gas (chart %)	2.3		10.0	2.4	
Calibration Gas (chart %)	46.7		57.4	54.9	
Zero Gas (ppmv)	0.31		0.01	0.06	
Calibration Gas (ppmv)	44.74		11.84	7.94	
Final Readings					
Zero Gas (chart %)	2.1		10.2	2.0	
Calibration Gas (chart %)	46.5		57.2	54.9	
Zero Gas (ppmv)	0.10		0.04	0.00	
Calibration Gas (ppmv)	44.54		11.81	7.94	
Bias and Drift Calculations					
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.1		0.2	0.0	
Calibration Bias (% Chart) ≤5%	-1.6		-0.5	-0.3	
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.2		-0.1	0.4	
Calibration Drift (Chart %) ≤2 or 3%	0.2		0.1	0.0	
Run Results					
Raw Results (chart %)	52.4		59.7	44.1	
Raw Results (ppmv or % vol)	50.41		12.42	6.31	
Corrected Results (ppmv or % vol) from % chart	52.20		12.51	6.35	
Run U3-Oil-100%-1	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>	THC
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	30.0	25.00	15.00	30.00
Calibration Gas Certified Value (ppm or %)	46.20	15.26	11.91	8.00	15.36
Strip Chart Offset	2.0	5.0	10.0	2.0	5.0
Target Calibration Gas (Chart %)	48.2	55.9	57.6	55.3	56.2
Actual Zero Gas from Direct (Chart %)	2.0	5.0	10.0	2.0	4.9
Actual Calibration Gas from Direct (Chart %)	48.2	55.8	57.7	55.3	56.2
Initial Readings					
Zero Gas (chart %)	2.1	6.9	10.2	2.0	5.0
Calibration Gas (chart %)	46.5	56.6	57.2	54.9	55.5
Zero Gas (ppmv)	0.10	0.56	0.04	0.00	0.00
Calibration Gas (ppmv)	44.54	15.49	11.81	7.94	15.16
Final Readings					
Zero Gas (chart %)	2.3	6.8	10.1	2.1	5.1
Calibration Gas (chart %)	46.7	56.2	57.2	54.9	56.1
Zero Gas (ppmv)	0.30	0.53	0.03	0.02	0.02
Calibration Gas (ppmv)	44.65	15.37	11.80	7.93	15.34
Bias and Drift Calculations					
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.3	1.8	0.1	0.1	0.1
Calibration Bias (% Chart) ≤5%	-1.5	0.4	-0.5	-0.4	0.0
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	-0.2	0.1	0.0	-0.1	-0.1
Calibration Drift (Chart %) ≤2 or 3%	-0.1	0.4	0.0	0.1	-0.6
Run Results					
Raw Results (chart %)	52.3	8.6	59.7	43.9	5.4
Raw Results (ppmv or % vol)	50.30	1.07	12.43	6.29	0.13
Corrected Results (ppmv or % vol) from % chart	52.14	0.54	12.54	6.34	0.12

Quality Assurance Activities  
Calibration Error, Bias, and Drift Checks

Unit 3

Run U3-Oil-100%-2	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>	THC
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	30.0	25.00	15.00	30.00
Calibration Gas Certified Value (ppm or %)	46.20	15.26	11.91	8.00	15.36
Strip Chart Offset	2.0	5.0	10.0	2.0	5.0
Target Calibration Gas (Chart %)	48.2	55.9	57.6	55.3	56.2
Actual Zero Gas from Direct (Chart %)	2.0	5.0	10.0	2.0	4.9
Actual Calibration Gas from Direct (Chart %)	48.2	55.8	57.7	55.3	56.2
Initial Readings					
Zero Gas (chart %)	2.3	6.8	10.1	2.1	5.1
Calibration Gas (chart %)	46.7	56.2	57.2	54.9	56.1
Zero Gas (ppmv)	0.30	0.53	0.03	0.02	0.02
Calibration Gas (ppmv)	44.65	15.37	11.80	7.93	15.34
Final Readings					
Zero Gas (chart %)	2.2	6.7	10.1	2.1	5.1
Calibration Gas (chart %)	46.8	56.3	57.2	54.9	56.6
Zero Gas (ppmv)	0.20	0.50	0.03	0.02	0.03
Calibration Gas (ppmv)	44.84	15.38	11.79	7.94	15.47
Bias and Drift Calculations					
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.2	1.7	0.1	0.1	0.2
Calibration Bias (% Chart) ≤5%	-1.3	0.4	-0.6	-0.3	0.4
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.1	0.1	0.0	0.0	0.0
Calibration Drift (Chart %) ≤2 or 3%	-0.2	0.0	0.0	-0.1	-0.4
Run Results					
Raw Results (chart %)	52.4	8.6	59.8	43.9	5.5
Raw Results (ppmv or % vol)	50.41	1.09	12.45	6.28	0.15
Corrected Results (ppmv or % vol) from % chart	52.08	0.59	12.57	6.33	0.12
Run U3-Oil-100%-3	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>	THC
Analyzer Range (ppm), O <sub>2</sub> & CO <sub>2</sub> in %	100.0	30.0	25.00	15.00	30.00
Calibration Gas Certified Value (ppm or %)	46.20	15.26	11.91	8.00	15.36
Strip Chart Offset	2.0	5.0	10.0	2.0	5.0
Target Calibration Gas (Chart %)	48.2	55.9	57.6	55.3	56.2
Actual Zero Gas from Direct (Chart %)	2.0	5.0	10.0	2.0	4.9
Actual Calibration Gas from Direct (Chart %)	48.2	55.8	57.7	55.3	56.2
Initial Readings					
Zero Gas (chart %)	2.2	6.7	10.1	2.1	5.1
Calibration Gas (chart %)	46.8	56.3	57.2	54.9	56.6
Zero Gas (ppmv)	0.20	0.50	0.03	0.02	0.03
Calibration Gas (ppmv)	44.84	15.38	11.79	7.94	15.47
Final Readings					
Zero Gas (chart %)	2.2	6.6	10.0	2.1	5.1
Calibration Gas (chart %)	47.2	56.1	57.2	54.9	57.6
Zero Gas (ppmv)	0.21	0.47	0.01	0.02	0.02
Calibration Gas (ppmv)	45.15	15.32	11.81	7.93	15.79
Bias and Drift Calculations					
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	0.2	1.6	0.0	0.1	0.1
Calibration Bias (% Chart) ≤5%	-1.0	0.2	-0.5	-0.4	1.5
Zero Drift (Chart %) (Run-Run) ≤2 or 3%	0.0	0.1	0.1	0.0	0.0
Calibration Drift (Chart %) ≤2 or 3%	-0.3	0.2	-0.1	0.1	-1.1
Run Results					
Raw Results (chart %)	52.4	8.6	59.7	43.9	5.2
Raw Results (ppmv or % vol)	50.42	1.08	12.43	6.29	0.07
Corrected Results (ppmv or % vol) from % chart	51.80	0.61	12.55	6.34	0.04

# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-NG-O2-Trav, W Port      5/7/02      7:29:01      7:59:01

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.94	14.86	8.51	0.71	-0.28	0.59
O2 (% vol)	0	4.52	11.95	20.91	0.05	-0.15	-0.02
CO2 (% vol)	0	8.03	12.62	4.55	-0.19	-0.01	-0.07

Initial and Final Bias and Drift	I-Zero	I-Span
NOx (ppmv)	0.08	8.57
O2 (% vol)	0.03	20.82
CO2 (% vol)	0	4.51

Run Results and Cal Gases Used	Raw	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	11.71	16	5.05	14.82	8.6
O2 (% vol)	13.78	25	4.53	11.91	20.9
CO2 (% vol)	4.1	15	8	12.62	4.54

Run U3-NG-O2-Trav, S Port      5/7/02      8:03:09      8:33:09

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.94	14.86	8.51	0.71	-0.28	0.59
O2 (% vol)	0	4.52	11.95	20.91	0.05	-0.15	-0.02
CO2 (% vol)	0	8.03	12.62	4.55	-0.19	-0.01	-0.07

Initial and Final Bias and Drift	I-Zero	I-Span
NOx (ppmv)	0.08	8.57
O2 (% vol)	0.03	20.82
CO2 (% vol)	0	4.51

Run Results and Cal Gases Used	Raw	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	11.07	16	5.05	14.82	8.6
O2 (% vol)	13.79	25	4.53	11.91	20.9
CO2 (% vol)	4.09	15	8	12.62	4.54

# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-NG-O2-Trav, E Port      5/7/02      8:41:10      9:11:10

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.94	14.86	8.51	0.71	-0.28	0.59
O2 (% vol)	0	4.52	11.95	20.91	0.05	-0.15	-0.02
CO2 (% vol)	0	8.03	12.62	4.55	-0.19	-0.01	-0.07

Initial and Final Bias and Drift	I-Zero	I-Span
NOx (ppmv)	0.08	8.57
O2 (% vol)	0.03	20.82
CO2 (% vol)	0	4.51

Run Results and Cal Gases Used	Raw	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	11.08	16	5.05	14.82	8.6
O2 (% vol)	13.81	25	4.53	11.91	20.9
CO2 (% vol)	4.08	15	8	12.62	4.54

Run U3-NG-O2-Trav, N Port      5/7/02      9:14:00      9:44:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.94	14.86	8.51	0.71	-0.28	0.59
O2 (% vol)	0	4.52	11.95	20.91	0.05	-0.15	-0.02
CO2 (% vol)	0	8.03	12.62	4.55	-0.19	-0.01	-0.07

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.08	8.57	0.12	8.43	0.63	-0.5	-0.25	0.88
O2 (% vol)	0.03	20.82	0.03	20.81	0.12	-0.4	0	0.04
CO2 (% vol)	0	4.51	0.01	4.52	0.07	-0.2	-0.07	-0.07

Run Results and Cal Gases Used	Raw	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	11.36	16	5.05	14.82	8.6
O2 (% vol)	13.83	25	4.53	11.91	20.9
CO2 (% vol)	4.07	15	8	12.62	4.54

# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-100%-1/U3-RA-1                      5/7/02      10:17:00      11:17:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.94	14.86	8.51	0.71	-0.28	0.59
CO (ppmv)	0	9.11	25.82	15.23	-0.65	-0.05	0.1
O2 (% vol)	0	4.52	11.95	20.91	0.05	-0.15	-0.02
CO2 (% vol)	0	8.03	12.62	4.55	-0.19	-0.01	-0.07
THC (ppmv)	0.01	9.26	25.65	15.38	-0.67	-0.17	-0.07

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.12	8.43	0.08	8.4	0.4	-0.69	0.21	0.2
CO (ppmv)	0.18	15.35	0.15	15.35	0.49	0.4	0.1	0
O2 (% vol)	0.03	20.81	0.02	20.79	0.07	-0.46	0.03	0.08
CO2 (% vol)	0.01	4.52	0.01	4.53	0.07	-0.11	0	-0.09
THC (ppmv)	-0.02	15.16	-0.05	15.38	-0.2	0	0.1	-0.73

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	9.22	9.43	16	5.05	14.82	8.6
CO (ppmv)	0.42	0.26	30	8.92	25.8	15.26
O2 (% vol)	13.66	13.72	25	4.53	11.91	20.9
CO2 (% vol)	4.18	4.19	15	8	12.62	4.54
THC (ppmv)	0.53	0.57	30	9.06	25.6	15.36



# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-100%-2/U3-RA-2                      5/7/02      11:30:05      12:30:05

Initial Linearity Test									
	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.02	4.94	14.86	8.51	0.71	-0.28	0.59		
CO (ppmv)	0	9.11	25.82	15.23	-0.65	-0.05	0.1		
O2 (% vol)	0	4.52	11.95	20.91	0.05	-0.15	-0.02		
CO2 (% vol)	0	8.03	12.62	4.55	-0.19	-0.01	-0.07		
THC (ppmv)	0.01	9.26	25.65	15.38	-0.67	-0.17	-0.07		
Initial and Final Bias and Drift									
	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.08	8.4	0.07	8.27	0.31	-1.5	0.09	0.81	
CO (ppmv)	0.15	15.35	0.18	15.32	0.59	0.29	-0.1	0.11	
O2 (% vol)	0.02	20.79	0.01	20.75	0.05	-0.64	0.02	0.18	
CO2 (% vol)	0.01	4.53	0	4.52	0.01	-0.19	0.05	0.08	
THC (ppmv)	-0.05	15.38	0.07	15.01	0.2	-1.23	-0.4	1.23	
Run Results and Cal Gases Used									
	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	9.12	9.42	16	5.05	14.82	8.6			
CO (ppmv)	0.38	0.22	30	8.92	25.8	15.26			
O2 (% vol)	13.64	13.72	25	4.53	11.91	20.9			
CO2 (% vol)	4.15	4.16	15	8	12.62	4.54			
THC (ppmv)	0.57	0.57	30	9.06	25.6	15.36			

# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-100%-3/U3-RA-3                      5/7/02      12:47:01      13:47:01

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.94	14.86	8.51	0.71	-0.28	0.59
CO (ppmv)	0	9.11	25.82	15.23	-0.65	-0.05	0.1
O2 (% vol)	0	4.52	11.95	20.91	0.05	-0.15	-0.02
CO2 (% vol)	0	8.03	12.62	4.55	-0.19	-0.01	-0.07
THC (ppmv)	0.01	9.26	25.65	15.38	-0.67	-0.17	-0.07

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.07	8.27	0.05	8.2	0.2	-1.9	0.11	0.4
CO (ppmv)	0.18	15.32	0.15	15.26	0.49	0.09	0.1	0.2
O2 (% vol)	0.01	20.75	0.01	20.75	0.04	-0.62	0.01	-0.02
CO2 (% vol)	0	4.52	0	4.51	0	-0.24	0.01	0.05
THC (ppmv)	0.07	15.01	0.05	14.86	0.13	-1.73	0.07	0.5

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	8.99	9.39	16	5.05	14.82	8.6
CO (ppmv)	0.37	0.21	30	8.92	25.8	15.26
O2 (% vol)	13.65	13.75	25	4.53	11.91	20.9
CO2 (% vol)	4.14	4.16	15	8	12.62	4.54
THC (ppmv)	0.45	0.40	30	9.06	25.6	15.36

# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-NG-50%-1                      5/9/02      10:11:21      10:31:21

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.02	4.93	14.72	8.6	0.72	0.63	-0.02		
O2 (% vol)	0	4.54	11.95	20.91	-0.02	-0.16	-0.05		
CO2 (% vol)	0	8	12.62	4.54	-0.03	0.01	-0.03		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.03	8.23	0.08	8.17	0.39	-2.72	-0.3	0.41	
O2 (% vol)	0	20.8	0.02	20.79	0.09	-0.49	-0.09	0.04	
CO2 (% vol)	0.02	4.51	0.02	4.53	0.11	-0.12	0	-0.09	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	8.74	9.17	16	5.05	14.82	8.6			
O2 (% vol)	13.98	14.05	25	4.53	11.91	20.9			
CO2 (% vol)	4	4.02	15	8	12.62	4.54			

Run U3-NG-50%-2                      5/9/02      10:39:00      10:59:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.02	4.93	14.72	8.6	0.72	0.63	-0.02		
O2 (% vol)	0	4.54	11.95	20.91	-0.02	-0.16	-0.05		
CO2 (% vol)	0	8	12.62	4.54	-0.03	0.01	-0.03		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.08	8.17	0.1	8.2	0.48	-2.52	-0.1	-0.2	
O2 (% vol)	0.02	20.79	0.01	20.83	0.03	-0.32	0.06	-0.17	
CO2 (% vol)	0.02	4.53	0.02	4.52	0.12	-0.15	-0.01	0.03	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	8.6	9.04	16	5.05	14.82	8.6			
O2 (% vol)	13.99	14.05	25	4.53	11.91	20.9			
CO2 (% vol)	4	4.01	15	8	12.62	4.54			

# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-NG-50%-3                      5/9/02      11:07:08      11:27:08

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.93	14.72	8.6	0.72	0.63	-0.02
O2 (% vol)	0	4.54	11.95	20.91	-0.02	-0.16	-0.05
CO2 (% vol)	0	8	12.62	4.54	-0.03	0.01	-0.03

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.1	8.2	0.08	8.14	0.39	-2.92	0.1	0.4
O2 (% vol)	0.01	20.83	0.02	20.82	0.08	-0.39	-0.05	0.07
CO2 (% vol)	0.02	4.52	0.03	4.53	0.17	-0.11	-0.05	-0.04

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	8.66	9.12	16	5.05	14.82	8.6
O2 (% vol)	13.97	14.02	25	4.53	11.91	20.9
CO2 (% vol)	4	4.01	15	8	12.62	4.54

Run U3-NG-65%-1                      5/9/02      11:34:10      11:54:10

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.93	14.72	8.6	0.72	0.63	-0.02
O2 (% vol)	0	4.54	11.95	20.91	-0.02	-0.16	-0.05
CO2 (% vol)	0	8	12.62	4.54	-0.03	0.01	-0.03

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.08	8.14	0.07	8.04	0.29	-3.52	0.1	0.6
O2 (% vol)	0.02	20.82	0.01	20.8	0.04	-0.45	0.04	0.06
CO2 (% vol)	0.03	4.53	0.02	4.52	0.13	-0.13	0.04	0.03

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	8.14	8.65	16	5.05	14.82	8.6
O2 (% vol)	13.71	13.76	25	4.53	11.91	20.9
CO2 (% vol)	4.14	4.15	15	8	12.62	4.54

# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-NG-65%-2                      5/9/02      12:01:06      12:21:06

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.02	4.93	14.72	8.6	0.72	0.63	-0.02		
O2 (% vol)	0	4.54	11.95	20.91	-0.02	-0.16	-0.05		
CO2 (% vol)	0	8	12.62	4.54	-0.03	0.01	-0.03		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.07	8.04	0.07	7.99	0.29	-3.81	0	0.29	
O2 (% vol)	0.01	20.8	0.01	20.81	0.05	-0.41	-0.01	-0.04	
CO2 (% vol)	0.02	4.52	0.02	4.52	0.15	-0.13	-0.01	0	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	8.04	8.63	16	5.05	14.82	8.6			
O2 (% vol)	13.72	13.78	25	4.53	11.91	20.9			
CO2 (% vol)	4.14	4.16	15	8	12.62	4.54			

Run U3-NG-65%-3                      5/9/02      12:28:01      12:48:01

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.02	4.93	14.72	8.6	0.72	0.63	-0.02		
O2 (% vol)	0	4.54	11.95	20.91	-0.02	-0.16	-0.05		
CO2 (% vol)	0	8	12.62	4.54	-0.03	0.01	-0.03		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.07	7.99	0.08	8.01	0.39	-3.72	-0.1	-0.09	
O2 (% vol)	0.01	20.81	0.01	20.8	0.06	-0.46	-0.01	0.05	
CO2 (% vol)	0.02	4.52	0.03	4.53	0.17	-0.12	-0.03	-0.01	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	8.06	8.67	16	5.05	14.82	8.6			
O2 (% vol)	13.72	13.78	25	4.53	11.91	20.9			
CO2 (% vol)	4.13	4.14	15	8	12.62	4.54			

# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-NG-80%-1                      5/9/02    12:56:00    13:16:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.93	14.72	8.6	0.72	0.63	-0.02
O2 (% vol)	0	4.54	11.95	20.91	-0.02	-0.16	-0.05
CO2 (% vol)	0	8	12.62	4.54	-0.03	0.01	-0.03

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.08	8.01	0.05	8.02	0.18	-3.62	0.2	-0.1
O2 (% vol)	0.01	20.8	0.01	20.81	0.06	-0.42	0	-0.04
CO2 (% vol)	0.03	4.53	0.03	4.52	0.17	-0.16	0	0.04

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	7.74	8.30	16	5.05	14.82	8.6
O2 (% vol)	13.71	13.77	25	4.53	11.91	20.9
CO2 (% vol)	4.14	4.15	15	8	12.62	4.54

Run U3-NG-80%-2                      5/9/02    13:22:07    13:42:07

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.02	4.93	14.72	8.6	0.72	0.63	-0.02
O2 (% vol)	0	4.54	11.95	20.91	-0.02	-0.16	-0.05
CO2 (% vol)	0	8	12.62	4.54	-0.03	0.01	-0.03

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.05	8.02	0.05	7.93	0.18	-4.22	0	0.6
O2 (% vol)	0.01	20.81	0.01	20.77	0.02	-0.56	0.04	0.14
CO2 (% vol)	0.03	4.52	0.02	4.52	0.13	-0.16	0.04	0

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	7.68	8.28	16	5.05	14.82	8.6
O2 (% vol)	13.7	13.77	25	4.53	11.91	20.9
CO2 (% vol)	4.13	4.15	15	8	12.62	4.54

# Tampa Electric Polk Power Station, Unit 3 Nat. Gas Testing, Logged QA Calibration Records

Run U3-NG-80%-3                      5/9/02    13:49:13    14:09:13

Initial Linearity Test									
	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.02	4.93	14.72	8.6	0.72	0.63	-0.02		
O2 (% vol)	0	4.54	11.95	20.91	-0.02	-0.16	-0.05		
CO2 (% vol)	0	8	12.62	4.54	-0.03	0.01	-0.03		
Initial and Final Bias and Drift									
	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.05	7.93	0.03	7.94	0.07	-4.12	0.11	-0.1	
O2 (% vol)	0.01	20.77	0	20.79	0	-0.47	0.02	-0.09	
CO2 (% vol)	0.02	4.52	0.01	4.51	0.09	-0.21	0.04	0.05	
Run Results and Cal Gases Used									
	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	7.64	8.28	16	5.05	14.82	8.6			
O2 (% vol)	13.7	13.78	25	4.53	11.91	20.9			
CO2 (% vol)	4.12	4.14	15	8	12.62	4.54			

# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-O2-Trav, N Port                    5/8/02            9:03:00            9:33:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
O2 (% vol)	0	4.53	11.93	20.89	0.01	-0.09	0.04
CO2 (% vol)	0	7.99	12.6	4.54	0.07	0.16	0.01

Initial and Final Bias and Drift	I-Zero	I-Span
NOx (ppmv)	0.21	46.05
O2 (% vol)	0.02	20.75
CO2 (% vol)	0.03	4.52

Run Results and Cal Gases Used	Raw	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	48.58	100	23	85.1	46.2
O2 (% vol)	12.94	25	4.53	11.91	20.9
CO2 (% vol)	5.92	15	8	12.62	4.54

Run U3-Oil-O2-Trav, S Port                    5/8/02            9:36:00            10:06:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
O2 (% vol)	0	4.53	11.93	20.89	0.01	-0.09	0.04
CO2 (% vol)	0	7.99	12.6	4.54	0.07	0.16	0.01

Initial and Final Bias and Drift	I-Zero	I-Span
NOx (ppmv)	0.21	46.05
O2 (% vol)	0.02	20.75
CO2 (% vol)	0.03	4.52

Run Results and Cal Gases Used	Raw	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	47.96	100	23	85.1	46.2
O2 (% vol)	12.94	25	4.53	11.91	20.9
CO2 (% vol)	5.96	15	8	12.62	4.54



# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-O2-Trav, E Port      5/8/02      10:09:05      10:39:05

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
O2 (% vol)	0	4.53	11.93	20.89	0.01	-0.09	0.04
CO2 (% vol)	0	7.99	12.6	4.54	0.07	0.16	0.01

Initial and Final Bias and Drift	I-Zero	I-Span
NOx (ppmv)	0.21	46.05
O2 (% vol)	0.02	20.75
CO2 (% vol)	0.03	4.52

Run Results and Cal Gases Used	Raw	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	47.76	100	23	85.1	46.2
O2 (% vol)	12.95	25	4.53	11.91	20.9
CO2 (% vol)	5.96	15	8	12.62	4.54

Run U3-Oil-O2-Trav, W Port      5/8/02      10:42:00      11:12:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
O2 (% vol)	0	4.53	11.93	20.89	0.01	-0.09	0.04
CO2 (% vol)	0	7.99	12.6	4.54	0.07	0.16	0.01

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.21	46.05	0.21	45.75	0.2	-0.4	0	0.3
O2 (% vol)	0.02	20.75	0.03	20.78	0.12	-0.43	-0.03	-0.12
CO2 (% vol)	0.03	4.52	0.05	4.53	0.29	-0.05	-0.13	-0.09

Run Results and Cal Gases Used	Raw	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	48.73	100	23	85.1	46.2
O2 (% vol)	13.02	25	4.53	11.91	20.9
CO2 (% vol)	5.9	15	8	12.62	4.54

# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-50%-1                      5/8/02      11:25:00      11:45:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05		
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08		
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.21	45.75	0.21	45.55	0.2	-0.6	0	0.2	
O2 (% vol)	0.03	11.85	0.02	11.87	0.09	-0.24	0.03	-0.09	
CO2 (% vol)	0.05	7.95	0.06	7.98	0.37	-0.09	-0.08	-0.17	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	48.25	48.84	100	23	85.1	46.2			
O2 (% vol)	12.99	13.05	25	4.53	20.9	11.91			
CO2 (% vol)	5.93	5.94	15	4.54	12.62	8			

Run U3-Oil-50%-2                      5/8/02      11:53:00      12:13:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05		
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08		
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.21	45.55	0.21	45.35	0.2	-0.8	0	0.2	
O2 (% vol)	0.02	11.87	0.01	11.86	0.04	-0.29	0.05	0.05	
CO2 (% vol)	0.06	7.98	0.05	7.97	0.31	-0.16	0.07	0.07	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	47.81	48.61	100	23	85.1	46.2			
O2 (% vol)	12.97	13.02	25	4.53	20.9	11.91			
CO2 (% vol)	5.93	5.93	15	4.54	12.62	8			

# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-50%-3                      5/8/02      12:24:07      12:44:07

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05		
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08		
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.21	45.35	0.21	45.15	0.2	-1	0	0.2	
O2 (% vol)	0.01	11.86	0.04	11.86	0.17	-0.29	-0.13	0	
CO2 (% vol)	0.05	7.97	0.07	7.96	0.47	-0.2	-0.16	0.04	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	47.53	48.54	100	23	85.1	46.2			
O2 (% vol)	12.99	13.05	25	4.53	20.9	11.91			
CO2 (% vol)	5.93	5.94	15	4.54	12.62	8			

Run U3-Oil-65%-1                      5/8/02      12:53:07      13:13:07

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05		
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08		
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.21	45.15	0.31	45.16	0.3	-0.99	-0.1	-0.01	
O2 (% vol)	0.04	11.86	0.05	11.85	0.21	-0.32	-0.04	0.03	
CO2 (% vol)	0.07	7.96	0.09	7.95	0.59	-0.27	-0.12	0.07	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	49.82	51.00	100	23	85.1	46.2			
O2 (% vol)	12.55	12.61	25	4.53	20.9	11.91			
CO2 (% vol)	6.26	6.28	15	4.54	12.62	8			

# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-65%-2                      5/8/02      13:21:00      13:41:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.31	45.16	0.31	44.85	0.3	-1.3	0	0.31
O2 (% vol)	0.05	11.85	0.04	11.83	0.15	-0.39	0.06	0.07
CO2 (% vol)	0.09	7.95	0.07	7.95	0.43	-0.29	0.16	0.03

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	49.68	51.03	100	23	85.1	46.2
O2 (% vol)	12.56	12.64	25	4.53	20.9	11.91
CO2 (% vol)	6.25	6.27	15	4.54	12.62	8

Run U3-Oil-65%-3                      5/8/02      13:49:01      14:09:01

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.31	44.85	0.31	45.15	0.3	-1	0	-0.3
O2 (% vol)	0.04	11.83	0.02	11.83	0.08	-0.39	0.07	0
CO2 (% vol)	0.07	7.95	0.06	7.95	0.4	-0.29	0.03	0

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	49.53	50.88	100	23	85.1	46.2
O2 (% vol)	12.54	12.63	25	4.53	20.9	11.91
CO2 (% vol)	6.24	6.27	15	4.54	12.62	8

# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-80%-1                      5/8/02      14:18:00      14:38:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.31	45.15	0.33	45.35	0.32	-0.8	-0.02	-0.2
O2 (% vol)	0.02	11.83	0	11.84	0.01	-0.37	0.07	-0.02
CO2 (% vol)	0.06	7.95	0.05	7.94	0.31	-0.35	0.09	0.05

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	50.52	51.62	100	23	85.1	46.2
O2 (% vol)	12.44	12.52	25	4.53	20.9	11.91
CO2 (% vol)	6.31	6.34	15	4.54	12.62	8

Run U3-Oil-80%-2                      5/8/02      14:47:02      15:07:02

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.33	45.35	0.31	44.74	0.3	-1.41	0.02	0.61
O2 (% vol)	0	11.84	0.01	11.84	0.03	-0.36	-0.02	-0.01
CO2 (% vol)	0.05	7.94	0.06	7.94	0.37	-0.36	-0.07	0.01

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	50.93	52.28	100	23	85.1	46.2
O2 (% vol)	12.44	12.51	25	4.53	20.9	11.91
CO2 (% vol)	6.31	6.35	15	4.54	12.62	8

# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-80%-3                      5/8/02      15:17:00      15:37:00

Initial Linearity Test									
	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05		
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08		
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07		
Initial and Final Bias and Drift									
	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.31	44.74	0.1	44.54	0.09	-1.61	0.21	0.2	
O2 (% vol)	0.01	11.84	0.04	11.81	0.17	-0.47	-0.14	0.11	
CO2 (% vol)	0.06	7.94	0	7.94	-0.01	-0.32	0.39	-0.04	
Run Results and Cal Gases Used									
	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	50.41	52.20	100	23	85.1	46.2			
O2 (% vol)	12.42	12.51	25	4.53	20.9	11.91			
CO2 (% vol)	6.31	6.35	15	4.54	12.62	8			

# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-100%-1                      5/8/02      15:55:02      16:55:02

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
CO (ppmv)	0	9.14	25.81	15.25	-0.73	-0.03	0.03
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07
THC (ppmv)	-0.02	9.21	25.59	15.35	-0.5	0.03	0.03

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.1	44.54	0.3	44.65	0.29	-1.5	-0.2	-0.11
CO (ppmv)	0.56	15.49	0.53	15.37	1.78	0.42	0.09	0.4
O2 (% vol)	0.04	11.81	0.03	11.8	0.1	-0.52	0.07	0.05
CO2 (% vol)	0	7.94	0.02	7.93	0.09	-0.43	-0.11	0.11
THC (ppmv)	0	15.16	0.02	15.34	0.13	-0.03	-0.07	-0.6

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	50.3	52.14	100	23	85.1	46.2
CO (ppmv)	1.07	0.54	30	8.92	25.8	15.26
O2 (% vol)	12.43	12.54	25	4.53	20.9	11.91
CO2 (% vol)	6.29	6.34	15	4.54	12.62	8
THC (ppmv)	0.13	0.12	30	9.06	25.6	15.36

# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-100%-2                      5/8/02      17:10:00      18:10:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05
CO (ppmv)	0	9.14	25.81	15.25	-0.73	-0.03	0.03
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07
THC (ppmv)	-0.02	9.21	25.59	15.35	-0.5	0.03	0.03

Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift
NOx (ppmv)	0.3	44.65	0.2	44.84	0.19	-1.31	0.1	-0.19
CO (ppmv)	0.53	15.37	0.5	15.38	1.67	0.43	0.11	-0.01
O2 (% vol)	0.03	11.8	0.03	11.79	0.11	-0.58	-0.01	0.06
CO2 (% vol)	0.02	7.93	0.02	7.94	0.12	-0.35	-0.03	-0.08
THC (ppmv)	0.02	15.34	0.03	15.47	0.17	0.4	-0.03	-0.43

Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas
NOx (ppmv)	50.41	52.08	100	23	85.1	46.2
CO (ppmv)	1.09	0.59	30	8.92	25.8	15.26
O2 (% vol)	12.45	12.57	25	4.53	20.9	11.91
CO2 (% vol)	6.28	6.33	15	4.54	12.62	8
THC (ppmv)	0.15	0.12	30	9.06	25.6	15.36



# Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged QA Calibration Records

Run U3-Oil-100%-3                      5/8/02      18:22:00      19:22:00

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
NOx (ppmv)	0.01	22.84	86.39	46.15	0.16	-1.29	0.05		
CO (ppmv)	0	9.14	25.81	15.25	-0.73	-0.03	0.03		
O2 (% vol)	0	4.53	20.89	11.93	0.01	0.04	-0.08		
CO2 (% vol)	0	4.54	12.6	7.99	0	0.16	0.07		
THC (ppmv)	-0.02	9.21	25.59	15.35	-0.5	0.03	0.03		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
NOx (ppmv)	0.2	44.84	0.21	45.15	0.2	-1	-0.01	-0.31	
CO (ppmv)	0.5	15.38	0.47	15.32	1.58	0.23	0.09	0.2	
O2 (% vol)	0.03	11.79	0.01	11.81	0.04	-0.49	0.07	-0.09	
CO2 (% vol)	0.02	7.94	0.02	7.93	0.09	-0.43	0.03	0.08	
THC (ppmv)	0.03	15.47	0.02	15.79	0.13	1.47	0.03	-1.07	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
NOx (ppmv)	50.42	51.80	100	23	85.1	46.2			
CO (ppmv)	1.08	0.61	30	8.92	25.8	15.26			
O2 (% vol)	12.43	12.55	25	4.53	20.9	11.91			
CO2 (% vol)	6.29	6.34	15	4.54	12.62	8			
THC (ppmv)	0.07	0.04	30	9.06	25.6	15.36			

# Instrumental Analyses Quality Assurance Data

**Date:** May 6, 2002  
**Company:** Tampa Electric Company  
**Facility:** Polk Power Station  
**Source ID:** Unit 3, a GE Frame 7FA Combustion Turbine  
**Location:** Mulberry, Polk County, Florida  
**Technicians:** LJB, RPO, SBB

## NO<sub>x</sub> Analyzer: NO<sub>2</sub> to NO Converter Efficiency Test - NG

NO<sub>x</sub> Calibration Gas: 8.60 ppmv  
 Diluent Gas: Air  
 Date: 5/6/02

	NO <sub>x</sub> conc. (ppmv)	% Decrease from Highest conc.	NO conc. (ppmv)
Highest NO <sub>x</sub> Concentration:	6.216		
Initial Concentration:	6.136	1.29	6.13
10 minute Concentration:	6.152	1.03	6.11
20 minute Concentration:	6.216	0.00	6.09
30 minute Concentration:	6.168	0.77	6.03
Lowest NO <sub>x</sub> Concentration:	6.136	1.29	

Converter efficiency criteria is less than 2% decrease from highest read value.

## NO<sub>x</sub> Analyzer: NO<sub>2</sub> to NO Converter Efficiency Test - Oil

NO<sub>x</sub> Calibration Gas: 46.20 ppmv  
 Diluent Gas: Air  
 Date: 5/8/02

	NO <sub>x</sub> conc. (ppmv)	% Decrease from Highest conc.	NO conc. (ppmv)
Highest NO <sub>x</sub> Concentration:	27.33		
Initial Concentration:	27.24	0.33	25.8
10 minute Concentration:	27.14	0.70	24.9
20 minute Concentration:	27.14	0.70	24.2
30 minute Concentration:	27.33	0.00	23.7
Lowest NO <sub>x</sub> Concentration:	27.13	0.73	

Converter efficiency criteria is less than 2% decrease from highest read value.

## Instrumental Sample System Leak Checks

Date	Run Number	Vacuum (inches Hg)	Leak Rate (inches Hg/min)	Pass
5/7/02	pre U3-NG-O <sub>2</sub> -Trav	23.2	0.4	yes
5/7/02	post U3-RA-9	22.4	0.5	yes
5/8/02	pre U3-Oil-O <sub>2</sub> -Trav	24.2	0.4	yes
5/8/02	post U3-Oil-100%-3	23.3	0.3	yes
5/9/02	pre U3-NG-50%-1	23.5	0.5	yes
5/9/02	post U3-NG-80%-3	23.9	0.3	yes

Leak check criteria less than 1.0" Hg Vac. Decline at greater than 15.0" Hg Vac.

NOx Converter Efficiency Test  
Unit 3  
Natural Gas Testing

Run Number	MODE	Date	Time	NOx (ppmv)
START NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:05:00	6.136
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:06:00	6.136
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:07:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:08:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:09:00	6.136
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:10:00	6.152
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:11:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:12:00	6.152
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:13:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:14:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:15:00	6.152
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:16:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:17:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:18:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:19:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:20:00	6.152
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:21:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:22:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:23:00	6.184
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:24:00	6.184
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:25:00	6.216
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:26:00	6.200
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:27:00	6.184
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:28:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:29:00	6.184
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:30:00	6.200
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:31:00	6.184
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:32:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:33:00	6.168
NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:34:00	6.166
END NOx Converter, Unit 3 (NG)	Total NOx	5/6/02	16:35:00	6.168

NOx Converter Efficiency Test  
Unit 3  
No. 2 Fuel Oil Testing

Run Number	MODE	Date	Time	NOx (ppmv)
START NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:37:01	27.24
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:38:01	27.23
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:39:01	27.24
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:40:01	27.24
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:41:01	27.24
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:42:01	27.24
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:43:01	27.14
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:44:01	27.14
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:45:01	27.13
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:46:01	27.14
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:47:01	27.14
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:48:01	27.24
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:49:01	27.13
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:50:01	27.13
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:51:01	27.14
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:52:00	27.14
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:53:00	27.14
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:54:00	27.13
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:55:00	27.13
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:56:00	27.14
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:57:00	27.14
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:58:00	27.13
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	6:59:00	27.13
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	7:00:00	27.13
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	7:01:00	27.23
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	7:02:00	27.13
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	7:03:00	27.23
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	7:04:00	27.23
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	7:05:00	27.23
NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	7:06:00	27.23
END NOx Converter, Unit 3 (Oil)	Total NOx	5/8/02	7:07:00	27.33

## Continuous Emission Analyzer Interference Response Tests

### Analyzer Interference Response Checks

(Frequency: Prior to initial use of sampling system or after alteration or modification.)

Test Date: March 4, 2002 Technician: LJB  
 Mobile Lab: T-10 Location: Gainesville, Florida

Analyzer	Manufacturer	Model	Serial Number	Detection Method/Comments
NO <sub>x</sub> Analyzer	TECO	42C	42CHL-69541-363	Chemiluminescence with Ozone
CO Analyzer	TECO	48C	48-51488-288	Infrared Absorption/GFC Detector
O <sub>2</sub> Analyzer	Servomex	1440	1420C/2647	Paramagnetic
CO <sub>2</sub> Analyzer	Servomex	1440	01415/2537	Infrared Absorption/ Solid State Detector
THC	JUM	3-300	9405393-33	Flame Ionization Detector

Interferrent Test Gases		Analyzer Response (ppmv or % as applicable)				
Type Gas	Conc.	NO <sub>x</sub> 0-25 ppmv	CO 0-50 ppmv	O <sub>2</sub> 0-25% vol	CO <sub>2</sub> 0-15% vol	THC 0-100 ppmv
CO/Methane in air	885/919	0.1 ppmv			0.00 %	
Propane in air	2000	0.1 ppmv	0.4 ppmv		0.03 %	
SO <sub>2</sub> in N <sub>2</sub>	4400	0.2 ppmv	-0.3 ppmv	0.00 %	0.00 %	0.0 ppmv
Air	dry instrument	< 0.1 ppmv	0.4 ppmv		0.03 %	0.6 ppmv
Nitrogen	pre-purified	0.0 ppmv	0.3 ppmv	0.00 %	0.00 %	0.4 ppmv
Air	UHC, CO free	0.0 ppmv	0.0 ppmv		0.01 %	0.0 ppmv
CO <sub>2</sub> / O <sub>2</sub>	4.54%/20.8%	< 0.1 ppmv	-0.2 ppmv			-0.2 ppmv
CO <sub>2</sub> / O <sub>2</sub>	8.004%/11.91%	< 0.1 ppmv	-0.4 ppmv			-0.3 ppmv
CO <sub>2</sub> / O <sub>2</sub>	12.62%/4.53%	< 0.1 ppmv	-0.6 ppmv			-0.3 ppmv
NO <sub>x</sub> in N <sub>2</sub>	1209		0.4 ppmv	0.18 %	0.03 %	0.0 ppmv

## Quality Assurance Report

### EPA Method 20 NO<sub>x</sub> and O<sub>2</sub> Response Time Test

Date: March 10, 2002

Technicians: LJB, JAS

As Applicable per the requirements of EPA Methods 3a, 7e, and 20

Cubix Mobile Unit #: T-10

#### Test Instrumentation

Analyzer	Make	Model	Serial Number	Detection Method
NO <sub>x</sub> Analyzer	Thermo Environmental	42C	42CHL-69541-363	Photodetection (photomultiplier) of a chemi-luminescent reaction of nitric oxide and ozone
O <sub>2</sub> Analyzer	Servomex	1440	1420C/2647	Paramagnetic detection

#### Test Conditions

Chart Speed 30 cm/minute  
 Data Logger 1-minute averages  
 Sample Line Vacuum 5 "Hg  
 Sample Manifold Pressure 5 psi  
 Analyzer Flow Meter Setting 7 mm  
 Gas Standard Pressure 5 psi  
 Sample System Configuration: 120 ft. Heat Trace, 100 ft. Heat Trace, and Minimum Contact Condensor

#### Response Time Test Data

Response Time (seconds to 95% of stable value)

	NO <sub>x</sub> (ppmv)	O <sub>2</sub> (% vol)
Zero Gas Concentration	0.00	0.00
Upscale Calibration Gas Concentration	12.26	20.80
Stack Gas Concentration (average values, values varied over test)	9.95	13.84
Analyzer Full Scale Span	15.00	25.00
<b>Upscale Response</b>		
Test # 1	73.0	39.0
Test # 2	80.0	45.0
Test # 3	69.0	45.0
Average Upscale Response	74.0	43.0
<b>Downscale Response</b>		
Test # 1	58.0	46.0
Test # 2	68.0	46.0
Test # 3	63.0	47.0
Average Downscale Response	63.0	46.3
<b>Minimum System Response Time (seconds)</b>	<b>74.0</b>	<b>seconds</b>
<b>Minimum Sampling Time Each Traverse Point</b>	<b>134.0</b>	<b>seconds</b>

**APPENDIX E:  
CALIBRATION CERTIFICATIONS**



# SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811  
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



## CERTIFICATE OF ANALYSIS

## EPA PROTOCOL MIXTURE PROCEDURE #: G1

CUSTOMER: Cubix Corporation  
SGI ORDER #: 0016012  
ITEM#: 6  
P.O.#: 2002014ROGER

CYLINDER #: CC-133035  
CYLINDER PRES: 2000 PSIG  
CGA OUTLET: 660

CERTIFICATION DATE: 1/28/2002  
EXPIRATION DATE: 1/28/2004

### CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Nitric Oxide	1/21/2002	5.070 ppm	5.05 ppm	+/- 1%
NOx	1/28/2002	5.028 ppm	5.05 ppm	Reference Value Only

BALANCE Nitrogen

PREVIOUS CERTIFICATION DATES: None

### REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Nitric Oxide	GMIS-1	CC-127534	15.12 ppm

### INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Nitric Oxide	Thermo 42C	42C-64942-345	Cheml	1/8/2002

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.  
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST: REX JOHNSON


DATE: 1/28/2002





# SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811  
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



## CERTIFICATE OF ANALYSIS

## EPA PROTOCOL MIXTURE PROCEDURE #: G1

CUSTOMER: Cubix Corporation  
SGI ORDER #: 0019339  
ITEM#: 1  
P.O.#: 2002179 T10LENO

CYLINDER #: CC-133286  
CYLINDER PRES: 2000 PSIG  
CGA OUTLET: 660

CERTIFICATION DATE: 4/2/2002  
EXPIRATION DATE: 4/2/2004

### CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Nitric Oxide	3/25/2002	8.616 ppm	8.60 ppm	+/- 1%
	4/2/2002	8.577 ppm		
NOx			8.60 ppm	Reference Value Only

BALANCE Nitrogen

PREVIOUS CERTIFICATION DATES: None

### REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Nitric Oxide	GMIS-1	CC-133063	19.86 ppm

### INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Nitric Oxide	Thermo 42C	42C-64942-345	Cheml	3/13/2002

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.  
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.


ANALYST: Fred Pikula  
FRED PIKULA

DATE: 4/2/2002



# SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811  
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



## CERTIFICATE OF ANALYSIS

## EPA PROTOCOL MIXTURE PROCEDURE # : G1

**CUSTOMER:** CUBIX c/o HAMAKUA ENERGY  
**SGI ORDER # :** 0012763  
**ITEM# :** 5  
**P.O.# :** 2001530 T10 TON

**CYLINDER # :** CC-133383  
**CYLINDER PRES:** 2000 PSIG  
**CGA OUTLET:** 660

**CERTIFICATION DATE:** 10/27/2001  
**EXPIRATION DATE:** 10/27/2003

### CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Nitric Oxide	10/16/2001	14.80 ppm	14.82 ppm	+/- 1%
	10/27/2001	14.84 ppm		
NOx			14.82 ppm	Reference Value Only

**BALANCE** Nitrogen

**PREVIOUS CERTIFICATION DATES:** None


### REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Nitric Oxide	GMIS-1	CC-131019	20.13 ppm

### INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Nitric Oxide	Thermo 42C	42C-64942-345	Cheml	10/10/2001

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.  
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.


**ANALYST:**   
REX JOHNSON

**DATE:** 10/27/2001



# SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811  
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



## CERTIFICATE OF ANALYSIS

## EPA PROTOCOL MIXTURE PROCEDURE #: G1

CUSTOMER: Cubix Corporation  
SGI ORDER #: 0003556  
ITEM#: 1  
P.O.#: 2001089 T10 LENO

CYLINDER #: CC126771  
CYLINDER PRES: 2000 PSIG  
CGA OUTLET: 660

CERTIFICATION DATE: 3/26/2001  
EXPIRATION DATE: 3/26/2003

### CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Nitric Oxide	3/19/2001	23.02 ppm	23.0 ppm	+/- 1%
	3/26/2001	23.05 ppm		
NOx			23.0 ppm	Reference Value Only

BALANCE Nitrogen

PREVIOUS CERTIFICATION DATES: None

### REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Nitric Oxide	NTRM-81684	CC65912	98.6 ppm

### INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Nitric Oxide	CAI-400-CLD	6L09004	Cheml	3/23/2001

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.  
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.


ANALYST: F.P.  
FRED PIKULA

DATE: 3/26/2001



# SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811  
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



## CERTIFICATE OF ANALYSIS

## EPA PROTOCOL MIXTURE PROCEDURE #: G1

**CUSTOMER:** CUBIX c/o HAMAKUA ENERGY  
**SGI ORDER # :** 0012763  
**ITEM# :** 7  
**P.O.# :** 2001530 T10 TON

**CYLINDER # :** CC-118596  
**CYLINDER PRES:** 2000 PSIG  
**CGA OUTLET:** 660

**CERTIFICATION DATE:** 10/24/2001  
**EXPIRATION DATE:** 10/24/2003

### CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Nitric Oxide	10/16/2001	46.45 ppm	46.2 ppm	+/- 1%
	10/24/2001	46.03 ppm		
NOx			46.2 ppm	Reference Value Only

**BALANCE** Nitrogen

**PREVIOUS CERTIFICATION DATES:** None


### REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Nitric Oxide	GMIS-1	CC-131206	86.6 ppm

### INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Nitric Oxide	CAI-400 CLD	6L 09004	Cheml	10/5/2001

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.  
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

**ANALYST:**   
REX JOHNSON


**DATE:** 10/24/2001





# SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811  
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



## CERTIFICATE OF ANALYSIS

## EPA PROTOCOL MIXTURE PROCEDURE # : G1

**CUSTOMER:** Cubix Corporation  
**SGI ORDER # :** 153396  
**ITEM# :** 2  
**P.O.# :** 2000131

**CYLINDER # :** CC63266  
**CYLINDER PRES:** 2000 PSIG  
**CGA OUTLET:** 590

**CERTIFICATION DATE:** 5/2/2000  
**EXPIRATION DATE:** 5/2/2003

### CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Monoxide	4/25/2000 5/2/2000	8.946 ppm 8.904 ppm	8.92 ppm	+/- 1%
Methane	5/2/2000	9.06 ppm	9.06 ppm	+/- 1%

**BALANCE** Air

**PREVIOUS CERTIFICATION DATES:** None

### REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Monoxide	GMIS-1	CC88476	10.04 ppm
Methane	GMIS-1	CC60179	50.10 ppm

### INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Monoxide	Nicolet 560	ADL9600109	FTIR	4/10/2000
Methane	H. Packard 6890	US00001434	GC - FID	5/2/2000

THIS STANDARD WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.  
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.


**ANALYST:** FRED PIKULA

**DATE:** 5/2/2000



# SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811  
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



## CERTIFICATE OF ANALYSIS

## EPA PROTOCOL MIXTURE

PROCEDURE #: G1

CUSTOMER: CUBIX c/o HAMAKUA ENERGY  
SGI ORDER #: 0012763  
ITEM#: 3  
P.O.#: 2001530 T10 TON

CYLINDER #: CC-113992  
CYLINDER PRES: 2000 PSIG  
CGA OUTLET: 590

CERTIFICATION DATE: 10/29/2001  
EXPIRATION DATE: 10/26/2004

### CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Monoxide	10/16/2001	15.23 ppm	15.26 ppm	+/- 1%
	10/26/2001	15.29 ppm		
Methane	10/29/2001	15.36 ppm	15.36 ppm	+/- 1%

BALANCE Air

PREVIOUS CERTIFICATION DATES: None

### REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Monoxide	GMIS-1	CC-109837	20.4 ppm
Methane	GMIS-1	CC60179	50.06 ppm

### INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Monoxide	Horiba VIA-510	570423011	NDIR	10/08/2001
Methane	H. Packard 6890	US00001434	GC - FID	10/08/2001

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.  
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.


ANALYST: TED NEEME

DATE: 10/29/2001



# SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811  
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



## CERTIFICATE OF ANALYSIS

## EPA PROTOCOL MIXTURE PROCEDURE # : G1

**CUSTOMER:** CUBIX c/o HAMAKUA ENERGY  
**SGI ORDER # :** 0012763  
**ITEM# :** 2  
**P.O.# :** 2001530 T10 TON

**CYLINDER # :** CC-88212  
**CYLINDER PRES:** 2000 PSIG  
**CGA OUTLET:** 590

**CERTIFICATION DATE:** 10/29/2001  
**EXPIRATION DATE:** 10/26/2004

### CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Monoxide	10/18/2001	25.9 ppm	25.8 ppm	+/- 1%
	10/26/2001	25.71 ppm		
Methane	10/29/2001	25.6 ppm	25.6 ppm	+/- 1%

**BALANCE** Air

**PREVIOUS CERTIFICATION DATES:** None

### REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Monoxide	NTRM-81679	CC-88447	97.4 ppm
Methane	GMS-1	CC60179	50.06 ppm

### INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Monoxide	Horiba VIA-510	570423011	NDIR	10/26/2001
Methane	H. Packard 6890	US00001434	GC - FID	10/08/2001

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.  
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

**ANALYST:** TED NEEME

**DATE:** 10/29/2001





# Scott Specialty Gases

## RATA CLASS

### Dual-Analyzed Calibration Standard

9810 BAY AREA BLVD, PASADENA, TX 77507

Phone: 281-474-5800

Fax: 281-474-5857

## CERTIFICATE OF ACCURACY: Interference Free <sup>TM</sup> Multi-Component EPA Protocol Gas

### Assay Laboratory

SCOTT SPECIALTY GASES  
9810 BAY AREA BLVD  
PASADENA, TX 77507

P.O. No.: G-1291  
Project No.: 04-85228-002

### Customer

CUBIX CORPORATION  
4536 NW 20TH DRIVE  
GAINESVILLE FL 32605



### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #G1; September, 1997.

Cylinder Number: ALM009152      Certification Date: 4/03/00      Exp. Date: 4/03/2003  
Cylinder Pressure\*\*\*: 1883 PSIG

### ANALYTICAL

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
CARBON DIOXIDE	12.62 %	+/- 1%	Direct NIST and NMI
OXYGEN	4.53 %	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol procedure G1, September 1997.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST or NMI standards.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM	1/01/03	ALM042032	13.96 %	CO2/N2
NTRM 2658	12/19/01	ALM031738	9.680 %	OXYGEN

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR System/8220A/AAB9400260	03/28/00	Scott Enhanced FTIR
MTI-A/M200/171109	03/21/00	GAS CHROMATOGRAPHY

### ANALYZER READINGS

(Z = Zero Gas    R = Reference Gas    T = Test Gas    r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

#### CARBON DIOXIDE

Date: 04/03/00	Response Unit: %	
Z1 = 0.0220	R1 = 13.956	T1 = 12.629
R2 = 13.966	Z2 = 0.0178	T2 = 12.617
Z3 = 0.0276	T3 = 12.620	R3 = 13.959
Avg. Concentration:	12.62	%



Concentration = A + Bx + Cx2 + Dx3 + Ex4	
r = 0.999990	
Constants:	A = 0.000000
B = 1.000000	C = 0.000000
D = 0.000000	E = 0.000000

#### OXYGEN

Date: 04/06/00	Response Unit: AREA	
Z1 = 114.00	R1 = 35455	T1 = 16619
R2 = 35183	Z2 = 141.00	T2 = 16552
Z3 = 118.00	T3 = 16573	R3 = 35179
Avg. Concentration:	4.530	%



Concentration = A + Bx + Cx2 + Dx3 + Ex4	
r = 0.99999418	
Constants:	A = -0.03442397
B = 0.000275952	C =
D =	E =

APPROVED BY:

John Hunnicutt



# Scott Specialty Gases

## RATA CLASS

Dual-Analyzed Calibration Standard

9810 BAY AREA BLVD, PASADENA, TX 77507

Phone: 281-474-5800

Fax: 281-474-5857

### CERTIFICATE OF ACCURACY: Interference Free <sup>TM</sup> Multi-Component EPA Protocol Gas

#### Assay Laboratory

SCOTT SPECIALTY GASES  
9810 BAY AREA BLVD  
PASADENA, TX 77507

P.O. No.: G-1291  
Project No.: 04-85228-001

#### Customer

CUBIX CORPORATION  
4536 NW 20TH DRIVE  
GAINESVILLE FL 32605



#### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #G1; September, 1997.

Cylinder Number: AAL17665 Certification Date: 4/10/00 Exp. Date: 4/10/2003  
Cylinder Pressure\*\*\*: 1945 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	8.004 %	+/- 1%	Direct NIST and NMI
OXYGEN	11.91 %	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

- \*\*\* Do not use when cylinder pressure is below 150 psig.
- \*\* Analytical accuracy is based on the requirements of EPA Protocol procedure G1, September 1997.
- Product certified as +/- 1% analytical accuracy is directly traceable to NIST or NMI standards.

#### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM	1/01/03	ALM016777	13.96 %	CO2/N2
NTRM 2658	1/02/01	ALM031726	9.680 %	OXYGEN

#### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR System/B220A/AA89400260	03/28/00	Scott Enhanced FTIR
MTI-A/M200/171109	03/21/00	GAS CHROMATOGRAPHY

#### ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

#### CARBON DIOXIDE

Date: 04/10/00	Response Unit: %
Z1 = 0.0142	R1 = 13.954 T1 = 8.0050
R2 = 13.972	Z2 = 0.0301 T2 = 8.0039
Z3 = 0.0231	T3 = 8.0034 R3 = 13.953
Avg. Concentration:	8.004 %

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>
r = 0.999990
Constants: A = 0.000000
B = 1.000000 C = 0.000000
D = 0.000000 E = 0.000000

#### OXYGEN

Date: 04/12/00	Response Unit: AREA
Z = 43.000	R1 = 35084. T1 = 43102.
R2 = 34965.	Z2 = 101.00 T2 = 43033.
Z3 = 91.000	T3 = 43023. R3 = 35009.
Avg. Concentration:	11.91 %

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>
r = 0.99999418
Constants: A = -0.03442397
B = 0.000275952 C =
D = E =


APPROVED BY:

John Hunnicutt



# SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811  
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



## CERTIFICATE OF ANALYSIS

## EPA PROTOCOL MIXTURE PROCEDURE #: G1

**CUSTOMER:** Cubix Corporation  
**SGI ORDER # :** 0016029  
**ITEM# :** 1  
**P.O.# :** 2002014 ROGER

**CYLINDER # :** CC-79844  
**CYLINDER PRES:** 2000 PSIG  
**CGA OUTLET:** 590

**CERTIFICATION DATE:** 1/22/2002  
**EXPIRATION DATE:** 1/22/2005

### CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Dioxide	1/22/2002	4.54 %	4.54 %	+/- 1%
Oxygen	1/22/2002	20.9 %	20.9 %	+/- 1%

**BALANCE** Nitrogen

**PREVIOUS CERTIFICATION DATES:** None

### REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Dioxide	GMS-1	CC-90832	9.98 %
Oxygen	NTRM-82659x	CC83917	22.8 %

### INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Dioxide	Horiba VIA-510	571417045	NDIR	1/15/2002
Oxygen	Horiba MPA-510	570694081	PM	1/9/2002

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.  
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

**ANALYST:** FRED PIKULA

**DATE:** 1/22/2002

# ALTIMETER TEST RECORD

This unit was tested and inspected IAW FAR Part 43,  
Appendix E, and is approved for return to service.

DATE: 3-8-02

WORK ORDER #: 3501

## SCALE ERROR

-1000	-15
0	0
+ 500	0
+1000	+10
+1500	0
+2000	+10
+3000	+5
+4000	0
+6000	-5
+8000	+5
+10,000	+15
+12,000	+20
+14,000	+20
+16,000	+15
+18,000	0
+20,000	-10
+22,000	
+25,000	
+30,000	
+35,000	
+40,000	
+45,000	
+50,000	

## BAROMETRIC SCALE ERROR TEST

28.10	0	30.50	+5
28.50	-5	30.90	0
29.00	0	30.99	0
29.50	0		
29.92	0		

## FRICTION TEST

1000	30	20,000	50
2000	30	25,000	
3000	30	30,000	
5000	30	35,000	
10,000	40	40,000	
15,000	45	50,000	

CASE LEAK TEST @ 18,000 0  
CASE LEAK TEST @ 1,200 0

HYSTERESIS TEST @ 50% 20  
HYSTERESIS TEST @ 40% 15

AFTER EFFECT 15

START PRESSURE 30.06

FINAL PRESSURE 30.06

SERIAL NUMBER 15924

INSPECTOR [Signature]

**TRAILER 10  
ALTIMETER/BAROMETER CALIBRATION SHEET**

BFG/C 9001

**BFGoodrich**  
Aerospace

817 Dessau Road  
Austin, Texas 78753  
512-251-3441  
FAX 512-990-1271

Component Overhaul & Repair

FAA Repair Station No. UZ2R232L

**CASTLEBERRY AERCOR  
Serviceable Part Tag**

COMPONENT Altimeter  
PART NO. 5934P-1A-83  
SERIAL NO. J5924  
MFG United Instr. WORK ORDER # V7071

Overhaul     Repair     Bench Check & Test     Other \_\_\_\_\_

The Aircraft Appliance identified above was overhauled, repaired, or bench tested (as per block marked) and inspected, in accordance with current Federal Aviation Administration Regulations, and is approved for return to service. Details of this component are on file at this repair station.

  
AUTHORIZED SIGNATURE

JAN 16 1995  
DATE

ALTIMETER SCALE ERROR					
PART NO. <u>5934P1A83</u>			SERIAL NO. <u>J5924</u>		
ALTIMETER PRESSURE					
TEST PT (FT)	INDICATOR READINGS AT + 25 °C	TEST PT (FT)	INDICATOR READINGS AT + 25 °C	TEST PT (FT)	INDICATOR READINGS AT + 25 °C
-1000	+5	8,000	+5	30,000	
0 0	0	10,000	+10	35,000	
500	0	12,000	+15	40,000	
1000	0	14,000	+15	45,000	
1500	0	16,000	+5	50,000	
2000	0	18,000	0	55,000	
3000	-5	20,000	-5	60,000	
4000	-10	22,000		70,000	
6000	-10	25,000		80,000	

# Certification

## Psychrometer Certificate

### COLE-PARMER® INSTRUMENT COMPANY

625 East Bunker, Vernon Hills IL•60061

Phone No.: 800-323-4340

Fax No.: 847-327-2929

Meter Under Test No. 03312-20

Serial Number: 57778

Catalog No. 17005-00

Received Condition: New

### NIST TRACEABLE REPORT OF CALIBRATION

#### Dry Bulb

#### Wet Bulb

Test Point °F	Reading °F	Deviation °F	Test Point °F	Reading °F	Deviation °F
32.00	32.0	0.0	32.00	32.0	0.0
59.94	60.0	0.1	59.94	60.0	0.1
100.07	100.0	-0.1	100.07	100.0	-0.1

Room Temperature: 21°C

Room Humidity: 38%

Instrument tolerance is: ±3% full-scale

Instrument is within tolerance.

Cole-Parmer Instrument Co. certifies that the calibration of the above unit used Procedure number MWI-17005-00 and equipment traceable to the National Institute of Standards and Technology (NIST), and this test was performed in accordance with ANSI/NC SL Z540-1.

### CALIBRATION STANDARDS

Hart Scientific Model No. 5614 platinum probe Serial No. 403541, 360810, 395508. Calibration due October 21, 2001.

Hart Scientific Model No. 850(C) Digital meter Serial numbers 4B185, 67609, 85307, 79014. Calibration due November 9, 2001.


Measurement Uncertainty = 0.08°C at k=2.

Listed uncertainties represent the best measurement uncertainty expressed at 95% confidence level.

CUSTOMER: Cubix Corp  
Certificate No. 3611876-00

Purchase Order No. 2001398

Calibrated by 321



Metrology Lab Tech

Calibration Date: September 14, 2001 Suggested re-calibration date: September 14, 2002

This certificate shall not be reproduced except in full, without the written approval of Cole Parmer Instrument Co.

**APPENDIX F:  
RECORDS OF LOGGED DATA  
ONE-MINUTE AVERAGES**

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-NG-O2-Trav, W Port	5/7/02	7:29:01	12.03		13.72	4.10		12.03		13.72	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:29:31	12.04		13.72	4.10		12.06		13.72	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:30:01	11.96		13.73	4.10		12.03		13.72	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:30:31	11.98		13.74	4.10		12.02		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:31:01	11.96		13.73	4.10		12.00		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:31:31	11.88		13.73	4.10		11.99		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:32:01	11.92		13.73	4.10		11.97		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:32:31	11.87		13.75	4.10		11.96		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:33:01	11.84		13.74	4.10		11.94		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:33:31	11.79		13.74	4.10		11.93		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:34:01	11.87		13.74	4.11		11.92		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:34:31	11.85		13.73	4.11		11.91		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:35:01	11.88		13.75	4.11		11.91		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:35:31	11.79		13.74	4.11		11.90		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:36:01	11.71		13.71	4.11		11.89		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:36:31	11.72		13.75	4.11		11.88		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:37:01	11.82		13.77	4.10		11.87		13.73	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:37:31	11.87		13.78	4.10		11.87		13.74	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:38:01	11.82		13.78	4.10		11.87		13.74	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:38:31	11.66		13.79	4.10		11.86		13.74	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:39:01	11.60		13.77	4.10		11.85		13.74	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:39:31	11.69		13.78	4.10		11.84		13.75	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:40:01	11.80		13.79	4.10		11.84		13.75	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:40:31	11.77		13.78	4.10		11.83		13.75	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:41:01	11.69		13.78	4.09		11.83		13.75	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:41:31	11.66		13.79	4.10		11.82		13.75	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:42:01	11.66		13.79	4.10		11.82		13.75	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:42:31	11.72		13.79	4.10		11.81		13.75	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:43:01	11.74		13.78	4.10		11.81		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:43:31	11.76		13.79	4.09		11.81		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:44:01	11.79		13.79	4.09		11.81		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:44:31	11.77		13.78	4.10		11.81		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:45:01	11.79		13.79	4.10		11.81		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:45:31	11.71		13.79	4.10		11.80		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:46:01	11.66		13.78	4.10		11.80		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:46:31	11.66		13.78	4.10		11.80		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:47:01	11.69		13.79	4.10		11.79		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:47:31	11.74		13.78	4.10		11.79		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:48:01	11.71		13.78	4.10		11.79		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:48:31	11.58		13.78	4.10		11.78		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:49:01	11.52		13.79	4.10		11.78		13.76	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:49:31	11.50		13.78	4.10		11.77		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:50:01	11.60		13.78	4.10		11.77		13.77	4.10	



## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-NG-O2-Trav, W Port	5/7/02	7:50:31	11.64		13.78	4.10		11.76		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:51:01	11.55		13.78	4.10		11.76		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:51:31	11.53		13.77	4.10		11.75		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:52:01	11.45		13.78	4.10		11.75		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:52:31	11.53		13.79	4.09		11.74		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:53:01	11.60		13.79	4.10		11.74		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:53:31	11.66		13.78	4.10		11.74		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:54:01	11.61		13.80	4.10		11.74		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:54:31	11.56		13.79	4.10		11.73		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:55:01	11.68		13.79	4.10		11.73		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:55:31	11.64		13.79	4.10		11.73		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:56:01	11.66		13.80	4.10		11.73		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:56:31	11.66		13.79	4.10		11.73		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:57:01	11.64		13.78	4.10		11.73		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:57:31	11.60		13.84	4.08		11.72		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:58:01	11.48		13.85	4.07		11.72		13.77	4.10	
Run U3-NG-O2-Trav, W Port	5/7/02	7:58:31	11.45		13.84	4.06		11.72		13.77	4.10	
END Run U3-NG-O2-Trav, W Port	5/7/02	7:59:01	11.42		13.84	4.07		11.71		13.78	4.10	

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-NG-O2-Trav, S Port	5/7/02	8:03:09	11.48		13.81	4.10		11.48		13.81	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:03:39	11.39		13.81	4.09		11.43		13.81	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:04:09	11.50		13.81	4.09		11.44		13.81	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:04:39	11.56		13.81	4.09		11.48		13.81	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:05:09	11.56		13.81	4.10		11.50		13.81	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:05:39	11.58		13.79	4.09		11.52		13.81	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:06:09	11.53		13.77	4.10		11.52		13.81	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:06:39	11.48		13.78	4.10		11.52		13.80	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:07:09	11.44		13.78	4.10		11.51		13.80	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:07:39	11.34		13.77	4.10		11.50		13.80	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:08:09	11.28		13.78	4.10		11.48		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:08:39	11.32		13.78	4.10		11.46		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:09:09	11.28		13.79	4.10		11.45		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:09:39	11.23		13.78	4.10		11.43		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:10:09	11.16		13.79	4.10		11.41		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:10:39	11.18		13.78	4.10		11.40		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:11:09	11.24		13.78	4.10		11.39		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:11:39	11.26		13.78	4.10		11.38		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:12:09	11.21		13.78	4.10		11.37		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:12:39	11.08		13.79	4.09		11.36		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:13:09	11.13		13.79	4.09		11.35		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:13:39	11.21		13.80	4.09		11.34		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:14:09	11.21		13.79	4.09		11.33		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:14:39	11.12		13.79	4.09		11.33		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:15:09	11.05		13.80	4.09		11.31		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:15:39	11.08		13.80	4.10		11.31		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:16:09	11.21		13.80	4.09		11.30		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:16:39	11.26		13.79	4.09		11.30		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:17:09	11.16		13.77	4.10		11.29		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:17:39	11.21		13.78	4.10		11.29		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:18:09	11.15		13.78	4.09		11.29		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:18:39	11.24		13.79	4.09		11.28		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:19:09	11.29		13.79	4.09		11.28		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:19:39	11.21		13.79	4.09		11.28		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:20:09	11.10		13.78	4.09		11.28		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:20:39	11.04		13.80	4.08		11.27		13.79	4.10	
Run U3-NG-O2-Trav, S Port	5/7/02	8:21:09	10.91		13.79	4.09		11.26		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:21:39	10.86		13.80	4.09		11.25		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:22:09	10.76		13.80	4.09		11.24		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:22:39	10.70		13.80	4.09		11.23		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:23:09	10.72		13.81	4.09		11.21		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:23:39	10.76		13.80	4.09		11.20		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:24:09	10.83		13.80	4.08		11.19		13.79	4.09	

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-NG-O2-Trav, S Port	5/7/02	8:24:39	10.83		13.80	4.09		11.19		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:25:09	10.81		13.81	4.09		11.18		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:25:39	10.78		13.81	4.08		11.17		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:26:09	10.78		13.80	4.09		11.16		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:26:39	10.72		13.80	4.09		11.15		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:27:09	10.73		13.80	4.09		11.14		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:27:39	10.70		13.80	4.08		11.13		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:28:09	10.68		13.80	4.09		11.12		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:28:39	10.72		13.80	4.09		11.12		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:29:09	10.78		13.81	4.08		11.11		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:29:39	10.84		13.81	4.09		11.10		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:30:09	10.76		13.80	4.09		11.10		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:30:39	10.80		13.81	4.08		11.09		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:31:09	10.81		13.81	4.08		11.09		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:31:39	10.83		13.82	4.08		11.08		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:32:09	10.89		13.83	4.08		11.08		13.79	4.09	
Run U3-NG-O2-Trav, S Port	5/7/02	8:32:39	10.78		13.81	4.08		11.08		13.79	4.09	
END Run U3-NG-O2-Trav, S Port	5/7/02	8:33:09	10.78		13.81	4.08		<b>11.07</b>		<b>13.79</b>	<b>4.09</b>	

# Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-NG-O2-Trav, E Port	5/7/02	8:41:10	11.37		13.79	4.10		11.37		13.79	4.10	
Run U3-NG-O2-Trav, E Port	5/7/02	8:41:40	11.37		13.78	4.09		11.38		13.78	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:42:10	11.42		13.78	4.09		11.38		13.78	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:42:40	11.47		13.79	4.09		11.40		13.78	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:43:10	11.53		13.78	4.09		11.42		13.78	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:43:40	11.47		13.79	4.09		11.44		13.78	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:44:10	11.37		13.79	4.09		11.44		13.78	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:44:40	11.29		13.80	4.09		11.43		13.78	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:45:10	11.18		13.80	4.09		11.40		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:45:40	11.15		13.79	4.09		11.38		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:46:10	11.21		13.79	4.10		11.36		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:46:40	11.15		13.80	4.09		11.34		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:47:09	11.08		13.80	4.09		11.32		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:47:40	10.97		13.79	4.09		11.30		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:48:10	10.96		13.80	4.09		11.28		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:48:40	11.00		13.81	4.09		11.25		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:49:10	11.07		13.80	4.09		11.24		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:49:40	11.05		13.81	4.09		11.23		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:50:10	10.91		13.81	4.09		11.22		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:50:40	10.92		13.81	4.08		11.20		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:51:10	10.97		13.80	4.08		11.19		13.79	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:51:40	11.02		13.82	4.08		11.18		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:52:10	11.00		13.80	4.08		11.17		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:52:40	10.94		13.81	4.08		11.16		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:53:10	10.94		13.82	4.09		11.15		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:53:40	11.00		13.80	4.08		11.15		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:54:10	11.08		13.82	4.08		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:54:40	11.16		13.81	4.09		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:55:10	11.15		13.81	4.08		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:55:40	11.12		13.81	4.08		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:56:10	11.16		13.81	4.08		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:56:40	11.20		13.81	4.09		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:57:10	11.15		13.81	4.08		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:57:40	11.12		13.81	4.08		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:58:10	11.02		13.81	4.08		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:58:40	11.02		13.81	4.09		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:59:10	11.04		13.81	4.08		11.14		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	8:59:40	11.12		13.80	4.08		11.13		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:00:10	11.12		13.80	4.09		11.13		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:00:40	11.07		13.81	4.08		11.13		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:01:10	10.99		13.82	4.08		11.13		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:01:40	11.04		13.80	4.08		11.13		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:02:10	11.10		13.81	4.08		11.13		13.80	4.09	

Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-NG-O2-Trav, E Port	5/7/02	9:02:40	11.07		13.81	4.08		11.12		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:03:10	10.99		13.80	4.08		11.12		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:03:40	11.00		13.82	4.08		11.12		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:04:10	10.96		13.81	4.08		11.12		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:04:40	10.84		13.81	4.08		11.11		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:05:10	10.84		13.82	4.08		11.11		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:05:40	10.99		13.82	4.08		11.10		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:06:10	11.02		13.81	4.08		11.10		13.80	4.09	
Run U3-NG-O2-Trav, E Port	5/7/02	9:06:40	11.00		13.82	4.08		11.10		13.80	4.08	
Run U3-NG-O2-Trav, E Port	5/7/02	9:07:10	11.02		13.83	4.07		11.10		13.80	4.08	
Run U3-NG-O2-Trav, E Port	5/7/02	9:07:40	11.00		13.83	4.08		11.10		13.80	4.08	
Run U3-NG-O2-Trav, E Port	5/7/02	9:08:10	11.08		13.83	4.07		11.09		13.81	4.08	
Run U3-NG-O2-Trav, E Port	5/7/02	9:08:40	11.12		13.83	4.07		11.09		13.81	4.08	
Run U3-NG-O2-Trav, E Port	5/7/02	9:09:10	11.10		13.83	4.07		11.09		13.81	4.08	
Run U3-NG-O2-Trav, E Port	5/7/02	9:09:40	10.97		13.93	4.02		11.09		13.81	4.08	
Run U3-NG-O2-Trav, E Port	5/7/02	9:10:10	10.83		13.89	4.04		11.09		13.81	4.08	
Run U3-NG-O2-Trav, E Port	5/7/02	9:10:40	10.86		13.85	4.06		11.09		13.81	4.08	
END Run U3-NG-O2-Trav, E Port	5/7/02	9:11:09	10.94		13.84	4.07		<b>11.08</b>		<b>13.81</b>	<b>4.08</b>	

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-NG-O2-Trav, N Port	5/7/02	9:14:01	11.45		13.82	4.07		11.45		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:14:31	11.40		13.82	4.07		11.43		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:15:01	11.36		13.81	4.07		11.41		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:15:31	11.28		13.82	4.07		11.38		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:16:01	11.34		13.82	4.07		11.36		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:16:30	11.36		13.82	4.07		11.36		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:17:00	11.36		13.83	4.07		11.36		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:17:30	11.28		13.82	4.07		11.36		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:18:00	11.16		13.82	4.07		11.34		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:18:30	11.08		13.82	4.07		11.32		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:19:00	11.21		13.83	4.07		11.30		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:19:30	11.26		13.82	4.07		11.29		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:20:00	11.23		13.82	4.07		11.29		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:20:30	11.21		13.83	4.07		11.29		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:21:00	11.16		13.83	4.08		11.28		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:21:30	11.20		13.83	4.07		11.27		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:22:00	11.28		13.83	4.08		11.27		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:22:30	11.32		13.83	4.08		11.27		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:23:00	11.24		13.82	4.08		11.27		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:23:30	11.15		13.83	4.08		11.27		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:24:00	11.18		13.82	4.08		11.26		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:24:30	11.26		13.81	4.08		11.26		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:25:00	11.29		13.82	4.08		11.26		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:25:30	11.42		13.83	4.07		11.27		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:26:00	11.32		13.82	4.08		11.27		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:26:30	11.24		13.82	4.07		11.27		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:27:00	11.36		13.82	4.08		11.27		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:27:30	11.52		13.82	4.08		11.28		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:28:00	11.47		13.82	4.07		11.29		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:28:30	11.32		13.83	4.08		11.29		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:29:00	11.32		13.84	4.08		11.29		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:29:30	11.50		13.82	4.08		11.29		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:30:00	11.52		13.83	4.08		11.30		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:30:30	11.52		13.84	4.08		11.31		13.82	4.07	
Run U3-NG-O2-Trav, N Port	5/7/02	9:31:00	11.39		13.82	4.08		11.31		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:31:30	11.34		13.84	4.08		11.31		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:32:00	11.34		13.84	4.08		11.31		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:32:30	11.37		13.84	4.08		11.31		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:33:00	11.39		13.84	4.07		11.32		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:33:30	11.42		13.85	4.07		11.32		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:34:00	11.34		13.84	4.08		11.32		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:34:30	11.34		13.85	4.08		11.32		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:34:59	11.50		13.83	4.07		11.32		13.82	4.08	

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-NG-O2-Trav, N Port	5/7/02	9:35:30	11.50		13.83	4.08		11.33		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:36:00	11.48		13.83	4.08		11.33		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:36:30	11.50		13.82	4.08		11.33		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:37:00	11.52		13.83	4.08		11.34		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:37:30	11.55		13.83	4.08		11.34		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:38:00	11.48		13.83	4.08		11.34		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:38:30	11.40		13.83	4.08		11.35		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:39:00	11.37		13.83	4.08		11.35		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:39:30	11.45		13.82	4.08		11.35		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:40:00	11.48		13.83	4.07		11.35		13.82	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:40:30	11.40		13.83	4.07		11.35		13.83	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:41:00	11.40		13.83	4.08		11.35		13.83	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:41:30	11.45		13.83	4.08		11.36		13.83	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:42:00	11.40		13.83	4.07		11.36		13.83	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:42:30	11.42		13.86	4.06		11.36		13.83	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:43:00	11.44		13.88	4.05		11.36		13.83	4.08	
Run U3-NG-O2-Trav, N Port	5/7/02	9:43:30	11.40		13.89	4.05		11.36		13.83	4.08	
END Run U3-NG-O2-Trav, N Port	5/7/02	9:44:00	11.34		13.89	4.04		11.36		13.83	4.07	

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-100%-1/U3-RA-1	5/7/02	10:17:01	9.53	0.42	13.64	4.18	0.98	9.53	0.42	13.64	4.18	0.98
Run U3-100%-1/U3-RA-1	5/7/02	10:18:01	9.53	0.42	13.64	4.18	0.94	9.54	0.41	13.64	4.18	0.99
Run U3-100%-1/U3-RA-1	5/7/02	10:19:00	9.52	0.36	13.65	4.18	0.83	9.54	0.39	13.64	4.18	0.92
Run U3-100%-1/U3-RA-1	5/7/02	10:20:00	9.44	0.36	13.67	4.18	0.78	9.51	0.38	13.65	4.18	0.88
Run U3-100%-1/U3-RA-1	5/7/02	10:21:00	9.45	0.33	13.63	4.18	0.73	9.50	0.37	13.65	4.18	0.85
Run U3-100%-1/U3-RA-1	5/7/02	10:22:00	9.40	0.30	13.63	4.19	0.71	9.48	0.36	13.64	4.18	0.83
Run U3-100%-1/U3-RA-1	5/7/02	10:23:00	9.37	0.33	13.62	4.19	0.70	9.47	0.36	13.64	4.18	0.81
Run U3-100%-1/U3-RA-1	5/7/02	10:24:00	9.34	0.30	13.63	4.18	0.66	9.45	0.35	13.64	4.18	0.79
Run U3-100%-1/U3-RA-1	5/7/02	10:25:00	9.36	0.30	13.63	4.18	0.69	9.43	0.35	13.64	4.18	0.77
Run U3-100%-1/U3-RA-1	5/7/02	10:26:00	9.26	0.33	13.63	4.19	0.65	9.42	0.34	13.64	4.18	0.76
Run U3-100%-1/U3-RA-1	5/7/02	10:27:00	9.18	0.30	13.64	4.19	0.63	9.40	0.34	13.64	4.18	0.75
Run U3-100%-1/U3-RA-1	5/7/02	10:28:00	9.18	0.30	13.64	4.19	0.60	9.38	0.33	13.64	4.19	0.74
Run U3-100%-1/U3-RA-1	5/7/02	10:29:00	9.16	0.30	13.64	4.18	0.58	9.37	0.33	13.64	4.19	0.72
Run U3-100%-1/U3-RA-1	5/7/02	10:30:00	9.16	0.33	13.64	4.18	0.58	9.35	0.33	13.64	4.19	0.71
Run U3-100%-1/U3-RA-1	5/7/02	10:31:00	9.18	0.30	13.64	4.19	0.58	9.34	0.33	13.64	4.19	0.70
Run U3-100%-1/U3-RA-1	5/7/02	10:32:00	9.15	0.30	13.65	4.19	0.58	9.33	0.33	13.64	4.19	0.70
Run U3-100%-1/U3-RA-1	5/7/02	10:33:00	9.10	0.30	13.65	4.18	0.57	9.31	0.32	13.64	4.19	0.69
Run U3-100%-1/U3-RA-1	5/7/02	10:34:00	8.97	0.30	13.64	4.18	0.56	9.30	0.32	13.64	4.19	0.68
Run U3-100%-1/U3-RA-1	5/7/02	10:35:00	9.02	0.33	13.65	4.19	0.55	9.28	0.32	13.64	4.19	0.68
Run U3-100%-1/U3-RA-1	5/7/02	10:36:00	9.05	0.33	13.65	4.18	0.55	9.27	0.32	13.64	4.19	0.67
Run U3-100%-1/U3-RA-1	5/7/02	10:37:00	9.07	0.33	13.64	4.18	0.55	9.26	0.32	13.64	4.18	0.66
Run U3-100%-1/U3-RA-1	5/7/02	10:38:00	9.16	0.30	13.65	4.18	0.55	9.25	0.32	13.64	4.18	0.66
Run U3-100%-1/U3-RA-1	5/7/02	10:39:00	9.15	0.30	13.65	4.19	0.58	9.25	0.32	13.64	4.18	0.65
Run U3-100%-1/U3-RA-1	5/7/02	10:40:00	9.18	0.36	13.65	4.18	0.55	9.25	0.32	13.64	4.18	0.65
Run U3-100%-1/U3-RA-1	5/7/02	10:41:00	9.12	0.33	13.65	4.18	0.54	9.24	0.32	13.64	4.18	0.65
Run U3-100%-1/U3-RA-1	5/7/02	10:42:00	9.10	0.36	13.65	4.18	0.53	9.24	0.32	13.64	4.18	0.64
Run U3-100%-1/U3-RA-1	5/7/02	10:43:00	9.11	0.36	13.66	4.18	0.53	9.23	0.32	13.64	4.18	0.64
Run U3-100%-1/U3-RA-1	5/7/02	10:44:00	9.13	0.32	13.67	4.17	0.51	9.23	0.33	13.64	4.18	0.63
Run U3-100%-1/U3-RA-1	5/7/02	10:45:00	9.15	0.36	13.67	4.17	0.49	9.22	0.33	13.64	4.18	0.63
Run U3-100%-1/U3-RA-1	5/7/02	10:46:00	9.16	0.36	13.67	4.17	0.48	9.22	0.33	13.64	4.18	0.62
Run U3-100%-1/U3-RA-1	5/7/02	10:47:00	9.12	0.39	13.67	4.17	0.47	9.22	0.33	13.64	4.18	0.62
Run U3-100%-1/U3-RA-1	5/7/02	10:48:00	9.16	0.36	13.67	4.17	0.48	9.22	0.33	13.65	4.18	0.61
Run U3-100%-1/U3-RA-1	5/7/02	10:49:00	9.15	0.39	13.67	4.16	0.46	9.21	0.33	13.65	4.18	0.61
Run U3-100%-1/U3-RA-1	5/7/02	10:50:00	9.15	0.39	13.67	4.17	0.47	9.21	0.33	13.65	4.18	0.61
Run U3-100%-1/U3-RA-1	5/7/02	10:51:00	9.21	0.45	13.67	4.17	0.46	9.21	0.34	13.65	4.18	0.60
Run U3-100%-1/U3-RA-1	5/7/02	10:52:00	9.20	0.42	13.67	4.17	0.49	9.21	0.34	13.65	4.18	0.60
Run U3-100%-1/U3-RA-1	5/7/02	10:53:00	9.24	0.42	13.68	4.17	0.47	9.21	0.34	13.65	4.18	0.59
Run U3-100%-1/U3-RA-1	5/7/02	10:54:00	9.26	0.42	13.66	4.18	0.51	9.21	0.34	13.65	4.18	0.59
Run U3-100%-1/U3-RA-1	5/7/02	10:55:00	9.26	0.42	13.66	4.18	0.53	9.21	0.35	13.65	4.18	0.59
Run U3-100%-1/U3-RA-1	5/7/02	10:56:00	9.24	0.45	13.65	4.17	0.48	9.21	0.35	13.65	4.18	0.59
Run U3-100%-1/U3-RA-1	5/7/02	10:57:00	9.31	0.45	13.66	4.17	0.47	9.22	0.35	13.65	4.18	0.58
Run U3-100%-1/U3-RA-1	5/7/02	10:58:00	9.26	0.48	13.67	4.17	0.48	9.22	0.35	13.65	4.18	0.58
Run U3-100%-1/U3-RA-1	5/7/02	10:59:00	9.20	0.51	13.67	4.17	0.49	9.22	0.36	13.65	4.18	0.58



## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-100%-1/U3-RA-1	5/7/02	11:00:00	9.16	0.48	13.67	4.17	0.48	9.22	0.36	13.65	4.18	0.58
Run U3-100%-1/U3-RA-1	5/7/02	11:01:00	9.15	0.48	13.68	4.16	0.48	9.21	0.36	13.65	4.18	0.57
Run U3-100%-1/U3-RA-1	5/7/02	11:02:00	9.20	0.48	13.68	4.16	0.46	9.21	0.36	13.65	4.18	0.57
Run U3-100%-1/U3-RA-1	5/7/02	11:03:00	9.18	0.51	13.67	4.16	0.46	9.21	0.37	13.65	4.18	0.57
Run U3-100%-1/U3-RA-1	5/7/02	11:04:00	9.19	0.51	13.67	4.17	0.44	9.21	0.37	13.65	4.18	0.57
Run U3-100%-1/U3-RA-1	5/7/02	11:05:00	9.18	0.54	13.70	4.17	0.44	9.21	0.37	13.65	4.18	0.56
Run U3-100%-1/U3-RA-1	5/7/02	11:06:00	9.21	0.57	13.67	4.17	0.43	9.21	0.38	13.65	4.18	0.56
Run U3-100%-1/U3-RA-1	5/7/02	11:07:00	9.21	0.57	13.69	4.17	0.44	9.21	0.38	13.65	4.18	0.56
Run U3-100%-1/U3-RA-1	5/7/02	11:08:00	9.26	0.57	13.67	4.17	0.45	9.21	0.39	13.65	4.18	0.56
Run U3-100%-1/U3-RA-1	5/7/02	11:09:00	9.26	0.57	13.67	4.17	0.42	9.21	0.39	13.65	4.18	0.55
Run U3-100%-1/U3-RA-1	5/7/02	11:10:00	9.21	0.57	13.68	4.17	0.44	9.21	0.39	13.66	4.18	0.55
Run U3-100%-1/U3-RA-1	5/7/02	11:11:00	9.27	0.57	13.66	4.17	0.41	9.21	0.40	13.66	4.18	0.55
Run U3-100%-1/U3-RA-1	5/7/02	11:12:00	9.27	0.60	13.67	4.17	0.40	9.21	0.40	13.66	4.18	0.55
Run U3-100%-1/U3-RA-1	5/7/02	11:13:00	9.29	0.63	13.68	4.16	0.41	9.22	0.40	13.66	4.18	0.54
Run U3-100%-1/U3-RA-1	5/7/02	11:14:00	9.26	0.63	13.69	4.16	0.40	9.22	0.41	13.66	4.18	0.54
Run U3-100%-1/U3-RA-1	5/7/02	11:15:00	9.18	0.63	13.69	4.16	0.40	9.22	0.41	13.66	4.18	0.54
Run U3-100%-1/U3-RA-1	5/7/02	11:16:00	9.16	0.63	13.68	4.16	0.39	9.22	0.41	13.66	4.18	0.54
END Run U3-100%-1/U3-RA-1	5/7/02	11:17:00	9.16	0.63	13.67	4.16	0.40	9.22	0.42	13.66	4.18	0.53

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-100%-2/U3-RA-2	5/7/02	11:30:06	9.24	0.27	13.62	4.13	1.00	9.24	0.27	13.62	4.13	1.00
Run U3-100%-2/U3-RA-2	5/7/02	11:31:06	9.16	0.27	13.64	4.14	0.89	9.19	0.26	13.63	4.14	0.92
Run U3-100%-2/U3-RA-2	5/7/02	11:32:06	9.13	0.24	13.63	4.15	0.79	9.17	0.26	13.63	4.14	0.89
Run U3-100%-2/U3-RA-2	5/7/02	11:33:06	9.21	0.27	13.64	4.15	0.75	9.17	0.25	13.63	4.15	0.85
Run U3-100%-2/U3-RA-2	5/7/02	11:34:06	9.23	0.24	13.64	4.16	0.72	9.18	0.25	13.64	4.15	0.82
Run U3-100%-2/U3-RA-2	5/7/02	11:35:06	9.28	0.24	13.64	4.16	0.68	9.19	0.25	13.64	4.15	0.80
Run U3-100%-2/U3-RA-2	5/7/02	11:36:06	9.26	0.27	13.63	4.16	0.63	9.21	0.25	13.64	4.15	0.77
Run U3-100%-2/U3-RA-2	5/7/02	11:37:06	9.29	0.24	13.62	4.16	0.62	9.22	0.25	13.63	4.15	0.75
Run U3-100%-2/U3-RA-2	5/7/02	11:38:06	9.31	0.24	13.63	4.16	0.74	9.23	0.25	13.63	4.15	0.74
Run U3-100%-2/U3-RA-2	5/7/02	11:39:06	9.20	0.24	13.62	4.16	0.65	9.23	0.25	13.63	4.15	0.74
Run U3-100%-2/U3-RA-2	5/7/02	11:40:06	9.13	0.27	13.64	4.16	0.60	9.22	0.25	13.63	4.15	0.73
Run U3-100%-2/U3-RA-2	5/7/02	11:41:06	9.21	0.27	13.63	4.17	0.61	9.22	0.25	13.63	4.15	0.72
Run U3-100%-2/U3-RA-2	5/7/02	11:42:06	9.24	0.27	13.63	4.16	0.61	9.22	0.25	13.63	4.16	0.71
Run U3-100%-2/U3-RA-2	5/7/02	11:43:06	9.23	0.24	13.64	4.16	0.61	9.22	0.25	13.63	4.16	0.70
Run U3-100%-2/U3-RA-2	5/7/02	11:44:06	9.19	0.27	13.64	4.16	0.63	9.22	0.25	13.63	4.16	0.69
Run U3-100%-2/U3-RA-2	5/7/02	11:45:06	9.18	0.27	13.64	4.16	0.60	9.22	0.25	13.63	4.16	0.69
Run U3-100%-2/U3-RA-2	5/7/02	11:46:06	9.10	0.27	13.64	4.16	0.59	9.21	0.25	13.63	4.16	0.68
Run U3-100%-2/U3-RA-2	5/7/02	11:47:06	9.02	0.27	13.64	4.16	0.59	9.20	0.26	13.63	4.16	0.68
Run U3-100%-2/U3-RA-2	5/7/02	11:48:06	9.08	0.26	13.64	4.16	0.60	9.19	0.26	13.63	4.16	0.67
Run U3-100%-2/U3-RA-2	5/7/02	11:49:06	9.10	0.30	13.63	4.16	0.62	9.19	0.26	13.63	4.16	0.67
Run U3-100%-2/U3-RA-2	5/7/02	11:50:06	9.10	0.30	13.64	4.16	0.62	9.19	0.26	13.63	4.16	0.67
Run U3-100%-2/U3-RA-2	5/7/02	11:51:05	9.13	0.29	13.64	4.16	0.61	9.18	0.26	13.63	4.16	0.67
Run U3-100%-2/U3-RA-2	5/7/02	11:52:05	9.02	0.33	13.65	4.16	0.64	9.18	0.27	13.63	4.16	0.66
Run U3-100%-2/U3-RA-2	5/7/02	11:53:05	9.13	0.33	13.64	4.16	0.72	9.18	0.27	13.63	4.16	0.66
Run U3-100%-2/U3-RA-2	5/7/02	11:54:05	9.13	0.33	13.64	4.16	0.65	9.17	0.27	13.63	4.16	0.66
Run U3-100%-2/U3-RA-2	5/7/02	11:55:05	9.10	0.36	13.63	4.16	0.64	9.17	0.27	13.63	4.16	0.66
Run U3-100%-2/U3-RA-2	5/7/02	11:56:05	9.18	0.33	13.65	4.16	0.65	9.17	0.28	13.64	4.16	0.66
Run U3-100%-2/U3-RA-2	5/7/02	11:57:05	9.28	0.36	13.65	4.16	0.62	9.17	0.28	13.64	4.16	0.66
Run U3-100%-2/U3-RA-2	5/7/02	11:58:05	9.23	0.33	13.65	4.16	0.61	9.17	0.28	13.64	4.16	0.66
Run U3-100%-2/U3-RA-2	5/7/02	11:59:05	9.13	0.36	13.65	4.15	0.62	9.17	0.28	13.64	4.16	0.66
Run U3-100%-2/U3-RA-2	5/7/02	12:00:05	9.05	0.36	13.66	4.16	0.56	9.17	0.28	13.64	4.16	0.65
Run U3-100%-2/U3-RA-2	5/7/02	12:01:05	9.05	0.35	13.66	4.15	0.56	9.17	0.29	13.64	4.16	0.65
Run U3-100%-2/U3-RA-2	5/7/02	12:02:05	8.97	0.39	13.66	4.15	0.55	9.16	0.29	13.64	4.16	0.65
Run U3-100%-2/U3-RA-2	5/7/02	12:03:05	8.99	0.39	13.66	4.15	0.54	9.16	0.29	13.64	4.16	0.65
Run U3-100%-2/U3-RA-2	5/7/02	12:04:05	9.00	0.42	13.65	4.16	0.54	9.15	0.30	13.64	4.16	0.64
Run U3-100%-2/U3-RA-2	5/7/02	12:05:05	8.97	0.42	13.65	4.15	0.52	9.14	0.30	13.64	4.16	0.64
Run U3-100%-2/U3-RA-2	5/7/02	12:06:05	9.03	0.42	13.66	4.16	0.52	9.14	0.30	13.64	4.16	0.64
Run U3-100%-2/U3-RA-2	5/7/02	12:07:05	9.05	0.42	13.65	4.15	0.49	9.14	0.31	13.64	4.16	0.63
Run U3-100%-2/U3-RA-2	5/7/02	12:08:05	9.05	0.42	13.66	4.15	0.51	9.14	0.31	13.64	4.16	0.63
Run U3-100%-2/U3-RA-2	5/7/02	12:09:05	9.07	0.41	13.65	4.15	0.48	9.13	0.31	13.64	4.16	0.63
Run U3-100%-2/U3-RA-2	5/7/02	12:10:05	9.08	0.45	13.65	4.16	0.47	9.13	0.31	13.64	4.16	0.62
Run U3-100%-2/U3-RA-2	5/7/02	12:11:05	9.13	0.45	13.65	4.16	0.46	9.13	0.32	13.64	4.16	0.62
Run U3-100%-2/U3-RA-2	5/7/02	12:12:05	9.18	0.45	13.65	4.15	0.45	9.13	0.32	13.64	4.16	0.61

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-100%-2/U3-RA-2	5/7/02	12:13:05	9.13	0.45	13.65	4.15	0.46	9.13	0.32	13.64	4.16	0.61
Run U3-100%-2/U3-RA-2	5/7/02	12:14:05	9.11	0.45	13.65	4.16	0.45	9.13	0.33	13.64	4.16	0.61
Run U3-100%-2/U3-RA-2	5/7/02	12:15:05	9.05	0.45	13.64	4.16	0.44	9.13	0.33	13.64	4.16	0.60
Run U3-100%-2/U3-RA-2	5/7/02	12:16:05	9.02	0.48	13.66	4.15	0.43	9.13	0.33	13.64	4.16	0.60
Run U3-100%-2/U3-RA-2	5/7/02	12:17:05	9.03	0.44	13.65	4.15	0.44	9.13	0.33	13.64	4.16	0.60
Run U3-100%-2/U3-RA-2	5/7/02	12:18:05	9.02	0.51	13.65	4.15	0.44	9.13	0.34	13.64	4.16	0.59
Run U3-100%-2/U3-RA-2	5/7/02	12:19:05	9.05	0.54	13.66	4.14	0.43	9.12	0.34	13.64	4.16	0.59
Run U3-100%-2/U3-RA-2	5/7/02	12:20:05	9.08	0.51	13.66	4.15	0.42	9.12	0.34	13.64	4.16	0.59
Run U3-100%-2/U3-RA-2	5/7/02	12:21:05	9.10	0.50	13.65	4.15	0.45	9.12	0.35	13.64	4.16	0.58
Run U3-100%-2/U3-RA-2	5/7/02	12:22:05	9.10	0.53	13.65	4.15	0.46	9.12	0.35	13.64	4.16	0.58
Run U3-100%-2/U3-RA-2	5/7/02	12:23:04	9.13	0.54	13.65	4.15	0.48	9.12	0.35	13.64	4.16	0.58
Run U3-100%-2/U3-RA-2	5/7/02	12:24:05	9.13	0.51	13.64	4.15	0.48	9.12	0.36	13.64	4.15	0.58
Run U3-100%-2/U3-RA-2	5/7/02	12:25:05	9.11	0.60	13.63	4.15	0.48	9.12	0.36	13.64	4.15	0.58
Run U3-100%-2/U3-RA-2	5/7/02	12:26:05	9.08	0.60	13.63	4.15	0.49	9.12	0.37	13.64	4.15	0.57
Run U3-100%-2/U3-RA-2	5/7/02	12:27:05	9.15	0.60	13.64	4.15	0.52	9.12	0.37	13.64	4.15	0.57
Run U3-100%-2/U3-RA-2	5/7/02	12:28:05	9.16	0.60	13.66	4.16	0.51	9.12	0.37	13.64	4.15	0.57
Run U3-100%-2/U3-RA-2	5/7/02	12:29:05	9.16	0.60	13.66	4.16	0.53	9.12	0.38	13.64	4.15	0.57
END Run U3-100%-2/U3-RA-2	5/7/02	12:30:05	9.05	0.65	13.66	4.15	0.52	9.12	0.38	13.64	4.15	0.57

# Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-100%-3/U3-RA-3	5/7/02	12:47:01	9.10	0.27	13.64	4.15	0.86	9.10	0.27	13.64	4.15	0.86
Run U3-100%-3/U3-RA-3	5/7/02	12:48:01	9.05	0.27	13.64	4.15	0.83	9.07	0.27	13.64	4.15	0.85
Run U3-100%-3/U3-RA-3	5/7/02	12:49:01	8.99	0.24	13.66	4.14	0.78	9.04	0.26	13.65	4.14	0.83
Run U3-100%-3/U3-RA-3	5/7/02	12:50:01	9.08	0.24	13.66	4.14	0.77	9.04	0.26	13.65	4.14	0.81
Run U3-100%-3/U3-RA-3	5/7/02	12:51:01	9.05	0.24	13.65	4.14	0.73	9.05	0.25	13.65	4.14	0.80
Run U3-100%-3/U3-RA-3	5/7/02	12:52:01	9.10	0.24	13.64	4.14	0.85	9.06	0.25	13.65	4.14	0.80
Run U3-100%-3/U3-RA-3	5/7/02	12:53:01	9.11	0.27	13.64	4.14	0.80	9.07	0.25	13.65	4.14	0.80
Run U3-100%-3/U3-RA-3	5/7/02	12:54:01	9.10	0.23	13.65	4.14	0.66	9.07	0.25	13.65	4.14	0.79
Run U3-100%-3/U3-RA-3	5/7/02	12:55:01	9.03	0.24	13.66	4.14	0.71	9.07	0.25	13.65	4.14	0.77
Run U3-100%-3/U3-RA-3	5/7/02	12:56:01	8.99	0.24	13.64	4.15	0.63	9.06	0.25	13.65	4.14	0.76
Run U3-100%-3/U3-RA-3	5/7/02	12:57:01	8.94	0.27	13.66	4.14	0.62	9.05	0.25	13.65	4.14	0.75
Run U3-100%-3/U3-RA-3	5/7/02	12:58:01	8.89	0.27	13.65	4.15	0.60	9.04	0.25	13.65	4.14	0.74
Run U3-100%-3/U3-RA-3	5/7/02	12:59:01	8.91	0.23	13.66	4.14	0.59	9.02	0.25	13.65	4.14	0.72
Run U3-100%-3/U3-RA-3	5/7/02	13:00:01	8.95	0.27	13.65	4.15	0.57	9.02	0.25	13.65	4.14	0.71
Run U3-100%-3/U3-RA-3	5/7/02	13:01:01	8.97	0.24	13.64	4.15	0.55	9.01	0.25	13.65	4.14	0.70
Run U3-100%-3/U3-RA-3	5/7/02	13:02:01	9.03	0.27	13.65	4.15	0.52	9.01	0.25	13.65	4.14	0.69
Run U3-100%-3/U3-RA-3	5/7/02	13:03:01	9.07	0.27	13.65	4.15	0.51	9.01	0.25	13.65	4.14	0.68
Run U3-100%-3/U3-RA-3	5/7/02	13:04:01	9.02	0.26	13.65	4.15	0.47	9.02	0.25	13.65	4.14	0.67
Run U3-100%-3/U3-RA-3	5/7/02	13:05:01	9.07	0.30	13.64	4.15	0.46	9.02	0.25	13.65	4.15	0.66
Run U3-100%-3/U3-RA-3	5/7/02	13:06:01	9.08	0.27	13.65	4.15	0.42	9.02	0.26	13.65	4.15	0.65
Run U3-100%-3/U3-RA-3	5/7/02	13:07:01	9.11	0.26	13.64	4.16	0.41	9.03	0.26	13.65	4.15	0.64
Run U3-100%-3/U3-RA-3	5/7/02	13:08:01	9.13	0.30	13.65	4.15	0.39	9.03	0.26	13.65	4.15	0.62
Run U3-100%-3/U3-RA-3	5/7/02	13:09:01	9.11	0.27	13.66	4.14	0.38	9.03	0.26	13.65	4.15	0.61
Run U3-100%-3/U3-RA-3	5/7/02	13:10:01	9.04	0.29	13.66	4.14	0.45	9.04	0.26	13.65	4.15	0.60
Run U3-100%-3/U3-RA-3	5/7/02	13:11:01	8.99	0.26	13.66	4.14	0.38	9.04	0.26	13.65	4.15	0.60
Run U3-100%-3/U3-RA-3	5/7/02	13:12:01	8.95	0.29	13.67	4.14	0.37	9.03	0.26	13.65	4.15	0.59
Run U3-100%-3/U3-RA-3	5/7/02	13:13:01	8.92	0.33	13.66	4.14	0.35	9.03	0.26	13.65	4.15	0.58
Run U3-100%-3/U3-RA-3	5/7/02	13:14:01	8.95	0.33	13.66	4.14	0.37	9.03	0.27	13.65	4.15	0.57
Run U3-100%-3/U3-RA-3	5/7/02	13:15:01	8.99	0.29	13.65	4.15	0.36	9.02	0.27	13.65	4.15	0.56
Run U3-100%-3/U3-RA-3	5/7/02	13:16:01	8.99	0.29	13.66	4.14	0.38	9.02	0.27	13.65	4.14	0.56
Run U3-100%-3/U3-RA-3	5/7/02	13:17:01	9.03	0.32	13.65	4.14	0.40	9.02	0.27	13.65	4.14	0.55
Run U3-100%-3/U3-RA-3	5/7/02	13:18:01	9.03	0.29	13.67	4.15	0.40	9.02	0.27	13.65	4.14	0.55
Run U3-100%-3/U3-RA-3	5/7/02	13:19:01	9.07	0.35	13.65	4.14	0.40	9.02	0.27	13.65	4.14	0.54
Run U3-100%-3/U3-RA-3	5/7/02	13:20:01	9.07	0.36	13.64	4.15	0.41	9.02	0.28	13.65	4.14	0.54
Run U3-100%-3/U3-RA-3	5/7/02	13:21:01	9.10	0.39	13.65	4.14	0.39	9.03	0.28	13.65	4.14	0.53
Run U3-100%-3/U3-RA-3	5/7/02	13:22:01	9.07	0.39	13.65	4.14	0.41	9.03	0.28	13.65	4.14	0.53
Run U3-100%-3/U3-RA-3	5/7/02	13:23:01	9.08	0.39	13.65	4.15	0.39	9.03	0.29	13.65	4.14	0.53
Run U3-100%-3/U3-RA-3	5/7/02	13:24:01	9.11	0.39	13.65	4.14	0.39	9.03	0.29	13.65	4.14	0.52
Run U3-100%-3/U3-RA-3	5/7/02	13:25:00	9.06	0.38	13.66	4.14	0.39	9.03	0.29	13.65	4.14	0.52
Run U3-100%-3/U3-RA-3	5/7/02	13:26:00	9.00	0.39	13.66	4.14	0.37	9.03	0.29	13.65	4.14	0.51
Run U3-100%-3/U3-RA-3	5/7/02	13:27:00	8.95	0.45	13.66	4.13	0.40	9.03	0.30	13.65	4.14	0.51
Run U3-100%-3/U3-RA-3	5/7/02	13:28:00	8.97	0.45	13.67	4.14	0.36	9.03	0.30	13.65	4.14	0.51
Run U3-100%-3/U3-RA-3	5/7/02	13:29:00	8.92	0.48	13.66	4.14	0.37	9.03	0.30	13.65	4.14	0.50

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-100%-3/U3-RA-3	5/7/02	13:30:00	8.99	0.48	13.66	4.14	0.37	9.03	0.31	13.65	4.14	0.50
Run U3-100%-3/U3-RA-3	5/7/02	13:31:00	8.94	0.44	13.66	4.14	0.35	9.02	0.31	13.65	4.14	0.50
Run U3-100%-3/U3-RA-3	5/7/02	13:32:00	8.84	0.51	13.66	4.14	0.35	9.02	0.32	13.65	4.14	0.49
Run U3-100%-3/U3-RA-3	5/7/02	13:33:00	8.86	0.48	13.66	4.14	0.36	9.02	0.32	13.65	4.14	0.49
Run U3-100%-3/U3-RA-3	5/7/02	13:34:00	8.86	0.47	13.66	4.14	0.35	9.01	0.32	13.65	4.14	0.49
Run U3-100%-3/U3-RA-3	5/7/02	13:35:00	8.89	0.53	13.66	4.14	0.34	9.01	0.33	13.65	4.14	0.49
Run U3-100%-3/U3-RA-3	5/7/02	13:36:00	8.94	0.53	13.66	4.15	0.33	9.01	0.33	13.65	4.14	0.48
Run U3-100%-3/U3-RA-3	5/7/02	13:37:00	8.94	0.51	13.65	4.14	0.33	9.01	0.33	13.65	4.14	0.48
Run U3-100%-3/U3-RA-3	5/7/02	13:38:00	8.94	0.53	13.66	4.14	0.31	9.01	0.34	13.65	4.14	0.48
Run U3-100%-3/U3-RA-3	5/7/02	13:39:00	8.97	0.53	13.65	4.14	0.32	9.01	0.34	13.65	4.14	0.47
Run U3-100%-3/U3-RA-3	5/7/02	13:40:00	8.92	0.56	13.66	4.14	0.32	9.00	0.35	13.65	4.14	0.47
Run U3-100%-3/U3-RA-3	5/7/02	13:41:00	8.91	0.56	13.66	4.14	0.32	9.00	0.35	13.65	4.14	0.47
Run U3-100%-3/U3-RA-3	5/7/02	13:42:00	8.89	0.57	13.66	4.14	0.31	9.00	0.35	13.65	4.14	0.47
Run U3-100%-3/U3-RA-3	5/7/02	13:43:00	8.89	0.59	13.67	4.14	0.32	9.00	0.36	13.65	4.14	0.46
Run U3-100%-3/U3-RA-3	5/7/02	13:44:00	8.84	0.59	13.67	4.13	0.31	9.00	0.36	13.65	4.14	0.46
Run U3-100%-3/U3-RA-3	5/7/02	13:45:00	8.84	0.63	13.67	4.14	0.33	8.99	0.37	13.65	4.14	0.46
Run U3-100%-3/U3-RA-3	5/7/02	13:46:00	8.86	0.59	13.66	4.14	0.33	8.99	0.37	13.65	4.14	0.46
END Run U3-100%-3/U3-RA-3	5/7/02	13:47:00	8.86	0.59	13.66	4.14	0.32	8.99	0.37	13.65	4.14	0.45

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-NG-50%-1	5/9/02	10:11:21	9.11		13.94	4.01		9.11		13.94	4.01	
Run U3-NG-50%-1	5/9/02	10:12:21	9.07		13.96	4.00		9.09		13.95	4.00	
Run U3-NG-50%-1	5/9/02	10:13:21	8.89		13.99	4.00		9.04		13.97	4.00	
Run U3-NG-50%-1	5/9/02	10:14:21	8.87		13.97	4.00		8.99		13.97	4.00	
Run U3-NG-50%-1	5/9/02	10:15:21	8.84		14.00	4.00		8.95		13.97	4.00	
Run U3-NG-50%-1	5/9/02	10:16:21	8.81		14.00	4.00		8.93		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:17:21	8.71		14.00	4.00		8.90		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:18:21	8.68		14.00	4.00		8.87		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:19:21	8.78		13.99	4.00		8.85		13.99	4.00	
Run U3-NG-50%-1	5/9/02	10:20:21	8.73		13.97	4.00		8.84		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:21:21	8.71		13.98	4.01		8.83		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:22:21	8.67		13.99	4.00		8.82		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:23:21	8.73		13.98	4.00		8.80		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:24:21	8.83		13.96	4.01		8.80		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:25:21	8.62		13.97	4.00		8.80		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:26:21	8.62		13.97	4.01		8.78		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:27:21	8.66		13.97	4.01		8.77		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:28:21	8.65		13.96	4.01		8.77		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:29:21	8.67		13.96	4.01		8.76		13.98	4.00	
Run U3-NG-50%-1	5/9/02	10:30:21	8.47		13.97	4.00		8.75		13.98	4.00	
END Run U3-NG-50%-1	5/9/02	10:31:21	8.62		13.96	4.01		<b>8.74</b>		<b>13.98</b>	<b>4.00</b>	
START Run U3-NG-50%-2	5/9/02	10:39:01	8.73		13.98	3.99		8.73		13.98	3.99	
Run U3-NG-50%-2	5/9/02	10:40:01	8.67		13.99	3.99		8.70		13.98	3.99	
Run U3-NG-50%-2	5/9/02	10:41:01	8.63		13.99	3.99		8.65		13.98	3.99	
Run U3-NG-50%-2	5/9/02	10:42:01	8.66		13.99	4.00		8.65		13.99	3.99	
Run U3-NG-50%-2	5/9/02	10:43:01	8.82		14.00	4.00		8.68		13.99	3.99	
Run U3-NG-50%-2	5/9/02	10:44:01	8.68		14.00	4.00		8.69		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:45:01	8.58		14.01	4.00		8.68		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:46:01	8.70		14.00	4.00		8.67		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:47:01	8.81		13.99	4.00		8.68		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:48:01	8.65		14.00	4.00		8.68		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:49:01	8.52		14.01	3.99		8.68		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:50:01	8.50		14.00	4.00		8.66		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:51:00	8.58		13.99	4.00		8.65		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:52:00	8.54		14.00	4.00		8.65		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:53:00	8.43		14.00	4.00		8.63		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:54:00	8.54		14.00	3.99		8.62		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:55:00	8.52		13.99	4.00		8.61		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:56:00	8.52		13.99	4.00		8.61		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:57:00	8.52		13.98	4.00		8.60		13.99	4.00	
Run U3-NG-50%-2	5/9/02	10:58:00	8.63		13.99	4.00		8.60		13.99	4.00	
END Run U3-NG-50%-2	5/9/02	10:59:00	8.52		13.98	4.00		<b>8.60</b>		<b>13.99</b>	<b>4.00</b>	

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-NG-50%-3	5/9/02	11:07:09	8.89		13.97	4.00		8.89		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:08:09	8.94		13.97	4.01		8.94		13.97	4.01	
Run U3-NG-50%-3	5/9/02	11:09:09	8.79		13.98	4.01		8.89		13.97	4.01	
Run U3-NG-50%-3	5/9/02	11:10:09	8.84		13.94	4.01		8.88		13.96	4.01	
Run U3-NG-50%-3	5/9/02	11:11:09	8.75		13.94	4.01		8.85		13.96	4.01	
Run U3-NG-50%-3	5/9/02	11:12:09	8.79		13.96	4.00		8.84		13.95	4.01	
Run U3-NG-50%-3	5/9/02	11:13:09	8.70		13.97	3.99		8.82		13.96	4.01	
Run U3-NG-50%-3	5/9/02	11:14:09	8.55		13.97	4.00		8.80		13.96	4.01	
Run U3-NG-50%-3	5/9/02	11:15:09	8.55		13.99	3.99		8.76		13.96	4.00	
Run U3-NG-50%-3	5/9/02	11:16:09	8.57		13.99	3.99		8.74		13.96	4.00	
Run U3-NG-50%-3	5/9/02	11:17:09	8.60		14.00	3.99		8.73		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:18:09	8.65		13.99	3.99		8.72		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:19:09	8.49		13.99	3.99		8.70		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:20:09	8.62		13.94	3.99		8.69		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:21:09	8.52		13.96	3.99		8.68		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:22:08	8.52		13.98	3.99		8.67		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:23:08	8.65		13.97	3.99		8.67		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:24:08	8.62		13.98	3.99		8.67		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:25:08	8.65		13.98	3.99		8.66		13.97	4.00	
Run U3-NG-50%-3	5/9/02	11:26:08	8.62		13.98	3.99		8.66		13.97	4.00	
END Run U3-NG-50%-3	5/9/02	11:27:08	8.62		13.98	3.99		<b>8.66</b>		<b>13.97</b>	<b>4.00</b>	
START Run U3-NG-65%-1	5/9/02	11:34:11	7.96		13.71	4.14		7.96		13.71	4.14	
Run U3-NG-65%-1	5/9/02	11:35:11	7.96		13.73	4.13		7.96		13.72	4.13	
Run U3-NG-65%-1	5/9/02	11:36:11	8.04		13.71	4.14		7.99		13.71	4.13	
Run U3-NG-65%-1	5/9/02	11:37:11	8.02		13.72	4.13		8.00		13.71	4.14	
Run U3-NG-65%-1	5/9/02	11:38:11	8.10		13.72	4.13		8.02		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:39:11	8.07		13.72	4.14		8.04		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:40:11	8.06		13.72	4.14		8.04		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:41:11	8.07		13.71	4.14		8.04		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:42:11	8.23		13.73	4.13		8.06		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:43:11	8.23		13.72	4.14		8.08		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:44:11	8.10		13.72	4.14		8.09		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:45:10	8.14		13.72	4.14		8.09		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:46:11	8.18		13.72	4.14		8.09		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:47:11	8.26		13.69	4.14		8.11		13.72	4.14	
Run U3-NG-65%-1	5/9/02	11:48:11	8.25		13.68	4.14		8.12		13.71	4.14	
Run U3-NG-65%-1	5/9/02	11:49:11	8.18		13.69	4.14		8.12		13.71	4.14	
Run U3-NG-65%-1	5/9/02	11:50:11	8.18		13.69	4.14		8.12		13.71	4.14	
Run U3-NG-65%-1	5/9/02	11:51:11	8.14		13.70	4.14		8.13		13.71	4.14	
Run U3-NG-65%-1	5/9/02	11:52:11	8.18		13.75	4.14		8.14		13.71	4.14	
Run U3-NG-65%-1	5/9/02	11:53:10	8.20		13.73	4.15		8.14		13.71	4.14	
END Run U3-NG-65%-1	5/9/02	11:54:10	8.15		13.73	4.13		<b>8.14</b>		<b>13.71</b>	<b>4.14</b>	

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-NG-65%-2	5/9/02	12:01:06	8.06		13.73	4.12		8.06		13.73	4.12	
Run U3-NG-65%-2	5/9/02	12:02:06	8.10		13.72	4.13		8.05		13.72	4.13	
Run U3-NG-65%-2	5/9/02	12:03:06	8.01		13.72	4.14		8.06		13.72	4.13	
Run U3-NG-65%-2	5/9/02	12:04:06	7.99		13.73	4.14		8.03		13.72	4.13	
Run U3-NG-65%-2	5/9/02	12:05:06	8.09		13.74	4.13		8.04		13.72	4.13	
Run U3-NG-65%-2	5/9/02	12:06:06	8.06		13.73	4.14		8.05		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:07:06	8.02		13.72	4.14		8.04		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:08:06	8.06		13.73	4.14		8.04		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:09:06	8.07		13.72	4.14		8.05		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:10:06	8.01		13.73	4.15		8.05		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:11:06	8.01		13.73	4.14		8.04		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:12:06	8.02		13.72	4.14		8.04		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:13:06	8.06		13.73	4.14		8.04		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:14:06	8.01		13.73	4.14		8.04		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:15:06	8.09		13.69	4.14		8.04		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:16:06	7.96		13.70	4.14		8.04		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:17:06	7.99		13.72	4.14		8.03		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:18:06	8.07		13.72	4.14		8.03		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:19:06	8.07		13.72	4.14		8.04		13.72	4.14	
Run U3-NG-65%-2	5/9/02	12:20:06	8.06		13.72	4.14		8.04		13.72	4.14	
END Run U3-NG-65%-2	5/9/02	12:21:06	8.09		13.70	4.13		<b>8.04</b>		<b>13.72</b>	<b>4.14</b>	
START Run U3-NG-65%-3	5/9/02	12:28:01	8.07		13.72	4.12		8.07		13.72	4.12	
Run U3-NG-65%-3	5/9/02	12:29:01	8.07		13.71	4.13		8.09		13.71	4.13	
Run U3-NG-65%-3	5/9/02	12:30:01	8.14		13.72	4.13		8.09		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:31:01	8.04		13.72	4.13		8.09		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:32:01	8.06		13.73	4.14		8.08		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:33:01	8.10		13.74	4.13		8.08		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:34:01	7.99		13.73	4.13		8.08		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:35:01	7.91		13.73	4.13		8.06		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:36:01	7.96		13.73	4.13		8.05		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:37:01	7.98		13.73	4.13		8.04		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:38:01	8.06		13.73	4.13		8.04		13.73	4.13	
Run U3-NG-65%-3	5/9/02	12:39:01	8.02		13.72	4.14		8.04		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:40:01	7.99		13.72	4.14		8.03		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:41:01	8.14		13.71	4.13		8.03		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:42:01	8.06		13.71	4.13		8.04		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:43:01	8.06		13.72	4.13		8.04		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:44:01	8.15		13.72	4.13		8.04		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:45:01	8.09		13.72	4.13		8.05		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:46:01	8.09		13.72	4.13		8.05		13.72	4.13	
Run U3-NG-65%-3	5/9/02	12:47:01	8.17		13.73	4.14		8.05		13.72	4.13	
END Run U3-NG-65%-3	5/9/02	12:48:01	8.07		13.71	4.13		<b>8.06</b>		<b>13.72</b>	<b>4.13</b>	



## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-NG-80%-1	5/9/02	12:56:00	7.66		13.70	4.13		7.66		13.70	4.13	
Run U3-NG-80%-1	5/9/02	12:57:00	7.69		13.70	4.13		7.68		13.70	4.13	
Run U3-NG-80%-1	5/9/02	12:58:00	7.70		13.70	4.14		7.69		13.70	4.14	
Run U3-NG-80%-1	5/9/02	12:59:00	7.75		13.70	4.14		7.70		13.70	4.14	
Run U3-NG-80%-1	5/9/02	13:00:00	7.78		13.70	4.14		7.72		13.70	4.14	
Run U3-NG-80%-1	5/9/02	13:01:00	7.82		13.70	4.15		7.73		13.70	4.14	
Run U3-NG-80%-1	5/9/02	13:02:00	7.78		13.71	4.14		7.75		13.70	4.14	
Run U3-NG-80%-1	5/9/02	13:03:00	7.75		13.70	4.14		7.76		13.70	4.14	
Run U3-NG-80%-1	5/9/02	13:04:01	7.77		13.72	4.13		7.75		13.70	4.14	
Run U3-NG-80%-1	5/9/02	13:05:00	7.82		13.71	4.14		7.76		13.70	4.14	
Run U3-NG-80%-1	5/9/02	13:06:00	7.77		13.71	4.14		7.76		13.70	4.14	
Run U3-NG-80%-1	5/9/02	13:07:00	7.78		13.71	4.13		7.76		13.70	4.14	
Run U3-NG-80%-1	5/9/02	13:08:00	7.72		13.72	4.13		7.76		13.71	4.14	
Run U3-NG-80%-1	5/9/02	13:09:00	7.70		13.72	4.14		7.75		13.71	4.14	
Run U3-NG-80%-1	5/9/02	13:10:00	7.67		13.72	4.14		7.75		13.71	4.14	
Run U3-NG-80%-1	5/9/02	13:11:00	7.72		13.73	4.13		7.75		13.71	4.14	
Run U3-NG-80%-1	5/9/02	13:12:00	7.74		13.72	4.14		7.75		13.71	4.14	
Run U3-NG-80%-1	5/9/02	13:13:00	7.70		13.72	4.14		7.74		13.71	4.14	
Run U3-NG-80%-1	5/9/02	13:14:00	7.74		13.70	4.13		7.74		13.71	4.14	
Run U3-NG-80%-1	5/9/02	13:15:00	7.70		13.70	4.13		7.74		13.71	4.14	
END Run U3-NG-80%-1	5/9/02	13:16:00	7.74		13.69	4.13		7.74		13.71	4.14	
START Run U3-NG-80%-2	5/9/02	13:22:07	7.88		13.72	4.11		7.88		13.72	4.11	
Run U3-NG-80%-2	5/9/02	13:23:07	7.86		13.70	4.12		7.86		13.70	4.12	
Run U3-NG-80%-2	5/9/02	13:24:07	7.86		13.70	4.13		7.86		13.70	4.12	
Run U3-NG-80%-2	5/9/02	13:25:07	7.86		13.70	4.13		7.86		13.70	4.12	
Run U3-NG-80%-2	5/9/02	13:26:07	7.78		13.70	4.12		7.86		13.70	4.12	
Run U3-NG-80%-2	5/9/02	13:27:07	7.80		13.70	4.13		7.85		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:28:07	7.75		13.70	4.12		7.84		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:29:07	7.62		13.70	4.12		7.81		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:30:07	7.54		13.70	4.12		7.79		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:31:07	7.54		13.70	4.12		7.76		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:32:07	7.54		13.71	4.13		7.74		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:33:07	7.58		13.71	4.13		7.73		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:34:07	7.62		13.70	4.13		7.72		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:35:07	7.62		13.71	4.13		7.71		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:36:07	7.62		13.71	4.13		7.70		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:37:07	7.60		13.71	4.12		7.70		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:38:07	7.67		13.71	4.12		7.69		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:39:07	7.66		13.72	4.12		7.69		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:40:07	7.69		13.71	4.12		7.69		13.70	4.13	
Run U3-NG-80%-2	5/9/02	13:41:07	7.70		13.72	4.13		7.69		13.70	4.13	
END Run U3-NG-80%-2	5/9/02	13:42:07	7.66		13.71	4.13		7.68		13.70	4.13	

## Tampa Electric Polk Power Station, Unit 3 Natural Gas Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-NG-80%-3	5/9/02	13:49:13	7.74		13.71	4.11		7.74		13.71	4.11	
Run U3-NG-80%-3	5/9/02	13:50:13	7.70		13.71	4.12		7.70		13.71	4.11	
Run U3-NG-80%-3	5/9/02	13:51:13	7.77		13.69	4.11		7.70		13.70	4.12	
Run U3-NG-80%-3	5/9/02	13:52:13	7.74		13.67	4.12		7.70		13.69	4.12	
Run U3-NG-80%-3	5/9/02	13:53:13	7.75		13.68	4.12		7.71		13.69	4.12	
Run U3-NG-80%-3	5/9/02	13:54:13	7.77		13.68	4.12		7.71		13.69	4.12	
Run U3-NG-80%-3	5/9/02	13:55:13	7.75		13.68	4.13		7.72		13.68	4.12	
Run U3-NG-80%-3	5/9/02	13:56:13	7.69		13.69	4.12		7.72		13.68	4.12	
Run U3-NG-80%-3	5/9/02	13:57:13	7.61		13.69	4.12		7.71		13.69	4.12	
Run U3-NG-80%-3	5/9/02	13:58:13	7.59		13.70	4.12		7.70		13.69	4.12	
Run U3-NG-80%-3	5/9/02	13:59:13	7.50		13.70	4.12		7.68		13.69	4.12	
Run U3-NG-80%-3	5/9/02	14:00:13	7.48		13.70	4.12		7.67		13.69	4.12	
Run U3-NG-80%-3	5/9/02	14:01:13	7.56		13.71	4.12		7.65		13.69	4.12	
Run U3-NG-80%-3	5/9/02	14:02:13	7.54		13.70	4.12		7.64		13.69	4.12	
Run U3-NG-80%-3	5/9/02	14:03:13	7.61		13.70	4.12		7.64		13.69	4.12	
Run U3-NG-80%-3	5/9/02	14:04:13	7.62		13.69	4.12		7.64		13.69	4.12	
Run U3-NG-80%-3	5/9/02	14:05:13	7.64		13.71	4.12		7.63		13.69	4.12	
Run U3-NG-80%-3	5/9/02	14:06:13	7.66		13.71	4.11		7.63		13.70	4.12	
Run U3-NG-80%-3	5/9/02	14:07:13	7.69		13.70	4.11		7.63		13.70	4.12	
Run U3-NG-80%-3	5/9/02	14:08:13	7.64		13.71	4.12		7.63		13.70	4.12	
END Run U3-NG-80%-3	5/9/02	14:09:13	7.65		13.70	4.12		7.64		13.70	4.12	

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-O2-Trav, N Port	5/8/02	9:03:01	48.05		12.92	5.95		48.05		12.92	5.95	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:04:01	48.95		12.91	5.96		48.74		12.91	5.95	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:05:01	48.95		12.93	5.93		48.67		12.92	5.95	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:06:01	49.35		12.95	5.94		48.86		12.92	5.94	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:07:01	49.05		12.94	5.94		48.95		12.93	5.94	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:08:01	49.05		12.97	5.93		48.94		12.93	5.94	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:09:01	48.95		12.95	5.93		48.97		12.94	5.94	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:10:01	49.05		12.96	5.92		48.96		12.94	5.94	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:11:01	49.05		12.92	5.93		48.99		12.94	5.94	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:12:01	49.15		12.93	5.93		49.00		12.94	5.94	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:13:01	48.75		12.95	5.93		48.99		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:14:01	49.05		12.89	5.93		48.98		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:15:01	48.95		12.93	5.91		48.98		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:16:01	49.25		12.95	5.92		48.98		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:17:01	48.85		12.95	5.92		48.98		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:18:01	48.65		12.96	5.93		48.97		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:19:01	48.95		12.94	5.93		48.96		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:20:01	48.65		12.96	5.93		48.95		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:21:01	48.35		12.95	5.93		48.92		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:22:01	48.25		12.95	5.92		48.89		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:23:01	48.45		12.96	5.91		48.86		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:24:01	48.35		12.97	5.91		48.84		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:25:01	48.25		12.96	5.92		48.82		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:26:01	48.25		12.96	5.93		48.79		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:27:01	48.15		12.95	5.93		48.77		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:28:00	48.25		12.93	5.93		48.75		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:29:00	48.25		12.95	5.93		48.73		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:30:00	47.95		12.94	5.93		48.70		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:31:00	48.05		12.94	5.93		48.68		12.94	5.93	
Run U3-Oil-O2-Trav, N Port	5/8/02	9:32:00	47.15		12.93	5.92		48.64		12.94	5.93	
END Run U3-Oil-O2-Trav, N Port	5/8/02	9:33:00	46.95		12.98	5.91		48.58		12.94	5.92	

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-O2-Trav, S Port	5/8/02	9:36:01	50.25		12.95	5.91		50.25		12.95	5.91	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:37:01	50.06		12.95	5.91		50.09		12.97	5.91	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:38:01	49.35		12.93	5.96		50.00		12.95	5.92	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:39:01	48.55		12.94	5.96		49.53		12.95	5.93	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:40:01	48.35		12.95	5.96		49.26		12.94	5.94	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:41:01	48.35		12.96	5.96		49.08		12.94	5.95	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:42:01	48.55		12.95	5.96		48.98		12.94	5.95	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:43:01	48.35		12.94	5.97		48.88		12.95	5.95	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:44:01	48.35		12.94	5.97		48.82		12.95	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:45:01	48.25		12.93	5.98		48.76		12.95	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:46:01	48.05		12.95	5.97		48.69		12.95	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:47:01	48.35		12.94	5.98		48.65		12.95	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:48:01	47.95		12.94	5.98		48.61		12.95	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:49:01	47.65		12.89	5.96		48.55		12.95	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:50:01	47.45		12.90	5.96		48.48		12.94	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:51:01	47.55		12.92	5.96		48.41		12.94	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:52:01	47.35		12.92	5.96		48.35		12.94	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:53:01	47.45		12.92	5.97		48.30		12.94	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:54:01	47.75		12.92	5.97		48.25		12.94	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:55:01	47.35		12.92	5.98		48.22		12.93	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:56:01	47.55		12.92	5.98		48.18		12.93	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:57:01	47.65		12.92	5.97		48.15		12.93	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:58:01	47.45		12.92	5.97		48.12		12.93	5.97	
Run U3-Oil-O2-Trav, S Port	5/8/02	9:59:00	47.75		12.92	5.97		48.10		12.93	5.97	
Run U3-Oil-O2-Trav, S Port	5/8/02	10:00:00	47.71		12.92	5.97		48.08		12.93	5.97	
Run U3-Oil-O2-Trav, S Port	5/8/02	10:01:00	47.65		12.95	5.95		48.06		12.93	5.97	
Run U3-Oil-O2-Trav, S Port	5/8/02	10:02:00	48.25		12.97	5.93		48.06		12.93	5.97	
Run U3-Oil-O2-Trav, S Port	5/8/02	10:03:00	47.85		12.93	5.95		48.05		12.93	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	10:04:00	48.05		12.92	5.97		48.03		12.93	5.96	
Run U3-Oil-O2-Trav, S Port	5/8/02	10:05:00	46.45		13.08	5.86		48.01		12.94	5.96	
END Run U3-Oil-O2-Trav, S Port	5/8/02	10:06:00	46.25		13.10	5.85		47.96		12.94	5.96	

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-O2-Trav, E Port	5/8/02	10:09:05	48.25		12.94	5.94		48.25		12.94	5.94	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:10:05	48.35		12.97	5.94		48.32		12.96	5.94	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:11:05	48.55		12.96	5.95		48.38		12.97	5.94	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:12:05	48.55		12.94	5.95		48.41		12.97	5.94	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:13:05	48.15		12.97	5.95		48.39		12.96	5.94	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:14:05	48.25		12.98	5.95		48.34		12.96	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:15:05	48.05		12.98	5.95		48.31		12.97	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:16:05	47.55		12.97	5.95		48.23		12.97	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:17:05	47.75		12.97	5.95		48.15		12.97	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:18:05	47.45		12.96	5.96		48.10		12.96	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:19:05	47.95		12.97	5.95		48.06		12.96	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:20:05	48.25		12.97	5.96		48.07		12.96	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:21:05	47.75		12.96	5.96		48.06		12.96	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:22:05	47.95		12.95	5.97		48.06		12.96	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:23:05	47.95		12.96	5.97		48.04		12.96	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:24:05	48.05		12.97	5.96		48.04		12.96	5.95	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:25:05	47.94		12.97	5.96		48.04		12.96	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:26:05	47.65		12.97	5.96		48.01		12.96	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:27:05	47.55		12.97	5.95		47.98		12.96	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:28:05	47.35		12.95	5.97		47.96		12.96	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:29:05	47.55		12.94	5.97		47.94		12.96	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:30:05	47.35		12.89	5.97		47.92		12.96	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:31:05	47.65		12.93	5.96		47.89		12.96	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:32:05	47.45		12.93	5.95		47.88		12.96	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:33:05	47.55		12.92	5.96		47.86		12.95	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:34:05	47.55		12.92	5.96		47.85		12.95	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:35:05	47.45		12.91	5.97		47.83		12.95	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:36:05	47.45		12.91	5.97		47.82		12.95	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:37:05	47.35		12.93	5.96		47.81		12.95	5.96	
Run U3-Oil-O2-Trav, E Port	5/8/02	10:38:05	47.05		12.95	5.94		47.79		12.95	5.96	
END Run U3-Oil-O2-Trav, E Port	5/8/02	10:39:05	46.85		12.94	5.94		47.76		12.95	5.96	

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-O2-Trav, N Port	5/8/02	10:42:01	49.15		13.00	5.88		49.15		13.00	5.88	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:43:01	49.55		13.03	5.90		49.38		13.02	5.89	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:44:01	49.35		13.06	5.89		49.43		13.03	5.89	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:45:01	49.35		12.97	5.90		49.44		13.03	5.89	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:46:01	49.15		13.00	5.92		49.41		13.02	5.90	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:47:01	48.65		13.01	5.91		49.29		13.02	5.90	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:48:01	48.55		13.01	5.91		49.17		13.01	5.90	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:49:01	48.35		13.00	5.92		49.08		13.01	5.90	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:50:01	48.85		13.03	5.91		49.05		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:51:01	48.45		13.02	5.91		49.03		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:52:01	48.85		13.01	5.92		48.98		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:53:01	48.75		12.96	5.91		48.96		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:54:01	48.95		12.98	5.90		48.94		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:55:01	48.65		13.00	5.91		48.93		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:56:01	48.85		13.02	5.91		48.90		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:57:01	48.65		13.02	5.90		48.89		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:58:01	48.65		13.01	5.91		48.87		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	10:59:01	49.05		13.02	5.91		48.87		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:00:01	49.35		13.02	5.90		48.88		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:01:00	48.85		13.03	5.90		48.90		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:02:00	48.45		13.03	5.90		48.89		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:03:00	48.85		13.02	5.91		48.88		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:04:00	48.75		13.04	5.90		48.88		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:05:00	48.95		13.04	5.89		48.88		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:06:00	48.44		13.03	5.89		48.87		13.01	5.91	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:07:00	48.45		13.04	5.89		48.85		13.02	5.90	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:08:00	48.35		13.07	5.86		48.84		13.02	5.90	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:09:00	48.05		13.05	5.88		48.81		13.02	5.90	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:10:00	48.25		13.05	5.87		48.79		13.02	5.90	
Run U3-Oil-O2-Trav, N Port	5/8/02	11:11:00	47.95		13.10	5.83		48.76		13.02	5.90	
END Run U3-Oil-O2-Trav, N Port	5/8/02	11:12:00	47.75		13.10	5.82		48.73		13.02	5.90	

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-50%-1	5/8/02	11:25:01	48.54		13.07	5.92		48.54		13.07	5.92	
Run U3-Oil-50%-1	5/8/02	11:26:01	48.62		13.07	5.92		48.77		13.06	5.92	
Run U3-Oil-50%-1	5/8/02	11:27:01	48.95		12.99	5.92		48.83		13.03	5.92	
Run U3-Oil-50%-1	5/8/02	11:28:01	48.25		12.98	5.93		48.85		13.02	5.92	
Run U3-Oil-50%-1	5/8/02	11:29:01	48.65		13.02	5.91		48.67		13.01	5.92	
Run U3-Oil-50%-1	5/8/02	11:30:01	48.45		13.00	5.92		48.66		13.01	5.92	
Run U3-Oil-50%-1	5/8/02	11:31:01	47.95		12.99	5.93		48.56		13.00	5.92	
Run U3-Oil-50%-1	5/8/02	11:32:00	47.55		12.99	5.93		48.47		13.00	5.92	
Run U3-Oil-50%-1	5/8/02	11:33:00	47.65		12.98	5.93		48.36		13.00	5.92	
Run U3-Oil-50%-1	5/8/02	11:34:00	48.05		12.99	5.92		48.31		13.00	5.92	
Run U3-Oil-50%-1	5/8/02	11:35:00	47.95		12.99	5.93		48.28		13.00	5.92	
Run U3-Oil-50%-1	5/8/02	11:36:00	48.15		13.00	5.92		48.28		13.00	5.92	
Run U3-Oil-50%-1	5/8/02	11:37:00	48.35		12.99	5.93		48.30		13.00	5.92	
Run U3-Oil-50%-1	5/8/02	11:38:00	48.55		13.00	5.93		48.30		13.00	5.92	
Run U3-Oil-50%-1	5/8/02	11:39:00	47.75		13.00	5.93		48.28		13.00	5.93	
Run U3-Oil-50%-1	5/8/02	11:40:00	48.35		13.00	5.92		48.27		13.00	5.93	
Run U3-Oil-50%-1	5/8/02	11:41:00	47.95		12.97	5.94		48.29		13.00	5.93	
Run U3-Oil-50%-1	5/8/02	11:42:00	48.65		12.98	5.94		48.29		13.00	5.93	
Run U3-Oil-50%-1	5/8/02	11:43:00	47.75		12.96	5.95		48.28		13.00	5.93	
Run U3-Oil-50%-1	5/8/02	11:44:00	47.85		12.96	5.95		48.26		12.99	5.93	
END Run U3-Oil-50%-1	5/8/02	11:45:00	47.95		12.98	5.95		<b>48.25</b>		<b>12.99</b>	<b>5.93</b>	
START Run U3-Oil-50%-2	5/8/02	11:53:01	47.95		12.92	5.93		47.95		12.92	5.93	
Run U3-Oil-50%-2	5/8/02	11:54:01	47.65		12.95	5.92		47.78		12.93	5.92	
Run U3-Oil-50%-2	5/8/02	11:55:01	48.05		13.00	5.91		47.77		12.95	5.92	
Run U3-Oil-50%-2	5/8/02	11:56:01	48.25		12.97	5.91		47.85		12.96	5.92	
Run U3-Oil-50%-2	5/8/02	11:57:01	47.45		12.99	5.91		47.89		12.97	5.92	
Run U3-Oil-50%-2	5/8/02	11:58:01	47.65		13.00	5.91		47.82		12.98	5.92	
Run U3-Oil-50%-2	5/8/02	11:59:01	47.55		13.01	5.91		47.78		12.98	5.92	
Run U3-Oil-50%-2	5/8/02	12:00:01	47.35		12.99	5.93		47.76		12.98	5.92	
Run U3-Oil-50%-2	5/8/02	12:01:01	47.85		12.99	5.92		47.70		12.99	5.92	
Run U3-Oil-50%-2	5/8/02	12:02:01	48.25		13.01	5.90		47.73		12.99	5.92	
Run U3-Oil-50%-2	5/8/02	12:03:01	48.85		13.03	5.91		47.82		12.99	5.92	
Run U3-Oil-50%-2	5/8/02	12:04:00	48.95		13.02	5.91		47.92		12.99	5.92	
Run U3-Oil-50%-2	5/8/02	12:05:00	47.85		12.96	5.94		47.97		12.99	5.92	
Run U3-Oil-50%-2	5/8/02	12:06:00	47.75		12.95	5.95		47.95		12.99	5.92	
Run U3-Oil-50%-2	5/8/02	12:07:00	47.55		12.94	5.95		47.93		12.99	5.92	
Run U3-Oil-50%-2	5/8/02	12:08:00	47.35		12.93	5.95		47.90		12.98	5.92	
Run U3-Oil-50%-2	5/8/02	12:09:00	47.45		12.93	5.96		47.87		12.98	5.93	
Run U3-Oil-50%-2	5/8/02	12:10:00	47.55		12.94	5.95		47.84		12.98	5.93	
Run U3-Oil-50%-2	5/8/02	12:11:00	47.65		12.95	5.95		47.83		12.98	5.93	
Run U3-Oil-50%-2	5/8/02	12:12:00	47.45		12.95	5.96		47.82		12.97	5.93	
END Run U3-Oil-50%-2	5/8/02	12:13:00	47.35		12.95	5.95		<b>47.81</b>		<b>12.97</b>	<b>5.93</b>	

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-50%-3	5/8/02	12:24:07	48.15		13.11	5.90		48.15		13.11	5.90	
Run U3-Oil-50%-3	5/8/02	12:25:07	48.55		13.10	5.90		48.27		13.11	5.90	
Run U3-Oil-50%-3	5/8/02	12:26:07	47.45		13.09	5.92		48.14		13.10	5.91	
Run U3-Oil-50%-3	5/8/02	12:27:07	47.25		13.06	5.92		47.86		13.09	5.91	
Run U3-Oil-50%-3	5/8/02	12:28:07	47.14		12.98	5.93		47.67		13.06	5.92	
Run U3-Oil-50%-3	5/8/02	12:29:07	47.25		12.99	5.93		47.57		13.05	5.92	
Run U3-Oil-50%-3	5/8/02	12:30:07	47.15		12.98	5.93		47.53		13.04	5.92	
Run U3-Oil-50%-3	5/8/02	12:31:07	47.65		12.99	5.93		47.51		13.03	5.92	
Run U3-Oil-50%-3	5/8/02	12:32:07	47.45		12.96	5.94		47.51		13.02	5.92	
Run U3-Oil-50%-3	5/8/02	12:33:07	47.55		12.98	5.94		47.50		13.02	5.92	
Run U3-Oil-50%-3	5/8/02	12:34:07	47.65		12.97	5.94		47.53		13.01	5.93	
Run U3-Oil-50%-3	5/8/02	12:35:07	47.75		12.97	5.94		47.53		13.01	5.93	
Run U3-Oil-50%-3	5/8/02	12:36:07	47.55		12.98	5.93		47.54		13.01	5.93	
Run U3-Oil-50%-3	5/8/02	12:37:07	48.05		12.98	5.94		47.55		13.00	5.93	
Run U3-Oil-50%-3	5/8/02	12:38:07	47.85		12.98	5.94		47.58		13.00	5.93	
Run U3-Oil-50%-3	5/8/02	12:39:07	47.65		12.96	5.95		47.59		13.00	5.93	
Run U3-Oil-50%-3	5/8/02	12:40:07	47.55		12.96	5.93		47.59		13.00	5.93	
Run U3-Oil-50%-3	5/8/02	12:41:07	47.15		12.96	5.95		47.58		12.99	5.93	
Run U3-Oil-50%-3	5/8/02	12:42:07	47.25		12.96	5.93		47.56		12.99	5.93	
Run U3-Oil-50%-3	5/8/02	12:43:07	47.25		12.95	5.94		47.55		12.99	5.93	
END Run U3-Oil-50%-3	5/8/02	12:44:07	47.15		12.96	5.93		<b>47.53</b>		<b>12.99</b>	<b>5.93</b>	
START Run U3-Oil-65%-1	5/8/02	12:53:07	49.45		12.47	6.27		49.45		12.47	6.27	
Run U3-Oil-65%-1	5/8/02	12:54:07	49.85		12.47	6.26		49.68		12.46	6.27	
Run U3-Oil-65%-1	5/8/02	12:55:07	49.95		12.53	6.26		49.84		12.49	6.27	
Run U3-Oil-65%-1	5/8/02	12:56:07	50.05		12.54	6.26		49.88		12.50	6.27	
Run U3-Oil-65%-1	5/8/02	12:57:07	49.85		12.55	6.26		49.89		12.51	6.27	
Run U3-Oil-65%-1	5/8/02	12:58:07	49.85		12.52	6.27		49.90		12.51	6.27	
Run U3-Oil-65%-1	5/8/02	12:59:07	49.65		12.53	6.28		49.86		12.52	6.27	
Run U3-Oil-65%-1	5/8/02	13:00:07	49.85		12.55	6.27		49.83		12.52	6.27	
Run U3-Oil-65%-1	5/8/02	13:01:07	50.15		12.54	6.27		49.85		12.53	6.27	
Run U3-Oil-65%-1	5/8/02	13:02:07	49.82		12.55	6.27		49.87		12.53	6.27	
Run U3-Oil-65%-1	5/8/02	13:03:07	49.95		12.57	6.26		49.86		12.53	6.27	
Run U3-Oil-65%-1	5/8/02	13:04:07	50.06		12.55	6.26		49.87		12.53	6.27	
Run U3-Oil-65%-1	5/8/02	13:05:07	49.75		12.57	6.25		49.88		12.53	6.27	
Run U3-Oil-65%-1	5/8/02	13:06:07	49.95		12.56	6.25		49.87		12.54	6.26	
Run U3-Oil-65%-1	5/8/02	13:07:07	49.75		12.55	6.26		49.86		12.54	6.26	
Run U3-Oil-65%-1	5/8/02	13:08:07	49.66		12.56	6.26		49.85		12.54	6.26	
Run U3-Oil-65%-1	5/8/02	13:09:07	49.45		12.57	6.25		49.83		12.54	6.26	
Run U3-Oil-65%-1	5/8/02	13:10:07	49.85		12.57	6.25		49.82		12.54	6.26	
Run U3-Oil-65%-1	5/8/02	13:11:07	49.86		12.55	6.26		49.83		12.54	6.26	
Run U3-Oil-65%-1	5/8/02	13:12:07	49.75		12.57	6.24		49.82		12.54	6.26	
END Run U3-Oil-65%-1	5/8/02	13:13:07	50.06		12.57	6.24		<b>49.82</b>		<b>12.55</b>	<b>6.26</b>	



## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-65%-2	5/8/02	13:21:01	50.15		12.62	6.25		50.15		12.62	6.25	
Run U3-Oil-65%-2	5/8/02	13:22:01	50.52		12.62	6.25		50.33		12.62	6.24	
Run U3-Oil-65%-2	5/8/02	13:23:01	50.15		12.52	6.26		50.34		12.60	6.25	
Run U3-Oil-65%-2	5/8/02	13:24:01	50.25		12.50	6.26		50.27		12.58	6.25	
Run U3-Oil-65%-2	5/8/02	13:25:01	50.05		12.55	6.24		50.25		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:26:01	50.05		12.56	6.25		50.21		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:27:01	50.05		12.57	6.26		50.17		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:28:01	49.95		12.57	6.26		50.15		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:29:01	50.15		12.57	6.24		50.14		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:30:01	49.16		12.56	6.25		50.07		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:31:01	49.65		12.56	6.24		50.01		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:32:01	49.26		12.54	6.26		49.96		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:33:01	49.35		12.57	6.24		49.90		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:34:01	49.25		12.54	6.25		49.86		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:35:01	49.15		12.56	6.25		49.81		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:36:01	49.45		12.57	6.24		49.78		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:37:00	49.35		12.56	6.25		49.76		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:38:00	49.35		12.58	6.24		49.73		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:39:00	49.45		12.57	6.24		49.72		12.56	6.25	
Run U3-Oil-65%-2	5/8/02	13:40:00	49.25		12.56	6.25		49.70		12.56	6.25	
END Run U3-Oil-65%-2	5/8/02	13:41:00	49.45		12.58	6.23		<b>49.68</b>		<b>12.56</b>	<b>6.25</b>	
START Run U3-Oil-65%-3	5/8/02	13:49:01	49.65		12.51	6.24		49.65		12.51	6.24	
Run U3-Oil-65%-3	5/8/02	13:50:01	49.45		12.52	6.25		49.54		12.51	6.24	
Run U3-Oil-65%-3	5/8/02	13:51:01	49.55		12.53	6.25		49.49		12.52	6.24	
Run U3-Oil-65%-3	5/8/02	13:52:01	49.65		12.53	6.24		49.52		12.52	6.24	
Run U3-Oil-65%-3	5/8/02	13:53:01	49.75		12.53	6.24		49.56		12.53	6.24	
Run U3-Oil-65%-3	5/8/02	13:54:01	49.55		12.55	6.25		49.58		12.53	6.24	
Run U3-Oil-65%-3	5/8/02	13:55:01	49.75		12.53	6.24		49.60		12.53	6.24	
Run U3-Oil-65%-3	5/8/02	13:56:01	49.45		12.54	6.25		49.58		12.53	6.24	
Run U3-Oil-65%-3	5/8/02	13:57:01	49.45		12.55	6.24		49.56		12.53	6.24	
Run U3-Oil-65%-3	5/8/02	13:58:01	49.55		12.53	6.24		49.56		12.53	6.24	
Run U3-Oil-65%-3	5/8/02	13:59:01	49.35		12.56	6.25		49.54		12.53	6.25	
Run U3-Oil-65%-3	5/8/02	14:00:01	49.75		12.55	6.24		49.54		12.54	6.25	
Run U3-Oil-65%-3	5/8/02	14:01:01	49.25		12.55	6.25		49.54		12.54	6.25	
Run U3-Oil-65%-3	5/8/02	14:02:01	49.45		12.57	6.24		49.52		12.54	6.24	
Run U3-Oil-65%-3	5/8/02	14:03:01	49.55		12.56	6.23		49.52		12.54	6.24	
Run U3-Oil-65%-3	5/8/02	14:04:01	49.45		12.55	6.25		49.52		12.54	6.24	
Run U3-Oil-65%-3	5/8/02	14:05:01	49.45		12.55	6.25		49.51		12.54	6.24	
Run U3-Oil-65%-3	5/8/02	14:06:01	49.55		12.57	6.24		49.51		12.54	6.24	
Run U3-Oil-65%-3	5/8/02	14:07:01	49.55		12.58	6.23		49.52		12.54	6.24	
Run U3-Oil-65%-3	5/8/02	14:08:01	49.65		12.55	6.25		49.53		12.54	6.24	
END Run U3-Oil-65%-3	5/8/02	14:09:01	49.45		12.57	6.24		<b>49.53</b>		<b>12.54</b>	<b>6.24</b>	

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-80%-1	5/8/02	14:18:01	50.35		12.40	6.31		50.35		12.40	6.31	
Run U3-Oil-80%-1	5/8/02	14:19:01	50.26		12.42	6.31		50.31		12.41	6.32	
Run U3-Oil-80%-1	5/8/02	14:20:01	50.46		12.44	6.31		50.32		12.42	6.32	
Run U3-Oil-80%-1	5/8/02	14:21:01	50.75		12.43	6.31		50.42		12.42	6.32	
Run U3-Oil-80%-1	5/8/02	14:22:01	50.75		12.46	6.30		50.51		12.43	6.31	
Run U3-Oil-80%-1	5/8/02	14:23:01	50.75		12.45	6.31		50.56		12.43	6.31	
Run U3-Oil-80%-1	5/8/02	14:24:01	50.75		12.45	6.31		50.59		12.44	6.31	
Run U3-Oil-80%-1	5/8/02	14:25:01	50.55		12.46	6.31		50.59		12.44	6.31	
Run U3-Oil-80%-1	5/8/02	14:26:01	50.66		12.47	6.30		50.60		12.44	6.31	
Run U3-Oil-80%-1	5/8/02	14:27:01	50.45		12.46	6.31		50.59		12.44	6.31	
Run U3-Oil-80%-1	5/8/02	14:28:01	50.55		12.46	6.31		50.58		12.45	6.31	
Run U3-Oil-80%-1	5/8/02	14:29:01	50.45		12.46	6.32		50.57		12.45	6.31	
Run U3-Oil-80%-1	5/8/02	14:30:01	50.36		12.47	6.31		50.55		12.45	6.31	
Run U3-Oil-80%-1	5/8/02	14:31:01	50.45		12.44	6.31		50.54		12.45	6.31	
Run U3-Oil-80%-1	5/8/02	14:32:01	50.45		12.43	6.31		50.53		12.45	6.31	
Run U3-Oil-80%-1	5/8/02	14:33:01	50.65		12.43	6.31		50.53		12.45	6.31	
Run U3-Oil-80%-1	5/8/02	14:34:01	50.45		12.41	6.32		50.53		12.44	6.31	
Run U3-Oil-80%-1	5/8/02	14:35:01	50.25		12.42	6.31		50.53		12.44	6.31	
Run U3-Oil-80%-1	5/8/02	14:36:01	50.66		12.42	6.31		50.52		12.44	6.31	
Run U3-Oil-80%-1	5/8/02	14:37:01	50.45		12.41	6.31		50.52		12.44	6.31	
END Run U3-Oil-80%-1	5/8/02	14:38:00	50.45		12.42	6.31		<b>50.52</b>		<b>12.44</b>	<b>6.31</b>	
START Run U3-Oil-80%-2	5/8/02	14:47:02	51.35		12.40	6.31		51.35		12.40	6.31	
Run U3-Oil-80%-2	5/8/02	14:48:02	51.15		12.41	6.30		51.08		12.41	6.30	
Run U3-Oil-80%-2	5/8/02	14:49:02	51.25		12.42	6.31		51.18		12.41	6.30	
Run U3-Oil-80%-2	5/8/02	14:50:02	51.05		12.42	6.31		51.16		12.41	6.31	
Run U3-Oil-80%-2	5/8/02	14:51:02	51.25		12.43	6.30		51.17		12.41	6.31	
Run U3-Oil-80%-2	5/8/02	14:52:02	51.05		12.42	6.31		51.17		12.41	6.31	
Run U3-Oil-80%-2	5/8/02	14:53:02	51.25		12.46	6.30		51.17		12.42	6.31	
Run U3-Oil-80%-2	5/8/02	14:54:02	50.65		12.46	6.31		51.12		12.42	6.31	
Run U3-Oil-80%-2	5/8/02	14:55:02	51.05		12.47	6.31		51.09		12.43	6.31	
Run U3-Oil-80%-2	5/8/02	14:56:02	50.85		12.47	6.31		51.08		12.43	6.31	
Run U3-Oil-80%-2	5/8/02	14:57:02	50.65		12.48	6.31		51.04		12.44	6.31	
Run U3-Oil-80%-2	5/8/02	14:58:02	50.95		12.44	6.30		51.03		12.44	6.31	
Run U3-Oil-80%-2	5/8/02	14:59:02	50.65		12.45	6.30		51.01		12.44	6.31	
Run U3-Oil-80%-2	5/8/02	15:00:02	50.85		12.44	6.31		51.00		12.44	6.31	
Run U3-Oil-80%-2	5/8/02	15:01:02	50.75		12.45	6.30		50.98		12.44	6.31	
Run U3-Oil-80%-2	5/8/02	15:02:02	50.85		12.44	6.31		50.97		12.44	6.31	
Run U3-Oil-80%-2	5/8/02	15:03:02	50.95		12.43	6.31		50.96		12.44	6.31	
Run U3-Oil-80%-2	5/8/02	15:04:02	50.85		12.43	6.31		50.96		12.44	6.31	
Run U3-Oil-80%-2	5/8/02	15:05:02	50.65		12.43	6.31		50.95		12.44	6.31	
Run U3-Oil-80%-2	5/8/02	15:06:02	50.85		12.45	6.30		50.93		12.44	6.31	
END Run U3-Oil-80%-2	5/8/02	15:07:02	50.85		12.43	6.32		<b>50.93</b>		<b>12.44</b>	<b>6.31</b>	

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-80%-3	5/8/02	15:17:01	50.15		12.43	6.28		50.15		12.43	6.28	
Run U3-Oil-80%-3	5/8/02	15:18:01	50.75		12.42	6.30		50.63		12.43	6.29	
Run U3-Oil-80%-3	5/8/02	15:19:01	50.55		12.43	6.30		50.65		12.43	6.30	
Run U3-Oil-80%-3	5/8/02	15:20:01	50.55		12.42	6.31		50.61		12.43	6.30	
Run U3-Oil-80%-3	5/8/02	15:21:01	50.52		12.43	6.30		50.60		12.43	6.30	
Run U3-Oil-80%-3	5/8/02	15:22:01	50.75		12.43	6.30		50.62		12.43	6.30	
Run U3-Oil-80%-3	5/8/02	15:23:01	50.35		12.43	6.31		50.61		12.43	6.30	
Run U3-Oil-80%-3	5/8/02	15:24:01	50.55		12.43	6.31		50.59		12.43	6.30	
Run U3-Oil-80%-3	5/8/02	15:25:01	50.55		12.42	6.31		50.58		12.43	6.30	
Run U3-Oil-80%-3	5/8/02	15:26:01	50.25		12.43	6.31		50.56		12.43	6.30	
Run U3-Oil-80%-3	5/8/02	15:27:01	50.35		12.43	6.31		50.52		12.42	6.31	
Run U3-Oil-80%-3	5/8/02	15:28:01	50.35		12.41	6.31		50.51		12.42	6.30	
Run U3-Oil-80%-3	5/8/02	15:29:01	50.35		12.42	6.31		50.49		12.42	6.31	
Run U3-Oil-80%-3	5/8/02	15:30:01	50.35		12.42	6.31		50.48		12.42	6.31	
Run U3-Oil-80%-3	5/8/02	15:31:01	50.25		12.42	6.31		50.46		12.42	6.31	
Run U3-Oil-80%-3	5/8/02	15:32:01	50.25		12.42	6.31		50.45		12.42	6.31	
Run U3-Oil-80%-3	5/8/02	15:33:01	50.25		12.42	6.32		50.44		12.42	6.31	
Run U3-Oil-80%-3	5/8/02	15:34:01	50.14		12.43	6.30		50.43		12.42	6.31	
Run U3-Oil-80%-3	5/8/02	15:35:01	50.45		12.43	6.31		50.43		12.42	6.31	
Run U3-Oil-80%-3	5/8/02	15:36:01	50.25		12.42	6.31		50.42		12.42	6.31	
END Run U3-Oil-80%-3	5/8/02	15:37:00	50.25		12.42	6.30		<b>50.41</b>		<b>12.42</b>	<b>6.31</b>	

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-100%-1	5/8/02	15:55:02	50.34	0.95	12.42	6.28	0.36	50.34	0.95	12.42	6.28	0.36
Run U3-Oil-100%-1	5/8/02	15:56:02	50.24	0.92	12.41	6.28	0.33	50.29	0.94	12.42	6.28	0.34
Run U3-Oil-100%-1	5/8/02	15:57:02	50.24	0.89	12.42	6.29	0.40	50.27	0.92	12.42	6.28	0.34
Run U3-Oil-100%-1	5/8/02	15:58:02	50.35	0.89	12.42	6.29	0.29	50.29	0.91	12.42	6.28	0.33
Run U3-Oil-100%-1	5/8/02	15:59:02	50.22	0.92	12.41	6.29	0.29	50.27	0.91	12.42	6.29	0.32
Run U3-Oil-100%-1	5/8/02	16:00:02	50.15	0.95	12.41	6.29	0.26	50.25	0.91	12.41	6.29	0.31
Run U3-Oil-100%-1	5/8/02	16:01:02	50.05	0.89	12.41	6.30	0.24	50.23	0.91	12.41	6.29	0.30
Run U3-Oil-100%-1	5/8/02	16:02:02	49.85	0.89	12.41	6.30	0.24	50.18	0.91	12.41	6.29	0.30
Run U3-Oil-100%-1	5/8/02	16:03:02	49.85	0.92	12.42	6.29	0.21	50.14	0.91	12.41	6.29	0.29
Run U3-Oil-100%-1	5/8/02	16:04:02	50.05	0.92	12.41	6.30	0.20	50.13	0.91	12.41	6.29	0.28
Run U3-Oil-100%-1	5/8/02	16:05:02	50.25	0.92	12.41	6.30	0.17	50.13	0.91	12.41	6.29	0.27
Run U3-Oil-100%-1	5/8/02	16:06:02	50.05	0.89	12.41	6.30	0.18	50.13	0.91	12.41	6.29	0.26
Run U3-Oil-100%-1	5/8/02	16:07:02	50.25	0.92	12.40	6.30	0.18	50.14	0.91	12.41	6.29	0.26
Run U3-Oil-100%-1	5/8/02	16:08:02	50.35	0.89	12.41	6.30	0.19	50.16	0.91	12.41	6.29	0.25
Run U3-Oil-100%-1	5/8/02	16:09:02	50.44	0.92	12.40	6.30	0.20	50.17	0.91	12.41	6.29	0.25
Run U3-Oil-100%-1	5/8/02	16:10:02	50.15	0.95	12.40	6.30	0.15	50.19	0.91	12.41	6.30	0.24
Run U3-Oil-100%-1	5/8/02	16:11:02	49.94	0.95	12.41	6.30	0.16	50.18	0.91	12.41	6.30	0.24
Run U3-Oil-100%-1	5/8/02	16:12:02	49.85	0.95	12.43	6.29	0.14	50.17	0.92	12.41	6.30	0.23
Run U3-Oil-100%-1	5/8/02	16:13:02	50.15	0.95	12.43	6.28	0.13	50.16	0.92	12.41	6.30	0.23
Run U3-Oil-100%-1	5/8/02	16:14:02	49.95	0.95	12.43	6.30	0.13	50.16	0.92	12.41	6.29	0.22
Run U3-Oil-100%-1	5/8/02	16:15:02	50.55	0.95	12.42	6.30	0.13	50.15	0.92	12.41	6.29	0.22
Run U3-Oil-100%-1	5/8/02	16:16:02	49.55	0.95	12.44	6.28	0.13	50.14	0.92	12.41	6.29	0.21
Run U3-Oil-100%-1	5/8/02	16:17:02	49.95	0.95	12.43	6.28	0.13	50.13	0.93	12.41	6.29	0.21
Run U3-Oil-100%-1	5/8/02	16:18:02	50.74	0.95	12.46	6.27	0.12	50.15	0.93	12.42	6.29	0.20
Run U3-Oil-100%-1	5/8/02	16:19:02	50.95	0.98	12.45	6.27	0.13	50.19	0.93	12.42	6.29	0.20
Run U3-Oil-100%-1	5/8/02	16:20:02	51.25	1.04	12.46	6.27	0.11	50.23	0.93	12.42	6.29	0.20
Run U3-Oil-100%-1	5/8/02	16:21:02	51.25	1.07	12.46	6.27	0.11	50.27	0.94	12.42	6.29	0.20
Run U3-Oil-100%-1	5/8/02	16:22:02	50.84	1.04	12.45	6.27	0.10	50.30	0.94	12.42	6.29	0.19
Run U3-Oil-100%-1	5/8/02	16:23:02	50.75	1.04	12.43	6.29	0.10	50.32	0.94	12.42	6.29	0.19
Run U3-Oil-100%-1	5/8/02	16:24:02	49.94	1.10	12.43	6.29	0.09	50.32	0.95	12.42	6.29	0.19
Run U3-Oil-100%-1	5/8/02	16:25:02	50.25	1.04	12.43	6.30	0.09	50.32	0.95	12.42	6.29	0.18
Run U3-Oil-100%-1	5/8/02	16:26:02	50.14	1.07	12.42	6.29	0.09	50.31	0.96	12.42	6.29	0.18
Run U3-Oil-100%-1	5/8/02	16:27:02	49.95	1.10	12.43	6.29	0.08	50.30	0.96	12.42	6.29	0.18
Run U3-Oil-100%-1	5/8/02	16:28:02	50.05	1.13	12.43	6.29	0.09	50.30	0.96	12.42	6.29	0.17
Run U3-Oil-100%-1	5/8/02	16:29:02	50.05	1.10	12.43	6.29	0.09	50.29	0.97	12.42	6.29	0.17
Run U3-Oil-100%-1	5/8/02	16:30:02	50.25	1.13	12.44	6.28	0.08	50.28	0.97	12.42	6.29	0.17
Run U3-Oil-100%-1	5/8/02	16:31:02	51.15	1.10	12.44	6.28	0.08	50.30	0.98	12.42	6.29	0.17
Run U3-Oil-100%-1	5/8/02	16:32:02	50.35	1.10	12.44	6.29	0.08	50.32	0.98	12.42	6.29	0.16
Run U3-Oil-100%-1	5/8/02	16:33:02	50.25	1.10	12.42	6.29	0.09	50.32	0.98	12.42	6.29	0.16
Run U3-Oil-100%-1	5/8/02	16:34:02	50.85	1.16	12.43	6.28	0.09	50.33	0.99	12.42	6.29	0.16
Run U3-Oil-100%-1	5/8/02	16:35:02	50.65	1.16	12.42	6.29	0.10	50.34	0.99	12.42	6.29	0.16
Run U3-Oil-100%-1	5/8/02	16:36:02	50.04	1.16	12.41	6.30	0.09	50.34	1.00	12.42	6.29	0.16

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-Oil-100%-1	5/8/02	16:37:02	49.75	1.16	12.41	6.29	0.10	50.32	1.00	12.42	6.29	0.16
Run U3-Oil-100%-1	5/8/02	16:38:02	49.65	1.16	12.42	6.29	0.09	50.31	1.00	12.42	6.29	0.15
Run U3-Oil-100%-1	5/8/02	16:39:02	50.65	1.19	12.44	6.27	0.09	50.31	1.01	12.42	6.29	0.15
Run U3-Oil-100%-1	5/8/02	16:40:02	50.75	1.16	12.45	6.27	0.08	50.32	1.01	12.42	6.29	0.15
Run U3-Oil-100%-1	5/8/02	16:41:02	50.14	1.16	12.45	6.28	0.08	50.32	1.01	12.42	6.29	0.15
Run U3-Oil-100%-1	5/8/02	16:42:02	50.25	1.19	12.46	6.27	0.08	50.32	1.02	12.42	6.29	0.15
Run U3-Oil-100%-1	5/8/02	16:43:01	50.15	1.22	12.45	6.28	0.06	50.32	1.02	12.42	6.29	0.15
Run U3-Oil-100%-1	5/8/02	16:44:01	50.45	1.19	12.44	6.28	0.07	50.32	1.03	12.43	6.29	0.15
Run U3-Oil-100%-1	5/8/02	16:45:01	49.45	1.22	12.43	6.29	0.06	50.32	1.03	12.43	6.29	0.14
Run U3-Oil-100%-1	5/8/02	16:46:01	50.25	1.19	12.45	6.27	0.06	50.30	1.03	12.43	6.29	0.14
Run U3-Oil-100%-1	5/8/02	16:47:01	50.54	1.22	12.46	6.27	0.06	50.31	1.04	12.43	6.29	0.14
Run U3-Oil-100%-1	5/8/02	16:48:01	50.74	1.25	12.45	6.28	0.07	50.32	1.04	12.43	6.29	0.14
Run U3-Oil-100%-1	5/8/02	16:49:01	50.55	1.25	12.45	6.27	0.07	50.32	1.04	12.43	6.29	0.14
Run U3-Oil-100%-1	5/8/02	16:50:01	50.25	1.25	12.44	6.28	0.07	50.32	1.05	12.43	6.29	0.14
Run U3-Oil-100%-1	5/8/02	16:51:01	49.94	1.25	12.43	6.28	0.06	50.32	1.05	12.43	6.29	0.14
Run U3-Oil-100%-1	5/8/02	16:52:01	49.85	1.25	12.44	6.28	0.06	50.31	1.06	12.43	6.29	0.13
Run U3-Oil-100%-1	5/8/02	16:53:01	49.64	1.25	12.44	6.28	0.08	50.30	1.06	12.43	6.29	0.13
Run U3-Oil-100%-1	5/8/02	16:54:01	50.15	1.28	12.38	6.28	0.08	50.30	1.06	12.43	6.29	0.13
END Run U3-Oil-100%-1	5/8/02	16:55:01	50.85	1.25	12.44	6.28	0.09	<b>50.30</b>	<b>1.07</b>	<b>12.43</b>	<b>6.29</b>	<b>0.13</b>

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-100%-2	5/8/02	17:10:01	49.95	0.95	12.43	6.27	0.26	49.95	0.95	12.43	6.27	0.26
Run U3-Oil-100%-2	5/8/02	17:11:01	49.85	0.95	12.41	6.28	0.26	49.99	0.94	12.43	6.27	0.28
Run U3-Oil-100%-2	5/8/02	17:12:01	49.95	0.95	12.43	6.28	0.23	49.92	0.94	12.43	6.28	0.26
Run U3-Oil-100%-2	5/8/02	17:13:00	50.05	0.95	12.43	6.28	0.23	49.92	0.95	12.43	6.28	0.25
Run U3-Oil-100%-2	5/8/02	17:14:00	50.65	0.95	12.44	6.27	0.22	50.05	0.94	12.43	6.28	0.25
Run U3-Oil-100%-2	5/8/02	17:15:00	49.44	0.92	12.44	6.28	0.22	50.08	0.94	12.43	6.28	0.24
Run U3-Oil-100%-2	5/8/02	17:16:00	50.34	0.92	12.46	6.27	0.21	50.07	0.94	12.43	6.28	0.24
Run U3-Oil-100%-2	5/8/02	17:17:00	50.75	0.92	12.47	6.27	0.22	50.13	0.94	12.44	6.28	0.23
Run U3-Oil-100%-2	5/8/02	17:18:00	50.35	0.89	12.46	6.28	0.21	50.17	0.93	12.44	6.28	0.23
Run U3-Oil-100%-2	5/8/02	17:19:00	50.25	0.92	12.48	6.26	0.20	50.15	0.93	12.44	6.28	0.23
Run U3-Oil-100%-2	5/8/02	17:20:00	50.05	0.89	12.46	6.27	0.21	50.18	0.93	12.44	6.27	0.23
Run U3-Oil-100%-2	5/8/02	17:21:00	49.75	0.95	12.44	6.29	0.22	50.18	0.93	12.45	6.28	0.22
Run U3-Oil-100%-2	5/8/02	17:22:00	49.65	0.89	12.45	6.28	0.19	50.14	0.93	12.45	6.28	0.22
Run U3-Oil-100%-2	5/8/02	17:23:00	50.25	0.92	12.45	6.28	0.17	50.13	0.93	12.45	6.28	0.22
Run U3-Oil-100%-2	5/8/02	17:24:00	50.85	0.92	12.47	6.27	0.18	50.14	0.93	12.45	6.28	0.22
Run U3-Oil-100%-2	5/8/02	17:25:00	50.45	0.92	12.47	6.27	0.17	50.18	0.93	12.45	6.28	0.21
Run U3-Oil-100%-2	5/8/02	17:26:00	50.55	0.95	12.46	6.27	0.17	50.22	0.93	12.45	6.28	0.21
Run U3-Oil-100%-2	5/8/02	17:27:00	50.65	0.98	12.46	6.27	0.16	50.24	0.93	12.45	6.28	0.21
Run U3-Oil-100%-2	5/8/02	17:28:00	51.15	1.01	12.46	6.27	0.14	50.28	0.93	12.45	6.28	0.20
Run U3-Oil-100%-2	5/8/02	17:29:00	50.65	0.98	12.45	6.28	0.13	50.31	0.94	12.45	6.28	0.20
Run U3-Oil-100%-2	5/8/02	17:30:00	50.35	0.98	12.45	6.29	0.14	50.31	0.94	12.45	6.28	0.20
Run U3-Oil-100%-2	5/8/02	17:31:00	50.25	0.98	12.44	6.29	0.13	50.31	0.94	12.45	6.28	0.20
Run U3-Oil-100%-2	5/8/02	17:32:00	50.45	0.98	12.45	6.29	0.12	50.32	0.94	12.45	6.28	0.19
Run U3-Oil-100%-2	5/8/02	17:33:00	51.05	0.98	12.47	6.28	0.13	50.34	0.94	12.45	6.28	0.19
Run U3-Oil-100%-2	5/8/02	17:34:00	50.55	0.98	12.45	6.28	0.11	50.36	0.94	12.45	6.28	0.19
Run U3-Oil-100%-2	5/8/02	17:35:00	50.35	1.04	12.45	6.29	0.12	50.36	0.95	12.45	6.28	0.18
Run U3-Oil-100%-2	5/8/02	17:36:00	50.85	1.10	12.45	6.29	0.11	50.37	0.95	12.45	6.28	0.18
Run U3-Oil-100%-2	5/8/02	17:37:00	50.35	1.10	12.44	6.29	0.11	50.37	0.96	12.45	6.28	0.18
Run U3-Oil-100%-2	5/8/02	17:38:00	51.04	1.07	12.46	6.28	0.10	50.38	0.96	12.45	6.28	0.18
Run U3-Oil-100%-2	5/8/02	17:39:00	51.05	1.10	12.45	6.28	0.11	50.40	0.97	12.45	6.28	0.17
Run U3-Oil-100%-2	5/8/02	17:40:00	51.15	1.10	12.44	6.28	0.11	50.42	0.97	12.45	6.28	0.17
Run U3-Oil-100%-2	5/8/02	17:41:00	50.84	1.07	12.45	6.29	0.13	50.43	0.97	12.45	6.28	0.17
Run U3-Oil-100%-2	5/8/02	17:42:00	50.15	1.13	12.47	6.27	0.12	50.43	0.98	12.45	6.28	0.17
Run U3-Oil-100%-2	5/8/02	17:43:00	50.05	1.13	12.45	6.28	0.12	50.43	0.98	12.45	6.28	0.17
Run U3-Oil-100%-2	5/8/02	17:44:00	50.15	1.13	12.45	6.28	0.12	50.42	0.99	12.45	6.28	0.17
Run U3-Oil-100%-2	5/8/02	17:45:00	49.25	1.13	12.45	6.28	0.11	50.40	0.99	12.45	6.28	0.16
Run U3-Oil-100%-2	5/8/02	17:46:00	50.65	1.13	12.45	6.28	0.12	50.39	0.99	12.45	6.28	0.16
Run U3-Oil-100%-2	5/8/02	17:47:00	49.95	1.13	12.45	6.28	0.10	50.38	1.00	12.45	6.28	0.16
Run U3-Oil-100%-2	5/8/02	17:48:00	50.05	1.16	12.44	6.28	0.13	50.37	1.00	12.45	6.28	0.16
Run U3-Oil-100%-2	5/8/02	17:49:00	49.55	1.19	12.44	6.29	0.12	50.36	1.01	12.45	6.28	0.16
Run U3-Oil-100%-2	5/8/02	17:50:00	50.05	1.19	12.44	6.29	0.12	50.35	1.01	12.45	6.28	0.16
Run U3-Oil-100%-2	5/8/02	17:51:00	49.65	1.19	12.45	6.28	0.12	50.33	1.02	12.45	6.28	0.16

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-Oil-100%-2	5/8/02	17:52:00	50.95	1.19	12.45	6.27	0.12	50.33	1.02	12.45	6.28	0.16
Run U3-Oil-100%-2	5/8/02	17:53:00	50.75	1.22	12.45	6.28	0.12	50.35	1.02	12.45	6.28	0.16
Run U3-Oil-100%-2	5/8/02	17:54:00	50.45	1.19	12.45	6.28	0.13	50.35	1.03	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	17:55:00	50.65	1.19	12.45	6.28	0.13	50.36	1.03	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	17:56:00	50.45	1.22	12.44	6.28	0.15	50.36	1.03	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	17:57:00	50.65	1.22	12.46	6.28	0.13	50.37	1.04	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	17:58:00	50.14	1.25	12.45	6.28	0.13	50.37	1.04	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	17:59:00	50.05	1.25	12.46	6.27	0.12	50.36	1.05	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:00:00	50.45	1.22	12.45	6.28	0.12	50.36	1.05	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:01:00	49.45	1.22	12.46	6.28	0.12	50.35	1.05	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:02:00	49.85	1.25	12.45	6.29	0.13	50.34	1.06	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:03:00	50.05	1.25	12.47	6.28	0.12	50.33	1.06	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:04:00	51.05	1.22	12.46	6.28	0.13	50.34	1.06	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:05:00	50.85	1.25	12.48	6.27	0.12	50.35	1.07	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:06:00	51.45	1.28	12.47	6.28	0.13	50.36	1.07	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:07:00	51.45	1.31	12.46	6.28	0.12	50.38	1.07	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:08:00	51.05	1.28	12.47	6.27	0.11	50.39	1.08	12.45	6.28	0.15
Run U3-Oil-100%-2	5/8/02	18:09:00	51.45	1.25	12.45	6.29	0.11	50.40	1.08	12.45	6.28	0.15
END Run U3-Oil-100%-2	5/8/02	18:10:00	50.15	1.28	12.43	6.30	0.10	50.41	1.09	12.45	6.28	0.15

## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
START Run U3-Oil-100%-3	5/8/02	18:22:01	51.05	1.01	12.39	6.25	0.22	51.05	1.01	12.39	6.25	0.22
Run U3-Oil-100%-3	5/8/02	18:23:01	51.15	0.98	12.38	6.27	0.18	50.97	1.00	12.39	6.26	0.19
Run U3-Oil-100%-3	5/8/02	18:24:01	50.65	0.98	12.38	6.29	0.16	50.90	0.99	12.39	6.27	0.17
Run U3-Oil-100%-3	5/8/02	18:25:01	51.45	0.95	12.40	6.27	0.16	50.90	0.98	12.39	6.27	0.17
Run U3-Oil-100%-3	5/8/02	18:26:01	51.35	0.95	12.40	6.28	0.14	51.06	0.98	12.40	6.27	0.16
Run U3-Oil-100%-3	5/8/02	18:27:01	51.25	0.95	12.38	6.29	0.14	51.05	0.97	12.40	6.27	0.16
Run U3-Oil-100%-3	5/8/02	18:28:01	50.95	0.95	12.40	6.29	0.13	51.00	0.97	12.39	6.28	0.15
Run U3-Oil-100%-3	5/8/02	18:29:01	50.95	0.92	12.42	6.28	0.12	50.97	0.97	12.40	6.28	0.14
Run U3-Oil-100%-3	5/8/02	18:30:01	50.95	0.92	12.44	6.28	0.10	50.96	0.96	12.40	6.28	0.14
Run U3-Oil-100%-3	5/8/02	18:31:01	49.75	0.92	12.42	6.28	0.10	50.92	0.96	12.40	6.28	0.14
Run U3-Oil-100%-3	5/8/02	18:32:01	50.55	0.92	12.43	6.28	0.10	50.86	0.95	12.41	6.28	0.13
Run U3-Oil-100%-3	5/8/02	18:33:01	50.55	0.92	12.42	6.28	0.09	50.85	0.95	12.41	6.28	0.13
Run U3-Oil-100%-3	5/8/02	18:34:01	49.95	0.92	12.41	6.30	0.09	50.81	0.95	12.41	6.28	0.13
Run U3-Oil-100%-3	5/8/02	18:35:01	49.75	0.89	12.43	6.28	0.09	50.74	0.94	12.41	6.28	0.13
Run U3-Oil-100%-3	5/8/02	18:36:01	50.85	0.92	12.42	6.30	0.07	50.74	0.94	12.41	6.28	0.12
Run U3-Oil-100%-3	5/8/02	18:37:01	50.55	0.92	12.42	6.29	0.08	50.72	0.94	12.41	6.28	0.12
Run U3-Oil-100%-3	5/8/02	18:38:01	50.35	0.89	12.41	6.29	0.10	50.70	0.94	12.41	6.28	0.12
Run U3-Oil-100%-3	5/8/02	18:39:01	49.75	0.98	12.43	6.29	0.08	50.66	0.94	12.41	6.28	0.12
Run U3-Oil-100%-3	5/8/02	18:40:01	50.25	1.04	12.43	6.29	0.07	50.62	0.94	12.41	6.28	0.11
Run U3-Oil-100%-3	5/8/02	18:41:01	50.05	1.04	12.43	6.28	0.07	50.59	0.95	12.41	6.28	0.11
Run U3-Oil-100%-3	5/8/02	18:42:01	50.25	1.04	12.43	6.30	0.06	50.57	0.95	12.41	6.28	0.11
Run U3-Oil-100%-3	5/8/02	18:43:01	50.45	1.04	12.43	6.29	0.07	50.56	0.96	12.42	6.28	0.11
Run U3-Oil-100%-3	5/8/02	18:44:01	50.14	1.07	12.43	6.29	0.05	50.55	0.96	12.42	6.28	0.10
Run U3-Oil-100%-3	5/8/02	18:45:01	50.35	1.04	12.44	6.29	0.04	50.53	0.97	12.42	6.28	0.10
Run U3-Oil-100%-3	5/8/02	18:46:00	49.94	1.07	12.43	6.29	0.04	50.52	0.97	12.42	6.28	0.10
Run U3-Oil-100%-3	5/8/02	18:47:00	50.34	1.04	12.44	6.28	0.05	50.50	0.97	12.42	6.28	0.10
Run U3-Oil-100%-3	5/8/02	18:48:00	50.05	1.07	12.43	6.29	0.04	50.49	0.98	12.42	6.28	0.10
Run U3-Oil-100%-3	5/8/02	18:49:00	50.35	1.07	12.44	6.29	0.04	50.47	0.98	12.42	6.28	0.09
Run U3-Oil-100%-3	5/8/02	18:50:00	49.95	1.04	12.44	6.29	0.03	50.46	0.98	12.42	6.28	0.09
Run U3-Oil-100%-3	5/8/02	18:51:00	50.05	1.04	12.43	6.29	0.05	50.45	0.99	12.42	6.28	0.09
Run U3-Oil-100%-3	5/8/02	18:52:00	50.15	1.07	12.44	6.28	0.04	50.43	0.99	12.42	6.28	0.09
Run U3-Oil-100%-3	5/8/02	18:53:00	50.15	1.07	12.52	6.29	0.04	50.43	0.99	12.42	6.28	0.09
Run U3-Oil-100%-3	5/8/02	18:54:00	49.85	1.10	12.44	6.28	0.06	50.42	0.99	12.42	6.28	0.09
Run U3-Oil-100%-3	5/8/02	18:55:00	50.45	1.10	12.45	6.28	0.04	50.41	1.00	12.42	6.28	0.08
Run U3-Oil-100%-3	5/8/02	18:56:00	50.25	1.10	12.43	6.28	0.04	50.41	1.00	12.42	6.28	0.08
Run U3-Oil-100%-3	5/8/02	18:57:00	50.25	1.10	12.43	6.29	0.04	50.40	1.00	12.42	6.28	0.08
Run U3-Oil-100%-3	5/8/02	18:58:00	50.15	1.13	12.44	6.29	0.04	50.40	1.01	12.42	6.28	0.08
Run U3-Oil-100%-3	5/8/02	18:59:00	50.55	1.13	12.44	6.29	0.04	50.40	1.01	12.42	6.28	0.08
Run U3-Oil-100%-3	5/8/02	19:00:00	50.44	1.13	12.43	6.29	0.04	50.40	1.01	12.42	6.28	0.08
Run U3-Oil-100%-3	5/8/02	19:01:00	50.35	1.13	12.45	6.29	0.04	50.40	1.02	12.43	6.28	0.08
Run U3-Oil-100%-3	5/8/02	19:02:00	50.25	1.19	12.44	6.29	0.04	50.40	1.02	12.43	6.28	0.08
Run U3-Oil-100%-3	5/8/02	19:03:00	50.25	1.22	12.44	6.28	0.04	50.39	1.02	12.43	6.28	0.08



## Tampa Electric Polk Power Station, Unit 3 Fuel Oil Testing, Logged Data Records

Run Number	Date	Time	NOx (ppmv)	CO (ppmv)	O2 (% vol)	CO2 (% vol)	THC (ppmv)	AVE NOx (ppmv)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)	AVE THC (ppmv)
Run U3-Oil-100%-3	5/8/02	19:04:00	50.75	1.19	12.45	6.29	0.04	50.40	1.03	12.43	6.28	0.08
Run U3-Oil-100%-3	5/8/02	19:05:00	50.56	1.22	12.44	6.29	0.03	50.40	1.03	12.43	6.29	0.07
Run U3-Oil-100%-3	5/8/02	19:06:00	50.55	1.19	12.46	6.28	0.05	50.41	1.04	12.43	6.29	0.07
Run U3-Oil-100%-3	5/8/02	19:07:00	50.25	1.19	12.45	6.28	0.05	50.41	1.04	12.43	6.28	0.07
Run U3-Oil-100%-3	5/8/02	19:08:00	50.35	1.19	12.43	6.28	0.06	50.41	1.04	12.43	6.28	0.07
Run U3-Oil-100%-3	5/8/02	19:09:00	50.45	1.19	12.43	6.28	0.04	50.40	1.05	12.43	6.28	0.07
Run U3-Oil-100%-3	5/8/02	19:10:00	50.15	1.19	12.42	6.29	0.06	50.40	1.05	12.43	6.28	0.07
Run U3-Oil-100%-3	5/8/02	19:11:00	50.45	1.19	12.42	6.29	0.05	50.40	1.05	12.43	6.28	0.07
Run U3-Oil-100%-3	5/8/02	19:12:00	50.45	1.19	12.42	6.28	0.05	50.40	1.06	12.43	6.28	0.07
Run U3-Oil-100%-3	5/8/02	19:13:00	50.55	1.19	12.43	6.28	0.05	50.40	1.06	12.43	6.28	0.07
Run U3-Oil-100%-3	5/8/02	19:14:00	50.55	1.22	12.41	6.30	0.05	50.41	1.06	12.43	6.28	0.07
Run U3-Oil-100%-3	5/8/02	19:15:00	50.65	1.22	12.42	6.28	0.06	50.41	1.06	12.43	6.28	0.07
Run U3-Oil-100%-3	5/8/02	19:16:00	50.25	1.22	12.41	6.29	0.06	50.41	1.07	12.43	6.29	0.07
Run U3-Oil-100%-3	5/8/02	19:17:00	50.55	1.25	12.42	6.29	0.06	50.41	1.07	12.43	6.29	0.07
Run U3-Oil-100%-3	5/8/02	19:18:00	50.65	1.25	12.43	6.28	0.05	50.41	1.07	12.43	6.29	0.07
Run U3-Oil-100%-3	5/8/02	19:19:00	50.75	1.22	12.42	6.29	0.06	50.42	1.08	12.43	6.29	0.07
Run U3-Oil-100%-3	5/8/02	19:20:00	50.54	1.22	12.42	6.29	0.06	50.42	1.08	12.43	6.29	0.07
Run U3-Oil-100%-3	5/8/02	19:21:00	50.65	1.22	12.42	6.28	0.05	50.42	1.08	12.43	6.29	0.07
END Run U3-Oil-100%-3	5/8/02	19:22:00	50.25	1.25	12.42	6.29	0.05	50.42	1.08	12.43	6.29	0.07

**APPENDIX G:  
OPACITY OBSERVATIONS**

Visible Emission Observation Form

SOURCE NAME <b>Polk Power Station</b>			OBSERVATION DATE <b>5/7/02</b>				START TIME <b>12:47</b>				STOP TIME <b>13:47</b>			
ADDRESS <b>9995 SR 37 South</b>			SEC MIN	0	15	30	45	SEC MIN	0	15	30	45		
CITY <b>Mulberry</b>			STATE <b>FL</b>				ZIP <b>33860</b>				1		31	
PHONE <b>(941) 428-5914</b>			SOURCE ID NUMBER <b>010 (CT6-3)</b>				2		32		3		33	
PROCESS EQUIPMENT <b>Combustion turbine</b>			OPERATING MODE <b>99.7% load</b>				4		34		5		35	
CONTROL EQUIPMENT <b>DA 2.6 combustors</b>			OPERATING MODE <b>NORMAL</b>				6		36		7		37	
DESCRIBE EMISSION POINT <b>START ~120' round stack STOP 1st stack when viewed from South</b>			HEIGHT ABOVE GROUND LEVEL <b>START ~120' STOP ~120'</b>				8		38		9		39	
DISTANCE FROM OBSERVER <b>START ~360' STOP ~360'</b>			DIRECTION FROM OBSERVER <b>START 22° STOP 22°</b>				10		40		11		41	
DESCRIBE EMISSIONS <b>START none seen STOP same</b>			EMISSION COLOR <b>START n/a STOP n/a</b>				12		42		13		43	
WATER DROPLETS PRESENT: <b>NO <input checked="" type="checkbox"/> YES <input type="checkbox"/></b>			IF WATER DROPLET PLUME: <b>ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/></b>				14		44		15		45	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED <b>START stack exit STOP same</b>			DESCRIBE BACKGROUND <b>START SKY STOP same</b>				16		46		17		47	
BACKGROUND COLOR <b>START Blue/white STOP same</b>			SKY CONDITIONS <b>START Blue/white STOP same</b>				18		48		19		49	
WIND SPEED <b>START ~1-2 mph STOP 2-6 mph</b>			WIND DIRECTION <b>START E STOP E</b>				20		50		21		51	
AMBIENT TEMP. <b>START 91.2 STOP 70.5</b>			WET BULB TEMP <b>73.5</b>		RH, percent <b>31%</b>		22		52		23		53	
<p>Unit 1 Unit 2 Unit 3 Emission Point Main Road Main Road Sun's Location Line Observers Position</p>			24		54		25		55		26		56	
			27		57		28		58		29		59	
			30		60		AVERAGE OPACITY FOR HIGHEST PERIOD <b>0</b>				NUMBER OF READINGS ABOVE 10% WERE			
			RANGE OF OPACITY READINGS				MINIMUM <b>0</b>				MAXIMUM <b>0</b>			
			OBSERVER'S NAME (PRINT) <b>Koger Paul Osier</b>											
			COMMENTS						OBSERVER'S SIGNATURE <i>Koger Paul Osier</i>				DATE <b>5/7/02</b>	
			ORGANIZATION <b>Cobix Corporation</b>											
			I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS SIGNATURE <b>N/A</b>						CERTIFIED BY <b>ETH</b>				DATE <b>12/5/01</b>	
			TITLE <b>N/A</b>			DATE <b>N/A</b>			VERIFIED BY <b>12/5/01 N/A</b>				DATE <b>N/A</b>	

# VISIBLE EMISSIONS EVALUATOR

This is to certify that

*Roger Osier*

met the specifications of Federal Reference Method 9 and qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, North Carolina. This certificate is valid for six months from date of issue.

291694

Certificate Number

Jacksonville, Florida

Location

December 5, 2001

Date of Issue

Thomas Hore

President

Michael W. Linsford

Director of Training

# VISIBLE EMISSIONS EVALUATION

*This is to certify that*

*Roger Osier*

*did complete a course in the methods of determining opacity of visible emissions from sources as specified by Federal Reference Method 9 conducted by Eastern Technical Associates of Raleigh, North Carolina.*

*Evan Wainright*

Course Moderator

*Jacksonville, Florida*

Location

*June 8, 1999*

Date



**EASTERN  
TECHNICAL  
ASSOCIATES**

919-878-3188

DATE: JULY 8, 1999  
TO: FIELD CERTIFIERS  
FROM: EASTERN TECHNICAL ASSOCIATES  
REGARDING: JACKSONVILLE, FLORIDA  
VISIBLE EMISSIONS TRAINING PROGRAM

ETA is enclosing your certificates for Field Certification (Visible Emissions Evaluator) and/or Classroom Lecture attendance (Visible Emissions Evaluation). For your convenience, we have also enclosed a wallet card to indicate certification in the Field.

The following person(s) achieved a written test grade of 88% or more and therefore, if they maintain continuous field certification, are not required to attend the lecture again until thirty-six (36) months from this school. If an individual fails to recertify on any six (6) months anniversary, they would need to take the lecture at the next smoke school.

**CUBIX CORPORATION- ROGER OSIER**

We wish to congratulate you and invite you to recertify with us again. If we can be of further assistance, please do not hesitate to call.

Sincerely,

Sheila Weathersbee  
Administration  
Visible Emissions Program

Enclosure

P.O. BOX 58495  
RALEIGH, NC 27658

Visible Emission Observation Form

1655 DST

SOURCE NAME Tolk Tower Station - Unit #3			OBSERVATION DATE 5/8/2002				START TIME 1355pm				STOP TIME 1655 DST															
ADDRESS 9995 SR 37 South			SEC				SEC				SEC															
			MIN	0	15	30	45	MIN	0	15	30	45	MIN	0	15	30	45									
CITY Mulberry			STATE FL				ZIP 33860				1				∅	∅	∅	∅								
PHONE (941) 428-5914			SOURCE ID NUMBER 010 (6T6-3)				2				∅	∅	∅	∅	3				∅	∅	∅	∅				
PROCESS EQUIPMENT Combustion Turbine - firing oil			OPERATING MODE Base load				5				∅	∅	∅	∅	6				∅	∅	∅	∅				
CONTROL EQUIPMENT D/N burners no PM controls			OPERATING MODE W/F Ratio 1.35				7				∅	∅	∅	∅	8				∅	∅	∅	∅				
DESCRIBE EMISSION POINT START metal stack STOP same			9				∅	∅	∅	∅	10				∅	∅	∅	∅	11				∅	∅	∅	∅
HEIGHT ABOVE GROUND LEVEL START 114' STOP same			HEIGHT RELATIVE TO OBSERVER START 114' STOP same				12				∅	∅	∅	∅	13				∅	∅	∅	∅				
DISTANCE FROM OBSERVER START ~400' STOP same			DIRECTION FROM OBSERVER START E STOP same				14				∅	∅	∅	∅	15				∅	∅	∅	∅				
DESCRIBE EMISSIONS START ND STOP same			16				∅	∅	∅	∅	17				∅	∅	∅	∅	18				∅	∅	∅	∅
EMISSION COLOR START ND STOP same			PLUME TYPE CONTINUOUS <input type="checkbox"/>				19				∅	∅	∅	∅	20				∅	∅	∅	∅				
			FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>				21				∅	∅	∅	∅	22				∅	∅	∅	∅				
WATER DROPLETS PRESENT: NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>			IF WATER DROPLET PLUME: ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>				23				∅	∅	∅	∅	24				∅	∅	∅	∅				
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START ~20' above exit STOP same			25				∅	∅	∅	∅	26				∅	∅	∅	∅	27				∅	∅	∅	∅
DESCRIBE BACKGROUND START broken skies STOP same			28				∅	∅	∅	∅	29				∅	∅	∅	∅	30				∅	∅	∅	∅
BACKGROUND COLOR START blue/white STOP same			SKY CONDITIONS START broken STOP same				31				∅	∅	∅	∅	32				∅	∅	∅	∅				
WIND SPEED START gentle/mod STOP same			WIND DIRECTION START N/NW STOP same				33				∅	∅	∅	∅	34				∅	∅	∅	∅				
AMBIENT TEMP. START 92 STOP 93			WET BULB TEMP 71.8				RH percent ~38%				35				∅	∅	∅	∅	36				∅	∅	∅	∅
92 Source Layout Sketch Draw North Arrow			37				∅	∅	∅	∅	38				∅	∅	∅	∅	39				∅	∅	∅	∅
<p>The sketch shows an 'X' for the Emission Point. A vertical line goes down to a triangle representing the 'Sun Location Line' with a 140-degree angle. A horizontal arrow labeled 'Sun Wind' points right. A vertical line labeled 'Plume and Stack' goes down from the emission point. A circle with an arrow labeled 'Observers Position' is to the right. A north arrow is also present.</p>			40				∅	∅	∅	∅	41				∅	∅	∅	∅	42				∅	∅	∅	∅
			43				∅	∅	∅	∅	44				∅	∅	∅	∅	45				∅	∅	∅	∅
AVERAGE OPACITY FOR HIGHEST PERIOD			∅				NUMBER OF READINGS ABOVE % WERE																			
RANGE OF OPACITY READINGS			MINIMUM				MAXIMUM																			
OBSERVER'S NAME (PRINT)			Raymond A. McDarby																							
COMMENTS			ND = none detected				OBSERVER'S SIGNATURE				DATE															
certification number 292695							[Signature]				5/8/2002															
I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS SIGNATURE			CERTIFIED BY				DATE																			
			ETA				2/21/02																			
TITLE			DATE				VERIFIED BY				DATE															
							LJB				6/14/02															

RAY MCDARBY

has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.

8/21/2002

FIELD EXPIRATION DATE

292695

CERTIFICATION NUMBER

TMPF04

LECTURE EXPIRATION DATE




BEARER'S SIGNATURE



**APPENDIX H:  
OPERATIONAL DATA**


**UNIT OPERATIONAL AND EMISSION CURVES**

# General Electric Model PG7241 Gas Turbine Polk Unit 3 S/N 297953 Natural Gas Performance Curve



# NO<sub>x</sub> Emissions Curve


## Polk Unit 3 - Natural Gas Fuel



# CO Emissions Curve

## Polk Unit 3 - Natural Gas Fuel


### First 12 months of operation



# CO Emissions Curve


## Polk Unit 3 - Natural Gas Fuel

### After 12 months of operation




# VOC Emissions Curve

## Polk Unit 3 - Natural Gas Fuel



# SO<sub>2</sub> Emissions Curve

## Polk Unit 3 - Natural Gas Fuel







# GENERAL ELECTRIC MODEL PG7241(FA) GAS TURBINE

Effect of Compressor Inlet Temperature on  
Output, Heat Rate, Heat Consumption, Exhaust Flow  
And Exhaust Temperature at Baseload

Fuel: Natural Gas  
Design Values on Curve S22HA851 Rev A  
DLN Combustor





**General Electric Model PG7241 Gas Turbine**  
**Tampa Electric Company GR0697**  
**Estimated Performance**  
**Gas Turbine Generator(s) 297956 ONLY**

Design Conditions and Corresponding Correction Curves			Applicable Correction Curve Drawing Numbers				
	Units		Output	Heat Rate	Exhaust Flow	Exhaust Temp	Heat Consumption
Fuel		Natural Gas					
Fuel LHV	Btu/lb	See Gas Constituents					
Load		Base					
IGV Angle	degrees	82					
Diluent Injection Fluid		None					
Generator Frequency	hertz	60					
Generator Power Factor	ratio	0.90					
Compressor Inlet Temperature	F	90.00	Sheet 1	Sheet 2	N/A	N/A	N/A
Compressor Inlet Relative Humidity		51%	Sheet 3	Sheet 4	N/A	N/A	N/A
Ambient Temperature & Humidity		N/A	N/A	N/A	N/A	N/A	N/A
Shaft Speed	rpm	3600	N/A	N/A	N/A	N/A	N/A
Fuel Temperature	F	80	N/A	N/A	N/A	N/A	N/A
Inlet Pressure Loss	In H <sub>2</sub> O	4.00	N/A	N/A	N/A	N/A	N/A
Exhaust Pressure Loss	In H <sub>2</sub> O	5.50	N/A	N/A	N/A	N/A	N/A
Barometric Pressure	psia	14.63	Sheet 5	Sheet 6	N/A	N/A	N/A
Diluent Injection	lb/sec	0	N/A	N/A	N/A	N/A	N/A
Gas Fuel Composition		See Gas Constituents	N/A	N/A	N/A	N/A	N/A
<b>Gas Fuel Composition</b>							
Methane (CH <sub>4</sub> )	Mole Frac	0.9620					
Ethane (C <sub>2</sub> H <sub>6</sub> )	Mole Frac	0.0238					
Propane (C <sub>3</sub> H <sub>8</sub> )	Mole Frac	0.0019					
Isobutane (C <sub>4</sub> H <sub>10</sub> )	Mole Frac	0.0001					
N-Butane (C <sub>4</sub> H <sub>10</sub> )	Mole Frac	0.0001					
Isopentane (C <sub>5</sub> H <sub>12</sub> )	Mole Frac	0.0000					
N-Pentane (C <sub>5</sub> H <sub>12</sub> )	Mole Frac	0.0000					
Hexanes, Avg. (C <sub>6</sub> H <sub>14</sub> )	Mole Frac	0.0002					
Heptanes, Avg. (C <sub>7</sub> H <sub>16</sub> )	Mole Frac	0.0000					
Carbon Monoxide (CO)	Mole Frac	0.0000					
Carbon Dioxide (CO <sub>2</sub> )	Mole Frac	0.0067					
Hydrogen Sulfide (H <sub>2</sub> S)	Mole Frac	0.0000					
Air (N <sub>2</sub> O <sub>2</sub> )	Mole Frac	0.0000					
Hydrogen (H <sub>2</sub> )	Mole Frac	0.0000					
Oxygen (O <sub>2</sub> )	Mole Frac	0.0000					
Nitrogen (N <sub>2</sub> )	Mole Frac	0.0053					
Water (H <sub>2</sub> O)	Mole Frac	0.0000					
Gas Fuel LHV	Btu/lb	20886					
Gas Fuel H/C Ratio	ratio	3.94					

**Additional Notes:**  
No inlet air treatment

**General Electric Model PG7241 Gas Turbine  
Tampa Electric Company GR0697**


**Estimated Performance**

**Effect of Compressor Inlet Temperature on Output**

Design Values Referenced on 553HA3460 Rev A

Fuel: Natural Gas

Mode: Base



	Units										
Compressor Inlet Temperature	F	18.00	27.10	36.20	45.30	54.40	63.60	72.70	81.80	90.00	100.00
Output Ratio		1.24958	1.22827	1.20485	1.1799	1.1531	1.1212934	1.0838	1.04433935	1.0066	0.95772

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

### Effect of Compressor Inlet Temperature on Heat Rate

Design Values Referenced on 553HA3460 Rev A

Fuel: Natural Gas

Mode: Base



	Units										
Compressor Inlet Temperature	F	18.00	27.10	36.20	45.30	54.40	63.60	72.70	81.80	90.00	100.00
Heat Rate Ratio		0.939708	0.942329	0.94604	0.950722	0.956354	0.963409	0.971982	0.981978	0.992824	1.008745

C. Banares  
04/23/02

553HA3460 Rev A  
Sheet 2

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Relative Humidity on Output at Different Compressor Inlet Temperatures

Design Values Referenced on 553HA3460 Rev A

Fuel: Natural Gas

Mode: Base



		Compressor Inlet Temperature (F)					
		18.0	38.0	55.0	70.0	90.0	100.0
Relative Humidity - %	0	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000
	30	1.00014	1.00030	1.00025	0.99915	0.99636	0.99348
	40	1.00019	1.00040	1.00033	0.99885	0.99500	0.99121
	50	1.00024	1.00049	1.00041	0.99855	0.99361	0.98890
	60	1.00028	1.00059	1.00048	0.99824	0.99219	0.98653
	70	1.00033	1.00069	1.00058	0.99793	0.99074	0.98412
	80	1.00038	1.00079	1.00063	0.99761	0.98926	0.98165
	90	1.00042	1.00088	1.00070	0.99728	0.98776	0.97914
	100	1.00047	1.00098	1.00077	0.99694	0.98622	0.97659

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Relative Humidity on Heat Rate at Different Compressor Inlet Temperatures

Design Values Referenced on 553HA3460 Rev A

Fuel: Natural Gas

Mode: Base



Relative Humidity - %	Compressor Inlet Temperature (F)					
	18.0	38.0	55.0	70.0	90.0	100.0
0	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000
30	1.00013	1.00035	1.00080	1.00169	1.00413	1.00633
40	1.00018	1.00046	1.00107	1.00226	1.00560	1.00849
50	1.00022	1.00058	1.00134	1.00283	1.00708	1.01068
60	1.00026	1.00069	1.00161	1.00341	1.00857	1.01289
70	1.00031	1.00081	1.00188	1.00399	1.01008	1.01514
80	1.00035	1.00092	1.00215	1.00457	1.01160	1.01741
90	1.00040	1.00104	1.00243	1.00515	1.01314	1.01972
100	1.00044	1.00116	1.00270	1.00574	1.01469	1.02205

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Barometric Pressure on Output at Different Compressor Inlet Temps

Design Values Referenced on 553HA3460 Rev A

Fuel: Natural Gas

Mode: Base



		Compressor Inlet Temperature (F)					
		18.0	38.0	55.0	70.0	90.0	100.0
Barometric Pressure (psia)	13.90	0.948734	0.948409	0.948323	0.948187	0.947832	0.947611
	14.04	0.958991	0.958723	0.958660	0.958551	0.958268	0.958090
	14.19	0.969244	0.969040	0.968994	0.968915	0.968705	0.968568
	14.34	0.979498	0.979359	0.979330	0.979277	0.979139	0.979047
	14.63	1.000000	1.000000	1.000000	1.000000	1.000000	1.000000
	14.92	1.020500	1.020639	1.020671	1.020719	1.020844	1.020950
	15.07	1.030749	1.030959	1.031010	1.031078	1.031264	1.031419
	15.22	1.040998	1.041281	1.041350	1.041438	1.041684	1.041890
	15.36	1.051243	1.051599	1.051689	1.051796	1.052103	1.052356

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Barometric Pressure on Heat Rate at Different Compressor Inlet Temps

Design Values Referenced on 553HA3460 Rev A

Fuel: Natural Gas

Mode: Base



		Compressor Inlet Temperature (F)					
		18.0	38.0	55.0	70.0	90.0	100.0
Barometric Pressure (psia)	13.90	1.000644	1.000865	1.000927	1.001022	1.001312	1.001490
	14.04	1.000509	1.000688	1.000732	1.000807	1.001035	1.001178
	14.19	1.000377	1.000514	1.000543	1.000597	1.000765	1.000872
	14.34	1.000248	1.000341	1.000358	1.000393	1.000502	1.000575
	14.63	1.000000	1.000000	1.000000	1.000000	1.000000	1.000000
	14.92	0.999765	0.999674	0.999654	0.999625	0.999533	0.999452
	15.07	0.999652	0.999516	0.999482	0.999444	0.999308	0.999189
	15.22	0.999542	0.999362	0.999314	0.999267	0.999089	0.998932
	15.36	0.999435	0.999211	0.999149	0.999093	0.998876	0.998686



TECO Polk Unit 3  
Preliminary Performance Test Results  
4/25/02

Performance @ Contract Conditions		Test Point 1	Test Point 2	Test Point 3
<b>Performance Margins</b>				
Output Margin	%	0.71	0.68	0.77
Heat Rate Margin	%	1.82	1.74	1.61
<b>Performance Results</b>				
Generator Gross Output	KW	152499.28	152462.18	152591.81
Generator Net Output (Gross - Excitation)	KW	152321.66	152283.59	152411.81
Equipment Net Output (Generator Net - Aux)	KW	152026.57	151980.95	152112.95
Heat Consumption(LHV)	Mbtu/hr	1449.27	1450.06	1453.28
Generator Gross Heat Rate (LHV)	BTU/kWh	9503.44	9510.95	9523.97
Generator Net Heat Rate (LHV)	BTU/kWh	9514.53	9522.10	9535.22
Equipment Net Heat Rate (LHV)	BTU/kWh	9532.99	9541.07	9553.95
<b>Contract Conditions (Basis of Guarantee)</b>				
<b>Guarantee Parameters</b>				
Output	KW	150950	150950	150950
Heat Rate	BTU/kWh	9710	9710	9710
<b>Test Tolerances</b>				
Output Test Tolerance	%	2.09	2.09	2.09
Heat Rate Test Tolerance	%	1.94	1.94	1.94
<b>Turbine Definition</b>				
Frame Size	alpha	7FA+e	7FA+e	7FA+e
Turbine Serial Number	none	297956	297956	297956
Type of Combustion	alpha	DLN	DLN	DLN
<b>Basis of Guarantee</b>				
Load Condition (Base)	alpha	Base	Base	Base
Point of Output Guarantee (EquipNet)	alpha	EquipNet	EquipNet	EquipNet
Ambient Pressure	psia	14.63	14.63	14.63
Ambient Temperature	F	90.00	90.00	90
Ambient Specific Humidity	lb/lb	0.02	0.02	0.02
Compressor Inlet Temperature	°F	90	90	90
Compressor Inlet Specific Humidity	°F	0.02	0.02	0.02
Shaft Speed	rpm	3600	3600	3600
Power Factor	ratio	0.90	0.90	0.90
Inlet Pressure Loss	"H2O	4.00	4.00	4.00
Exhaust DP Measurement Location: (AO42OUT)	alpha	AO42OUT	AO42OUT	AO42OUT
Exhaust Pressure Loss F-Class AO42 Outlet	"H2O	5.50	5.50	5.5
Type Of Power Metering	alpha	Precision	Precision	Precision
Type Of Fuel (Gas, Oil)	alpha	Gas	Gas	Gas
Type Of Heating Value Used For Guarantee	alpha	LHV	LHV	LHV
Fuel Pressure	psia	450	450	450
Fuel Temperature	F	80	80	80
Evaporative Cooler Installed? (Yes, No)	alpha	No	No	No
Fired Hours Allowance	hours	100	100	100
<b>Contract Gas Fuel Composition</b>				
Methane (CH4)	Mole Frac	0.9620	0.9620	0.9620

TECO Polk Unit 3  
Preliminary Performance Test Results  
4/25/02

Ethane (C2H6)	Mole Frac	0.0238	0.0238	0.0238
Propane (C3H8)	Mole Frac	0.0019	0.0019	0.0019
Isobutane (C4H10)	Mole Frac	0.0001	0.0001	0.0001
N-Butane (C4H10)	Mole Frac	0.0001	0.0001	0.0001
Isopentane (C5H12)	Mole Frac	0.0000	0.0000	0.0000
N-Pentane (C5H12)	Mole Frac	0.0000	0.0000	0.0000
Hexanes, Avg. (C6H14)	Mole Frac	0.0002	0.0002	0.0002
Heptanes, Avg. (C7H16)	Mole Frac	0.0000	0.0000	0.0000
Carbon Monoxide (CO)	Mole Frac	0.0000	0.0000	0.0000
Carbon Dioxide (CO2)	Mole Frac	0.0067	0.0067	0.0067
Hydrogen Sulfide (H2S)	Mole Frac	0.0000	0.0000	0.0000
Air (N2O2)	Mole Frac	0.0000	0.0000	0.0000
Hydrogen (H2)	Mole Frac	0.0000	0.0000	0.0000
Oxygen (O2)	Mole Frac	0.0000	0.0000	0.0000
Nitrogen (N2)	Mole Frac	0.0053	0.0053	0.0053
Water (H2O)	Mole Frac	0.0000	0.0000	0.0000

**Test Measurements**

**Conditions**

Test Date	mm/dd/yy	23-Apr-02	23-Apr-02	23-Apr-02
Time at Start of Test	24hr	15:01:00	15:47:00	16:35:00
Test Duration	minutes	30	30	30
Test Point Designation	alpha	TP1	TP2	TP3
Performance Engineer		CRB	CRB	CRB

**Setup**

Type of Humidity Sensor (Psych or EHS)	alpha	EHS	EHS	EHS
Evaporative Coolers In Service? (Yes, No)	alpha	No	No	No
Fired Hours Since Offline Water Wash	hours	19.0	19.75	20.5
Combustion Mode	alpha	Pre-Mix	Pre-Mix	Pre-Mix

**Precision GT Measurements**

Ambient Pressure	psia	14.67	14.66	14.66
Ambient Dry Bulb Temperature	F	87.39	88.15	88.27
Ambient Relative Humidity	%	40.916	40.270	38.655
Inlet Air Total Pressure Drop	"H2O	2.57	2.57	2.56
Inlet Air Total Temperature	F	87.39	88.15	88.27
Bellmouth Throat Wall Static Air Pressure	"H2O	74.74	74.50	74.46
Compressor Discharge Pressure (CPD)	psig	201	200	200
Exhaust DP, Turbine AO42 Exit Flange	"H2O	1.55	1.52	1.49

**Control System GT Measurements**

Fired Hours	hours	67.3	68.1	68.8
Atmospheric Pressure	in Hg	29.9	29.9	29.9
Inlet Pressure Drop	"H2O	2.40	2.41	2.41
Compressor Inlet Temperature	F	89.00	89.71	89.68
Compressor Inlet Specific Humidity	lb/lb	0.0139	0.0139	0.0135
Bellmouth Pressure Depression	"H2O	75.42	75.12	75.19
Airflow	lb/s	914.70	912.41	912.71
Inlet Guide Vane Angle	degrees	82.1	82.1	82.1
Shaft Speed	rpm	3600	3599	3600
Compressor Discharge Pressure	psig	200.25	199.81	199.76
Compressor Pressure Ratio	psia/psia	14.73	14.70	14.70
Compressor Discharge Temperature	F	765.65	766.39	766.74
Cprs Inlet Bleed Heat Extraction Valve Position	%	-1.00	-1.01	-1.01

TECO Polk Unit 3  
Preliminary Performance Test Results

4/25/02

Gaseous Fuel Flow	lb/s	19.69	19.63	19.65
Combustion Reference Temperature	F	2390.10	2390.06	2389.77
Wheelspace Temp, 1st Fwd Inner Left (FLA)	F	887.26	888.71	888.19
Wheelspace Temp, 1st Fwd Inner Right	F	882.97	884.39	883.97
Wheelspace Temp, 1st Aft Left	F	928.74	929.77	929.65
Wheelspace Temp, 1st Aft Right	F	931.52	932.81	932.68
Wheelspace Temp, 2nd Fwd Left	F	940.58	942.13	942.23
Wheelspace Temp, 2nd Fwd Right	F	943.13	944.13	944.06
Wheelspace Temp, 2nd Aft Left	F	779.29	779.29	779.29
Wheelspace Temp, 2nd Aft Right	F	771.65	773.23	773.13
Wheelspace Temp, 3rd Fwd Left	F	808.87	811.35	811.94
Wheelspace Temp, 3rd Fwd Right	F	785.77	789.55	789.94
Wheelspace Temp, 3rd Aft Left	F	305.03	306.52	307.16
Wheelspace Temp, 3rd Aft Right	F	258.97	259.77	260.00
Exhaust Temperature Demand (Primary)	F	1134.55	1135.10	1135.55
Exhaust Temperature Demand (Secondary)	F	1187.94	1188.77	1188.84
Exhaust Temperature (TTXM)	F	1134.61	1135.35	1135.61
Exhaust Temperature Spread	F	45.58	45.81	47.19
Exhaust Pressure	"H2O	1.90	1.89	1.91

**Engineering Test Measurements**

**Generator Measurements**

Gross Output (Precision Metering)	KW	155340	154685	154715
Gross Output (Station Metering)	KW	155626	154964	155052
Gross Output (Control System Metering)	KW	155090	154410	154432
Generator Output (Other Metering)	KW			
Power Factor (Precision Metering)	ratio	0.991	0.991	0.990
Power Factor (Station Metering)	ratio	0.991	0.991	0.990
Power Factor (Control System Metering)	ratio	0.991	0.991	0.991
Power Factor (Other Metering)	ratio			
Excitation (Amount After Power Metering)	KW	178	179	180
GT Equipment Aux Power	KW	295	303	299
Transformer Losses	KW			

**Gas Fuel Temperature**

Flowing Temperature (at Contract Boundary Point)	°F	98.76	98.81	98.69
Flowing Temperature (At Final Inlet to GT)	°F	98.76	98.81	98.69

**Primary Gas Fuel Metering**

Type Of Meter (Vortex, Turbine, Annubar, or DP)	alpha	DP	DP	DP
Flowing Pressure (Absolute)	psia	465.00	464.86	464.92
Flowing Temperature (at Metering)	°F	98.76	98.81	98.69
Type of DP Flow Element	—	AGA_orifice	AGA_orifice	AGA_orifice
Differential Pressure	"H2O68°F	93.35	92.95	93.20
Pipe Diameter	inches	7.986	7.986	7.986
Throat Diameter	inches	5.120	5.120	5.120
Flowing Fluid	—	natgas	natgas	natgas
Pipe Meas. Temp	°F	50	50	50
Pipe Alpha	in/in-°F	9.25E-06	9.25E-06	9.25E-06
Throat Meas. Temp	°F	50	50	50
Throat Alpha	in/in-°F	9.25E-06	9.25E-06	9.25E-06

**Gas Fuel Composition**

Basis		Contract	Contract	Contract
-------	--	----------	----------	----------

TECO Polk Unit 3  
Preliminary Performance Test Results  
4/25/02

Methane (CH4)	Mole Frac	0.9620	0.9620	0.9620
Ethane (C2H6)	Mole Frac	0.0238	0.0238	0.0238
Propane (C3H8)	Mole Frac	0.0019	0.0019	0.0019
Isobutane (C4H10)	Mole Frac	0.0001	0.0001	0.0001
N-Butane (C4H10)	Mole Frac	0.0001	0.0001	0.0001
Isopentane (C5H12)	Mole Frac	0.0000	0.0000	0.0000
N-Pentane (C5H12)	Mole Frac	0.0000	0.0000	0.0000
Hexanes, Avg. (C6H14)	Mole Frac	0.0002	0.0002	0.0002
Heptanes, Avg. (C7H16)	Mole Frac	0.0000	0.0000	0.0000
Carbon Monoxide (CO)	Mole Frac	0.0000	0.0000	0.0000
Carbon Dioxide (CO2)	Mole Frac	0.0067	0.0067	0.0067
Hydrogen Sulfide (H2S)	Mole Frac	0.0000	0.0000	0.0000
Air (N2O2)	Mole Frac	0.0000	0.0000	0.0000
Hydrogen (H2)	Mole Frac	0.0000	0.0000	0.0000
Oxygen (O2)	Mole Frac	0.0000	0.0000	0.0000
Nitrogen (N2)	Mole Frac	0.0053	0.0053	0.0053
Water (H2O)	Mole Frac	0.0000	0.0000	0.0000

**Corrections**


**Output**

Inlet Temperature	ratio	0.9873	0.9908	0.9914
Inlet Humidity	ratio	0.9983	0.9983	0.9981
Ambient Pressure	ratio	0.9972	0.9977	0.9979
Generator Power Factor	ratio	0.9988	0.9988	0.9988
Fuel Composition	ratio	1.0000	1.0000	1.0000
Degradation	ratio	1.0000	1.0000	1.0000
Total Contract Correction	ratio	0.9817	0.9856	0.9863
Contract Corrected Generator Net Output	kW	152322	152284	152412

**Heat Rate**


Inlet Temperature	ratio	1.0040	1.0030	1.0028
Inlet Humidity	ratio	1.0019	1.0019	1.0021
Ambient Pressure	ratio	1.0001	1.0001	1.0000
Generator Power Factor	ratio	1.0012	1.0012	1.0012
Fuel Composition	ratio	1.0000	1.0000	1.0000
Degradation	ratio	1.0000	1.0000	1.0000
Total Contract Correction	ratio	1.0073	1.0062	1.0062
Contract Corrected Generator Net Heat Rate (LHV) BTU/kWh		9515	9522	9535

# General Electric Model PG7241 Gas Turbine Polk Unit 3 S/N 297953 Distillate Oil Performance Curve



# NO<sub>x</sub> Emissions Curve


## Polk Unit 3 - Distillate Oil Fuel



# CO Emissions Curve

## Polk Unit 3 - Distillate Oil Fuel


### First 12 months of operation



# CO Emissions Curve

## Polk Unit 3 - Distillate Oil Fuel


### After 12 months of operation






# VOC Emissions Curve

## Polk Unit 3 - Distillate Oil Fuel



# SO<sub>2</sub> Emissions Curve

## Polk Unit 3 - Distillate Oil Fuel





**General Electric Model PG7241 Gas Turbine**  
**Tampa Electric Company GR0697**  
**Estimated Performance**  
**Gas Turbine Generator(s) 297956 ONLY**

Design Conditions and Corresponding Correction Curves			Applicable Correction Curve Drawing Numbers				
	Units		Output	Heat Rate	Exhaust Flow	Exhaust Temp	Heat Consumption
Fuel		Distillate Oil					
Fuel LHV	Btu/lb	18300					
Load		Base					
IGV Angle	degrees	82					
Diluent Injection Fluid		Water					
Generator Frequency	hertz	60					
Generator Power Factor	ratio	0.90					
Compressor Inlet Temperature	F	90.00	Sheet 2	Sheet 3	N/A	N/A	N/A
Compressor Inlet Relative Humidity		51%	Sheet 4	Sheet 5	N/A	N/A	N/A
Ambient Temperature & Humidity		N/A	N/A	N/A	N/A	N/A	N/A
Shaft Speed	rpm	3600	N/A	N/A	N/A	N/A	N/A
Fuel Temperature	F	80	N/A	N/A	N/A	N/A	N/A
Inlet Pressure Loss	in H <sub>2</sub> O	4.00	N/A	N/A	N/A	N/A	N/A
Exhaust Pressure Loss	in H <sub>2</sub> O	5.50	N/A	N/A	N/A	N/A	N/A
Barometric Pressure	psia	14.63	Sheet 6	Sheet 7	N/A	N/A	N/A
Diluent Injection	lb/sec	28.461	Sheet 8	Sheet 9	N/A	N/A	N/A
Gas Fuel Composition		N/A	N/A	N/A	N/A	N/A	N/A
<b>Gas Fuel Composition</b>							
Methane (CH <sub>4</sub> )	Mole Frac	N/A					
Ethane (C <sub>2</sub> H <sub>6</sub> )	Mole Frac	N/A					
Propane (C <sub>3</sub> H <sub>8</sub> )	Mole Frac	N/A					
Isobutane (C <sub>4</sub> H <sub>10</sub> )	Mole Frac	N/A					
N-Butane (C <sub>4</sub> H <sub>10</sub> )	Mole Frac	N/A					
Isopentane (C <sub>5</sub> H <sub>12</sub> )	Mole Frac	N/A					
N-Pentane (C <sub>5</sub> H <sub>12</sub> )	Mole Frac	N/A					
Hexanes, Avg. (C <sub>6</sub> H <sub>14</sub> )	Mole Frac	N/A					
Heptanes, Avg. (C <sub>7</sub> H <sub>16</sub> )	Mole Frac	N/A					
Carbon Monoxide (CO)	Mole Frac	N/A					
Carbon Dioxide (CO <sub>2</sub> )	Mole Frac	N/A					
Hydrogen Sulfide (H <sub>2</sub> S)	Mole Frac	N/A					
Air (N <sub>2</sub> O <sub>2</sub> )	Mole Frac	N/A					
Hydrogen (H <sub>2</sub> )	Mole Frac	N/A					
Oxygen (O <sub>2</sub> )	Mole Frac	N/A					
Nitrogen (N <sub>2</sub> )	Mole Frac	N/A					
Water (H <sub>2</sub> O)	Mole Frac	N/A					
Gas Fuel LHV	Btu/lb	18300					
Gas Fuel H/C Ratio	ratio	#DIV/0!					

**Additional Notes:**  
No inlet air treatment

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

### Effect of Compressor Inlet Temperature on Output

Design Values Referenced on 553HA3461 Rev A

Fuel: Distillate Oil

Mode: Base



	Units										
Compressor Inlet Temperature	F	18.00	27.10	36.20	45.30	54.40	63.60	72.70	81.80	90.00	100.00
Output Ratio		1.25883	1.23611	1.21123	1.1857	1.1583	1.123784	1.0859	1.04539371	1.0069	0.957657

C. Banares  
04/23/03

553HA3461 Rev A  
Sheet 2

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

### Effect of Compressor Inlet Temperature on Heat Rate

Design Values Referenced on 553HA3461 Rev A

Fuel: Distillate Oil

Mode: Base



	Units										
Compressor Inlet Temperature	F	18.00	27.10	36.20	45.30	54.40	63.60	72.70	81.80	90.00	100.00
Heat Rate Ratio		0.935741	0.938967	0.943344	0.948239	0.954094	0.961634	0.970489	0.981187	0.992604	1.00894

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Relative Humidity on Output at Different Compressor Inlet Temperatures

Design Values Referenced on 553HA3461 Rev A

Fuel: Distillate Oil

Mode: Base



Relative Humidity - %	Compressor Inlet Temperature (F)					
	18.0	38.0	55.0	70.0	90.0	100.0
0	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000
30	1.00015	1.00029	1.00023	0.99913	0.99607	0.99347
40	1.00019	1.00038	1.00030	0.99883	0.99470	0.99118
50	1.00024	1.00048	1.00037	0.99852	0.99330	0.98886
60	1.00029	1.00057	1.00044	0.99820	0.99188	0.98648
70	1.00034	1.00067	1.00051	0.99788	0.99042	0.98406
80	1.00039	1.00076	1.00058	0.99755	0.98894	0.98160
90	1.00043	1.00086	1.00065	0.99722	0.98743	0.97908
100	1.00048	1.00095	1.00068	0.99688	0.98590	0.97652

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Relative Humidity on Heat Rate at Different Compressor Inlet Temperatures

Design Values Referenced on 553HA3461 Rev A

Fuel: Distillate Oil

Mode: Base



Relative Humidity - %	Compressor Inlet Temperature (F)					
	18.0	38.0	55.0	70.0	90.0	100.0
0	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000
30	1.00013	1.00035	1.00081	1.00171	1.00434	1.00636
40	1.00017	1.00047	1.00108	1.00229	1.00581	1.00854
50	1.00022	1.00058	1.00136	1.00287	1.00730	1.01074
60	1.00026	1.00070	1.00163	1.00345	1.00880	1.01297
70	1.00030	1.00082	1.00190	1.00403	1.01032	1.01522
80	1.00035	1.00093	1.00218	1.00462	1.01185	1.01751
90	1.00039	1.00105	1.00245	1.00521	1.01339	1.01982
100	1.00043	1.00117	1.00274	1.00580	1.01495	1.02216

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Barometric Pressure on Output at Different Compressor Inlet Temps

Design Values Referenced on 553HA3461 Rev A

Fuel: Distillate Oil

Mode: Base



		Compressor Inlet Temperature (F)					
		18.0	38.0	55.0	70.0	90.0	100.0
Barometric Pressure (psia)	13.90	0.948625	0.948395	0.948297	0.948147	0.947642	0.947581
	14.04	0.958899	0.958716	0.958639	0.958520	0.958115	0.958065
	14.19	0.969175	0.969037	0.968981	0.968892	0.968588	0.968548
	14.34	0.979450	0.979357	0.979321	0.979262	0.979059	0.979031
	14.49	0.989725	0.989647	0.989600	0.989520	0.989262	0.989234
	14.63	1.000000	1.000000	1.000000	1.000000	1.000000	1.000000
	14.78	1.020541	1.020647	1.020680	1.020734	1.020936	1.020960
	15.07	1.030813	1.030973	1.031013	1.031100	1.031397	1.031439
	15.22	1.041081	1.041297	1.041354	1.041466	1.041855	1.041917
15.36	1.051351	1.051623	1.051697	1.051830	1.052317	1.052394	



# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Barometric Pressure on Heat Rate at Different Compressor Inlet Temps

Design Values Referenced on 553HA3461 Rev A

Fuel: Distillate Oil

Mode: Base



		Compressor Inlet Temperature (F)					
		18.0	38.0	55.0	70.0	90.0	100.0
Barometric Pressure (psia)	13.90	1.000723	1.000881	1.000958	1.001065	1.001466	1.001530
	14.04	1.000574	1.000697	1.000756	1.000840	1.001158	1.001209
	14.19	1.000425	1.000517	1.000560	1.000621	1.000858	1.000897
	14.34	1.000280	1.000342	1.000369	1.000409	1.000565	1.000591
	14.63	1.000000	1.000000	1.000000	1.000000	1.000000	1.000000
	14.92	0.999735	0.999665	0.999647	0.999611	0.999463	0.999437
	15.07	0.999607	0.999502	0.999477	0.999424	0.999210	0.999166
	15.22	0.999483	0.999343	0.999309	0.999240	0.998965	0.998901
	15.36	0.999361	0.999187	0.999140	0.999062	0.998724	0.998642

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Water Injection on Output at Different Compressor Inlet Temps

Design Values Referenced on 553HA3461 Rev A

Fuel: Distillate Oil

Mode: Base



		Compressor Inlet Temperature (F)					
		18.0	38.0	55.0	70.0	90.0	100.0
Water Injection Flow (lb - sec)	0.00	1.000000	1.000000	1.000000	1.000000	1.000000	1.000000
	7.12	1.015082	1.018060	1.019591	1.023826	1.027923	1.029996
	14.23	1.029491	1.035504	1.038994	1.047469	1.055365	1.060129
	21.35	1.043453	1.051983	1.058204	1.070942	1.082375	1.089792
	28.46	1.057107	1.067676	1.076948	1.092294	1.108360	1.118594
	29.88	1.059809	1.070740	1.080556	1.096399	1.113536	1.124348
	31.31	1.062502	1.073781	1.084139	1.100493	1.118705	1.130096
	32.73	1.065187	1.076806	1.087679	1.104581	1.123868	1.135840
	34.15	1.067865	1.079812	1.091182	1.108658	1.129021	1.141581
	35.58	1.070534	1.082803	1.094646	1.112731	1.134167	1.147316

# General Electric Model PG7241 Gas Turbine Tampa Electric Company GR0697


## Estimated Performance

Effect of Water Injection on Heat Rate at Different Compressor Inlet Temps

Design Values Referenced on 553HA3461 Rev A

Fuel: Distillate Oil

Mode: Base



		Compressor Inlet Temperature (F)					
		18.0	38.0	55.0	70.0	90.0	100.0
Water Injection Flow (lb - sec)	0.00	1.000000	1.000000	1.000000	1.000000	1.000000	1.000000
	7.12	1.011657	1.010651	1.010543	1.010162	1.009074	1.008623
	14.23	1.023338	1.021249	1.020726	1.019910	1.017907	1.016601
	21.35	1.034917	1.032047	1.030569	1.029274	1.026494	1.024365
	28.46	1.046321	1.042948	1.040283	1.038558	1.035231	1.032191
	29.88	1.048578	1.045129	1.042266	1.040397	1.036934	1.033706
	31.31	1.050826	1.047310	1.044251	1.042224	1.038624	1.035205
	32.73	1.053065	1.049487	1.046245	1.044038	1.040299	1.036689
	34.15	1.055294	1.051660	1.048247	1.045841	1.041962	1.038158
	35.58	1.057516	1.053829	1.050258	1.047633	1.043611	1.039612

**NATURAL GAS TESTING OPERATIONAL DATA**

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp °F	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
<b>Run U3-NG-100%-1</b>									
07-May-02 10:17:00	158.2	1131.5	71794	760.3	82.9	203.4	82.0	30.01	2.28
07-May-02 10:18:00	158.1	1131.8	71580	760.6	83.2	203.1	82.0	30.01	2.28
07-May-02 10:19:00	157.8	1132.3	71658	760.8	83.3	202.8	82.0	30.01	2.28
07-May-02 10:20:00	157.7	1132.1	71522	762.2	83.4	202.9	82.0	30.01	2.28
07-May-02 10:21:00	158.5	1132.0	71736	760.9	83.4	203.2	82.0	30.01	2.28
07-May-02 10:22:00	158.1	1132.0	71646	760.6	83.4	203.4	82.0	30.01	2.28
07-May-02 10:23:00	158.1	1131.9	71726	760.5	83.6	203.1	82.0	30.01	2.28
07-May-02 10:24:00	157.9	1132.0	71406	761.0	83.8	202.7	82.0	30.01	2.28
07-May-02 10:25:00	158.1	1132.0	71794	761.0	83.9	203.1	82.0	30.01	2.28
07-May-02 10:26:00	158.1	1132.1	71388	761.0	84.1	203.3	82.0	30.01	2.28
07-May-02 10:27:00	158.2	1132.1	71466	761.1	83.7	203.4	82.0	30.01	2.28
07-May-02 10:28:00	157.9	1132.2	71646	761.3	84.1	202.9	82.0	30.01	2.28
07-May-02 10:29:00	157.6	1132.3	71478	761.6	84.6	202.4	82.0	30.01	2.28
07-May-02 10:30:00	157.1	1132.6	71242	763.3	85.5	202.4	82.0	30.01	2.28
07-May-02 10:31:00	156.7	1132.9	71388	763.0	85.6	202.4	82.0	30.01	2.28
07-May-02 10:32:00	156.9	1132.8	71297	763.3	85.6	202.4	82.0	30.01	2.28
07-May-02 10:33:00	157.0	1132.8	71252	761.8	85.4	202.5	82.0	30.01	2.28
07-May-02 10:34:00	156.9	1132.7	71242	761.8	85.3	202.6	82.0	30.01	2.28
07-May-02 10:35:00	157.0	1132.7	71343	762.0	85.0	202.3	82.0	30.01	2.29
07-May-02 10:36:00	157.3	1132.6	71342	762.6	84.8	202.4	82.0	30.01	2.29
07-May-02 10:37:00	157.1	1132.6	71297	762.3	85.3	202.5	82.0	30.01	2.29
07-May-02 10:38:00	157.0	1132.5	71342	761.6	85.5	202.6	82.0	30.01	2.29
07-May-02 10:39:00	157.1	1132.4	71512	761.3	84.9	202.7	82.0	30.01	2.29
07-May-02 10:40:00	157.7	1132.3	71558	761.5	84.8	202.7	82.0	30.01	2.29
07-May-02 10:41:00	157.7	1132.2	71535	761.5	84.8	202.8	82.0	30.01	2.29
07-May-02 10:42:00	157.5	1132.7	71342	762.3	85.0	202.8	82.0	30.01	2.29
07-May-02 10:43:00	157.3	1132.5	71298	763.0	85.4	202.2	82.0	30.01	2.29
07-May-02 10:44:00	157.4	1132.6	71422	762.8	85.5	202.4	82.0	30.01	2.29
07-May-02 10:45:00	157.3	1132.7	71286	762.3	85.3	202.6	82.0	30.01	2.29
07-May-02 10:46:00	157.3	1132.6	71512	761.9	85.1	202.7	82.0	30.01	2.29
07-May-02 10:47:00	157.3	1132.5	71522	761.5	84.9	202.7	82.0	30.01	2.29
07-May-02 10:48:00	157.9	1132.5	71422	761.3	84.7	202.7	82.0	30.01	2.29
07-May-02 10:49:00	157.7	1132.5	71422	761.7	84.6	202.6	82.0	30.01	2.29
07-May-02 10:50:00	157.5	1132.5	71444	762.0	84.6	202.6	82.0	30.01	2.29
07-May-02 10:51:00	157.5	1132.5	71434	762.4	84.8	201.8	82.0	30.01	2.29
07-May-02 10:52:00	157.3	1132.5	71150	762.7	84.9	202.8	82.0	30.01	2.29
07-May-02 10:53:00	157.4	1132.5	71467	762.7	85.1	202.4	82.0	30.01	2.29
07-May-02 10:54:00	157.4	1132.4	71500	762.6	85.2	202.5	82.0	30.01	2.29
07-May-02 10:55:00	157.2	1133.1	71206	763.3	85.5	202.3	82.0	30.01	2.30

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPi916	3PWRZI904	3TMSPi909	3TMSPDI912
07-May-02 10:56:00	156.8	1133.9	71140	763.5	85.9	201.9	82.0	30.01	2.30
07-May-02 10:57:00	156.9	1133.1	71298	763.6	86.4	202.6	82.0	30.01	2.30
07-May-02 10:58:00	157.2	1132.9	71298	763.3	86.1	202.6	82.0	30.01	2.30
07-May-02 10:59:00	157.2	1133.3	71389	762.9	85.9	202.5	82.0	30.01	2.30
07-May-02 11:00:00	156.7	1133.6	71286	763.2	85.6	202.5	82.0	30.01	2.30
07-May-02 11:01:00	157.1	1133.5	71376	762.6	85.5	202.7	82.0	30.01	2.30
07-May-02 11:02:00	157.1	1133.2	71151	763.1	85.3	202.2	82.0	30.01	2.30
07-May-02 11:03:00	156.7	1133.2	71252	762.5	85.2	202.0	82.0	30.01	2.30
07-May-02 11:04:00	156.5	1133.3	71166	762.5	85.1	202.1	82.0	30.01	2.30
07-May-02 11:05:00	157.3	1133.1	71388	762.5	85.0	202.3	82.0	30.01	2.30
07-May-02 11:06:00	157.1	1132.8	71376	762.4	84.8	202.3	82.0	30.01	2.30
07-May-02 11:07:00	157.2	1132.9	71422	761.9	84.8	202.6	82.0	30.01	2.30
07-May-02 11:08:00	157.4	1133.0	71602	762.1	84.8	202.4	82.0	30.01	2.30
07-May-02 11:09:00	157.0	1133.2	71357	762.8	84.9	202.5	82.0	30.01	2.30
07-May-02 11:10:00	157.0	1133.0	71128	762.9	85.4	202.6	82.0	30.01	2.30
07-May-02 11:11:00	156.8	1133.2	71242	763.0	85.9	202.4	82.0	30.01	2.30
07-May-02 11:12:00	156.4	1133.5	71330	763.2	86.1	202.4	82.0	30.00	2.30
07-May-02 11:13:00	156.3	1134.0	70892	764.5	86.4	201.9	82.0	30.00	2.30
07-May-02 11:14:00	156.4	1134.3	71041	764.4	86.7	201.9	82.0	30.00	2.30
07-May-02 11:15:00	156.3	1134.1	71026	763.9	86.8	201.8	82.0	30.00	2.31
07-May-02 11:16:00	156.4	1134.0	71150	763.4	86.4	201.8	82.0	30.00	2.31
07-May-02 11:17:00	156.6	1133.7	71206	763.0	86.1	202.2	82.0	30.00	2.31
<b>Average:</b>	<b>157.3</b>	<b>1132.8</b>	<b>71379</b>	<b>762.3</b>	<b>85.0</b>	<b>202.5</b>	<b>82.0</b>	<b>30.01</b>	<b>2.29</b>

Note: Operational data times adjusted to CEMS time by subtracting 1 hour and 2 minutes.

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJ1900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
<b>Run U3-NG-100%-2</b>									
07-May-02 11:30:00	156.4	1133.6	71118	763.8	87.1	201.9	82.0	30.00	2.29
07-May-02 11:31:00	156.7	1133.5	71330	763.6	86.5	202.3	82.0	30.00	2.29
07-May-02 11:32:00	156.8	1133.5	71286	762.8	85.9	202.6	82.0	30.00	2.30
07-May-02 11:33:00	156.6	1133.4	71185	763.1	85.4	202.3	82.0	30.00	2.30
07-May-02 11:34:00	156.3	1133.5	71128	763.7	85.4	202.2	82.0	30.00	2.30
07-May-02 11:35:00	156.8	1133.5	71118	763.3	85.5	202.1	82.0	30.00	2.30
07-May-02 11:36:00	157.1	1133.5	71286	762.9	85.6	202.1	82.0	30.00	2.30
07-May-02 11:37:00	156.9	1133.4	71162	763.4	85.6	202.2	82.0	30.00	2.30
07-May-02 11:38:00	156.7	1133.2	71184	763.4	85.6	202.2	82.0	30.00	2.30
07-May-02 11:39:00	157.1	1133.2	71264	763.1	85.7	202.0	82.0	30.00	2.30
07-May-02 11:40:00	157.2	1133.3	71118	763.0	85.9	201.9	82.0	30.00	2.30
07-May-02 11:41:00	156.4	1133.4	71206	763.0	86.2	201.9	82.0	30.00	2.30
07-May-02 11:42:00	156.5	1133.5	71060	763.3	86.4	202.3	82.0	30.00	2.30
07-May-02 11:43:00	156.2	1133.6	70936	764.1	86.6	201.9	82.0	30.00	2.30
07-May-02 11:44:00	156.5	1133.7	71139	763.9	86.8	201.9	82.0	30.00	2.30
07-May-02 11:45:00	156.5	1133.8	71072	763.3	86.7	202.0	82.0	30.00	2.30
07-May-02 11:46:00	156.2	1133.9	71162	763.9	86.9	201.8	82.0	30.00	2.30
07-May-02 11:47:00	155.5	1133.9	71016	764.2	87.1	201.8	82.0	30.00	2.30
07-May-02 11:48:00	155.7	1133.9	70848	764.6	87.2	201.3	82.0	30.00	2.30
07-May-02 11:49:00	155.8	1133.9	71072	764.6	87.0	201.7	82.0	30.00	2.30
07-May-02 11:50:00	155.9	1134.1	70936	764.1	86.9	201.7	82.0	30.00	2.30
07-May-02 11:51:00	155.6	1134.6	70848	764.2	86.8	201.4	82.0	30.00	2.30
07-May-02 11:52:00	156.1	1134.6	71026	763.7	86.6	201.4	82.0	30.00	2.30
07-May-02 11:53:00	156.2	1134.3	71060	764.2	86.7	201.5	82.0	30.00	2.30
07-May-02 11:54:00	156.3	1134.0	71057	764.5	86.8	201.6	82.0	30.00	2.30
07-May-02 11:55:00	155.7	1133.7	70847	764.7	87.0	201.6	82.0	30.00	2.30
07-May-02 11:56:00	156.4	1133.8	70936	764.8	87.2	202.0	82.0	30.00	2.30
07-May-02 11:57:00	155.8	1134.0	70848	764.6	87.5	201.7	82.0	30.00	2.30
07-May-02 11:58:00	155.4	1134.6	70834	765.3	87.8	201.5	82.0	30.00	2.30
07-May-02 11:59:00	155.8	1135.1	70564	765.1	88.1	201.3	82.0	30.00	2.30
07-May-02 12:00:00	154.8	1135.7	70609	765.8	88.4	201.2	82.0	30.00	2.30
07-May-02 12:01:00	155.0	1135.4	70712	766.2	88.8	201.2	82.0	30.00	2.30
07-May-02 12:02:00	155.6	1135.1	70768	765.3	88.5	201.2	82.0	30.00	2.30
07-May-02 12:03:00	155.5	1134.8	70834	765.1	88.0	201.4	82.0	30.00	2.30
07-May-02 12:04:00	155.9	1134.4	70848	764.8	87.6	201.6	82.0	30.00	2.30
07-May-02 12:05:00	155.8	1134.5	70848	764.7	87.4	201.8	82.0	30.00	2.31
07-May-02 12:06:00	155.6	1134.6	70802	764.5	87.1	201.3	82.0	30.00	2.31
07-May-02 12:07:00	155.5	1134.7	70895	764.3	86.9	201.8	82.0	30.00	2.31
07-May-02 12:08:00	155.8	1134.6	70880	764.1	86.6	201.5	82.0	30.00	2.31

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output	Turbine	Fuel Gas	Compressor	Compressor	Compressor	Inlet Guide Vane	Bar. Pressure	Air Inlet
	MW	Exhaust °F	Flow lbs/hr	Disc. Temp oF	Inlet Temp °F	Disc. Press. Psig	Angle Deg.	Hg	Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
07-May-02 12:09:00	156.5	1134.5	71026	764.3	86.4	201.8	82.0	30.00	2.31
07-May-02 12:10:00	155.3	1134.6	70654	765.6	87.2	201.5	82.0	30.00	2.31
07-May-02 12:11:00	155.1	1135.1	70712	766.1	88.1	201.2	82.0	30.00	2.31
07-May-02 12:12:00	155.4	1134.9	70926	765.3	88.2	201.4	82.0	30.00	2.31
07-May-02 12:13:00	155.6	1134.6	70959	765.0	88.1	201.6	82.0	30.00	2.31
07-May-02 12:14:00	155.9	1134.4	70756	765.0	88.1	201.7	82.0	30.00	2.31
07-May-02 12:15:00	155.5	1134.4	70670	765.3	88.0	201.5	82.0	30.00	2.31
07-May-02 12:16:00	155.9	1134.3	70880	765.7	88.2	201.4	82.0	30.00	2.31
07-May-02 12:17:00	156.0	1134.3	70746	765.3	88.1	201.4	82.0	30.00	2.31
07-May-02 12:18:00	155.3	1134.2	70620	765.1	87.9	201.4	82.0	30.00	2.31
07-May-02 12:19:00	155.3	1134.1	70848	764.9	87.7	201.4	82.0	30.00	2.31
07-May-02 12:20:00	155.8	1134.3	70892	764.9	87.4	201.1	82.0	30.00	2.31
07-May-02 12:21:00	155.1	1134.7	70936	765.3	87.4	201.3	82.0	30.00	2.31
07-May-02 12:22:00	155.4	1135.0	70779	765.4	87.3	200.9	82.0	30.00	2.31
07-May-02 12:23:00	155.7	1135.2	70922	764.9	87.2	201.3	82.0	30.00	2.31
07-May-02 12:24:00	155.3	1135.4	70756	765.5	87.5	201.2	82.0	30.00	2.31
07-May-02 12:25:00	154.8	1135.7	70564	766.3	88.2	200.8	82.0	30.00	2.31
07-May-02 12:26:00	154.6	1136.0	70518	766.6	88.8	200.5	82.0	30.00	2.31
07-May-02 12:27:00	155.3	1135.8	70700	766.1	89.0	200.9	82.0	30.00	2.31
07-May-02 12:28:00	154.4	1135.4	70486	766.0	88.8	200.9	82.0	30.00	2.31
07-May-02 12:29:00	155.2	1135.2	70667	766.0	88.5	200.7	82.0	30.00	2.31
07-May-02 12:30:00	155.2	1134.9	70790	765.6	88.2	201.0	82.0	30.00	2.31
<b>Average:</b>	<b>155.9</b>	<b>1134.3</b>	<b>70912</b>	<b>764.6</b>	<b>87.2</b>	<b>201.6</b>	<b>82.0</b>	<b>30.00</b>	<b>2.30</b>

Note: Operational data times adjusted to CEMS time by subtracting 1 hour and 2 minutes.



## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJ1900	3TMET1934	3FGSFT904CMP	3TMST1920B	3TMST1922M	3TMSP1916	3PWRZ1904	3TMSP1909	3TMSPDI912
<b>Run U3-NG-100%-3</b>									
07-May-02 12:47:00	155.0	1135.2	70576	765.8	87.9	201.3	82.0	30.00	2.30
07-May-02 12:48:00	154.8	1135.3	70712	765.8	87.8	201.0	82.0	30.00	2.30
07-May-02 12:49:00	155.1	1135.4	70700	765.6	87.9	200.8	82.0	30.00	2.30
07-May-02 12:50:00	154.7	1135.4	70666	766.3	88.2	201.1	82.0	30.00	2.30
07-May-02 12:51:00	154.4	1135.2	70620	766.4	88.6	200.9	82.0	30.00	2.30
07-May-02 12:52:00	155.1	1136.1	70620	767.1	88.9	200.7	82.0	30.00	2.30
07-May-02 12:53:00	154.6	1135.9	70576	767.2	89.2	200.6	82.0	30.00	2.30
07-May-02 12:54:00	154.8	1135.6	70248	766.1	89.5	200.5	82.0	30.00	2.30
07-May-02 12:55:00	154.7	1135.6	70486	765.9	89.4	200.8	82.0	30.00	2.30
07-May-02 12:56:00	154.5	1135.7	70532	765.6	89.0	200.7	82.0	30.00	2.30
07-May-02 12:57:00	155.1	1135.4	70474	765.3	88.6	200.8	82.0	30.00	2.30
07-May-02 12:58:00	155.2	1135.2	70564	764.8	88.2	201.1	82.0	30.00	2.30
07-May-02 12:59:00	155.7	1135.1	70847	764.4	88.1	200.9	82.0	30.00	2.30
07-May-02 13:00:00	154.8	1135.2	70564	765.2	88.1	200.9	82.0	30.00	2.30
07-May-02 13:01:00	154.9	1135.3	70880	765.2	87.9	200.6	82.0	30.00	2.30
07-May-02 13:02:00	155.7	1135.3	70532	765.0	87.6	201.0	82.0	30.00	2.30
07-May-02 13:03:00	155.0	1135.3	70666	764.8	87.6	200.3	82.0	30.00	2.30
07-May-02 13:04:00	155.1	1135.3	70692	764.7	87.8	200.8	82.0	30.00	2.30
07-May-02 13:05:00	155.3	1135.4	70745	764.6	88.0	201.2	82.0	30.00	2.30
07-May-02 13:06:00	155.3	1135.4	70620	765.2	88.2	200.9	82.0	30.00	2.30
07-May-02 13:07:00	155.0	1135.4	70554	766.2	88.5	200.8	82.0	30.00	2.30
07-May-02 13:08:00	154.6	1135.4	70474	766.5	88.8	201.0	82.0	30.00	2.30
07-May-02 13:09:00	154.5	1135.3	70576	766.3	89.1	200.6	82.0	30.00	2.30
07-May-02 13:10:00	155.2	1135.3	70712	765.8	88.9	200.8	82.0	30.00	2.30
07-May-02 13:11:00	155.2	1135.2	70620	765.4	88.6	200.5	82.0	30.00	2.30
07-May-02 13:12:00	154.8	1135.2	70486	765.6	88.5	201.0	82.0	30.00	2.30
07-May-02 13:13:00	155.2	1135.5	70620	766.0	88.4	200.5	82.0	30.00	2.30
07-May-02 13:14:00	155.2	1135.8	70620	766.1	88.3	200.6	82.0	30.00	2.30
07-May-02 13:15:00	154.7	1136.1	70610	765.1	88.7	200.5	82.0	30.00	2.30
07-May-02 13:16:00	155.0	1136.4	70654	765.4	88.6	200.5	82.0	30.00	2.30
07-May-02 13:17:00	154.7	1136.6	70518	765.5	88.5	200.1	82.0	30.00	2.30
07-May-02 13:18:00	154.6	1136.4	70532	765.3	88.4	200.1	82.0	30.00	2.30
07-May-02 13:19:00	154.8	1136.2	70609	765.3	88.4	200.7	82.0	30.00	2.30
07-May-02 13:20:00	155.2	1136.0	70700	765.3	88.3	200.8	82.0	30.00	2.30
07-May-02 13:21:00	154.8	1135.8	70564	765.4	88.3	200.5	82.0	30.00	2.30
07-May-02 13:22:00	154.9	1135.9	70576	766.3	88.6	200.2	82.0	30.00	2.30
07-May-02 13:23:00	154.4	1136.0	70486	766.6	89.0	200.8	82.0	30.00	2.30
07-May-02 13:24:00	154.5	1136.2	70361	767.0	89.5	200.1	82.0	30.00	2.30
07-May-02 13:25:00	154.7	1136.4	70474	766.3	89.8	200.1	82.0	30.00	2.30

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output	Turbine	Fuel Gas	Compressor	Compressor	Compressor	Inlet Guide Vane	Bar. Pressure	Air Inlet
	MW	Exhaust °F	Flow lbs/hr	Disc. Temp oF	Inlet Temp °F	Disc. Press. Psig	Angle Deg.	Hg	Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
07-May-02 13:26:00	154.3	1136.5	70396	765.8	89.5	200.3	82.0	30.00	2.30
07-May-02 13:27:00	155.0	1136.3	70532	765.8	89.3	200.1	82.0	30.00	2.30
07-May-02 13:28:00	155.1	1136.1	70328	765.4	89.0	200.3	82.0	30.00	2.30
07-May-02 13:29:00	154.8	1136.0	70532	765.2	88.8	200.5	82.0	30.00	2.30
07-May-02 13:30:00	154.6	1135.9	70700	765.0	88.5	200.6	82.0	30.00	2.30
07-May-02 13:31:00	155.3	1135.8	70790	764.8	88.3	200.5	82.0	30.00	2.30
07-May-02 13:32:00	155.1	1135.7	70711	764.7	88.1	200.8	82.0	30.00	2.30
07-May-02 13:33:00	155.0	1135.7	70598	764.8	88.0	200.6	82.0	30.00	2.30
07-May-02 13:34:00	154.9	1135.7	70564	765.2	88.1	200.5	82.0	30.00	2.31
07-May-02 13:35:00	154.6	1135.6	70576	765.9	88.1	200.4	82.0	30.00	2.31
07-May-02 13:36:00	153.9	1135.5	70532	766.1	88.2	200.4	82.0	30.00	2.31
07-May-02 13:37:00	154.8	1135.5	70459	766.1	88.3	200.5	82.0	30.00	2.31
07-May-02 13:38:00	155.0	1135.5	70666	766.1	88.6	200.5	82.0	30.00	2.31
07-May-02 13:39:00	155.1	1135.5	70666	766.1	88.8	201.0	82.0	30.00	2.31
07-May-02 13:40:00	154.6	1135.5	70486	767.2	89.1	199.6	82.0	30.00	2.31
07-May-02 13:41:00	154.9	1135.5	70306	766.6	89.1	200.4	82.0	30.00	2.31
07-May-02 13:42:00	155.1	1135.4	70576	765.9	89.1	200.5	82.0	30.00	2.31
07-May-02 13:43:00	154.4	1135.9	70486	766.7	89.1	200.3	82.0	30.00	2.31
07-May-02 13:44:00	154.5	1136.5	70260	766.9	89.1	200.2	82.0	30.00	2.31
07-May-02 13:45:00	154.5	1136.6	70396	766.3	89.1	200.3	82.0	30.00	2.31
07-May-02 13:46:00	154.3	1136.7	70474	766.5	89.1	200.1	82.0	30.00	2.31
07-May-02 13:47:00	154.0	1136.7	70396	766.9	89.1	200.2	82.0	30.00	2.31
<b>Average:</b>	<b>154.8</b>	<b>1135.7</b>	<b>70565</b>	<b>765.8</b>	<b>88.6</b>	<b>200.6</b>	<b>82.0</b>	<b>30.00</b>	<b>2.30</b>

Note: Operational data times adjusted to CEMS time by subtracting 1 hour and 2 minutes.

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPi916	3PWRZI904	3TMSPi909	3TMSPDI912
<b>Run U3-NG-50%-1</b>									
09-May-02 10:11:00	79.2	1200.8	46441	685.9	98.6	129.9	50.9	29.97	1.67
09-May-02 10:12:00	79.0	1199.1	46532	685.6	98.8	129.9	50.9	29.97	1.67
09-May-02 10:13:00	78.8	1198.6	46487	685.6	99.3	129.9	50.9	29.97	1.66
09-May-02 10:14:00	78.9	1199.8	46496	685.6	99.4	130.2	50.9	29.97	1.66
09-May-02 10:15:00	78.9	1200.6	46532	685.5	99.1	129.3	50.9	29.97	1.65
09-May-02 10:16:00	79.0	1200.5	46496	685.3	98.9	129.6	50.9	29.97	1.65
09-May-02 10:17:00	78.8	1199.6	46451	686.1	98.9	129.4	50.9	29.97	1.65
09-May-02 10:18:00	78.8	1198.6	46487	686.0	99.0	129.6	50.9	29.97	1.64
09-May-02 10:19:00	78.3	1199.6	46441	685.4	99.1	129.5	50.9	29.97	1.64
09-May-02 10:20:00	78.9	1200.8	46406	685.7	99.1	129.4	50.9	29.97	1.63
09-May-02 10:21:00	79.1	1199.4	46623	685.9	99.2	130.3	50.9	29.98	1.63
09-May-02 10:22:00	78.9	1199.8	46623	686.0	99.1	130.0	50.9	29.98	1.62
09-May-02 10:23:00	79.0	1201.0	46487	685.7	99.0	129.7	50.9	29.98	1.62
09-May-02 10:24:00	79.1	1199.8	46586	685.3	99.0	130.6	50.9	29.98	1.61
09-May-02 10:25:00	79.1	1199.4	46586	685.3	98.9	130.0	50.9	29.98	1.61
09-May-02 10:26:00	79.2	1198.7	46542	686.2	98.9	130.1	50.9	29.98	1.60
09-May-02 10:27:00	79.5	1200.9	46676	686.8	99.2	129.8	50.9	29.98	1.60
09-May-02 10:28:00	79.2	1198.5	46609	686.9	99.7	129.8	50.9	29.98	1.60
09-May-02 10:29:00	79.2	1200.8	46712	687.1	100.2	129.9	50.9	29.98	1.59
09-May-02 10:30:00	79.5	1199.9	46631	688.0	100.8	130.1	50.9	29.98	1.59
09-May-02 10:31:00	79.4	1201.0	46667	688.6	100.8	130.2	50.9	29.98	1.58
<b>Average:</b>	<b>79.0</b>	<b>1199.9</b>	<b>46548</b>	<b>686.1</b>	<b>99.3</b>	<b>129.9</b>	<b>50.9</b>	<b>29.98</b>	<b>1.63</b>

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp °F	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
<b>Run U3-NG-50%-2</b>									
09-May-02 10:39:00	78.9	1200.1	46550	686.5	100.1	130.2	50.9	29.98	1.63
09-May-02 10:40:00	78.9	1199.1	46315	686.8	100.0	129.5	50.9	29.98	1.63
09-May-02 10:41:00	78.9	1199.7	46451	687.1	99.9	129.7	50.9	29.98	1.62
09-May-02 10:42:00	79.0	1200.5	46383	686.6	99.7	129.6	50.9	29.98	1.62
09-May-02 10:43:00	78.9	1200.0	46542	686.2	100.0	129.3	50.9	29.98	1.62
09-May-02 10:44:00	78.7	1199.3	46496	687.1	100.4	129.4	50.9	29.98	1.62
09-May-02 10:45:00	78.9	1199.5	46542	687.2	100.8	129.8	50.9	29.98	1.62
09-May-02 10:46:00	79.2	1200.5	46682	687.2	101.3	130.0	50.9	29.98	1.61
09-May-02 10:47:00	79.3	1200.0	46623	688.6	101.8	130.1	50.9	29.98	1.61
09-May-02 10:48:00	79.4	1199.5	46600	688.8	101.6	129.8	50.9	29.98	1.61
09-May-02 10:49:00	79.3	1201.2	46667	688.3	101.8	130.0	50.9	29.98	1.61
09-May-02 10:50:00	79.2	1198.9	46676	687.9	101.7	129.5	50.9	29.98	1.60
09-May-02 10:51:00	79.2	1201.1	46583	687.4	101.5	129.4	50.9	29.98	1.60
09-May-02 10:52:00	79.1	1198.8	46605	687.8	101.3	129.8	50.9	29.98	1.60
09-May-02 10:53:00	78.7	1200.3	46812	688.1	101.1	130.4	50.9	29.98	1.60
09-May-02 10:54:00	79.0	1199.6	46745	687.9	100.8	130.2	50.9	29.98	1.59
09-May-02 10:55:00	79.1	1200.4	46631	687.9	100.6	129.7	50.9	29.98	1.59
09-May-02 10:56:00	79.5	1201.0	46790	688.1	100.6	130.2	50.9	29.98	1.59
09-May-02 10:57:00	80.2	1199.0	46848	688.6	100.2	130.3	50.9	29.98	1.59
09-May-02 10:58:00	79.6	1200.8	46983	688.4	100.0	130.5	50.9	29.98	1.58
09-May-02 10:59:00	79.5	1200.0	46767	687.6	100.1	130.5	50.9	29.98	1.58
<b>Average:</b>	<b>79.2</b>	<b>1200.0</b>	<b>46633</b>	<b>687.6</b>	<b>100.7</b>	<b>129.9</b>	<b>50.9</b>	<b>29.98</b>	<b>1.61</b>

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMET1934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
<b>Run U3-NG-50%-3</b>									
09-May-02 11:07:00	80.3	1200.1	47127	690.1	101.6	131.2	50.9	29.97	1.77
09-May-02 11:08:00	80.4	1198.6	46902	690.3	101.6	130.6	50.9	29.97	1.77
09-May-02 11:09:00	79.8	1201.5	46631	689.8	101.7	130.8	50.9	29.97	1.77
09-May-02 11:10:00	79.5	1199.6	46577	689.6	102.2	129.6	50.9	29.97	1.77
09-May-02 11:11:00	79.1	1201.0	46623	690.2	102.8	129.6	50.9	29.97	1.77
09-May-02 11:12:00	79.3	1198.9	46803	690.8	103.1	130.7	50.9	29.97	1.77
09-May-02 11:13:00	79.4	1201.0	46668	689.8	103.0	130.4	50.9	29.97	1.77
09-May-02 11:14:00	79.3	1199.6	46487	689.6	102.8	129.8	50.9	29.97	1.77
09-May-02 11:15:00	79.3	1200.3	46519	689.5	102.6	129.7	50.9	29.97	1.77
09-May-02 11:16:00	79.1	1199.5	46446	689.9	102.5	129.6	50.9	29.97	1.77
09-May-02 11:17:00	79.3	1200.0	46451	689.4	102.3	129.6	51.0	29.97	1.77
09-May-02 11:18:00	79.2	1201.2	46496	688.8	102.1	129.5	51.0	29.97	1.77
09-May-02 11:19:00	79.0	1199.9	46519	688.6	102.1	129.6	51.0	29.97	1.77
09-May-02 11:20:00	78.9	1199.1	46360	688.8	101.6	129.7	51.0	29.97	1.77
09-May-02 11:21:00	78.7	1200.8	46550	688.9	101.6	129.5	51.1	29.97	1.78
09-May-02 11:22:00	78.9	1199.0	46360	689.0	101.6	129.4	51.4	29.97	1.78
09-May-02 11:23:00	79.1	1200.8	46623	689.3	101.5	129.8	51.6	29.97	1.78
09-May-02 11:24:00	79.3	1198.6	46712	689.8	101.4	129.8	51.9	29.97	1.78
09-May-02 11:25:00	79.9	1199.7	46667	689.2	101.3	130.3	52.1	29.97	1.78
09-May-02 11:26:00	86.4	1201.3	48967	693.0	100.0	135.0	52.8	29.97	1.78
09-May-02 11:27:00	96.9	1194.6	52077	701.0	98.0	143.6	54.5	29.97	1.78
<b>Average:</b>	<b>80.5</b>	<b>1199.8</b>	<b>46979</b>	<b>690.3</b>	<b>101.8</b>	<b>130.9</b>	<b>51.4</b>	<b>29.97</b>	<b>1.77</b>

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output	Turbine	Fuel Gas	Compressor	Compressor	Compressor	Inlet Guide Vane	Bar. Pressure	Air Inlet
	MW	Exhaust °F	Flow lbs/hr	Disc. Temp oF	Inlet Temp °F	Disc. Press. Psig	Angle Deg.	Hg	Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPi916	3PWRZI904	3TMSPi909	3TMSPDI912
<b>Run U3-NG-65%-1</b>									
09-May-02 11:34:00	105.4	1182.8	54387	705.1	91.3	150.5	56.6	29.97	1.78
09-May-02 11:35:00	105.9	1181.9	54523	705.1	91.2	150.5	56.6	29.97	1.78
09-May-02 11:36:00	106.1	1184.0	54308	705.5	91.1	150.2	56.6	29.97	1.79
09-May-02 11:37:00	106.1	1183.2	54478	705.1	91.0	150.3	56.6	29.97	1.79
09-May-02 11:38:00	105.9	1180.9	54332	704.6	90.8	150.0	56.6	29.97	1.79
09-May-02 11:39:00	105.7	1181.8	54342	705.2	90.6	150.6	56.6	29.97	1.79
09-May-02 11:40:00	105.7	1183.2	54387	706.1	90.4	150.5	56.6	29.97	1.79
09-May-02 11:41:00	105.8	1183.7	54468	705.9	91.2	150.7	56.6	29.98	1.79
09-May-02 11:42:00	106.0	1184.2	54433	705.6	91.0	150.3	56.6	29.98	1.79
09-May-02 11:43:00	105.8	1181.6	54378	705.4	91.0	150.6	56.5	29.98	1.79
09-May-02 11:44:00	105.6	1182.0	54388	706.3	91.1	150.6	56.5	29.98	1.79
09-May-02 11:45:00	105.7	1183.7	54298	706.1	91.2	150.2	56.5	29.98	1.79
09-May-02 11:46:00	106.0	1183.9	54378	705.6	91.0	150.6	56.5	29.98	1.79
09-May-02 11:47:00	105.8	1185.8	54342	705.2	90.9	150.3	56.5	29.98	1.79
09-May-02 11:48:00	104.5	1186.9	53982	703.8	91.4	149.0	56.5	29.98	1.79
09-May-02 11:49:00	103.6	1183.9	53774	704.3	91.8	148.5	56.5	29.98	1.79
09-May-02 11:50:00	103.6	1185.8	53847	704.7	92.0	148.4	56.5	29.98	1.80
09-May-02 11:51:00	104.3	1185.4	53882	704.9	92.5	148.8	56.6	29.98	1.80
09-May-02 11:52:00	103.9	1185.4	53999	705.4	93.1	149.1	56.6	29.98	1.80
09-May-02 11:53:00	104.1	1185.9	53971	705.8	92.8	149.2	56.6	29.98	1.80
09-May-02 11:54:00	103.5	1188.6	53837	705.6	92.9	148.2	56.6	29.98	1.80
<b>Average:</b>	<b>105.2</b>	<b>1184.0</b>	<b>54225</b>	<b>705.3</b>	<b>91.4</b>	<b>149.9</b>	<b>56.6</b>	<b>29.98</b>	<b>1.79</b>

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJ1900	3TMET1934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
<b>Run U3-NG-65%-2</b>									
09-May-02 12:01:00	105.1	1183.4	54117	707.0	92.2	150.3	56.6	29.98	1.81
09-May-02 12:02:00	105.9	1184.0	54253	706.2	91.8	150.3	56.7	29.98	1.81
09-May-02 12:03:00	106.0	1184.8	54523	705.8	91.4	150.4	56.7	29.98	1.81
09-May-02 12:04:00	106.0	1186.6	54468	705.8	91.0	149.1	56.7	29.98	1.81
09-May-02 12:05:00	105.5	1182.9	54207	705.7	91.2	149.7	56.7	29.98	1.82
09-May-02 12:06:00	105.4	1185.8	54287	705.8	91.8	149.9	56.7	29.98	1.82
09-May-02 12:07:00	105.7	1182.9	54198	706.1	92.3	149.8	56.7	29.98	1.82
09-May-02 12:08:00	106.0	1183.4	54378	706.7	92.3	150.2	56.7	29.98	1.82
09-May-02 12:09:00	105.2	1184.6	54378	706.5	92.3	149.9	56.7	29.98	1.82
09-May-02 12:10:00	105.0	1184.4	54053	706.2	92.1	149.6	56.8	29.98	1.82
09-May-02 12:11:00	105.1	1183.2	54107	705.7	92.5	149.8	56.8	29.98	1.82
09-May-02 12:12:00	104.4	1185.5	54044	706.1	92.5	149.6	56.8	29.98	1.82
09-May-02 12:13:00	104.5	1184.7	54017	706.3	92.7	148.9	56.8	29.98	1.82
09-May-02 12:14:00	104.2	1184.9	53972	706.5	93.1	149.5	56.8	29.98	1.82
09-May-02 12:15:00	104.0	1186.1	53842	706.6	93.3	148.9	56.8	29.98	1.82
09-May-02 12:16:00	103.9	1185.9	53837	706.1	93.0	149.1	56.8	29.98	1.82
09-May-02 12:17:00	104.1	1184.4	53837	706.1	92.7	148.6	56.8	29.98	1.82
09-May-02 12:18:00	103.8	1186.4	53915	705.1	92.2	148.7	56.9	29.98	1.83
09-May-02 12:19:00	103.7	1184.2	53801	705.8	92.4	148.9	56.9	29.98	1.83
09-May-02 12:20:00	104.1	1186.6	53801	706.1	92.6	149.1	56.9	29.98	1.83
09-May-02 12:21:00	104.1	1185.0	53756	706.7	92.7	149.0	56.9	29.98	1.83
<b>Average:</b>	<b>104.9</b>	<b>1184.8</b>	<b>54085</b>	<b>706.1</b>	<b>92.3</b>	<b>149.5</b>	<b>56.8</b>	<b>29.98</b>	<b>1.82</b>

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
<b>Run U3-NG-65%-3</b>									
09-May-02 12:28:00	104.0	1184.7	53971	706.6	93.3	149.4	57.0	29.98	1.81
09-May-02 12:29:00	104.1	1184.4	53905	706.6	93.2	149.7	57.0	29.98	1.81
09-May-02 12:30:00	104.0	1186.3	53971	706.8	93.7	149.3	57.0	29.98	1.81
09-May-02 12:31:00	104.1	1185.2	53882	707.1	93.6	149.0	57.0	29.98	1.81
09-May-02 12:32:00	104.8	1184.7	54198	707.4	93.6	149.6	57.1	29.98	1.81
09-May-02 12:33:00	105.7	1184.7	54365	707.2	93.1	150.5	57.1	29.98	1.81
09-May-02 12:34:00	105.9	1183.8	54140	706.8	92.7	150.4	57.1	29.98	1.81
09-May-02 12:35:00	105.6	1184.5	54297	706.8	92.5	150.4	57.1	29.98	1.81
09-May-02 12:36:00	105.6	1183.2	54253	707.1	92.3	149.9	57.1	29.98	1.81
09-May-02 12:37:00	105.6	1182.7	54162	707.0	92.1	150.2	57.1	29.98	1.82
09-May-02 12:38:00	105.5	1185.0	54212	707.4	92.0	150.1	57.1	29.98	1.82
09-May-02 12:39:00	105.4	1181.8	54162	706.8	92.1	150.3	57.1	29.98	1.82
09-May-02 12:40:00	105.3	1183.3	54207	706.8	92.2	149.8	57.2	29.98	1.82
09-May-02 12:41:00	105.9	1184.4	54287	706.7	92.2	150.1	57.2	29.98	1.82
09-May-02 12:42:00	105.7	1185.2	54152	707.5	92.5	150.5	57.2	29.98	1.82
09-May-02 12:43:00	105.1	1183.6	54198	707.4	92.4	150.4	57.2	29.98	1.82
09-May-02 12:44:00	105.2	1186.6	54107	708.2	92.9	149.8	57.2	29.98	1.82
09-May-02 12:45:00	105.3	1184.8	54107	708.9	93.9	149.8	57.2	29.98	1.82
09-May-02 12:46:00	105.0	1185.0	54071	708.9	94.6	149.5	57.2	29.98	1.82
09-May-02 12:47:00	104.8	1185.9	54062	708.7	94.8	149.9	57.3	29.98	1.82
09-May-02 12:48:00	104.7	1186.5	53977	708.8	94.7	149.6	57.3	29.98	1.82
<b>Average:</b>	<b>105.1</b>	<b>1184.6</b>	<b>54128</b>	<b>707.4</b>	<b>93.1</b>	<b>149.9</b>	<b>57.1</b>	<b>29.98</b>	<b>1.82</b>



## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
<b>Run U3-NG-80%-1</b>									
09-May-02 12:56:00	131.3	1155.7	62098	728.1	86.6	174.5	64.6	29.98	1.85
09-May-02 12:57:00	131.5	1155.7	61953	728.6	86.6	174.6	64.6	29.98	1.85
09-May-02 12:58:00	131.2	1155.8	61918	728.4	86.6	174.2	64.5	29.98	1.85
09-May-02 12:59:00	130.5	1158.2	61728	726.4	86.8	173.4	64.5	29.98	1.86
09-May-02 13:00:00	130.3	1156.7	61660	726.0	86.1	172.8	64.5	29.98	1.86
09-May-02 13:01:00	130.1	1156.6	61557	726.0	86.3	173.2	64.5	29.98	1.86
09-May-02 13:02:00	129.9	1156.9	61637	726.4	86.7	173.1	64.5	29.98	1.86
09-May-02 13:03:00	129.8	1157.8	61502	726.7	87.0	173.0	64.4	29.98	1.86
09-May-02 13:04:00	129.8	1157.8	61592	727.2	87.2	172.9	64.4	29.98	1.86
09-May-02 13:05:00	129.8	1158.1	61592	727.7	87.3	172.9	64.4	29.98	1.86
09-May-02 13:06:00	129.8	1158.1	61603	726.7	87.4	172.9	64.4	29.98	1.86
09-May-02 13:07:00	129.8	1157.5	61660	726.0	87.4	173.0	64.4	29.98	1.86
09-May-02 13:08:00	129.8	1157.9	61643	726.4	87.4	173.1	64.4	29.98	1.86
09-May-02 13:09:00	129.7	1157.4	61620	725.4	87.3	173.1	64.3	29.98	1.86
09-May-02 13:10:00	129.7	1157.8	61643	726.1	87.3	173.1	64.3	29.98	1.86
09-May-02 13:11:00	129.6	1157.4	61693	727.1	87.2	173.1	64.3	29.98	1.86
09-May-02 13:12:00	129.6	1157.2	61739	727.5	87.0	172.7	64.3	29.98	1.87
09-May-02 13:13:00	129.5	1157.4	61633	726.5	86.9	172.6	64.3	29.98	1.87
09-May-02 13:14:00	129.5	1157.5	61603	725.8	86.8	172.5	64.2	29.98	1.87
09-May-02 13:15:00	129.5	1157.5	61377	726.1	86.7	172.4	64.2	29.98	1.87
09-May-02 13:16:00	129.5	1157.4	61637	726.3	86.6	172.4	64.2	29.98	1.87
<b>Average:</b>	<b>130.0</b>	<b>1157.2</b>	<b>61671</b>	<b>726.7</b>	<b>86.9</b>	<b>173.1</b>	<b>64.4</b>	<b>29.98</b>	<b>1.86</b>

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
<b>Run U3-NG-80%-2</b>									
09-May-02 13:22:00	129.9	1157.8	61457	726.1	87.1	172.5	64.3	29.97	1.73
09-May-02 13:23:00	129.8	1157.9	61547	726.3	87.3	172.7	64.3	29.97	1.73
09-May-02 13:24:00	129.8	1157.7	61592	726.5	87.6	172.9	64.3	29.97	1.73
09-May-02 13:25:00	129.7	1157.6	61529	726.7	87.9	172.7	64.2	29.97	1.73
09-May-02 13:26:00	129.6	1157.8	61547	728.1	88.3	172.6	64.2	29.97	1.73
09-May-02 13:27:00	129.5	1158.0	61546	727.5	88.2	172.7	64.2	29.97	1.73
09-May-02 13:28:00	129.5	1158.2	61592	726.9	88.1	172.5	64.2	29.97	1.73
09-May-02 13:29:00	129.4	1158.4	61592	727.5	87.7	172.3	64.2	29.97	1.73
09-May-02 13:30:00	129.3	1158.3	61412	726.7	88.4	172.2	64.2	29.97	1.73
09-May-02 13:31:00	129.2	1158.3	61321	726.4	88.3	172.0	64.2	29.97	1.73
09-May-02 13:32:00	129.1	1158.7	61287	726.7	88.1	172.0	64.2	29.97	1.73
09-May-02 13:33:00	129.0	1158.3	61175	727.1	88.0	172.1	64.1	29.97	1.73
09-May-02 13:34:00	129.0	1158.3	61287	727.5	88.5	172.2	64.1	29.97	1.73
09-May-02 13:35:00	129.0	1158.5	61287	726.8	87.8	172.3	64.1	29.97	1.73
09-May-02 13:36:00	129.1	1158.4	61491	726.5	87.6	172.2	64.1	29.97	1.73
09-May-02 13:37:00	129.1	1158.5	61457	726.5	87.7	171.9	64.1	29.97	1.73
09-May-02 13:38:00	129.3	1158.7	61512	727.4	88.5	172.5	64.1	29.97	1.73
09-May-02 13:39:00	129.4	1158.6	61546	728.4	88.6	172.3	64.1	29.97	1.73
09-May-02 13:40:00	129.4	1158.5	61512	728.6	88.7	172.7	64.1	29.97	1.73
09-May-02 13:41:00	129.5	1159.0	61615	727.9	88.8	172.7	64.0	29.97	1.73
09-May-02 13:42:00	129.5	1158.7	61557	728.4	88.8	172.3	64.0	29.97	1.73
<b>Average:</b>	<b>129.4</b>	<b>1158.3</b>	<b>61469</b>	<b>727.2</b>	<b>88.1</b>	<b>172.4</b>	<b>64.2</b>	<b>29.97</b>	<b>1.73</b>

## Unit 3 Operational Data, Natural Gas Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Gas Flow lbs/hr	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMETI934	3FGSFT904CMP	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSPI909	3TMSPDI912
<b>Run U3-NG-80%-3</b>									
09-May-02 13:49:00	129.0	1157.9	61412	727.3	87.8	172.3	63.9	29.97	1.66
09-May-02 13:50:00	129.2	1157.6	61592	727.3	88.0	172.3	63.9	29.97	1.66
09-May-02 13:51:00	129.5	1157.7	61682	727.6	88.1	172.6	63.9	29.97	1.66
09-May-02 13:52:00	129.4	1158.2	61557	727.8	88.4	172.5	63.9	29.97	1.66
09-May-02 13:53:00	129.2	1158.0	61603	728.3	88.7	172.4	63.9	29.97	1.66
09-May-02 13:54:00	129.1	1158.2	61508	728.1	88.6	172.0	63.9	29.97	1.66
09-May-02 13:55:00	128.4	1159.3	61423	727.7	88.3	171.8	63.9	29.97	1.66
09-May-02 13:56:00	128.8	1158.8	61197	728.1	88.5	171.7	63.9	29.97	1.66
09-May-02 13:57:00	128.8	1159.0	61242	728.2	88.8	172.0	63.8	29.97	1.66
09-May-02 13:58:00	128.8	1159.1	61287	728.8	89.1	172.0	63.8	29.97	1.66
09-May-02 13:59:00	128.7	1158.8	61107	727.6	89.0	172.2	63.8	29.97	1.66
09-May-02 14:00:00	128.7	1158.9	61321	728.5	88.9	171.9	63.8	29.97	1.66
09-May-02 14:01:00	128.7	1159.2	61276	727.8	88.8	171.6	63.8	29.97	1.66
09-May-02 14:02:00	128.7	1159.3	61377	728.9	88.8	172.0	63.8	29.97	1.66
09-May-02 14:03:00	128.7	1158.6	61440	729.2	88.6	172.2	63.8	29.97	1.66
09-May-02 14:04:00	128.7	1158.7	61468	727.1	88.4	172.1	63.8	29.97	1.66
09-May-02 14:05:00	128.7	1159.4	61321	726.5	87.9	171.9	63.7	29.97	1.66
09-May-02 14:06:00	128.7	1158.8	61332	726.1	87.6	171.7	63.7	29.97	1.66
09-May-02 14:07:00	128.7	1158.6	61395	727.3	88.3	171.7	63.7	29.97	1.66
09-May-02 14:08:00	128.7	1158.8	61298	729.1	89.0	172.1	63.7	29.97	1.66
09-May-02 14:09:00	128.1	1159.4	61186	728.4	89.2	171.4	63.7	29.97	1.66
<b>Average:</b>	<b>128.8</b>	<b>1158.7</b>	<b>61382</b>	<b>727.9</b>	<b>88.5</b>	<b>172.0</b>	<b>63.8</b>	<b>29.97</b>	<b>1.66</b>

**FUEL OIL TESTING OPERATIONAL DATA**

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output	Turbine	Fuel Oil Flow	Compressor	Compressor	Compressor	Inlet Guide Vane	H2O Injection	Water/Fuel	Bar. Pressure	Air Inlet
	MW	Exhaust °F	lbs/sec	Disc. Temp of F	Inlet Temp °F	Disc. Press. Psig	Angle Deg.	Rate lbs/sec	Ratio	Hg	Duct Loss H2O
	3PWRJI900	3TMETI934	3FOYFI900	3TMSTI920B	3TMSTI922M	3TMSPi916	3PWRZ1904	3TMSPi914		3TMSPi909	3TMSPDI912
<b>Run U3-Oil-50%-1</b>											
08-May-02 11:25:00	79.7	1199.2	15.3742	696.1	107.5	127.9	50.1	17.7401	1.15	29.97	0.78
08-May-02 11:26:00	79.9	1199.8	15.3728	695.7	107.3	128.2	50.1	17.7452	1.15	29.97	0.79
08-May-02 11:27:00	80.1	1199.5	15.3714	695.8	107.0	127.7	50.1	17.7503	1.15	29.97	0.79
08-May-02 11:28:00	80.0	1201.8	15.3700	695.6	107.9	128.1	50.1	17.7554	1.16	29.97	0.79
08-May-02 11:29:00	80.0	1200.6	15.3686	696.7	107.8	128.3	50.2	17.7605	1.16	29.97	0.80
08-May-02 11:30:00	80.0	1199.6	15.3672	696.1	107.8	127.9	50.2	17.7655	1.16	29.97	0.80
08-May-02 11:31:00	80.0	1199.8	15.3658	695.9	107.8	128.4	50.2	17.7706	1.16	29.97	0.81
08-May-02 11:32:00	80.0	1199.3	15.3644	696.4	107.6	128.0	50.2	17.7757	1.16	29.97	0.81
08-May-02 11:33:00	79.9	1198.9	15.3631	696.1	107.4	127.9	50.2	17.7808	1.16	29.97	0.81
08-May-02 11:34:00	79.7	1198.9	15.3617	696.6	107.1	128.2	50.2	17.7859	1.16	29.97	0.82
08-May-02 11:35:00	79.8	1200.0	15.3603	696.6	106.9	128.0	50.2	17.7909	1.16	29.97	0.82
08-May-02 11:36:00	79.9	1201.7	15.3589	696.6	106.7	128.1	50.2	17.7960	1.16	29.97	0.82
08-May-02 11:37:00	79.8	1201.8	15.3575	696.2	106.6	128.1	50.2	17.8011	1.16	29.97	0.83
08-May-02 11:38:00	79.6	1198.2	15.3561	695.5	106.4	128.0	50.2	17.8062	1.16	29.97	0.83
08-May-02 11:39:00	80.0	1202.0	15.3609	696.1	106.3	128.5	50.2	17.8113	1.16	29.97	0.84
08-May-02 11:40:00	79.7	1198.4	15.3704	696.7	106.6	128.0	50.3	17.8163	1.16	29.97	0.84
08-May-02 11:41:00	79.7	1198.6	15.3799	696.5	107.0	128.3	50.3	17.8214	1.16	29.97	0.84
08-May-02 11:42:00	79.8	1200.3	15.3894	696.2	107.0	128.3	50.3	17.8265	1.16	29.97	0.85
08-May-02 11:43:00	79.6	1201.2	15.3989	696.7	107.1	128.2	50.3	17.8316	1.16	29.97	0.85
08-May-02 11:44:00	79.9	1201.4	15.4084	697.3	107.2	128.4	50.3	17.8367	1.16	29.97	0.85
08-May-02 11:45:00	80.2	1198.2	15.4179	695.9	107.3	128.3	50.3	17.8418	1.16	29.97	0.86
<b>Average:</b>	<b>79.9</b>	<b>1200.0</b>	<b>15.3732</b>	<b>696.2</b>	<b>107.2</b>	<b>128.1</b>	<b>50.2</b>	<b>17.7909</b>	<b>1.16</b>	<b>29.97</b>	<b>0.82</b>
<b>Run U3-Oil-50%-2</b>											
08-May-02 11:53:00	79.7	1201.0	15.4939	696.5	108.4	128.2	50.4	17.8824	1.15	29.96	1.10
08-May-02 11:54:00	79.5	1200.4	15.5034	697.0	108.4	128.0	50.4	17.8875	1.15	29.96	1.10
08-May-02 11:55:00	80.0	1201.1	15.5129	696.7	108.9	127.9	50.4	17.8926	1.15	29.96	1.11
08-May-02 11:56:00	79.4	1202.1	15.5224	697.1	108.4	128.4	50.4	17.8976	1.15	29.96	1.11
08-May-02 11:57:00	79.8	1201.3	15.5319	697.3	108.3	127.9	50.4	17.9027	1.15	29.96	1.12
08-May-02 11:58:00	79.3	1200.5	15.5414	696.6	108.0	127.9	50.4	17.9078	1.15	29.96	1.12
08-May-02 11:59:00	79.2	1199.5	15.5510	696.0	107.8	128.0	50.4	17.9129	1.15	29.96	1.13
08-May-02 12:00:00	79.0	1199.4	15.5605	695.6	107.6	127.6	50.4	17.9180	1.15	29.96	1.13
08-May-02 12:01:00	79.9	1200.4	15.5700	696.4	107.3	128.0	50.4	17.9231	1.15	29.96	1.14
08-May-02 12:02:00	80.1	1199.0	15.5795	697.4	107.3	128.4	50.5	17.9281	1.15	29.96	1.14
08-May-02 12:03:00	81.0	1199.2	15.5890	697.4	107.3	128.5	50.5	17.9332	1.15	29.96	1.15
08-May-02 12:04:00	80.6	1202.0	15.5985	697.2	107.3	128.3	50.5	17.9383	1.15	29.96	1.15
08-May-02 12:05:00	80.3	1199.3	15.6080	697.8	107.5	128.2	50.5	17.9434	1.15	29.96	1.15
08-May-02 12:06:00	80.3	1199.0	15.6175	697.5	107.7	128.4	50.5	17.9485	1.15	29.96	1.16
08-May-02 12:07:00	81.1	1201.7	15.6270	697.9	107.6	128.8	50.5	17.9535	1.15	29.96	1.16
08-May-02 12:08:00	80.6	1197.9	15.6365	697.9	107.4	128.8	50.5	17.9586	1.15	29.96	1.17
08-May-02 12:09:00	80.7	1200.7	15.6460	697.9	107.3	128.4	50.5	17.9637	1.15	29.96	1.17
08-May-02 12:10:00	81.0	1200.8	15.6555	698.2	107.4	129.4	50.5	17.9688	1.15	29.96	1.18
08-May-02 12:11:00	80.8	1198.9	15.6650	699.0	107.5	128.8	50.5	17.9739	1.15	29.96	1.18
08-May-02 12:12:00	81.3	1199.2	15.6745	698.5	107.6	128.8	50.5	17.9789	1.15	29.96	1.19
08-May-02 12:13:00	81.0	1201.5	15.6840	698.4	107.4	128.8	50.6	17.9840	1.15	29.96	1.19
<b>Average:</b>	<b>80.2</b>	<b>1200.2</b>	<b>15.5890</b>	<b>697.3</b>	<b>107.7</b>	<b>128.3</b>	<b>50.5</b>	<b>17.9332</b>	<b>1.15</b>	<b>29.96</b>	<b>1.15</b>

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output	Turbine	Fuel Oil Flow	Compressor	Compressor	Compressor	Inlet Guide Vane	H2O Injection	Water/Fuel	Bar. Pressure	Air Inlet
	MW	Exhaust °F	lbs/sec	Disc. Temp of	Inlet Temp °F	Disc. Press. Psig	Angle Deg.	Rate lbs/sec	Ratio	Hg	Duct Loss H2O
	3PWRJI900	3TMETI934	3FOYFI900	3TMSTI920B	3TMSTI922M	3TMSP1916	3PWRZI904	3TMSEFI914		3TMSP1909	3TMSPDI912
<b>Run U3-Oil-50%-3</b>											
08-May-02 12:24:00	79.9	1198.6	15.7886	698.3	108.5	128.1	50.6	18.0399	1.14	29.96	1.22
08-May-02 12:25:00	80.2	1201.4	15.7981	697.6	108.2	128.8	50.6	18.0450	1.14	29.96	1.23
08-May-02 12:26:00	80.1	1197.9	15.8076	697.6	107.9	128.5	50.6	18.0501	1.14	29.96	1.23
08-May-02 12:27:00	80.1	1201.8	15.8171	697.6	107.6	128.1	50.6	18.0552	1.14	29.96	1.24
08-May-02 12:28:00	80.0	1197.9	15.8266	697.2	107.8	128.3	50.6	18.0602	1.14	29.96	1.24
08-May-02 12:29:00	80.0	1201.3	15.8361	697.6	107.9	128.3	50.6	18.0653	1.14	29.96	1.25
08-May-02 12:30:00	80.0	1198.1	15.8456	698.2	108.0	128.3	50.6	18.0704	1.14	29.96	1.25
08-May-02 12:31:00	80.0	1201.5	15.8551	698.3	108.1	128.3	50.6	18.0755	1.14	29.96	1.25
08-May-02 12:32:00	80.0	1199.3	15.8646	697.7	108.2	128.2	50.6	18.0806	1.14	29.96	1.26
08-May-02 12:33:00	80.1	1200.0	15.8741	698.3	108.3	128.5	50.6	18.0856	1.14	29.96	1.26
08-May-02 12:34:00	80.2	1199.2	15.8836	697.2	108.4	128.5	50.6	18.0907	1.14	29.96	1.27
08-May-02 12:35:00	79.9	1200.7	15.8931	697.7	108.5	128.3	50.6	18.0958	1.14	29.96	1.27
08-May-02 12:36:00	80.0	1200.6	15.9026	697.9	108.5	128.4	50.6	18.1009	1.14	29.96	1.28
08-May-02 12:37:00	79.9	1200.8	15.9121	699.0	108.6	128.6	50.6	18.1060	1.14	29.96	1.28
08-May-02 12:38:00	80.1	1199.1	15.9216	699.3	108.7	128.6	50.6	18.1111	1.14	29.96	1.29
08-May-02 12:39:00	80.6	1200.9	15.9312	699.3	108.8	128.4	50.6	18.1161	1.14	29.96	1.29
08-May-02 12:40:00	80.2	1198.9	15.9407	698.7	108.6	128.8	50.6	18.1212	1.14	29.96	1.30
08-May-02 12:41:00	80.1	1199.6	15.9502	698.6	108.8	128.1	50.6	18.1263	1.14	29.96	1.30
08-May-02 12:42:00	80.0	1200.3	15.9597	698.4	108.4	128.4	50.6	18.1314	1.14	29.96	1.30
08-May-02 12:43:00	87.1	1202.8	16.1877	703.8	108.0	135.1	51.5	18.6229	1.15	29.96	1.31
08-May-02 12:44:00	98.5	1195.1	17.0713	712.4	104.8	142.2	53.1	20.0875	1.18	29.96	1.31
<b>Average:</b>	<b>81.3</b>	<b>1199.8</b>	<b>15.9461</b>	<b>699.1</b>	<b>108.1</b>	<b>129.4</b>	<b>50.7</b>	<b>18.2066</b>	<b>1.14</b>	<b>29.96</b>	<b>1.27</b>
<b>Run U3-Oil-65%-1</b>											
08-May-02 12:53:00	110.6	1184.1	18.5771	719.5	97.1	150.5	55.6	22.7935	1.23	29.96	1.28
08-May-02 12:54:00	110.9	1185.4	18.5836	719.3	97.1	150.5	55.6	22.7999	1.23	29.96	1.29
08-May-02 12:55:00	110.6	1186.7	18.5901	720.0	97.1	151.0	55.6	22.8062	1.23	29.96	1.29
08-May-02 12:56:00	111.0	1186.4	18.5967	720.3	96.6	150.9	55.6	22.8125	1.23	29.96	1.30
08-May-02 12:57:00	110.4	1182.4	18.6032	719.4	96.8	150.5	55.6	22.8189	1.23	29.96	1.30
08-May-02 12:58:00	110.6	1187.3	18.6097	719.5	97.0	150.3	55.6	22.8252	1.23	29.96	1.31
08-May-02 12:59:00	110.2	1184.9	18.6162	720.4	97.5	150.4	55.6	22.8315	1.23	29.96	1.31
08-May-02 13:00:00	109.9	1186.2	18.6227	720.1	97.8	150.4	55.6	22.8378	1.23	29.96	1.31
08-May-02 13:01:00	109.9	1185.3	18.6292	720.1	97.4	150.6	55.6	22.8442	1.23	29.96	1.32
08-May-02 13:02:00	110.6	1184.7	18.6357	720.9	98.5	150.3	55.6	22.8505	1.23	29.96	1.32
08-May-02 13:03:00	110.2	1187.3	18.6422	721.0	98.4	150.5	55.6	22.8568	1.23	29.96	1.33
08-May-02 13:04:00	110.8	1188.4	18.6487	722.4	98.5	150.9	55.6	22.8632	1.23	29.96	1.33
08-May-02 13:05:00	110.6	1184.4	18.6552	721.4	98.0	151.8	55.6	22.8695	1.23	29.96	1.34
08-May-02 13:06:00	110.9	1183.9	18.6617	721.3	97.5	151.1	55.6	22.8758	1.23	29.96	1.34
08-May-02 13:07:00	110.6	1187.3	18.6682	720.6	97.1	150.9	55.6	22.8822	1.23	29.96	1.34
08-May-02 13:08:00	110.4	1184.4	18.6747	720.6	97.4	150.8	55.6	22.8885	1.23	29.96	1.35
08-May-02 13:09:00	110.5	1184.5	18.6813	720.6	97.3	151.1	55.6	22.8948	1.23	29.96	1.35
08-May-02 13:10:00	110.9	1187.1	18.6878	721.1	97.6	150.8	55.6	22.9012	1.23	29.96	1.36
08-May-02 13:11:00	110.8	1185.2	18.6943	720.1	97.3	151.3	55.6	22.9075	1.23	29.96	1.36
08-May-02 13:12:00	111.0	1183.9	18.7008	720.1	97.3	151.4	55.6	22.9138	1.23	29.96	1.37
08-May-02 13:13:00	110.8	1187.0	18.7073	720.0	97.3	149.8	55.6	22.9202	1.23	29.96	1.37
<b>Average:</b>	<b>110.6</b>	<b>1185.6</b>	<b>18.6422</b>	<b>720.4</b>	<b>97.5</b>	<b>150.8</b>	<b>55.6</b>	<b>22.8568</b>	<b>1.23</b>	<b>29.96</b>	<b>1.33</b>

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output	Turbine	Fuel Oil Flow	Compressor	Compressor	Compressor	Inlet Guide Vane	H2O Injection	Water/Fuel	Bar. Pressure	Air Inlet
	MW	Exhaust °F	lbs/sec	Disc. Temp of	Inlet Temp °F	Disc. Press. Psig	Angle Deg.	Rate lbs/sec	Ratio	Hg	Duct Loss H2O
	3PWRJI900	3TMETI934	3FOYFI900	3TMSTI920B	3TMSTI922M	3TMSPi916	3PWRZI904	3TMSFI914		3TMSPi909	3TMSPDI912
<b>Run U3-Oil-65%-2</b>											
08-May-02 13:21:00	111.0	1184.8	18.7593	722.5	98.3	151.2	55.6	22.9708	1.22	29.96	1.43
08-May-02 13:22:00	111.0	1188.3	18.7659	722.9	98.4	150.7	55.6	22.9771	1.22	29.96	1.43
08-May-02 13:23:00	111.0	1184.1	18.7724	722.2	98.2	151.4	55.6	22.9835	1.22	29.96	1.44
08-May-02 13:24:00	110.3	1188.1	18.7789	721.1	98.6	150.3	55.6	22.9898	1.22	29.96	1.44
08-May-02 13:25:00	109.9	1187.7	18.7854	721.0	97.6	149.8	55.6	22.9961	1.22	29.96	1.45
08-May-02 13:26:00	110.2	1186.5	18.7919	720.8	97.7	150.3	55.6	23.0025	1.22	29.96	1.45
08-May-02 13:27:00	110.0	1184.9	18.7984	720.2	97.8	150.3	55.6	23.0088	1.22	29.96	1.46
08-May-02 13:28:00	110.1	1187.6	18.8049	719.7	97.7	150.4	55.6	23.0151	1.22	29.96	1.46
08-May-02 13:29:00	110.6	1185.2	18.8114	720.3	97.6	150.0	55.6	23.0215	1.22	29.96	1.46
08-May-02 13:30:00	110.1	1188.0	18.8179	719.5	97.4	150.2	55.6	23.0278	1.22	29.96	1.47
08-May-02 13:31:00	110.5	1185.2	18.8244	719.9	97.1	150.4	55.7	23.0341	1.22	29.96	1.47
08-May-02 13:32:00	110.0	1184.7	18.8309	719.8	97.3	150.3	55.7	23.0404	1.22	29.96	1.48
08-May-02 13:33:00	110.6	1188.9	18.8374	719.4	97.2	150.5	55.7	23.0468	1.22	29.96	1.48
08-May-02 13:34:00	110.0	1184.1	18.8439	719.6	97.1	150.8	55.7	23.0531	1.22	29.96	1.49
08-May-02 13:35:00	110.2	1187.5	18.8505	719.1	97.0	150.5	55.7	23.0594	1.22	29.95	1.49
08-May-02 13:36:00	110.6	1183.6	18.8570	719.1	96.9	151.3	55.7	23.0658	1.22	29.95	1.49
08-May-02 13:37:00	110.4	1185.8	18.8635	719.1	96.8	150.9	55.7	23.0721	1.22	29.95	1.50
08-May-02 13:38:00	110.2	1187.4	18.8700	719.3	96.9	151.0	55.7	23.0784	1.22	29.95	1.50
08-May-02 13:39:00	109.5	1187.7	18.8765	720.0	97.0	150.4	55.7	23.0848	1.22	29.95	1.51
08-May-02 13:40:00	110.1	1185.7	18.8830	720.3	97.4	150.7	55.8	23.0911	1.22	29.95	1.51
08-May-02 13:41:00	109.8	1186.2	18.8895	720.3	98.0	150.5	55.8	23.0974	1.22	29.95	1.52
<b>Average:</b>	<b>110.3</b>	<b>1186.3</b>	<b>18.8244</b>	<b>720.3</b>	<b>97.5</b>	<b>150.6</b>	<b>55.7</b>	<b>23.0341</b>	<b>1.22</b>	<b>29.96</b>	<b>1.47</b>
<b>Run U3-Oil-65%-3</b>											
08-May-02 13:49:00	110.0	1187.3	18.9416	719.7	96.8	150.3	55.9	23.1481	1.22	29.95	1.56
08-May-02 13:50:00	110.8	1182.6	18.9481	720.3	96.7	151.2	55.9	23.1544	1.22	29.95	1.56
08-May-02 13:51:00	110.3	1186.5	18.9546	719.5	96.6	150.9	55.9	23.1607	1.22	29.95	1.57
08-May-02 13:52:00	110.3	1185.4	18.9611	719.9	96.6	151.4	55.9	23.1671	1.22	29.95	1.57
08-May-02 13:53:00	110.1	1183.8	18.9676	719.9	96.6	150.5	55.9	23.1734	1.22	29.95	1.58
08-May-02 13:54:00	110.4	1186.5	18.9741	719.8	96.9	150.4	55.9	23.1797	1.22	29.95	1.58
08-May-02 13:55:00	110.1	1185.3	18.9806	720.5	97.2	150.8	55.9	23.1861	1.22	29.95	1.59
08-May-02 13:56:00	110.1	1187.3	18.9871	720.4	97.5	150.3	55.9	23.1924	1.22	29.95	1.59
08-May-02 13:57:00	110.3	1186.3	18.9936	720.9	97.8	150.2	55.9	23.1987	1.22	29.95	1.59
08-May-02 13:58:00	110.6	1184.7	19.0001	721.9	98.1	150.9	56.0	23.2051	1.22	29.95	1.60
08-May-02 13:59:00	110.1	1188.6	19.0066	721.3	98.4	150.3	56.0	23.2114	1.22	29.95	1.60
08-May-02 14:00:00	109.7	1187.2	19.0132	720.7	97.9	150.6	56.0	23.2177	1.22	29.95	1.61
08-May-02 14:01:00	109.8	1185.2	19.0197	720.6	97.5	151.1	56.0	23.2241	1.22	29.95	1.61
08-May-02 14:02:00	109.8	1185.9	19.0262	720.2	97.9	150.0	56.0	23.2304	1.22	29.95	1.62
08-May-02 14:03:00	109.8	1187.6	19.0327	720.3	97.9	149.5	56.0	23.2367	1.22	29.95	1.62
08-May-02 14:04:00	109.2	1189.1	19.0392	719.9	98.1	149.9	56.0	23.2430	1.22	29.95	1.63
08-May-02 14:05:00	109.2	1184.8	19.0457	719.9	97.7	149.9	56.0	23.2494	1.22	29.95	1.63
08-May-02 14:06:00	109.6	1189.3	19.0522	720.4	98.0	149.4	56.0	23.2557	1.22	29.95	1.63
08-May-02 14:07:00	109.4	1189.7	19.0587	720.4	98.4	149.6	56.1	23.2620	1.22	29.95	1.64
08-May-02 14:08:00	111.4	1183.7	19.0652	721.6	97.8	152.4	56.5	23.2684	1.22	29.95	1.64
08-May-02 14:09:00	122.6	1175.9	19.7344	728.3	95.8	161.9	59.3	24.5789	1.25	29.95	1.65
<b>Average:</b>	<b>110.7</b>	<b>1185.8</b>	<b>19.0382</b>	<b>720.8</b>	<b>97.4</b>	<b>151.0</b>	<b>56.1</b>	<b>23.2735</b>	<b>1.22</b>	<b>29.95</b>	<b>1.60</b>

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output	Turbine	Fuel Oil Flow	Compressor	Compressor	Compressor	Inlet Guide Vane	H2O Injection	Water/Fuel	Bar. Pressure	Air Inlet
	MW	Exhaust °F	lbs/sec	Disc. Temp ofF	Inlet Temp °F	Disc. Press. Psig	Angle Deg.	Rate lbs/sec	Ratio	Hg	Duct Loss H2O
	3PWRJI900	3TMETI934	3FOYFI900	3TMSTI920B	3TMSTI922M	3TMSPi916	3PWRZi904	3TMSFI914		3TMSPi909	3TMSPDI912
<b>Run U3-Oil-80%-1</b>											
08-May-02 14:18:00	136.3	1158.1	21.1559	735.3	89.0	173.0	62.0	27.4390	1.30	29.94	1.86
08-May-02 14:19:00	135.9	1158.0	21.1620	735.0	88.5	172.4	62.0	27.4354	1.30	29.94	1.87
08-May-02 14:20:00	135.7	1158.0	21.1681	735.0	88.5	172.7	62.1	27.4318	1.30	29.94	1.87
08-May-02 14:21:00	134.8	1158.4	21.1742	734.6	88.5	172.3	62.2	27.4282	1.30	29.94	1.88
08-May-02 14:22:00	135.1	1159.4	21.1803	733.8	88.5	171.6	62.3	27.4246	1.29	29.94	1.88
08-May-02 14:23:00	134.7	1160.4	21.1864	734.4	88.5	171.8	62.4	27.4210	1.29	29.94	1.89
08-May-02 14:24:00	136.0	1158.9	21.1925	735.2	88.6	172.7	62.4	27.4174	1.29	29.94	1.89
08-May-02 14:25:00	136.4	1158.3	21.1986	735.8	88.9	173.4	62.5	27.4138	1.29	29.94	1.90
08-May-02 14:26:00	136.8	1157.9	21.2047	736.3	89.2	173.3	62.6	27.4103	1.29	29.94	1.90
08-May-02 14:27:00	136.6	1157.5	21.2108	736.8	89.4	173.5	62.6	27.4067	1.29	29.94	1.91
08-May-02 14:28:00	136.9	1157.4	21.2169	738.0	89.6	173.8	62.6	27.4031	1.29	29.94	1.91
08-May-02 14:29:00	137.0	1157.4	21.2230	738.0	89.7	173.9	62.6	27.3995	1.29	29.94	1.92
08-May-02 14:30:00	136.4	1157.7	21.2290	737.3	89.8	174.0	62.6	27.3959	1.29	29.94	1.92
08-May-02 14:31:00	136.6	1158.0	21.2351	736.5	89.6	173.6	62.6	27.3923	1.29	29.94	1.93
08-May-02 14:32:00	136.6	1158.0	21.2412	736.9	89.6	172.9	62.6	27.3887	1.29	29.94	1.93
08-May-02 14:33:00	136.6	1157.9	21.2473	736.6	89.6	173.3	62.7	27.3851	1.29	29.94	1.94
08-May-02 14:34:00	136.5	1157.8	21.2534	736.8	89.6	173.5	62.7	27.3815	1.29	29.94	1.94
08-May-02 14:35:00	136.5	1157.8	21.2595	736.7	89.6	173.6	62.7	27.3779	1.29	29.94	1.95
08-May-02 14:36:00	136.5	1157.8	21.2656	736.4	89.6	172.9	62.7	27.3743	1.29	29.94	1.95
08-May-02 14:37:00	136.5	1157.9	21.2717	736.4	88.9	173.3	62.7	27.3708	1.29	29.94	1.96
08-May-02 14:38:00	136.5	1158.0	21.2778	736.5	88.9	173.3	62.7	27.3672	1.29	29.94	1.96
<b>Average:</b>	<b>136.2</b>	<b>1158.1</b>	<b>21.2169</b>	<b>736.1</b>	<b>89.1</b>	<b>173.1</b>	<b>62.5</b>	<b>27.4031</b>	<b>1.29</b>	<b>29.94</b>	<b>1.91</b>
<b>Run U3-Oil-80%-2</b>											
08-May-02 14:47:00	136.3	1157.4	21.3327	737.5	89.1	173.4	62.8	27.3348	1.28	29.94	2.01
08-May-02 14:48:00	136.4	1158.2	21.3387	737.7	89.4	173.4	62.8	27.3312	1.28	29.94	2.01
08-May-02 14:49:00	136.4	1157.7	21.3448	737.1	89.9	174.0	62.8	27.3277	1.28	29.94	2.02
08-May-02 14:50:00	136.4	1157.7	21.3509	737.3	89.3	173.3	62.8	27.3241	1.28	29.94	2.02
08-May-02 14:51:00	136.4	1157.7	21.3570	737.4	89.5	173.7	62.8	27.3205	1.28	29.94	2.02
08-May-02 14:52:00	136.4	1157.8	21.3631	737.7	89.4	173.6	62.9	27.3169	1.28	29.94	2.03
08-May-02 14:53:00	136.5	1157.8	21.3692	738.1	89.8	173.5	62.9	27.3133	1.28	29.94	2.03
08-May-02 14:54:00	136.5	1157.8	21.3753	738.2	90.0	173.6	62.9	27.3097	1.28	29.94	2.04
08-May-02 14:55:00	136.6	1158.1	21.3814	738.2	90.1	173.5	62.9	27.3061	1.28	29.94	2.04
08-May-02 14:56:00	137.0	1158.0	21.3875	738.0	90.0	173.5	62.9	27.3025	1.28	29.94	2.05
08-May-02 14:57:00	136.8	1157.9	21.3936	737.8	89.9	173.6	62.9	27.2989	1.28	29.94	2.05
08-May-02 14:58:00	136.8	1158.0	21.3997	737.6	89.8	173.5	62.9	27.2953	1.28	29.94	2.06
08-May-02 14:59:00	136.8	1158.3	21.4058	737.3	90.0	173.1	62.9	27.2917	1.27	29.94	2.06
08-May-02 15:00:00	136.6	1158.5	21.4119	737.3	90.1	173.6	62.9	27.2882	1.27	29.94	2.07
08-May-02 15:01:00	136.4	1158.7	21.4180	738.3	90.3	173.5	63.0	27.2846	1.27	29.94	2.07
08-May-02 15:02:00	137.0	1158.3	21.4241	739.3	90.4	173.7	63.0	27.2810	1.27	29.94	2.08
08-May-02 15:03:00	136.9	1158.3	21.4302	739.3	90.4	174.1	63.0	27.2961	1.27	29.94	2.08
08-May-02 15:04:00	136.6	1157.8	21.4258	739.3	90.4	173.8	63.0	27.3276	1.28	29.94	2.09
08-May-02 15:05:00	137.0	1157.4	21.3424	739.5	90.5	173.9	63.0	27.3591	1.28	29.94	2.09
08-May-02 15:06:00	137.1	1157.7	21.2589	739.9	90.7	174.1	63.0	27.3905	1.29	29.94	2.10
08-May-02 15:07:00	136.8	1158.0	21.1754	739.8	90.8	173.7	63.0	27.4220	1.29	29.94	2.10
<b>Average:</b>	<b>136.7</b>	<b>1158.0</b>	<b>21.3660</b>	<b>738.2</b>	<b>90.0</b>	<b>173.6</b>	<b>62.9</b>	<b>27.3201</b>	<b>1.28</b>	<b>29.94</b>	<b>2.05</b>



## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Oil Flow lbs/sec	Compressor Disc. Temp ofF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	H2O Injection Rate lbs/sec	Water/Fuel Ratio	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJ1900	3TMET1934	3FOYF1900	3TMST1920B	3TMST1922M	3TMSP1916	3PWRZ1904	3TMSF1914		3TMSP1909	3TMSPDI912
<b>Run U3-Oil-80%-3</b>											
08-May-02 15:17:00	137.3	1157.3	21.0432	738.2	89.9	174.3	63.1	27.7369	1.32	29.94	2.15
08-May-02 15:18:00	137.5	1157.4	21.0534	738.4	89.4	173.7	63.1	27.7684	1.32	29.94	2.16
08-May-02 15:19:00	137.3	1157.4	21.0636	738.6	89.7	173.7	63.2	27.7998	1.32	29.94	2.16
08-May-02 15:20:00	137.3	1157.5	21.0738	738.9	90.8	173.9	63.2	27.8313	1.32	29.94	2.17
08-May-02 15:21:00	137.3	1157.8	21.0840	739.7	90.6	174.1	63.2	27.8628	1.32	29.94	2.17
08-May-02 15:22:00	136.9	1158.0	21.0942	740.1	90.8	174.1	63.2	27.8943	1.32	29.94	2.18
08-May-02 15:23:00	136.6	1157.9	21.1044	740.4	91.0	174.2	63.2	27.9258	1.32	29.94	2.18
08-May-02 15:24:00	136.4	1157.9	21.1146	740.2	91.0	174.0	63.2	27.9573	1.32	29.94	2.19
08-May-02 15:25:00	136.2	1158.0	21.1248	740.4	91.1	173.9	63.2	27.9888	1.32	29.94	2.19
08-May-02 15:26:00	137.0	1158.1	21.1350	739.8	91.2	173.7	63.2	28.0202	1.33	29.94	2.20
08-May-02 15:27:00	137.0	1158.2	21.1452	739.8	91.2	173.7	63.2	28.0517	1.33	29.94	2.20
08-May-02 15:28:00	136.9	1158.3	21.1554	740.1	91.1	173.8	63.3	28.0832	1.33	29.94	2.21
08-May-02 15:29:00	136.9	1158.1	21.1656	739.8	90.9	173.7	63.3	28.1147	1.33	29.94	2.21
08-May-02 15:30:00	137.0	1158.0	21.1758	739.8	90.9	173.0	63.3	28.1462	1.33	29.94	2.22
08-May-02 15:31:00	137.1	1158.0	21.1860	739.5	90.6	173.7	63.3	28.1777	1.33	29.94	2.22
08-May-02 15:32:00	137.2	1158.0	21.1961	739.5	90.4	173.3	63.3	28.2092	1.33	29.94	2.23
08-May-02 15:33:00	137.3	1158.1	21.2063	740.5	90.9	173.7	63.3	28.2406	1.33	29.94	2.23
08-May-02 15:34:00	137.3	1158.2	21.2165	740.8	91.4	173.7	63.3	28.2721	1.33	29.94	2.23
08-May-02 15:35:00	137.4	1159.3	21.2267	740.8	91.2	173.7	63.3	28.3036	1.33	29.94	2.24
08-May-02 15:36:00	145.4	1153.3	22.0412	747.9	90.7	181.3	66.8	28.8484	1.31	29.94	2.24
08-May-02 15:37:00	156.4	1142.8	23.3212	760.4	90.8	192.5	72.3	30.6918	1.32	29.94	2.25
<b>Average:</b>	<b>138.4</b>	<b>1157.0</b>	<b>21.2822</b>	<b>741.1</b>	<b>90.7</b>	<b>175.0</b>	<b>63.8</b>	<b>28.1869</b>	<b>1.32</b>	<b>29.94</b>	<b>2.20</b>

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Oil Flow lbs/sec	Compressor Disc. Temp of	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	H2O Injection Rate lbs/sec	Water/Fuel Ratio	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJ1900	3TMET1934	3FOYF1900	3TMST1920B	3TMST1922M	3TMSP1916	3PWRZ1904	3TMSF1914		3TMSP1909	3TMSPD1912
<b>Run U3-Oil-100%-1</b>											
08-May-02 15:55:00	167.1	1125.0	24.7433	781.0	90.9	206.1	82.0	33.8590	1.37	29.93	2.31
08-May-02 15:56:00	166.8	1125.0	24.7422	781.1	90.9	206.3	82.0	33.8497	1.37	29.93	2.31
08-May-02 15:57:00	166.9	1124.8	24.7401	781.1	90.9	206.3	82.0	33.8404	1.37	29.93	2.31
08-May-02 15:58:00	166.9	1124.7	24.7380	780.8	90.9	206.7	82.0	33.8311	1.37	29.93	2.31
08-May-02 15:59:00	166.4	1124.5	24.7359	781.4	90.9	206.4	82.0	33.8218	1.37	29.93	2.31
08-May-02 16:00:00	166.7	1124.6	24.7338	781.4	90.9	206.4	82.0	33.8125	1.37	29.93	2.31
08-May-02 16:01:00	166.1	1124.8	24.6913	781.4	90.9	206.6	82.0	33.8032	1.37	29.93	2.31
08-May-02 16:02:00	166.9	1124.9	24.5679	781.4	90.9	206.1	82.0	33.7939	1.38	29.93	2.31
08-May-02 16:03:00	166.4	1125.0	24.4445	781.4	90.9	206.2	82.0	33.7846	1.38	29.93	2.31
08-May-02 16:04:00	166.5	1125.2	24.3211	781.1	90.9	206.3	82.0	33.7753	1.39	29.93	2.31
08-May-02 16:05:00	166.5	1125.3	24.5832	781.0	90.9	206.1	82.0	33.7660	1.37	29.93	2.31
08-May-02 16:06:00	165.9	1125.3	24.5762	781.7	90.9	205.8	82.0	33.7567	1.37	29.93	2.31
08-May-02 16:07:00	166.4	1125.3	24.5693	781.3	90.9	205.9	82.0	33.7473	1.37	29.93	2.31
08-May-02 16:08:00	166.5	1125.5	24.5989	781.0	91.1	206.1	82.0	33.7380	1.37	29.93	2.31
08-May-02 16:09:00	165.9	1126.0	24.6342	781.8	91.5	205.6	82.0	33.7287	1.37	29.93	2.31
08-May-02 16:10:00	166.5	1125.2	24.6695	781.4	91.7	206.1	82.0	33.7194	1.37	29.93	2.31
08-May-02 16:11:00	166.5	1126.0	24.7047	781.4	91.8	205.8	82.0	33.8008	1.37	29.93	2.31
08-May-02 16:12:00	166.3	1125.7	24.7400	782.5	91.9	205.7	82.0	33.8074	1.37	29.93	2.31
08-May-02 16:13:00	165.8	1125.6	24.7753	782.2	92.0	205.6	82.0	33.7627	1.36	29.93	2.31
08-May-02 16:14:00	166.0	1125.5	24.8105	780.8	91.8	205.6	82.0	33.7180	1.36	29.93	2.31
08-May-02 16:15:00	166.1	1125.4	24.8458	780.6	91.3	205.8	82.0	33.6733	1.36	29.93	2.31
08-May-02 16:16:00	166.1	1125.3	24.8811	780.1	90.9	205.9	82.0	33.6287	1.35	29.93	2.31
08-May-02 16:17:00	166.2	1125.4	24.9163	780.1	90.9	206.1	82.0	33.5840	1.35	29.93	2.31
08-May-02 16:18:00	166.0	1125.5	24.9516	781.1	91.2	205.8	82.0	33.5393	1.34	29.93	2.31
08-May-02 16:19:00	166.1	1124.9	24.9869	781.1	91.4	206.1	82.0	33.4946	1.34	29.93	2.31
08-May-02 16:20:00	166.2	1124.6	24.8846	781.1	91.4	206.2	82.0	33.4914	1.35	29.93	2.31
08-May-02 16:21:00	167.1	1124.9	24.6536	781.1	91.4	206.1	82.0	33.5073	1.36	29.93	2.31
08-May-02 16:22:00	166.1	1124.7	24.8339	781.1	91.3	206.2	82.0	33.5233	1.35	29.93	2.31
08-May-02 16:23:00	166.4	1124.5	24.7674	781.1	91.1	206.1	82.0	33.5393	1.35	29.93	2.31
08-May-02 16:24:00	166.4	1125.2	24.6751	781.1	91.0	206.1	82.0	33.5552	1.36	29.93	2.31
08-May-02 16:25:00	166.8	1125.3	24.5827	780.8	90.9	206.6	82.0	33.5712	1.37	29.93	2.31
08-May-02 16:26:00	166.1	1125.3	24.5626	780.8	90.9	205.9	82.0	33.5871	1.37	29.93	2.31
08-May-02 16:27:00	166.4	1125.4	24.5464	780.7	90.9	205.8	82.0	33.6031	1.37	29.93	2.31
08-May-02 16:28:00	165.9	1126.3	24.5301	780.8	90.9	205.7	82.0	33.6191	1.37	29.93	2.31
08-May-02 16:29:00	166.2	1125.8	24.5138	780.9	90.9	205.6	82.0	33.6348	1.37	29.93	2.31
08-May-02 16:30:00	166.5	1125.9	24.4975	780.5	90.9	205.5	82.0	33.6364	1.37	29.93	2.31
08-May-02 16:31:00	165.8	1126.1	24.4812	780.9	90.9	205.7	82.0	33.6380	1.37	29.93	2.31
08-May-02 16:32:00	166.0	1126.2	24.4649	781.1	90.9	205.3	82.0	33.6397	1.38	29.93	2.31
08-May-02 16:33:00	166.1	1125.9	24.4486	782.3	91.6	205.8	82.0	33.6413	1.38	29.93	2.31
08-May-02 16:34:00	165.8	1125.8	24.4323	781.3	92.2	205.4	82.0	33.6429	1.38	29.93	2.31
08-May-02 16:35:00	165.9	1125.3	24.4160	780.9	91.8	206.1	82.0	33.6446	1.38	29.93	2.31
08-May-02 16:36:00	166.1	1125.3	24.3997	780.6	91.6	206.3	82.0	33.6462	1.38	29.93	2.31
08-May-02 16:37:00	166.0	1125.4	24.3834	780.8	91.6	206.4	82.0	33.6478	1.38	29.93	2.31
08-May-02 16:38:00	166.3	1125.7	24.3672	780.6	91.6	205.8	82.0	33.6494	1.38	29.93	2.31
08-May-02 16:39:00	166.3	1125.7	24.3509	780.8	91.5	206.2	82.0	33.6511	1.38	29.93	2.31

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output	Turbine	Fuel Oil Flow	Compressor	Compressor	Compressor	Inlet Guide Vane	H2O Injection	Water/Fuel	Bar. Pressure	Air Inlet
	MW	Exhaust °F	lbs/sec	Disc. Temp of	Inlet Temp °F	Disc. Press. Psig	Angle Deg.	Rate lbs/sec	Ratio	Hg	Duct Loss H2O
	3PWRJI900	3TMETI934	3FOYFI900	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSFI914		3TMSPI909	3TMSPDI912
08-May-02 16:40:00	166.1	1125.7	24.3346	780.6	91.4	205.6	82.0	33.6527	1.38	29.93	2.31
08-May-02 16:41:00	166.0	1125.6	24.3183	781.1	91.9	205.5	82.0	33.6540	1.38	29.93	2.31
08-May-02 16:42:00	166.1	1125.5	24.3020	781.1	91.9	205.6	82.0	33.6383	1.38	29.92	2.31
08-May-02 16:43:00	166.1	1125.6	24.2857	781.1	91.8	205.7	82.0	33.6225	1.38	29.92	2.31
08-May-02 16:44:00	166.1	1125.6	24.2694	781.1	91.7	205.2	82.0	33.6068	1.38	29.92	2.31
08-May-02 16:45:00	165.6	1125.2	24.2531	781.1	91.5	206.3	82.0	33.5910	1.39	29.92	2.31
08-May-02 16:46:00	166.1	1124.9	24.2368	780.7	91.4	206.3	82.0	33.5753	1.39	29.92	2.31
08-May-02 16:47:00	166.1	1126.1	24.2654	781.2	91.5	205.8	82.0	33.5599	1.38	29.92	2.31
08-May-02 16:48:00	165.9	1125.9	24.3018	781.4	91.6	205.9	82.0	33.5502	1.38	29.92	2.31
08-May-02 16:49:00	165.7	1126.1	24.3383	781.9	91.8	205.9	82.0	33.5404	1.38	29.92	2.31
08-May-02 16:50:00	165.6	1125.9	24.3399	781.4	92.0	206.0	82.0	33.5307	1.38	29.92	2.31
08-May-02 16:51:00	165.9	1126.1	24.3353	781.2	91.6	205.9	82.0	33.5210	1.38	29.92	2.31
08-May-02 16:52:00	165.0	1126.3	24.3307	781.5	91.5	205.2	82.0	33.5112	1.38	29.92	2.31
08-May-02 16:53:00	166.1	1125.8	24.3261	781.1	91.5	205.3	82.0	33.5343	1.38	29.92	2.31
08-May-02 16:54:00	166.3	1124.8	24.3290	780.7	91.6	205.4	82.0	33.5632	1.38	29.92	2.31
08-May-02 16:55:00	166.4	1125.4	24.3693	781.0	91.6	205.8	82.0	33.5920	1.38	29.92	2.31
<b>Average:</b>	<b>166.2</b>	<b>1125.4</b>	<b>24.5480</b>	<b>781.1</b>	<b>91.3</b>	<b>205.9</b>	<b>82.0</b>	<b>33.6549</b>	<b>1.37</b>	<b>29.93</b>	<b>2.31</b>

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Oil Flow lbs/sec	Compressor Disc. Temp oF	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	H2O Injection Rate lbs/sec	Water/Fuel Ratio	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJ1900	3TMET1934	3FOYF1900	3TMST1920B	3TMST1922M	3TMSPI916	3PWRZ1904	3TMSF1914		3TMSPI909	3TMSPI912
<b>Run U3-Oil-100%-2</b>											
08-May-02 17:10:00	165.7	1125.4	24.4461	780.1	91.0	205.8	82.0	33.1518	1.36	29.92	2.32
08-May-02 17:11:00	166.1	1125.5	24.4275	780.2	90.9	205.8	82.0	33.0941	1.35	29.92	2.32
08-May-02 17:12:00	165.8	1125.5	24.4088	780.4	90.9	206.1	82.0	33.0365	1.35	29.92	2.32
08-May-02 17:13:00	165.8	1125.5	24.3901	780.6	90.9	206.4	82.0	32.9789	1.35	29.92	2.32
08-May-02 17:14:00	166.4	1125.1	24.3714	780.8	91.0	206.0	82.0	32.9212	1.35	29.92	2.32
08-May-02 17:15:00	164.9	1125.4	24.3528	781.6	91.2	205.8	82.0	32.8636	1.35	29.92	2.32
08-May-02 17:16:00	165.8	1125.4	24.3341	781.1	91.3	205.8	82.0	32.8381	1.35	29.92	2.32
08-May-02 17:17:00	166.1	1125.6	24.3211	781.0	91.4	205.6	82.0	32.8938	1.35	29.92	2.32
08-May-02 17:18:00	166.0	1125.9	24.3181	780.3	91.4	205.7	82.0	32.9495	1.35	29.92	2.32
08-May-02 17:19:00	166.2	1125.1	24.3150	780.0	91.4	205.8	82.0	33.0161	1.36	29.92	2.32
08-May-02 17:20:00	166.4	1124.8	24.3236	779.9	91.2	206.0	82.0	33.1186	1.36	29.92	2.32
08-May-02 17:21:00	165.6	1125.1	24.3791	780.5	90.9	206.1	82.0	33.2211	1.36	29.92	2.32
08-May-02 17:22:00	166.5	1125.1	24.4346	779.6	90.6	205.7	82.0	33.3236	1.36	29.92	2.32
08-May-02 17:23:00	166.2	1125.1	24.4901	779.9	90.4	205.4	82.0	33.4261	1.36	29.92	2.32
08-May-02 17:24:00	165.5	1125.1	24.5456	780.1	90.3	205.9	82.0	33.5286	1.37	29.92	2.32
08-May-02 17:25:00	166.3	1124.4	24.6011	780.1	90.2	206.4	82.0	33.5906	1.37	29.92	2.32
08-May-02 17:26:00	166.7	1125.0	24.6097	779.9	90.2	206.3	82.0	33.5873	1.36	29.92	2.32
08-May-02 17:27:00	166.2	1125.6	24.5774	780.8	90.1	205.7	82.0	33.5841	1.37	29.92	2.32
08-May-02 17:28:00	166.0	1125.4	24.5450	780.4	90.2	205.8	82.0	33.5809	1.37	29.92	2.32
08-May-02 17:29:00	166.2	1125.1	24.5127	780.5	90.3	205.9	82.0	33.5777	1.37	29.92	2.32
08-May-02 17:30:00	166.2	1125.3	24.4803	780.3	90.4	206.0	82.0	33.5821	1.37	29.92	2.32
08-May-02 17:31:00	166.1	1125.4	24.4480	780.0	90.7	206.2	82.0	33.5933	1.37	29.92	2.32
08-May-02 17:32:00	165.9	1125.8	24.4156	781.3	90.9	205.9	82.0	33.6044	1.38	29.92	2.32
08-May-02 17:33:00	165.6	1125.6	24.3833	781.4	91.2	205.5	82.0	33.5817	1.38	29.92	2.32
08-May-02 17:34:00	165.9	1125.6	24.3568	780.7	91.2	205.8	82.0	33.5466	1.38	29.91	2.32
08-May-02 17:35:00	166.0	1125.6	24.3535	781.0	91.2	205.8	82.0	33.5116	1.38	29.91	2.32
08-May-02 17:36:00	165.9	1125.6	24.3503	781.1	91.3	205.7	82.0	33.4765	1.37	29.91	2.32
08-May-02 17:37:00	166.0	1125.8	24.3471	781.5	91.3	205.5	82.0	33.5271	1.38	29.91	2.32
08-May-02 17:38:00	165.9	1125.6	24.3439	781.4	91.4	206.0	82.0	33.6204	1.38	29.91	2.32
08-May-02 17:39:00	166.1	1125.4	24.3406	781.1	91.4	206.0	82.0	33.7138	1.39	29.91	2.32
08-May-02 17:40:00	165.8	1125.7	24.3374	781.5	91.7	205.6	82.0	33.7549	1.39	29.91	2.32
08-May-02 17:41:00	165.9	1125.9	24.3342	782.0	92.0	205.3	82.0	33.7656	1.39	29.91	2.32
08-May-02 17:42:00	165.6	1125.6	24.3310	782.0	92.2	205.9	82.0	33.7764	1.39	29.91	2.32
08-May-02 17:43:00	165.9	1125.6	24.3277	781.6	91.7	205.9	82.0	33.7718	1.39	29.91	2.32
08-May-02 17:44:00	166.2	1125.8	24.3245	781.2	92.1	205.7	82.0	33.7616	1.39	29.91	2.32
08-May-02 17:45:00	165.5	1125.8	24.3213	782.0	91.9	205.3	82.0	33.7514	1.39	29.91	2.32
08-May-02 17:46:00	165.9	1125.7	24.3180	781.4	91.8	205.6	82.0	33.7413	1.39	29.91	2.32
08-May-02 17:47:00	165.6	1125.7	24.3148	781.4	91.6	205.4	82.0	33.7311	1.39	29.91	2.32
08-May-02 17:48:00	165.8	1125.6	24.3304	780.6	91.3	205.7	82.0	33.7209	1.39	29.91	2.32
08-May-02 17:49:00	166.2	1125.1	24.3934	780.4	91.1	205.7	82.0	33.7227	1.38	29.91	2.33
08-May-02 17:50:00	165.5	1125.0	24.4564	780.8	91.0	205.7	82.0	33.7325	1.38	29.91	2.33
08-May-02 17:51:00	166.1	1125.0	24.5195	780.6	90.9	205.7	82.0	33.7423	1.38	29.91	2.33
08-May-02 17:52:00	166.0	1125.0	24.5825	780.6	90.9	205.7	82.0	33.7522	1.37	29.91	2.33
08-May-02 17:53:00	166.0	1125.5	24.6455	780.7	91.0	205.7	82.0	33.7620	1.37	29.91	2.33
08-May-02 17:54:00	166.2	1125.9	24.7085	781.2	91.4	205.6	82.0	33.7718	1.37	29.91	2.33

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output	Turbine	Fuel Oil Flow	Compressor	Compressor	Compressor	Inlet Guide Vane	H2O Injection	Water/Fuel	Bar. Pressure	Air Inlet
	MW	Exhaust °F	lbs/sec	Disc. Temp oF	Inlet Temp °F	Disc. Press. Psig	Angle Deg.	Rate lbs/sec	Ratio	Hg	Duct Loss H2O
	3PWRJI900	3TMETI934	3FOYFI900	3TMSTI920B	3TMSTI922M	3TMSPI916	3PWRZI904	3TMSFI914		3TMSPI909	3TMSPDI912
08-May-02 17:55:00	165.4	1126.3	24.7716	782.0	92.5	205.2	82.0	33.7817	1.36	29.91	2.33
08-May-02 17:56:00	165.8	1125.7	24.8346	781.6	92.5	205.8	82.0	33.7915	1.36	29.91	2.33
08-May-02 17:57:00	165.7	1125.4	24.8584	781.8	92.5	205.5	82.0	33.7676	1.36	29.91	2.33
08-May-02 17:58:00	165.8	1125.6	24.8654	781.4	92.5	205.8	82.0	33.7256	1.36	29.91	2.33
08-May-02 17:59:00	165.7	1125.1	24.8723	781.6	92.5	206.0	82.0	33.6835	1.35	29.91	2.33
08-May-02 18:00:00	165.7	1125.6	24.8793	780.8	91.4	205.9	82.0	33.6415	1.35	29.91	2.33
08-May-02 18:01:00	165.7	1125.5	24.8863	780.6	91.3	205.6	82.0	33.5995	1.35	29.91	2.33
08-May-02 18:02:00	165.9	1125.3	24.8932	780.6	91.2	205.5	82.0	33.5575	1.35	29.91	2.33
08-May-02 18:03:00	165.9	1125.5	24.9002	780.7	91.1	206.0	82.0	33.5154	1.35	29.91	2.33
08-May-02 18:04:00	166.2	1125.5	24.9072	779.8	91.0	205.9	82.0	33.4734	1.34	29.91	2.33
08-May-02 18:05:00	166.3	1125.1	24.9142	779.8	90.2	206.3	82.0	33.4314	1.34	29.91	2.33
08-May-02 18:06:00	166.3	1125.1	24.9208	780.3	90.7	206.1	82.0	33.1919	1.33	29.91	2.33
08-May-02 18:07:00	166.2	1125.4	24.8967	780.4	90.9	205.8	82.0	32.9220	1.32	29.91	2.33
08-May-02 18:08:00	166.0	1125.4	24.8457	780.0	90.9	206.1	82.0	32.7351	1.32	29.91	2.33
08-May-02 18:09:00	166.0	1125.7	24.7579	780.6	91.0	205.8	82.0	32.7583	1.32	29.91	2.33
08-May-02 18:10:00	165.2	1126.0	24.5490	781.1	91.7	205.4	82.0	32.7816	1.34	29.91	2.33
<b>Average:</b>	<b>165.9</b>	<b>1125.4</b>	<b>24.5299</b>	<b>780.8</b>	<b>91.2</b>	<b>205.8</b>	<b>82.0</b>	<b>33.4534</b>	<b>1.36</b>	<b>29.91</b>	<b>2.32</b>

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Oil Flow lbs/sec	Compressor Disc. Temp of F	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	H2O Injection Rate lbs/sec	Water/Fuel Ratio	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMETI934	3FOYFI900	3TMSTI920B	3TMSTI922M	3TMSPi916	3PWRZI904	3TMSFI914		3TMSPi909	3TMSPDI912
<b>Run U3-Oil-100%-3</b>											
08-May-02 18:22:00	165.8	1125.6	24.4130	779.7	90.2	206.0	82.0	33.1162	1.36	29.91	2.33
08-May-02 18:23:00	166.7	1125.3	24.4339	779.6	90.4	206.2	82.0	33.1934	1.36	29.91	2.33
08-May-02 18:24:00	165.9	1125.3	24.4651	779.4	90.7	205.7	82.0	33.2707	1.36	29.91	2.33
08-May-02 18:25:00	166.0	1125.4	24.5249	779.8	91.0	205.8	82.0	33.3480	1.36	29.91	2.34
08-May-02 18:26:00	166.6	1125.5	24.5846	780.3	91.3	206.0	82.0	33.4253	1.36	29.91	2.34
08-May-02 18:27:00	166.2	1125.4	24.6443	780.7	91.4	205.5	82.0	33.4947	1.36	29.91	2.34
08-May-02 18:28:00	166.2	1125.3	24.7040	780.1	91.4	205.6	82.0	33.4777	1.36	29.91	2.34
08-May-02 18:29:00	166.3	1125.2	24.7637	780.3	91.2	205.8	82.0	33.4607	1.35	29.91	2.34
08-May-02 18:30:00	166.0	1125.8	24.8167	779.6	91.0	205.8	82.0	33.4437	1.35	29.91	2.34
08-May-02 18:31:00	165.9	1125.2	24.8397	779.2	90.7	205.6	82.0	33.4267	1.35	29.91	2.34
08-May-02 18:32:00	166.2	1125.2	24.8626	779.8	90.5	205.7	82.0	33.4098	1.34	29.91	2.34
08-May-02 18:33:00	166.0	1124.2	24.8856	779.3	90.3	206.3	82.0	33.3994	1.34	29.91	2.34
08-May-02 18:34:00	166.6	1124.3	24.6910	779.2	90.1	206.4	82.0	33.4024	1.35	29.91	2.34
08-May-02 18:35:00	166.8	1124.4	24.6785	779.1	89.9	206.6	82.0	33.4053	1.35	29.91	2.34
08-May-02 18:36:00	167.6	1124.1	24.6660	779.1	89.8	206.6	82.0	33.4083	1.35	29.91	2.34
08-May-02 18:37:00	167.2	1124.3	24.6535	779.1	89.8	206.5	82.0	33.4113	1.36	29.91	2.34
08-May-02 18:38:00	166.4	1124.7	24.6410	779.1	89.8	205.9	82.0	33.4142	1.36	29.91	2.34
08-May-02 18:39:00	166.8	1124.4	24.6285	778.9	89.9	206.2	82.0	33.4172	1.36	29.91	2.34
08-May-02 18:40:00	166.8	1124.5	24.6161	779.0	89.9	206.1	82.0	33.4202	1.36	29.91	2.34
08-May-02 18:41:00	167.1	1124.1	24.6036	779.1	90.1	206.1	82.0	33.4231	1.36	29.91	2.34
08-May-02 18:42:00	167.0	1124.4	24.5911	779.2	90.4	206.2	82.0	33.4261	1.36	29.91	2.34
08-May-02 18:43:00	166.4	1124.4	24.6157	779.3	89.6	206.3	82.0	33.4291	1.36	29.91	2.34
08-May-02 18:44:00	166.3	1124.5	24.6889	779.3	90.2	206.2	82.0	33.4320	1.35	29.91	2.34
08-May-02 18:45:00	166.7	1124.7	24.7620	779.3	90.1	206.3	82.0	33.4350	1.35	29.91	2.34
08-May-02 18:46:00	167.3	1124.9	24.8348	779.2	90.2	206.2	82.0	33.4379	1.35	29.91	2.34
08-May-02 18:47:00	166.4	1124.7	24.8834	779.0	90.2	206.1	82.0	33.4409	1.34	29.91	2.34
08-May-02 18:48:00	166.3	1124.6	24.9319	778.9	90.3	206.5	82.0	33.4439	1.34	29.91	2.34
08-May-02 18:49:00	166.4	1124.6	24.9460	779.4	90.4	206.6	82.0	33.4468	1.34	29.91	2.34
08-May-02 18:50:00	166.8	1124.5	24.9233	779.1	90.2	206.1	82.0	33.4498	1.34	29.91	2.34
08-May-02 18:51:00	166.4	1124.5	24.9005	778.5	90.0	206.7	82.0	33.4528	1.34	29.91	2.34
08-May-02 18:52:00	167.2	1124.4	24.8778	778.4	89.9	206.6	82.0	33.4557	1.34	29.91	2.34
08-May-02 18:53:00	166.8	1124.4	24.8550	778.4	89.7	206.6	82.0	33.4587	1.35	29.91	2.34
08-May-02 18:54:00	166.7	1124.2	24.8323	778.8	89.6	206.2	82.0	33.4616	1.35	29.91	2.34
08-May-02 18:55:00	166.7	1123.8	24.8281	778.5	89.4	206.9	82.0	33.4646	1.35	29.91	2.34
08-May-02 18:56:00	166.9	1123.6	24.8281	778.4	89.5	206.9	82.0	33.4676	1.35	29.91	2.34
08-May-02 18:57:00	167.3	1123.8	24.8281	778.3	89.5	206.7	82.0	33.4705	1.35	29.91	2.34
08-May-02 18:58:00	167.3	1124.0	24.8281	778.5	89.5	206.5	82.0	33.4735	1.35	29.91	2.34
08-May-02 18:59:00	166.7	1124.2	24.8281	779.2	89.3	206.7	82.0	33.4765	1.35	29.91	2.34
08-May-02 19:00:00	167.0	1124.1	24.8139	778.4	89.3	207.1	82.0	33.4794	1.35	29.91	2.34
08-May-02 19:01:00	167.0	1124.2	24.7785	778.9	89.3	206.3	82.0	33.4824	1.35	29.91	2.34
08-May-02 19:02:00	167.0	1124.3	24.7430	779.3	89.9	206.5	82.0	33.4853	1.35	29.91	2.34
08-May-02 19:03:00	167.0	1124.1	24.7076	779.5	90.7	206.8	82.0	33.4883	1.36	29.91	2.34
08-May-02 19:04:00	166.4	1124.3	24.6721	780.4	91.0	206.7	82.0	33.4913	1.36	29.91	2.34
08-May-02 19:05:00	167.2	1123.9	24.6443	779.9	90.7	206.6	82.0	33.4942	1.36	29.91	2.34
08-May-02 19:06:00	167.0	1124.2	24.6546	780.0	90.4	206.4	82.0	33.4972	1.36	29.91	2.34

## Unit 3 Operational Data, Fuel Oil Testing, Polk Power Station

Polk Unit 3	Gen Output MW	Turbine Exhaust °F	Fuel Oil Flow lbs/sec	Compressor Disc. Temp °F	Compressor Inlet Temp °F	Compressor Disc. Press. Psig	Inlet Guide Vane Angle Deg.	H2O Injection Rate lbs/sec	Water/Fuel Ratio	Bar. Pressure Hg	Air Inlet Duct Loss H2O
	3PWRJI900	3TMEI934	3FOYFI900	3TMSTI920B	3TMSTI922M	3TMSP1916	3PWRZI904	3TMSFI914		3TMSP1909	3TMSPDI912
08-May-02 19:07:00	167.0	1124.3	24.6649	778.8	90.2	206.4	82.0	33.5001	1.36	29.91	2.34
08-May-02 19:08:00	166.8	1124.1	24.6752	778.8	90.0	206.6	82.0	33.5031	1.36	29.91	2.34
08-May-02 19:09:00	166.9	1123.8	24.7366	778.8	89.9	206.8	82.0	33.5061	1.35	29.91	2.34
08-May-02 19:10:00	166.9	1123.7	24.9882	778.5	89.7	206.7	82.0	33.5090	1.34	29.91	2.34
08-May-02 19:11:00	167.4	1123.9	24.9541	778.3	89.6	206.3	82.0	33.5120	1.34	29.91	2.34
08-May-02 19:12:00	166.8	1123.8	24.9200	778.3	89.7	206.9	82.0	33.5150	1.34	29.91	2.34
08-May-02 19:13:00	166.9	1123.7	24.8941	778.3	89.0	206.7	82.0	33.5179	1.35	29.91	2.34
08-May-02 19:14:00	167.3	1123.6	24.8692	778.5	89.5	206.5	82.0	33.5209	1.35	29.91	2.34
08-May-02 19:15:00	167.1	1123.6	24.7997	778.5	89.0	206.8	82.0	33.5238	1.35	29.91	2.34
08-May-02 19:16:00	167.2	1123.6	24.7195	778.8	88.9	206.9	82.0	33.5268	1.36	29.91	2.34
08-May-02 19:17:00	167.4	1123.7	24.8009	778.8	89.3	206.7	82.0	33.5298	1.35	29.91	2.34
08-May-02 19:18:00	167.1	1123.9	24.8822	778.8	89.3	206.4	82.0	33.5327	1.35	29.91	2.34
08-May-02 19:19:00	166.9	1124.0	24.9636	778.4	89.2	206.8	82.0	33.5357	1.34	29.91	2.34
08-May-02 19:20:00	167.0	1123.9	24.9463	778.8	89.1	207.2	82.0	33.5387	1.34	29.91	2.34
08-May-02 19:21:00	167.7	1123.4	24.9069	779.0	89.3	206.6	82.0	33.5416	1.35	29.91	2.34
08-May-02 19:22:00	167.2	1123.3	24.8675	779.2	89.5	207.0	82.0	33.5446	1.35	29.91	2.34
<b>Average:</b>	<b>166.8</b>	<b>1124.4</b>	<b>24.7623</b>	<b>779.1</b>	<b>90.0</b>	<b>206.4</b>	<b>82.0</b>	<b>33.4536</b>	<b>1.35</b>	<b>29.91</b>	<b>2.34</b>

**APPENDIX I:  
FDEP PSD PERMIT**





# Department of Environmental Protection

Jeb Bush  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

## PERMITTEE:

Tampa Electric Company (TEC)  
6944 U.S. Highway 41 North  
Apollo Beach, Florida 33572-9200

File No.	PSD-FL-263 (PA92-32)
FID No.	1050233
SIC No.	4911
Expires:	December 31, 2002

## Authorized Representative:

Gregory M. Nelson, Manager, Environmental Planning

## PROJECT AND LOCATION:

Permit pursuant to the requirements for the Prevention of Significant Deterioration of Air Quality (PSD Permit) for the construction of: two dual-fuel nominal 165 megawatt (MW) General Electric PG7241FA combustion turbine-electrical generators and two 114-foot stacks. The units will operate in simple cycle mode and intermittent duty. The units will be equipped with Dry Low NO<sub>x</sub> (DLN-2.6) combustors and wet injection capability. They are designated by TEC as CTGs Nos. 2 and 3 and by the Department as ARMS Emissions Units 009 and 010.

The project will be located at the existing Polk Power Station, 9995 State Route 37 South, Mulberry, Polk County. UTM coordinates are: Zone 17; 402.45 km E; 3067.35 km N.


## STATEMENT OF BASIS:

This PSD permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), and Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.) and 40CFR52.21. The above named permittee is authorized to modify the facility in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department of Environmental Protection (Department).

Attached Appendices and Tables made a part of this permit:

Appendix BD  
Appendix GC

BACT Determination  
Construction Permit General Conditions

  
Howard L. Rhodes, Director  
Division of Air Resources  
Management

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

Printed on recycled paper.

PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

SECTION I - FACILITY INFORMATION

FACILITY DESCRIPTION

This facility presently generates electric power from a 260 megawatt (MW) integrated coal gasification and combined cycle turbine unit. The primary mover is a General Electric MS 7001F combustion turbine capable of firing syngas or No. 2 fuel oil. Associated support facilities include: a solid fuel gasification system; a hydrogen sulfide to sulfur dioxide converter; a sulfuric acid plant; solid fuel handling and storage; and fuel oil handling and storage.

This permitting action is to install two dual-fuel nominal 165 megawatt (MW) General Electric PG7241FA combustion turbine-electrical generators with two 114-foot stacks. The project will utilize existing infrastructure including oil storage and auxiliary equipment.

Emissions from the new units will be controlled by Dry Low NO<sub>x</sub> (DLN-2.6) combustors when operating on natural gas and wet injection when firing fuel oil. Inherently clean fuels and good combustion practices will be employed to control all pollutants.

EMISSION UNITS

This permit addresses the following emission units:

ARMS EMISSIONS UNIT	SYSTEM	EMISSION UNIT DESCRIPTION
009 (CTG-2)	Power Generation	One nominal 165 Megawatt Gas Simple Cycle Combustion Turbine-Electrical Generator
010 (CTG-3)	Power Generation	One nominal 165 Megawatt Simple Cycle Gas Combustion Turbine-Electrical Generator

REGULATORY CLASSIFICATION

The facility is classified as a Major or Title V Source of air pollution because emissions of at least one regulated air pollutant, such as particulate matter (PM/PM<sub>10</sub>), sulfur dioxide (SO<sub>2</sub>), nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), or volatile organic compounds (VOC) exceeds 100 tons per year (TPY).

This facility is within an industry included in the list of the 28 Major Facility Categories per Table 212.400-1, F.A.C. Because emissions are greater than 100 TPY for at least one criteria pollutant, the facility is also a Major Facility with respect to Rule 62-212.400, Prevention of Significant Deterioration (PSD). Pursuant to Table 62-212.400-2, modifications at this facility resulting in emissions increases greater than any of the following values require review per the PSD rules as well as a determination of Best Available Control Technology (BACT): 40 TPY of NO<sub>x</sub>, SO<sub>2</sub>, or VOC; 25/15 TPY of PM/PM<sub>10</sub>; 100 TPY of CO; or 7 TPY of sulfuric acid mist (SAM).

This project is subject to certain requirements of Chapter 403, Part II, F.S., Electric Power Plant and Transmission Line Siting, including a modification of the Conditions of Certification (reference Site Certification PA92-32).

## PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

### SECTION I - FACILITY INFORMATION

---

This facility and the project are also subject to applicable provisions of Title IV, Acid Rain, of the Clean Air Act..

#### PERMIT SCHEDULE

- xx/xx/99 Modification of Conditions of Certification Approved.
- 07/10/99 Notice of Intent to Issue PSD Permit published in the Lakeland Ledger.
- 06/30/99 Distributed Intent to Issue Permit.
- 06/10/99 Application deemed complete for PSD review.
- 02/08/99 Received revised PSD Application.

#### RELEVANT DOCUMENTS:

The documents listed below are the basis of the permit. They are specifically related to this permitting action, but not all are incorporated into this permit. These documents are on file with the Department.

- Application received on February 8, 1999
- Department/ Siting Coordination Office incompleteness letter dated February 11, 1999
- Department/BAR memo to Siting Coordination Office dated March 9, 1999
- Comments and letter from the U. S. Fish and Wildlife Service dated March 19, 1999
- Site Certification and Revised PSD Application received May 10, 1999
- Department/BAR comments on Modeling dated May 20, 1999
- Comments from Hillsborough County EPC dated June 7, 1999
- Response from TEC/ECT received June 10, 1999
- Department's Intent to Issue PSD Permit and Public Notice Package dated June 30, 1999
- Department's Final Determination and Best Available Control Technology Determination issued concurrently with this Final Permit.
- Comments from TEC dated August 9, September 10, and 14, 1999.

## PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

### SECTION II - ADMINISTRATIVE REQUIREMENTS

---

#### GENERAL AND ADMINISTRATIVE REQUIREMENTS

1. Regulating Agencies: All documents related to applications for permits to construct, operate or modify an emissions unit should be submitted to the Bureau of Air Regulation (BAR), Florida Department of Environmental Protection (FDEP), at 2600 Blairstone Road, Tallahassee, Florida 32399-2400 and phone number (850)488-0114. All documents related to reports, tests, and notifications should be submitted to the DEP Southwest District, 3804 Coconut Palm Drive, Tampa, Fl 33619-8218 and phone number 813/744-6100.
2. General Conditions: The owner and operator is subject to and shall operate under the attached General Permit Conditions G.1 through G.15 listed in Appendix GC of this permit. General Permit Conditions are binding and enforceable pursuant to Chapter 403 of the Florida Statutes. [Rule 62-4.160, F.A.C.]
3. Terminology: The terms used in this permit have specific meanings as defined in the corresponding chapters of the Florida Administrative Code.
4. Forms and Application Procedures: The permittee shall use the applicable forms listed in Rule 62-210.900, F.A.C. and follow the application procedures in Chapter 62-4, F.A.C. [Rule 62-210.900, F.A.C.]
5. Modifications: The permittee shall give written notification to the Department when there is any modification to this facility. This notice shall be submitted sufficiently in advance of any critical date involved to allow sufficient time for review, discussion, and revision of plans, if necessary. Such notice shall include, but not be limited to, information describing the precise nature of the change; modifications to any emission control system; production capacity of the facility before and after the change; and the anticipated completion date of the change. [Chapters 62-210 and 62-212, F.A.C.]
6. Expiration: Approval to construct shall become invalid if construction is not commenced within 18 months after receipt of such approval, or if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable time. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified. [40 CFR 52.21(r)(2)]
7. BACT Determination: In conjunction with extension of the 18 month periods to commence or continue construction, or extension of the December 31, 2002 permit expiration date, the permittee may be required to demonstrate the adequacy of any previous determination of best available control technology for the source. In accordance with paragraph (4) of 40 CFR 52.21(j) the Best Available Control Technology (BACT) determination shall be reviewed and modified as appropriate in the event of a plant conversion. This paragraph states: "For phased construction project, the determination of best available control technology shall be reviewed and modified as appropriate at the latest reasonable time which occurs no later than 18 months prior to commencement of construction of each independent phase of the project. At such time, the owner or operator of the applicable stationary source may be required to demonstrate

## PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

### SECTION III - EMISSIONS UNIT(S) SPECIFIC CONDITIONS

---

#### APPLICABLE STANDARDS AND REGULATIONS:

1. Unless otherwise indicated in this permit, the construction and operation of the subject emission unit(s) shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of Chapter 403, F.S. and Florida Administrative Code Chapters 62-4, 62-17, 62-204, 62-210, 62-212, 62-213, 62-214, 62-296, and 62-297; and the applicable requirements of the Code of Federal Regulations Section 40, Parts 52, 60, 72, 73, and 75.
2. Issuance of this permit does not relieve the facility owner or operator from compliance with any applicable federal, state, or local permitting requirements or regulations. [Rule 62-210.300, F.A.C.]
3. These emission units shall comply with all applicable requirements of 40CFR60, Subpart A, General Provisions including:
  - 40CFR60.7, Notification and Recordkeeping
  - 40CFR60.8, Performance Tests
  - 40CFR60.11, Compliance with Standards and Maintenance Requirements
  - 40CFR60.12, Circumvention
  - 40CFR60.13, Monitoring Requirements
  - 40CFR60.19, General Notification and Reporting requirements
4. ARMS Emissions Unit 009. Direct Power Generation, consisting of a nominal 165 megawatt simple cycle combustion turbine-electrical generator, shall comply with all applicable provisions of 40CFR60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted by reference in Rule 62-204.800(7)(b), F.A.C. The Subpart GG requirement to correct test data to ISO conditions applies. However, such correction is not used for compliance determinations with the BACT standard(s).
5. ARMS Emissions Unit 010. Direct Power Generation, consisting of a nominal 165 megawatt simple cycle combustion turbine-electrical generator, shall comply with all applicable provisions of 40CFR60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted by reference in Rule 62-204.800(7)(b), F.A.C. The Subpart GG requirement to correct test data to ISO conditions applies. However, such correction is not used for compliance determinations with the BACT standard(s).
6. All notifications and reports required by the above specific conditions shall be submitted to the DEP's Southwest District.

#### GENERAL OPERATION REQUIREMENTS

7. Fuels: Only pipeline natural gas or maximum 0.05 percent sulfur fuel oil No. 2 or superior grade of distillate fuel oil shall be fired in this unit. [Applicant Request, Rule 62-210.200, F.A.C. (Definitions - Potential Emissions)] {Note: The limitation of this specific condition is more stringent than the NSPS sulfur dioxide limitation and thus assures compliance with 40 CFR 60.333 and 60.334}

## PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

### SECTION III - EMISSIONS UNIT(S) SPECIFIC CONDITIONS

---

8. Combustion Turbine Capacity: The maximum heat input rates, based on the lower heating value (LHV) of each fuel to each unit at ambient conditions of 59°F temperature, 60% relative humidity, 100% load, and 14.7 psi pressure shall not exceed 1,600 million Btu per hour (mmBtu/hr) when firing natural gas, nor 1,800 mmBtu/hr when firing No. 2 or superior grade of distillate fuel oil. These maximum heat input rates will vary depending upon ambient conditions and the combustion turbine characteristics. Manufacturer's curves corrected for site conditions or equations for correction to other ambient conditions shall be provided to the Department of Environmental Protection (DEP) within 45 days of completing the initial compliance testing. [Design, Rule 62-210.200, F.A.C. (Definitions - Potential Emissions)]
9. Unconfined Particulate Emissions: During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary.
10. Plant Operation - Problems: If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the owner or operator shall notify the DEP Southwest District as soon as possible, but at least within (1) working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; the steps being taken to correct the problem and prevent future recurrence; and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit and the regulations. [Rule 62-4.130, F.A.C.]
11. Operating Procedures: Operating procedures shall include good operating practices and proper training of all operators and supervisors. The good operating practices shall meet the guidelines and procedures as established by the equipment manufacturers. All operators (including supervisors) of air pollution control devices shall be properly trained in plant specific equipment. [Rule 62-4.070(3), F.A.C.]
12. Circumvention: The owner or operator shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly. [Rules 62-210.650, F.A.C.]
13. Maximum allowable hours of operation for each unit are 4,380 hours per year on natural gas and 750 hours per year on fuel oil. [Rule 62-210.200, F.A.C., (Definitions - Potential Emissions), 62-212.400, F.A.C., (BACT Determination)]

### CONTROL TECHNOLOGY

14. Dry Low NO<sub>x</sub> (DLN) combustors shall be installed on the stationary combustion turbine to comply with the NO<sub>x</sub> emissions limits while firing natural gas. [Design, Rules 62-4.070 and 62-212.400, F.A.C. (BACT Determination)]
15. A water injection system shall be installed for use when firing No. 2 or superior grade distillate fuel oil for control of NO<sub>x</sub> emissions. [Design, Rules 62-4.070 and 62-212.400, F.A.C.]

**PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263**

**SECTION III - EMISSIONS UNIT(S) SPECIFIC CONDITIONS**

16. The permittee shall design these units to accommodate adequate testing and sampling locations for compliance with the applicable emission limits (per each unit) listed in Specific Conditions No. 19 through 24. [Rule 62-4.070, Rule 62-204.800, F.A.C., and 40 CFR60.40a(b)]
17. The permittee shall provide manufacturer's emissions performance versus load diagrams for the DLN and wet injection systems prior to their installation. DLN systems shall each be tuned upon initial operation to optimize emissions reductions consistent with normal operation and maintenance practices and shall be maintained to minimize NO<sub>x</sub> emissions and CO emissions, consistent with normal operation and maintenance practices. Operation of the DLN systems in the diffusion-firing mode shall be minimized when firing natural gas. [Rule 62-4.070, and 62-210.650, F.A.C.]

**EMISSION LIMITS AND STANDARDS**

18. Following is a summary of the emission limits and required technology. Values for NO<sub>x</sub> are corrected to 15 % O<sub>2</sub> on a dry basis. These limits or their equivalent in terms of lb/hr or NSPS units, as well as the applicable averaging times, are followed by the applicable specific conditions [Rules 62-212.400, 62-204.800(7)(b) (Subpart GG), 62-210.200 (Definitions-Potential Emissions) F.A.C.]

POLLUTANT	CONTROL TECHNOLOGY	EMISSION LIMIT
PM/PM <sub>10</sub> , VE	Pipeline Natural Gas Good Combustion	10 Percent Opacity (gas or oil)
VOC	As Above	1.4 ppmvw (Gas) 3.5 ppmvw (FO)
CO	As Above	12 ppmvd (Gas) 20 ppmvd (FO)
SO <sub>2</sub> and Sulfuric Acid Mist	Pipeline Natural Gas Low Sulfur Oil	2 gr S/100 ft <sup>3</sup> 0.05% S Fuel Oil
NO <sub>x</sub>	DLN, WI for F.O., limited fuel oil usage	10.5 ppmvd (DLN) → 9 ppmvd stack test 42 ppmvd (FO)

**19. Nitrogen Oxides (NO<sub>x</sub>) Emissions:**

- While firing Natural Gas: The emission rate of NO<sub>x</sub> in the exhaust gas shall not exceed 10.5 ppm @15% O<sub>2</sub> on a 24 hr block average as measured by the continuous emission monitoring system (CEMS). In addition, NO<sub>x</sub> emissions calculated as NO<sub>2</sub> shall not exceed 59 pounds per hour (at ISO conditions) and 9 ppmvd @15% O<sub>2</sub> to be demonstrated by the initial "new and clean" GE performance stack test. [Rule 62-212.400, F.A.C.]

Notwithstanding the applicable NO<sub>x</sub> limit during normal operation, reasonable measures shall be implemented to maintain the concentration of NO<sub>x</sub> in the exhaust gas at 9 ppmvd at 15% O<sub>2</sub> or lower. Any tuning of the combustors for Dry Low NO<sub>x</sub> operation while firing gas shall result in initial subsequent NO<sub>x</sub> concentrations of 9 ppmvd @15% O<sub>2</sub> or lower. [Rules 62-212.400 and 62-4.070, F.A.C.]

PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

SECTION III - EMISSIONS UNIT(S) SPECIFIC CONDITIONS

- While firing Fuel oil: The concentration of NO<sub>x</sub> in the exhaust gas shall not exceed 42 ppmvd at 15% O<sub>2</sub> on the basis of a 3-hr average as measured by the continuous emission monitoring system (CEMS). In addition, NO<sub>x</sub> emissions calculated as NO<sub>2</sub> shall not exceed 319 lb/hr (at ISO conditions) and 42 ppmvd @15% O<sub>2</sub> to be demonstrated by stack test. [Rule 62-212.400, F.A.C.]

The permittee shall develop a NO<sub>x</sub> reduction plan when the hours of oil firing reach the allowable limit of 750 hours per year. This plan shall include a testing protocol designed to establish the maximum water injection rate and the lowest NO<sub>x</sub> emissions possible without affecting the actual performance of the gas turbine. The testing protocol shall set a range of water injection rates and attempt to quantify the corresponding NO<sub>x</sub> emissions for each rate and noting any problems with performance. Based on the test results, the plan shall recommend a new NO<sub>x</sub> emissions limiting standard and shall be submitted to the Department's Bureau of Air Regulation and Compliance Authority for review. If the Department determines that a lower NO<sub>x</sub> emissions standard is warranted for oil firing, this permit shall be revised. (BACT Determination).

20. Carbon Monoxide (CO) Emissions: During the first 12 months after initial start up, the concentration of CO in the stack exhaust gas shall exceed neither 15 ppmvd nor 48 lb/hr (at ISO conditions) while firing gas and neither 33 ppmvd nor 106 lb/hr (at ISO conditions) while firing oil based on stack test. Thereafter, these limits will be revised and lowered to 12 ppmvd and 38 lb/hr (at ISO conditions) while firing gas and 20 ppmvd and 65 lb/hr (at ISO conditions). The permittee shall demonstrate compliance with these limits by stack test using EPA Method 10. [Rule 62-212.400, F.A.C.]
21. Volatile Organic Compounds (VOC) Emissions: The concentration of VOC in the stack exhaust gas with the combustion turbine operating on natural gas shall exceed neither 1.4 ppmvw nor 2.8 lb/hr (ISO conditions) and neither 3.5 ppmvw nor 7 lb/hr (ISO conditions) while operating on oil to be demonstrated by initial stack test using EPA Method 18, 25 or 25A. [Applicant Request]
22. Sulfur Dioxide (SO<sub>2</sub>) emissions: SO<sub>2</sub> emissions shall be limited by firing pipeline natural gas (sulfur content less than 2 grains per 100 standard cubic foot) or by firing No. 2 or superior grade distillate fuel oil with a maximum 0.05 percent sulfur for 750 hours per year per unit. Emissions of SO<sub>2</sub> (at ISO conditions) shall not exceed 9.2 lb/hr (natural gas) and 98.1 lb/hr (fuel oil) as measured by applicable compliance methods described below. [40CFR60 Subpart GG and Rules 62-4.070, 62-212.400, and 62-204.800(7), F.A.C.]
23. Visible Emissions (VE): VE emissions shall serve as a surrogate for PM/PM10 emissions and shall not exceed 10 opacity. Rules 62-4.070, 62-212.400, and 62-204.800(7), F.A.C.]

**EXCESS EMISSIONS**

24. Excess emissions resulting from startup, shutdown, or malfunction shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized. Excess emissions occurrences shall in no case exceed two hours in any 24-hour



PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

SECTION III - EMISSIONS UNIT(S) SPECIFIC CONDITIONS

period for other reasons unless specifically authorized by DEP for longer duration. Operation below 50% output shall be limited to 2 hours per unit cycle (breaker closed to breaker open).

25. Excess emissions entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction, shall be prohibited pursuant to Rule 62-210.700, F.A.C. These emissions shall be included in the 24-hr average for NO<sub>x</sub>.
26. Excess Emissions Report: If excess emissions occur due to malfunction (for greater than 2 hours in a 24-hr period), the owner or operator shall notify DEP's Southwest District within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident. Following the NSPS format, 40 CFR 60.7 Subpart A, periods of startup, shutdown, malfunction, shall be monitored, recorded, and reported as excess emissions when emission levels exceed the permitted standards listed in Specific Condition No. 18 and 19. [Rules 62-4.130, 62-204.800, 62-210.700(6), F.A.C., and 40 CFR 60.7 (1998 version)].

COMPLIANCE DETERMINATION

27. Compliance with the allowable emission limiting standards shall be determined within 60 days after achieving the maximum production rate, but not later than 180 days of initial operation of the unit, and annually thereafter as indicated in this permit, by using the following reference methods as described in 40 CFR 60, Appendix A (1998 version), and adopted by reference in Chapter 62-204.800, F.A.C.
28. Initial (I) performance tests (for both fuels) shall be performed on each unit while firing natural gas as well as while firing oil. Initial tests shall also be conducted after any modifications (and shake down period not to exceed 100 days after re-starting the CT) of air pollution control equipment such as change or tuning of combustors. Annual (A) compliance tests shall be performed during every federal fiscal year (October 1 - September 30) pursuant to Rule 62-297.310(7), F.A.C., on each unit as indicated. The following reference methods shall be used. No other test methods may be used for compliance testing unless prior DEP approval is received in writing.
- EPA Reference Method 9, "Visual Determination of the Opacity of Emissions from Stationary Sources" (I, A).
  - EPA Reference Method 10, "Determination of Carbon Monoxide Emissions from Stationary Sources" (I, A).
  - EPA Reference Method 20, "Determination of Oxides of Nitrogen Oxide, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines." Initial test only for compliance with 40CFR60 Subpart GG and (I, A) short-term NO<sub>x</sub> BACT limits (EPA reference Method 7E, "Determination of Nitrogen Oxides Emissions from Stationary Sources" or RATA test data may be used to demonstrate compliance for annual test requirements).

**PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263**  
**SECTION III - EMISSIONS UNIT(S) SPECIFIC CONDITIONS**

---

- EPA Reference Method 18, 25 and/or 25A, "Determination of Volatile Organic Concentrations." Initial test only.
29. Continuous compliance with the NO<sub>x</sub> emission limits: Continuous compliance with the NO<sub>x</sub> emission limits shall be demonstrated with the CEM system based on the applicable averaging time of 24-hr block average (DLN). Based on CEMS data, a separate compliance determination is conducted at the end of each operating day and a new average emission rate is calculated from the arithmetic average of all valid hourly emission rates from the previous operating day. A valid hourly emission rate shall be calculated for each hour in which at least two NO<sub>x</sub> concentrations are obtained at least 15 minutes apart. Valid hourly emission rates shall not include periods of start up, shutdown, or malfunction unless prohibited by 62-210.700 F.A.C. These excess emissions periods shall be reported as required in Conditions 25 and 26. [Rules 62-4.070 F.A.C., 62-210.700, F.A.C., 40 CFR 75 and BACT]
- All continuous monitoring systems (CEMS) shall be in continuous operation except for breakdowns, repairs, calibration checks, and zero and span adjustments. These CEMS shall meet minimum frequency of operation requirements: one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data average. [40CFR60.13]
30. Compliance with the SO<sub>2</sub> and PM/PM<sub>10</sub> emission limits: Notwithstanding the requirements of Rule 62-297.340, F.A.C., the use of pipeline natural gas, is the method for determining compliance for SO<sub>2</sub> and PM<sub>10</sub>. For the purposes of demonstrating compliance with the 40 CFR 60.333 SO<sub>2</sub> standard, ASTM methods D4084-82 or D3246-81 (or equivalent) for sulfur content of gaseous fuel shall be utilized in accordance with the EPA-approved custom fuel monitoring schedule or natural gas supplier data may be submitted or the natural gas sulfur content referenced in 40 CFR 75 Appendix D may be utilized. However, the applicant is responsible for ensuring that the procedures in 40 CFR60.335 or 40 CFR75 are used when determination of fuel sulfur content is made. Analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency pursuant to 40 CFR 60.335(e) (1998 version).
31. Compliance with CO emission limit: An initial test for CO shall be conducted concurrently with the initial NO<sub>x</sub> test, as required. The initial NO<sub>x</sub> and CO test results shall be the average of three valid one-hour runs. Annual compliance testing for CO may be conducted at less than capacity when compliance testing is conducted concurrent with the annual RATA testing for the NO<sub>x</sub> CEMS required pursuant to 40 CFR 75
32. Compliance with the VOC emission limit: An initial test is required to demonstrate compliance with the VOC emission limit. Thereafter, the CO emission limit and periodic tuning data will be employed as surrogate and no annual testing is required.
33. Testing procedures: Testing of emissions shall be conducted with the combustion turbine operating at permitted capacity. Permitted capacity is defined as 90-100 percent of the maximum

## PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

### SECTION III - EMISSIONS UNIT(S) SPECIFIC CONDITIONS

---

heat input rate allowed by the permit, corrected for the average ambient air temperature during the test (with 100 percent represented by a curve depicting heat input vs. ambient temperature). If it is impracticable to test at permitted capacity, the source may be tested at less than permitted capacity. In this case, subsequent operation is limited by adjusting the entire heat input vs. ambient temperature curve downward by an increment equal to the difference between the maximum permitted heat input (corrected for ambient temperature) and 110 percent of the value reached during the test until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purposes of additional compliance testing to regain the permitted capacity. Procedures for these tests shall meet all applicable requirements (i.e., testing time frequency, minimum compliance duration, etc.) of Chapters 62-204 and 62-297, F.A.C.

34. Test Notification: The DEP's Southwest District shall be notified, in writing, at least 30 days prior to the initial performance tests and at least 15 days before annual compliance test(s).
35. Special Compliance Tests: The DEP may request a special compliance test pursuant to Rule 62-297.310(7), F.A.C., when, after investigation (such as complaints, increased visible emissions, or questionable maintenance of control equipment), there is reason to believe that any applicable emission standard is being violated.
36. Test Results: Compliance test results shall be submitted to the DEP's Southwest District no later than 45 days after completion of the last test run. [Rule 62-297.310(8), F.A.C.].

#### NOTIFICATION, REPORTING, AND RECORDKEEPING

37. Records: All measurements, records, and other data required to be maintained by TEC shall be recorded in a permanent form and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. These records shall be made available to DEP representatives upon request.
38. Compliance Test Reports: A test report indicating the results of the required compliance tests shall be filed as per Condition No.36 above. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8), F.A.C.

#### MONITORING REQUIREMENTS

39. Continuous Monitoring System: The permittee shall install, calibrate, maintain, and operate a continuous emission monitor in the stack to measure and record the nitrogen oxides emissions from these units. Upon request from EPA or DEP, the CEMS emission rates for NO<sub>x</sub> on these Units shall be corrected to ISO conditions to demonstrate compliance with the NO<sub>x</sub> standard established in 40 CFR 60.332. [Rules 62-204.800, 62-210.700, 62-4.130, 62-4.160(8), F.A.C., 40 CFR 75 and 40 CFR 60.7 (1998 version)].
40. CEMS for reporting excess emissions: Excess Emissions and Monitoring System Performance Reports shall be submitted as specified in 40 CFR 60.7(c). CEM monitor downtime shall be

PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

SECTION III - EMISSIONS UNIT(S) SPECIFIC CONDITIONS

calculated and reported according to the requirements of 40 CFR 60.7(c)(3) and 40CFR 60.7(d)(2). Periods when NO<sub>x</sub> emissions (ppmvd @ 15% oxygen) are above the BACT standards, listed in Specific Conditions No 18 and 19, shall be reported to the DEP Southwest District within one working day (verbally) followed up by a written explanation not later than three (3) working days (alternatively by facsimile within one working day).

41. CEMS in lieu of Water to Fuel Ratio: The NO<sub>x</sub> CEMS shall be used in lieu of the water/fuel monitoring system for reporting excess emissions in accordance with 40 CFR 60.334(c)(1), Subpart GG (1998 version). The calibration of the water/fuel monitoring device required in 40 CFR 60.335 (c)(2) (1998 version) will be replaced by the 40 CFR 75 certification tests of the NO<sub>x</sub> CEMS
42. Continuous Monitoring Certification and Quality Assurance Requirements: The monitoring devices shall comply with the certification and quality assurance, and any other applicable requirements of Rule 62-297.520, F.A.C., 40 CFR 60.13, including certification of each device in accordance with 40 CFR 60, Appendix B, Performance Specifications and 40 CFR 60.7(a)(5) or 40 CFR Part 75. Quality assurance procedures must conform to all applicable sections of 40 CFR 60, Appendix F or 40CFR75. The monitoring plan, consisting of data on CEM equipment specifications, manufacturer, type, calibration and maintenance needs, and its proposed location shall be provided to the DEP Emissions Monitoring Section Administrator and EPA for review no later than 45 days prior to the first scheduled certification test pursuant to 40 CFR 75.62.
43. Natural Gas Monitoring Schedule: A custom fuel monitoring schedule pursuant to 40 CFR 75 Appendix D for natural gas may be used in lieu of the daily sampling requirements of 40 CFR 60.334 (b)(2) provided the following requirements are met:
- The permittee shall apply for an Acid Rain permit within the deadlines specified in 40 CFR 72.30.
  - The permittee shall submit a monitoring plan, certified by signature of the Designated Representative, that commits to using a primary fuel of pipeline supplied natural gas (sulfur content less than 20 gr/100 scf pursuant to 40 CFR 75.11(d)(2)).
  - Each unit shall be monitored for SO<sub>2</sub> emissions using methods consistent with the requirements of 40 CFR 75 and certified by the USEPA.

This custom fuel monitoring schedule will only be valid when pipeline natural gas is used as a primary fuel. If the primary fuel for these units is changed to a higher sulfur fuel, SO<sub>2</sub> emissions must be accounted for as required pursuant to 40 CFR 75.11(d).

44. Fuel Oil Monitoring Schedule: The following monitoring schedule for No. 2 or superior grade fuel oil shall be followed: For all bulk shipments of No. 2 fuel oil received at this facility an analysis which reports the sulfur content and nitrogen content of the fuel shall be provided by the fuel vendor. The analysis shall also specify the methods by which the analyses were conducted and shall comply with the requirements of 40 CFR 60.335(d).

PREVENTION OF SIGNIFICANT DETERIORATION PERMIT PSD-FL-263

SECTION III - EMISSIONS UNIT(S) SPECIFIC CONDITIONS

---

45. Determination of Process Variables:

- The permittee shall operate and maintain equipment and/or instruments necessary to determine process variables, such as process weight input or heat input, when such data is needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- Equipment and/or instruments used to directly or indirectly determine such process variables, including devices such as belt scales, weigh hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value [Rule 62-297.310(5), F.A.C]