



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

April 22, 1991

CERTIFIED MAIL-RETURN RECEIPT REQUESTED


Mr. Henry Hirschman, General Manager
Georgia-Pacific Corporation
P. O. Box 919
Palatka, Florida 32078-0919

Dear Mr. Hirschman:

Attached is one copy of the Technical Evaluation and Preliminary Determination and proposed permits for Georgia-Pacific Corporation to implement modifications/enhancements on the No. 4 recovery Boiler (RB) and No. 4 Lime Kiln, which have the potential to increase their total process input and product rates and potential pollutant emissions. The No. 4 Smelt Dissolving Tanks (North and South units) will also have the potential to increase the total process input rate of smelt and the potential pollutant emissions due to the increase of black liquor solids burned in the No. 4 RB. The proposed modification will result in new source review for Prevention of Significant Deterioration for the pollutants PM (particulate matter), PM₁₀, NO_x (nitrogen oxides), CO (carbon monoxide), and VOC (volatile organic compounds) pursuant to F.A.C. Rule 17-2.500(5).

Please submit any written comments you wish to have considered concerning the Department's proposed action to Mr. Barry Andrews of the Bureau of Air Regulation.

Sincerely,


C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/BM/plm

Attachments

c: J. Harper, EPA
A. Kutyna, NE District
D. A. Buff, P.E., KBN
V. L. Adams, G-PC

SENDER: Complete items 1 and 2 when additional services are desired and complete items 3 and 4. Put your address in the RETURN TO. Space on the reverse side. Failure to do this will prevent this card from being returned to you. The return receipt fee will provide you the name of the person delivered to and the date of delivery. For additional fees, the following services are available. Consult postmaster for fees and check box(es) for additional fees requested. (Extra charge)

1. Show to whom delivered date, and addressee's address. 2. Restricted Delivery (Extra charge)

3. Article Addressed to:
 Mr. Henry Hirschman
 General Manager
 Georgia-Pacific Corporation
 P. O. Box 919
 Palatka, FL 32078-0919

4. Article Number
 P 407 852 665

Type of Service:
 Registered Insured
 Certified COD
 Express Mail Return Receipt for Merchandise

5. Signature Addressee
 X *Henry Hirschman*

6. Signature Agent
 X *Robert [unclear]*

7. Date of Delivery
 4/25/91

8. Addressee's Address (ONLY if requested and fee paid)

PS Form 3811 Apr 1989 U.S.G.P.O. 1989-238-815

DOMESTIC RETURN RECEIPT

P 407 852 665
RECEIPT FOR CERTIFIED MAIL
 NO INSURANCE COVERAGE PROVIDED
 NOT FOR INTERNATIONAL MAIL
 (See Reverse)

U.S.G.P.O. 1989-234-555 PS Form 3800, June 1985	Sent to	Mr. Henry Hirschman, G-P
	Street and No.	P. O. Box 919
	P.O., State and ZIP Code	Palatka, FL 32078-0919
	Postage	\$
	Certified Fee	
	Special Delivery Fee	
	Restricted Delivery Fee	
	Return Receipt showing to whom and Date Delivered	
	Return Receipt showing to whom, Date, and Address of Delivery	
	TOTAL Postage and Fees	\$
Postmark or Date	Mailed: 4-23-91 Permit: AC 54-192250, -51 -193841, PSD-171	



Georgia-Pacific Corporation

Palatka Operations
Southern Pulp & Paper
P.O. Box 919
Palatka, Florida 32178-0919
Telephone (904) 325-2001

April 13, 1992

Mr. James K. Pennington, P.E.
Administrator
Air Compliance and Enforcement Section
Florida Department of Environmental Regulation
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Fl. 32399-2400

Re: Georgia-Pacific Corporation, Palatka, Fl. - Request for Exception and Approval of an Alternate Sampling Procedure for Measurement of Volatile Organic Compounds (VOC) Emissions from the No. 4 Recovery Furnace and No. 4 Lime Kiln

Dear Mr. Pennington:

The purpose of this letter is to provide the basis for requesting approval from the Florida Department of Environmental Regulation (FDER) of an alternate sampling procedure (ASP) when conducting VOC emission testing on the No. 4 Recovery Furnace and the No. 4 Lime Kiln at the Georgia-Pacific Corporation (G-P) mill in Palatka, Florida. This ASP request is in accordance with Rule 17-2.700(3), F.A.C.

1. Sources and Permit Numbers

No. 4 Recovery Furnace AC 54-192550
No. 4 Lime Kiln AC 54-192551

2. Current Regulations and Requested Exception

Section 17-2.700 F.A.C., pertains to source emission test procedures to be used for emission compliance testing. The No. 4 Recovery Furnace and the No. 4 Lime Kiln are by rule and specific conditions of the permits, subject to the source sampling methods of Section 17-2.700, F.A.C., i.e., EPA Reference Method 25 for the measurement of VOC emissions.

Exception is being sought to change the VOC emission test methodology as required in the permits from EPA Reference Method 25, to EPA Reference Method 25A.



Exhibit 1

3. Basis for Exception

Roy F. Weston, Inc. (WESTON[®]) conducted emission testing on the No. 4 Recovery Furnace and No. 4 Lime Kiln in accordance with G-P's permit requirements. WESTON recommended that EPA Method 25A be used in lieu of Method 25 for determining compliance with VOC emission limitations because of the expected high H₂O and CO₂ concentrations and low VOC concentrations of the gas streams. A mutual decision was made between G-P and WESTON to conduct the emission testing using both methods in parallel in order to compare the results of both methods:

- A. The use of EPA Reference Method 25 on combustion sources with high carbon dioxide and moisture concentrations is not appropriate. Section 1.1 of EPA Reference Method 25 states that CO₂ and water vapor can produce a positive bias, if the product of water vapor concentration and carbon dioxide concentration in the gas stream is greater than 100. Test results produced the following results:

<u>Source</u>	<u>H₂O</u> <u>(%)</u>	<u>CO₂</u> <u>(%)</u>	<u>Product</u>
No. 4 Recovery Furnace	24	14	336
No. 4 Lime Kiln	36	18	648

Therefore, the high results obtained with Method 25 were expected based on all known information. These results include significant positive interference from the CO₂ trapped in the ice of the cold trap. During preliminary testing, extra traps were collected for analysis by EPA Reference Method 25. Two of the traps (one from the No. 4 Lime Kiln and one from the No. 4 Recovery Furnace) were warmed to ice bath temperatures and purged with dry nitrogen to remove the moisture and CO₂. Then the VOC measured in the trap was lower by a factor of 10. This procedure demonstrates that in fact CO₂ was entrapped in the dry ice trap. The results obtained by EPA Reference Method 25 were, therefore, inaccurate. The results by EPA Reference Method 25A are representative of the source emissions.

- B. EPA Method 25 was developed for use in the coatings industry where volatile solvents are measured. The gas streams are normally ambient air with unsaturated moisture conditions. Concentrations normally range from 1000 - 5000 mg C/M³. The method does not have adequate detection limits for measuring less than 100 mg C/M³.

**EMISSION MEASUREMENT TECHNICAL INFORMATION CENTER
GUIDELINE DOCUMENT**

Applicability of Methods 25 and 25A**SUMMARY**

State regulations sometimes require testers to measure VOC emissions from sources where the concentration of VOC is less than 50 ppm as carbon. We recommend that Method 25A be used to measure the concentration of VOC emissions from these kind of sources.

DISCUSSION

There are three EPA test methods that are appropriate for measuring total VOC emissions. These are Methods 25, 25A, and 25B. Method 25 is designed to measure the destruction efficiency of incinerators used to control VOC emissions from coating sources. While it would be generally applicable to any source, it has a relatively high minimum detectable level of 50 ppm, as carbon. This would limit its usefulness at sources where VOC emissions are less than 50 ppm.

We recommend that testers use Method 25A for measuring VOC emissions from sources that have VOC emissions that are below the minimum detectable level of Method 25. This approach is not without problems. When Method 25A is used to measure unknown VOC emissions, there is a potential negative bias in the results. In addition, if methane is present in the source emissions, a separate method would be required to measure the methane and subtract it from total organic emissions measured by Method 25A to determine VOC. Despite these problems, Method 25A is the only EPA procedure that can measure total VOC at the levels present at some sources.

Prepared by Gary McAlister, Emission Measurement Branch
Technical Support Division, OAQPS, EPA

EMTIC 60-011
January 23, 1991



TABLE 2.5. VOC EMISSION DATA -
NO. 4 RECOVERY FURNACE

	RUN 1	RUN 2	RUN 3	MEAN
Date	03/13/92	03/13/92	03/13/92	---
Time Began	1147	1311	1432	---
Time Ended	1250	1415	1535	---
Stack Gas				
Temperature, °F	430	433	432	432
Velocity, ft/sec	54.6	54.7	54.2	54.5
Moisture, %	23.2	21.9	22.2	22.4
CO ₂ Concentration, %	14.6	14.6	14.8	14.7
O ₂ Concentration, %	4.0	4.2	4.2	4.1
Volumetric Flow Rate				
At Stack Conditions, x 10 ³ ft ³ /min	4.46	4.47	4.43	4.45
At Standard Conditions*, x 10 ³ ft ³ /min	2.03	2.07	2.04	2.05
Production Rate, ton BLS ^b /hr	96.6	97.1	97.4	97.0
Volatile Organic Compounds ^c				
Concentration, ppmvd @ 8% O ₂				
EPA 25	602.4	34.9	54.3	230.6
EPA 25A	8.1	7.1	4.2	6.5
Emission Rate, lb/hr				
EPA 25	299.0	17.5	26.8	114.4
EPA 25A	4.0	3.6	2.1	3.2
Emission Rate, lb/ton ELS ^b				
EPA 25	3.10	0.18	0.28	1.19
EPA 25A	0.04	0.04	0.02	0.03
Permit Limit, lb/hr	---	---	---	54.6
Permit Limit, lb/ton BLS ^b	---	---	---	0.52

*68°F, 29.92 in. Hg.

^bBlack liquor solids.

^cAs carbon.



TABLE 2.3. NO_x, CO, AND VOC EMISSION DATA -
NO. 4 LIME KILN

	RUN 1	RUN 2	RUN 3	MEAN
Date	02/05/92	02/05/92	02/05/92	---
Time Began	1915	2052	2315	---
Time Ended	2016	2152	0043	---
Stack Gas				
Temperature, °F	164	166	161	164
Velocity, ft/sec	60.9	60.0	60.5	60.5
Moisture, %	35.9	37.6	33.5	(35.7)
CO ₂ Concentration, %	18.0	18.1	17.7	(17.9)
O ₂ Concentration, %	5.8	5.8	6.0	5.9
Volumetric Flow Rate				
At Stack Conditions, x 10 ⁴ ft ³ /min	5.60	5.52	5.56	5.56
At Standard Conditions ^a , x 10 ⁴ ft ³ /min	3.00	2.87	3.11	2.99
Nitrogen Oxides				
Concentration, ppmvd @ 10% O ₂	69	108	65	80
Emission Rate, lb/hr	20.4	30.6	19.6	23.6
Permit Limit, ppmvd @ 10% O ₂	---	---	---	290
Permit Limit, lb/hr	---	---	---	50.3
Carbon Monoxide				
Concentration, ppmvd @ 10% O ₂	12	11	11	11
Emission Rate, lb/hr	2.2	1.9	2.0	2.0
Permit Limit, ppmvd @ 10% O ₂	---	---	---	69
Permit Limit, lb/hr	---	---	---	7.3
Volatile Organic Compounds^b				
Concentration, ppmvd @ 10% O ₂				
EPA 25	601	673	532	602
EPA 25A	15	1	3	6
Emission Rate, lb/hr				
EPA 25	46.6	49.9	42.2	46.2
EPA 25A	1.1	0.1	0.3	0.5
Permit Limit, ppmvd @ 10% O ₂	---	---	---	185
Permit Limit, lb/hr	---	---	---	17.2

^a68°F, 29.92 in Hg.

^bAs carbon.

Attachments Available Upon Request



Georgia-Pacific Corporation *Palatka Operations*
Southern Pulp & Paper Division
P.O. Box 919
Palatka, Florida 32078-0919
Telephone (904) 325-2001

March 21, 1991

RECEIVED

MAR 22 1991

DER-BAQM

Mr. Clair H. Fancy, P.E.
Florida Department of
Environmental Regulation
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Dear Mr. Fancy:

We have received your letter of March 15, 1991 regarding the completeness review of our applications to modify our existing No. 4 Recovery Boiler, Smelt Dissolving Tanks and No. 4 Lime Kiln. We will address each of your concerns below.

The majority of the information requested in item No. 1 of your letter was supplied in our letter to Bruce Mitchell of March 15th. The process flow rate was supplied in the application. The compliance test protocol for the smelt dissolving tanks has varied throughout the years with the mill striving to satisfy the district office. We believe the most appropriate test protocol is to either test both stacks simultaneously and call it one test or to test the two stacks back to back and add the emissions together to get the results for one test.

Item No. 2 of your letter stated that the kiln was not capable of accommodating the increased capacity without the proposed physical modification and may be subject to NSPS. We disagree, the kiln is capable of accommodating the increased capacity and in fact is currently permitted for the same rate requested in the new permit. An additional analysis of the NSPS applicability is presented on pages 3-18 and 3-19 of the application. The application was submitted due to PSD requirements.

Items Nos. 3 and 4 deal with purchased lime and its use as a supplement to the kiln. The supplemental lime usage will not decrease on a 1 to 1 basis with increased production from the kiln. The production of green liquor at the smelt dissolving tanks will increase and the additional lime from the kiln will be used to process the additional green liquor to white liquor. The amount of purchased lime used at the mill is not pertinent to this permit, purchased lime is not used in the production of the artificial white liquor for the digesters. The usage of artificial white liquor made from NaOH and NaSH will decrease as real white liquor becomes available. The information requested concerning the amount of lime purchased by the mill in each of the last five years is not readily available in that form and my discussions with Bruce Mitchell confirm that the information is not necessary for these permits.

Questions #5 and #6 are asking us to rate each of the systems in the mill on a tons of ADUP basis for the last five years and for the future. We agree this might make life appear simple, but unfortunately life is not that easy. The numbers we have that would allow us to estimate our throughput on a tons of ADUP basis are just estimates and vary widely based on such things as inorganic and organic load within the various systems. For example our estimated pounds of BLS per ton of pulp varied from 3557 to 2630 within one three month period in 1990. The units measuring throughput in the rule are the appropriate units to use and are supplied in the applications. As we have stated before we are not changing throughput on the other units and the emissions will remain the same from the other units.

Item 7 requests that we address all of the concerns in the March 12th letter from EPA. We have addressed these concerns in previous letters to Bruce Mitchell from David Buff and myself dated March 13th and March 15th.

I spoke with Mr. Kutyna concerning the questions addressed in item 8. As addressed on page 2-1 of the application, we are modifying the air distribution system to a more modern design and adding a tertiary forced draft fan. The work which is being done on the precipitator is designed to basically put the unit back into near original condition. The unit is a relatively modern boiler with efficient computer control.

We have noted the change in PM10 modeling as noted in EPA's letter and will apply those changes to future modeling efforts. Previous letters submitted to the Department confirm that the approach we utilized is even more conservative and demonstrates compliance.

If you have any questions or if I can be of further service, please call me at 904-325-2001.

Sincerely,



Vernon L. Adams
Superintendent of
Environmental Affairs

Seal



David A. Buff, P.E.
Florida Registration No. 19011

cc: A. Beshire
D. Buff
H. Hirschman
B. Mitchell
W. R. Wilson
C. Holladay
B. Andrews
A. Kitzner, NE Dist
J. Harper, EPA

Georgia-Pacific



Palatka Operations
P.O. Box 919
Palatka, Florida 32178-0919
Telephone: (904) 325-2001

FAX Number: (904) 328-0014

COVER SHEET FOR ALL FAX TRANSMITTALS

DATE: 3/21/91

TO: Bruce Mitchell

FAX No. (904) 922-6979 Speed No.

PAGES = Total number of pages (including this cover sheet)

FROM: Vernon Adams

FAX No. If different from (904) 328-0014 Phone No. If different from (904) 325-2001 Ext.

Comments:

MISSION

**Palatka Pride,
Dedicated People
Delivering Quality:
On Time, Every Time!**



Georgia-Pacific Corporation

Palatka Operations
Southern Pulp & Paper DivisionP.O. Box 919
Palatka, Florida 32078-0919
Telephone (904) 325-2001

March 21, 1991

Mr. Clair H. Fancy, P.E.
Florida Department of
Environmental Regulation
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Dear Mr. Fancy:

We have received your letter of March 15, 1991 regarding the completeness review of our applications to modify our existing No. 4 Recovery Boiler, Smelt Dissolving Tanks and No. 4 Lime Kiln. We will address each of your concerns below.

The majority of the information requested in item No. 1 of your letter was supplied in our letter to Bruce Mitchell of March 15th. The process flow rate was supplied in the application. The compliance test protocol for the smelt dissolving tanks has varied throughout the years with the mill striving to satisfy the district office. We believe the most appropriate test protocol is to either test both stacks simultaneously and call it one test or to test the two stacks back to back and add the emissions together to get the results for one test.

Item No. 2 of your letter stated that the kiln was not capable of accommodating the increased capacity without the proposed physical modification and may be subject to NSPS. We disagree, the kiln is capable of accommodating the increased capacity and in fact is currently permitted for the same rate requested in the new permit. An additional analysis of the NSPS applicability is presented on pages 3-18 and 3-19 of the application. The application was submitted due to PSD requirements.

Items Nos. 3 and 4 deal with purchased lime and its use as a supplement to the kiln. The supplemental lime usage will not decrease on a 1-to-1 basis with increased production from the kiln. The production of green liquor at the smelt dissolving tanks will increase and the additional lime from the kiln will be used to process the additional green liquor to white liquor. The amount of purchased lime used at the mill is not pertinent to this permit, purchased lime is not used in the production of the artificial white liquor for the digesters. The usage of artificial white liquor made from NaOH and NaSH will decrease as real white liquor becomes available. The information requested concerning the amount of lime purchased by the mill in each of the last five years is not readily available in that form and my discussions with Bruce Mitchell confirm that the information is not necessary for these permits.

Questions #5 and #6 are asking us to rate each of the systems in the mill on a tons of ADUP basis for the last five years and for the future. We agree this might make life appear simple, but unfortunately life is not that easy. The numbers we have that would allow us to estimate our throughput on a tons of ADUP basis are just estimates and vary widely based on such things as inorganic and organic load within the various systems. For example our estimated pounds of BLS per ton of pulp varied from 3557 to 2630 within one three month period in 1990. The units measuring throughput in the rule are the appropriate units to use and are supplied in the applications. As we have stated before we are not changing throughput on the other units and the emissions will remain the same from the other units.


Item 7 requests that we address all of the concerns in the March 12th letter from EPA. We have addressed these concerns in previous letters to Bruce Mitchell from David Buff and myself dated March 13th and March 15th.

I spoke with Mr. Kutyna concerning the questions addressed in item 8. As addressed on page 2-1 of the application, we are modifying the air distribution system to a more modern design and adding a tertiary forced draft fan. The work which is being done on the precipitator is designed to basically put the unit back into near original condition. The unit is a relatively modern boiler with efficient computer control.

We have noted the change in PM10 modeling as noted in EPA's letter and will apply those changes to future modeling efforts. Previous letters submitted to the Department confirm that the approach we utilized is even more conservative and demonstrates compliance.


If you have any questions or if I can be of further service, please call me at 904-325-2001.

Sincerely,



Vernon L. Adams
Superintendent of
Environmental Affairs


Seal



David A. Buff, P.E.
Florida Registration No. 19011

cc: A. Beshire
E. Buff
H. Hirschman
B. Mitchell
W. R. Wilson

File Copy



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

March 18, 1991

Ms. Jewell A. Harper, Chief
Air Enforcement Branch
Air, Pesticides & Toxics Management Division
U.S. EPA, Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30365


Dear Ms. Harper:

Re: Georgia-Pacific Corporation
PSD-FL-171 Addendum

The Department has received an addendum to the above referenced PSD application package. Please attach this document to the application package. Upon receipt of the mill's response to the incompleteness letter of March 15, 1991, we will forward a copy of it for your evaluation.

If you have any questions, please call Bruce Mitchell or Cleve Holladay at (904)488-1344 or write to me at the above address.


Sincerely,


E. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/BM/rbm

Attachment

c: A. Kutyna, NE District
V. Adams, G-PC



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

FAX TRANSMITTAL LETTER

DATE: 3-16-91

TO:

NAME: Vernon Adams

AGENCY: Georgia-Pacific Corp (904) 325-2001

TELEPHONE: 904-328-0014

OF PAGES (INCLUDE COVER SHEET): 3

FROM:

NAME: Bruce Mitchell

AGENCY: EDER/DARM/BAR

IF ANY PAGES ARE NOT CLEARLY RECEIVED, PLEASE CALL IMMEDIATELY. PHONE NO. (904) 488-1344

SENDER'S NAME: Sam

COMMENTS: Incompleteness Letter

AC 54-192250

-192251

-193841

PSD-FL-171


MESSAGE CONFIRMATION

MAR-16-'91 SAT 10:06

TERM ID: DIV OF AIR RES NGMT P-9999

TEL NO: 904-923-6979

NO.	DATE	ST. TIME	TOTAL TIME	ID	DEPT CODE	OK	NG
662	03-16	10:04	00'01'59	9043280014		03	00



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

March 15, 1991

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Henry Hirschman, General Manager
Georgia-Pacific Corporation
Post Office Box 919
Palatka, Florida 32078-0919

Dear Mr. Hirschman:

Re: Completeness Review of Applications to Modify
AC 54-192250: No. 4 Recovery Boiler
AC 54-192251: No. Lime Kiln
AC 54-193841: No. 4 Smelt Dissolving Tanks (North & South)
PSD-FL-171

The Department has reviewed the above referenced application packages received February 13, 1991. Based on a technical evaluation, the applications are deemed incomplete. Please submit to the Department's Bureau of Air Regulation a response to the following, including all calculations, assumptions and reference material, and the status will, again, be ascertained. Also, all technical responses must be under the seal of the P.E. of Record.

1. Provide a detailed physical and operational description of the North and South No. 4 Smelt Dissolving Tanks (i.e., single/dual operations, raw material throughput rates, compliance testing protocol, etc.).
2. Since the No. 4 Lime Kiln was not capable of accommodating the increased capacity without the proposed physical modification, the subject of NSPS applicability arises. The Department will continue to evaluate this with Region IV, U.S. EPA, and will advise.
3. Will the amount of purchased lime that has been used to supplement the No. 4 lime kiln decrease on a 1 to 1 basis to the amount of the increased lime production projected after the modification is completed? If not, please explain.
4. How much purchased lime, on a per year basis and for the last 5 years, has been obtained to supplement the No. 4 lime kiln?


Mr. Henry Hirschman
March 15, 1991
Page Two

5. On a per system basis (i.e., batch digester system, multiple effect evaporator systems, lime kilns, recovery boilers, etc.), what are the actual equivalent tons in ADUP that the facility has been producing on a per year basis and for the last 5 years?
6. On a per system basis, what are the proposed production levels in equivalent tons of ADUP that the facility will be at after the modifications are completed?
7. Please address all of the concerns contained in the attached March 12, 1991 letter from Ms. Jewell A. Harper, U.S. EPA, Region IV.
8. As received via FAX, the Department's Northeast District requests that the following be addressed:

What specific changes are proposed to increase the No. 4 Recovery Boiler's efficiency (e.g. combustion air modifications, black liquor additives, precipitator modifications such as computer control, etc.)?
9. Please note Modeling/Monitoring comment No. 2 in the attached March 12, 1991 letter from Region IV, U.S. EPA. In any future permit applications and if additional PM-10 modeling is required with this analysis, the sixth highest 24-hour concentration (based on 5 full years of 24-hour concentration estimates at the same receptor) for each receptor in the network must be identified for comparison with the PM-10 24-hour standard.

If there are any questions, please call Bruce Mitchell or Cleve Holladay at 904-488-1344 or write to me at the above address.

Sincerely,



C. H. Fancy, P.E.
Chief
Bureau of Air Regulation.

CHF/BM/plm

Attachment

c: A. Kutyna, NED
J. Harper, U.S. EPA
V. Adams, G-PC
D. Buff, P.E., KBN



Georgia-Pacific Corporation Palatka Operations
Southern Pulp & Paper Division
P.O. Box 919
Palatka, Florida 32078-0919
Telephone (904) 325-2001

March 15, 1991

RECEIVED

MAR 18 1991

DER-BAQM

Mr. Bruce Mitchell
Florida Department of
Environmental Regulation
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Dear Mr. Mitchell:

Pursuant to our conversations yesterday, please find within this letter a description of the smelt dissolving tank system associated with the #4 Recovery Boiler and find attached a response which was prepared by David Buff, to EPA's recent inquiries.

The smelt from the #4 Recovery flow out of the bottom of the unit on both the North and South sides (see the attached drawing). As it exits the furnace the smelt enters either the North or South smelt dissolving tanks. There is no control on how much smelt goes to which tank, but we believe that the distribution is approximately even. Weak wash can enter the system through either the North or South unit, it then contacts the smelt from the corresponding side of the furnace and continues flowing to the other tank where it contacts the smelt from the other side of the furnace, it is then green liquor.

If you have any questions or if I can be of further service, please call me at 904-325-2001.


Sincerely,

Vernon L. Adams
Superintendent of
Environmental Affairs

cc: A. Beshire
D. Buff
H. Hirschman
W. R. Wilson

A. Kutyna, NE Dist.
B. Mitchell
C. Holladay
J. Harper, U.S. EPA, Region IV (attn. Gregg Worley ; Lou Negler)

} 3-18-91 RAN





March 15, 1991

Mr. Bruce Mitchell, P.E.
Bureau of Air Regulation
Florida Department of Environmental Regulation
2600 Blair Stone Road
Tallahassee, Florida

Re: Georgia-Pacific Corporation
Proposed Recovery Boiler/Lime Kiln Project

Dear Mr. Mitchell:

The purpose of this letter is to address comments that EPA Region IV have made in regard to the Georgia-Pacific Corporation (G-P) air construction permit application for a proposed rate increase for the No. 4 Recovery Boiler (RB4), No. 4 Smelt Dissolving Tank (SDT4), and No. 4 Lime Kiln (LK4). The comments were provided in an EPA Region IV letter to DER dated March 12, 1991. G-P's response to these comments are provided below, under the same topics as listed in the letter.

Modeling/Monitoring

These issues were addressed in G-P's letter to DER dated March 13, 1991. NAAQS modeling for PM10 was performed as part of the original permit application. KBN's use of the highest, second highest 24-hour PM10 concentration results in a higher predicted impact than if the sixth-highest concentration was used.

Netting Calculation

G-P's response to this concern was contained in the March 13 letter to DER.

BACT Analysis

RECOVERY BOILER

1. The black liquor input is shown in Section III.E. of the application and is based on a solids content of 66.3%.
2. Current actual SO₂ emissions have been in the range of 7 to 10 ppm for RB4. However, the effect of the changes being implemented in the air and firing systems of the boiler are not known. The boiler vendor has guaranteed an SO₂ level of 125 ppm at 8 percent O₂. In addition, review of permitted SO₂ emission rates for recovery boilers indicates there are only two boilers with SO₂ limits less than 75 ppm. Most boilers have permit limits of 150 ppm or higher. Based on these considerations, the proposed limit for RB4 of 75 ppm is reasonable.

KBN ENGINEERING AND APPLIED SCIENCES, INC.

1034 Northwest 57th Street Gainesville, Florida 32605 904/331-9000 FAX: 904/332-4189

EQUAL EMPLOYMENT OPPORTUNITY / AN AFFIRMATIVE ACTION EMPLOYER



B. Mitchell
March 15, 1991
Page 2

3. Historic PM emission data from RB4 was presented in the permit application. These data showed that the existing ESP has achieved emission levels ranging from 0.009 to 0.037 gr/dscf, which is below the proposed NSPS level of 0.044 gr/dscf. However, the original design of the ESP was to meet the state of Florida standard of 3 lb/3000 lb BLS. This is equivalent to approximately 0.100 gr/dscf.

Under the current proposal, the gas flow rate through the ESP is projected to increase, and this may slightly lower the effectiveness of the ESP. G-P will be refurbishing the ESP as part of the proposed project, which likely result in improved performance. However, the performance of the ESP, as with any control device, varies over time. The ESP vendor has indicated that the current ESP design is appropriate for RB4, i.e., a new ESP would be designed in a similar manner.

The proposal to refurbish the ESP and agree to a much lower PM emission limit than present represents a significant commitment on the part of G-P.

Although emissions lower than the 0.044 gr/dscf NSPS are expected to be achieved, the NSPS level is a reasonable maximum emission limit.

A review of current permit limits for recovery boilers indicated that there are currently 22 boilers with PM limits set equal to the NSPS. Of these, 15 were BACT determinations.

4. G-P has proposed short-term emission limits for CO and VOC for RB4 (reference pages 6-8 and 6-11 of the permit application). The proposed short-term CO limit is 800 ppm, and the maximum VOC limit not to be exceeded is 0.52 lb/ton BLS. For NO_x, G-P is willing to accept a 24-hour average emission limit equal to the annual average limit, i.e., 100 ppmvd corrected to 8 percent O₂.

LIME KILN

G-P has proposed the current PM limit for LK4 because only minor changes are being made to the kiln. The maximum permitted throughput of the kiln is not changing. The existing control equipment is working well. The present scrubber is operating within its design conditions. As described in the application, the proposed PM limit is 0.098 gr/dscf, corrected to 10 percent O₂ (based on 4 percent oxygen in kiln). This limit is well within the range of previous BACT determinations for other facilities. Considering these aspects, a lower PM emission limit is not warranted.


Please call if you have any questions concerning this information.

Sincerely,

A handwritten signature in cursive script that reads "David A. Buff".

David A. Buff, M.E., P.E.
Principal Engineer

cc: Vernon Adams
Keith Bentley



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

March 15, 1991

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Henry Hirschman, General Manager
Georgia-Pacific Corporation
Post Office Box 919
Palatka, Florida 32078-0919

Dear Mr. Hirschman:

Re: ¹⁹²⁵⁵⁰ ¹⁹²⁵⁵¹ Completeness Review of Applications to Modify
AC 54-192250: No. 4 Recovery Boiler
AC 54-192251: No. Lime Kiln
AC 54-193841: No. 4 Smelt Dissolving Tanks (North & South)
PSD-FL-171

The Department has reviewed the above referenced application packages received February 13, 1991. Based on a technical evaluation, the applications are deemed incomplete. Please submit to the Department's Bureau of Air Regulation a response to the following, including all calculations, assumptions and reference material, and the status will, again, be ascertained. Also, all technical responses must be under the seal of the P.E. of Record.

1. Provide a detailed physical and operational description of the North and South No. 4 Smelt Dissolving Tanks (i.e., single/dual operations, raw material throughput rates, compliance testing protocol, etc.).
2. Since the No. 4 Lime Kiln was not capable of accommodating the increased capacity without the proposed physical modification, the subject of NSPS applicability arises. The Department will continue to evaluate this with Region IV, U.S. EPA, and will advise.
3. Will the amount of purchased lime that has been used to supplement the No. 4 lime kiln decrease on a 1 to 1 basis to the amount of the increased lime production projected after the modification is completed? If not, please explain.
4. How much purchased lime, on a per year basis and for the last 5 years, has been obtained to supplement the No. 4 lime kiln?

Mr. Henry Hirschman
March 15, 1991
Page Two

5. On a per system basis (i.e., batch digester system, multiple effect evaporator systems, lime kilns, recovery boilers, etc.), what are the actual equivalent tons in ADUP that the facility has been producing on a per year basis and for the last 5 years?
6. On a per system basis, what are the proposed production levels in equivalent tons of ADUP that the facility will be at after the modifications are completed?
7. Please address all of the concerns contained in the attached March 12, 1991 letter from Ms. Jewell A. Harper, U.S. EPA, Region IV.
8. As received via FAX, the Department's Northeast District requests that the following be addressed:

What specific changes are proposed to increase the No. 4 Recovery Boiler's efficiency (e.g. combustion air modifications, black liquor additives, precipitator modifications such as computer control, etc.)?
9. Please note Modeling/Monitoring comment No. 2 in the attached March 12, 1991 letter from Region IV, U.S. EPA. In any future permit applications and if additional PM-10 modeling is required with this analysis, the sixth highest 24-hour concentration (based on 5 full years of 24-hour concentration estimates at the same receptor) for each receptor in the network must be identified for comparison with the PM-10 24-hour standard.

If there are any questions, please call Bruce Mitchell or Cleve Holladay at 904-488-1344 or write to me at the above address.

Sincerely,



C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/BM/plm

Attachment

c: A. Kutyna, NED
J. Harper, U.S. EPA
V. Adams, G-PC
D. Buff, P.E., KBN

SENDER: Complete items 1 and 2 when additional services are desired and complete items 3 and 4.
 Put your address in the RETURN TO space on the reverse side. Failure to do this will prevent this card from being returned to you. The return receipt fee will provide you the name of the person delivered to and the date of delivery. For additional fees the following services are available. Consult postmaster for fees and check box(es) for additional service(s) requested.

1. Show to whom delivered, date and addressee's address. 2. Restricted Delivery (Extra charge)

3. Article Addressed to:
 Henry Airschman
 GA-Pacific Corp.
 P.O. Box 919
 Palatka, FL 32078-0919

4. Article Number:
 P 407 852 654

Type of Service:
 Registered Insured
 Certified COD
 Express Mail Return Receipt for Merchandise

5. Signature - Addressee:
 X *Henry Airschman*

6. Signature - Agent:
 X *S. F. Brown*

7. Date of Delivery:
 3/15/91

8. Addressee's Address (ONLY if requested and fee paid):
 A1

PS Form 3811, Apr 1985 U.S.G.P.O. 1989-234-555 DOMESTIC RETURN RECEIPT

P 407 852 654

RECEIPT FOR CERTIFIED MAIL

NO INSURANCE COVERAGE PROVIDED
 NOT FOR INTERNATIONAL MAIL
 (See Reverse)

U.S.G.P.O. 1989-234-555
 PS Form 3800, June 1985

Sender	<i>Henry Airschman</i>
Street and No.	<i>GA-Pacific</i>
P.O. Station and ZIP Code	<i>Palatka, FL</i>
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt showing to whom and Date Delivered	
Return Receipt showing to whom, Date, and Address of Delivery	
TOTAL Postage and Fees	\$
Postmark or Date	<i>3-15-91</i>
	<i>AC 54-192250</i>
	<i>PSD-FL-171 251</i>
	<i>841</i>



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET, N.E.
ATLANTA, GEORGIA 30365

RECEIVED

MAR 15 1991

MAR 12 1991

DER-BAQM

4APT-AEB

Mr. Clair H. Fancy, P.E., Chief
Bureau of Air Regulation
Florida Department of Environmental
Regulation
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

RE: Georgia-Pacific Corporation, Palatka (PSD-FL-171)

Dear Mr. Fancy:

This is to acknowledge receipt of an application for a Prevention of Significant Deterioration (PSD) permit for the above referenced facility transmitted by your letter of February 14, 1991. As discussed between Mr. Bruce Mitchell of your staff and Mr. Gregg Worley of my staff on March 7, 1991, we have the following comments and questions on the submittal.

Modelling/Monitoring

The modeling analysis as submitted has been reviewed. The modification will have a significant impact for TSP/PM-10; however, since a previously permitted PSD source at the plant was never constructed, the total increment consumption will be less now than with the prior application. Based on this decrease in overall emissions, further modelling was deemed by the applicant to be unnecessary.

After discussing this point with EPA Headquarters, it was agreed that if there is a significant impact from the new source or modification, a NAAQS review is required. There is no basis in our regulations to exempt further analysis, even if there is no threat to the available increment; we still need to determine what the impact on the NAAQS will be. Our comments are as follows:

1. A NAAQS modeling analysis is necessary for PM-10.
2. The standard for PM-10 is now a statistical standard and the sixth highest 24 hour concentration based on five years of meteorological data is now used instead of the high second highest value.

Netting Calculation

When calculating the net emissions increase for TRS emissions, GP included an emissions decrease which resulted from complying with Florida's TRS rule. Since the reduction was made to comply with regulations, it does not qualify as a creditable emissions decrease.

BACT Analysis

The BACT analysis does not propose controls other than the existing controls for the emissions units. Questions and comments about the BACT analysis performed by the applicant are as follows:

Recovery Boiler


1. What is the percent dryness of the black liquor solids? (Note that the recent trend for recovery boilers has been to burn drier black liquor solids, about 70 to 75% solids. The increased dryness has an effect both on SO₂ emissions and NO_x emissions.)
2. The application states that current actual emissions for SO₂ are in the range of 7-9 ppm, yet the requested permit limit is for 75 ppm. Although GP will apparently net out of PSD review for SO₂, the allowable emissions should more closely reflect the actual capabilities of the emissions unit.
3. What changes are being made to the ESP? In a recent permit application in Region IV (Hammermill Papers in Alabama) in which an existing recovery boiler was being modified, the efficiency of the existing ESP was evaluated and cost estimates were made on improving the efficiency of the ESP. GP has proposed a PM limit of 0.044 gr/dscf utilizing the existing ESP. Current permits for new recovery boilers are being issued in the range of 0.021 to 0.030 gr/dscf. The Hammermill facility mentioned above has proposed a level of 0.034 gr/dscf based on an economic evaluation. In any case, defaulting to the NSPS level without supporting documentation does not meet the requirements of a BACT analysis.
4. The applicant proposed emissions limits for CO, VOC, and NO_x based on an annual average. This does not meet the requirement of "short-term and specific" limits.

Lime Kiln


Again the applicant did not consider more stringent limits than the existing allowable emissions.

Thank you for the opportunity to review and comment on this application. If you have any questions or comments on the modeling comments, please contact Mr. Lew Nagler at (404) 347-2904. Other questions may be directed to Mr. Gregg Worley of my staff, also at (404) 347-2904.

Sincerely yours,

A handwritten signature in cursive script, appearing to read "Jewel A. Harper". The signature is written in black ink and is positioned above the typed name and title.

Jewel A. Harper, Chief
Air Enforcement Branch
Air, Pesticides, and Toxics
Management Division



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2000 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

FAX TRANSMITTAL LETTER

DATE: 3-16-91

TO:

NAME: Vernon Adams

AGENCY: Georgia-Pacific Corp (904) 325-2001

TELEPHONE: 904-328-0014

OF PAGES (INCLUDE COVER SHEET): 3

FROM:

NAME: Bruce Mitchell

AGENCY: FDER/DARM/BAR

IF ANY PAGES ARE NOT CLEARLY RECEIVED, PLEASE CALL IMMEDIATELY. PHONE NO. (904) 488-1344

SENDER'S NAME: Same

COMMENTS: Incompleteness Letter without Attachment

AC 54-192250

-192251

-193841

PSD-FL-171

MESSAGE CONFIRMATION

MAR-16-'91 SAT 10:06

TERM ID: DIV OF AIR RES MGMT P-9999

TEL NO: 904-922-6979

NO.	DATE	ST. TIME	TOTAL TIME	ID	DEPT CODE	OK	NG
662	03-16	10:04	00' 01' 59	9043280014		03	00

cc: Reading File }
Bruce Mitchell } 3-16-91 am

State of Florida
DEPARTMENT OF ENVIRONMENTAL REGULATION

Interoffice Memorandum

RECEIVED

MAR 13 1991

NORTHEAST DISTRICT DER BAQM JACONVILLE

TO: C.H. Fancy

FROM: Andrew Butyna

DATE: March 12, 1991

SUBJECT: PSD Application for Ga. Pacific/Putnam County

I have reviewed the PSD application submitted by Georgia Pacific for modifications to the recovery boiler and lime kiln.

The application appears to be complete, in my opinion. However, I do have one question:

What specific changes are proposed to improve the efficiency (e.g. combustion modifications, air pollution additives, precipitator modifications, etc.)?

Interoffice Memorandum

RECEIVED

MAR 13 1991

NORTHEAST DISTRICT DER-BAQM

TO: C.H. Fandy
FROM: Andrew Rutyn
DATE: March 12, 1991
SUBJECT: PSD Application for Ga. Pacific/Tulsa

I have reviewed the PSD application submitted by Georgia Pacific for modifications to the recovery boiler and lime kiln.

The application appears to be complete, in my opinion. However, I do have one question.

(See attached for details regarding the question. The question is: Are there any other modifications such as computer control, etc.?)

To: C.H. Fandy	Co. NED
From: Andrew Rutyn	Dept.
Date: 3/12/91	Phone #
Fax #	Fax #



DATE: 3/15/91

RECEIVED

TO: Bruce Mitchell

MAR 15 1991

ORGANIZATION: FDER

DER-BAQM

FAX NUMBER: 904 922-6979

TELEPHONE NUMBER: _____

FROM: D. Buff

TOTAL NUMBER OF PAGES: 5 (including cover page)

MESSAGE/INSTRUCTIONS:

PROJECT NUMBER: 90133

FAX OPERATOR: _____

() This is the ONLY form of delivery of the transmitted document.

() The original of the transmitted document will be sent by:

- () US Mail
- () Overnight delivery
- () Other: _____

Hand Delivered By V Adams

Return original to MBB

cc: Project File _____ yes _____ no _____



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET, N.E.
ATLANTA, GEORGIA 30365

BRUCE MITCHELL

FDER

Please find enclosed the following information:

Hammermill Papers PSD APPLICATION
(modified recovery boiler)

Gregg M. Worley
Source Evaluation Unit
Air Enforcement Branch
(404) 347-2904
FTS 257-2904

RECEIVED

MAR 13 1991

DER-BAQM




**Hammermill Papers
Riverdale Mill
Selma, Alabama**

**New Source Review for
Mill Expansion**

**Prepared for the Alabama
Department of Environmental
Management**

**Project No. 4032
September 1990**



Simons-Eastern Consultants, Inc.

Hammermill Papers
 Selma, Alabama
 New Source Review for Mill Expansion

Project No. 4032
 September 1990

TABLE OF CONTENTS

	<u>PAGE</u>
1. <u>INTRODUCTION</u>	1-1
2. <u>PROJECT DESCRIPTION</u>	2-1
2.1 PLANT LOCATION	2-1
2.2 PROJECT OVERVIEW	2-1
2.3 DIGESTERS	2-4
2.4 BROWN STOCK WASHING	2-5
2.5 BLEACH PLANTS	2-5
2.6 NO. 2 PAPER MACHINE	2-6
2.7 EXISTING NO. 3 LIME KILN	2-7
2.8 RECAUSTICIZING AREA	2-8
2.9 NO. 2 BLACK LIQUOR EVAPORATORS	2-9
2.10 EXISTING NO. 2 CHEMICAL RECOVERY BOILER	2-10
2.11 NO. 2 SMELT DISSOLVING TANK	2-12
2.12 NEW GAS AND OIL FIRED BOILER	2-13
3. <u>PSD APPLICABILITY</u>	3-1
4. <u>BACT ANALYSIS</u>	4-1
4.1 PARTICULATE MATTER - RECOVERY BOILER	4-2
4.2 PARTICULATE MATTER - NEW GAS/OIL FIRED BOILER	4-4

(continued)

Hammermill Papers
 Selma, Alabama
 New Source Review for Mill Expansion

Project No. 4032
 September 1990

TABLE OF CONTENTS (CONTINUED)

	<u>PAGE</u>
4.3 NITROGEN OXIDES - RECOVERY BOILER	4-14
4.4 NITROGEN OXIDES - NEW GAS/OIL FIRED BOILER	4-19
5. <u>AIR QUALITY ANALYSIS</u>	5-1
5.1 DISPERSION MODEL SELECTION AND DESCRIPTION OF SCREENING MODELING PROCEDURES	5-1
5.2 STRUCTURES AND GEP ANALYSIS	5-4
5.3 STACK CONDITIONS FOR MODELING	5-6
5.4 LOCATION OF RECEPTORS	5-8
5.5 RESULTS OF SCREENING MODELING FOR NITROGEN OXIDES	5-9
5.6 RESULTS OF SCREENING MODELING FOR PARTICULATE MATTER	5-10
6. <u>OTHER IMPACTS</u>	6-1
6.1 VISIBILITY	6-1
6.2 SOILS AND VEGETATION	6-3
6.3 DEMOGRAPHICS	6-3
6.4 CONSTRUCTION IMPACTS	6-5

LIST OF FIGURES

FIGURE 1 PLANT SITE LOCATION MAP	2-2
----------------------------------	-----

(continued)

Hammermill Papers
 Selma, Alabama
 New Source Review for Mill Expansion

Project No. 4032
 September 1990

TABLE OF CONTENTS (CONTINUED)

	<u>PAGE</u>
<u>LIST OF TABLES</u>	
TABLE 3.1 NEW SOURCE REVIEW APPLICABILITY ANALYSIS	3-4
TABLE 4.1 BACT ANALYSIS FOR CONTROL OF PARTICULATE MATTER FROM NO. 2 RECOVERY BOILER	4-5
TABLE 4.2 COMPLETE BACT/LAER CLEARINGHOUSE LISTINGS OF PARTICULATE EMISSIONS FROM GAS FIRED BOILERS	4-7
TABLE 4.3 COMPLETE BACT/LAER CLEARINGHOUSE LISTINGS OF PARTICULATE EMISSIONS FROM OIL FIRED BOILERS	4-10,11
TABLE 4.4 FINANCIAL IMPACT OF ADDING BAGHOUSE FOR CONTROL OF PARTICULATE WHEN FIRING OIL ON THE NEW GAS/OIL BOILER	4-13
TABLE 4.5 COMPLETE BACT/LAER CLEARINGHOUSE LISTINGS OF NO _x EMISSIONS FROM GAS FIRED BOILERS	4-21, 22,23
TABLE 4.6 FINANCIAL IMPACT OF ADDING SELECTIVE CATALYTIC REDUCTION FOR CONTROL OF NITROGEN OXIDES WHEN FIRING NATURAL GAS	4-26
TABLE 4.7 COMPLETE BACT/LAER CLEARINGHOUSE LISTINGS OF NO _x EMISSIONS FROM OIL FIRED BOILERS	4-28,29
TABLE 5.1 UPPER AIR DATA FOR MONTGOMERY-AVERAGE MIXING HEIGHTS	5-3
TABLE 5.2 STACK CONDITIONS FOR MODELED SOURCES	5-7
TABLE 5.3 RESULTS OF NO _x SCREENING MODELING	5-9
TABLE 5.4 RESULTS OF PARTICULATE SCREENING MODELING	5-11
TABLE 6.1 EMISSIONS AND SOURCES INCLUDED IN VISIBILITY ANALYSIS	6-2
TABLE 6.2 VISIBILITY MODEL RESULTS	6-4

(continued)

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

TABLE OF CONTENTS (CONTINUED)

LIST OF EXHIBITS

- EXHIBIT A BASIS OF CALCULATIONS OF EMISSIONS ESTIMATES
- EXHIBIT B SITE PLAN SHOWING SOURCE LOCATIONS AND BUILDING HEIGHTS
- EXHIBIT C DISPERSION MODEL COMPUTER PRINTOUTS
- EXHIBIT D VISIBILITY ANALYSIS CALCULATIONS
- EXHIBIT E AREA PLOT PLAN AND RECEPTOR LOCATION DRAWING
- EXHIBIT F REFERENCE MATERIALS FOR GEP CALCULATIONS:
TABLES OF COORDINATES AND HEIGHTS OF EACH MAJOR BUILDING OR BUILDING GROUP; SITE PLAN WORKSHEETS FOR DETERMINING COORDINATES; AND COMPUTER PRINT OUT SHEETS FOR "BREEZE WAKE" MODEL

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

1. INTRODUCTION

International Paper Incorporated owns and operates Hammermill Papers at Riverdale, Alabama, a bleached kraft pulp and paper mill. The products manufactured are fine papers and bleached kraft market pulp. An expansion is proposed that would significantly increase the mill's output of fine papers by the addition of a new 1000 TPD paper machine. Pulp production will increase by 143 bleached ADTD, or about 11 percent of current production rates.

This report was prepared to accompany applications to the Alabama Department of Environmental Management for permits to construct and operate new and modified sources of air pollutant emissions. It describes the proposed project and addresses all requirements of a new source review as set forth in the regulations of the United States Environmental Protection Agency and those of the Alabama Department of Environmental Management.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

2. PROJECT DESCRIPTION

2.1 PLANT LOCATION

Hammermill Paper's Riverdale mill, now owned by International Paper Company, is located on the Alabama River in Dallas County. The mill site is on Dallas County Highway 78 approximately eight miles east of Selma and four miles southeast of Brownsville. A vicinity map on page 2-2 locates the site.

The facility is situated in a location that is ideal for a pulp and paper operation. There are no major metropolitan areas nearby. The area is used essentially for tree and agricultural farming. Wood is available from virtually all points on the compass, and water supplies are adequate.

2.2 PROJECT OVERVIEW

Hammermill Paper's Riverdale mill, which now markets both fine papers and bleached pulp, will upgrade its product line by the addition of a new No. 2 paper machine having a nominal capacity of 1032 finished tons per day. The bleached pulp now sold will gradually be totally diverted to use as furnish for the new machine. Eventually, the

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990




Figure 1: Plant Site Location

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

combined output of the two paper machines will reach a nominal total of 1782 finished tons per day of fine reprographic papers.

The nominal capacity of the existing pulp mill is 1285 bleached air dry tons per day (1428 unbleached). To support the paper machine operations, a nominal pulp production capacity of 1428 bleached air dry tons per day (1586 unbleached) will be required. The additional tonnage, 143 bleached ADTPD (158 unbleached), will be achieved by changes in the plant which include the addition of certain new facilities, modifications to others, and the continued use of yet others that do not require modification.

Modifications and/or new facilities that will impact existing pollutant emissions will be implemented in the following production areas: digesters, brown stock washing, bleaching, new No. 2 paper machine, No.3 lime kiln, recausticizing, No. 2 black liquor evaporators, No. 2 chemical recovery boiler and smelt tank, and a new No. ²/₃ gas and oil fired power boiler.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

A new long log facility will be added to the woodyard operation, but it will not generate process pollutant emissions. This is also the case for a new 40 megawatt steam turbine generator.

It is planned that construction will be initiated in January, 1993 and concluded with start-up of the new gas/oil fired boiler in April, 1995.

Further detail on the proposed changes is provided in the following paragraphs.

2.3 DIGESTERS

The required additional pulp production of 158 unbleached air dry tons per day will be achieved by the installation of one new 6300 ft³ batch digester, No. 11. The three existing blow tanks have adequate capacity to accommodate the additional production from the new digester. With the addition of a new 5900 ft² indirect heat exchanger, the existing blow heat recovery system will also be adequate. All noncondensable gases will be directed to the existing lime kiln, or to the existing back-up incinerator, for thermal destruction.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

The total production of softwood pulp will decrease in the expanded mill, so VOC emissions from the turpentine condenser and storage tank will be less than at present. In the absence of previous testing or reliable emissions factors, no effort has been made to quantify credits for the PSD applicability analysis.

2.4 BROWN STOCK WASHING

The existing No. 1 and No. 2 brown stock washer lines do not require modification to accommodate the average production increase of 158 unbleached air dry tons per day. It is presumed that there may be an accompanying increase of reduced sulfide emissions, so an allowance for an increase that is proportionate to the production change has been included in the PSD applicability analysis.

2.5 BLEACH PLANTS

A project not a part of the expansion program is being planned to modify the sequences of the existing No. 1 and No. 2 bleach plants to effect reductions of chloroform, dioxins, and other chlorinated organics. Scrubbers to remove chlorine and chlorine dioxide from process emissions will be included. Any changes needed to

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

accommodate the additional tonnage from the expansion program will be addressed as a part of the bleach plant project.

All emissions changes that result from the combined effects of the increased tonnage, the sequence changes, and the scrubber additions will be accounted for when application is made to permit the bleach plant project. It is anticipated that the bleach plant modifications will be complete before the expansion project is operational.

2.6 NO. 2 PAPER MACHINE

A new No. 2 paper machine to produce a line of reprographic papers will be installed. With a wire width of 382 inches and a design speed of 4000 fpm, rated nominal production will be 1032 finished tons per day. The product will supplement that from the existing No. 1 paper machine, which has a nominal capacity of 750 tons per day. The new operation will include stock preparation equipment, a new winder, roll finishing, and additional warehouse space.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

Bulk chemicals used in paper manufacture that are shipped to the mill in dry form will be transferred to existing storage silos by air conveying systems that exhaust through highly efficient baghouses. Transfer from storage to points of use on the new machine will also be accomplished by air conveyors that exhaust through baghouses.

The unloading and transfer operations occur infrequently and for short durations. Due to the high efficiency of the baghouses, it is judged that any increase of particulate matter to ambient air will be of an insignificant quantity and without measurable impact.

2.7 EXISTING NO. 3 LIME KILN

The existing No. 3 lime kiln has sufficient capacity to manufacture the additional reburned lime needed to support the incremental pulp production increase of 158 unbleached air dry tons per day. None of the air pollutants emitted from this operation will increase above the quantities that constitute the current permit limits.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

Since the No. 3 kiln is a previously reviewed PSD source to which there will be no modifications, the U.S. EPA and the Alabama Department of Environmental Management have ruled that it need not be included in the current PSD review since future emissions will remain within the constraints of the current permit limits. Therefore, the No. 3 lime kiln is not further addressed in this document.

The existing No. 1 and No. 2 lime kilns will remain in standby service only to be used in the event the No. 3 kiln is down.

2.8 RECAUSTICIZING AREA

Additional green liquor clarification capacity is needed, so the existing 85 foot diameter white liquor clarifier will be converted to green liquor use. A new 95 foot white liquor clarifier will be provided. A new 20 foot diameter causticizer tank will also be added.

The existing No. 3 green liquor slaker will accommodate the increased lime production from No. 3 kiln. Additional showers will be placed in the slaker's atmospheric vent line to increase the particulate capture efficiency, thus

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

ensuring that there will be no increase of pollutant discharged to ambient air from this source. Engineering judgment indicates that there will probably be a PM reduction, but, in the absence of either actual measurements or reasonably good estimates of existing emissions, no credit for reduction has been claimed in the PSD applicability analysis.

2.9 NO. 2 BLACK LIQUOR EVAPORATORS

Two sets of evaporators are used to concentrate black liquor for burning in the recovery boilers. No. 1 set will remain in operation unmodified. No. 2 set will be extensively modified to accommodate the increased production and the shift to a greater proportion of hardwood pulp.

The split-body effects will be opened up, external heaters will be added as needed, and the two existing concentrators will be converted to use as a new second effect. Thus, the existing five-body, five effect configuration will be converted to a seven-body, six effect system.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

A new two effect concentrator set will be added downstream of the evaporators to further concentrate the black liquor to 75 percent solids. A new heated storage tank will be provided for the strong liquor.

2.10 EXISTING NO. 2 CHEMICAL RECOVERY BOILER

The existing No. 2 chemical recovery boiler will be physically modified to optimize its performance and to reconfigure it for higher solids firing. Black liquor is currently fired at 68 percent dry solids; this will increase to an average of 72 percent when 75 percent solids liquor from the modified No. 2 evaporator set is blended with 68 percent liquor from the No. 1 evaporator set.

The modified No. 2 recovery boiler will accommodate the full increase of solids loading that will result from the additional pulp produced. The furnace rating will increase from the current nameplate of 2,700,000 pounds of dry solids per day to a new rating of 3,100,000 pounds per day, producing 426,000 pounds per hour of 1500 psig steam.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

The furnace air system will be modified by adding three new fans to increase air flow and to provide three levels of combustion air instead of the current design of two. A new steam coil air heater will be added. New air ports will be installed through the furnace water wall tubes. New ports will also be installed to accommodate the six new stationary guns needed to fire the more concentrated black liquor.

Platen screen assemblies will be added inside the furnace and fitted with new soot blowers to keep the flue gas pathways open. This change is expected to increase the reliability and availability of the furnace to the extent that the operating time between tube wash downs will, hopefully, be as long as six months.

The existing electrostatic precipitator will be modified to minimize particulate emissions from the boiler. The two existing parallel chambers have more than ample volume for the future service. They were originally designed to accommodate a gas flow of 380,000 ACFM, which will not be exceeded in the future due to the lower moisture and oxygen contents of the flue gas.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

To effect an increased efficiency of solids capture, the current density will be increased on the electrodes in the outlet half of each chamber. This will be accomplished by the addition of three new transformer rectifiers and controllers. Discharge electrodes throughout the ESP will be replaced in kind.

The bottoms on the precipitator will be changed from the existing wet configuration to dry hoppers, which will serve to better ensure that TRS emissions limits are achieved.

The existing No. 1 chemical recovery boiler will continue to operate at its present load condition and without physical or process modifications. There will, therefore, be no changes of stack conditions nor of pollutant emissions to ambient air.

2.11 NO. 2 SMELT DISSOLVING TANK

The existing smelt dissolving tank, and the existing wet scrubber on the vent line, have adequate capacity to accommodate, without modification, the increased smelt

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

load from the modified No. 2 recovery boiler. Future pollutant emissions will remain within the constraints of the existing PSD permit.

As was the case for the existing No. 3 lime kiln, this previously reviewed PSD source does not require further review since no physical modifications will be made and pollutant emissions will remain within the existing PSD permit limits. Therefore, the No. 2 smelt dissolving tank is not further addressed in this report.

2.12 NEW GAS AND OIL FIRED BOILER

A new No. 2 power boiler, rated at 350,000 pounds per hour of 1500 psig steam, will be constructed to supply steam for the new paper machine and for a new 40 megawatt steam turbine generator. It will be designed to be fired at full load with either natural gas or No. 2 fuel oil. The heat input rating will be 512.5×10^6 Btu per hour on either fuel.

No. 2 distillate oil having an SO_2 content no greater than 0.5 percent by weight will be utilized for oil

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

firing. For purposes of PSD applicability, it was assumed that the boiler will operate on oil for no more than the equivalent of 100 days per year.

The new boiler will be located adjacent to the east side of the existing No. 2 wood waste boiler. The stack will be 200 feet tall and approximately eight feet in diameter.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

3. PSD APPLICABILITY

The Riverdale mill is considered a major stationary source since it is one of the listed 28 industrial categories and emits over 100 tons per year of a regulated pollutant.

Dallas County is classified as "attainment" or "nonclassifiable" for all regulated pollutants.

Therefore, if a net emissions increase of a pollutant from the mill exceeds its designated "significance" level, a PSD review for the pollutant is required. Applicability to the PSD process is determined on a pollutant-by-pollutant basis.

All increases and decreases of each regulated pollutant throughout the mill that will occur as a result of the project were considered. There were no contemporaneous increases or decreases during the five year period prior to project start-up. Actual emissions during the two year period ending December 31, 1988 were used for the netting calculations. This period is also wholly representative of 1989 and 1990.

Under current PSD regulations, the proposed future total emission of each pollutant from all sources combined is

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

compared to the current actual total. Records of actual emissions over a recent representative operating period of at least two years is desired. The difference in proposed and actual then becomes the "net emissions increase" that is compared to significance levels.

The regulatory definition of "net emissions increase" states that if an emission increase has already been relied upon in issuing a PSD permit, then the increase is not creditable. Consultation with EPA Region IV and ADEM concerning this project resulted in agreement that the increase in actual emissions from the No. 3 lime kiln and No. 2 smelt tank are not creditable and should not be included in the applicability analysis. This exclusion is based on the facts that these sources have already undergone a PSD review, that they will not be modified or have a change in method of operation, and that the future emissions will not exceed the existing permit limits. The remaining sources that are to be included in the netting calculations are the gas/oil fired boiler, the modified No. 2 chemical recovery boiler, and the existing brown stock washers.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

Various sources of information were utilized to generate estimates of emissions. Actual stack testing data for particulate matter was available for the No. 2 recovery boiler. Other information sources that were relied upon were AP-42, the National Council for Air and Stream Improvement (NCASI) technical bulletins, and equipment manufacturer estimates. Whenever more than one means of determining an emissions rate was available, the one thought to be the most representative was utilized. Estimates from manufacturers were used to predict emissions for modified and new equipment.

Table 3.1, on the following page, provides a summary of the changes of emissions rates that will occur as a result of the project. Each emissions rate shown in the table includes a reference to Exhibit A, where an explanation of the basis of the calculation is provided.

Table 3.1 shows that particulates and nitrogen oxides are the only regulated pollutants that exceed their respective significance levels and, hence, the only ones subject to PSD review. For all other pollutants, the modification of

Hammermill Papers
 Selma, Alabama
 New Source Review for Mill Expa

Project No. 4032
 September 1990

EMISSIONS POINTS								
LOCATION	STATUS	C	REF	LEAD	REF	H ₂ SO ₄	VINYL CHLORIDE	REF
						ASBESTOS		
Existing No. 2 Recovery Boiler	Shut Down	.9	19	-9x10 ⁻⁴	13	--	--	
Modified No. 2 Recovery Boiler	New	.2	20	+13.9x10 ⁻⁴	13	--	--	
Gas/Oil Fired Boiler	New	.1	21	+1.34x10 ⁻⁴	22	+0.936	23	--
Incremental Change From Existing Brown Stock Washing	Increase in Production	--		--		--	--	
Net Change	Lbs/Hr	6		1.83x10 ⁻⁴		0.936/0	None	
Change	Tons/Year	9		8.0x10 ⁻³		4.1/0	None	
Significance, TPY		0		+0.6		+7/0.007	+1	

Note: The absence of an emission from the process or to be

*Hourly emissions rates throughout downtime. Rates shown for

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

the existing equipment provided more than enough reduction credit to offset increased emissions from the new equipment.

Two regulated pollutants, benzene and arsenic, are not listed in Table 3.1. These are subject to NESHAP regulations and do not yet have a defined PSD significance level. They can be present in trace quantities in the products of combustion of fossil fuel, particularly oil and coal. Emissions factors from "Estimating Air Toxics Emission from Coal and Oil Combustion Sources", EPA 450/2/89-001, indicate that combustion of distillate oil may result in an uncontrolled emission rate of arsenic of 4.1 lb per 10^{12} Btu. At a peak firing rate of 512.6 mm Btu/hr, the calculated resultant uncontrolled mass emission rate of arsenic from the new power boiler when firing oil could be 0.0022 lb/hr.

A reference on heavy metal emission from chemical recovery units (EPA 600/7-79-015A, Appendix F) indicates that a measurable quantity of arsenic was found in the treated flue gas from one of three units tested, the concentration being 4 micrograms per cubic meter. At the design exhaust

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

gas flow rate from Hammermill's modified No. 2 recovery boiler of $3684 \text{ DS}_{69} \text{m}^3/\text{min}$, the calculated arsenic emission would be 0.0026 lb/hr.

The total combined emission of arsenic from the new power boiler and the modified No. 2 recovery boiler could be, then, 0.005 lb/hr, primarily in the form of fine particulates.

Industry experience has shown that both baghouses and electrostatic precipitators are better devices for control of fine particulate than are wet scrubbers. Since the application of a baghouse to a recovery boiler is not a technologically feasible option, the choice of an ESP provides the best available technology for control of arsenic.

A simple screening model was used to predict the potential impact of the computed possible arsenic emissions. The indicated calculated maximum ground level concentration would be 0.0095 micrograms per cubic meter, which is 1/21,000th of the TLV.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

Information on the potential release of benzene from a kraft mill chemical recovery boiler was sought from three sources:

EPA 450/4-86-010, July 1986, "Toxics Air Emissions Factors for Industrial Sources"

EPA 450/4-86-010a, April 1987, "Preliminary Compilation of Air Pollutant Emission Factors for Selected Air Toxic Compounds"

EPA 450/4-87-023a, December 1987, "Toxic Air Pollutant/Source Crosswalk"

Benzene is addressed in all three documents, but without any indication that it is emitted from a recovery boiler or brown stock washer. The most recent update of "Toxic Air Pollutant Emission Factors - A Compilation for Selected Air Toxic Compounds and Sources", 450/2-88-006a, provides an emission estimate for benzene from natural gas combustion of 4 percent by weight of the total of hydrocarbons emitted during combustion. As appears in Table 3.1 herein, the estimated emission of VOC of

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

5.1 lb/hr from the gas fired boiler translates to an estimated concurrent benzene emission of 0.204 lb/hr.

A simple screening model was used to predict the impact of the computed potential emission of benzene from the gas/oil fired boiler. The calculated maximum ground level concentration would be 0.39 micrograms per cubic meter, which is about 1/80,000th of the TLV.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

4. BACT ANALYSES

As determined in Section 3, nitrogen oxides and particulates are the pollutants for which BACT analyses are required. The modified No. 2 chemical recovery boiler and the new gas/oil power boiler are the affected facilities.

To determine BACT for the new power boiler, EPA's "top-down" approach was followed. This method compares demonstrated emission control for similar units in similar applications, with the most restrictive taken as the standard for comparison. If the owner proposes that the emission factor for the new equipment be at least as low as that standard, then the analysis is complete. If a higher unit emissions factor is proposed, then an overriding economic and/or technological justification must be shown.

Similar guidance as to how to conduct a BACT analysis for an existing unit source that will be physically modified has not been provided by EPA. Therefore, Region IV left the determination of a BACT analysis approach for the Hammermill modified recovery boiler to the discretion of

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

ADEM. Both EPA and ADEM did state, however, that BACT for the modified unit would have to demonstrate, as a minimum, some degree of improved efficiency of pollutant control over that which would be expected if no modification were made to the existing control equipment. ADEM, after considering alternative methods of analysis, decided that BACT should be determined based upon cost per incremental ton of pollutant captured for increasingly stringent levels of control that are above and beyond that provided by the initial modification to improve efficiency.

4.1 PARTICULATE MATTER - RECOVERY BOILER

The No. 2 recovery boiler utilizes an existing ESP that is rated to handle 380,000 ACFM. The modified boiler is expected to have a maximum flue gas emission rate of 360,000 ACFM, so the existing precipitator has ample volume to handle the gas flow without adding another chamber. It is estimated that the existing unit with no change would deliver flue gas from the modified boiler at a PM concentration no greater than 0.038 grains per dry standard cubic foot at 8 percent O₂.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

A logical means to significantly improve collection efficiency is to add three additional transformer-rectifier sets to the existing three sets that serve the back half of the two chambers, which will effectively double the power output to that half. In addition, all barbed and round discharge electrodes throughout the precipitator will be replaced. These two items comprise Option 1 changes. It is expected that the result will be to deliver flue gas at a PM concentration no greater than 0.034 gr/dscf at 8 percent oxygen, compared to 0.038 gr/dscf without the changes. The Option 1 configuration is proposed as BACT for the modified boiler.

To confirm that Option 1 does, in fact, satisfy ADEM's definition of BACT, the cost effectiveness of additional control over and above that provided by Option 1 was considered. The next logical step to provide yet another increment of control (Option 2) would be to install three new transformer-rectifier sets to serve the front half of the two chambers, which would effectively double the power input thereto. In addition, the electronic control of the six existing T/R sets would be upgraded to state-of-the-art technology. The changes would result in flue gas cleansed

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

to a maximum particulate concentration of 0.030 grains per
dry standard cubic foot at 8 percent O₂.

Table 4.1 on the following page outlines the details of the determination to evaluate the cost effectiveness of Option 2. As can be seen, the annualized cost per ton of additional pollutant recovered by utilization of this option would be about \$3600.

Dispersion modeling predicts that the reduction of the
maximum 24 hour average PM concentration in ambient air
that would result from implementing Option 2 would be less
than 0.25 µg/m³. It is judged, therefore, that the high cost to achieve an immeasurably small improvement to ambient air quality is not justified and that BACT for control of PM from the modified No. 2 chemical recovery boiler is well served by the Option 1 modification to the existing electrostatic precipitator as proposed herein.

not acceptable

4.2 PARTICULATE MATTER - NEW GAS/OIL FIRED BOILER

The new gas/oil fired boiler proposed for this project will generate minimal emissions of particulate due to the ash free fuels that will be burned, natural gas and No. 2

Hammermill Papers
 Selma, Alabama
 New Source Review for Mill Expansion

Project No. 4032
 September 1990

TABLE 4.1

BACT ANALYSIS FOR CONTROL OF PARTICULATE
 MATTER FROM NO. 2 RECOVERY BOILER

	<u>M O D I F I C A T I O N</u>		
	<u>NONE</u>	<u>OPTION 1</u>	<u>OPTION 2</u>
Flue Gas PM Conc., Grains/ds _{68cf} at 8 percent oxygen	0.038	0.034	0.030
PM Emission Rate, Lb/Hr T/Yr	70.0 306.8	62.7 274.5	55.3 242.2
Additional Saltcake Recovered, TPY	--	--	32.3
Capital Expenditure For Option 2	--	--	430,000
Annualized Additional Costs For Option 2			
Capital Recovery ¹			\$70,100
Maintenance Labor & Material ²			17,200
Tax, Insurance, Administration ²			17,200
Electric Power At 0.045 Per kWh			14,100
Value Of Recovered Saltcake ³			<u>(3,200)</u>
Net Annualized Cost For Option 2:			\$115,400
Net Annualized Cost Per Ton of Pollutant Recovered			\$ 3,573

Notes:

- (1) 10 Years Useful Life, 10 percent Interest =
0.163 x Capital Cost
- (2) 4 percent Of Capital
- (3) Current Market Value - \$98/Ton

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

distillate oil. State-of-the-art combustion controls and furnace design will ensure complete oxidation of the fuels at all times. The installation of continuous flue gas monitors for oxygen and carbon monoxide will ensure that the air to fuel ratio does not become too rich, thus essentially eliminating any possibility of soot formation.

It is generally accepted by regulatory agencies that good furnace design and adequate control of combustion conditions constitutes BACT for boilers that fire natural gas and/or distillate oil. A canvass of boiler manufacturer indicates that the best guarantees that will be available for uncontrolled emissions of particulate matter are 0.005 lbs per 10^6 Btu for gas firing and 0.05 lbs per 10^6 Btu for oil firing. As might be expected, these numbers are not wholly in keeping with certain of the entries that appear in the EPA BACT/LAER clearinghouse document.

Particulate - Gas Firing

Table 4.2 on the following page is a presentation of all clearinghouse entries for permitted emissions of particulate matter from boilers fired with natural gas.

TABLE 4.2

COMPLETE BACT/LAER CLEARINGHOUSE LISTING OF
 PARTICULATE EMISSIONS FROM GAS FIRED BOILERS

4 - 7

<u>BACT Listing ID Number</u>	<u>Source</u>	<u>Boiler Size</u>	<u>Emission Rate</u>	<u>Emission Factor</u>
OH-0104	Hale Chrome Service	1.05 mm Btu/hr		0.02 lb/mm Btu
OK-0006	Colorado Interstate Gas	2.6 mm Btu/hr	0.011 lb/hr	(0.005 lb/mm Btu)
OH-0096A	Baron Drawn Steel	6 mm Btu/hr		0.02 lb/mm Btu
OH-0107	Kaiser Aluminum	16.8 mm Btu/hr		0.02 lb/mm Btu
TX-0081	PPG Industries	20.9 mm Btu/hr	0.3 lb/hr	(0.014 lb/mm Btu)
TX-0024	Mapee Alcohol Fuel	35 mm Btu/hr		0.01 lb/mm Btu
TX-0079	Shintech, Inc.	55 mm Btu/hr	0.3 lb/hr	(0.005 lb/mm Btu)
CA-0161A	Shell California Product	62.5 mm Btu/hr	0.27 lb/hr	(0.0043 lb/mm Btu)
OH-0116B	Sun Refining & Marketing	68 mm Btu/hr	5 lb/ft ³	
AR-0002A	Arkansas Eastman	78 mm Btu/hr	0.4 lb/hr	0.005 lb/mm Btu
OH-0148	Champion International	197 mm Btu/hr		0.02 lb/mm Btu
CA-0161	Shell California Product		4.8 lb/D	
WI-0037	Wisconsin Tissue	146.4 mm Btu/hr		0.09 lb/mm Btu
WI-0043	Wisconsin Tissue	75 mm Btu/hr	0.38 lb/hr	0.005 lb/mm Btu
MS-0016	E.I. Dupont	231 mm Btu/hr	0.2 lb/hr	(0.0009 lb/mm Btu)
MS-0014	Newsprint South	227.4 mm Btu/hr		0.005 lb/mm Btu

Numbers in parentheses did not appear in the document and are those calculated from the boiler sizes and emission rates listed therein.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

Two of the entries are lower than the 0.005 proposed as BACT for the Hammermill boiler, one being 0.0043 for a 62.5×10^6 Btu boiler in California and the other 0.0009 for a 231×10^6 Btu unit in Mississippi.

The California regulatory agency states that the emissions rate of 0.27 lbs PM per hour that appears in the listing for permit CA-0161A is in error and that the correct rate is 0.303 lbs per hour. This change would bring the computed emissions factor to 0.0048 lbs per 10^6 Btu. The owner advises that the emission factor originally used for the computations was the AP-42 listing of 5 lbs PM per 10^6 cubic feet of gas, which results in a computed factor of 0.0048 if a heat value of 1050 Btu per cubic foot is assumed. For the 1000 Btu gas available to Hammermill, the AP-42 factor results in a calculated emissions rate of 0.005 lbs per 10^6 Btu input. Since the basis of the computation of the emissions factor for the proposed Hammermill boiler is the same as that used to derive the factor for the California boiler, the Hammermill rate is considered to be just as true a representation of BACT as is the rate for the California boiler. Furthermore, the latter has never been tested, so its rate has not actually been demonstrated.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

The second entry of 0.0009 is for a boiler permitted in Mississippi that has not yet been placed in service. No external control equipment will be provided and the emissions limit is not supported by a vendor guarantee. The number was generated by the owner, who has announced his intention to negotiate with the Mississippi regulatory agency for a higher limit. In the absence of a demonstration by either operation or technology transfer, it is judged that this entry is not a valid representation of BACT.

The next lowest entry in the clearinghouse is 0.005 lbs of PM per 10^6 Btu input, of which there are several. Hammermill proposes to match this factor by providing state-of-the-art boiler design to achieve combustion uniformity and control. The proposed emissions rate and design technology are considered BACT for control of particulate matter when firing natural gas in the new power boiler.

Particulate - Oil Firing

Table 4.3 on the following page is a tabulation of all entries that appear in the EPA BACT/LAER clearinghouse document for power boilers fired with distillate oil. As

TABLE 4.3

COMPLETE BACT/LAER CLEARINGHOUSE LISTINGS OF
 PARTICULATE EMISSIONS FROM OIL FIRED BOILERS

BACT Listing ID Number	Source	Boiler Size	Emission Rate	Emission Factor
MA-0003	Natick Paperboard	60.1 mm Btu/hr		0.1 lb/mm Btu
VA-0007	Anheuser Busch, Inc.	98 mm Btu/hr		
DE-0004	Dupont Institute	37.5 mm Btu/hr	0.58 lb/hr	
AL-0004	Degussa Chemical Corp.	205.7 mm Btu/hr		0.1 lb/mm Btu
GA-0003	Firestone Tire Co.	96.4 mm Btu/hr		0.16 lb/mm Btu
FL-0010	Sugar Cane Growers Coop.	240,000 lb/hr		0.1 lb/mm Btu
NC-0021	Cranston Print Works	243 mm Btu/hr		0.1 lb/mm Btu
NC-0010	Meredith/Burda, Inc.	3366 lb/hr paper	4 lb/hr	
FL-0022	Port St. Joe	756 mm Btu/hr	75.6 lb/hr	(0.1 lb/mm Btu)
IN-0001	New Energy Corp.	176 mm Btu/hr		0.02 lb/mm Btu
WI-0020	A O Smith Corp.			0.15 lb/mm Btu
OH-0022	Timken Co.	40 mm Btu/hr		0.02 lb/mm Btu
TX-0013	Houston Lighting & Power	185 mm Btu/hr		0.1 lb/mm Btu
LA-0035	Allied Chemical Corp.	131 mm Btu/hr		0.0015 lb/mm Btu
LA-0030	Shell Chemical Co.	198.5 mm Btu/hr		0.1 lb/mm Btu
TX-0080	Proctor & Gamble	100 mm Btu/hr	6.9 lb/hr	(0.069 lb/mm Btu)
IA-0003	Am. Modern Food Energy Sys.	94.5 mm Btu/hr		0.03 lb/mm Btu
FL-0012	Osceola Farms Co.	1.1 bbl oil/hr		0.1 lb/mm Btu
CA-0037	Chevron USA, Inc.	390 gal/hr	3.6 lb/hr	(0.066 lb/mm Btu)
GA-0013	W F Hall Printing	60 mm Btu/hr		0.1 lb/mm Btu
UT-0024	Paraho Development Corp.	14.5 mm Btu/hr	2 lb/1000 gal	(0.013 lb/106 Btu)
ME-0006	New England Ethanol, Inc.	175 mm Btu/hr		
NC-0034	Allied Corporation	64.2 mm Btu/hr		0.12 lb/mm Btu
OH-0071	Delco Moraine Div.	144 mm Btu/hr		0.08 lb/mm Btu
VA-0030	University of Virginia	103,760 gal/hr		0.15 lb/mm Btu
VA-0044	Tultex Corp.	93.3 mm Btu/hr	1.33 lb/hr	(0.014 lb/mm Btu)

(Continued next page)

TABLE 4.3
 (Cont'd)

COMPLETE BACT/LAER CLEARINGHOUSE LISTING OF
 PARTICULATE EMISSIONS FROM OIL FIRED BOILERS

<u>BACT Listing ID Number</u>	<u>Source</u>	<u>Boiler Size</u>	<u>Emission Rate</u>	<u>Emission Factor</u>
VA-0051	VA Department of Hiways	4.2 mm Btu/hr	0.34 lb/hr	(0.08 lb/mm Btu)
OH-0094	Georgia Pacific Corp.	118 mm Btu/hr		0.09 lb/mm Btu
OH-0112	General Mills	71.5 mm Btu/hr		0.1 lb/mm Btu
OH-0117	Owens-Illinois Inc.	10.3 mm Btu/hr		0.02 lb/mm Btu
WI-0037	Wisconsin Tissue Mills, Inc.	72.4 mm Btu/hr		0.09 lb/mm Btu
VA-0141	Hopewell Cogen. Ltd. Part.	197 mm Btu/hr		0.1 lb/mm Btu
VA-0165	Hadson Power II	81.58 mm Btu/hr		0.04 lb/mm Btu
CT-0009	U.S. Navy Base, North Div.	98 mm Btu/hr		0.05 lb/mm Btu
CT-0011	Mansfield Training School	4.8/2.9 mm Btu/hr		0.048 lb/mm Btu
CT-0081	New England Furniture	15.2 mm Btu/hr		0.047 lb/mm Btu

4
 11 - 11

Numbers in parenthesis are values calculated from information provided in the document.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

will be noted, the permitted emissions factors for about one-fourth of the total entries are lower than the 0.05 lbs per 10^6 Btu proposed as BACT for the Hammermill boiler.

The lowest of the entries is 0.0015 lbs per 10^6 Btu for a boiler in Louisiana, permit LA-0035. Flue gas desulfurization is practiced on this unit, so the flue gases are cleansed by a baghouse. The requirement for external particulate control was dictated by the requirement for FGD and not because of a need to remove the particulate generated by combustion of the oil.

Nevertheless, a financial impact analysis was made of adding a baghouse to the Hammermill boiler to control particulate, when firing oil, to a level that would match the Louisiana unit, or 0.0015 lbs/ 10^6 Btu. Table 4.4, on the following page, presents the results of the analysis. As is shown, the annualized cost per ton of particulate matter captured would be greater than \$23,000 per ton.

Hammermill Papers
 Selma, Alabama
 New Source Review for Mill Expansion

Project No. 4032
 September 1990

TABLE 4.4

FINANCIAL IMPACT OF ADDING BAGHOUSE FOR CONTROL OF
 PARTICULATE WHEN FIRING OIL ON THE NEW GAS/OIL BOILER

(Oil Firing 100 Days Per Year Max.)

	<u>Uncontrolled</u>	<u>With Baghouse</u>
PM Emission Factors, lbs/10 ⁶ Btu	0.05	0.0015
Heat Input, 10 ⁶ Btu/hr	512.6	512.6
Total Emission, Tons Per Year	30.76	0.92
PM Capture, TPY	0	29.84
 Project Total Capital Cost		 \$3,549,000
		 <u>Annualized Costs</u>
Capital Recovery ¹		465,000
Maintenance Labor and Material ²		112,600
Taxes, Insurance, Administration ²		112,600
Electric Power ³		<u>18,900</u>
 Total Annualized Costs		 \$709,100
 Annualized Cost Per Ton Captured =		 \$ 23,763

- 1- 15 year useful life, 10 percent interest = 0.131 factor
 2- 4 percent of project direct costs (\$2,814,000)
 3- 175 kW at \$0.045 per kWh

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

As shown by dispersion modeling, the favorable ambient impact of capturing the additional 30 tons per year would be so low as to be immeasurable. In view of the prohibitively high cost to provide add-on control equipment, the proposed emissions rate for particulate matter of 0.05 lbs per 10^6 Btu input from the new power boiler when firing oil is seen as meeting all requirements of BACT.

4.3 NITROGEN OXIDES - RECOVERY BOILER

A chemical recovery boiler in a kraft pulp mill serves three important functions:

- The disposal, by incineration, of waste organics generated during the digestion of wood.

- The recovery of valuable heat energy that is released during the incineration of waste solids by converting it to high pressure, high temperature steam.

- The recovery and chemical reduction of valuable inorganic chemicals for reuse in the wood digestion process.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

To achieve these varied goals, a recovery boiler is, of necessity, a highly specialized unit operation. As a combustor, it does not have the same flexibilities that are found in a conventional wood or fossil fuel fired boiler.

Hammermill proposes to modify the existing No. 2 chemical recovery boiler so it will accommodate a greater load of black liquor solids that will be fired at a higher dryness than at present. These changes will enable the boiler to efficiently serve its intended functions in the expanded mill.

Prior to the 1980's, black liquor was fired to recovery furnaces at dry solids percentages ranging from the low to the mid-sixties. The trend of recent years has been to move to drier solids since the thermal efficiency of the chemical recovery unit is dramatically improved. The higher the thermal efficiency, the lower the quantity of steam that must be produced from the combustion of fossil fuels elsewhere in the mill. The reduced use of fossil fuel results, of course, in less pollution released to ambient air. Thus, the use of a drier black liquor fuel

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

to the chemical recovery unit is a BACT measure to the extent that pollutant emissions from the use of fossil fuel are reduced. The chemical recovery boiler at Hammermill will be designed to fire black liquor which enters the guns at drynesses up to 75 percent solids.

The firing of black liquor at a lower moisture content results in a higher temperature of the smelt bed. This has the desirable effect of lowering emissions of reduced sulfides and sulfur oxides, accompanied by an undesirable effect of increased nitrogen oxides. On balance, however, the reduction of SO_2 emissions over the past decade that has resulted from higher smelt temperatures has far exceeded the increase of NO_x emissions. Ten years ago, boilers were typically being permitted at 300 ppm SO_2 and 50 ppm NO_x . Today, the numbers are more like 100 ppm SO_2 and 100-150 ppm NO_x .

The converted recovery boiler at the Riverdale mill will be designed with the latest state-of-the-art technology for minimizing the formation of NO_x . Ample furnace volume and heat exchange area are available. Multiple liquor firing guns will be utilized to uniformly

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

distribute the fuel over the smelt bed, thus reducing possibilities for hot and cold spots. Three levels of combustion air, primary, secondary, and tertiary, each individually controlled, will provide for staged combustion to minimize the formation of NO_x and for better mixing of combustion gasses to eliminate pockets of high temperature. Continuous monitoring of the flue gas will help to maintain oxygen at design concentrations at all times, thus ensuring that excessive oxygen is not present to promote the generation of NO_x . All known technically feasible features to minimize NO_x generation will be incorporated into the design of the boiler rebuild.

The available technologies for add-on reduction of NO_x from fossil fuel fired boilers, such as flue gas recycle, thermal de- NO_x , and selective catalytic reduction have not been demonstrated as applicable to chemical recovery boilers. In fact, it is probable that none of these would be successful due to the manner in which the unit must be fired and the high sulfate content of the solids that are present in the flue gas.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

A canvass of chemical recovery boiler manufacturers indicates that the lowest NO_x guarantee which can be expected for the Riverdale unit is a concentration in the flue gas of 115 ppm dv corrected to 8 percent O_2 . To the best of Hammermill's knowledge, there is not, at this time, a chemical recovery boiler in the United States that is continuously operating on black liquor at 72 percent solids or higher. The 115 ppm NO_x concentration indicated by some manufacturers as being attainable is based on limited foreign experience and on extrapolations from actual U.S. experience with liquors in the 65 to 70 percent range.

There are no EPA clearinghouse entries that are identifiable as chemical recovery boilers that will be rebuilt. Nor is any other source of information known from which the lowest attainable emissions rates can be identified for this class of equipment. To assess BACT, there is no choice but to rely on the guarantees of manufacturers and to be certain that all technically feasible features to minimize NO_x generation are included in the design. These will be incorporated into the Riverdale unit and include the following:

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

- Ample furnace volume
- Ample heat exchange area
- Multiple liquor guns for uniform distribution of black liquor over the smelt bed
- Three levels of independently controlled combustion air for staged combustion and uniform mixing in each combustion zone
- Continuous monitoring and control of residual oxygen in the flue gas

It is believed that these features constitute BACT for a rebuilt chemical recovery boiler.

4.4 NITROGEN OXIDES - NEW GAS/OIL FIRED BOILER

The new boiler will be designed to fire either natural gas or distillate oil at a design heat input rate of 512.5×10^6 Btu/hr. It is intended that distillate oil having a maximum sulfur content of 0.5 percent will be used as a back-up fuel when gas is unavailable. Computations herein are based on oil being used intermittently for a combined maximum of 2400 hours per year.

Hammermill Papers
 Selma, Alabama
 New Source Review for Mill Expansion

Project No. 4032
 September 1990

Nitrogen Oxides - Gas Firing

A canvass of manufacturers of gas fired boilers that are equipped with low NO_x burners and 10-15 percent flue gas recycle indicates that the best guarantee available for minimum NO_x emissions rates will be no lower than 0.05 lbs per 10⁶ Btu input. This rate is proposed as BACT for the Hammermill boiler when firing natural gas.

Table 4.5 on the following page presents all clearinghouse entries for permitted emissions of nitrogen oxides from gas fired boilers. Eight are lower than the 0.05 lbs rate proposed for the new boiler. These eight were investigated with the following results:

<u>Permit</u>	<u>Rate lb/10⁶ Btu</u>	<u>Comment</u>
TX 0024	0.0006	Mapee Alcohol - never built and the technology never demonstrated, thus eliminated from consideration.
OH 0155	0.01	BFT of Ohio - error in computation, actual permit rate is 0.1 which is higher than that proposed for Hammermill.
CA 0292	0.015	Equipped with low NO _x burners, flue gas recycle, and selective catalytic reduction - cost analysis required for similar technology with Hammermill boiler.

TABLE 4.5

COMPLETE BACT/LAER CLEARINGHOUSE LISTINGS OF
 NO_x EMISSIONS FROM GAS FIRED BOILERS

BACT Listing ID Number	Source	Boiler Size	Emission Rate	Emission Factor
CA-0149	Rockwell International	50 hp (1.67 mm Btu/hr)	0.04 lb/hr	(0.024 lb/mm Btu) ¹
OK-0006	Colorado Interstate Gas	2.6 mm Btu/hr	0.32 lb/hr	0.12 lb/mm Btu
CO-0013	Rio Blanco	5 mm Btu/hr	1 lb/hr	0.20 lb/mm Btu
MS-0003	Southern Natural Gas	14000 cf/hr	37.4 lb/hr	2.7 lb/mm Btu
OH-0107	Kaiser Aluminum	16 mm Btu/hr		0.1 lb/mm Btu
TX-0081	PPG Industries	20.92 mm Btu/hr	4.8 lb/hr	0.23 lb/mm Btu
CA-0193	Naval Station	24 mm Btu/hr		0.05 lb/mm Btu
WY-0014	Exxon Company	26 mm Btu/hr		0.17 lb/hr Btu
WY-0016	Wycon Chemicals	26 mm Btu/hr		0.23 lb/mm Btu
CA-0234	Ventura Coastal Corp.	31.4 mm Btu/hr	25.7 lb/D 30 ppm	(0.034 lb/mm Btu) ²
CA-0231	Douglas Aircraft	33.5 mm Btu/hr	68 lb/D 35 ppm	(0.085 lb/mm Btu)
TX-0024	Mapee Alcohol	35 mm Btu/hr		0.0006 lb/mm Btu
CA-0166	Folsom Prison	48 mm Btu/hr	40 ppm at 3% O ₂	
WY-0011	CIG	48.4 mm Btu/hr		0.2 lb/mm Btu
TX-0079A	Shintech Inc.	55 mm Btu/hr		.12 lb/mm
CA-0195	McClellan AFB	62 mm Btu/hr		40 ppm
WY-0008	Amoco Production	65.5 mm Btu/hr		0.20 lb/mm Btu
OH-01168	Sun Refining & Marketing	68 mm Btu/hr		0.12 lb/mm Btu
CA-0187A	CA Dept. of Corrections	71.3 mm Btu/hr	81.6 lb/D	(0.048 lb/mm Btu)
AR-829A	Arkansas Eastman	78 mm Btu/hr	13.3 lb/hr	(0.17 lb/mm Btu)
LA-0031	Hill Petroleum Co.	78.2 mm Btu/hr		0.1 lb/mm Btu
CA-0122	Gilroy Energy Co.	90 mm Btu/hr	40 ppm at 3% O ₂	
IL-0020	Archer Daniels Midland	90 mm Btu/hr		0.17 lb/mm Btu
WY-0009	Chevron	93.8 mm Btu/hr		0.20 lb/mm Btu
TX-0037	Tex-USS	99 mm Btu/hr		0.11 lb/mm Btu
WY-0015	Chevron Co.	105.6 mm Btu/hr		0.20 lb/mm Btu
MS-0009	Newsprint South, Inc.	137.3 mm Btu/hr		0.20 lb/mm Btu

4 - 21

(Continued next page)

TABLE 4.5
 (Cont'd)

BACT Listing ID Number	Source	Boiler Size	Emission Rate	Emission Factor
CA-0249A	BAF Energy	150 mm Btu/hr	7.25 lb/hr	(0.048 lb/mm Btu) ³
CA-0097	Stanislaus Food	125,000 lb/hr steam	65 ppm at 3% O ₂	
PA-0052	Amtrak	90 mm Btu/hr	5.87 lb/hr	(0.065 lb/mm Btu)
IN-0027	I/N Tek	73.2 mm Btu/hr		0.05 lb/mm Btu
NC-0051	Panda Rosemary Corp.	81.25 mm Btu/hr	8.1 lb/hr	(0.1 lb/mm Btu)
IL-0043	Natural Gas Pipeline Co.	8.4 mm Btu/hr		0.1 lb/mm Btu
CA-0292	Westinghouse Electric Corp.	380 mm Btu/hr	140 lb/day	0.015 lb/mm Btu
IA-0012	Grain Processing Corp.	169 mm Btu/hr		0.25 lb/mm Btu
OH-0148	Champion International	197 mm Btu/hr		0.20 lb/mm Btu
CO-0013	Rio Blanco Oil Shale	198 mm Btu/hr	39.6 lb/hr	(0.20 lb/mm Btu)
WV-0003	PPG Industries, Inc.	243 mm Btu/hr		0.70 lb/mm Btu
LA-0014	BASF Wyandotte Co.	303 mm Btu/hr	36.4 lb/hr	0.12 lb/mm Btu
LA-0041B	Georgia Pacific Corp.	987 mm Btu/hr		0.10 lb/mm Btu
MI-0013	Consumers Power Company	175,000 lb/hr steam		0.2 lb/mm Btu
VA-0141	Hopewell Cogeneration	197 mm Btu/hr		0.1 lb/mm Btu
WI-0037	Wisconsin Tissue Mills	146.4 mm Btu/hr		0.38 lb/mm Btu
SC-0015	Williamette Industries	305 mm Btu/hr		0.2 lb/mm Btu
MI-0109	Dow Chemicals Co.	40.4 mm Btu/hr		0.07 lb/mm Btu
LA-0060	Chevron Chemicals	543 mm Btu/hr		0.1 lb/mm Btu
OH-0155	BFI of Ohio and Michigan	3.3 mm Btu/hr		0.01 lb/mm Btu ⁴
AL-0036	General Electric	99.5 mm Btu/hr	9.9 lb/hr	0.15 lb/mm Btu
CA-0290	Smud/Campbell Soup Co.	100 mm Btu/hr	1734 lb/D	(0.72 lb/mm Btu)
CA-0281	Ventura Coastal Corp.	27.2 mm Btu/hr	0.89 lb/hr	(0.033 lb/mm Btu) ²
WI-0043	Wisconsin Tissue Mills	75 mm Btu/hr		0.30 lb/mm Btu
MN-0011	Boise Cascade	205 mm Btu/hr		0.05 lb/mm Btu
AL-0041	Reynolds Metals Co.	29 mm Btu/hr	18 T/yr	(0.14 lb/mm Btu)
AL-0045	Shell Offshore Inc.	48.2 mm Btu/hr	42 ppm	0.1 lb/mm Btu

4 - 22

(Continued on next page)

Hammermill Papers
 Selma, Alabama
 New Source Review for Mill Expansion

Project No. 4032
 September 1990

TABLE 4.5
 (Cont'd)

<u>BACT Listing ID Number</u>	<u>Source</u>	<u>Boiler Size</u>	<u>Emission Rate</u>	<u>Emission Factor</u>
MS-0016	EI Dupont	231 mm Btu/hr	27.7 lb/hr	0.12 lb/mm Btu
MS-0014	Newsprint South	227.4 mm Btu/hr		0.2 lb/mm Btu

Parentheses indicate calculated emission factor based on information provided in the document.

- 1 Utilizes a ceramic duct burner design capable of burning natural gas only (does not work with oil) and which can be utilized for small boilers only.
- 2 Utilizes flue gas recirculation and oxygen trim. The vendor guarantee of 30 ppm is lower than other vendors using the same technology and is not available in boilers sized larger than 70×10^6 Btu/hr.
- 3 This listing is actually a gas turbine and should not appear as a boiler.
- 4 Incorrectly computed from an AP-42 emission factor, should be listed as 0.1 lb/mm Btu.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

CA 0149	0.024	The technology is available for very small boilers only (1.7×10^6 Btu/hr) and does not work on oil - thus eliminated from consideration.
CA 0234	0.034	This is a special technology not available in a boiler larger than 70×10^6 Btu/hr, thus eliminated from consideration.
CA 0281	0.033	Same as CA 0234.
CA 0187A	0.048	Probably developed from the same basis of technology as that used to compute the 0.05 proposed herein, with the differences attributable to rounding. Therefore, the 0.048 and 0.05 are considered to be equivalent numbers.
CA 02492	0.048	The equipment is actually a gas turbine and incorrectly appears in the clearinghouse listing for boilers.

It is concluded from this analysis that, with but one exception, there is no demonstrated technology available to minimize NO_x emissions from a large field erected high pressure gas fired boiler better than that proposed for the new Hammermill unit. Selective catalytic reduction has been demonstrated as an add-on technology that may hold promise for additional reduction of NO_x , so a financial analysis was prepared to determine its economic feasibility for the Hammermill boiler.

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

The less expensive catalysts that are satisfactory for gas firing fail rapidly when exposed to SO_2 and SO_3 . The Hammermill system would thus require provision to bypass the catalyst chamber when the boiler is being fired with oil. The cost of the bypass system is included as a part of the cost of the SCR system.

↖ NO

Table 4.6 on the following page presents the results of the economic analysis. As is seen, SCR would reduce the NO_x emission by 57 tons per year at an annualized cost of \$11,000 per ton. This cost is entirely too high to be justified. The reduction in the average concentration in ambient air would be about $0.2 \mu g/m^3$, a quantity too small to be measurable.

It is concluded, therefore, that BACT for the new Hammermill power boiler when firing gas is an emissions rate of 0.05 lbs NO_x per 10^6 Btu heat input. This will be achieved by state-of-the-art boiler design including adequate furnace volume, low NO_x burners, flue gas recycle, and continuous monitoring of the flue gas for oxygen and nitrogen oxides.

Hammermill Papers
 Selma, Alabama
 New Source Review for Mill Expansion

Project No. 4032
 September 1990

TABLE 4.6

FINANCIAL IMPACT OF ADDING SELECTIVE CATALYTIC REDUCTION
 FOR CONTROL OF NITROGEN OXIDES FROM NEW BOILER WHEN
 FIRING NATURAL GAS FOR 265 DAYS PER YEAR

	<u>Uncontrolled</u>	<u>With SCR</u>
NO _x Emission Factor, lbs/10 ⁶ Btu	0.05	0.015
Heat Input, 10 ⁶ Btu/hr	512.6	512.6
Total Emission, Tons Per Year	81.5	24.5
NO _x Reduction, TPY	--	57.0
Project Total Capital Cost		\$2,810,000
		<u>Annualized Costs</u>
Capital Recovery ¹		368,100
Maintenance Labor and Material ²		142,300
Taxes, Insurance, Administration ³		94,800
Electric Power ⁴		18,900
Ammonia		<u>2,100</u>
Total Annualized Costs		\$626,200
Annualized Cost Per Ton Removed =		\$ 11,000

¹- 15 year useful life, 10 percent interest = 0.131 factor

²- 6 percent of direct costs

³- 4 percent of direct costs

⁴- 175 kW at \$0.045 per kWh

Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

Nitrogen Oxides - Oil Firing

A canvass was made of manufacturers of oil fired boilers who incorporate low NO_x burners and flue gas recycle in the basic design. The result is an indication that the best guarantee for NO_x emissions will be no lower than 0.1 lbs per 10^6 Btu heat input when firing distillate oil. This emissions rate is proposed as BACT for the Hammermill boiler when firing oil.

Table 4.7 on the following page presents all clearinghouse entries for permitted NO_x emissions from boilers fired with oil. The document provides no indication as to the type of oil for which each boiler is designed.

One number in the listing is lower than the emission rate proposed by Hammermill. It is for General Mills in Ohio and appears as 0.014 lbs per 10^6 Btu. It was determined from the owner and the state agency that the listing is in error. The boiler is actually gas fired and is permitted at 0.14 lbs NO_x per 10^6 Btu.

The next lowest number in the listing is 0.1 lb per 10^6 Btu, the same as the factor proposed by Hammermill.

TABLE 4.7

COMPLETE BACT/LAER CLEARINGHOUSE LISTINGS OF
 NO_x EMISSIONS FROM OIL FIRED BOILERS

BACT Listing ID Number	Source	Boiler Size	Emission Rate	Emission Factor*
CA-0089	HOPCO	62.5 mm Btu/hr	7.4 lb/hr	(0.118 lb/mm Btu)
OH-0094	Georgia Pacific Corp.	118 mm Btu/hr		0.3 lb/mm Btu
OH-0117	Owens Illinois	10.3 mm Btu/hr		0.145 lb/mm Btu
NY-0003	N.Y. State Elect. & Gas	195 mm Btu/hr		
DE-0004	Dupont Institute	37.5 mm Btu/hr	30 lb/hr	(0.8 lb/mm Btu)
AL-0004	Degussa Chemical Corp.	205.7 mm Btu/hr		0.4 lb/mm Btu
NC-0021	Cranston Print Works	243 mm Btu/hr		0.7 lb/mm Btu
FL-0022	Port St. Joe	756 mm Btu/hr	228.8 lb/hr	(0.3 lb/mm Btu)
IN-0001	New Energy Corp.	176 mm Btu/hr		0.6 lb/mm Btu
OH-0022	Timken Co.	40 mm Btu/hr		0.25 lb/mm Btu
TX-0013	Houston Lighting & Power	185 mm Btu/hr		0.3 lb/mm Btu
LA-0035	Allied Chemical Corp.	131 mm Btu/hr		0.3 lb/mm Btu
LA-0030	Shell Chemical Co.	198.5 mm Btu/hr		0.3 lb/mm Btu
TX-0074	Anheuser Busch Inc.	77 mm Btu/hr	32.1 lb/hr	0.42 lb/mm Btu
TX-0080	Proctor & Gamble Paper Prod.	100 mm Btu/hr	30 lb/hr	0.3 lb/mm Btu
IA-0003	Am. Modern Food Energy Sys.	945 mm Btu/hr		0.25 lb/mm Btu
CA-0007	Tosco Corp.	92,700 lb/hr	41 lb/hr	(0.29 lb/mm Btu)
IN-0024	Northern Indiana Public Serv.		75 ppm	
UT-0024	Paraho Development Corp.	14.5 mm Btu/hr	22 lb/1000 gal	(0.147 lb/mm Btu)
CA-0069	Angus Petrotech	62.5 mm Btu/hr	199 lb/D	(0.13 lb/mm Btu)
NC-0034	Allied Corp.	64.2 mm Btu/hr		0.4 lb/mm Btu
CA-0116	Petro Lewis Corp.	50 mm Btu/hr		0.12 lb/mm Btu
CA-0113	Berry Holding Co.	31.5 mm Btu/hr		0.2 lb/mm Btu
CA-0113	Berry Holding Co.	62.5 mm Btu/hr	7.5 lb/hr	0.12 lb/mm Btu
VA-0030	University of Virginia	103,760 bal/yr		0.45 lb/mm Btu
OH-0094	Georgia Pacific Corp.	118 mm Btu/hr		0.3 lb/mm Btu
OH-0112	General Mills	71.5 mm Btu/hr		0.014 lb/mm Btu (1)

(Continued next page)

TABLE 4.7
 (Cont'd)

COMPLETE BACT/LAER CLEARINGHOUSE LISTINGS OF
 NO_x EMISSIONS FROM OIL FIRED BOILERS

BACT Listing ID Number	Source	Boiler Size	Emission Rate	Emission Factor
WI-0037	Wisconsin Tissue Mills	72.4 mm Btu/hr		0.38 lb/mm Btu
AL-0036	General Electric	99.48 mm Btu/hr	14.9 lb/hr	(0.15 lb/mm Btu)
WI-0043	Wisconsin Tissue	75 mm Btu/hr		0.3 lb/mm Btu
LA-0279	Delano Growers Grape Products	32 mm Btu/hr	10.6 lb/hr	(0.33 lb/mm Btu)
NC-0051	Panda Rosemary Corp.	81.25 mm Btu/hr	9.8 lb/hr	(0.12 lb/mm Btu)
VA-0165	Hadson Power II	81.6 mm Btu/hr		0.1 lb/mm Btu
CT-0009	U.S. Navy Base North Div.	98 mm Btu/hr		0.2 lb/mm Btu
CT-0011	Mansfield Training School	4.8, 2.9, 2.2 mm Btu/hr		0.379 lb/mm Btu
CT-0081	New England Furniture	15.2 mm Btu/hr		0.367 lb/mm Btu
VA-0171	Mecklenburg Cogen Ltd.	304.8 mm Btu/hr		0.4 lb/mm Btu

4 - 29

* Numbers in parentheses do not appear as such in the clearinghouse document and were computed from the reported boiler size and mass emission rate.

¹Erroneously reported - This boiler is actually gas fired and permitted at 0.14 lb/10⁶ Btu.



Hammermill Papers
Selma, Alabama
New Source Review for Mill Expansion

Project No. 4032
September 1990

This is a BACT emissions rate that will be achieved by state-of-the-art boiler design, including ample furnace volume, low NO_x burners, flue gas recycle, and flue gas monitoring for NO_x and oxygen. The 0.1 lb limit will also satisfy the NSPS requirement.

FEDERAL EXPRESS AIRBILL PACKAGE TRACKING NUMBER 0127427322

QUESTIONS? CALL 800-238-5355 TOLL FREE.

1004M | 0127427322

From (Your Name) Please Print: **EPA**
Company: **EPA**
Street Address: **345 COURTLAND ST**
City: **ATLANTA** State: **GA** ZIP Required: **30303**

To (Recipient's Name) Please Print: **BRUCE MITCHELL**
Company: **FEDER TWIN TOWERS BLDG**
Exact Street Address (We Cannot Deliver to P.O. Boxes or P.O. Zip Codes.): **200 BLAIR STONE RD**
City: **Tallahassee** State: **FL** ZIP Required: **32399-2400**

YOUR INTERNAL BILLING REFERENCE INFORMATION (First 24 characters will appear on invoice.)

PAYMENT 1 Bill Sender 2 Bill Recipient's FedEx Acct No 3 Bill 3rd Party FedEx Acct No 4 Bill Credit Card
5 Cash/Check

SERVICES (Check only one box)
 11 YOUR PACKAGING
 16 FEDEX LETTER *
 12 FEDEX PAK *
 13 FEDEX BOX
 14 FEDEX TUBE
 51 Standard Overnight Service (Delivery by next business afternoon)
 56 FEDEX LETTER *
 52 FEDEX PAK *
 53 FEDEX BOX
 54 FEDEX TUBE
 70 Heavyweight Service (for Extra Large or any package over 150 lbs)
 80 DEFERRED HEAVYWEIGHT **

DELIVERY AND SPECIAL HANDLING (Check services required)
 1 HOLD FOR PICK-UP (Use Box #)
 2 DELIVER WEEKDAY
 3 DELIVER SATURDAY (Extra charge) (Not available to all locations)
 4 DANGEROUS GOODS (Extra charge)
 5 DRY ICE _____ lbs
 7 OTHER SPECIAL SERVICE _____
 8 SATURDAY PICK-UP (Extra charge)
 9 SATURDAY PICK-UP (Extra charge)
 10 HOLIDAY DELIVERY (if offered) (Extra charge)
 11
 12

PACKAGES 1 Regular Ship 3 Drop Box
2 Ch-Cat Ship 4 B5C
5 Station

YOUR DECLARED VALUE
 DIM SHIPMENT (Chargeable Weight) _____ lbs
 1 Regular Ship 3 Drop Box
2 Ch-Cat Ship 4 B5C
5 Station

Emp No _____ Date _____
 Federal Express Use
 Cash Received
 Return Shipment
 Third Party Chg To Del Chg To Hold
 Street Address _____
 City _____ State _____ Zip _____
 Received By _____
 Date/Time Received _____ FedEx Employee Number _____
 Release Signature **Angel D. Moore** 5
 Date/Time **3-12-91**

REVISION DATE 8/90
 PART #119-01 (REV. 1/85)
 FORMAT #041
041
 © 1990 F.E.C. PRINTED IN USA



Hand Delivered
@ 8:53 3-14-91
Marcia

Georgia-Pacific Corporation *Palatka Operations*
Southern Pulp & Paper Division
P.O. Box 919
Palatka, Florida 32078-0919
Telephone (904) 325-2001

File Copy
PSD-FL-171
AL54-192250

RECEIVED

MAR 14 1991

March 13, 1991

Hand Delivered

DER-BAQM

Mr. Bruce Mitchell
Florida Department of
Environmental Regulation
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Dear Mr. Mitchell:


In our recent phone conversation concerning the PSD application for the work scheduled to be performed on our #4 Recovery Boiler and #4 Lime Kiln you stated that your only remaining concerns were the appropriate creditable emission decreases for TRS and EPA's questions regarding PM10.

Georgia-Pacific still believes that the reduction in TRS emissions due to the TRS project are fully creditable. We did however ask David Buff to calculate what allowable TRS emission limit for the #4 Recovery Boiler would be necessary for us to net out of PSD if the final ruling was that the reductions mentioned above were not creditable. A limit of 11.4 ppm TRS corrected to 8% O₂ on our #4 Recovery Boiler would allow us to net out of PSD and would be the desired method of handling the situation if the credits are disallowed. A letter from David Buff detailing the calculations is attached.

David Buff spoke with Greg Worley of EPA concerning their questions regarding PM10 and his comments are also summarized in the attached letter. In short EPA did not realize that an AAQS analysis had been done for PM10 and that the analysis we did, which showed compliance, was more conservative than what they were requesting.

If you have any questions or if I can be of further service, please call me at 904-325-2001.

Sincerely,



Vernon L. Adams
Superintendent of
Environmental Affairs

cc: A. Beshire
D. Buff
H. Hirschman
W. R. Wilson

Bruce Mitchell

Cleve Holladay

Andy Kutynas NE District

Jewell Harper / Guss Worley / Lew Negler: EPA, Region IV
(FAX) (FAX)

} 3-14-91 RAL

Seal



David A. Buff
Florida Registration No. 19011



March 13, 1991

Mr. Vernon Adams
Georgia-Pacific Corporation
County Road 216
Palatka, FL 32017

Re: Georgia-Pacific Corporation
Proposed Recovery Boiler/Lime Kiln Project

Dear Mr. Adams:

KBN Engineering and Applied Sciences, Inc. (KBN) was asked to calculate the allowable TRS emissions for Recovery Boiler No. 4 (RB4) in the event that past TRS reductions at the mill are not creditable for PSD purposes. If the past reductions are not creditable, Georgia-Pacific Corporation (G-P) desires to reduce the allowable TRS emissions for RB4 in order to not trigger PSD review.

In conversations with Bruce Mitchell of FDER, Mr. Mitchell stated that FDER would accept the current allowable TRS emission level of 17.5 ppm (along with actual operating hours for the boiler) as the basis for PSD baseline emissions. The operating permit for the boiler allows 21.6 lb/hr TRS, based on the 17.5 ppm limit. The average of actual operating hours for the boiler in 1989 and 1990 was 8,463 hr/yr. The baseline TRS emission rate for RB4, therefore, is as follows:

$$21.6 \text{ lb/hr} \times 8,463 \text{ hr/yr} \div 2,000 \text{ lb/ton} = 91.4 \text{ TPY}$$

The proposed new level of allowable TRS emissions for RB4 is 17.8 lb/hr and 78.0 TPY. This equates to a level of 11.4 ppm TRS at 8 percent O₂ at the higher RB4 production rate. The calculation is provided below:

$$V = \text{MRT/P}$$

$$V_{\text{TRS}} = \frac{17.8 \text{ lb}_m}{\text{hr}} \times \frac{\text{hr}}{60 \text{ min}} \times \frac{1,545 \text{ ft-lb}_f}{34 \text{ lb}_m \cdot ^\circ\text{R}} \times \frac{528^\circ\text{R ft}^2}{2,116.8 \text{ lb}_f} = 3.36 \text{ scfm}$$

$$\text{ppm} = 3.36/210,000 \times 10^6 = 16.00 \text{ ppm @ } 2.8\% \text{ O}_2$$

$$\text{ppm @ } 8\% \text{ O}_2 = 16.00/1.40 = 11.4 \text{ ppm @ } 8\% \text{ O}_2$$

The PSD applicability analysis for TRS emissions, based on the above calculations and information provided in the PSD permit application submitted for the project, is presented in the following table.

90133A1/2

KBN ENGINEERING AND APPLIED SCIENCES, INC.
1034 Northwest 57th Street Gainesville, Florida 32605 904/331-9000 FAX: 904/332-4189



Source	Current Actual Emissions (TPY)	Future Maximum Emissions (TPY)	Net Change in Emissions (TPY)
No. 4 Recovery Boiler	91.4	78.0	-13.40
No. 4 Smelt Diss. Tank	5.3	14.7	9.40
No. 4 Lime Kiln	3.6	17.5	13.90
TOTALS	100.30	110.20	9.90

As shown, the net increase in TRS emissions is 9.90 TPY, which is below the PSD significant emission rate of 10.0 TPY.

G-P also requested that I investigate FDER's indication that EPA Region IV provided comments relating to the PM10 modeling analysis presented in the permit application. I, therefore, spoke with Greg Worley and Lew Nagler at Region IV. Mr. Nagler stated their concern was that a PM10 AAQS analysis be conducted, even though PSD increment consumption was being expanded for PM10. He also stated that the PM10 standard is now a statistical standard, and when using 5 years of meteorological data, the sixth highest value at each receptor over all 5 years of data should be used to determine compliance.

In regard to the first issue, I pointed out that KBN had indeed presented a PM10 AAQS analysis in the permit application. The analysis showed maximum impacts to be well below the AAQS. Mr. Nagler acknowledged this oversight, and indicated this satisfied their concern.

In regard to the second issue, KBN used the standard modeling approach of using the highest, second-highest model result over the entire 5 years. Using this approach, there can only be five concentrations out of the entire 5 years at a particular receptor that are higher in value than the highest, second-highest value. Therefore, if the highest, second-highest value at a receptor is in compliance with the standards, then the sixth highest value will also be in compliance. Therefore, our approach is conservative.

Please call if you have any questions concerning this information.

Sincerely,

A handwritten signature in cursive script that reads "David A. Buff".

David A. Buff, M.E., P.E.
Principal Engineer

DAB/dmw

Department of Environmental Regulation Routing and Transmittal Slip

Palatka Operations
Southern Pulp & Paper Division
P.O. Box 919
Palatka, Florida 32078-0919
Telephone (904) 325-2001

To: (Name, Office, Location)

1. Mr. Jewell A. Harper, Chief
2. Air Enforcement Branch
3. Air, Pesticides & Toxics Management Division
4. U.S. EPA Region IV

13, 1991

RECEIVED

MAR 14 1991

DER-BAQM

Remarks: Re: Georgia-Pacific Corp.: PSD-FL-171

Please find attached a copy of an amendment submittal to the application package currently under review.

If there are any questions, please call Bruce Mitchell or Cleve Holladay or write to me at the above address.

Sincerely,

attn: Gregg Worley
Lew Negler

P.S.: FAX sent 3-14-91 to Gregg Worley / Lew Negler


Concerning the PSD performed on our #4 we noted that your only creditable emission regarding PM10.

the reduction in TRS is not creditable. We noted that what allowable TRS would be necessary if the only creditable was that the Recovery Boiler would be the desired credits are failing the

From *R. Bruce Mitchell*
for C. H. Fancy

Date
3-14-91
Phone
904-488-1344

EPA concerning comments are also summarized in the attached letter. In short EPA did not realize that an AAQS analysis had been done for PM10 and that the analysis we did, which showed compliance, was more conservative than what they were requesting.



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

FAX TRANSMITTAL LETTER

DATE: 3-14-91

TO:

NAME: Gregg Worley / Lew Negler

AGENCY: Region IV, U.S. EPA

TELEPHONE: (404) 347-5207

OF PAGES (INCLUDE COVER SHEET): 5

FROM:

NAME: Bruce Mitchell

AGENCY: FNER/DARM/Bureau of Air Regulation

IF ANY PAGES ARE NOT CLEARLY RECEIVED, PLEASE CALL IMMEDIATELY. PHONE NO. (404) 448-1344

SENDER'S NAME: Sam

COMMENTS: Amendment submittal to PSD-FL-171

Georgia-Pacific Corporation

MESSAGE CONFIRMATION

MAR-14-'91 THU 09:29

TERM ID: DIV OF AIR RES MGMT P-9999

TEL NO: 904-932-8979

NO.	DATE	ST. TIME	TOTAL TIME	ID	DEPT CODE	OK	NG
856	03-14	09:26	00:02:59	404 347 5207		05	00

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY - REGION IV
 AIR, PESTICIDES & TOXICS MANAGEMENT DIVISION
 345 Courtland Street, N. E.
 Atlanta, Georgia 30365
 Fax Number: FTS 257-5207 or 404/347-5207

RECEIVED

MAR 12 1991

FACSIMILE TRANSMISSION SHEET

DER-BAQM

DATE: 3/12/91 NUMBER OF PAGES (Including this sheet) _____
 (Preparer must number all pages)

TO: Bruce Mitchell PHONE: (904) 488-1344

ADDRESS: FDER FAX NUMBER: (904) 922-6979

FROM: GREGG WORLEY PHONE: (404) 347-2904

If the following pages are received poorly, please call _____
 at FTS 257-_____ or 404/347-_____.

SPECIAL INSTRUCTIONS FOR RECEIVER: _____

cc:
 Bruce Mitchell (vid from BA 3-13-91) } 3-15-91 PAM
 Cleve Holliday }
 Vernon Adams : G-PC, gave him a copy by hand 3-14-91 PAM



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET, N.E.
ATLANTA, GEORGIA 30365

4APT-AEB

MAR 12 1991

Mr. Clair H. Fancy, P.E., Chief
Bureau of Air Regulation
Florida Department of Environmental
Regulation
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

RE: Georgia-Pacific Corporation, Palatka (PSD-FL-171)

Dear Mr. Fancy:

This is to acknowledge receipt of an application for a Prevention of Significant Deterioration (PSD) permit for the above referenced facility transmitted by your letter of February 14, 1991. As discussed between Mr. Bruce Mitchell of your staff and Mr. Gregg Worley of my staff on March 7, 1991, we have the following comments and questions on the submittal.

Modelling/Monitoring

The modeling analysis as submitted has been reviewed. The modification will have a significant impact for TSP/PM-10; however, since a previously permitted PSD source at the plant was never constructed, the total increment consumption will be less now than with the prior application. Based on this decrease in overall emissions, further modelling was deemed by the applicant to be unnecessary.

After discussing this point with EPA Headquarters, it was agreed that if there is a significant impact from the new source or modification, a NAAQS review is required. There is no basis in our regulations to exempt further analysis, even if there is no threat to the available increment; we still need to determine what the impact on the NAAQS will be. Our comments are as follows:

1. A NAAQS modeling analysis is necessary for PM-10.
2. The standard for PM-10 is now a statistical standard and the sixth highest 24 hour concentration based on five years of meteorological data is now used instead of the high second highest value.

Netting Calculation

When calculating the net emissions increase for TRS emissions, GP included an emissions decrease which resulted from complying with Florida's TRS rule. Since the reduction was made to comply with regulations, it does not qualify as a creditable emissions decrease.

-2-

BACT Analysis

The BACT analysis does not propose controls other than the existing controls for the emissions units. Questions and comments about the BACT analysis performed by the applicant are as follows:

Recovery Boiler

1. What is the percent dryness of the black liquor solids? (Note that the recent trend for recovery boilers has been to burn drier black liquor solids, about 70 to 75% solids. The increased dryness has an effect both on SO₂ emissions and NO_x emissions.)
2. The application states that current actual emissions for SO₂ are in the range of 7-9 ppm, yet the requested permit limit is for 75 ppm. Although GP will apparently net out of PSD review for SO₂, the allowable emissions should more closely reflect the actual capabilities of the emissions unit.
3. What changes are being made to the ESP? In a recent permit application in Region IV (Hammermill Papers in Alabama) in which an existing recovery boiler was being modified, the efficiency of the existing ESP was evaluated and cost estimates were made on improving the efficiency of the ESP. GP has proposed a PM limit of 0.044 gr/dscf utilizing the existing ESP. Current permits for new recovery boilers are being issued in the range of 0.021 to 0.030 gr/dscf. The Hammermill facility mentioned above has proposed a level of 0.034 gr/dscf based on an economic evaluation. In any case, defaulting to the NSPS level without supporting documentation does not meet the requirements of a BACT analysis.
4. The applicant proposed emissions limits for CO, VOC, and NO_x based on an annual average. This does not meet the requirement of "short-term and specific" limits.


Lime Kiln

Again the applicant did not consider more stringent limits than the existing allowable emissions.

-3-

Thank you for the opportunity to review and comment on this application. If you have any questions or comments on the modeling comments, please contact Mr. Lew Nagler at (404) 347-2904. Other questions may be directed to Mr. Gregg Worley of my staff, also at (404) 347-2904.

Sincerely yours,



Jewell A. Harper, Chief
Air Enforcement Branch
Air, Pesticides, and Toxics
Management Division



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET, N.E.
ATLANTA, GEORGIA 30365

RECEIVED

MAR 15 1991

MAR 12 1991

DER-BAQM

4APT-AEB

Mr. Clair H. Fancy, P.E., Chief
Bureau of Air Regulation
Florida Department of Environmental
Regulation
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

RE: Georgia-Pacific Corporation, Palatka (PSD-FL-171)

Dear Mr. Fancy:

This is to acknowledge receipt of an application for a Prevention of Significant Deterioration (PSD) permit for the above referenced facility transmitted by your letter of February 14, 1991. As discussed between Mr. Bruce Mitchell of your staff and Mr. Gregg Worley of my staff on March 7, 1991, we have the following comments and questions on the submittal.

Modelling/Monitoring

The modeling analysis as submitted has been reviewed. The modification will have a significant impact for TSP/PM-10; however, since a previously permitted PSD source at the plant was never constructed, the total increment consumption will be less now than with the prior application. Based on this decrease in overall emissions, further modelling was deemed by the applicant to be unnecessary.

After discussing this point with EPA Headquarters, it was agreed that if there is a significant impact from the new source or modification, a NAAQS review is required. There is no basis in our regulations to exempt further analysis, even if there is no threat to the available increment; we still need to determine what the impact on the NAAQS will be. Our comments are as follows:

1. A NAAQS modeling analysis is necessary for PM-10.
2. The standard for PM-10 is now a statistical standard and the sixth highest 24 hour concentration based on five years of meteorological data is now used instead of the high second highest value.

Netting Calculation

When calculating the net emissions increase for TRS emissions, GP included an emissions decrease which resulted from complying with Florida's TRS rule. Since the reduction was made to comply with regulations, it does not qualify as a creditable emissions decrease.

BACT Analysis

The BACT analysis does not propose controls other than the existing controls for the emissions units. Questions and comments about the BACT analysis performed by the applicant are as follows:

Recovery Boiler


1. What is the percent dryness of the black liquor solids? (Note that the recent trend for recovery boilers has been to burn drier black liquor solids, about 70 to 75% solids. The increased dryness has an effect both on SO₂ emissions and NO_x emissions.)
2. The application states that current actual emissions for SO₂ are in the range of 7-9 ppm, yet the requested permit limit is for 75 ppm. Although GP will apparently net out of PSD review for SO₂, the allowable emissions should more closely reflect the actual capabilities of the emissions unit.
3. What changes are being made to the ESP? In a recent permit application in Region IV (Hammermill Papers in Alabama) in which an existing recovery boiler was being modified, the efficiency of the existing ESP was evaluated and cost estimates were made on improving the efficiency of the ESP. GP has proposed a PM limit of 0.044 gr/dscf utilizing the existing ESP. Current permits for new recovery boilers are being issued in the range of 0.021 to 0.030 gr/dscf. The Hammermill facility mentioned above has proposed a level of 0.034 gr/dscf based on an economic evaluation. In any case, defaulting to the NSPS level without supporting documentation does not meet the requirements of a BACT analysis.
4. The applicant proposed emissions limits for CO, VOC, and NO_x based on an annual average. This does not meet the requirement of "short-term and specific" limits.

Lime Kiln

Again the applicant did not consider more stringent limits than the existing allowable emissions.

Thank you for the opportunity to review and comment on this application. If you have any questions or comments on the modeling comments, please contact Mr. Lew Nagler at (404) 347-2904. Other questions may be directed to Mr. Gregg Worley of my staff, also at (404) 347-2904.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Jewell A. Harper". The signature is written in a cursive style with a large initial "J" and "H".

Jewell A. Harper, Chief
Air Enforcement Branch
Air, Pesticides, and Toxics
Management Division



Georgia Pacific Corporation Palatka Operations
Southern Pulp & Paper Division
P.O. Box 919
Palatka, Florida 32078-0919
Telephone (904) 325-2001

RECEIVED
March 7, 1991
MAR 08 1991
DER-BAQM

Mr. Bruce Mitchell
Florida Department of
Environmental Regulation
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Dear Mr. Mitchell:

At our recent meeting concerning the PSD application for the work scheduled to be performed on our #4 Recovery Boiler and #4 Lime Kiln you asked us to address three questions. They dealt with property boundaries, black liquor flow in the concentrator, and contemporaneous reductions in TRS.

The property boundary question dealt with public accessibility. The area detailed on the map which was enclosed in the application is accurate. Public accessibility is controlled in several ways. The boundary closest to the mill is fenced and patrolled by security guards. The other boundaries are secured thru a combination of other means which include gates, posted signs, security patrols, and natural barriers such as thick vegetation. KBN checked the areas just outside the fences in the areas which had the greatest likelihood of having ambient problems and found none (modeling supporting this conclusion is attached).

You questioned whether we needed to apply for a PSD permit for our evaporator system due to possible increased throughput through the concentrators. The multiple effect evaporators are permitted as a system to handle a given amount of black liquor solids. The concentrators are just one component of this permitted system which is currently processing all of the black liquor produced by the mill's digesters. All of the black liquor solids produced by the mill pass through the evaporator system at least one time and some of the solids are processed more than once due to the way the mill's black liquor pond is utilized. The end result is we do not expect an increase in the amount of black liquor solids we are handling in the evaporator system or resultant emissions and we do not need to raise the permitted rate for throughput thus we do not believe we need a PSD permit for the evaporator system.

FEDERAL EXPRESS

QUESTIONS? CALL 800-238-5355 TOLL FREE.

AIRBILL
PACKAGE
TRACKING NUMBER

0169678843

1011

0169678843

RECIPIENT'S COPY

From (Your Name) Please Print David A. Buff		Your Phone Number (Very Important) 304-331-9000	To (Recipient's Name) Please Print Bruce Mitchell		Recipient's Phone Number (Very Important) (904) 488-1344
Company KBN ENG & APPLIED SCIENCES		Department/Floor No	Company Florida Dept. of Environmental Regulation		Department/Floor No
Street Address 1034 NW 57TH ST		Exact Street Address (We Cannot Deliver to P.O. Boxes or P.O. Zip Codes) 2600 Blair Stone Road			
City GAINESVILLE	State FL	ZIP Required 32605	City Tallahassee,	State FL	ZIP Required 32399-2400

YOUR INTERNAL BILLING REFERENCE INFORMATION (First 24 characters will appear on invoice.) 90133		IF HOLD FOR PICK-UP, Print FEDEX Address Here Street Address City State ZIP Required	
PAYMENT 1 <input checked="" type="checkbox"/> Bill Sender 2 <input type="checkbox"/> Bill Recipient's FedEx Acct No 3 <input type="checkbox"/> Bill 3rd Party FedEx Acct No 4 <input type="checkbox"/> Bill Credit Card		5 <input type="checkbox"/> Cash/Check	

SERVICES (Check only one box)		DELIVERY AND SPECIAL HANDLING (Check services required)		PACKAGES	WEIGHT in Pounds Only	YOUR DECLARED VALUE	Emp No	Date	Federal Express Use
Priority Overnight Service (Delivery by next business morning!) Standard Overnight Service (Delivery by next business afternoon!) 11 <input type="checkbox"/> YOUR PACKAGING 51 <input type="checkbox"/> 16 <input type="checkbox"/> FEDEX LETTER * 56 <input checked="" type="checkbox"/> FEDEX LETTER * 12 <input type="checkbox"/> FEDEX PAK * 52 <input type="checkbox"/> FEDEX PAK * 13 <input type="checkbox"/> FEDEX BOX 53 <input type="checkbox"/> FEDEX BOX 14 <input type="checkbox"/> FEDEX TUBE 54 <input type="checkbox"/> FEDEX TUBE Economy Two-Day Service (formerly Standard Air) (Delivery by second business day!) Heavyweight Service (For Extra Large or any package over 150 lbs) 70 <input type="checkbox"/> HEAVYWEIGHT ** 30 <input type="checkbox"/> ECONOMY TWO-DAY SVC 80 <input type="checkbox"/> DEFERRED HEAVYWEIGHT ** *Declared Value Limit \$100 **Call for delivery schedule	1 <input type="checkbox"/> HOLD FOR PICK-UP (if # in Box #) 2 <input checked="" type="checkbox"/> DELIVER WEEKDAY 3 <input type="checkbox"/> DELIVER SATURDAY (Extra charge) (Not available to all locations) 4 <input type="checkbox"/> DANGEROUS GOODS (Extra charge) 5 <input type="checkbox"/> 6 <input type="checkbox"/> DRY ICE _____ Lbs 7 <input type="checkbox"/> OTHER SPECIAL SERVICE _____ 8 <input type="checkbox"/> 9 <input type="checkbox"/> SATURDAY PICK-UP (Extra charge) 10 <input type="checkbox"/> 11 <input type="checkbox"/> 12 <input type="checkbox"/> HOLIDAY DELIVERY (if offered) (Extra charge)	Total Total Total DIM SHIPMENT (Chargeable Weight) <input type="checkbox"/> _____ lbs Received At 1 <input type="checkbox"/> Regular Stop 3 <input type="checkbox"/> Drop Box 2 <input type="checkbox"/> On Call Stop 4 <input type="checkbox"/> BSC 5 <input type="checkbox"/> Station	<input type="checkbox"/> Cash Received <input type="checkbox"/> Return Shipment <input type="checkbox"/> Third Party <input type="checkbox"/> Chg To Del <input type="checkbox"/> Chg To Hold Street Address City State Zip Received By X Date/Time Received FedEx Employee Number	Base Charges Declared Value Charge Other 1 Other 2 Total Charges REVISION DATE 8/90 PART #119501 FXEM12790 FORMAT #041 041 * 1990 FEC PRINTED IN USA					

In regard to creditable emission changes for TRS at the mill the question arose as to the creditable status of the prior TRS reductions at the facility due to the TRS control project . It is our position that the reduction in TRS emissions due to the TRS project are fully creditable. This position is supported by the construction permits (AC54-1422-82, 88, and 91) which were issued on April 29, 1988. In Specific Condition 16 of the permits, it is stated:

For the purposes of future permits and PSD determinations, the mass emissions of pollutants listed in Table 500-2 and the associated emission changes are:

Pollutant	Pre-		Post-		Changes	
	lbs/hr	TPY	lbs/hr	TPY	lbs/hr	TPY
TRS	637.5	1824.3	0.1	0.5	-637.4	-1823.8

This specific condition fully documents the TRS reductions, and specifically states that the listed mass emission are to be used for future permitting and PSD determinations.

Our review of the Florida Administrative Code, Rule 17-2.500(2)(e)4 also supports the position that the previous TRS decreases are creditable. This rule states that a decrease in actual emissions is creditable only if:


- a. The old level of actual emissions, the old level of federally enforceable allowable emission, or the old level of allowable emissions under Rule 17-2.650, whichever is lowest exceeds the new level of actual emission.
- b. The decrease is federally enforceable.
- c. The Department or EPA has not relied on it in issuing a PSD permit, demonstrating attainment, defining reasonable further progress, or in issuing a nonattainment permit, or permit requiring RACT.

In our case, there were no federally enforceable allowable TRS emissions limits prior to the decrease, and no allowable TRS emissions limits under Rule 17-2.650. The decrease was federally enforceable through the issued construction permit. The Department has not relied on the TRS decrease in issuing a PSD permit or the other requirements described in c. above. As you are aware, EPA has ruled that a net decrease in emissions for a specific pollutant,

resulting from a modification, is not "relied" upon if PSD is not triggered for that pollutant. Any net decreases are retained for future applicability within the contemporaneous period. The wording in our TRS construction permit supports this position.

If you have any questions or if I can be of further service, please call me at 904-325-2001.

Sincerely,



Vernon L. Adams
Superintendent of
Environmental Affairs

cc: A. Beshire
D. Buff
H. Hirschman
W. R. Wilson

Seal



David A. Buff
Florida Registration No. 19011

cc: B. Mitchell
C. Holladay
B. Andrews

A. Kutyna NE District -

G. Harper, EPA 3-15-91 @ Inc. letter

} 3-13-91 PRH

Attachment A

Dispersion Modeling Results at Revised Plant Property Receptors

In the dispersion modeling analysis presented in the permit application, receptors were placed at the extent of Georgia-Pacific property (i.e., at the edge of State Road 216 and U.S. Highway 17) at 10-degree increments from 40 to 200 degrees relative to the TRS incinerator stack. In response to FDER comments, additional dispersion modeling was performed locating plant property receptors at the Georgia-Pacific fence line bordering State Road 26 and U.S. Highway 17. The locations of the revised receptors are presented in Figure A-1. A comparison of the locations of the original and revised plant property receptors is presented in Table A-1. A summary of additional receptors used to provide 100-m resolution in the zone between original and revised plant property receptors is presented in Table A-2.

The significant impact analysis was remodeled to determine if predicted annual NO_x concentrations or 1- and 8-hour CO concentrations were above significant impact levels. The results of the significant impact analysis for CO and NO_x are presented in Table A-3. Only the maximum predicted highest, second-highest 8-hour average CO concentration, $9.3 \mu\text{g}/\text{m}^3$, is greater than that predicted in the original analysis. However, this concentration is still well below the 8-hour significance level of $10,000 \mu\text{g}/\text{m}^3$ for CO. As before, no additional modeling is required for CO and NO_x .

The results of the PM10 AAQS modeling analysis are presented in Table A-4. The maximum annual and highest, second-highest 24-hour PM10 concentrations predicted at the revised receptors were greater than those originally presented, but are still well below the annual and 24-hour AAQS of 50 and $150 \mu\text{g}/\text{m}^3$, respectively. No refined analysis is presented because maximum receptor spacing in this analysis is already much less than 100 m.




Figure A-1 LOCATIONS OF REVISED PLANT PROPERTY RECEPTORS



Table A-1. Comparison of Plant Property Receptor Locations Used in Original and Revised Modeling Analysis

<u>Direction</u> (deg)	<u>Original</u> <u>Downwind Distance</u> ^a (m)	<u>Revised</u> <u>Downwind Distance</u> ^a (m)
0-40	As Presented in Application	No Change
50	1,500	562
60	1,500	633
70	1,500	649
80	838	694
90	686	623
100	533	461
110	457	319
115	-	304
120	457	365
130	457	400
140	457	380
150	457	345
160	488	300
170	533	238
180	610	263
190	750	253
200-350	As Presented in Application	No Change

^aReceptor locations are relative to the location of the TRS incinerator stack.

Table A-2. Summary of Additional (Non-Plant Property) Receptor Locations
Used in the Revised Modeling

<u>Direction</u> (deg)	<u>Downwind Distance</u> ^a (m)
110	400
120	400
150	400
160	400
170	300, 400, 500
180	300, 400, 500
190	300

^aReceptor locations are relative to the location of the TRS incinerator stack.

Table A-3. Results of the Significant Impact Analysis for Revised Plant Property and Additional Receptors

Pollutant	Averaging Period	<u>Predicted Concentration ($\mu\text{g}/\text{m}^3$) for year:</u>					Maximum Concentration ($\mu\text{g}/\text{m}^3$)	Significant Impact Level ($\mu\text{g}/\text{m}^3$)
		1983	1984	1985	1986	1987		
Carbon Monoxide	1-hour	41	41	44	44	43	43	40,000
	8-hour	5.2	9.3	7.0	7.9	5.5	9.3	10,000
Nitrogen Dioxide	Annual	0.2	0.3	0.2	0.3	0.3	0.3	1.0

Table A-4. Results of the PM10 AAQS Analysis for Revised Plant Property and Additional Receptors

Year	Concentration ($\mu\text{g}/\text{m}^3$)			Receptor		Period (day)	PM10 AAQS ($\mu\text{g}/\text{m}^3$)
	Background	Modeled	Total	Direction (deg)	Distance (km)		
<u>Annual</u>							
1983	21	5.5	26.5	70	0.649	—	
1984	21	5.2	26.2	115	0.304	—	
1985	21	5.3	26.3	70	0.649	—	50
1986	21	6.2	27.2	70	0.649	—	
1987	21	7.0	28.0	115	0.304	—	
<u>24-Hour</u>							
1983	51	37	88	115	0.304	71	
1984	51	39	90	70	0.649	155	
1985	51	31	82	115	0.304	189	150
1986	51	36	87	115	0.304	364	
1987	51	52	103	120	0.365	1	

File Copy



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

February 14, 1991

Mr. Andy Kutyna, Administrator
Air Programs
Northeast District
7825 Baymeadows Way, Suite B200
Jacksonville, Florida 32256-7577


Dear Mr. Kutyna:

Re: Completeness Review of Application to Modify
Georgia-Pacific Corporation
PSD-FL-171

Enclosed is the above referenced application package for a proposed modification at Georgia-Pacific Corporation's facility located in Palatka, Putnam County, Florida. Please have a technical evaluation of the package conducted and provide the Bureau of Air Regulation (BAR) with comments by March 12, 1991. The BAR's FAX number is (904)922-6979.

If there are any questions, please give Bruce Mitchell or Cleve Holladay a call at (904)488-1344 or write to me at the above address.

Sincerely,



C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/BM/rbm

Enclosure

c: D. Buff, P.E., KBN
V. Adams, G-PC

Reading File
Bruce Mitchell } 2-14-91 RBM
Cleve Holladay
Barry Andrews



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400
Lawton Chiles, Governor Carol M. Browner, Secretary

February 14, 1991

Ms. Jewell A. Harper, Chief
Air Enforcement Branch
Air, Pesticides & Toxics Management Division
U.S. EPA, Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30365

Dear Ms. Harper:

Re: Completeness Review of Application to Modify
Georgia-Pacific Corporation
PSD-FL-171

Enclosed is the above referenced application package for a proposed modification at Georgia-Pacific Corporation's facility located in Palatka, Putnam County, Florida. Please have a technical evaluation of the package conducted and provide the Bureau of Air Regulation (BAR) with comments by March 12, 1991. The BAR's FAX number is (904)922-6979.

If there are any questions, please give Bruce Mitchell or Cleve Holladay a call at (904)488-1344 or write to me at the above address.

Sincerely,

C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/BM/rbm

Enclosure

c: A. Kutyna, NE Dist.
D. Buff, P.E., KBN
V. Adams, G-PC

Reading File }
Bruce Mitchell } 2-14-91 RBM
Cleve Holladay }
Barry Andrews }