

RECEIVED

JAN 06 2002

BUREAU OF AIR REGULATION

**TEST REPORT
On
STACK EMISSIONS**

From the
BLEACH PLANT WET SCRUBBER OUTLET

In service at
GEORGIA-PACIFIC PALATKA OPERATIONS

Located in
PALATKA, PUTNAM COUNTY, FLORIDA

Prepared for
GEORGIA-PACIFIC CORPORATION

Test Completion Date: October 28th, 2002
Report Submittal Date: November 8th, 2002

Cubix Project No. 7382-FL1

Prepared by



CORPORATE HEADQUARTERS
9225 US Hwy. 183 South, Austin, TX 78747

TABLE OF CONTENTS

INTRODUCTION	1
Table 1: Background Data	2
SUMMARY OF RESULTS	4
Table 2: Summary of Results	4
PROCESS DESCRIPTION	6
ANALYTICAL TECHNIQUE	7
Table 3: Analytical Instrumentation	10
Figure 1: Instrumental Sample System Diagram	11
QUALITY ASSURANCE ACTIVITIES	12
APPENDICES:	
A. Field Data Sheets	
B. Example Calculations	
C. Operational Data	
D. Quality Assurance Activities	
E. Calibration Certifications	
F. Logged Data Records	

INTRODUCTION

Emission testing was conducted on a Bleach Plant wet scrubber at the Georgia-Pacific Corporation (GaPac) Palatka Operations facility located on County Road 216 in Palatka, Putnam County, Florida. Carbon monoxide (CO) and other combustion products were measured in the outlet of the scrubber stack. Cubix Corporation, Southeast Regional Office conducted these tests on October 28th, 2002.

The purpose of this testing was to determine the CO emission rates of the scrubber while bleaching softwood in lieu of hardwood as an engineering study. Three one-hour test runs were conducted on the unit documenting process operating data, emission concentrations, and mass emission rates.

The tests followed the principles of the procedures set forth in the Code of Federal Regulations, Title 40, Part 60, Appendix A, Methods 1, 2, 3a, 4, and 10. Table 1 summarizes the background information pertinent to these tests.

This report has been reviewed and is approved for submittal by the following representative:


Cubix Corporation

TABLE 1
Background Data

<u>Source Owner:</u>	Georgia-Pacific Corporation County Road 216 Palatka, Florida 32177 Attention: Joe E. Taylor (386) 329-0027 Phone (386) 328-0014 Facsimile Email: JETAYLOR@GAPAC.com
<u>Test Contractor:</u>	Cubix Corporation, SE Regional Office 3709 SW 42 nd Avenue, Suite 2 Gainesville, Florida 32608 Attention: Roger Osier, Project Foreman (352) 378-0332 Phone (352) 378-0354 Facsimile Email: rosier@cubixcorp.com
<u>Process Description:</u>	This pulp and paper mill produces both natural and bleached Kraft paper grades. Wood pulp is processed at the Bleach Plant in the manufacture of bleached paper products. The process utilizes chlorine dioxide (ClO ₂) for the bleaching of pulp. Emissions from all stages of the bleaching process are sent to an alkaline wet scrubber.
<u>Test Date(s):</u>	October 28 th , 2002.
<u>Location:</u>	Georgia-Pacific Palatka Operations is located on County Road 216 in Palatka, Putnam County, Florida.
<u>Emission Sampling Point:</u>	The Bleach Plant scrubber (outlet) stack has two 3" diameter flanged NPT sample ports located 90° to each other in the vertical stack before venting to atmosphere, see Appendix A for stack diagram.
<u>Test Participants:</u>	Georgia-Pacific Corporation Joe Taylor, Test Coordinator

Test Participants (continued):

Cubix Corporation

Roger Paul Osier, Project Foreman
James Hastings, Field Technician

Test Methods:

Environmental Protection Agency (EPA) Method 1 was used for selection of velocity traverse point locations.

EPA Method 2 was used for conducting stack gas pitot tube measurements used in determination of stack gas velocity.

EPA Method 3a was used for determination of oxygen (O₂) and carbon dioxide (CO₂) concentrations.

EPA Method 4 was used for determination of stack gas moisture content.

EPA Method 10 was used for determination of carbon monoxide (CO) concentrations.

SUMMARY OF RESULTS

GaPac owns and operates Georgia-Pacific Palatka Operations facility in Palatka, Putnam County, Florida. At this facility a wet scrubber is used to collect and control emissions from the Bleach Plant in the bleaching process of wood pulp. The emissions from this scrubber are the subject of this report.

Table 2 is a summary of the testing results for the emissions from the wet scrubber. The summary table contains data recorded during the test from the process feed rate and scrubber operation as supplied by GaPac personnel, ambient conditions, and the measured emissions. The emission rates for CO are reported in terms of parts per million by volume (ppmv) on a dry basis and pounds per hour (lbs/hr).

**TABLE 2: Summary of Results
Bleach Plant Scrubber - Softwood Testing**

Test Run No.	Run 1	Run 2	Run 3	
Date	10/28/02	10/28/02	10/28/02	
Start Time	09:34	11:27	13:17	
Stop Time	10:34	12:27	14:17	
Unit Operation				Averages
Wood Type	Softwood	Softwood	Softwood	-
Production Rate (adtbph)	49.7	49.7	35.0	44.8
#ClO ₂ (adtbp)	45.8	46.8	49.9	47.5
Ambient Conditions				
Atmospheric Pressure ("Hg)	29.98	29.96	29.91	29.95
Temperature (°F) : Dry bulb	80.5	84.2	87.6	84.1
(°F): Wet bulb	75.5	74.3	74.8	74.8
Humidity (lbs moisture/lb air)	0.0174	0.0155	0.0151	0.0160
Measured Emissions				
CO (ppmv, dry basis)	955.3	1083.6	951.3	996.7
O ₂ (% volume, dry basis)	20.76	20.67	20.69	20.71
CO ₂ (% volume, dry basis)	1.04	1.22	1.03	1.10
Stack Volumetric Flow Rates				
via Pitot Tube (SCFH, dry basis)	7.70E+05	8.06E+05	8.19E+05	7.98E+05
Mass Emission Rates				
CO (lbs/hr)	53.5	63.5	56.7	57.9

Please note that ClO₂ Application Rate is considered
Confidential Business Information

Three one-hour test runs were conducted for each required EPA test method on the wet scrubber outlet. CO, O₂, and CO₂ emissions were continuously monitored during each of these runs. Moisture content was determined gravimetrically during each test run using a chilled water impingement system. Stack velocity measurements were performed during each test run.

Pollutant mass emission rates were calculated using the volumetric flow rates determined by EPA Methods 1-4. Examples of mass emission rate calculations and other calculations necessary for the presentation of the results of this section are contained in Appendix B.

Appendix A contains all field data sheets used during these tests. Appendix B contains examples of all calculations necessary for the reduction of the data presented in this report. Operational data obtained during the testing is presented in Appendix C. Records of quality assurance activities are in Appendix D. Certifications of calibration gases and equipment used to conduct tests at this facility are in Appendix E. Appendix F contains a copy of the logged data records of the analyzer monitored emission concentrations.

PROCESS DESCRIPTION

Georgia-Pacific Corporation owns and operates the Georgia-Pacific Palatka Operations facility. In operation since 1947, this pulp and paper mill produces natural and bleached Kraft paper grades. The emissions from the outlet of the wet scrubber located at the Bleach Plant, a stage of the manufacture of bleached Kraft paper products, were measured as an engineering study to determine the effects of bleaching softwood pulp in lieu of hardwood pulp in the system. This section of the report provides a brief description of the process and the wet scrubber outlet.

The bleaching process is an elemental chlorine-free (ECF) process. The process utilizes ClO_2 for the pulp bleaching process. No elemental chlorine or hypochlorite salts are used in the process. The ClO_2 is produced on site.

The bleaching process consists of the staged introduction of ClO_2 to the pulp slurry followed by washing of the bleached pulp. G-P Palatka utilizes a 3-stage bleach plant for this process. The pulp comes across a pre-washer, followed by the D0 stage where ClO_2 is introduced, the E or extraction stage, and the D1 stage where additional ClO_2 is applied. The off gases from all stages of the process are collected and passed through a wet scrubber utilizing an alkaline scrubbing solution.

Sample ports meeting the criteria of EPA Method 1 were located in a straight vertical section of the scrubber stack outlet. The sample ports were greater than 2 stack diameters upstream from the nearest flow disturbance, the elbow just prior to the stack outlet, and greater than 8 diameters downstream from the nearest flow disturbance. Access to the stack was made available via a permanent steel frame platform equipped with a caged safety ladder. The diameter of the exhaust stack was 41.75 inches. Appendix A contains a field sketch of the stack configuration and sample port locations.

GaPac personnel provided operational data from the process instrumentation. Data sets were recorded during each test run; the average of this data was recorded in the summary table. Copies of the original data are contained in Appendix C of this report.

ANALYTICAL TECHNIQUE

The emissions from a bleach plant scrubber were measured to determine the quantity of emissions being emitted to the atmosphere under various operating conditions. The sampling and analysis procedures used during these tests conformed with those outlined in The Code of Federal Regulations, Title 40, Part 60, Appendix A, Methods 1, 2, 3a, 4, and 10. This section of the report describes the analytical techniques and procedures used during the testing.

The test matrix for the scrubber outlet consisted of three one-hour test runs following each test method specified by GaPac. The stack gas was analyzed for CO, O₂, and CO₂ by continuous instrumental monitors. All exhaust gas analyses were performed on a dry basis. Table 3 lists the instruments and detection principles used for these analyses.

Provisions were made to introduce the calibration gases to the instrumental monitors via two paths: 1) directly to the instruments via the sample manifold quick-connects and rotameters, and 2) through the complete sampling system including the sample probe, filter, heat trace, condenser, sample line, manifold, and rotameters. The former method was used for quick, convenient calibration checks. The latter method was used to demonstrate that the sample was not altered due to leakage, reactions, or adsorption within the sampling system (sample system bias check). An O₂ standard calibration gas was introduced into the O₂ analyzer directly. Then the response from the O₂ analyzer was noted as the calibration gas was introduced at the probe. Any difference between the two responses in the instrument was attributed to the bias of the sample system. Following the span gas bias check, a zero gas bias check was performed on the O₂ analyzer using nitrogen to check for any zero gas bias of the sample system. In accordance with EPA Method 3a, this span and zero bias check procedure was repeated for the CO₂ analyzer. This procedure was also used for the CO analyzer although not required by EPA Method 10.

As shown in Figure 1, a 1-inch diameter stainless steel probe was inserted into the sample port of the stack. The gas sample was continuously pulled through the probe and transported via a 100-foot long, $\frac{3}{8}$ -inch diameter heat-traced Teflon® line into the mobile laboratory using a stainless steel/Teflon® diaphragm pump. At the pump exit the pressurized sample was pushed into a heated sample manifold. The bulk of the gas stream then passed into a stainless steel minimum contact condenser to dry the sample stream and into the (dry) sample manifold. From the manifold, the sample was partitioned to the analyzers through glass and stainless steel rotameters for flow control of the sample.

Instrumental monitors were housed in an air-conditioned trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e., NO_x calibration gases).

EPA Method 1 was used to determine the velocity traverse point locations. Prior to conducting the tests, a cyclonic flow check was conducted. No significant cyclonic flow was encountered. The stack met the minimum criteria set forth in the method. Pitot tube measurements were made at eight (8) separate traverse points in each stack cross section for a total of sixteen (16) traverse points. The location of the sample ports and the pitot tube traverse point distances for the scrubber stack are denoted in the "Circular Stack Sampling Traverse Point Layout" data sheet, see Appendix A.

EPA Method 2 was used for determination of stack gas velocity during each run. A pitot tube and inclined gauge oil manometer were used to measure the differential pressure at each traverse point. The stack temperature was determined with a K-type thermocouple and digital thermometer.

The stack gas analyses for CO₂ and O₂ concentrations were performed in accordance with procedures set forth in EPA Method 3a. Instrumental analyses were used in lieu of an Orsat or Fyrite procedure due to the greater accuracy and precision provided by the instruments. The CO₂ analyzer was based on the principle of infrared absorption. The O₂ analyzer operated using a paramagnetic detector.

EPA Method 4 was used to measure the moisture content of the stack gas. A chilled water impingement system was used in conjunction with a calibrated dry gas meter to pull a sample greater than 21 scf coincident with each test run. A K-type (chromel-alumel) thermocouple was used in conjunction with a digital thermometer to determine the exit temperatures in the chilled water impingement sampling train. This parameter is measured to ensure that the gas stream is cooled to a minimum of 68 degrees Fahrenheit as required by sampling methodology. Determination of the moisture content was necessary to determine stack gas molecular weights and volumetric flow rates.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous non-dispersive infrared (NDIR) analyzer was used for this purpose. This reference method analyzer was equipped with a gas correlation filter that removes most interference from moisture, CO₂, and other combustion products.

All data from the continuous monitoring instruments were logged into a computer file in 1-minute intervals and rolling 1-minute averages. A data logging system with a computer generated display screen monitored, recorded and averaged the emission concentrations. The program controlling the logging of data was also

used to log QA data. See Appendix F of this report for copies of the raw data and Appendix D for the QA data.

Cubix personnel collected ambient absolute pressure, temperature and humidity data. A wet/dry bulb sling psychrometer was used to determine ambient temperature and humidity conditions. An aircraft-type aneroid barometer (altimeter) was used to measure absolute atmospheric pressure.


Emission calculations were conducted by a computer spreadsheet as shown in Table 2 of this report. Example calculations were performed manually using a hand-held calculator in order to verify the formulas used in the spreadsheet. Example calculations are in Appendix B of this report.

TABLE 3
ANALYTICAL INSTRUMENTATION

Parameter	Model and Manufacturer	Common Use Ranges	Sensitivity	Response Time (sec.)	Detection Principle
CO	TECO Model 48C	0-1 ppm 0-10 ppm 0-30 ppm 0-50, 0-100 ppm 0-200 ppm 0-500 ppm 0-1000 ppm	0.1 ppm	60	Infrared absorption, gas filter correlation detector, micro-processor based linearization.
CO ₂	Servomex 1400	0-5% 0-10% 0-15%	0.025% 0.05% 0.075%	< 10	Non-dispersive infrared absorption, electronic linearization of a logarithmic signal (Beer's Law)
O ₂	Servomex 1400	0-5% 0-10% 0-25%	0.02% 0.02% 0.02%	< 10	Paramagnetic cell detector, inherently linear.

NOTE: Higher ranges available by sample dilution.
Other ranges available via signal attenuation.

FIGURE 1
INSTRUMENTAL SAMPLE SYSTEM DIAGRAM



QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities were undertaken before, during and after this testing project. This section of the report in conjunction with the documentation in Appendix D describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via a multi-point calibration. The instrument's linearity was checked by first adjusting the instrument's zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration. For CO, O₂, and CO₂, the instrument's response was accepted as being linear if the response of the other calibration gases agreed within $\pm 2\%$ span of the predicted values. The responses of the infrared absorption type CO and CO₂ analyzers are made linear through electronic suppression.

System bias checks were performed both before and after the sampling system was used for emissions testing. The sampling system's integrity was tested by comparing the responses of the O₂ analyzer to a calibration gas (and a zero gas) introduced via two paths as previously described in the *Analytical Techniques* section of this report. This system bias test was performed to assure that no alteration of the sample had occurred during the test due to leakage, reactions, or absorption. Similarly, system bias checks were performed with CO and CO₂ for added assurance of sample system integrity. Examination of the logged QA data records and Instrumental Analysis Quality Assurance Data worksheet in Appendix D shows that the analyzer response via both sample paths agreed within $\pm 5\%$.

The residence time of the sampling and measurement system was estimated using the pump flow rate and the sampling system volume. The pump's rated flow rate is 0.8 scfm at 5 psig. The sampling system volume was approximately 0.175 scf. Therefore, the minimum sample residence time was approximately 13 seconds.

Cubix Corporation and instrument vendors conducted interference response tests on the CO, O₂, and CO₂ analyzers. The sum of the interference responses for H₂O, C₃H₈, CO, CO₂ and O₂ is less than 2 percent of the applicable full-scale span value. The instruments used for the tests meet the performance specifications for EPA Methods 3a and 10. The results of the interference tests are available in Appendix D of this report.

The sampling system was leak checked by demonstrating that it could hold a vacuum greater than 15 inches of mercury (Hg) for at least 1 minute with a decline of less than 1 inch Hg. A leak test was conducted after the sample system was set

up and before testing began and after testing was completed before the system was dismantled. This test was conducted to insure that ambient air was not diluting the sampling system. The actual vacuum was greater than 24 inches Hg during the leak tests with no leakage detected.

As a minimum, before and after each test run, the analyzers were checked for zero and span drift. This allows test runs to be bracketed by calibrations and documents the precision of the data just collected. Calibration gases were introduced to the analyzers through the entire sampling system. Based on the applicable test method, the criterion for acceptable data is that each instrument drifts no more than $\pm 3\%$ of the full-scale response. Appendix D contains quality assurance tables and logged QA calibration records that summarize the zero and span checks that were performed for each test run. The worksheets also contain the data used to correct the data for drift per EPA Method 6c, Equation 6c-1. O_2 and CO_2 emissions data were corrected for drift as required by the test methods. CO emissions data was also corrected for drift to provide more accurate results and consistent quality assurance procedures.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to $\pm 1\%$ accuracy for each calibration gas. EPA Protocol No. 1 was used, where applicable (i.e., NO_x gases), to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix E.

The pitot tube tips used during the testing were visually inspected to insure that they met the criteria of EPA Method 2. The pitot tube lines were leak checked in the field in accordance with EPA Method 2 guidelines each time connection to the oil manometer was made.

The working dry gas meter used for the moisture train was calibrated prior to testing in accordance with EPA Method 4. A laboratory grade dry gas meter calibrated against a NIST reference instrument, a bell prover, was used for this calibration. Calibration certification documentation of the working meter can be found in Appendix E.

Appendix E also contains calibration data on ancillary measurement equipment used during this testing. The altimeter/barometer was used for determination of atmospheric pressure. Thermometers and thermocouples were used to determine stack gas temperatures and moisture train temperatures.

Cubix collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Cubix makes no warranty as to the suitability of the test methods. Cubix assumes no liability relating to the interpretation and use of the test data by others.

**APPENDIX A:
FIELD DATA SHEETS**

Cubix Corporation

Air Emission Testing Job Safety Analysis

Date: October 27th and 28th, 2002
 Mobile Lab/Cubix Crew: T-13/LJB, RPO, DLD, and JTH
 Client: Georgia-Pacific Corporation
 Job #/Contact: 7382-FL1/Joe Taylor
 Plant Name: Georgia-Pacific Palatka Operations
 Unit Name(s): Bleach Pplant Scrubber
 Location (city/state): Palatka, Florida

Description of Testing Activities:

Set-up on 10/27/02. Tested wet scrubber outlet stack at the Bleach Plant on 10/28/02.

Permits Required Hot Work <input type="checkbox"/> Check Cold Work <input type="checkbox"/> Check Lock & Tag <input type="checkbox"/> Check Scaffolding <input type="checkbox"/> Check Crane/Lift <input type="checkbox"/> Check Line Break <input type="checkbox"/> Check	Comments No permits required in area where we were working.	Personal Protective Equipment Required hard hat <input type="checkbox"/> Check ear plugs/muffs <input type="checkbox"/> Check safety glasses <input type="checkbox"/> Check steel toed shoes <input type="checkbox"/> Check gloves <input type="checkbox"/> Check hot gloves <input type="checkbox"/> Check acid suit <input type="checkbox"/> Check rubber boots <input type="checkbox"/> Check monogoggles <input type="checkbox"/> Check face shield <input type="checkbox"/> Check safety harness <input type="checkbox"/> Check respirator <input type="checkbox"/> Check
Emergency Response Safe Haven: Upwind Wind Direction: East Evacuation Route: Upwind Assembly Points: Down the road Plant Map Reviewed: Not Applicable	(Control room? Plant office? N NE E SE S SW W NW from gate? Back gate? Crosswind? office? Down the road? Yes or No or Not Applicable	Phone No's. & Alarm Knowledge (list type of sound) Plant Contact Ph.: 386-329-0027 Control Room Ph.: Emergency Ph.: 911 Other: Evacuate: Fire: All Clear: Poison Gas: yes <i>If facility has no alarms, verify communication with control room</i>
Emergency Equipment Locations Identified Emergency Shut Off <input type="checkbox"/> Located <input type="checkbox"/> Not Applicable Fire Extinguisher <input type="checkbox"/> Located <input type="checkbox"/> Not Applicable Safety Showers <input type="checkbox"/> Located <input type="checkbox"/> Not Applicable Escape Air Pack <input type="checkbox"/> Located <input type="checkbox"/> Not Applicable		manual emergency trip Cubix Mobile Lab & Plant Ext. required for plant? required for plant?
JOB HAZARD IDENTIFIED		PRECAUTIONS TO BE IMPLEMENTED
Hazardous Material (in plant area) (flammability, reactivity, health hazards)	List Hazmat?? ClO2.	Cubix MSDS in Mobile Lab <input type="checkbox"/> Yes <input type="checkbox"/> No Plant MSDS reviewed??? <input type="checkbox"/> Yes <input type="checkbox"/> Not Available
Environmental Hazards airborne particulate <input type="checkbox"/> Present <input type="checkbox"/> No Hazard burn hazard <input type="checkbox"/> Present <input type="checkbox"/> No Hazard rain / fog <input type="checkbox"/> Present <input type="checkbox"/> No Hazard electrical shock <input type="checkbox"/> Present <input type="checkbox"/> No Hazard heat stress <input type="checkbox"/> Present <input type="checkbox"/> No Hazard cold weather/frostbite <input type="checkbox"/> Present <input type="checkbox"/> No Hazard inadequate lighting <input type="checkbox"/> Present <input type="checkbox"/> No Hazard noise <input type="checkbox"/> Present <input type="checkbox"/> No Hazard poor access/egress <input type="checkbox"/> Present <input type="checkbox"/> No Hazard		Protective Equipment respirator <input type="checkbox"/> Check work gloves <input type="checkbox"/> Check rain protect elect. equip. <input type="checkbox"/> Check inspect extension cords <input type="checkbox"/> Check hot gloves <input type="checkbox"/> Check cold weather clothing <input type="checkbox"/> Check flash light/head lamp <input type="checkbox"/> Check hearing protection <input type="checkbox"/> Check housekeeping <input type="checkbox"/> Check
Chemical Hazards (check hazards that are present at jobsite) asfixiation <input type="checkbox"/> Check poison gas <input type="checkbox"/> Check chemical eye exposure <input type="checkbox"/> Check flammable gas <input type="checkbox"/> Check strong acid <input type="checkbox"/> Check OTHER <input type="checkbox"/> Check		Protective Actions OTHER <input type="checkbox"/> Check shade/cool breaks <input type="checkbox"/> Check rain gear <input type="checkbox"/> Check secure/protect ext.cords <input type="checkbox"/> Check warm up breaks <input type="checkbox"/> Check liquid intake <input type="checkbox"/> Check night lighting <input type="checkbox"/> Check hard hat liner <input type="checkbox"/> Check alternate route <input type="checkbox"/> Check
Equipment Lifting & Fall Hazard test equipment hoisting (pulley/boom) <input type="checkbox"/> Required <input type="checkbox"/> Not Applicable portable ladder <input type="checkbox"/> Required <input type="checkbox"/> Not Applicable man lift (cherry picker) <input type="checkbox"/> Required <input type="checkbox"/> Not Applicable personnel basket (crane) <input type="checkbox"/> Required <input type="checkbox"/> Not Applicable Plant Stairs & Ladders <input type="checkbox"/> Required <input type="checkbox"/> Not Applicable rigging sample lines, umbilic scaffold <input type="checkbox"/> Required <input type="checkbox"/> Not Applicable		Respiratory Safety Equip supplied fresh air <input type="checkbox"/> Check SCBA <input type="checkbox"/> Check respirator (correct type?) <input type="checkbox"/> Check escape pack <input type="checkbox"/> Check exposure dosimeter <input type="checkbox"/> Check OTHER <input type="checkbox"/> Check
Inspections and Protective Actions equipment secure <input type="checkbox"/> Check operator certification <input type="checkbox"/> Check guy lines <input type="checkbox"/> Check radios/handsignals <input type="checkbox"/> Check housekeeping <input type="checkbox"/> Check lines secure <input type="checkbox"/> Check secure tools <input type="checkbox"/> Check		Protective Clothing fire suit <input type="checkbox"/> Check acid suit <input type="checkbox"/> Check rubber boots <input type="checkbox"/> Check monogoggles <input type="checkbox"/> Check face shield <input type="checkbox"/> Check OTHER <input type="checkbox"/> Check


Circular Stack Sampling Traverse Point Layout (EPA Method 1, Velocity Measurement Traverse Points)

Date: October 27th, 2002
 Client: Georgia-Pacific Corporation
 Plant: G-P Palatka Operations
 Source: Bleach Plant Scrubber
 Technician(s): RPO, JTH


Port + Stack ID (in): 51.25
 Port Extension (in): 9.50
 Stack ID (in): 41.75
 Stack Area (ft²): 9.507
 Duct Diameters **upstream** from flow disturbance (A): > 2
 Duct Diameters **downstream** from flow disturbance (B): > 8
 Total Required Traverse Points: 16
 No. of Traverse Points per Diameter: 8

Stack Diagram

(Draw side view showing major components, dimensions, upstream downstream flow disturbances)





Cross Section



Unit Information

Bleach Plant Scrubber
 Wet scrubber that uses an alkaline solution.

Traverse Point Number	Number of Traverse Points on a Diameter				*Calculated Traverse Point	*Traverse Point with Port Extension
	4	6	8	12		
1	6.7	4.4	3.2	2.1	1.34	10.84
2	25.0	14.6	10.5	6.7	4.38	13.88
3	75.0	29.6	19.4	11.8	8.10	17.60
4	93.3	70.4	32.3	17.7	13.49	22.99
5		85.4	67.7	25.0	28.26	37.76
6		95.6	80.6	35.6	33.65	43.15
7			89.5	64.4	37.37	46.87
8			96.8	75.0	40.41	49.91
9				82.3		
10				88.2		
11				93.3		
12				97.9		



*Stack diameters > 24 in shall have no traverse points located within 1-inch of the stack wall
 *Stack diameters ≤ 24 in shall have no traverse points located within 0.5-inch of the stack wall

EPA Methods 1 through 4: Velocity, Moisture Content, Molecular Weight, and Volumetric Flow Rates

Test Run No.	Run 1	Run 2	Run 3
Date	10/28/02	10/28/02	10/28/02
Start Time (Moisture Run Times)	09:42	11:33	13:24
Stop Time (Moisture Run Times)	10:27	12:14	14:05
Stack Moisture & Molecular Wt. via EPA Methods 3a & 4			
O ₂ (% volume, dry basis)	20.76	20.67	20.69
CO ₂ (% volume, dry basis)	1.04	1.22	1.03
Beginning Meter Reading (ft ³)	675.970	703.905	739.319
Ending Meter Reading (ft ³)	703.495	726.224	762.465
Beginning Impingers Weight (g)	2235.2	2262.1	2285.0
Ending Impingers Weight (g)	2262.1	2285.0	2316.9
Dry Gas Meter Factor (K _d)	0.9869	0.9869	0.9869
Dry Gas Meter Temperature (°F begin)	96	84	88
Dry Gas Meter Temperature (°F end)	90.6	90	95
Atmospheric Pressure ("Hg, absolute)	29.98	29.96	29.91
Volume of Water Vapor Collected (SCF)	1.268	1.080	1.504
Volume of Air Metered (SCF)	25.964	21.281	21.851
Stack Gas Moisture (% volume)	4.66	4.83	4.50
Dry Gas Fraction	0.9534	0.9517	0.9550
Stack Gas Molecular Wt. (lbs/lb-mole)	28.48	28.49	28.50
Stack Flow Rate via Pitot Tube			
ΔP #1	0.13	0.14	0.18
ΔP #2	0.18	0.19	0.19
ΔP #3	0.22	0.23	0.22
ΔP #4	0.20	0.25	0.22
ΔP #5	0.24	0.27	0.23
ΔP #6	0.24	0.24	0.23
ΔP #7	0.18	0.24	0.25
ΔP #8	0.18	0.22	0.25
ΔP #9	0.18	0.17	0.19
ΔP #10	0.20	0.19	0.22
ΔP #11	0.21	0.23	0.23
ΔP #12	0.22	0.22	0.25
ΔP #13	0.19	0.19	0.21
ΔP #14	0.20	0.23	0.22
ΔP #15	0.18	0.22	0.21
ΔP #16	0.16	0.22	0.23
Pitot Tube Factor	0.84	0.84	0.84
Sum of Square Root of ΔP's	7.0355	7.4085	7.5071
Number of Traverse Points	16	16	16
Average Square Root of ΔP's	0.439721	0.463030	0.469191
Average Temperature (°F)	126.8	130.9	130.8
Static Pressure ("H ₂ O)	-0.28	-0.14	-0.18
Stack Diameter (inches)	41.75	41.75	41.75
Stack Area (ft ²)	9.507	9.507	9.507
Stack Velocity (ft/min)	1571	1660	1683
Stack Flow, wet (ACFM)	14936	15783	16005
Average Stack Flow, dry (SCFH)	7.70E+05	8.06E+05	8.19E+05

MOISTURE & VELOCITY FIELD DATA SHEET

Date: 10-28-02
 Plant: G-P Poltke Plant
 Source: Chlorine Plant Scrubber
 Technicians: KPO, JTH
 Atm. Pressure: 29.98 "Hg (Ph)
 Test Run No.: Run 1

Dry Gas Meter ID: T-10 EQUIVIMETER
 Dry Gas Meter Factor: 0.9869 (Kd)
 Pitot Tube No/Type: #2110 .7' x 3/8" ID SS STAFF
 Pitot Tube Factor: 0.84
 Static Pressure: - .28 "H₂O (P_g)
 Ave. Stack Temp: 126.8 °F (Ts)

Collection Data

Sample Box	/	
Leak Check ≤ 0.02 ft ³ /min		
Pre-Test	0.000 ft ³ /min	
Leak Check	24.2 "Hg Vac.	
Post-Test	0.000 ft ³ /min	
Leak Check	25.0 "Hg Vac.	
	Initial	Final
Time	9:42	10:27
DGM Reading	675.970	703.495
(ft ³ or L)		
DGM Average	96	90.6
Temp (°F)		
Last Impinger	66	62.4
Temp. (°F)		
DGM Flow Rate	40	48
O ₂ (% vol.)	X	
CO ₂ (% vol.)	X	

Impingement System

Impinger	Contents	Initial Weight	Final Weight
1	D ₂ H ₂ O	545.7	565.0
2	D ₂ H ₂ O	557.5	559.8
3	Empty	485.9	486.5
4	Siccell	646.1	650.8
5			
6			
Totals		2235.2	2262.1

Velocity Traverse Data with Stack Temperature and Cyclonic Flow Check

Point	ΔP ("H ₂ O)	°F	α	Point	ΔP ("H ₂ O)	°F	α
1-1	.13	125	5	2-1	.18	122	10
1-2	.18	125	10	2-2	.26	123	10
1-3	.22	125	10	2-3	.21	127	7
1-4	.20	126	5	2-4	.22	128	5
1-5	.24	126	6	2-5	.19	130	6
1-6	.24	126	8	2-6	.20	130	6
1-7	.18	126	8	2-7	.18	132	8
1-8	.18	126	10	2-8	.16	132	10
X							
X							
X							
X							
X							
X							
X							

Velocity System Leak Check

Leak Check ≤ 0.1 "H ₂ O/min at a pressure ≥ 3.0 "H ₂ O		
Pre-Test	0.0 0.0 "H ₂ O/min	
Leak Check	3.6 4.6 "H ₂ O Pres.	
Post-Test	0.0 0.0 "H ₂ O/min	
Leak Check	4.2 4.1 "H ₂ O Pres.	

MOISTURE & VELOCITY FIELD DATA SHEET

Date: 10-28-2002
 Plant: G-P PRATKA PLANT
 Source: Chlorine Plant Scrubbers
 Technicians: RPO, JTH
 Atm. Pressure: 29.96 " Hg (Pb)
 Test Run No.: RUN 2

Dry Gas Meter ID: T-10 EQUIPMENT
 Dry Gas Meter Factor: 0.9869 (Kd)
 Pitot Tube No./Type: #2110 7 1/2" OD SS-147F
 Pitot Tube Factor: 0.84
 Static Pressure: -.14 "H₂O (Pg)
 Ave. Stack Temp: 130.9 °F (Ts)

Collection Data

Sample Box	/	
Leak Check ≤ 0.02 ft ³ /min		
Pre-Test	0.000	ft ³ /min
Leak Check	22.5	"Hg Vac.
Post-Test	0.000	ft ³ /min
Leak Check	23.0	"Hg Vac.
	Initial	Final
Time	11:33	12:14
DGM Reading	703.905	726.224
(ft ³ or L)		
DGM Average	84	90
Temp (°F)		
Last Impinger	67	58
Temp. (°F)		
DGM Flow Rate	40	40
O ₂ (% vol.)	 	
CO ₂ (% vol.)	 	

Impingment System

Impinger	Contents	Initial Weight	Final Weight
1	D, H ₂ O	565.0	582.6
2	D, H ₂ O	559.8	561.7
3	MT	486.5	486.8
4	SiGel	650.8	653.9
5			
6			
Totals		2262.1	2285.0

Velocity Traverse Data

with Stack Temperature and Cyclonic Flow Check

Point	ΔP ("H ₂ O)	°F	α	Point	ΔP ("H ₂ O)	°F	α
1-1	.14	129		2-1	.17	133	
1-2	.19	129		2-2	.19	133	
1-3	.23	131		2-3	.23	133	
1-4	.25	132		2-4	.22	133	
1-5	.27	133		2-5	.19	131	
1-6	.24	134		2-6	.23	130	
1-7	.24	134		2-7	.22	125	
1-8	.22	133	✓	2-8	.22	121	✓
 							
 							
 							
 							
 							
 							
 							

Velocity System Leak Check

Leak Check ≤ 0.1 "H ₂ O/min at a pressure ≥ 3.0 "H ₂ O		
Pre-Test	+	-
Leak Check	0.0	0.0
	"H ₂ O/min	
	3.6	4.6
	"H ₂ O Pres.	
Post-Test	+	-
Leak Check	0.0	0.0
	"H ₂ O/min	
	4.2	4.1
	"H ₂ O Pres.	

MOISTURE & VELOCITY FIELD DATA SHEET

Date: 10-28-2002
 Plant: G-P PLATKA PLANT
 Source: Chlorine Plant Scrubber
 Technicians: RPO, JTH
 Atm. Pressure: 29.91 " Hg (Pb)
 Test Run No.: RUN 3

Dry Gas Meter ID: T-10 EQUIMETER
 Dry Gas Meter Factor: 0.9869 (Kd)
 Pitot Tube No/Type: #2110 7' x 3/8" OD SS S-TAPE
 Pitot Tube Factor: 0.84
 Static Pressure: .1 - .18 "H₂O (P_s)
 Ave. Stack Temp. 130.8 °F (T_s)

Collection Data

Sample Box	<u>1</u>	
Leak Check	≤ 0.02 ft ³ /min	
Pre-Test	<u>0.000</u>	ft ³ /min
Leak Check	<u>25.0</u>	"Hg Vac.
Post-Test	<u>0.000</u>	ft ³ /min
Leak Check	<u>25.5</u>	"Hg Vac.
	Initial	Final
Time	<u>13:24</u>	<u>14:05</u>
DGM Reading	<u>739.319</u>	<u>762.465</u>
(ft ³ or L)		
DGM Average	<u>88</u>	<u>95</u>
Temp (°F)		
Last Impinger	<u>66</u>	<u>64</u>
Temp. (°F)		
DGM Flow Rate	<u>40</u>	<u>40</u>
O ₂ (% vol.)	X	
CO ₂ (% vol.)	X	

Impingement System

Impinger	Contents	Initial Weight	Final Weight
1	<u>D:H₂O</u>	582.6	<u>605.0</u>
2	<u>D:H₂O</u>	<u>561.7</u>	<u>565.6</u>
3	<u>MT</u>	<u>486.8</u>	<u>487.7</u>
4	<u>SIGEL</u>	<u>653.9</u>	<u>658.6</u>
5			
6			
Totals		<u>2285</u>	<u>2316.9</u>

Velocity Traverse Data with Stack Temperature and Cyclonic Flow Check

Point	ΔP ("H ₂ O)	°F	α	Point	ΔP ("H ₂ O)	°F	α
1-1	<u>.18</u>	<u>129</u>		2-1	<u>.19</u>	<u>130</u>	
1-2	<u>.19</u>	<u>129</u>		2-2	<u>.22</u>	<u>130</u>	
1-3	<u>.22</u>	<u>131</u>		2-3	<u>.23</u>	<u>131</u>	
1-4	<u>.22</u>	<u>131</u>		2-4	<u>.25</u>	<u>132</u>	
1-5	<u>.23</u>	<u>131</u>		2-5	<u>.21</u>	<u>131</u>	
1-6	<u>.23</u>	<u>132</u>		2-6	<u>.22</u>	<u>131</u>	
1-7	<u>.25</u>	<u>131</u>		2-7	<u>.21</u>	<u>131</u>	
1-8	.23 <u>.25</u>	<u>131</u>	✓	2-8	<u>.23</u>	<u>131</u>	✓
X							

Velocity System Leak Check

Leak Check ≤ 0.1 "H ₂ O/min at a pressure ≥ 3.0 "H ₂ O		
Pre-Test	<u>0.0</u>	<u>0.0</u> "H ₂ O/min
Leak Check	<u>3.6</u>	<u>4.6</u> "H ₂ O Pres.
Post-Test	<u>0.0</u>	<u>0.0</u> "H ₂ O/min
Leak Check	<u>4.2</u>	<u>4.1</u> "H ₂ O Pres.

**APPENDIX B:
EXAMPLE CALCULATIONS**

EXAMPLE CALCULATIONS

Moisture Content via EPA Method 4

refers to Test Run # 1

M_{WC}	= net impinger weight gain = 2262.1 g - 2235.2 g	= 26.9 g
Y	= dry gas meter correction factor	= 0.9869
V_m	= volume metered = (703.495 - 675.970)	= 27.525 ft ³
P_{atm}	= atmospheric pressure	= 29.98 "Hg
P_{met}	= average meter pressure = P_{atm}	= 29.98 "Hg
T_{met}	= average meter temperature = 93.3° F + 460 °F	= 553.3° R
K_2	= conversion factor, water weight to vapor	= 0.04715 ft ³ /g
K_3	= standard temp, pressure (STP) correction factor	= 17.64° R/ "Hg

$$\begin{aligned}V_{WC} &= \text{total volume of water vapor collected at STP} \\ &= K_2 \times M_{WC} \\ &= (0.04715 \times 26.9) \\ &= 1.2683 \text{ ft}^3\end{aligned}$$

$$\begin{aligned}V_{m(std)} &= \text{total volume metered at STP} \\ &= K_3 \times Y \times V_m \times \frac{P_{met}}{T_{met}} \\ &= 17.64 \times 0.9869 \times 27.525 \times \frac{29.98}{553.3} \\ &= 25.964 \text{ ft}^3\end{aligned}$$

$$\begin{aligned}B_{ws} &= \text{moisture content by EPA Method 4} \\ &= \frac{V_{WC}}{V_{WC} + V_{STP}} \\ &= \frac{1.2683}{1.2683 + 25.964}\end{aligned}$$

$$\begin{aligned}B_{ws} &= 0.04657 \\ &= 4.66 \% \text{ moisture}\end{aligned}$$

Stack Gas Molecular Weight

Refers to Test Run # 1

MW_{H_2O}	= molecular wt of H_2O	= 18 lb/lb-mole
MW_{CO_2}	= molecular wt of CO_2	= 44 lb/lb-mole
MW_{O_2}	= molecular wt of O_2	= 32 lb/lb-mole
MW_{N_2}	= molecular wt of N_2	= 28 lb/lb-mole
C_{CO_2}	= concentration of CO_2	= 0.0104 (from analyzer)
C_{O_2}	= concentration of O_2	= 0.2076 (from analyzer)
C_{N_2}	= concentration of N_2	= $1 - (C_{CO_2} + C_{O_2}) = 0.782$
F_d	= dry gas fraction = $1 - B_{ws}$	= 0.95343

$$\begin{aligned} MW &= \text{molecular weight of stack gas (lb/lb-mole)} \\ &= \text{wt. of } H_2O + \text{wt. of } CO_2 + \text{wt. of } O_2 + \text{wt. of } N_2 \\ &= (MW_{H_2O} \times B_{ws}) + (F_d \times ((MW_{CO_2} \times C_{CO_2}) + (MW_{O_2} \times C_{O_2}) \\ &\quad + (MW_{N_2} \times C_{N_2}))) \\ &= (18 \times 0.04657) + (0.95343 \times ((44 \times 0.0104) + (32 \times 0.2076) \\ &\quad + (28 \times 0.782))) \end{aligned}$$

$$MW = 28.48(4) \text{ lb/lb-mole}$$

Stack Gas Flow Rate via Pitot Tube, Q_d

Refers to Test Run # 1

$$\begin{aligned}
 C_p &= \text{pitot tube coefficient} &= 0.84 \\
 \Delta P &= \text{pressure difference in stack as measured (in. H}_2\text{O)} \\
 \sqrt{\Delta P_{av}} &= \text{average of square root of } \Delta P\text{'s} &= 0.439721 \\
 T_s &= \text{ave. stack temperature} = 126.8^\circ \text{ F} + 460 &= 586.8^\circ \text{ R} \\
 P_{atm} &= \text{site corrected atmospheric pressure} &= 29.98 \text{ "Hg} \\
 P_g &= \text{stack static pressure (in. H}_2\text{O)} &= -0.28 \text{ "H}_2\text{O} \\
 P_s &= \text{absolute stack pressure} \\
 &= P_{atm} + (P_g/13.6) &= 29.959 \text{ "Hg}
 \end{aligned}$$

$$\begin{aligned}
 K_p &= \text{pitot tube constant} &= 85.49 \frac{\text{ft}}{\text{sec}} \left(\frac{(\text{lb/lb-mole})(\text{in.Hg})}{(^{\circ}\text{R})(\text{in.H}_2\text{O})} \right)^{\frac{1}{2}} \\
 T_{std} &= \text{absolute Temperature} &= 528^\circ \text{ R} \\
 P_{std} &= \text{standard atmospheric pressure} &= 29.92 \text{ "Hg}
 \end{aligned}$$

$$V_s = \text{stack velocity (ft/sec)}$$

$$\begin{aligned}
 &= K_p \times C_p \times \sqrt{\Delta P_{av}} \times \sqrt{\frac{T_s}{(P_s \times MW)}} \\
 &= 85.49 \times 0.84 \times 0.439721 \times \sqrt{\frac{586.8}{(29.959 \times 28.484)}} \\
 &= 26.185 \text{ ft/sec} \times 60 \text{ sec/min}
 \end{aligned}$$

$$V_s = 1571.1 \text{ ft/min}$$

$$Q_a = \text{stack flow rate (ft}^3\text{/min, actual)}$$

$$= V \times A, \text{ where } A = \text{area of stack} = 9.507 \text{ ft}^2$$

$$Q_a = 1571.1 \times 9.507 = 14936.4 \text{ ft}^3\text{/min}$$

$$Q_d = \text{average stack flow rate on a dry basis at standard conditions (DSCFH)}$$

$$\begin{aligned}
 &= \frac{Q_a \times T_{std} \times P_s}{T_s \times P_{std}} \times F_d \times 60 \\
 &= \frac{14936.4 \times 528 \times 29.959}{586.8 \times 29.92} \times 0.95343 \times 60
 \end{aligned}$$

$$Q_d = 7.698 \times 10^5 \text{ DSCFH, Average Flow}$$

Correction of O₂ Gas Concentrations, CO₂

Refers to Test Run # 1

Analytical instruments tend to drift in their calibrations over time and with changes in atmospheric conditions. Span and zero gas bias drift checks (calibrations) were conducted prior to and following each test. The results of these calibrations were used to bracket and thus correct the raw gas concentrations into corrected (more accurate) gas concentrations. The calculation used for these correction is 40 CFR 60, Appendix A, Method 6c, Equation 6c-1. This correction is required for CO₂ exhaust concentrations when using Method 3a. Cubix also conducts this correction for EPA Method 10 in order to present more accurate and consistent test results.

U_{O₂} = analyzer O₂ gas concentration, uncorrected for drift and bias

U_{O₂} = 20.52 ppmv, uncorrected

C₀ = Average of initial/final zero gas concentrations

= -0.04 ppmv

C_m = Average of initial/final span gas concentrations

= 11.785 ppmv

C_{ma} = Actual upscale cylinder span gas concentrations

= 11.94 ppmv

C_{O₂} = Effluent O₂ gas concentration, ppmv corrected

$$= (U_{O_2} - C_0) \times \frac{C_{ma}}{C_m - C_0}$$

$$= (20.52 + 0.04) \times \frac{11.94}{11.785 + 0.04}$$

C_{O₂} = 20.76 ppmv O₂, dry basis corrected

CO Mass Emission Rate (lbs/hr)

Refers to Test Run # 1

C_{CO} = observed concentration of CO = 955.3 ppmv

MW_{CO} = 28.01 lb/lb-mole for carbon monoxide
for ideal gas, 385.15 SCF = 1.0 lb/mole

Q_d = 7.698×10^5 SCFH (from ave. pitot tube volumetric flow)

E_{CO} = mass emission rate of CO in (lb/hr)

$$= C_{CO} \times 10^{-6} \times Q_d \times \frac{MW_{CO}}{385.15}$$

$$= 955.3 \times 10^{-6} \times 7.698 \times 10^5 \times \frac{28.01}{385.15}$$

E_{CO} = 53.5 lbs/hr

**APPENDIX C:
OPERATIONAL DATA**

PRODUCTION RATE DATA

RUN	DATE	TIME	SPECIES	PRODUCTION RATE, adtbph	#ClO2/adtbp
1	10/28/02	0934-1034	softwood	49.7	45.8
2	10/28/02	1127-1227	softwood	49.7	46.8
3	10/28/02	1317-1417	softwood	35.0	49.9

Please note that the Chemical Application Rate is considered
Confidential Business Information

**APPENDIX D:
QUALITY ASSURANCE ACTIVITIES**

Quality Assurance Activities
Calibration Error, Bias, and Drift Checks

Linearity Check	CO	O ₂	CO ₂
Analyzer Range (ppmv), O ₂ & CO ₂ in % vol	1250.0	25.00	15.00
Strip Chart Offset	0.0	10.0	2.0
Low Level Certified Value (ppm or % vol)	253.0	4.53	4.48
Mid Level Certified Value (ppm or % vol)	441.0	11.94	7.99
High Level Certified Value (ppm or % vol)	885.0	20.90	12.62
Zero Target (% Chart)	0.0	10.0	2.0
Low Level Target (% Chart)	20.2	28.1	31.9
Mid Level Target (% Chart)	35.3	57.8	55.3
High Level Target (% Chart)	70.8	93.6	86.1
Zero Observed (% Chart)	0.0	10.0	2.0
Low Level Observed (% Chart)	19.6	28.0	32.1
Mid Level Observed (% Chart)	34.5	57.8	55.5
High Level Observed (% Chart)	71.2	93.6	86.1
Zero Observed (ppm or % vol)	0.33	0.00	0.00
Low Level Observed (ppm or % vol)	244.64	4.50	4.52
Mid Level Observed (ppm or % vol)	430.65	11.95	8.02
High Level Observed (ppm or % vol)	889.46	20.90	12.62
% Difference From Zero to Target	0.0	0.0	0.0
% Difference From Low to Target	0.7	0.1	-0.3
% Difference From Mid to Target	0.8	0.0	-0.2
% Difference From High to Target	-0.4	0.0	0.0
EPA Allowable % Difference from Target	±2% Span	±2% Span	±2% Span
Test Run 1	CO	O ₂	CO ₂
Analyzer Range (ppm), O ₂ & CO ₂ in %	1250.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	885	11.94	7.99
Strip Chart Offset	0.0	10.0	2.0
Target Calibration Gas (Chart %)	70.8	57.8	55.3
Actual Zero Gas from Direct (Chart %)	0.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	71.2	57.8	55.5
Initial Readings			
Zero Gas (chart %)	-0.2	9.9	2.4
Calibration Gas (chart %)	71.0	57.1	54.9
Zero Gas (ppmv)	-2.97	-0.03	0.06
Calibration Gas (ppmv)	887.15	11.77	7.94
Final Readings			
Zero Gas (chart %)	-0.2	9.8	2.3
Calibration Gas (chart %)	71.1	57.2	55.2
Zero Gas (ppmv)	-2.97	-0.05	0.04
Calibration Gas (ppmv)	888.80	11.80	7.98
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	-0.3	-0.2	0.3
Calibration Bias (% Chart) ≤5%	-0.1	-0.6	-0.3
Zero Drift (Chart %) (Run-Run) ≤3%	0.0	0.1	0.1
Calibration Drift (Chart %) ≤3%	-0.1	-0.1	-0.3
Run Results			
Raw Results (chart %)	76.7	92.1	9.2
Raw Results (ppmv or % vol)	958.7	20.52	1.08
Corrected Results (ppmv or % vol) from % chart	955.3	20.76	1.04

Quality Assurance Activities
Calibration Error, Bias, and Drift Checks

Test Run 2	CO	O ₂	CO ₂
Analyzer Range (ppm), O ₂ & CO ₂ in %	1250.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	885	20.90	4.48
Strip Chart Offset	0.0	10.0	2.0
Target Calibration Gas (Chart %)	70.8	93.6	31.9
Actual Zero Gas from Direct (Chart %)	0.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	71.2	93.6	32.1
Initial Readings			
Zero Gas (chart %)	-0.2	9.8	2.3
Calibration Gas (chart %)	71.1	92.8	32.0
Zero Gas (ppmv)	-2.97	-0.05	0.04
Calibration Gas (ppmv)	888.80	20.70	4.50
Final Readings			
Zero Gas (chart %)	-0.1	9.9	2.4
Calibration Gas (chart %)	71.4	92.5	31.9
Zero Gas (ppmv)	-1.40	-0.03	0.06
Calibration Gas (ppmv)	893.00	20.62	4.48
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	-0.1	-0.1	0.4
Calibration Bias (% Chart) ≤5%	0.3	-1.1	-0.3
Zero Drift (Chart %) (Run-Run) ≤3%	-0.1	-0.1	-0.1
Calibration Drift (Chart %) ≤3%	-0.3	0.3	0.1
Run Results			
Raw Results (chart %)	87.3	91.7	10.4
Raw Results (ppmv or % vol)	1091.3	20.43	1.26
Corrected Results (ppmv or % vol) from % chart	1083.6	20.67	1.22
Test Run 3	CO	O ₂	CO ₂
Analyzer Range (ppm), O ₂ & CO ₂ in %	1250.0	25.00	15.00
Calibration Gas Certified Value (ppm or %)	885	20.90	4.48
Strip Chart Offset	0.0	10.0	2.0
Target Calibration Gas (Chart %)	70.8	93.6	31.9
Actual Zero Gas from Direct (Chart %)	0.0	10.0	2.0
Actual Calibration Gas from Direct (Chart %)	71.2	93.6	32.1
Initial Readings			
Zero Gas (chart %)	-0.1	9.9	2.4
Calibration Gas (chart %)	71.4	92.5	31.9
Zero Gas (ppmv)	-1.40	-0.03	0.06
Calibration Gas (ppmv)	893.00	20.62	4.48
Final Readings			
Zero Gas (chart %)	-0.1	9.9	2.3
Calibration Gas (chart %)	69.8	92.2	31.9
Zero Gas (ppmv)	-1.40	-0.03	0.04
Calibration Gas (ppmv)	873.00	20.55	4.48
Bias and Drift Calculations			
Zero Bias (% Chart) (Run-Direct Cal) ≤5%	-0.1	-0.1	0.3
Calibration Bias (% Chart) ≤5%	-1.3	-1.4	-0.3
Zero Drift (Chart %) (Run-Run) ≤3%	0.0	0.0	0.1
Calibration Drift (Chart %) ≤3%	1.6	0.3	0.0
Run Results			
Raw Results (chart %)	75.9	91.5	9.1
Raw Results (ppmv or % vol)	949.3	20.35	1.07
Corrected Results (ppmv or % vol) from % chart	951.3	20.69	1.03

Georgia-Pacific Palatka Operations, Bleach Plant Scrubber, Logged QA Calibration Records

Run 1										
10/28/02 9:34:18 10:34:18										
Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin			
CO (ppmv)	0.33	244.64	430.65	889.46	0.67	0.83	-0.36			
O2 (% vol)	0.00	4.50	20.90	11.95	0.12	0.00	-0.04			
CO2 (% vol)	0.00	4.52	12.62	8.02	-0.27	0.00	-0.20			
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift		
CO (ppmv)	-2.97	887.15	-2.97	888.80	-0.26	-0.05	0.00	-0.13		
O2 (% vol)	-0.03	11.77	-0.05	11.80	-0.20	-0.60	0.08	-0.12		
CO2 (% vol)	0.06	7.94	0.04	7.98	0.27	-0.27	0.13	-0.27		
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas				
CO (ppmv)	958.7	955.3	1250.0	253.0	441.0	885.0				
O2 (% vol)	20.52	20.76	25.00	4.53	20.90	11.94				
CO2 (% vol)	1.08	1.04	15.00	4.48	12.62	7.99				
Run 2										
10/28/02 11:27:39 12:27:39										
Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin			
CO (ppmv)	0.33	244.64	430.65	889.46	0.67	0.83	-0.36			
O2 (% vol)	0.00	4.50	11.95	20.90	0.12	-0.04	0.00			
CO2 (% vol)	0.00	8.02	12.62	4.52	-0.20	0.00	-0.27			
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift		
CO (ppmv)	-2.97	888.80	-1.40	893.00	-0.14	0.28	-0.13	-0.34		
O2 (% vol)	-0.05	20.70	-0.03	20.62	-0.12	-1.12	-0.08	0.32		
CO2 (% vol)	0.04	4.50	0.06	4.48	0.40	-0.27	-0.13	0.13		
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas				
CO (ppmv)	1091.3	1083.6	1250.0	253.0	441.0	885.0				
O2 (% vol)	20.43	20.67	25.00	4.53	11.94	20.90				
CO2 (% vol)	1.26	1.22	15.00	7.99	12.62	4.48				

Georgia-Pacific Palatka Operations, Bleach Plant Scrubber, Logged QA Calibration Records

Run 3

10/28/02 13:17:44 PM 14:17:44 PM

Initial Linearity Test	Zero	Low	Mid	Span	L-Lin	M-Lin	S-Lin		
CO (ppmv)	0.33	244.64	430.65	889.46	0.67	0.83	-0.36		
O2 (% vol)	0.00	4.50	11.95	20.90	0.12	-0.04	0.00		
CO2 (% vol)	0.00	8.02	12.62	4.52	-0.20	0.00	-0.27		
Initial and Final Bias and Drift	I-Zero	I-Span	F-Zero	F-Span	Z-Bias	S-Bias	Z-Drift	S-Drift	
CO (ppmv)	-1.40	893.00	-1.40	873.00	-0.14	-1.32	0.00	1.60	
O2 (% vol)	-0.03	20.62	-0.03	20.55	-0.12	-1.40	0.00	0.28	
CO2 (% vol)	0.06	4.48	0.04	4.48	0.27	-0.27	0.13	0.00	
Run Results and Cal Gases Used	Raw	Corrected	Ranges	Low Gas	Mid Gas	Span Gas			
CO (ppmv)	949.3	951.3	1250.0	253.0	441.0	885.0			
O2 (% vol)	20.38	20.69	25.00	4.53	11.94	20.90			
CO2 (% vol)	1.07	1.03	15.00	7.99	12.62	4.48			

Instrumental Analyses Quality Assurance Data

Date: October 28, 2002
Company: Georgia-Pacific Corporation
Facility: Georgia-Pacific Palatka Operations
Source ID: Bleach Plant Wet Scrubber
Location: Palatka, Putnam County, Florida
Technicians: RPO, JTH

Instrumental Sample System Leak Checks				
Date	Run Number	Vacuum (inches Hg)	Leak Rate (inches Hg/min)	Pass
10/27/02	Set-Up	24.8	0.0	yes
10/28/02	pre Run 1	24.0	0.0	yes
10/28/02	post Run 3	24.2	0.0	yes

Leak check criteria less than 1.0" Hg Vac. Decline at greater than 15.0" Hg Vac.

Continuous Emission Analyzer Interference Response Tests

Analyzer Interference Response Checks

(Frequency: Prior to initial use of sampling system or after alteration or modification.)

Test Date: September 27, 2002 Technician: RPO
 Mobile Lab: T-13 Location: Gainesville, Florida

Analyzer	Manufacturer	Model	Serial Number	Detection Method/Comments
NO _x Analyzer	TECO	42C	42CHL-69541-363	Chemiluminescence with Ozone
CO Analyzer	TECO	48C	48C-70472-365	Infrared Absorption/GFC Detector
O ₂ Analyzer	Servomex	1440	1420C/2647	Paramagnetic Cell Detector
CO ₂ Analyzer	Servomex	1440	01415/2537	Infrared Absorption/ Solid State Detector
THC	California Analytical	300-HFID CE	4J11003	Flame Ionization Detector

Interferent Test Gases		Analyzer Response (ppmv or % as applicable)				
Type Gas	Conc.	NO _x 0-25 ppmv	CO 0-50 ppmv	O ₂ 0-25% vol	CO ₂ 0-15% vol	THC 0-100 ppmv
CO/Methane in air	885/919	0.1 ppmv			0.00 %	
Propane in air	2000	0.1 ppmv	0.4 ppmv		0.03 %	
SO ₂ in N ₂	4400	0.2 ppmv	-0.3 ppmv	0.00 %	0.00 %	no data
Air	dry instrument	< 0.1 ppmv	0.4 ppmv		0.03 %	no data
Nitrogen	pre-purified	0.0 ppmv	0.3 ppmv	0.00 %	0.00 %	no data
Air	UHC, CO free	0.0 ppmv	0.0 ppmv		0.01 %	no data
CO ₂ / O ₂	4.54%/20.8%	< 0.1 ppmv	-0.2 ppmv			no data
CO ₂ / O ₂	8.004%/11.91%	< 0.1 ppmv	-0.4 ppmv			no data
CO ₂ / O ₂	12.62%/4.53%	< 0.1 ppmv	-0.6 ppmv			no data
NO _x in N ₂	1209		0.4 ppmv	0.18 %	0.03 %	no data

**APPENDIX E:
CALIBRATION CERTIFICATIONS**



SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



CERTIFICATE OF ANALYSIS

EPA PROTOCOL MIXTURE
PROCEDURE #: G1

CUSTOMER: Cubix Corporation
SGI ORDER #: 0016436
ITEM#: 7
P.O.#: 2001032 T12 SID

CYLINDER #: CC-94787
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 590

CERTIFICATION DATE: 2/11/02
EXPIRATION DATE: 2/6/2005

CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Monoxide	1/30/02	252.8 ppm	253 ppm	+/- 1%
	2/6/02	252.5 ppm		
Methane	2/11/02	249 ppm	249 ppm	+/- 1%

BALANCE Air
PREVIOUS CERTIFICATION DATES: None

REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Monoxide	GMIS-1	CC94699	486 ppm
Methane	GMIS-1	CC52976	503.3 ppm

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Monoxide	Horiba VIA-510	570423011	NDIR	1/8/02
Methane	H. Packard 6890	US00001434	GC - FID	2/5/02

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST: _____

TED NEEME

DATE: 2/11/02



SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax. (906) 252-0811
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



CERTIFICATE OF ANALYSIS

EPA PROTOCOL MIXTURE PROCEDURE #: G1

CUSTOMER: Cubix Corporation
SGI ORDER #: 0023960
ITEM#: 2
P.O.#: 2002420

CYLINDER #: CC-60135
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 590

CERTIFICATION DATE: 7/19/2002
EXPIRATION DATE: 7/11/2005

CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Monoxide	7/11/2002	441.6 ppm	441 ppm	+/- 1%
	7/19/2002	439.9 ppm		
Methane	7/11/2002	445 ppm	445 ppm	+/- 1%

BALANCE Air

PREVIOUS CERTIFICATION DATES: None

REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Monoxide	NTRM-81681	CC-55779	994 ppm
Methane	GMIS-1	CC55777	993.6 ppm

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Monoxide	Horiba VIA-510	570423011	NDIR	7/19/2002
Methane	H. Packard 6890	US00001434	GC - FID	6/24/2002

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST: FRED PIKULA

DATE: 7/19/2002



SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax: (908) 252-0811
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



CERTIFICATE OF ANALYSIS

EPA PROTOCOL MIXTURE

PROCEDURE #: G1

CUSTOMER: Cubix Corporation
SGI ORDER #: 0000840
ITEM#: 4
P.O.#: G-1334

CYLINDER #: CC126532
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 590

CERTIFICATION DATE: 1/31/2001
EXPIRATION DATE: 1/30/2004

CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Monoxide	1/23/2001	885.2 ppm	885 ppm	+/- 1%
	1/31/2001	884.4 ppm		
Methane	1/30/2001	919 ppm	919 ppm	+/- 1%

BALANCE Air

PREVIOUS CERTIFICATION DATES: None

REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Monoxide	NTRM-81681	CC55721	994 ppm
Methane	GMIS-1	CC55777	994.1 ppm

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Monoxide	Horiba VIA-510	570423011	NDIR	1/19/2001
Methane	H. Packard 6890	US00001434	GC - FID	1/30/2001

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST: FRED PIKULA
FRED PIKULA

DATE: 1/31/2001



SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax (908) 252-0811
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



CERTIFICATE OF ANALYSIS

EPA PROTOCOL MIXTURE
PROCEDURE #: G1

CUSTOMER: Cubix Corporation
SGI ORDER #: 0021285
ITEM#: 1
P.O.#: 2002275 T10LENO

CYLINDER #: CC-133482
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 590

Begin use 7/24/02

CERTIFICATION DATE: 5/24/2002
EXPIRATION DATE: 5/24/2005

CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Dioxide	5/24/2002	4.48 %	4.48 %	+/- 1%
Oxygen	5/24/2002	20.9 %	20.9 %	+/- 1%

BALANCE Nitrogen

PREVIOUS CERTIFICATION DATES: None

REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Dioxide	GMIS-1	CC-90832	9.98 %
Oxygen	NTRM-1	CC-83909	22.8 %

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Dioxide	Horiba VIA-510	571417045	NDIR	5/24/2002
Oxygen	Horiba MPA-510	570694081	PM	5/20/2002

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.


ANALYST: *FP*
FRED PIKULA

DATE: 5/24/2002



SPECTRA GASES INC.

3434 Route 22 West • Branchburg, NJ 08876 USA Tel.: (908) 252-9300 • (800) 932-0624 • Fax (908) 252-0811
Shipped From: 80 Industrial Drive • Alpha, NJ 08865



CERTIFICATE OF ANALYSIS

EPA PROTOCOL MIXTURE PROCEDURE #: G1

CUSTOMER: Cubix Corporation
SGI ORDER #: 0023960
ITEM#: 1
P.O.#: 2002420

CYLINDER #: CC-127463
CYLINDER PRES: 2000 PSIG
CGA OUTLET: 590

CERTIFICATION DATE: 7/23/2002
EXPIRATION DATE: 7/23/2005

CERTIFICATION HISTORY

COMPONENT	DATE OF ASSAY	MEAN CONCENTRATION	CERTIFIED CONCENTRATION	ANALYTICAL ACCURACY
Carbon Dioxide	7/23/2002	7.99 %	7.99 %	+/- 1%
Oxygen	7/23/2002	11.94 %	11.94 %	+/- 1%

BALANCE Nitrogen

PREVIOUS CERTIFICATION DATES: None

REFERENCE STANDARDS

COMPONENT	SRM/NTRM#	CYLINDER#	CONCENTRATION
Carbon Dioxide	GMIS-1	CC-90832	9.98 %
Oxygen	NTRM-1	CC-83909	22.8 %

INSTRUMENTATION

COMPONENT	MAKE/MODEL	SERIAL #	DETECTOR	CALIBRATION DATE(S)
Carbon Dioxide	Horiba VIA-510	571417045	NDIR	6/25/2002
Oxygen	Horiba MPA-510	570694081	PM	7/23/2002

THIS STANDARD IS NIST TRACEABLE. IT WAS CERTIFIED ACCORDING TO THE EPA PROTOCOL PROCEDURES.
DO NOT USE THIS STANDARD IF THE CYLINDER PRESSURE IS LESS THAN 150 PSIG.

ANALYST: Fred Pikula
FRED PIKULA

DATE: 7/23/2002



Scott Specialty Gases

RATA CLASS

Dual-Analyzed Calibration Standard

9810 BAY AREA BLVD, PASADENA, TX 77507

Phone: 281-474-5800

Fax: 281-474-5857

CERTIFICATE OF ACCURACY: Interference Free TM Multi-Component EPA Protocol Gas

Assay Laboratory

SCOTT SPECIALTY GASES
9810 BAY AREA BLVD
PASADENA, TX 77507

P.O. No.: G-1291
Project No.: 04-85228-002

Customer

CUBIX CORPORATION
4536 NW 20TH DRIVE
GAINESVILLE FL 32605



ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards;

Procedure #G1; September, 1997.

Cylinder Number: ALM009152 Certification Date: 4/03/00 Exp. Date: 4/03/2003

Cylinder Pressure***: 1883 PSIG

COMPONENT

CARBON DIOXIDE
OXYGEN
NITROGEN

CERTIFIED CONCENTRATION (Moles)

12.62 %
4.53 %

ANALYTICAL

ACCURACY**

+/- 1%
+/- 1%

TRACEABILITY

Direct NIST and NMI
Direct NIST and NMI

BALANCE

Do not use when cylinder pressure is below 150 psig.

Analytical accuracy is based on the requirements of EPA Protocol procedure G1, September 1997.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST or NMI standards

REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2658	12/19/01	ALM031738	9.680 %	OXYGEN
NTRM 2658	12/19/01	ALM042032	13.96 %	CO2/N2

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#
FTIR System/8220A/AAB9400260
MTI-A/M200/71109

DATE LAST CALIBRATED

03/28/00
03/21/00

ANALYTICAL PRINCIPLE

Scott Enhanced FTIR
GAS CHROMATOGRAPHY

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)


First Triad Analysis

Second Triad Analysis

Calibration Curve

CARBON DIOXIDE


Date: 04/03/00	Response Unit: %	
Z1 = 0.0220	R1 = 13.956	T1 = 12.629
R2 = 13.966	Z2 = 0.0178	T2 = 12.617
Z3 = 0.0276	T3 = 12.620	R3 = 13.959
Avg. Concentration:		12.62 %



Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴	
r = 0.999990	
Constants:	A = 0.000000
B = 1.000000	C = 0.000000
D = 0.000000	E = 0.000000

OXYGEN

Date: 04/06/00	Response Unit: AREA	
Z1 = 114.00	R1 = 35455.	T1 = 16619.
R2 = 35183.	Z2 = 141.00	T2 = 16552.
Z3 = 118.00	T3 = 16573.	R3 = 35179.
Avg. Concentration:		4.530 %



Concentration = A + Bx + Cx ² + Dx ³ + Ex ⁴	
r = 0.99999418	
Constants:	A = -0.03442397
B = 0.000275952	C =
D =	E =

APPROVED BY:

John Hannicutt

Air Products and Chemicals, Inc.
5837 W. Fifth Street
Jacksonville, FL 32254
Telephone (904) 786-2663
FAX (904) 693-9128




30 March, 1995

Cubix Corporation
2106 NW 67th Place
Suite 7
Gainesville, FL 32653

CERTIFICATE OF CONFORMANCE

This document certifies that the product listed below is supplied via Air Products and Chemicals, Inc. and complies with the current minimum purity specifications of Air Products and Chemicals, Inc., Specialty Gas Department.

Product	Hydrogen
Product Code	3602
Product	Oxygen
Product Code	1602
Shipper Number	854-C-78428
Product	Compressed Air
Product Code	9197
Product	Nitrogen
Product Code	2602
Shipper Number	854-C-78440


Authorized Signature

Dry Gas Meter Calibration

WORKING METER

Date: 4/12/02
 Prev. Calib. Date: rebuilt
 Location: Cubix Austin Lab
 Technician: Bradley Rayhons
 Meter Serial No: 2962152
 Cubix DGM ID: T-10
 Prev. Calib Factor (Y): 1.0000

REFERENCE METER

Calibration Date: 4/11/02
 Location: Cubix Austin Lab
 Technician: Steve Oleyar
 Meter Serial No: F164240
 Cubix DGM ID: American
 Calib. Factor (Y): 1.0022

REFERENCE METER

Calibration Run #	Time (min)	Start Temp (deg F)	Stop Temp (deg F)	Vol (initial) (cu ft)	Vol (final) (cu ft)	Vol. Total (cu ft)	Meter Rate (cu-ft./min)	Corr. Vol @ EPA STP (cu ft)
1	20	74	73.7	18.936	25.078	6.155	0.3078	5.998
2	18	74	74.5	26.261	33.362	7.117	0.3954	6.928
3	10	74	73.4	12.401	18.122	5.734	0.5734	5.589
4	11	74	74.6	35.001	42.645	7.661	0.6965	7.453
5	11	75	75.1	44.308	53.922	9.635	0.8759	9.367


WORKING METER

Calibration Run #	Time (min)	Start Temp (deg F)	Stop Temp (deg F)	Vol (initial) (cu ft)	Vol (final) (cu ft)	Vol. Total (cu ft)	Meter Rate (cu-ft./min)	Corr. Vol @ EPA STP (cu ft)	Calculated DGM Factor (Y)	Dry Gas Meter (DGM Factor) Calibration Test Results
1	20	75	73.7	19.158	25.436	6.278	0.314	6.108	0.9819	
2	18	75	73.9	26.635	33.854	7.219	0.401	7.023	0.9866	
3	10	73	74.6	12.465	18.285	5.820	0.582	5.672	0.9854	
4	11	74	75.8	35.525	43.266	7.741	0.704	7.529	0.9900	
5	11	76	73.9	44.957	54.684	9.727	0.864	9.455	0.9906	

Criteria:

* Y - ratio of the reading of the reference meter to the working DGM. Acceptable tolerance of individual values from the average is +/- 0.02, with a value between 0.95 and 1.05.

DGM Factor vs. Flow rate



Bradley Rayhons
 signature

Pitot Tube Calibration Sheet

S-Type Tip Inspection (Method 2, Section 4)


7A

Alignment Inspection

Transverse tube axis pitot-tip angle:
 $\alpha_1 = 4^\circ$ $\alpha_2 = 3^\circ$
 Each α must be less than 10° from perpendicular to the transverse tube axis

Longitudinal tube axis pitot-tip angle:
 $\beta_1 = 2^\circ$ $\beta_2 = 3^\circ$
 Each β must be less than 5° from parallel to the longitudinal tube axis

Pitot-tip end length alignment:
 $Z = 0$ (in or cm)
 Z must be ≤ 0.32 cm (1/8 in)




Pitot-tip centroid alignment with respect to transverse axis:
 $W = 0$ (in or cm)
 W must be ≤ 0.08 cm (1/32 in)

Pitot Tip Dimension Check

External tubing diameter:
 $D_1 = .375$ (in or cm)
 D_1 must be between 0.48 and 0.95 cm (3/16 and 3/8 in)

Base to opening plane distance:
 $P_A = P_B = .475$ (in or cm)
 P_A and P_B must be between $1.05 D_1$ and $1.50 D_1$



Pitot Tube Coefficient

$C_p = 0.84$ Pitot Tube: 2110 Date and Initials: 8-7-02 (JA)

ALTIMETER TEST RECORD

This unit was tested and inspected IAW FAR Part 43,
Appendix E, and is approved for return to service.

DATE: 3-8-02

WORK ORDER #: 3501

SCALE ERROR

-1000	-15
0	0
+500	0
+1000	+10
+1500	0
+2000	+10
+3000	+5
+4000	0
+6000	-5
+8000	+5
+10,000	+15
+12,000	+20
+14,000	+20
+16,000	+15
+18,000	0
+20,000	-10
+22,000	
+25,000	
+30,000	
+35,000	
+40,000	
+45,000	
+50,000	

BAROMETRIC SCALE ERROR TEST

28.10	0	30.50	+5
28.50	-5	30.90	0
29.00	0	30.99	0
29.50	0		
29.92	0		

FRICTION TEST

1000	30	20,000	50
2000	30	25,000	
3000	30	30,000	
5000	30	35,000	
10,000	40	40,000	
15,000	45	50,000	

CASE LEAK TEST @ 18,000 0
CASE LEAK TEST @ 1,200 0

HYSTERESIS TEST @ 50% 20
HYSTERESIS TEST @ 40% 15

AFTER EFFECT 15

START PRESSURE 30.06

FINAL PRESSURE 30.06

SERIAL NUMBER 15924

INSPECTOR [Signature]

TRAILER 10
ALTIMETER/BAROMETER CALIBRATION SHEET

BFG/C 9001

BFGoodrich
Aerospace

817 Dessau Road
Austin, Texas 78753
512-251-3441
FAX 512-990-1271

Component Overhaul & Repair

FAA Repair Station No. UZ2R232L

CASTLEBERRY AERCOR
Serviceable Part Tag

COMPONENT Altimeter
PART NO. 5934P-1A.83
SERIAL NO. J5924
MFG United Fastc WORK ORDER # V7071

Overhaul Repair Bench Check & Test Other _____

The Aircraft Appliance identified above was overhauled, repaired, or bench tested (as per block marked) and inspected, in accordance with current Federal Aviation Administration Regulations, and is approved for return to service. Details of this component are on file at this repair station.

[Signature]
AUTHORIZED SIGNATURE

JAN 16 1995
DATE

ALTIMETER SCALE ERROR					
PART NO. <u>5934P1A83</u>			SERIAL NO. <u>J5924</u>		
ALTIMETER PRESSURE					
TEST PT (FT)	INDICATOR READINGS AT + 25 °C	TEST PT (FT)	INDICATOR READINGS AT + 25 °C	TEST PT (FT)	INDICATOR READINGS AT + 25 °C
-1000	+5	8,000	+5	30,000	
0 0	0	10,000	+10	35,000	
500	0	12,000	+15	40,000	
1000	0	14,000	+15	45,000	
1500	0	16,000	+5	50,000	
2000	0	18,000	0	55,000	
3000	-5	20,000	-5	60,000	
4000	-10	22,000		70,000	
6000	-10	25,000		80,000	

NIST CALIBRATION CERTIFICATE

Catalog Number : 17005-00

Certificate Reference Number 3924899

Instrument Tolerance

±3% full-scale

Equipment "As Found"					Equipment "As Left"				
	Test Points	Reading	Deviation	O.O.T	Test Points	Reading	Deviation		
Measured in: °F	32.00	32.0	0.0000	<input type="checkbox"/>	32.00	32.0	0.0000	<input type="checkbox"/>	
	110.00	110.0	0.0000	<input type="checkbox"/>	110.00	110.0	0.0000	<input type="checkbox"/>	
Measured in: °F	32.00	32.0	0.0000	<input type="checkbox"/>	32.00	32.0	0.0000	<input type="checkbox"/>	
	110.00	110.0	0.0000	<input type="checkbox"/>	110.00	110.0	0.0000	<input type="checkbox"/>	
Measured in:				<input type="checkbox"/>				<input type="checkbox"/>	
Measured in:				<input type="checkbox"/>				<input type="checkbox"/>	
Measured in:				<input type="checkbox"/>				<input type="checkbox"/>	
Measured in:				<input type="checkbox"/>				<input type="checkbox"/>	

**** Note **** Check mark under the O.O.T column indicates the equipment is Out Of Tolerance.

This certificate was performed under the climate controlled lab conditons of: 22 °C 50 %RH 29.5 "Hg

Additional Comments:
n/a

*This certificate shall not be reproduced except in full and requires written approval from InnoCal. * Results data shown relates only to above listed item(s) **

INNOCAL™

INNOVATIVE CALIBRATION SOLUTIONS
625 East Bunker Court, Vernon Hills, Illinois, 60061
Domestic 866-InnoCal - Fax 847-247-2984

NIST CALIBRATION CERTIFICATE

Page 1 of 2

Catalog Number : 17005-00

Certificate Reference Number 3924899

Unit Under Test 1 : 03312-20
Serial Number 1 : 57778

Unit Under Test 2: n/a
Serial Number 2: n/a

Certificate Completed for: **Cubix Corp**
3709 SW 42nd Ave
Gainesville FL 32608

InnoCal certifies that the calibration of the listed units, used procedure number MWI-17005-00 with equipment traceable to the National Institute of Standards and Technology (NIST), and the test was performed in accordance with ANSI/NC SL Z540-1, ISO Guide 25.

Best measurement uncertainty: $k=2, \pm 0.08^{\circ}\text{C}$

Listed uncertainties represent the best measurement uncertainty expressed at 95% confidence level. Actual uncertainties available upon request.

Purchase Order Number: 2002615

Secondary ID #: n/a

Equipment Condition : USED

Calibration Standards Used

Manufacturer	Function Performed	Model Number	Serial Number	Due Date
Hart Scientific	Platinum Resistance Probe	5680	1074	04/14/03
Ertco/Hart	Temperature Indicator	850	85307	04/14/03

Lab Technician: 321



Date Completed: 10/17/02

Issue Date: 10/17/02

Received Date 9/18/02

*This certificate shall not be reproduced except in full and requires written approval from InnoCal. * Results data shown relates only to above listed item(s) **



One Omega Drive, Box 4047, Stamford, CT 06907
(203) 359-1660 - <http://www.omega.com> - e-mail: info@omega.com

CERTIFICATE OF CALIBRATION

Model HH-25KF Serial Number T-233418

Omega Engineering, Inc., certifies that the above listed instrument has been calibrated using standards whose accuracy is traceable to the U.S. National Institute of Standards and Technology, and meets or exceeds its published specifications. Calibration traceability of the above listed instrument is in full compliance with ANSI/Z540-1-1994 standards and requirements.

DATE 2-1-03
TESTED BY RF
AUTHORIZED SIGNATURE mck

MD-4 ©Copyright 1998 Omega Engineering, Inc.

Placed in service: August 14, 2002
Recalibration Date: February 1, 2003
Location: Trailer 10



Certificate Of Calibration

CUBIX

Cust. P.O. #: G1342 Report #: 102915471
 Test Item: ASTM-1C-CC Test Date: 22-FEB-01
 Serial #: 99293 Recal Date: Per System Application

Omega Engineering, Inc. certifies that the above instrumentation has been calibrated and tested to **meet or exceed** the published specifications. This calibration and testing was performed using instrumentation and standards that are traceable to the United States National Institute of Standards and Technology. Calibration on this product was performed by an approved Supplier/Lab of Omega Engineering, Inc. and is in compliance with **MIL-STD-45662A**.

Test Conditions: Temperature 22 C Relative Humidity 35%

NIST Traceable Test Numbers: 213426,264615-01

Temperature	Thermometer Reading	Correction
	We certify that subject thermometer conforms to specifications and tolerances stated in A.S.T.M. Designate E-1, Table 1, No. 1C, Scale Error + or - 0.5 C Max.	


 Metrology Inspector

27-FEB-01

**APPENDIX F:
LOGGED DATA RECORDS
1-MINUTE AVERAGES**

Georgia-Pacific Palatka Operations, Bleach Plant Scrubber, Logged Data Records

Run Number	Date	Time	CO (ppmv)	O2 (% vol)	CO2 (% vol)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)
START Run 1	10/28/02	9:34:18	843.3	20.60	0.88	843.3	20.60	0.88
Run 1	10/28/02	9:35:18	850.0	20.58	0.94	846.6	20.60	0.91
Run 1	10/28/02	9:36:18	841.2	20.60	0.94	844.8	20.60	0.92
Run 1	10/28/02	9:37:18	910.5	20.60	0.96	861.2	20.60	0.93
Run 1	10/28/02	9:38:18	853.2	20.60	0.96	859.6	20.60	0.94
Run 1	10/28/02	9:39:18	895.1	20.60	0.94	865.5	20.60	0.95
Run 1	10/28/02	9:40:18	910.5	20.60	1.00	871.9	20.60	0.95
Run 1	10/28/02	9:41:18	856.6	20.58	0.96	870.0	20.60	0.95
Run 1	10/28/02	9:42:18	909.4	20.58	0.94	874.4	20.60	0.95
Run 1	10/28/02	9:43:18	851.1	20.58	0.94	872.0	20.59	0.94
Run 1	10/28/02	9:44:18	833.5	20.58	0.90	868.5	20.59	0.94
Run 1	10/28/02	9:45:18	908.3	20.58	0.92	871.9	20.59	0.94
Run 1	10/28/02	9:46:18	868.7	20.55	0.98	871.6	20.59	0.94
Run 1	10/28/02	9:47:18	930.3	20.53	1.00	875.8	20.59	0.94
Run 1	10/28/02	9:48:17	869.8	20.53	1.02	875.4	20.58	0.94
Run 1	10/28/02	9:49:16	919.3	20.55	1.04	878.1	20.58	0.95
Run 1	10/28/02	9:50:18	953.4	20.55	1.06	882.6	20.58	0.96
Run 1	10/28/02	9:51:17	892.9	20.55	1.04	883.1	20.58	0.96
Run 1	10/28/02	9:52:18	944.6	20.55	1.04	886.4	20.57	0.96
Run 1	10/28/02	9:53:17	928.1	20.58	1.06	888.4	20.57	0.97
Run 1	10/28/02	9:54:17	961.1	20.53	1.08	891.9	20.57	0.97
Run 1	10/28/02	9:55:17	963.3	20.53	1.12	895.2	20.57	0.98
Run 1	10/28/02	9:56:18	985.5	20.53	1.12	899.1	20.57	0.99
Run 1	10/28/02	9:57:18	961.1	20.55	1.14	901.7	20.57	0.99
Run 1	10/28/02	9:58:18	1000.7	20.58	1.12	905.6	20.57	1.00
Run 1	10/28/02	9:59:18	999.6	20.55	1.16	909.2	20.57	1.00
Run 1	10/28/02	10:00:18	1015.4	20.58	1.08	913.2	20.57	1.01
Run 1	10/28/02	10:01:18	997.4	20.55	1.08	916.2	20.57	1.01
Run 1	10/28/02	10:02:18	964.4	20.55	1.04	917.8	20.57	1.01
Run 1	10/28/02	10:03:18	1000.7	20.55	1.06	920.6	20.57	1.01
Run 1	10/28/02	10:04:18	975.4	20.53	1.10	922.4	20.56	1.02
Run 1	10/28/02	10:05:18	995.8	20.53	1.08	924.7	20.56	1.02
Run 1	10/28/02	10:06:18	954.5	20.53	1.06	925.6	20.56	1.02

Georgia-Pacific Palatka Operations, Bleach Plant Scrubber, Logged Data Records

Run Number	Date	Time	CO (ppmv)	O2 (% vol)	CO2 (% vol)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)
Run 1	10/28/02	10:07:18	987.5	20.53	1.06	927.4	20.56	1.02
Run 1	10/28/02	10:08:18	930.3	20.50	1.06	927.5	20.56	1.02
Run 1	10/28/02	10:09:18	987.5	20.53	1.02	929.1	20.56	1.02
Run 1	10/28/02	10:10:18	949.0	20.50	1.08	929.7	20.56	1.02
Run 1	10/28/02	10:11:18	1000.7	20.50	1.08	931.5	20.56	1.02
Run 1	10/28/02	10:12:18	1015.0	20.48	1.10	933.7	20.55	1.03
Run 1	10/28/02	10:13:17	1021.3	20.45	1.10	935.9	20.55	1.03
Run 1	10/28/02	10:14:17	1003.2	20.45	1.16	937.5	20.55	1.03
Run 1	10/28/02	10:15:17	1000.7	20.45	1.16	939.0	20.55	1.03
Run 1	10/28/02	10:16:17	1003.0	20.45	1.18	940.5	20.55	1.04
Run 1	10/28/02	10:17:17	1005.7	20.45	1.22	942.0	20.54	1.04
Run 1	10/28/02	10:18:17	1015.7	20.45	1.18	943.6	20.54	1.04
Run 1	10/28/02	10:19:17	1008.7	20.45	1.18	945.0	20.54	1.05
Run 1	10/28/02	10:20:17	1002.7	20.48	1.18	946.3	20.54	1.05
Run 1	10/28/02	10:21:17	947.9	20.45	1.10	946.3	20.54	1.05
Run 1	10/28/02	10:22:17	990.7	20.40	1.16	947.2	20.53	1.05
Run 1	10/28/02	10:23:17	990.1	20.43	1.18	948.1	20.53	1.05
Run 1	10/28/02	10:24:17	1000.3	20.50	1.16	949.1	20.53	1.06
Run 1	10/28/02	10:25:17	1024.1	20.53	1.10	950.5	20.53	1.06
Run 1	10/28/02	10:26:17	1035.3	20.50	1.16	952.1	20.53	1.06
Run 1	10/28/02	10:27:17	1007.3	20.50	1.16	953.1	20.53	1.06
Run 1	10/28/02	10:28:17	1002.0	20.50	1.18	954.0	20.53	1.06
Run 1	10/28/02	10:29:17	1012.8	20.50	1.22	955.1	20.53	1.06
Run 1	10/28/02	10:30:17	998.6	20.50	1.24	955.8	20.53	1.07
Run 1	10/28/02	10:31:17	987.5	20.48	1.28	956.4	20.53	1.07
Run 1	10/28/02	10:32:17	999.6	20.45	1.26	957.1	20.53	1.07
Run 1	10/28/02	10:33:17	1000.7	20.43	1.28	957.8	20.52	1.08
END Run 1	10/28/02	10:34:17	1012.4	20.43	1.32	958.7	20.52	1.08

Georgia-Pacific Palatka Operations, Bleach Plant Scrubber, Logged Data Records

Run Number	Date	Time	CO (ppmv)	O2 (% vol)	CO2 (% vol)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)
START Run 2	10/28/02	11:27:40	1012.8	20.43	1.32	1012.8	20.43	1.32
Run 2	10/28/02	11:28:40	1000.8	20.45	1.28	1034.6	20.44	1.31
Run 2	10/28/02	11:29:39	1043.0	20.45	1.32	1020.5	20.43	1.32
Run 2	10/28/02	11:30:39	1022.8	20.43	1.32	1020.2	20.44	1.31
Run 2	10/28/02	11:31:39	1047.0	20.43	1.34	1027.8	20.43	1.32
Run 2	10/28/02	11:32:39	1105.0	20.45	1.30	1034.8	20.43	1.32
Run 2	10/28/02	11:33:39	1049.0	20.48	1.30	1041.2	20.43	1.32
Run 2	10/28/02	11:34:39	788.8	20.30	1.22	1040.1	20.44	1.29
Run 2	10/28/02	11:35:39	1063.0	20.40	1.28	1030.5	20.43	1.29
Run 2	10/28/02	11:36:39	1022.8	20.43	1.26	1033.0	20.43	1.29
Run 2	10/28/02	11:37:39	1071.0	20.43	1.28	1034.2	20.43	1.29
Run 2	10/28/02	11:38:39	1089.0	20.45	1.32	1036.9	20.43	1.29
Run 2	10/28/02	11:39:39	1041.0	20.45	1.30	1042.5	20.43	1.29
Run 2	10/28/02	11:40:39	1107.0	20.48	1.30	1044.7	20.43	1.29
Run 2	10/28/02	11:41:39	1051.0	20.43	1.32	1045.3	20.43	1.29
Run 2	10/28/02	11:42:39	1057.0	20.45	1.30	1047.6	20.43	1.29
Run 2	10/28/02	11:43:39	1087.0	20.43	1.30	1048.9	20.43	1.29
Run 2	10/28/02	11:44:39	1092.8	20.45	1.30	1050.3	20.43	1.29
Run 2	10/28/02	11:45:39	1069.0	20.43	1.28	1053.1	20.43	1.29
Run 2	10/28/02	11:46:39	1083.0	20.40	1.32	1053.8	20.43	1.29
Run 2	10/28/02	11:47:39	1081.0	20.40	1.30	1055.6	20.43	1.29
Run 2	10/28/02	11:48:39	1083.0	20.43	1.28	1057.1	20.43	1.29
Run 2	10/28/02	11:49:39	1047.0	20.53	0.78	1057.6	20.43	1.29
Run 2	10/28/02	11:50:39	1061.0	20.40	1.26	1052.9	20.43	1.28
Run 2	10/28/02	11:51:39	1123.0	20.40	1.32	1054.3	20.43	1.28
Run 2	10/28/02	11:52:39	1081.0	20.43	1.24	1057.3	20.43	1.28
Run 2	10/28/02	11:53:39	1127.0	20.43	1.24	1058.8	20.43	1.28
Run 2	10/28/02	11:54:39	1061.0	20.43	1.26	1059.3	20.43	1.28
Run 2	10/28/02	11:55:39	1076.8	20.45	1.22	1060.3	20.43	1.28
Run 2	10/28/02	11:56:39	1127.0	20.40	1.30	1061.0	20.43	1.28
Run 2	10/28/02	11:57:39	1097.0	20.43	1.28	1063.2	20.43	1.28
Run 2	10/28/02	11:58:39	1127.0	20.43	1.28	1064.7	20.43	1.28
Run 2	10/28/02	11:59:39	1081.0	20.43	1.30	1065.7	20.43	1.28

Georgia-Pacific Palatka Operations, Bleach Plant Scrubber, Logged Data Records

Run Number	Date	Time	CO (ppmv)	O2 (% vol)	CO2 (% vol)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)
Run 2	10/28/02	12:00:39	1095.0	20.45	1.30	1066.8	20.43	1.28
Run 2	10/28/02	12:01:39	1079.0	20.43	1.26	1067.1	20.43	1.28
Run 2	10/28/02	12:02:39	1093.0	20.45	1.28	1067.8	20.43	1.28
Run 2	10/28/02	12:03:39	1087.0	20.45	1.30	1067.8	20.43	1.28
Run 2	10/28/02	12:04:39	1101.0	20.40	1.28	1069.0	20.43	1.28
Run 2	10/28/02	12:05:39	1149.0	20.43	1.30	1070.3	20.43	1.28
Run 2	10/28/02	12:06:39	1145.0	20.38	1.28	1072.7	20.43	1.28
Run 2	10/28/02	12:07:39	1209.0	20.38	1.32	1075.0	20.43	1.28
Run 2	10/28/02	12:08:39	1171.0	20.40	1.32	1077.7	20.43	1.28
Run 2	10/28/02	12:09:39	1187.0	20.40	1.32	1079.9	20.43	1.28
Run 2	10/28/02	12:10:39	1109.0	20.43	1.28	1081.8	20.43	1.28
Run 2	10/28/02	12:11:39	1131.0	20.43	1.22	1082.9	20.43	1.28
Run 2	10/28/02	12:12:39	1125.0	20.70	1.20	1083.4	20.43	1.28
Run 2	10/28/02	12:13:39	1099.0	20.48	1.16	1083.3	20.43	1.28
Run 2	10/28/02	12:14:39	1125.0	20.45	1.20	1083.4	20.43	1.28
Run 2	10/28/02	12:15:39	1091.0	20.48	1.18	1084.1	20.43	1.28
Run 2	10/28/02	12:16:39	1135.0	20.48	1.20	1084.5	20.43	1.27
Run 2	10/28/02	12:17:39	1083.0	20.48	1.18	1085.0	20.43	1.27
Run 2	10/28/02	12:18:39	1127.0	20.45	1.18	1085.8	20.43	1.27
Run 2	10/28/02	12:19:38	1113.0	20.45	1.20	1086.0	20.43	1.27
Run 2	10/28/02	12:20:38	1079.0	20.45	1.20	1086.5	20.43	1.27
Run 2	10/28/02	12:21:38	1145.0	20.45	1.20	1087.0	20.43	1.27
Run 2	10/28/02	12:22:38	1153.0	20.45	1.20	1087.6	20.43	1.27
Run 2	10/28/02	12:23:38	1091.0	20.43	1.22	1088.5	20.43	1.26
Run 2	10/28/02	12:24:38	1113.0	20.45	1.16	1089.4	20.43	1.26
Run 2	10/28/02	12:25:38	1173.0	20.45	1.20	1089.7	20.43	1.26
Run 2	10/28/02	12:26:38	1127.0	20.45	1.20	1090.3	20.43	1.26
END Run 2	10/28/02	12:27:38	1137.0	20.40	1.26	1091.3	20.43	1.26

Georgia-Pacific Palatka Operations, Bleach Plant Scrubber, Logged Data Records

Run Number	Date	Time	CO (ppmv)	O2 (% vol)	CO2 (% vol)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)
START Run 3	10/28/02	13:17:45	1009.0	20.40	1.04	1009.0	20.40	1.04
Run 3	10/28/02	13:18:45	1023.0	20.45	1.06	1004.8	20.42	1.06
Run 3	10/28/02	13:19:45	969.0	20.45	1.04	999.4	20.44	1.04
Run 3	10/28/02	13:20:45	991.0	20.45	1.00	996.6	20.43	1.04
Run 3	10/28/02	13:21:45	983.0	20.45	0.98	992.1	20.44	1.03
Run 3	10/28/02	13:22:45	979.0	20.43	1.02	991.8	20.44	1.02
Run 3	10/28/02	13:23:45	991.0	20.43	1.02	988.9	20.44	1.02
Run 3	10/28/02	13:24:45	957.0	20.43	1.02	987.7	20.44	1.02
Run 3	10/28/02	13:25:45	1007.0	20.43	1.06	986.4	20.43	1.02
Run 3	10/28/02	13:26:45	923.0	20.28	1.04	985.4	20.42	1.02
Run 3	10/28/02	13:27:45	1015.0	20.33	1.04	985.1	20.41	1.03
Run 3	10/28/02	13:28:45	1025.0	20.33	1.14	986.6	20.40	1.03
Run 3	10/28/02	13:29:45	1039.0	20.38	1.12	992.9	20.40	1.04
Run 3	10/28/02	13:30:45	1089.0	20.38	1.12	997.1	20.40	1.05
Run 3	10/28/02	13:31:45	1055.0	20.38	1.14	1002.2	20.39	1.06
Run 3	10/28/02	13:32:45	1093.0	20.38	1.12	1007.8	20.39	1.06
Run 3	10/28/02	13:33:45	1065.0	20.35	1.14	1010.7	20.39	1.07
Run 3	10/28/02	13:34:44	1015.0	20.35	1.10	1014.0	20.39	1.07
Run 3	10/28/02	13:35:44	1083.0	20.35	1.14	1015.7	20.38	1.07
Run 3	10/28/02	13:36:44	1007.0	20.35	1.14	1017.6	20.38	1.07
Run 3	10/28/02	13:37:44	1013.0	20.38	1.08	1018.3	20.38	1.08
Run 3	10/28/02	13:38:44	1025.0	20.35	1.14	1017.1	20.38	1.08
Run 3	10/28/02	13:39:44	1005.0	20.35	1.12	1017.4	20.38	1.08
Run 3	10/28/02	13:40:44	1037.0	20.33	1.12	1016.7	20.38	1.08
Run 3	10/28/02	13:41:44	993.0	20.33	1.14	1016.6	20.38	1.09
Run 3	10/28/02	13:42:44	999.0	20.33	1.12	1016.1	20.37	1.09
Run 3	10/28/02	13:43:44	947.0	20.43	1.14	1013.9	20.37	1.09
Run 3	10/28/02	13:44:44	937.0	20.38	1.12	1011.8	20.38	1.09
Run 3	10/28/02	13:45:44	935.0	20.40	1.10	1008.9	20.38	1.09
Run 3	10/28/02	13:46:44	911.0	20.40	1.08	1006.3	20.38	1.09
Run 3	10/28/02	13:47:44	959.0	20.40	1.12	1003.6	20.38	1.09
Run 3	10/28/02	13:48:44	945.0	20.40	1.14	1001.9	20.38	1.09
Run 3	10/28/02	13:49:44	971.0	20.40	1.10	1000.9	20.38	1.09

Georgia-Pacific Palatka Operations, Bleach Plant Scrubber, Logged Data Records

Run Number	Date	Time	CO (ppmv)	O2 (% vol)	CO2 (% vol)	AVE CO (ppmv)	AVE O2 (% vol)	AVE CO2 (% vol)
Run 3	10/28/02	13:50:44	961.0	20.38	1.16	999.0	20.38	1.10
Run 3	10/28/02	13:51:44	929.0	20.35	1.08	998.1	20.38	1.10
Run 3	10/28/02	13:52:44	973.0	20.35	1.08	996.5	20.38	1.10
Run 3	10/28/02	13:53:44	909.0	20.38	1.12	994.6	20.38	1.10
Run 3	10/28/02	13:54:44	945.0	20.33	1.06	993.4	20.38	1.09
Run 3	10/28/02	13:55:44	933.0	20.33	1.08	991.5	20.38	1.09
Run 3	10/28/02	13:56:44	690.8	20.35	0.98	988.5	20.38	1.09
Run 3	10/28/02	13:57:44	927.0	20.33	1.04	984.3	20.37	1.09
Run 3	10/28/02	13:58:44	873.0	20.35	1.00	982.1	20.37	1.09
Run 3	10/28/02	13:59:44	891.0	20.38	1.02	980.0	20.37	1.08
Run 3	10/28/02	14:00:44	915.0	20.38	1.06	977.9	20.37	1.08
Run 3	10/28/02	14:01:44	861.0	20.38	1.04	976.3	20.37	1.08
Run 3	10/28/02	14:02:44	921.0	20.40	1.06	974.2	20.37	1.08
Run 3	10/28/02	14:03:44	855.0	20.38	1.06	972.2	20.37	1.08
Run 3	10/28/02	14:04:44	893.0	20.38	1.02	970.4	20.37	1.08
Run 3	10/28/02	14:05:44	849.0	20.38	1.04	967.8	20.37	1.08
Run 3	10/28/02	14:06:44	889.0	20.40	1.04	966.3	20.37	1.08
Run 3	10/28/02	14:07:44	917.0	20.40	1.04	964.7	20.37	1.08
Run 3	10/28/02	14:08:44	879.0	20.40	1.06	963.3	20.37	1.08
Run 3	10/28/02	14:09:44	903.0	20.38	1.04	962.1	20.37	1.08
Run 3	10/28/02	14:10:44	863.0	20.38	1.08	960.2	20.38	1.08
Run 3	10/28/02	14:11:44	855.0	20.38	1.02	958.7	20.38	1.08
Run 3	10/28/02	14:12:44	917.0	20.38	1.06	957.2	20.38	1.07
Run 3	10/28/02	14:13:44	879.0	20.38	1.06	956.0	20.38	1.07
Run 3	10/28/02	14:14:44	845.0	20.40	0.96	954.6	20.38	1.07
Run 3	10/28/02	14:15:44	883.0	20.38	0.98	952.6	20.38	1.07
Run 3	10/28/02	14:16:44	825.0	20.38	0.96	951.0	20.38	1.07
END Run 3	10/28/02	14:17:44	849.0	20.38	0.90	949.3	20.38	1.07