

RECEIVED

AUG 29 2011

BUREAU OF
AIR REGULATION

original

APPLICATION FOR AIR CONSTRUCTION PERMIT

To Improve Performance of Sanford Plant Units 4 and 5

PERMIT APPLICATION

Prepared For: Florida Power & Light Company
700 Universe Blvd.
Juno Beach, FL 33408

Submitted By: Golder Associates Inc.
6026 NW 1st Place
Gainesville, FL 32607 USA

Distribution: 4 copies – Florida Department of Environmental Protection
2 copies – Florida Power & Light Company
1 copy – Golder Associates Inc.

August 2011

113-87631

A world of
capabilities
delivered locally



APPLICATION FOR AIR PERMIT

LONG FORM



Department of Environmental Protection

RECEIVED

AUG 29 2011

Division of Air Resource Management

DIVISION OF AIR RESOURCE MANAGEMENT

APPLICATION FOR AIR PERMIT - LONG FORM

I. APPLICATION INFORMATION

Air Construction Permit – Use this form to apply for an air construction permit:

- For any required purpose at a facility operating under a federally enforceable state air operation permit (FESOP) or Title V air operation permit;
- For a proposed project subject to prevention of significant deterioration (PSD) review, nonattainment new source review, or maximum achievable control technology (MACT);
- To assume a restriction on the potential emissions of one or more pollutants to escape a requirement such as PSD review, nonattainment new source review, MACT, or Title V; or
- To establish, revise, or renew a plantwide applicability limit (PAL).

Air Operation Permit – Use this form to apply for:

- An initial federally enforceable state air operation permit (FESOP); or
- An initial, revised, or renewal Title V air operation permit.

To ensure accuracy, please see form instructions.

Identification of Facility

1. Facility Owner/Company Name: Florida Power & Light Company (FPL)	
2. Site Name: Sanford Power Plant	
3. Facility Identification Number: 1270009	
4. Facility Location... Street Address or Other Locator: 950 South Highway 17-92 City: DeBary County: Volusia Zip Code: 32713	
5. Relocatable Facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6. Existing Title V Permitted Facility? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Application Contact

1. Application Contact Name: Kevin Washington, Project Manager	
2. Application Contact Mailing Address... Organization/Firm: Florida Power & Light Company – FPL Environmental Services Street Address: 700 Universe Blvd. City: Juno Beach State: FL Zip Code: 33408	
3. Application Contact Telephone Numbers... Telephone: (561) 691-2877 ext. Fax: (561) 691-7049	
4. Application Contact E-mail Address:	

Application Processing Information (DEP Use)

1. Date of Receipt of Application: 8-29-11	3. PSD Number (if applicable):
2. Project Number(s): 1270009-022-AC	4. Siting Number (if applicable):

APPLICATION INFORMATION

Purpose of Application

This application for air permit is being submitted to obtain: (Check one)

Air Construction Permit

- Air construction permit.
- Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL).
- Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL), and separate air construction permit to authorize construction or modification of one or more emissions units covered by the PAL.

Air Operation Permit

- Initial Title V air operation permit.
- Title V air operation permit revision.
- Title V air operation permit renewal.
- Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is required.
- Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is not required.

Air Construction Permit and Revised/Renewal Title V Air Operation Permit (Concurrent Processing)

- Air construction permit and Title V permit revision, incorporating the proposed project.
- Air construction permit and Title V permit renewal, incorporating the proposed project.

Note: By checking one of the above two boxes, you, the applicant, are requesting concurrent processing pursuant to Rule 62-213.405, F.A.C. In such case, you must also check the following box:

- I hereby request that the department waive the processing time requirements of the air construction permit to accommodate the processing time frames of the Title V air operation permit.

Application Comment

Minor source air construction permit application to improve the performance of the existing General Electric (GE) Model MS7241FA(7FA.03) combustion turbines associated with Units 4A,4B,4C,4D,5A,5B,5C and 5D with GE 7FA.04 components.

APPLICATION INFORMATION

Scope of Application

Emissions Unit ID Number	Description of Emissions Unit	Air Permit Type	Air Permit Processing Fee
005	Combined-Cycle Combustion Turbine (CT) 4A	AC1B	NA
006	Combined-Cycle Combustion Turbine (CT) 4B	AC1B	NA
007	Combined-Cycle Combustion Turbine (CT) 4C	AC1B	NA
008	Combined-Cycle Combustion Turbine (CT) 4D	AC1B	NA
009	Combined-Cycle Combustion Turbine (CT) 5A	AC1B	NA
010	Combined-Cycle Combustion Turbine (CT) 5B	AC1B	NA
011	Combined-Cycle Combustion Turbine (CT) 5C	AC1B	NA
012	Combined-Cycle Combustion Turbine (CT) 5D	AC1B	NA

Application Processing Fee

Check one: Attached - Amount: _____ Not Applicable

APPLICATION INFORMATION

Owner/Authorized Representative Statement

Complete if applying for an air construction permit or an initial FESOP.

1. Owner/Authorized Representative Name : Jeff Smith, Plant General Manager
2. Owner/Authorized Representative Mailing Address... Organization/Firm: Sanford Plant Street Address: 950 South Highway 17-92 City: DeBary State: FL Zip Code: 32713
3. Owner/Authorized Representative Telephone Numbers... Telephone: (386) 575-5100 Fax: (386) 575-5299
4. Owner/Authorized Representative E-mail Address: jeff_smith@fpl.com
5. Owner/Authorized Representative Statement: <i>I, the undersigned, am the owner or authorized representative of the corporation, partnership, or other legal entity submitting this air permit application. To the best of my knowledge, the statements made in this application are true, accurate and complete, and any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department.</i>  Signature _____  Date _____

APPLICATION INFORMATION


Application Responsible Official Certification

Complete if applying for an initial, revised, or renewal Title V air operation permit or concurrent processing of an air construction permit and revised or renewal Title V air operation permit. If there are multiple responsible officials, the "application responsible official" need not be the "primary responsible official."

1. Application Responsible Official Name:			
2. Application Responsible Official Qualification (Check one or more of the following options, as applicable):			
<input type="checkbox"/> For a corporation, the president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit under Chapter 62-213, F.A.C.			
<input type="checkbox"/> For a partnership or sole proprietorship, a general partner or the proprietor, respectively.			
<input type="checkbox"/> For a municipality, county, state, federal, or other public agency, either a principal executive officer or ranking elected official.			
<input type="checkbox"/> The designated representative at an Acid Rain source or CAIR source.			
3. Application Responsible Official Mailing Address...			
Organization/Firm:			
Street Address:			
City:		State:	Zip Code:
4. Application Responsible Official Telephone Numbers...			
Telephone:	ext.	Fax:	
5. Application Responsible Official E-mail Address:			
6. Application Responsible Official Certification:			
<p>I, the undersigned, am a responsible official of the Title V source addressed in this air permit application. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof and all other applicable requirements identified in this application to which the Title V source is subject. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department, and I will promptly notify the department upon sale or legal transfer of the facility or any permitted emissions unit. Finally, I certify that the facility and each emissions unit are in compliance with all applicable requirements to which they are subject, except as identified in compliance plan(s) submitted with this application.</p>			
_____ Signature		_____ Date	

APPLICATION INFORMATION

Professional Engineer Certification

1. Professional Engineer Name: Kennard F. Kosky Registration Number: 14996
2. Professional Engineer Mailing Address... Organization/Firm: Golder Associates Inc.** Street Address: 6026 NW 1st Place City: Gainesville State: FL Zip Code: 32607
3. Professional Engineer Telephone Numbers... Telephone: (352) 336-5600 ext. 21156 Fax: (352) 336-6603
4. Professional Engineer E-mail Address: Ken_Kosky@golder.com
5. Professional Engineer Statement: <i>I, the undersigned, hereby certify, except as particularly noted herein*, that:</i> <i>(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this application for air permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and</i> <i>(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.</i> <i>(3) If the purpose of this application is to obtain a Title V air operation permit (check here <input type="checkbox"/> , if so), I further certify that each emissions unit described in this application for air permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance plan and schedule is submitted with this application.</i> <i>(4) If the purpose of this application is to obtain an air construction permit (check here <input checked="" type="checkbox"/> , if so) or concurrently process and obtain an air construction permit and a Title V air operation permit revision or renewal for one or more proposed new or modified emissions units (check here <input type="checkbox"/> , if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.</i> <i>(5) If the purpose of this application is to obtain an initial air operation permit or operation permit revision or renewal for one or more newly constructed or modified emissions units (check here <input type="checkbox"/> , if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.</i> Signature: <u><i>Kennard F. Kosky</i></u> Date: <u>8/26/11</u> (seal) 

* Attach any exception to certification statement.

** Board of Professional Engineers Certificate of Authorization # 00001670

Facility Regulatory Classifications

Check all that would apply *following* completion of all projects and implementation of all other changes proposed in this application for air permit. Refer to instructions to distinguish between a “major source” and a “synthetic minor source.”

1. <input type="checkbox"/> Small Business Stationary Source	<input type="checkbox"/> Unknown
2. <input type="checkbox"/> Synthetic Non-Title V Source	
3. <input checked="" type="checkbox"/> Title V Source	
4. <input checked="" type="checkbox"/> Major Source of Air Pollutants, Other than Hazardous Air Pollutants (HAPs)	
5. <input type="checkbox"/> Synthetic Minor Source of Air Pollutants, Other than HAPs	
6. <input checked="" type="checkbox"/> Major Source of Hazardous Air Pollutants (HAPs)	
7. <input type="checkbox"/> Synthetic Minor Source of HAPs	
8. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NSPS (40 CFR Part 60)	
9. <input checked="" type="checkbox"/> One or More Emissions Units Subject to Emission Guidelines (40 CFR Part 60)	
10. <input type="checkbox"/> One or More Emissions Units Subject to NESHAP (40 CFR Part 61 or Part 63)	
11. <input type="checkbox"/> Title V Source Solely by EPA Designation (40 CFR 70.3(a)(5))	
12. Facility Regulatory Classifications Comment:	

List of Pollutants Emitted by Facility

1. Pollutant Emitted	2. Pollutant Classification	3. Emissions Cap [Y or N]?
PM/PM10	A	Y
CO	A	N
VOC	A	N
SO2	A	Y
NOx	A	Y
HAPS	A	N
SAM	A	N

C. FACILITY ADDITIONAL INFORMATION

Additional Requirements for All Applications, Except as Otherwise Stated

1.	Facility Plot Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: <u>May, 2009</u>
2.	Process Flow Diagram(s): (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: <u>May, 2009</u>
3.	Precautions to Prevent Emissions of Unconfined Particulate Matter: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: <u>May, 2009</u>

Additional Requirements for Air Construction Permit Applications

1.	Area Map Showing Facility Location: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable (existing permitted facility)
2.	Description of Proposed Construction, Modification, or Plantwide Applicability Limit (PAL): <input checked="" type="checkbox"/> Attached, Document ID: <u>Part II</u>
3.	Rule Applicability Analysis: <input checked="" type="checkbox"/> Attached, Document ID: <u>Part II</u>
4.	List of Exempt Emissions Units: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable (no exempt units at facility)
5.	Fugitive Emissions Identification: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
6.	Air Quality Analysis (Rule 62-212.400(7), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
7.	Source Impact Analysis (Rule 62-212.400(5), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
8.	Air Quality Impact since 1977 (Rule 62-212.400(4)(e), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
9.	Additional Impact Analyses (Rules 62-212.400(8) and 62-212.500(4)(e), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
10.	Alternative Analysis Requirement (Rule 62-212.500(4)(g), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

C. FACILITY ADDITIONAL INFORMATION (CONTINUED)

Additional Requirements for FESOP Applications -- NA

1. List of Exempt Emissions Units:
 Attached, Document ID: _____ Not Applicable (no exempt units at facility)

Additional Requirements for Title V Air Operation Permit Applications-- NA

1. List of Insignificant Activities: (Required for initial/renewal applications only)
 Attached, Document ID: _____ Not Applicable (revision application)
2. Identification of Applicable Requirements: (Required for initial/renewal applications, and for revision applications if this information would be changed as a result of the revision being sought)
 Attached, Document ID: _____
 Not Applicable (revision application with no change in applicable requirements)
3. Compliance Report and Plan: (Required for all initial/revision/renewal applications)
 Attached, Document ID: _____
Note: A compliance plan must be submitted for each emissions unit that is not in compliance with all applicable requirements at the time of application and/or at any time during application processing. The department must be notified of any changes in compliance status during application processing.
4. List of Equipment/Activities Regulated under Title VI: (If applicable, required for initial/renewal applications only)
 Attached, Document ID: _____
 Equipment/Activities Onsite but Not Required to be Individually Listed
 Not Applicable
5. Verification of Risk Management Plan Submission to EPA: (If applicable, required for initial/renewal applications only)
 Attached, Document ID: _____ Not Applicable
6. Requested Changes to Current Title V Air Operation Permit:
 Attached, Document ID: _____ Not Applicable

C. FACILITY ADDITIONAL INFORMATION (CONTINUED)

Additional Requirements for Facilities Subject to Acid Rain, CAIR, or Hg Budget Program

<p>1. Acid Rain Program Forms:</p> <p>Acid Rain Part Application (DEP Form No. 62-210.900(1)(a)):</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: <u>June, 2008</u></p> <p><input type="checkbox"/> Not Applicable (not an Acid Rain source)</p> <p>Phase II NO_x Averaging Plan (DEP Form No. 62-210.900(1)(a)1.):</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____</p> <p><input checked="" type="checkbox"/> Not Applicable</p> <p>New Unit Exemption (DEP Form No. 62-210.900(1)(a)2.):</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date: _____</p> <p><input checked="" type="checkbox"/> Not Applicable</p>
<p>2. CAIR Part (DEP Form No. 62-210.900(1)(b)):</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: <u>June, 2008</u></p> <p><input type="checkbox"/> Not Applicable (not a CAIR source)</p>

Additional Requirements Comment

EMISSIONS UNIT INFORMATION

Section [1]

Combustion Turbines 4A, 4B, 4C and 4D

III. EMISSIONS UNIT INFORMATION

Title V Air Operation Permit Application - For Title V air operation permitting only, emissions units are classified as regulated, unregulated, or insignificant. If this is an application for an initial, revised or renewal Title V air operation permit, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each regulated and unregulated emissions unit addressed in this application. Some of the subsections comprising the Emissions Unit Information Section of the form are optional for unregulated emissions units. Each such subsection is appropriately marked. Insignificant emissions units are required to be listed at Section II, Subsection C.

Air Construction Permit or FESOP Application - For air construction permitting or federally enforceable state air operation permitting, emissions units are classified as either subject to air permitting or exempt from air permitting. The concept of an "unregulated emissions unit" does not apply. If this is an application for an air construction permit or FESOP, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air permitting are required to be listed at Section II, Subsection C.

Air Construction Permit and Revised/Renewal Title V Air Operation Permit Application - Where this application is used to apply for both an air construction permit and a revised or renewal Title V air operation permit, each emissions unit is classified as either subject to air permitting or exempt from air permitting for air construction permitting purposes, and as regulated, unregulated, or insignificant for Title V air operation permitting purposes. A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit addressed in this application that is subject to air construction permitting and for each such emissions unit that is a regulated or unregulated unit for purposes of Title V permitting. (An emissions unit may be exempt from air construction permitting but still be classified as an unregulated unit for Title V purposes.) Emissions units classified as insignificant for Title V purposes are required to be listed at Section II, Subsection C.

If submitting the application form in hard copy, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application must be indicated in the space provided at the top of each page.

EMISSIONS UNIT INFORMATION

Section [1]
Combustion Turbines 4A, 4B, 4C and 4D

A. GENERAL EMISSIONS UNIT INFORMATION

Title V Air Operation Permit Emissions Unit Classification

1. Regulated or Unregulated Emissions Unit? (Check one, if applying for an initial, revised or renewal Title V air operation permit. Skip this item if applying for an air construction permit or FESOP only.)
- The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.
 - The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in this Section: (Check one)
- This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).
 - This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.
 - This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

2. Description of Emissions Unit Addressed in this Section:
Units 4A – 4D: Four identical combustion turbines with unfired heat recovery steam generators

3. Emissions Unit Identification Number:
EU 005 (Unit 4A), EU 006 (Unit 4B), EU 007 (Unit 4C), EU 008 (Unit 4D)

4. Emissions Unit Status Code: A	5. Commence Construction Date:	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: 49
--	--------------------------------	--------------------------	---

8. Federal Program Applicability: (Check all that apply)
 Acid Rain Unit CAIR Unit

9. Package Unit:
Manufacturer: **General Electric** Model Number: **MS7241, 7FA.04**

10. Generator Nameplate Rating:

11. Emissions Unit Comment:
4-on-1 combined-cycle system will consist of four nominal 170 megawatt (MW) General Electric (GE) 7FA.04 combustion turbines, four heat recovery steam generators, and a nominal 320-MW steam electrical generator set rated for a total nominal capacity of 1,000 MW.

Initial startup dates: December 6, 2002 (Unit 4A); December 4, 2002 (Unit 4B); December 16, 2002 (Unit 4C); and January 3, 2003 (Unit 4D)

EMISSIONS UNIT INFORMATION

Section [1]

Combustion Turbines 4A, 4B, 4C and 4D

Emissions Unit Control Equipment/Method: Control 1 of 2

1. Control Equipment/Method Description:

Low nitrogen oxides (NO_x) burners - Dry low-NO_x (DLN) combustors for firing natural gas

2. Control Device or Method Code: **205**

Emissions Unit Control Equipment/Method: Control 2 of 2

1. Control Equipment/Method Description:

Miscellaneous Control Devices - Use of Natural gas

2. Control Device or Method Code: **99**

Emissions Unit Control Equipment/Method: Control _ of _

1. Control Equipment/Method Description:

2. Control Device or Method Code:

Emissions Unit Control Equipment/Method: Control _ of _

1. Control Equipment/Method Description:

2. Control Device or Method Code:

EMISSIONS UNIT INFORMATION

Section [1]

Combustion Turbines 4A, 4B, 4C and 4D

B. EMISSIONS UNIT CAPACITY INFORMATION

(Optional for unregulated emissions units.)

Emissions Unit Operating Capacity and Schedule

1. Maximum Process or Throughput Rate:
2. Maximum Production Rate: 170 MW (nominal) per turbine
3. Maximum Heat Input Rate: 1,776 MMBtu/hr (HHV) (NG)
4. Maximum Incineration Rate: pounds/hr tons/day
5. Requested Maximum Operating Schedule: 24 hours/day 52 weeks/year 7 days/week 8,760 hours/year
6. Operating Capacity/Schedule Comment: Maximum heat input and power outputs for each turbine are at 59 °F ambient temperature and based on 100-percent load. Maximum heat input rate for each turbine at HTPM = 1,838 MMBtu/hr (HHV) (NG)

EMISSIONS UNIT INFORMATION

Section [1]

Combustion Turbines 4A, 4B, 4C and 4D

C. EMISSION POINT (STACK/VENT) INFORMATION

(Optional for unregulated emissions units.)

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram: 4A-4D HRSG STACK		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking:			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 125 feet	7. Exit Diameter: 19 feet	
8. Exit Temperature: 220°F	9. Actual Volumetric Flow Rate: 1,053,410 acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates... Zone: 17 East (km): 468.1 North (km): 3190.86		14. Emission Point Latitude/Longitude... Latitude (DD/MM/SS) 28/50/42 N Longitude (DD/MM/SS) 81/19/37 W	
15. Emission Point Comment: <p>For each turbine:</p> <p>Flow rate (NG-firing, 59 °F, base load) = 3,614,000 lb/hr (GE data) /28.39 (mol wt) x 1545.6 (gas constant) x (460+220) (temperature) /2116.8 lb/ft² (pressure) x hr/60 min = 1,053,410 acfm</p>			

EMISSIONS UNIT INFORMATION

Section [1]

Combustion Turbines 4A, 4B, 4C and 4D

D. SEGMENT (PROCESS/FUEL) INFORMATION

Segment Description and Rate: Segment 1 of 1

1. Segment Description (Process/Fuel Type): Internal Combustion Engines; Electric Generation; Natural Gas Turbine		
2. Source Classification Code (SCC): 2-01-002-01	3. SCC Units: Million cubic feet burned	
4. Maximum Hourly Rate: 7.1	5. Maximum Annual Rate: 62,196	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: 1,000 (HHV)
10. Segment Comment: <p>Hourly rate = 1,776 MMBtu/hr / 1,000 MMBtu/10⁶ ft³ x 4 turbines = 7.1 x 10⁶ ft³/hr Annual rate = 7.1 x 10⁶ ft³/hr x 8,760 hrs/yr = 62,196 x 10⁶ ft³/yr</p>		

Segment Description and Rate: Segment of

1. Segment Description (Process/Fuel Type):		
2. Source Classification Code (SCC):	3. SCC Units:	
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment:		

EMISSIONS UNIT INFORMATION

Section [1]

Combustion Turbines 4A, 4B, 4C and 4D

E. EMISSIONS UNIT POLLUTANTS

List of Pollutants Emitted by Emissions Unit

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
NO _x	205		EL
CO			EL
PM/PM ₁₀			WP
VOC			EL
SO ₂	99		WP

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]
 Combustion Turbines 4A, 4B, 4C and 4D

Page [1] of [5]
 Nitrogen Oxide – NO_x

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions

1. Pollutant Emitted: NO_x		2. Total Percent Efficiency of Control:	
3. Potential Emissions lb/hour		4. Synthetically Limited? <input type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): 1,328.0 tons/year		8.b. Baseline 24-month Period: From: 1/1/2006 To: 12/31/2007	
9.a. Projected Actual Emissions (if required): 1,359.8 tons/year		9.b. Projected Monitoring Period: <input checked="" type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: See Table 7 of Part II.			
11. Potential, Fugitive, and Actual Emissions Comment: Baseline projected and actual emissions include 4 & 5 only.			

EMISSIONS UNIT INFORMATION

Section [1]
 Combustion Turbines 4A, 4B, 4C and 4D

POLLUTANT DETAIL INFORMATION

Page [1] of [5]
 Nitrogen Oxide – NO_x

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 5

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 65 lb/hr	4. Equivalent Allowable Emissions: 65 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 7E or 20. Initial Compliance test only	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation. Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions 2 of 5

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 9 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: CEMS data	
6. Allowable Emissions Comment (Description of Operating Method): Based on 30-day rolling average. Equivalent allowable emissions based on GE data for GE7FA.04 at base load and 59°F.	

Allowable Emissions Allowable Emissions 3 of 5

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 102 lb/hr	4. Equivalent Allowable Emissions: 102 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 7E or 20. Initial Compliance test only.	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at High temperature Peaking mode. In this mode each turbine operation limited to 400 hr/yr.	

EMISSIONS UNIT INFORMATION

Section [1]
 Combustion Turbines 4A, 4B, 4C and 4D

POLLUTANT DETAIL INFORMATION

Page [1] of [5]
 Nitrogen Oxide – NO_x

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 4 of 5

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 15 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: CEM data	
6. Allowable Emissions Comment (Description of Operating Method): 24-Hour block average standard during NG-firing combined-cycle operation at high temperature peaking mode. In this mode each turbine operation limited to 400 hr/yr.	

Allowable Emissions Allowable Emissions 5 of 5

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 75 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: CEM data	
6. Allowable Emissions Comment (Description of Operating Method): Based on 4-hour rolling average. 40 CFR 60 Subpart GG limit.	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [1]
 Combustion Turbines 4A, 4B, 4C and 4D

POLLUTANT DETAIL INFORMATION

Page [2] of [5]
 Carbon Monoxide – CO

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 12 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation. Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions 2 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 43 lb/hr	4. Equivalent Allowable Emissions: 43 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation. Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions 3 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 9 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at High temperature Peaking Mode. In this mode each turbine operation limited to 400 hr/yr.	

EMISSIONS UNIT INFORMATION

Section [1]
 Combustion Turbines 4A, 4B, 4C and 4D

POLLUTANT DETAIL INFORMATION

Page [2] of [5]
 Carbon Monoxide – CO

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions **4** of **4**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 29 lb/hr	4. Equivalent Allowable Emissions: 29 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at high temperature peaking mode. In this mode each turbine operation limited to 400 hr/yr.	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]
 Combustion Turbines 4A, 4B, 4C and 4D

Page [3] of [5]
 VOC

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions

1. Pollutant Emitted: VOC		2. Total Percent Efficiency of Control:	
3. Potential Emissions lb/hour		4. Synthetically Limited? <input type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): 0.15 tons/year		8.b. Baseline 24-month Period: From: 1/1/2006 To: 12/31/2007	
9.a. Projected Actual Emissions (if required): 0.16 tons/year		9.b. Projected Monitoring Period: <input checked="" type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: See Table 7 of Part II.			
11. Potential, Fugitive, and Actual Emissions Comment: Baseline projected and actual emissions include 4 & 5 only.			

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]
Combustion Turbines 4A, 4B, 4C and 4D

Page [3] of [5]
VOC

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 1.4 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: 2.9 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Methods 25A or 18, initial test only	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation. Emissions rates are for each turbine. Equivalent allowable emissions based on GE data for GE7FA.04 at base load and 59° F.	

Allowable Emissions Allowable Emissions 2 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 2.9 lb/hr	4. Equivalent Allowable Emissions: 2.9 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Methods 25A or 18, initial test only	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation. Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions 3 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 1.4 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Stack test using EPA Methods 25A or 18, initial test only	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at high temperature peaking mode. In this mode each turbine operation limited to 400 hr/yr.	

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 4 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 3 lb/hr	4. Equivalent Allowable Emissions: 3 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Methods 25A or 18, initial test only	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at high temperature peaking mode. In this mode each turbine shall operate 400 hr/yr.	

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]
Combustion Turbines 4A, 4B, 4C and 4D

Page [4] of [5]
PM/PM10

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions

1. Pollutant Emitted: PM/PM10		2. Total Percent Efficiency of Control:	
3. Potential Emissions lb/hour		4. Synthetically Limited? <input type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): 287.2 tons/year		8.b. Baseline 24-month Period: From: 1/1/2006 To: 12/31/2007	
9.a. Projected Actual Emissions (if required): 287.2 tons/year		9.b. Projected Monitoring Period: <input checked="" type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: See Table 7 of Part II.			
11. Potential, Fugitive, and Actual Emissions Comment: Baseline projected and actual emissions include 4 & 5 only.			

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]
Combustion Turbines 4A, 4B, 4C and 4D

Page [4] of [5]
PM/PM10

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 10% opacity	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: EPA Method 9	
6. Allowable Emissions Comment (Description of Operating Method): Opacity used as surrogate standard for PM/PM₁₀. Permit No. 1270009-018-AV.	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [1]
 Combustion Turbines 4A, 4B, 4C and 4D

POLLUTANT DETAIL INFORMATION

Page [5] of [5]
 Sulfur Dioxide – SO₂

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions

1. Pollutant Emitted: SO₂		2. Total Percent Efficiency of Control:	
3. Potential Emissions lb/hour		tons/year	4. Synthetically Limited? <input type="checkbox"/> Yes <input type="checkbox"/> No
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): 26.5 tons/year		8.b. Baseline 24-month Period: From: 1/1/2006 To: 12/31/2007	
9.a. Projected Actual Emissions (if required): 27.2 tons/year		9.b. Projected Monitoring Period: <input checked="" type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: See Table 7 of Part II.			
11. Potential, Fugitive, and Actual Emissions Comment: Baseline projected and actual emissions include 4 & 5 only.			

EMISSIONS UNIT INFORMATION

Section [1]
 Combustion Turbines 4A, 4B, 4C and 4D

POLLUTANT DETAIL INFORMATION

Page [5] of [5]
 Sulfur Dioxide – SO2

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: Use of natural gas	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Fuel specifications	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas used as primary fuel. Permit No. 1270009-018-AV.	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [1]
 Combustion Turbines 4A, 4B, 4C and 4D

G. VISIBLE EMISSIONS INFORMATION

Complete Subsection G if this emissions unit is or would be subject to a unit-specific visible emissions limitation.

Visible Emissions Limitation: Visible Emissions Limitation 1 of 2

1. Visible Emissions Subtype: VE10	2. Basis for Allowable Opacity: <input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: 10 % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: EPA Method 9	
5. Visible Emissions Comment: Visible emission (VE) standard used as surrogate standard for minimizing PM/PM₁₀ emissions.	

Visible Emissions Limitation: Visible Emissions Limitation 2 of 2

1. Visible Emissions Subtype: VE99	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: Exceptional Conditions: 100% Maximum Period of Excess Opacity Allowed: 60 min/hour	
4. Method of Compliance: None	
5. Visible Emissions Comment: Per 62-210.700(1), F.A.C., excess emissions during startup, shutdown or malfunction limited to 2 hours per 24 hour period.	

EMISSIONS UNIT INFORMATION

Section [1]

Combustion Turbines 4A, 4B, 4C and 4D

H. CONTINUOUS MONITOR INFORMATION

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor 1 of 2

1. Parameter Code: EM	2. Pollutant(s): NOx
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: TEI Model Number: 42CLS Serial Number: 4A:76011-381, 4B:76009-381, 4C:76010-381, 4D:76008-381	
5. Installation Date: 4A:12/5/02 4B:12/7/02,4C:12/1/02,4D:12/1/02	6. Performance Specification Test Date: 4A: 5/3/03, 4B:4/24/03, 4C:4/25/03, 4D:4/25/03
7. Continuous Monitor Comment: 40 CFR Part 75 Requirement	

Continuous Monitoring System: Continuous Monitor 2 of 2

1. Parameter Code: O2	2. Pollutant(s):
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: SERVOMEX Model Number: 1440C:02D Serial Number: 4A:01420C/2557:14, 4B:01420C/2558:14, 4C:01420C/2561:14, 4D:01420C/2563:14	
5. Installation Date: 4A: 12/05/02 4B: 12/7/02 4C: 12/1/02 4D: 12/1/02	6. Performance Specification Test Date: 4A: 5/3/03 4B: 4/24/03 4C: 4/25/03 4D: 4/25/03
7. Continuous Monitor Comment: 40 CFR Part 75 Requirement	

EMISSIONS UNIT INFORMATION

Section [1]

Combustion Turbines 4A, 4B, 4C and 4D

I. EMISSIONS UNIT ADDITIONAL INFORMATION

Additional Requirements for All Applications, Except as Otherwise Stated

1. Process Flow Diagram: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date May,2009
2. Fuel Analysis or Specification: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date May,2009
3. Detailed Description of Control Equipment: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____
4. Procedures for Startup and Shutdown: (Required for all operation permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date May,2009 <input type="checkbox"/> Not Applicable (construction application)
5. Operation and Maintenance Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____ <input checked="" type="checkbox"/> Not Applicable
6. Compliance Demonstration Reports/Records: <input type="checkbox"/> Attached, Document ID: _____ Test Date(s)/Pollutant(s) Tested: _____ <input type="checkbox"/> Previously Submitted, Date: _____ Test Date(s)/Pollutant(s) Tested: _____ <input type="checkbox"/> To be Submitted, Date (if known): _____ Test Date(s)/Pollutant(s) Tested: _____ <input checked="" type="checkbox"/> Not Applicable Note: For FESOP applications, all required compliance demonstration records/reports must be submitted at the time of application. For Title V air operation permit applications, all required compliance demonstration reports/records must be submitted at the time of application, or a compliance plan must be submitted at the time of application.
7. Other Information Required by Rule or Statute: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

EMISSIONS UNIT INFORMATION

Section [2]

Combustion Turbines 5A, 5B, 5C and 5D

III. EMISSIONS UNIT INFORMATION

Title V Air Operation Permit Application - For Title V air operation permitting only, emissions units are classified as regulated, unregulated, or insignificant. If this is an application for an initial, revised or renewal Title V air operation permit, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each regulated and unregulated emissions unit addressed in this application. Some of the subsections comprising the Emissions Unit Information Section of the form are optional for unregulated emissions units. Each such subsection is appropriately marked. Insignificant emissions units are required to be listed at Section II, Subsection C.

Air Construction Permit or FESOP Application - For air construction permitting or federally enforceable state air operation permitting, emissions units are classified as either subject to air permitting or exempt from air permitting. The concept of an "unregulated emissions unit" does not apply. If this is an application for an air construction permit or FESOP, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air permitting are required to be listed at Section II, Subsection C.

Air Construction Permit and Revised/Renewal Title V Air Operation Permit Application - Where this application is used to apply for both an air construction permit and a revised or renewal Title V air operation permit, each emissions unit is classified as either subject to air permitting or exempt from air permitting for air construction permitting purposes, and as regulated, unregulated, or insignificant for Title V air operation permitting purposes. A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit addressed in this application that is subject to air construction permitting and for each such emissions unit that is a regulated or unregulated unit for purposes of Title V permitting. (An emissions unit may be exempt from air construction permitting but still be classified as an unregulated unit for Title V purposes.) Emissions units classified as insignificant for Title V purposes are required to be listed at Section II, Subsection C.

If submitting the application form in hard copy, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application must be indicated in the space provided at the top of each page.

EMISSIONS UNIT INFORMATION

Section [2]

Combustion Turbines 5A, 5B, 5C and 5D

A. GENERAL EMISSIONS UNIT INFORMATION

Title V Air Operation Permit Emissions Unit Classification

1. Regulated or Unregulated Emissions Unit? (Check one, if applying for an initial, revised or renewal Title V air operation permit. Skip this item if applying for an air construction permit or FESOP only.)

The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.

The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in this Section: (Check one)

This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).

This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.

This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

2. Description of Emissions Unit Addressed in this Section:

Units 5A – 5D: Four identical combustion turbines with unfired heat recovery steam generators

3. Emissions Unit Identification Number:

EU 009 (Unit 5A), EU 010 (Unit 5B), EU 011 (Unit 5C), EU 012 (Unit 5D)

4. Emissions Unit Status Code:
A

5. Commence Construction Date:

6. Initial Startup Date:

7. Emissions Unit Major Group SIC Code: **49**

8. Federal Program Applicability: (Check all that apply)

Acid Rain Unit CAIR Unit

9. Package Unit:

Manufacturer: **General Electric** Model Number: **MS7241, 7FA.04**

10. Generator Nameplate Rating:

11. Emissions Unit Comment:

4-on-1 combined-cycle system will consist of four nominal 170 MW GE 7FA.04 combustion turbines, four heat recovery steam generators and a nominal 320 MW steam electrical generator sets for a total nominal capacity of 1000 MW.

Initial startup dates: 21-Feb-02 (Units 5A), 25-Feb-02 (Unit 5B), 04-March-02 (Unit 5C), and 11-March-02 (Units 5D).

EMISSIONS UNIT INFORMATION

Section [2]

Combustion Turbines 5A, 5B, 5C and 5D

Emissions Unit Control Equipment/Method: Control 1 of 3

1. Control Equipment/Method Description:

Low NOx Burners - Dry low-NOx combustors for firing natural gas

2. Control Device or Method Code: **205**

Emissions Unit Control Equipment/Method: Control 2 of 3

1. Control Equipment/Method Description:

Steam or Water Injection –Use of Water injection for oil firing

2. Control Device or Method Code: **28**

Emissions Unit Control Equipment/Method: Control 3 of 3

1. Control Equipment/Method Description:

Miscellaneous Control Devices- : Use of natural gas and low sulfur distillate oil

2. Control Device or Method Code: **99**

Emissions Unit Control Equipment/Method: Control _ of _

1. Control Equipment/Method Description:

2. Control Device or Method Code:

EMISSIONS UNIT INFORMATION

Section [2]

Combustion Turbines 5A, 5B, 5C and 5D

C. EMISSION POINT (STACK/VENT) INFORMATION

(Optional for unregulated emissions units.)

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram: 5A-5D HRSG STACK		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking:			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 125 feet	7. Exit Diameter: 19 feet	
8. Exit Temperature: 220°F	9. Actual Volumetric Flow Rate: 1,053,410 acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates... Zone: 17 East (km): 468.1 North (km): 3190.86		14. Emission Point Latitude/Longitude... Latitude (DD/MM/SS) 28/50/42 N Longitude (DD/MM/SS) 81/19/37 W	
15. Emission Point Comment: <p>For each turbine:</p> <p>Flow rate (NG-firing, 59 F, base load) = 3,614,000 lb/hr (GE data) /28.39 (mol wt) x 1545.6 (gas constant) x (460+220) (temperature) /2116.8 lb/ft² (pressure) x hr/60 min = 1,053,410 acfm</p> <p>Flow rate (oil-firing, 59 F, baseload) = 3,737,000 lb/hr (GE data) /28.27 (mol wt) x 1545.6 (gas constant) x (460+220) (temperature) /2116.8 lb/ft² (pressure) x hr/60 min = 1,093,886 acfm</p>			

EMISSIONS UNIT INFORMATION

Section [2]

Combustion Turbines 5A, 5B, 5C and 5D

D. SEGMENT (PROCESS/FUEL) INFORMATION

Segment Description and Rate: Segment 1 of 2

1. Segment Description (Process/Fuel Type): Internal Combustion Engines; Electric Generation; Natural Gas Turbine		
2. Source Classification Code (SCC): 2-01-002-01	3. SCC Units: Million cubic feet burned	
4. Maximum Hourly Rate: 7.1	5. Maximum Annual Rate: 62,196	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: 1,000 (HHV)
10. Segment Comment: <p>Hourly rate = 1,776 MMBtu/hr / 1,000 MMBtu/10⁶ ft³ x 4 turbines = 7.1 x 10⁶ ft³/hr Annual rate = 7.1 x 10⁶ ft³/hr x 8,760 hrs/yr = 62,196 x 10⁶ ft³/yr</p>		

Segment Description and Rate: Segment 2 of 2

1. Segment Description (Process/Fuel Type): Internal Combustion Engine; Electric Generation; Distillate Oil (Diesel) Turbine		
2. Source Classification Code (SCC): 2-01-001-01	3. SCC Units: Thousand gallons Distillate Oil (Diesel) burned	
4. Maximum Hourly Rate: 56.76	5. Maximum Annual Rate: 28,600	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: 0.05	8. Maximum % Ash: 0	9. Million Btu per SCC Unit: 136 (HHV)
10. Segment Comment: <p>Hourly rate = 1,930 MMBtu/hr / 136 MMBtu/10³ gal x 4 turbines = 56.76 x 10³ gal/hr</p> <p>Annual rate limited to 28,600,000 gal/yr.</p>		

EMISSIONS UNIT INFORMATION

Section [2]

Combustion Turbines 5A, 5B, 5C and 5D

E. EMISSIONS UNIT POLLUTANTS

List of Pollutants Emitted by Emissions Unit

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
NOx	205,28		EL
CO			EL
PM/PM ₁₀			WP
VOC			EL
SO ₂	99		WP

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

Page [1] of [5]
 Nitrogen Oxide – NO_x

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions

1. Pollutant Emitted: NO _x		2. Total Percent Efficiency of Control:	
3. Potential Emissions lb/hour		4. Synthetically Limited? <input type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): 1328.0 tons/year		8.b. Baseline 24-month Period: From: 1/1/2006 To: 12/31/2007	
9.a. Projected Actual Emissions (if required): 1359.8 tons/year		9.b. Projected Monitoring Period: <input checked="" type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: See Table 7 of Part II.			
11. Potential, Fugitive, and Actual Emissions Comment: Baseline and projected actual emissions include Units 4 and 5 only.			

EMISSIONS UNIT INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

POLLUTANT DETAIL INFORMATION

Page [1] of [5]
 Nitrogen Oxide – NO_x

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 8

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 65 lb/hr	4. Equivalent Allowable Emissions: 65 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 7E or 20. Initial Compliance test only	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation. Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions 2 of 8

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 9 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: 60.2 lb/hour tons/year
5. Method of Compliance: CEMS data	
6. Allowable Emissions Comment (Description of Operating Method): Based on 30 day rolling average. Equivalent allowable emissions based on GE data for GE 7FA.04 at base load and 59° F	

Allowable Emissions Allowable Emissions 3 of 8

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 102 lb/hr	4. Equivalent Allowable Emissions: 102 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 7E or 20. Initial Compliance test only.	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at high temperature peaking mode. In this mode operation is limited to 400 hr/yr.	

EMISSIONS UNIT INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

POLLUTANT DETAIL INFORMATION

Page [1] of [5]
 Nitrogen Oxide – NO_x

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 4 of 8

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 15 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: CEM data	
6. Allowable Emissions Comment (Description of Operating Method): 24-Hour block average standard during NG-firing combined-cycle operation at high temperature peaking mode. In this mode operation is limited to 400 hr/yr.	

Allowable Emissions Allowable Emissions 5 of 8

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 75 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: CEM data	
6. Allowable Emissions Comment (Description of Operating Method): Based on 4 hour rolling average. 40 CFR 60 Subpart GG limit for NG firing.	

Allowable Emissions Allowable Emissions 6 of 8

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 355 lb/hr	4. Equivalent Allowable Emissions: 355 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 7E or 20. Initial Compliance test only	
6. Allowable Emissions Comment (Description of Operating Method): Oil-firing combined-cycle operation. Emissions rates are for each turbine.	

EMISSIONS UNIT INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

POLLUTANT DETAIL INFORMATION

Page [1] of [5]
 Nitrogen Oxide – NO_x

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 7 of 8

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 42 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: CEMS data	
6. Allowable Emissions Comment (Description of Operating Method): Based on 24 hour Block Average for Oil firing.	

Allowable Emissions Allowable Emissions 8 of 8

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 110 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: CEMS data	
6. Allowable Emissions Comment (Description of Operating Method): Based on 4 hour rolling for Oil firing. 40-CFR 60 Subpart GG limit for Oil firing.	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

POLLUTANT DETAIL INFORMATION

Page [2] of [5]
 Carbon Monoxide - CO

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL/ESTIMATED FUGITIVE EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions

1. Pollutant Emitted: CO		2. Total Percent Efficiency of Control:	
3. Potential Emissions lb/hour		4. Synthetically Limited? <input type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): 159.9 tons/year		8.b. Baseline 24-month Period: From: 1/1/2006 To: 12/31/2007	
9.a. Projected Actual Emissions (if required): 167.5 tons/year		9.b. Projected Monitoring Period: <input checked="" type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: See Table 7 of Part II.			
11. Potential, Fugitive, and Actual Emissions Comment: Baseline and projected actual emissions include Units 4 and 5 only.			

EMISSIONS UNIT INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

POLLUTANT DETAIL INFORMATION

Page [2] of [5]
 Carbon Monoxide – CO

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions **1** of **6**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 12 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation. Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions **2** of **6**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 43 lb/hr	4. Equivalent Allowable Emissions: 43 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation. Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions **3** of **6**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 9 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at high temperature peaking mode. In this mode each turbine operation is limited to 400 hr/yr.	

EMISSIONS UNIT INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

POLLUTANT DETAIL INFORMATION

Page [2] of [5]
 Carbon Monoxide – CO

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 4 of 6

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 29 lb/hr	4. Equivalent Allowable Emissions: 29 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at high temperature peaking mode. In this mode each turbine operation limited to 400 hr/yr.	

Allowable Emissions Allowable Emissions 5 of 6

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 20 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Annual Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): Oil-firing combined-cycle operation. Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions 6 of 6

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 71.6 lb/hr	4. Equivalent Allowable Emissions: 71.6 lb/hour tons/year
5. Method of Compliance: Annual Stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): Oil-firing combined-cycle operation. Emissions rates are for each turbine.	

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [2]
Combustion Turbines 5A, 5B, 5C and 5D

Page [3] of [5]
VOC

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 6

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 1.4 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: 2.9 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Methods 25A or 18	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation with duct burner. Emissions rates are for each turbine. Equivalent allowable emissions based on GE data for GE7FA.04 at base load and 59°F	

Allowable Emissions Allowable Emissions 2 of 6

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 2.9 lb/hr	4. Equivalent Allowable Emissions: 2.9 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Methods 25A or 18	
6. Allowable Emissions Comment (Description of Operating Method): NG-firing combined-cycle operation. Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions 3 of 6

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 1.4 ppmvd @ 15% O2	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Stack test using EPA Methods 25A or 18	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at high temperature peaking mode. In this mode each turbine shall operate 400 hr/yr.	

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

Page [3] of [5]
 VOC

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 4 of 6

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 3 lb/hr	4. Equivalent Allowable Emissions: 3 lb/hour tons/year
5. Method of Compliance: Stack test using EPA Methods 25A or 18	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas-firing combined-cycle operation. Emissions rates are for each turbine at high temperature peaking mode. In this mode each turbine shall operate 400 hr/yr.	

Allowable Emissions Allowable Emissions 5 of 6

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 7 ppmw	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Annual Stack test using EPA Methods 25A or 18	
6. Allowable Emissions Comment (Description of Operating Method): Oil-firing combined-cycle operation Emissions rates are for each turbine.	

Allowable Emissions Allowable Emissions 6 of 6

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 16.1 lb/hr	4. Equivalent Allowable Emissions: 16.1 lb/hour tons/year
5. Method of Compliance: Annual Stack test using EPA Methods 25A or 18	
6. Allowable Emissions Comment (Description of Operating Method): Oil-firing combined-cycle operation. Emissions rates are for each turbine.	

EMISSIONS UNIT INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

POLLUTANT DETAIL INFORMATION

Page [4] of [5]
 PM/PM10

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 10% opacity	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: EPA Method 9	
6. Allowable Emissions Comment (Description of Operating Method): Opacity used as surrogate standard for PM/PM₁₀. Permit No. 1270009-018-AV.	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [2]
 Combustion Turbines 5A, 5B, 5C and 5D

POLLUTANT DETAIL INFORMATION

Page [5] of [5]
 Sulfur Dioxide – SO2

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: Use of natural gas and distillate oil	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Fuel specifications	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas used as primary fuel. Use of 0.05% S distillate oil limited to 28,600,000 gal/yr for all 4 turbines combined. Permit No. 1270009-018-AV	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [2]

Combustion Turbines 5A, 5B, 5C and 5D

G. VISIBLE EMISSIONS INFORMATION

Complete Subsection G if this emissions unit is or would be subject to a unit-specific visible emissions limitation.

Visible Emissions Limitation: Visible Emissions Limitation 1 of 2

1. Visible Emissions Subtype: VE10	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: 10 % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: EPA Method 9	
5. Visible Emissions Comment: Visible emission standard used as a surrogate standard for minimizing PM/PM₁₀ emissions	

Visible Emissions Limitation: Visible Emissions Limitation 2 of 2

1. Visible Emissions Subtype: VE99	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: % Exceptional Conditions: 100% Maximum Period of Excess Opacity Allowed: 60 min/hour	
4. Method of Compliance: None	
5. Visible Emissions Comment: Per 62-210.700(1), F.A.C., excess emissions during startup, shutdown or malfunction limited to 2 hours per 24 hour period.	

EMISSIONS UNIT INFORMATION

Section [2]

Combustion Turbines 5A, 5B, 5C and 5D

H. CONTINUOUS MONITOR INFORMATION

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor 1 of 2

1. Parameter Code: EM	2. Pollutant(s): NOx
3. CMS Requirement: <input type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information... Manufacturer: TEI Model Number: 42CLS Serial Number: 5A:77996-387, 5B:77997-387, 5C:77998-387, 5D:77999-387	
5. Installation Date: 4/18/2003	6. Performance Specification Test Date: 5A&5B:4/25/03, 5C:4/29/03, 5D:5/14/03
7. Continuous Monitor Comment:	

Continuous Monitoring System: Continuous Monitor 2 of 2

1. Parameter Code: O2	2. Pollutant(s):
3. CMS Requirement: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information... Manufacturer: SERVOMEX Model Number: 1440C:02D Serial Number: 5A:01420C/1831:14, 5B:01420C/1832:14, 5C:01420C/1833:14, 5D:01420C/1834:14	
5. Installation Date: 5A: 2/21/02 5B: 2/25/02 5C: 3/14/02 5D: 3/11/02	6. Performance Specification Test Date: 5A: 2/21/02 5B: 4/30/02 5C: 5/4/02 5D: 5/10/02
7. Continuous Monitor Comment:	

EMISSIONS UNIT INFORMATION

Section [2]

Combustion Turbines 5A, 5B, 5C and 5D

I. EMISSIONS UNIT ADDITIONAL INFORMATION

Additional Requirements for All Applications, Except as Otherwise Stated

1. Process Flow Diagram: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date <u>May,2009</u>
2. Fuel Analysis or Specification: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date <u>May,2009</u>
3. Detailed Description of Control Equipment: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: ___ <input type="checkbox"/> Previously Submitted, Date _____
4. Procedures for Startup and Shutdown: (Required for all operation permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: ___ <input checked="" type="checkbox"/> Previously Submitted, Date <u>May,2009</u> <input type="checkbox"/> Not Applicable (construction application)
5. Operation and Maintenance Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: ___ <input type="checkbox"/> Previously Submitted, Date _____ <input checked="" type="checkbox"/> Not Applicable
6. Compliance Demonstration Reports/Records: <input type="checkbox"/> Attached, Document ID: _____ Test Date(s)/Pollutant(s) Tested: _____ <input type="checkbox"/> Previously Submitted, Date: _____ Test Date(s)/Pollutant(s) Tested: _____ <input type="checkbox"/> To be Submitted, Date (if known): _____ Test Date(s)/Pollutant(s) Tested: _____ <input type="checkbox"/> Not Applicable Note: For FESOP applications, all required compliance demonstration records/reports must be submitted at the time of application. For Title V air operation permit applications, all required compliance demonstration reports/records must be submitted at the time of application, or a compliance plan must be submitted at the time of application.
7. Other Information Required by Rule or Statute: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

PART II

PART II
APPLICATION FOR AIR CONSTRUCTION PERMIT
FOR IMPROVING SANFORD
UNIT 4 (EU IDS 005, 006, 007, AND 008) AND
UNIT 5 (EU IDS 009, 010, 011, AND 012)

EXECUTIVE SUMMARY

Florida Power & Light Company (FPL) is seeking authorization from the Florida Department of Environmental Protection (FDEP) to improve the performance of the General Electric (GE) Model PG7241 gas turbines (7FA.03) associated with Units 4A through 4D (EU IDs 005, 006, 007, and 008) and Units 5A through 5D (EU IDs 009, 010, 011, and 012) at the FPL Sanford Plant. The purpose of the project is to improve the performance of the GE Model PG7241 turbines with 7FA.04 components. The components being replaced are typically those requiring routine replacement due to normal operation. However, replacing the 7FA.03 components with 7FA.04 components results in higher efficiency and provides approximately a 5-percent increase in output power per turbine (3 percent for combined-cycle operation of Unit 8) with an approximate 2-percent decrease in heat rate (heat input/output power) per turbine (1-percent for combined-cycle operation).

The project will not result in a significant net increase for any regulated new source review (NSR) pollutants including greenhouse gas (GHGs) emissions regulated under EPA's Tailoring Rule, Title 40, Part 52.21 of the Code of Federal Regulations (40 CFR 52.21), and as a result, is not subject to Prevention of Significant Deterioration (PSD) review for GHGs. FPL submitted an air construction permit application for a similar combustion turbine (CT) improvement project at the FPL Martin facility in July 2011.

The 7FA.04 components have a projected design heat input capacity approximately 2-percent higher than the 7FA.03. As a result, there will be an expected increase in the design fuel flow for the units compared to the same turbine inlet temperature based on manufacturer information. In addition, hourly emissions of air pollutants regulated under FDEP and the federal PSD program that are directly related to fuel, such as sulfur dioxide (SO₂), sulfuric acid mist (SAM), and particulate matter (PM), including PM with aerodynamic diameter equal to or less than 10 or 2.5 microns (PM₁₀/PM_{2.5}), will also potentially increase. Based on GE data for the 7FA.04 components, there will be no increase in hourly mass emissions of carbon monoxide (CO) or volatile organic compounds (VOCs), and a small increase in the potential hourly mass emission rate of nitrogen oxides (NO_x); however, the increased rate will be below the currently permitted mass emission rate, and the heat input is expected to be within the current operating range. Based on the current actual-to-projected actual annual emissions test, the turbine improvement project will not result in a net increase of any regulated pollutant, nor of GHGs regulated under the Tailoring Rule, above the PSD significant emission rates.

INTRODUCTION

The Sanford Plant is located on the St. Johns River near the west side of Lake Monroe in Volusia County near the county line with Seminole County. The facility is currently operating under Title V Permit No. 1270009-018-AV.

Golder Associates Inc. (Golder) was contracted to prepare and submit the necessary air permit application seeking authorization for the turbine energy improvements and assist with any FDEP questions and additional information requests. This air permit application consists of the appropriate application form [Part I; DEP Form 62-210.900(1)], a technical description of the project, rule applicability for the project, and emissions calculations demonstrating that the proposed project will not result in a significant net emissions increase for all regulated NSR pollutants including GHGs.

Natural gas is the primary fuel for the eight gas turbines of Sanford Units 4 and 5 (four for each). The current design heat input rates for the turbines are 1,553.0 million British thermal units per hour (MMBtu/hr) [at low heat value (LHV)] (based on GE data for 7FA.03). Sanford Unit 5 is also permitted to fire distillate fuel oil as an alternative fuel when natural gas is unavailable. Sanford Unit 5 has not used distillate during the last 5 years. There will be no change in the type of permitted fuels as a result of the project. The design heat input rates for natural gas-firing and fuel oil-firing will theoretically increase by 32 MMBtu/hr (2 percent) and 35 MMBtu/hr (2 percent), respectively, based on GE data on 7FA.04 turbines at 75°F ambient temperature. Data from the National Climatic Data Center (NCDC) indicates the 30-year (1971 to 2000) average temperature for Orlando is 72.8°F. As a result, GE data for an ambient temperature of 75°F reasonably represents annual operating conditions and were used in the calculation.

The current permitted emissions limits for the Units 4 and 5 gas turbines are listed in Condition Nos. B.8 and B.9 of Title V Permit No. 1270009-018-AV. The improved 7FA.04 model turbines will guarantee the same concentration-base emissions limits for NO_x, CO, and VOC. There will also be no increase in hourly mass emission rates for CO and VOC. Based on GE performance data for the 7FA.03 and 7FA.04, the potential hourly mass emission rate of NO_x will theoretically increase from 58.6 to 60.2 pound per hour (lb/hr) (at 59°F) for natural gas-firing in Units 4 and 5 and from 326.8 to 330.3 lb/hr for oil-firing in Unit 5. On a heat input basis, the GE data indicates that only emissions of NO_x will increase (maximum of 0.27 percent) while there are no increase of the other regulated pollutants. However, the increased rates are less than the current permitted emissions rates of 65 lb/hr and 355 lb/hr for natural gas (Units 4 and 5) and fuel oil-firing (Unit 5), respectively.

There are currently no mass based emissions limits for SO₂, SAM, or PM/PM₁₀/PM_{2.5}. Since emissions of these pollutants are directly proportional to fuel flow and the proposed project will increase the design fuel flow capacity of the turbines, the potential hourly mass emission rates of these pollutants will also theoretically increase under the identical operating conditions (i.e., turbine inlet temperature, ambient

pressure, and unit operating load). Due to the improved efficiency and higher output of the energy improvements, potential emissions of all pollutants will decrease on a per megawatt-hour (MW-hr) basis.

There are currently no post-combustion control technologies for emissions of NO_x, CO, VOC, SO₂, SAM, or PM/PM₁₀/PM_{2.5}. Emissions of NO_x are controlled by dry low-NO_x (DLN) combustion technology during natural gas-firing and by water injection during fuel oil-firing (Unit 5 only). The proposed energy improvements will rely on the same existing control technologies.

PROJECT DESCRIPTION

Sanford Units 4 and 5 consist of four gas turbine electrical generator sets each, which include GE Model MS7241FA turbines/generators, heat recovery steam generators, and a steam electric generator. The proposed project will replace component parts normally associated with maintenance outages for the GE MS7241, 7FA.03 turbine with 7FA.04 components, which offer greater output and greater efficiency without sacrificing reliability, availability, or operational flexibility. The 7FA.04 components will increase the output power by approximately 5 percent (baseload with natural gas-firing at 59°F). As a result of the greater output, mass emission rates of all criteria pollutants will decrease on a per MW-hr basis.

The project will include installation of new hot gas path components, new combustion liners and flow sleeves, and new control software to increase firing temperature. The advanced gas path of 7FA.04 uses less air for cooling the parts. As a result, more air is available for combustion and power generation. The turbines will remain equipped with the DLN 2.6 combustion system, which is GE's latest evolution of DLN combustion technology.

RULE APPLICABILITY

PSD/NSR

Under federal and state of Florida PSD review requirements, all major new or modified sources of air pollutants regulated under the Clean Air Act (CAA) must be reviewed and a pre-construction permit issued. The U.S. Environmental Protection Agency (EPA) has approved Florida's State Implementation Plan (SIP), which contains PSD regulations. The applicable PSD rules in Florida are found in Rule 62-212.400, Florida Administrative Code (F.A.C.).

A "major facility" is defined as any 1 of 28 named source categories that have the potential to emit 100 tons per year (TPY) or more, or any other stationary facility that has the potential to emit 250 TPY or more, of any pollutant regulated under the CAA. "Potential to emit" means the capability, at maximum design capacity, to emit a pollutant after the application of control equipment. Once a new source is determined to be a "major facility" for a particular pollutant, any pollutant emitted in amounts greater than the PSD significant emission rates is subject to PSD review.

The Sanford Plant is an existing major facility under PSD rules. For an existing major facility for which a project is proposed, the project is subject to PSD review if the net increase in emissions due to the project is greater than the PSD significant emission rates for any applicable pollutant. A "modification" is defined in FDEP Rule 62-210.200(205), F.A.C., as "any physical change in, change in the method of operation of, or addition to a facility which would result in an increase in the actual emissions of any pollutant subject to regulation under the [Clean Air] Act, including any not previously emitted, from any emission unit or facility." Because there is a physical change and the hourly mass emission rates will potentially increase, the project is a potential modification as defined in Rules 62-210.200 and 62-212.400 (PSD), F.A.C.

To demonstrate that the proposed project is not a major modification under FDEP's PSD rules, an emissions comparison between baseline actual emissions and projected actual emissions was conducted pursuant to FDEP Rule 62-212.400(2)(1), F.A.C., for Sanford Unit 4 (Units 4A, 4B, 4C, and 4D) and Unit 5 (Units 5A, 5B, 5C, and 5D). The baseline, or current actual emissions are the emissions over a consecutive 24-month period within the 5 years immediately preceding the date that a complete application is submitted. The use of different consecutive 24-month periods for each pollutant is allowed. Projected actual emissions are maximum annual rate, in TPY, at which the existing emission unit is projected to emit a PSD pollutant in any of the 5 years following the date the unit resumes regular operation.

Table 1 presents the actual annual heat inputs from different fuels reported in the Annual Operating Reports (AORs) for the period 2006 through 2010. This table also presents the total actual heat input from all fuels for Units 4A through 4D and 5A through 5D, as well as the actual operating hours for each unit. Unit 5 did not use any fuel oil during the 5-year period.

Tables 2A and 2B summarize the annual emissions reported in the AORs for each calendar year in the period 2006 through 2010. The carbon dioxide (CO₂) emission rates in Tables 2A and 2B were obtained from EPA's acid rain database. Data from the acid rain database is presented in Appendix C.

Since emissions of nitrous oxide (N₂O) and methane (CH₄) were not reported in the AORs, they were calculated based on the actual annual heat input and emission factors from 40 CFR 98, Subpart C. These emissions are summarized in Table 3, which also shows the CO₂ equivalent (CO₂e) rates for these pollutants.

Table 4 presents the average emissions for each consecutive 2-year period based on the calendar year emissions in Tables 2A, 2B, and 3. The annual average emissions for each consecutive 2-year period are consistent with the definition of baseline actual emissions for fossil fuel-fired steam electric generating units.

The actual hourly emission rates were calculated based on the reported annual emission rates and operating hours in the AORs, which are summarized in Tables 5A and 5B for Unit 4 and Unit 5, respectively.

The actual emission factors in pounds per million British thermal units heat input (lb/MMBtu) were calculated in Table 6 for each calendar year in the period 2006 through 2010. The factors are calculated by dividing the total annual emissions by the total annual heat input, which includes both natural gas- and fuel oil-firing. The combined maximum actual emission factor for Units 4 & 5 is used in Table 7 to calculate the projected actual emission rates.

The PSD applicability analysis is presented in Table 7. The baseline emissions are obtained from Table 4, which are maximum 2-year average emissions for each pollutant. The projected annual heat input rates are obtained from Table 6, which are maximum 2-year average actual heat input rates. The actual emission factors were obtained from Table 6. The projected annual emissions are based on the projected annual heat input rates based on the highest two-year average from 2006 - 2010 multiplied by the maximum actual emission factors for Units 4 and 5 from 2006 - 2010. The emission factor for NO_x includes a 0.27-percent increase in heat input emissions (i.e., lb/MMBtu) based on GE data for 7FA.04 relative to the 7FA.03. For the other regulated pollutants, there is no increase in emissions based on heat input based on GE data. The difference between the projected actual emissions and the baseline emissions were compared to the PSD significant emission rates. As shown, all emissions increases are less than the PSD significant emission rates.

The projected increase in GHG emissions as total CO₂e is also shown in Table 7. As shown, the projected increase in all regulated pollutants including GHGs is less than the PSD significant emission rates in the EPA Tailoring Rule. As a result, the proposed project is not subject to PSD review. A minor source air construction permit application is applicable to the project.

While there is a slight project increase in GHG emissions, there is an overall reduction in heat rate British thermal units/kilowatt-hour (Btu/kWh) that reduces the amount of emissions for each megawatt-hour (MWh) generated. For example, there is an approximate 1-percent decrease in heat rate as a result of the project. As shown in Table 8, the baseline actual CO₂e emissions are approximately 5.3 million TPY. With a 1-percent reduction in heat rate for the project, the CO₂e emissions for the same amount of generation as 2008–2009 would be approximately 53,000 tons lower. Since the proposed project will increase power output, on a lb CO₂e/MWh basis, Sanford Units 4 & 5 will have less CO₂e emissions than it currently does. The output based emissions for other air emissions will also decrease on a lb/MWh basis.

NSPS

Sanford Units 4 & 5 (Units 4A through 4D and Units 5A through 5D) are currently subject to 40 CFR 60, Subpart GG, Standard of Performance for Stationary Gas Turbines. For the purpose of New Source Performance Standards (NSPS) applicability, 40 CFR 60.14 defines modification as any physical or operational change to an existing facility that results in an increase in the emission rate to the atmosphere of any pollutant to which a standard applies. 40 CFR 60.14 also states that the emission rate shall be expressed as kilograms per hour (kg/hr). NO_x and SO₂ are regulated under NSPS for Stationary Gas Turbines. Since the hourly emission rates for these pollutants may potentially increase, the proposed project is a potential modification according to the rules for NSPS. As a result, the improved Units 4 & 5 turbines may be subject to 40 CFR 60 Subpart KKKK, the revised Standard of Performance for Stationary Combustion Turbines, which applies to stationary combustion turbines with a heat input at peak load equal to greater than 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005.

After the energy improvement, the turbines will comply with the same concentration-based NO_x emissions standards they are currently subject to, which are 9 parts per million, dry volume basis, at 15-percent oxygen (ppmvd @ 15% O₂) for natural gas-firing, and 42 ppmvd @ 15% O₂ for fuel oil-firing, during combined-cycle operation.

NSPS Subpart KKKK limits NO_x emissions to 15 ppmvd @ 15% O₂ for natural gas-firing and 42 ppmvd @ 15% O₂ for fuel oil-firing for turbines with heat input rate greater than 850 MMBtu/hr (high heating value). NSPS Subpart KKKK also limits NO_x emissions to 0.43 pound per megawatt-hour (lb/MWh) for natural gas-firing and 1.3 lb/MWh for fuel oil-firing. The improved combined-cycle units will comply with these emissions standards.

The 7FA.04 improvement decreases the exhaust mass flow of the combustion turbine slightly. As a result, it is expected that the increase in NO_x emissions on a heat input basis will be offset by the slight decrease in mass flow.

For these reasons, it is believed no increase in kg/hr NO_x emissions will occur from the project. It is proposed that the first quarter of continuous emissions monitoring systems (CEMS) data be reviewed to determine if an increase has occurred. In any event, the 7FA.04 project will comply with, and be much less than, the emission limiting standards of Subpart KKKK for NO_x.

NSPS Subpart KKKK limits SO₂ emissions by limiting the sulfur in the fuel (0.06 lb/MMBtu) or based on the output (0.9 lb/MWh). Based on AOR data for the period 2006 – 2010, the current actual maximum SO₂ emission rate is 0.0006 lb/MMBtu. The potential heat input rate for the turbines will increase by approximately 2 percent. SO₂ emissions are directly proportional to heat input for the same sulfur content

of fuel and the lb/MMBtu rate is expected to remain the same. Since natural gas is the primary fuel, the amount of sulfur will vary slightly. As a result, the projected minor increase in heat input may not increase emissions based on the normal variability of sulfur in natural gas. Indeed, Section 60.14(2) of 40 CFR 60 recognizes the potential for statistical variability in determining an increase in kg/hr (i.e., Appendix C of 40 CFR 60). For this reason, the first quarter of sulfur content data will be reviewed to determine if an increase in kg/hr SO₂ emissions has occurred. In any event, the 7FA.04 project will comply with the emission limiting standards of Subpart KKKK for SO₂.

PROPOSED CHANGES TO EXISTING PERMIT CONDITIONS

The Sanford Plant is currently operating under Title V Air Operating Permit No. 1270009-018-AV. Condition No. B.8 of Title V permit lists the natural gas-firing emissions limitations and standards, and Table B.9 lists the fuel oil-firing emissions limitations and standards. NO_x, CO, and VOC are the three pollutants with concentration-based and mass emissions limits, which are based on GE performance data for baseload operation at 59°F ambient temperature. Based on GE data, the improved turbines will achieve the same concentration-based emissions and same mass emission rates for CO and VOC. Therefore, FPL is requesting no change to the existing emissions limits for CO and VOC, and the same concentration-based limits for NO_x. Based on GE data, the mass emission rate potential for NO_x could theoretically slightly increase. However, the slightly increased NO_x hourly emissions rates are well within the current maximum hourly emission rates and will be less than the currently permitted hourly mass emissions rates. Therefore, FPL is requesting no change to the existing NO_x emissions limits.

The GE data sheets for the 7FA.03 and 7FA.04 are presented in Appendix C. It should be noted that the NO_x mass emissions in the data sheets are used only for comparison with annual emissions tests (baseline-to-projected actual). The hourly mass emission rates also vary significantly with compressor inlet temperature, unit load, etc. while the concentration-based rates remain the same. As shown in the CEM data for 2010 in Appendix D, the actual mass emission rates varied significantly for same heat input rates. As a result, although the design mass emission rates in the GE data sheet for 7FA.04 are slightly higher than the rates in the data sheet for 7FA.03, actual hourly emissions (lb/hr or kg/hr) are not expected to increase. It should also be noted that the hourly mass emission limits are for initial compliance only. Continuous compliance is based on concentration-based limits of 9 ppmvd and 42 ppmvd corrected to 15% O₂ for natural gas and oil, respectively while operating in baseload conditions.

FPL also requests no change to the turbine heat input rates in permit No. 1270001-021-AV. Although the GE data sheet for 7FA.04 theoretically shows a slightly higher heat input rate than the rates in the data sheet for 7FA.03, the small increase is within the normal operating heat input range for the CTs.

TABLES

Table 1. Sanford Units 4 and 5 Annual Heat Inputs and Operating Hours, 2006 - 2010

UNIT 4

Year	Heat Input from Distillate Oil (Diesel) (MMBtu/yr)					Heat Input from Natural Gas (MMBtu/yr)					Total Actual Heat Input (MMBtu/yr)				
	Unit 4A	Unit 4B	Unit 4C	Unit 4D	Total	Unit 4A	Unit 4B	Unit 4C	Unit 4D	Total	Unit 4A	Unit 4B	Unit 4C	Unit 4D	Total
2010	NA	NA	NA	NA	NA	10,278,000	10,401,000	9,867,000	9,586,000	40,132,000	10,278,000	10,401,000	9,867,000	9,586,000	40,132,000
2009	NA	NA	NA	NA	NA	9,203,000	9,920,000	10,135,000	10,061,000	39,319,000	9,203,000	9,920,000	10,135,000	10,061,000	39,319,000
2008	NA	NA	NA	NA	NA	10,123,000	11,163,000	9,788,000	9,834,000	40,908,000	10,123,000	11,163,000	9,788,000	9,834,000	40,908,000
2007	NA	NA	NA	NA	NA	10,966,000	10,798,000	11,095,000	10,801,000	43,660,000	10,966,000	10,798,000	11,095,000	10,801,000	43,660,000
2006	NA	NA	NA	NA	NA	11,596,000	10,251,000	11,949,000	11,610,000	45,406,000	11,596,000	10,251,000	11,949,000	11,610,000	45,406,000

Note: Unit 4 is not authorized to use distillate oil.

UNIT 5

Year	Heat Input from Distillate Oil (Diesel) (MMBtu/yr)					Heat Input from Natural Gas (MMBtu/yr)					Total Actual Heat Input (MMBtu/yr)				
	Unit 5A	Unit 5B	Unit 5C	Unit 5D	Total	Unit 5A	Unit 5B	Unit 5C	Unit 5D	Total	Unit 5A	Unit 5B	Unit 5C	Unit 5D	Total
2010	0	0	0	0	0	10,708,000	9,747,000	10,377,000	8,122,000	38,954,000	10,708,000	9,747,000	10,377,000	8,122,000	38,954,000
2009	0	0	0	0	0	11,493,000	10,081,000	9,822,000	10,072,000	41,468,000	11,493,000	10,081,000	9,822,000	10,072,000	41,468,000
2008	0	0	0	0	0	8,403,000	10,520,000	8,951,000	9,977,000	37,851,000	8,403,000	10,520,000	8,951,000	9,977,000	37,851,000
2007	0	0	0	0	0	11,058,000	11,292,000	11,552,000	9,722,000	43,624,000	11,058,000	11,292,000	11,552,000	9,722,000	43,624,000
2006	0	0	0	0	0	11,769,000	8,937,000	9,490,000	11,146,000	41,342,000	11,769,000	8,937,000	9,490,000	11,146,000	41,342,000

UNIT 4

Year	Distillate Oil Operating Hours (hr/yr)					Natural Gas Operating Hours (hr/yr)					Total Actual Operating Hours (hr/yr)				
	Unit 4A	Unit 4B	Unit 4C	Unit 4D	Total	Unit 4A	Unit 4B	Unit 4C	Unit 4D	Total	Unit 4A	Unit 4B	Unit 4C	Unit 4D	Total
2010	NA	NA	NA	NA	NA	7,257	7,344	7,007	6,854	28,462	7,257	7,344	7,007	6,854	28,462
2009	NA	NA	NA	NA	NA	6,473	6,982	7,101	7,036	27,592	6,473	6,982	7,101	7,036	27,592
2008	NA	NA	NA	NA	NA	7,174	7,829	6,897	6,937	28,837	7,174	7,829	6,897	6,937	28,837
2007	NA	NA	NA	NA	NA	7,575	7,455	7,674	7,448	30,152	7,575	7,455	7,674	7,448	30,152
2006	NA	NA	NA	NA	NA	7,797	6,899	8,035	7,783	30,514	7,797	6,899	8,035	7,783	30,514

Note: Unit 4 is not authorized to use distillate oil.

UNIT 5

Year	Distillate Oil Operating Hours (hr/yr)					Natural Gas Operating Hours (hr/yr)					Total Actual Operating Hours (hr/yr)				
	Unit 5A	Unit 5B	Unit 5C	Unit 5D	Total	Unit 5A	Unit 5B	Unit 5C	Unit 5D	Total	Unit 5A	Unit 5B	Unit 5C	Unit 5D	Total
2010	0	0	0	0	0	7,535	6,933	7,348	5,830	27,646	7,535	6,933	7,348	5,830	27,646
2009	0	0	0	0	0	8,004	7,129	6,924	7,116	29,173	8,004	7,129	6,924	7,116	29,173
2008	0	0	0	0	0	6,002	7,494	6,424	7,135	27,055	6,002	7,494	6,424	7,135	27,055
2007	0	0	0	0	0	7,559	7,703	7,883	6,640	29,785	7,559	7,703	7,883	6,640	29,785
2006	0	0	0	0	0	7,956	6,050	6,438	7,525	27,969	7,956	6,050	6,438	7,525	27,969

Note: All values are based on annual operating reports for the period 2006 - 2010.

Table 2A. Annual Emissions Reported in 2006-2010 Annual Operating Reports and Acid Rain Database for Unit 4

Year	Pollutant	Unit 4A (tons)	Unit 4B (tons)	Unit 4C (tons)	Unit 4D (tons)	Total (tons)
2010	NO _x	150.3	153.9	150.9	151.7	606.8
	CO	10.1	6.8	5.2	7.4	29.4
	SO ₂	3.1	3.1	3.0	2.9	12.1
	VOC	0.02	0.03	0.01	0.02	0.1
	PM	33.9	34.3	32.6	31.6	132.4
	PM ₁₀	33.9	34.3	32.6	31.6	132.4
	SAM ^a	--	--	--	--	1.9
	CO ₂	613,261.6	620,409.5	590,324.7	571,873.6	2,395,869.4
2009	NO _x	135.5	150.3	150.6	151.9	588.3
	CO	11.2	12.1	11.6	10.0	44.9
	SO ₂	2.7	3.0	3.1	3.1	11.9
	VOC	0.02	0.02	0.01	0.02	0.1
	PM ^b	30.37	32.74	33.45	33.20	129.8
	PM ₁₀ ^b	30.37	32.74	33.45	33.20	129.8
	SAM ^a	--	--	--	--	1.8
	CO ₂	551,117.2	593,423.4	604,529.6	596,984.6	2,346,054.9
2008	NO _x	143.1	173.9	145.9	147.7	610.6
	CO	4.6	5.8	5.1	5.0	20.6
	SO ₂	3.1	3.4	3.0	3.6	13.1
	VOC	0.02	0.03	0.01	0.02	0.1
	PM	33.4	36.8	32.3	32.5	135.0
	PM ₁₀	33.4	36.8	32.3	32.5	135.0
	SAM ^a	--	--	--	--	2.0
	CO ₂	611,095.3	677,165.5	580,004.2	581,998.8	2,450,263.9
2007	NO _x	159.0	172.8	149.8	178.2	659.8
	CO	21.2	19.0	21.5	20.7	82.4
	SO ₂	3.2	3.3	3.3	3.3	13.1
	VOC	0.02	0.03	0.02	0.02	0.1
	PM ^b	36.19	35.63	36.61	35.64	144.1
	PM ₁₀ ^b	36.19	35.63	36.61	35.64	144.1
	SAM ^a	--	--	--	--	2.0
	CO ₂	651,051.8	648,224.6	656,150.8	636,649.7	2,592,076.9
2006	NO _x	191.3	158.9	179.2	185.8	715.2
	CO	19.6	16.2	20.7	19.2	75.7
	SO ₂	3.6	3.2	3.6	3.5	13.9
	VOC	0.02	0.02	0.02	0.02	0.1
	PM	38.3	33.8	39.4	38.3	149.8
	PM ₁₀	38.3	33.8	39.4	38.3	149.8
	SAM ^a	--	--	--	--	2.1
	CO ₂	707,205.6	620,923.8	720,455.0	694,044.5	2,742,628.8

^a Not reported in AORs - based on assuming 10% of SO₂ converts to SO₃, all of which converts to SAM.

^b Emissions rates reported in the AORs were multiplied by 1000 to correct error in the emission factor used in the AORs for 2007 and 2009.

Source: Annual Operating Report (AOR) for Sanford Power Plant, 2006 - 2010; EPA's Acid Rain database.

Table 2B. Annual Emissions Reported in 2006-2010 Annual Operating Reports and Acid Rain Database for Unit 5

Year	Pollutant	Unit 4A (tons)	Unit 4B (tons)	Unit 4C (tons)	Unit 4D (tons)	Total (tons)
2010	NO _x	159.4	151.0	159.4	130.2	600.0
	CO	8.9	7.5	7.2	5.8	29.4
	SO ₂	3.2	3.0	3.2	2.5	11.9
	VOC	0.02	0.02	0.01	0.01	0.1
	PM	35.3	32.2	34.2	26.8	128.5
	PM ₁₀	35.3	32.2	34.2	26.8	128.5
	SAM ^a	--	--	--	--	1.8
	CO ₂	648,390.1	594,791.6	623,134.4	485,777.2	2,352,093.3
2009	NO _x	176.2	158.2	156.1	153.0	643.5
	CO	8.0	6.5	7.7	6.4	28.6
	SO ₂	3.5	3.1	3.0	3.1	12.7
	VOC	0.02	0.02	0.01	0.01	0.1
	PM ^b	37.93	33.27	32.41	33.24	136.8
	PM ₁₀ ^b	37.93	33.27	32.41	33.24	136.8
	SAM ^a	--	--	--	--	1.9
	CO ₂	685,666.7	599,196.9	589,903.1	602,803.1	2,477,569.8
2008	NO _x	128.9	162.8	144.9	155.4	592.0
	CO	3.7	6.3	6.0	3.4	19.4
	SO ₂	2.6	3.2	2.7	3.0	11.5
	VOC	0.01	0.02	0.01	0.01	0.1
	PM	27.7	34.7	29.5	32.9	124.9
	PM ₁₀	27.7	34.7	29.5	32.9	124.9
	SAM ^a	--	--	--	--	1.8
	CO ₂	505,467.4	627,111.5	543,117.9	597,176.8	2,272,873.6
2007	NO _x	171.4	169.4	167.5	136.1	644.4
	CO	20.8	22.6	22.7	19.5	85.6
	SO ₂	3.3	3.4	3.5	3.1	13.3
	VOC	0.02	0.02	0.02	0.01	0.1
	PM ^b	36.49	37.26	38.12	32.08	144.0
	PM ₁₀ ^b	36.49	37.26	38.12	32.08	144.0
	SAM ^a	--	--	--	--	2.0
	CO ₂	652,435.3	663,979.4	696,238.3	591,622.9	2,604,275.9
2006	NO _x	194.2	138.5	142.4	161.6	636.7
	CO	21.5	17.7	17.1	19.9	76.2
	SO ₂	3.6	2.7	2.9	3.4	12.6
	VOC	0.02	0.02	0.01	0.02	0.1
	PM	38.8	29.5	31.3	36.8	136.4
	PM ₁₀	38.8	29.5	31.3	36.8	136.4
	SAM ^a	--	--	--	--	1.9
	CO ₂	721,820.1	530,281.0	571,682.9	665,715.6	2,489,499.6

^a Not reported in AORs - based on assuming 10% of SO₂ converts to SO₃, all of which converts to SAM.

^b Emissions rates reported in the AORs were multiplied by 1000 to correct error in the emission factor used in the AORs for 2007 and 2009.

Source: Annual Operating Report (AOR) for Sanford Power Plant, 2006 - 2010; EPA's Acid Rain database.

**Table 3. Actual Annual Emissions of N₂O and CH₄ for the Period 2006 - 2010
Units 4 & 5 CT Improvement Project**

Unit	Actual Annual Heat Input ^a (MMBtu/yr)	N ₂ O Emissions				CH ₄ Emissions			
		Emission Factor ^b (lb/MMBtu)	Annual Emissions		CO ₂ e ^c Rate (TPY)	Emission Factor ^b (lb/MMBtu)	Annual Emissions		CO ₂ e ^c Rate (TPY)
			(lb/yr)	(TPY)			(lb/yr)	(TPY)	
<i>Unit 4 - Natural Gas-Firing</i>									
2010	40,132,000	2.20E-04	8,845.1	4.4	1,371.0	2.2E-03	88,450.9	44.2	928.7
2009	39,319,000	2.20E-04	8,665.9	4.3	1,343.2	2.2E-03	86,659.1	43.3	909.9
2008	40,908,000	2.20E-04	9,016.1	4.5	1,397.5	2.2E-03	90,161.2	45.1	946.7
2007	43,660,000	2.20E-04	9,622.7	4.8	1,491.5	2.2E-03	96,226.6	48.1	1,010.4
2006	45,406,000	2.20E-04	10,007.5	5.0	1,551.2	2.2E-03	100,074.8	50.0	1,050.8
<i>Unit 5 - Natural Gas-Firing</i>									
2010	38,954,000	2.20E-04	8,585.5	4.3	1,330.7	2.2E-03	85,854.6	42.9	901.5
2009	41,468,000	2.20E-04	9,139.5	4.6	1,416.6	2.2E-03	91,395.5	45.7	959.7
2008	37,851,000	2.20E-04	8,342.4	4.2	1,293.1	2.2E-03	83,423.6	41.7	875.9
2007	43,624,000	2.20E-04	9,614.7	4.8	1,490.3	2.2E-03	96,147.3	48.1	1,009.5
2006	41,342,000	2.20E-04	9,111.8	4.6	1,412.3	2.2E-03	91,117.8	45.6	956.7
<i>Total</i>									
2010	--	--	--	8.7	2,701.7	--	--	87.2	1,830.2
2009	--	--	--	8.9	2,759.8	--	--	89.0	1,869.6
2008	--	--	--	8.7	2,690.6	--	--	86.8	1,822.6
2007	--	--	--	9.6	2,981.8	--	--	96.2	2,019.9
2006	--	--	--	9.6	2,963.5	--	--	95.6	2,007.5

^a Based on AOR data - see Table 1.

^b Table G-2, Subpart C, 40 CFR 98. Emission factors in kg/MMBtu were converted to lb/MMBtu by multiplying by 2.204.

^c N₂O and CH₄ are multiplied by a factor of 310 and 21, respectively, to determine CO₂ equivalence.

Table 4. Annual Average Emissions for Sanford Units 4 & 5 for Each Consecutive Two-Year Period, 2006-2010

Pollutant	Annual Emissions for Units 4 & 5					Two-Year Average Emissions			
	2010	2009	2008	2007	2007	2010-2009 (tons)	2009-2008 (tons)	2008-2007 (tons)	2007-2006 (tons)
NO _x	1,206.8	1,231.8	1,202.6	1,304.2	1,351.9	1,219.3	1,217.2	1,253.4	1,328.0
CO	58.8	73.5	40.0	168.0	151.9	66.2	56.8	104.0	159.9
SO ₂	24.0	24.6	24.6	26.4	26.5	24.3	24.6	25.5	26.5
VOC	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
PM	261.0	266.6	259.9	288.0	286.3	263.8	263.3	274.0	287.2
PM ₁₀	261.0	266.6	259.9	288.0	286.3	263.8	263.3	274.0	287.2
PM _{2.5} ^a	261.0	266.6	259.9	288.0	286.3	263.8	263.3	274.0	287.2
SAM ^b	3.7	3.8	3.8	4.0	4.1	3.7	3.8	3.9	4.1
CO ₂	4,747,962.7	4,823,624.7	4,723,137.5	5,196,352.8	5,232,128.4	4,785,793.7	4,773,381.1	4,959,745.1	5,214,240.6
N ₂ O ^c (CO ₂ e)	2,701.7	2,759.8	2,690.6	2,981.8	2,963.5	2,730.8	2,725.2	2,836.2	2,972.6
CH ₄ ^c (CO ₂ e)	1,830.2	1,869.6	1,822.6	2,019.9	2,007.5	1,849.9	1,846.1	1,921.3	2,013.7

^a Assuming equal to PM₁₀ emissions.

^b Not reported in AORs - based on assuming 10% of SO₂ converts to SO₃, all of which converts to SAM.

^c Calculated based on actual annual heat input - see Table 3.

Source: Annual Operating Report (AOR) for Sanford Power Plant, 2006 - 2010; EPA's Acid Rain database.

Table 5A. Actual Hourly Emission Rates, FPL Sanford Units 4A, 4B, 4C, and 4D

Pollutant	Year	Annual Emissions ^a (tons)				Operating Hours ^a				Hourly Emission Rates (lb/hr)				Maximum Rate (lb/hr)
		Unit 4A	Unit 4B	Unit 4C	Unit 4D	Unit 4A	Unit 4B	Unit 4C	Unit 4D	Unit 4A	Unit 4B	Unit 4C	Unit 4D	
NO _x	2010	150.3	153.9	150.9	151.7	7,257	7,344	7,007	6,854	41.4	41.9	43.1	44.3	49.1
	2009	135.5	150.3	150.6	151.9	6,473	6,982	7,101	7,036	41.9	43.1	42.4	43.2	
	2008	143.1	173.9	145.9	147.7	7,174	7,829	6,897	6,937	39.9	44.4	42.3	42.6	
	2007	159.0	172.8	149.8	178.2	7,575	7,455	7,674	7,448	42.0	46.3	39.0	47.9	
	2006	191.3	158.9	179.2	185.8	7,797	6,899	8,035	7,783	49.1	46.1	44.6	47.7	
										Maximum =	49.1	46.3	44.6	
CO	2010	10.1	6.8	5.2	7.4	7,257	7,344	7,007	6,854	2.8	1.8	1.5	2.2	5.6
	2009	11.2	12.1	11.6	10.0	6,473	6,982	7,101	7,036	3.5	3.5	3.3	2.8	
	2008	4.6	5.8	5.1	5.0	7,174	7,829	6,897	6,937	1.3	1.5	1.5	1.5	
	2007	21.2	19.0	21.5	20.7	7,575	7,455	7,674	7,448	5.6	5.1	5.6	5.6	
	2006	19.6	16.2	20.7	19.2	7,797	6,899	8,035	7,783	5.0	4.7	5.1	4.9	
										Maximum =	5.6	5.1	5.6	
VOC	2010	0.022	0.026	0.014	0.021	7,257	7,344	7,007	6,854	0.0	0.0	0.0	0.0	0.0
	2009	0.019	0.024	0.014	0.021	6,473	6,982	7,101	7,036	0.0	0.0	0.0	0.0	
	2008	0.022	0.027	0.014	0.021	7,174	7,829	6,897	6,937	0.0	0.0	0.0	0.0	
	2007	0.023	0.026	0.015	0.022	7,575	7,455	7,674	7,448	0.0	0.0	0.0	0.0	
	2006	0.023	0.024	0.016	0.023	7,797	6,899	8,035	7,783	0.0	0.0	0.0	0.0	
										Maximum =	0.0	0.0	0.0	
SO ₂	2010	3.1	3.1	3.0	2.9	7,257	7,344	7,007	6,854	0.9	0.8	0.9	0.8	1.0
	2009	2.7	3.0	3.1	3.1	6,473	6,982	7,101	7,036	0.8	0.9	0.9	0.9	
	2008	3.1	3.4	3.0	3.6	7,174	7,829	6,897	6,937	0.9	0.9	0.9	1.0	
	2007	3.2	3.3	3.3	3.3	7,575	7,455	7,674	7,448	0.8	0.9	0.9	0.9	
	2006	3.6	3.2	3.6	3.5	7,797	6,899	8,035	7,783	0.9	0.9	0.9	0.9	
										Maximum =	0.9	0.9	0.9	
PM/PM ₁₀ /PM _{2.5}	2010	33.9	34.3	32.6	31.6	7,257	7,344	7,007	6,854	9.3	9.3	9.3	9.2	9.8
	2009	30.37	32.74	33.45	33.20	6,473	6,982	7,101	7,036	9.4	9.4	9.4	9.4	
	2008	33.4	36.8	32.3	32.5	7,174	7,829	6,897	6,937	9.3	9.4	9.4	9.4	
	2007	36.19	35.63	36.61	35.64	7,575	7,455	7,674	7,448	9.6	9.6	9.5	9.6	
	2006	38.3	33.8	39.4	38.3	7,797	6,899	8,035	7,783	9.8	9.8	9.8	9.8	
										Maximum =	9.8	9.8	9.8	

^a Reported in AORs for the period 2006 - 2010.

Table 5B. Actual Hourly Emission Rates, FPL Sanford Units 5A, 5B, 5C, and 5D

Pollutant	Year	Annual Emissions ^a (tons)				Operating Hours ^a				Hourly Emission Rates (lb/hr)				Maximum Rate (lb/hr)
		Unit 4A	Unit 4B	Unit 4C	Unit 4D	Unit 4A	Unit 4B	Unit 4C	Unit 4D	Unit 4A	Unit 4B	Unit 4C	Unit 4D	
NO _x	2010	159.4	151.0	159.4	130.2	7,535	6,933	7,348	5,830	42.3	43.6	43.4	44.7	48.8
	2009	176.2	158.2	156.1	153.0	8,004	7,129	6,924	7,116	44.0	44.4	45.1	43.0	
	2008	128.9	162.8	144.9	155.4	6,002	7,494	6,424	7,135	43.0	43.4	45.1	43.6	
	2007	171.4	169.4	167.5	136.1	7,559	7,703	7,883	6,640	45.3	44.0	42.5	41.0	
	2006	194.2	138.5	142.4	161.6	7,956	6,050	6,438	7,525	48.8	45.8	44.2	43.0	
										Maximum =	48.8	45.8	45.1	
CO	2010	8.9	7.5	7.2	5.8	7,535	6,933	7,348	5,830	2.4	2.2	2.0	2.0	5.9
	2009	8.0	6.5	7.7	6.4	8,004	7,129	6,924	7,116	2.0	1.8	2.2	1.8	
	2008	3.7	6.3	6.0	3.4	6,002	7,494	6,424	7,135	1.2	1.7	1.9	1.0	
	2007	20.8	22.6	22.7	19.5	7,559	7,703	7,883	6,640	5.5	5.9	5.8	5.9	
	2006	21.5	17.7	17.1	19.9	7,956	6,050	6,438	7,525	5.4	5.9	5.3	5.3	
										Maximum =	5.5	5.9	5.8	
VOC	2010	0.015	0.017	0.015	0.012	7,535	6,933	7,348	5,830	0.0	0.0	0.0	0.0	0.0
	2009	0.016	0.018	0.014	0.014	8,004	7,129	6,924	7,116	0.0	0.0	0.0	0.0	
	2008	0.012	0.019	0.013	0.014	6,002	7,494	6,424	7,135	0.0	0.0	0.0	0.0	
	2007	0.015	0.019	0.016	0.013	7,559	7,703	7,883	6,640	0.0	0.0	0.0	0.0	
	2006	0.016	0.015	0.013	0.015	7,956	6,050	6,438	7,525	0.0	0.0	0.0	0.0	
										Maximum =	0.0	0.0	0.0	
SO ₂	2010	3.2	3.0	3.2	2.5	7,535	6,933	7,348	5,830	0.8	0.9	0.9	0.9	0.9
	2009	3.5	3.1	3.0	3.1	8,004	7,129	6,924	7,116	0.9	0.9	0.9	0.9	
	2008	2.6	3.2	2.7	3.0	6,002	7,494	6,424	7,135	0.9	0.9	0.8	0.8	
	2007	3.3	3.4	3.5	3.1	7,559	7,703	7,883	6,640	0.9	0.9	0.9	0.9	
	2006	3.6	2.7	2.9	3.4	7,956	6,050	6,438	7,525	0.9	0.9	0.9	0.9	
										Maximum =	0.9	0.9	0.9	
PM/PM ₁₀ /PM _{2.5}	2010	35.3	32.2	34.2	26.8	7,535	6,933	7,348	5,830	9.4	9.3	9.3	9.2	9.8
	2009	37.93	33.27	32.41	33.24	8,004	7,129	6,924	7,116	9.5	9.3	9.4	9.3	
	2008	27.7	34.7	29.5	32.9	6,002	7,494	6,424	7,135	9.2	9.3	9.2	9.2	
	2007	36.49	37.26	38.12	32.08	7,559	7,703	7,883	6,640	9.7	9.7	9.7	9.7	
	2006	38.8	29.5	31.3	36.8	7,956	6,050	6,438	7,525	9.8	9.7	9.7	9.8	
										Maximum =	9.8	9.7	9.7	

^a Reported in AORs for the period 2006 - 2010.

Table 6. Sanford Units 4 and 5 Actual Emissions as a Function of Heat Input, 2006 - 2010

UNIT 4

Year	Actual Annual Heat Input (MMBtu/yr) ^a					Units 4A, 4B, 4C, & 4D Total Actual Emissions (TPY) ^b							Emissions per Unit Heat Input ^c (lb/MMBtu)						
	Unit 4A	Unit 4B	Unit 4C	Unit 4D	Total	NO _x	CO	VOC	SO ₂	PM/PM ₁₀	SAM	CO ₂	NO _x	CO	VOC	SO ₂	PM/PM ₁₀	SAM	CO ₂
2010	10,278,000	10,401,000	9,867,000	9,586,000	40,132,000	606.8	29.4	0.1	12.1	132.4	1.9	2,395,869.4	0.0302	0.0015	0.0000	0.0006	0.0066	0.0001	119.4
2009	9,203,000	9,920,000	10,135,000	10,061,000	39,319,000	588.3	44.9	0.1	11.9	129.8	1.8	2,346,054.9	0.0299	0.0023	0.0000	0.0006	0.0066	0.0001	119.3
2008	10,123,000	11,163,000	9,788,000	9,834,000	40,908,000	610.6	20.6	0.1	13.1	135.0	2.0	2,450,263.9	0.0299	0.0010	0.0000	0.0006	0.0066	0.0001	119.8
2007	10,966,000	10,798,000	11,095,000	10,801,000	43,660,000	659.8	82.4	0.1	13.1	144.1	2.0	2,592,076.9	0.0302	0.0038	0.0000	0.0006	0.0066	0.0001	118.7
2006	11,596,000	10,251,000	11,949,000	11,610,000	45,406,000	715.2	75.7	0.1	13.9	149.8	2.1	2,742,628.8	0.0315	0.0033	0.0000	0.0006	0.0066	0.0001	120.8
												Maximum =	0.0315	0.0038	0.0000	0.0006	0.0066	0.0001	120.8

UNIT 5

Year	Actual Annual Heat Input (MMBtu/yr) ^a					Units 5A, 5B, 5C, & 5D Total Actual Emissions (TPY) ^b							Emissions per Unit Heat Input ^c (lb/MMBtu)						
	Unit 5A	Unit 5B	Unit 5C	Unit 5D	Total	NO _x	CO	VOC	SO ₂	PM/PM ₁₀	SAM	CO ₂	NO _x	CO	VOC	SO ₂	PM/PM ₁₀	SAM	CO ₂
2010	10,708,000	9,747,000	10,377,000	8,122,000	38,954,000	600.0	29.4	0.1	11.9	128.5	1.8	2,352,093.3	0.0308	0.0015	0.0000	0.0006	0.0066	0.0001	120.8
2009	11,493,000	10,081,000	9,822,000	10,072,000	41,468,000	643.5	28.6	0.1	12.7	136.8	1.9	2,477,569.8	0.0310	0.0014	0.0000	0.0006	0.0066	0.0001	119.5
2008	8,403,000	10,520,000	8,951,000	9,977,000	37,851,000	592.0	19.4	0.1	11.5	124.9	1.8	2,272,873.6	0.0313	0.0010	0.0000	0.0006	0.0066	0.0001	120.1
2007	11,058,000	11,292,000	11,552,000	9,722,000	43,624,000	644.4	85.6	0.1	13.3	144.0	2.0	2,604,275.9	0.0295	0.0039	0.0000	0.0006	0.0066	0.0001	119.4
2006	11,769,000	8,937,000	9,490,000	11,146,000	41,342,000	636.7	76.2	0.1	12.6	136.4	1.9	2,489,499.6	0.0308	0.0037	0.0000	0.0006	0.0066	0.0001	120.4
												Maximum =	0.0313	0.0039	0.0000	0.0006	0.0066	0.0001	120.8

Units 4 & 5

Year	Units 4 & 5 Total Actual Annual Heat Input (MMBtu/yr) ^a					Units 4 & 5 Total Actual Emissions (TPY) ^b							Emissions per Unit Heat Input ^c (lb/MMBtu)						
					Total	NO _x	CO	VOC	SO ₂	PM/PM ₁₀	SAM	CO ₂	NO _x	CO	VOC	SO ₂	PM/PM ₁₀	SAM	CO ₂
2010	--	--	--	--	79,086,000	1,206.8	58.8	0.1	24.0	261.0	3.7	4,747,963	0.0305	0.0015	0.0000	0.0006	0.0066	0.0001	120.1
2009	--	--	--	--	80,787,000	1,231.8	73.5	0.1	24.6	266.6	3.8	4,823,625	0.0305	0.0018	0.0000	0.0006	0.0066	0.0001	119.4
2008	--	--	--	--	78,759,000	1,202.6	40.0	0.1	24.6	259.9	3.8	4,723,137	0.0305	0.0010	0.0000	0.0006	0.0066	0.0001	119.9
2007	--	--	--	--	87,284,000	1,304.2	168.0	0.1	26.4	288.0	4.0	5,196,353	0.0299	0.0038	0.0000	0.0006	0.0066	0.0001	119.1
2006	--	--	--	--	86,748,000	1,351.9	151.9	0.1	26.5	286.3	4.1	5,232,128	0.0312	0.0035	0.0000	0.0006	0.0066	0.0001	120.6
												Maximum =	0.0312	0.0038	0.0000	0.0006	0.0066	0.0001	120.6

^a Based on AOR data, see Table 1.

^b Based on AOR data, see Table 2.

^c Total actual emissions divided by total heat input.

**Table 7. PSD Applicability - Sanford Units 4 and 5
GE 7FA.04 Improvements**

Pollutant	Baseline Actual Emissions ^a (TPY)	Actual Emission Factor ^b (lb/MMBtu)	Projected Actual Heat Input ^c (MMBtu)	Projected Actual Emissions ^d (TPY)	Increase/Decrease in Annual Emissions ^e (TPY)	PSD Significant Emission Rates (TPY)
NO _x	1,328.05	0.0313	87,016,000	1,359.8	31.8	40
CO	159.94	0.0038	87,016,000	167.5	7.5	100
SO ₂	26.45	0.0006	87,016,000	27.2	0.7	40
VOC	0.15	3.59E-06	87,016,000	0.16	0.01	40
PM	287.15	0.0066	87,016,000	287.2	0.001	25
PM ₁₀	287.15	0.0066	87,016,000	287.2	0.001	15
PM _{2.5}	287.15	0.0066	87,016,000	287.2	0.001	10
SAM	4.05	0.0001	87,016,000	4.2	0.11	7
GHGs						
CO ₂	5,214,240.6	120.6	87,016,000	5,248,292.6	34,052.0	
N ₂ O (CO ₂ e)	2,972.6	9.04E-02	87,016,000	3,931.6	958.9	
CH ₄ (CO ₂ e)	2,013.7	4.63E-02	87,016,000	2,013.7	0.0	
Total GHGs (CO₂e)	5,219,227.0			5,254,237.9	35,010.9	75,000

^a Maximum 2-Year average emissions - see Tables 4.

^b Maximum actual emission factor for the period 2006-2010 for Units 4 & 5 total - see Table 6. Emission factor for NO_x includes a 0.27-percent increase based on GE data for 7FA.04 CTs.

^c Maximum 2-year average heat input for 2006-2010 for Units 4 & 5 - see Table 6.

^d Projected actual emissions = Emission factor x Projected actual heat input x (1 ton/2000 lb)

^e Projected actual emissions minus baseline actual emissions.

APPENDIX A

Appendix A
Sanford Power Plant
Summary of AOR Data for Unit 4 (EU IDs 005, 006, 007, 008)

Emission Unit 005 Unit 4A - Combined Cycle CT with unfired HRSG (250 MW)					Emission Unit 006 Unit 4B - Combined Cycle CT with unfired HRSG (250 MW)				
2010	Diesel TPY	Natural Gas TPY	Total TPY	Hours	2010	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx		150.3	150.30	7267	NOx		153.9	153.9	7344
CO		10.0872	10.09		CO		6.75648	6.75648	
SO2		3.1	3.10		SO2		3.1	3.1	
VOC		0.021771	0.02		VOC		0.025704	0.025704	
PM		33.9174	33.92		PM		34.3233	34.3233	
PM10		33.9174	33.92		PM10		34.3233	34.3233	
Unit 4A - Combined Cycle CT with unfired HRSG (250 MW)					Unit 4B - Combined Cycle CT with unfired HRSG (250 MW)				
2009	Diesel TPY	Natural Gas TPY	Total TPY	Hours	2009	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx		135.5	135.5	6473	NOx		150.3	150.3	6982
CO		11.2307	11.2307		CO		12.0789	12.0789	
SO2		2.7	2.7		SO2		3	3	
VOC		0.019419	0.019419		VOC		0.024437	0.024437	
PM		30.37	30.37		PM		32.736	32.736	
PM10		30.37	30.37		PM10		32.736	32.736	
Unit 4A - Combined Cycle CT with unfired HRSG (250 MW)					Unit 4B - Combined Cycle CT with unfired HRSG (250 MW)				
2008	Diesel TPY	Natural Gas TPY	Total TPY	Hours	2008	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx		143.1	143.1	7174	NOx		173.9	173.9	7829
CO		4.59136	4.59136		CO		5.83261	5.83261	
SO2		3.1	3.1		SO2		3.4	3.4	
VOC		0.021522	0.021522		VOC		0.027402	0.027402	
PM		33.4059	33.4059		PM		36.8379	36.8379	
PM10		33.4059	33.4059		PM10		36.8379	36.8379	
Unit 4A - Combined Cycle CT with unfired HRSG (250 MW)					Unit 4B - Combined Cycle CT with unfired HRSG (250 MW)				
2007	Diesel TPY	Natural Gas TPY	Total TPY	Hours	2007	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx		159.012	159.012	7575	NOx		172.762	172.762	7455
CO		21.21	21.21		CO		18.973	18.973	
SO2		3.2	3.2		SO2		3.3	3.3	
VOC		0.022725	0.022725		VOC		0.026093	0.026093	
PM		36.188	36.188		PM		35.633	35.633	
PM10		36.188	36.188		PM10		35.633	35.633	
Unit 4A - Combined Cycle CT with unfired HRSG (250 MW)					Unit 4B - Combined Cycle CT with unfired HRSG (250 MW)				
2006	Diesel TPY	Natural Gas TPY	Total TPY	Hours	2006	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx		191.34	191.34	7797	NOx		158.888	158.888	6899
CO		19.6484	19.6484		CO		16.1782	16.1782	
SO2		3.6	3.6		SO2		3.2	3.2	
VOC		0.023391	0.023391		VOC		0.024147	0.024147	
PM		38.2668	38.2668		PM		33.8283	33.8283	
PM10		38.2668	38.2668		PM10		33.8283	33.8283	

Appendix A
Sanford Power Plant
Summary of AOR Data for Unit 4 (EU IDs 005, 006, 007, 008)

Emission Unit 007					Emission Unit 008				
Unit 4C - Combined Cycle CT with unfired HRSG (250 MW)					Unit 4D - Combined Cycle CT with unfired HRSG (250 MW)				
2010	Diesel TPY	Natural Gas		Hours	2010	Diesel TPY	Natural Gas		Hours
		Gas TPY	Total TPY				Gas TPY	Total TPY	
NOx		150.9	150.9	7007	NOx		151.7	151.7	6864
CO		5.18518	5.18518		CO		7.36805	7.36805	
SO2		3	3		SO2		2.9	2.9	
VOC		0.014014	0.014014		VOC		0.020562	0.020562	
PM		32.5611	32.5611		PM		31.6338	31.6338	
PM10		32.5611	32.5611		PM10		31.6338	31.6338	
Unit 4C - Combined Cycle CT with unfired HRSG (250 MW)					Unit 4D - Combined Cycle CT with unfired HRSG (250 MW)				
2009	Diesel TPY	Natural Gas		Hours	2009	Diesel TPY	Natural Gas		Hours
		Gas TPY	Total TPY				Gas TPY	Total TPY	
NOx		150.6	160.6	7101	NOx		151.9	161.9	7036
CO		11.6101	11.6101		CO		9.99112	9.99112	
SO2		3.1	3.1		SO2		3.1	3.1	
VOC		0.014202	0.014202		VOC		0.021108	0.021108	
PM		33.446	33.446		PM		33.201	33.201	
PM10		33.446	33.446		PM10		33.201	33.201	
Unit 4C - Combined Cycle CT with unfired HRSG (250 MW)					Unit 4D - Combined Cycle CT with unfired HRSG (250 MW)				
2008	Diesel TPY	Natural Gas		Hours	2008	Diesel TPY	Natural Gas		Hours
		Gas TPY	Total TPY				Gas TPY	Total TPY	
NOx		145.9	145.9	6897	NOx		147.7	147.7	6937
CO		5.10378	5.10378		CO		5.02933	6.02933	
SO2		3	3		SO2		3.5883	3.5883	
VOC		0.013794	0.013794		VOC		0.020811	0.020811	
PM		32.3004	32.3004		PM		32.4522	32.4522	
PM10		32.3004	32.3004		PM10		32.4522	32.4522	
Unit 4C - Combined Cycle CT with unfired HRSG (250 MW)					Unit 4D - Combined Cycle CT with unfired HRSG (250 MW)				
2007	Diesel TPY	Natural Gas		Hours	2007	Diesel TPY	Natural Gas		Hours
		Gas TPY	Total TPY				Gas TPY	Total TPY	
NOx		149.777	149.777	7674	NOx		178.225	178.225	7448
CO		21.4872	21.4872		CO		20.7054	20.7054	
SO2		3.3	3.3		SO2		3.3	3.3	
VOC		0.015348	0.015348		VOC		0.022344	0.022344	
PM		36.614	36.614		PM		35.643	35.643	
PM10		36.614	36.614		PM10		35.643	35.643	
Unit 4C - Combined Cycle CT with unfired HRSG (250 MW)					Unit 4D - Combined Cycle CT with unfired HRSG (250 MW)				
2006	Diesel TPY	Natural Gas		Hours	2006	Diesel TPY	Natural Gas		Hours
		Gas TPY	Total TPY				Gas TPY	Total TPY	
NOx		179.241	179.241	8035	NOx		185.764	185.764	7783
CO		20.6901	20.6901		CO		19.224	19.224	
SO2		3.6	3.6		SO2		3.5	3.5	
VOC		0.01607	0.01607		VOC		0.023349	0.023349	
PM		39.4317	39.4317		PM		38.313	38.313	
PM10		39.4317	39.4317		PM10		38.313	38.313	

Appendix A
Sanford Power Plant
Summary of AOR Data for Unit 4 (EU IDs 005, 006, 007, 008)

<u>Fuel Usage</u>			<u>Fuel Heat Content</u>			<u>Heat Input per Year</u>		
Diesel	Natural Gas		Diesel	Natural Gas		Diesel	Natural Gas	Total
1000 gal/yr	MMBtu/yr		MMBtu/1000 gal	MMBtu/MMBtu		MMBtu/yr	MMBtu/yr	MMBtu/yr
Unit 4A - Combined Cycle CT with unfired HRSG (250 MW)			Unit 4A - Combined Cycle CT with unfired HRSG (250 MW)			Unit 4A - Combined Cycle CT with unfired HRSG (250 MW)		
2010	0	10278	2010	136	1000	2010	0	10278000
2009	0	9203	2009	136	1000	2009	0	9203000
2008	0	10123	2008	136	1000	2008	0	10123000
2007	0	10966	2007	136	1000	2007	0	10966000
2006	0	11596	2006	136	1000	2006	0	11596000
Unit 4B - Combined Cycle CT with unfired HRSG (250 MW)			Unit 4B - Combined Cycle CT with unfired HRSG (250 MW)			Unit 4B - Combined Cycle CT with unfired HRSG (250 MW)		
2010	0	10401	2010	136	1000	2010	0	10401000
2009	0	9920	2009	136	1000	2009	0	9920000
2008	0	11163	2008	136	1000	2008	0	11163000
2007	0	10798	2007	136	1000	2007	0	10798000
2006	0	10251	2006	136	1000	2006	0	10251000
Unit 4C - Combined Cycle CT with unfired HRSG (250 MW)			Unit 4C - Combined Cycle CT with unfired HRSG (250 MW)			Unit 4C - Combined Cycle CT with unfired HRSG (250 MW)		
2010	0	9867	2010	136	1000	2010	0	9867000
2009	0	10135	2009	136	1000	2009	0	10135000
2008	0	9788	2008	136	1000	2008	0	9788000
2007	0	11095	2007	136	1000	2007	0	11095000
2006	0	11949	2006	136	1000	2006	0	11949000
Unit 4D - Combined Cycle CT with unfired HRSG (250 MW)			Unit 4D - Combined Cycle CT with unfired HRSG (250 MW)			Unit 4D - Combined Cycle CT with unfired HRSG (250 MW)		
2010	0	9586	2010	136	1000	2010	0	9586000
2009	0	10081	2009	136	1000	2009	0	10081000
2008	0	9834	2008	136	1000	2008	0	9834000
2007	0	10801	2007	136	1000	2007	0	10801000
2006	0	11610	2006	136	1000	2006	0	11610000

**Appendix A
Sanford Power Plant
Summary of AOR Data for Unit 5 (EU IDs 009, 010, 011, 012)**

Emission Unit 009 Unit 5A - Combined Cycle CT with unfired HRSG (250 MW)					Emission Unit 010 Unit 5B - Combined Cycle CT with unfired HRSG (250 MW)						
	2010	Diesel TPY	Natural Gas TPY	Total TPY	Hours		2010	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx			159.4	159.40	7535	NOx			151	151.00	6933
CO			8.8913	8.89		CO			7.45298	7.45	
SO2			3.2	3.20		SO2			3	3.00	
VOC			0.01507	0.02		VOC			0.017333	0.02	
PM			35.3364	35.34		PM			32.1651	32.17	
PM10			35.3364	35.34		PM10			32.1651	32.17	
<u>Unit 5A - Combined Cycle CT with unfired HRSG (250 MW)</u>					<u>Unit 5B - Combined Cycle CT with unfired HRSG (250 MW)</u>						
	2009	Diesel TPY	Natural Gas TPY	Total TPY	Hours		2009	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx			176.2	176.20	8004	NOx			158.2	158.20	7129
CO			8.04402	8.04		CO			6.48739	6.49	
SO2			3.5	3.50		SO2			3.1	3.10	
VOC			0.016008	0.02		VOC			0.017823	0.02	
PM			37.927	37.93		PM			33.267	33.27	
PM10			37.927	37.93		PM10			33.267	33.27	
<u>Unit 5A - Combined Cycle CT with unfired HRSG (250 MW)</u>					<u>Unit 5B - Combined Cycle CT with unfired HRSG (250 MW)</u>						
	2008	Diesel TPY	Natural Gas TPY	Total TPY	Hours		2008	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx			128.9	128.90	6002	NOx			162.8	162.80	7494
CO			3.66122	3.66		CO			6.33243	6.33	
SO2			2.6	2.60		SO2			3.2	3.20	
VOC			0.012004	0.01		VOC			0.018735	0.02	
PM			27.7299	27.73		PM			34.716	34.72	
PM10			27.7299	27.73		PM10			34.716	34.72	
<u>Unit 5A - Combined Cycle CT with unfired HRSG (250 MW)</u>					<u>Unit 5B - Combined Cycle CT with unfired HRSG (250 MW)</u>						
	2007	Diesel TPY	Natural Gas TPY	Total TPY	Hours		2007	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx			171.398	171.40	7569	NOx			169.386	169.39	7703
CO			20.7873	20.79		CO			22.6468	22.65	
SO2			3.3	3.30		SO2			3.4	3.40	
VOC			0.015118	0.02		VOC			0.019258	0.02	
PM			36.491	36.49		PM			37.264	37.26	
PM10			36.491	36.49		PM10			37.264	37.26	
<u>Unit 5A - Combined Cycle CT with unfired HRSG (250 MW)</u>					<u>Unit 5B - Combined Cycle CT with unfired HRSG (250 MW)</u>						
	2006	Diesel TPY	Natural Gas TPY	Total TPY	Hours		2006	Diesel TPY	Natural Gas TPY	Total TPY	Hours
NOx			194.192	194.19	7956	NOx			138.529	138.53	6050
CO			21.521	21.52		CO			17.7265	17.73	
SO2			3.6	3.60		SO2			2.7	2.70	
VOC			0.015912	0.02		VOC			0.015125	0.02	
PM			38.8377	38.84		PM			29.4921	29.49	
PM10			38.8377	38.84		PM10			29.4921	29.49	

Appendix A
Sanford Power Plant
Summary of AOR Data for Unit 5 (EU IDs 009, 010, 011, 012)

Emission Unit 011					Emission Unit 012				
Unit 5C - Combined Cycle CT with unfired HRSG (250 MW)					Unit 5D - Combined Cycle CT with unfired HRSG (250 MW)				
		Natural Gas	Total			Natural Gas	Total		
	Diesel	TPY	TPY	Hours		TPY	TPY	Hours	
2010					2010				
NOx		159.4	159.40	7348	NOx		130.2	130.20	5830
CO		7.23778	7.24		CO		5.80085	5.80	
SO2		3.2	3.20		SO2		2.5	2.50	
VOC		0.014696	0.01		VOC		0.01166	0.01	
PM		34.2441	34.24		PM		26.8026	26.80	
PM10		34.2441	34.24		PM10		26.8026	26.80	
2009					2009				
NOx		156.1	156.10	6924	NOx		153	153.00	7116
CO		7.68564	7.69		CO		6.4044	6.40	
SO2		3	3.00		SO2		3.1	3.10	
VOC		0.013848	0.01		VOC		0.014232	0.01	
PM		32.413	32.41		PM		33.238	33.24	
PM10		32.413	32.41		PM10		33.238	33.24	
2008					2008				
NOx		144.9	144.90	6424	NOx		155.4	155.40	7135
CO		6.00644	6.01		CO		3.4248	3.42	
SO2		2.7	2.70		SO2		3	3.00	
VOC		0.012848	0.01		VOC		0.01427	0.01	
PM		29.5383	29.54		PM		32.9241	32.92	
PM10		29.5383	29.54		PM10		32.9241	32.92	
2007					2007				
NOx		167.503	167.50	7883	NOx		136.113	136.11	6640
CO		22.703	22.70		CO		19.4552	19.46	
SO2		3.5	3.50		SO2		3.1	3.10	
VOC		0.015766	0.02		VOC		0.01328	0.01	
PM		38.122	38.12		PM		32.083	32.08	
PM10		38.122	38.12		PM10		32.083	32.08	
2006					2006				
NOx		142.352	142.35	6438	NOx		161.616	161.62	7525
CO		17.0607	17.06		CO		19.866	19.87	
SO2		2.9	2.90		SO2		3.4	3.40	
VOC		0.012876	0.01		VOC		0.01505	0.02	
PM		31.317	31.32		PM		36.7818	36.78	
PM10		31.317	31.32		PM10		36.7818	36.78	

Appendix A
Sanford Power Plant
Summary of AOR Data for Unit 5 (EU IDs 009, 010, 011, 012)

Fuel Usage			Fuel Heat Content			Heat Input per Year		
Diesel 1000 gal/yr	Natural Gas MMBtu/yr		Diesel MMBtu/1000 gal	Natural Gas MMBtu/MMBtu3		Diesel MMBtu/yr	Natural Gas MMBtu/yr	Total MMBtu/yr
Unit 5A - Combined Cycle CT with unfired HRSG (250 MW)			Unit 5A - Combined Cycle CT with unfired HRSG (250 MW)			Unit 5A - Combined Cycle CT with unfired HRSG (250 MW)		
2010	0	10708	2010	136	1000	2010	0	10708000
2009	0	11493	2009	136	1000	2009	0	11493000
2008	0	8403	2008	136	1000	2008	0	8403000
2007	0	11058	2007	136	1000	2007	0	11058000
2006	0	11769	2006	136	1000	2006	0	11769000
Unit 5B - Combined Cycle CT with unfired HRSG (250 MW)			Unit 5B - Combined Cycle CT with unfired HRSG (250 MW)			Unit 5B - Combined Cycle CT with unfired HRSG (250 MW)		
2010	0	9747	2010	136	1000	2010	0	9747000
2009	0	10081	2009	136	1000	2009	0	10081000
2008	0	10520	2008	136	1000	2008	0	10520000
2007	0	11292	2007	136	1000	2007	0	11292000
2006	0	8937	2006	136	1000	2006	0	8937000
Unit 5C - Combined Cycle CT with unfired HRSG (250 MW)			Unit 5C - Combined Cycle CT with unfired HRSG (250 MW)			Unit 5C - Combined Cycle CT with unfired HRSG (250 MW)		
2010	0	10377	2010	136	1000	2010	0	10377000
2009	0	9822	2009	136	1000	2009	0	9822000
2008	0	8951	2008	136	1000	2008	0	8951000
2007	0	11552	2007	136	1000	2007	0	11552000
2006	0	9490	2006	136	1000	2006	0	9490000
Unit 5D - Combined Cycle CT with unfired HRSG (250 MW)			Unit 5D - Combined Cycle CT with unfired HRSG (250 MW)			Unit 5D - Combined Cycle CT with unfired HRSG (250 MW)		
2010	0	8122	2010	136	1000	2010	0	8122000
2009	0	10072	2009	136	1000	2009	0	10072000
2008	0	9977	2008	136	1000	2008	0	9977000
2007	0	9722	2007	136	1000	2007	0	9722000
2006	0	11146	2006	136	1000	2006	0	11146000

APPENDIX B

Appendix B
CEM Reports from Acid Rain Database
Annual Reports

STATE	FACILITY_ NAME	ORISPL_ CODE	UNITID	OP_YEAR	ASSOC_ STACKS	PRG_CODE	SUM_OP TIME	NUM_ MONTHS_ REPORTE D	GLOAD	SO2_MASS	NOX_RATE	NOX_MASS	CO2_MASS	HEAT_ INPUT	UNIT_ TYPE_ INFO	PRIMARY_FUEL_INFO	SECONDARY_ FUEL_INFO	CAPACITY_ INPUT
FL	Sanford	620	SNCT4A	2006	ARP		7846.23	12	1070463.3	3.57	0.0301	176.081	707205.57	11900133	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4B	2006	ARP		6880.82	12	936594.08	3.135	0.0313	160.399	620923.799	10448328.9	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4C	2006	ARP		7997.81	12	1094719.65	3.637	0.0305	182.613	720454.959	12123089.4	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4D	2006	ARP		7754.46	12	1054512.19	3.504	0.0313	178.835	694044.48	11678554.4	Combined cycle	Pipeline Natural Gas		1910
							30479.32		4156289.22			697.928						
FL	Sanford	620	SNCT5A	2006	ARP		7998.6	12	1084996.92	3.644	0.0303	179.156	721820.078	12146012.6	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5B	2006	ARP		5952.01	12	791952.57	2.677	0.0308	133.27	530281.045	8922994.88	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5C	2006	ARP		6403.26	12	853617.57	2.886	0.0317	144.799	571682.895	9619715.31	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5D	2006	ARP		7433.25	12	999136.57	3.361	0.0312	170.262	665715.583	11201893.8	Combined cycle	Pipeline Natural Gas		1910
							27787.12		3729703.63			627.487						
FL	Sanford	620	SNCT4A	2007	ARP		7465.63	12	976847.69	3.287	0.0305	162.959	651051.793	10955233.3	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4B	2007	ARP		7349.35	12	959488.12	3.272	0.0311	164.997	648224.602	10907583	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4C	2007	ARP		7570.93	12	981294.1	3.312	0.0311	165.926	656150.773	11040898.7	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4D	2007	ARP		7353.11	12	961153.3	3.214	0.0313	164.235	636649.703	10712835	Combined cycle	Pipeline Natural Gas		1910
							29739.02		3878783.21			658.117						
FL	Sanford	620	SNCT5A	2007	ARP		7443.82	12	974671.51	3.294	0.03	159.94	652435.338	10978486.6	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5B	2007	ARP		7670.7	12	983746.88	3.352	0.0308	169.408	663979.394	11172731.6	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5C	2007	ARP		7769.43	12	1054629.39	3.515	0.0312	176.755	696238.255	11715469.3	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5D	2007	ARP		6605.09	12	884983.08	2.987	0.0313	147.33	591622.916	9955180.24	Combined cycle	Pipeline Natural Gas		1910
							29489.04		3898030.86			653.433						
FL	Sanford	620	SNCT4A	2008	ARP		7091.53	12	906071.94	3.085	0.0294	143.218	611095.309	10282910.4	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4B	2008	ARP		7810.68	12	998213.96	3.418	0.031	173.949	677165.529	11394658.7	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4C	2008	ARP		6854.4	12	858802.95	2.928	0.0312	145.842	580004.187	9759668.07	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4D	2008	ARP		6884.18	12	870962.3	2.938	0.0315	147.723	581998.826	9793271.18	Combined cycle	Pipeline Natural Gas		1910
							28640.79		3634051.15			610.732						
FL	Sanford	620	SNCT5A	2008	ARP		5956.34	12	741132.3	2.552	0.0318	128.868	505467.362	8505448.44	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5B	2008	ARP		7453.47	12	910209.89	3.166	0.0314	162.81	627111.541	10552359.3	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5C	2008	ARP		6382.97	12	801061.51	2.742	0.033	144.897	543117.92	9138989.36	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5D	2008	ARP		7072.12	12	866485.72	3.015	0.0326	155.399	597176.802	10048656.9	Combined cycle	Pipeline Natural Gas		1910
							26864.9		3318889.42			591.974						
FL	Sanford	620	SNCT4A	2009	ARP		6386.05	12	822245.1	2.782	0.0309	135.497	551117.211	9273676.91	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4B	2009	ARP		6880.29	12	884920.37	2.996	0.0321	150.3	593423.4	9985445.8	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4C	2009	ARP		7026.7	12	895613.83	3.052	0.0311	150.572	604529.619	10172370.1	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4D	2009	ARP		6974.2	12	888007.24	3.014	0.0316	151.875	596984.64	10045455.6	Combined cycle	Pipeline Natural Gas		1910
							27267.24		3490786.54			588.244						
FL	Sanford	620	SNCT5A	2009	ARP		7977.74	12	1027096.28	3.461	0.0309	176.127	685666.662	11537632.7	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5B	2009	ARP		7013.46	12	882156.28	3.025	0.0339	158.32	599196.916	10082672.6	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5C	2009	ARP		6826.75	12	882174.48	2.978	0.0334	156.069	589903.098	9926224.84	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5D	2009	ARP		7000.16	12	896078.17	3.043	0.0327	153.027	602803.141	10143286.1	Combined cycle	Pipeline Natural Gas		1910
							28818.11		3687505.21			643.543						
FL	Sanford	620	SNCT4A	2010	ARP		7174.9	12	909057.52	3.096	0.0307	150.218	613261.563	10319359.3	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4B	2010	ARP		7261.15	12	923046.53	3.132	0.0309	153.906	620409.506	10439647	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4C	2010	ARP		6894.23	12	871841.81	2.98	0.0325	150.814	590324.698	9933364.28	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT4D	2010	ARP		6706.76	12	856670.55	2.887	0.0342	151.776	571873.648	9622866.33	Combined cycle	Pipeline Natural Gas		1910
							28037.04		3560616.41			606.714						
FL	Sanford	620	SNCT5A	2010	ARP		7438.51	12	966267.7	3.273	0.0311	159.404	648390.076	10910348.6	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5B	2010	ARP		6783.97	12	869754.99	3.003	0.0329	151.086	594791.612	10008505.6	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5C	2010	ARP		7216.2	12	929855.36	3.146	0.0336	159.471	623134.371	10485437	Combined cycle	Pipeline Natural Gas		1910
FL	Sanford	620	SNCT5D	2010	ARP		5656.34	12	724010.61	2.452	0.0361	130.09	485777.221	8174157.46	Combined cycle	Pipeline Natural Gas		1910
							27095.02		3489888.66			600.051						

APPENDIX C

Appendix C
FPL Sanford
Estimated Performance 7FA.03

Load Condition		BASE	BASE	BASE	BASE	Peaking	BASE
Inlet Loss	in H2O	3.04	3.04	3.04	3.04	3.04	3.04
Exhaust Pressure Loss	in H2O	12.36	11.45	10.62	9.49	11.56	12.42
Ambient Temperature	°F	35	59	75	95	59	59
Ambient Relative Humidity	%	60	60	60	60	60	60
Evap. Cooler Status		None	None	None	None	None	None
Evap. Cooler Effectiveness	%						
Fuel Type		Cust Gas	Cust Gas	Cust Gas	Cust Gas	Cust Gas	Liquid
Fuel LHV	BTU/lb	20,835	20835	20,835	20835	20835	18387
Fuel Temperature	°F	365	365.00	365	365.00	365.00	59.00
Output	kW	185,386.00	175,988.00	166,529.00	152,343.00	180,631.00	188,491.00
Heat Rate (LHV)	BTU/kWh	9,093.00	9,202.00	9,326.00	9,567.00	9,176.00	9,978.00
Heat Cons. (LHV)	MMBTU/hr	1,685.70	1,619.4	1,553.00	1,457.4	1,657.5	1,880.8
Exhaust Flow	x10 ³ lb/hr	3,794.00	3,629.00	3,483.00	3,278.00	3,630.00	3,799.00
Exhaust Temperature	°F	1,086.00	1,114.00	1,131.00	1,151.00	1,134.00	1,090.00
Exhaust MolWt	lb/lbmol	28.47	28.41	28.33	28.17	28.4	28.24
Exhaust Energy	MMBTU/hr	1025.9	991.4	957.6	910.9	1013.2	1034.2
Water / Steam Flow	lb/hr						152,895

EMISSIONS

NOx	ppmvd	9.00	9.00	9.00	9.00	14.00	42.00
NOx Correction O2 Value	% O2	15.00	15.00	15.00	15.00	15.00	15.00
NOx as NO2	lb/hr	61.02	58.63	56.21	52.77	93.28	326.75
CO	ppmvd	9.00	9.00	9.00	9.00	9.00	20.00
CO	lb/hr	31.04	29.56	28.23	26.30	29.53	66.36
UHC	ppmw	7.00	7.00	7.00	7.00	7.00	7.00
UHC	lb/hr	15.21	14.49	13.84	12.89	14.47	14.63
VOC	ppmw	1.40	1.40	1.40	1.40	1.40	3.50
VOC	lb/hr	3.00	2.90	2.80	2.60	2.90	7.50
SO2	ppmw						11.29
SO2	lb/hr						97.18
SO3	ppmw						0.59
SO3	lb/hr						5.11
Sulfur Mist	lb/hr						10.23
Fuel Sulfur	Wt%						0.05 Wt%
Particulates	lb/hr	9.00	9.00	9.00	9.00	9.00	17.00
Particulate Basis		Front	Front	Front	Front	Front	Front

EXHAUST ANALYSIS

Argon	%VOL	0.89	0.89	0.88	0.87	0.89	0.84
Nitrogen	%VOL	74.94	74.49	73.94	72.77	74.42	70.72
Oxygen	%VOL	12.77	12.63	12.51	12.26	12.45	10.96
Carbon Dioxide	%VOL	3.78	3.78	3.77	3.74	3.87	5.53
Water	%VOL	7.62	8.21	8.91	10.36	8.38	11.95
CO2	lb/hr	221705.74	212498.68	203988.18	191560.95	217740.58	327409.96

SITE CONDITIONS

Elevation	Feet	0.00	0.00	0.00	0.00	0.00	0.00
Site Pressure	psia	14.70	14.70	14.70	14.70	14.70	14.70
Exhaust Loss	in H2O	11.30	11.30	11.30	11.30	11.30	11.30
Relative Humidity	%	60.00	60.00	60.00	60.00	60.00	60.00
Application		H2Gen	H2Gen	H2Gen	H2Gen	H2Gen	H2Gen
Power Factor (lag)		0.80	0.80	0.80	0.80	0.80	0.80
Combustion System		DLN9	DLN9	DLN9	DLN9	DLN9	DLN9

Appendix C
FPL Sanford
Estimated Performance 7FA.04

Load Condition		BASE	BASE	BASE	BASE	Peaking	BASE
Inlet Loss	in H2O	3.04	3.04	3.04	3.04	3.04	3.04
Exhaust Pressure Loss	in H2O	12.54	11.58	10.72	9.59	11.66	12.25
Ambient Temperature	°F	35	59	75	95	59	59
Ambient Relative Humidity	%	60	60	60	60	60	60
Evap. Cooler Status		None	None	None	None	None	None
Evap. Cooler Effectiveness	%						
Fuel Type		Cust Gas	Cust Gas	Cust Gas	Cust Gas	Cust Gas	Liquid
Fuel LHV	BTU/lb	20,835	20835	20,835	20835	20835	18387
Fuel Temperature	°F	365	365.00	365	365.00	365.00	80.00
Output	kW	194,537.00	184,510.00	173,970.00	160,194.00	187,731.00	194,010.00
Heat Rate (LHV)	BTU/kWh	8,913.00	8,993.00	9,112.00	9,318.00	8,981.00	9,716.00
Heat Cons. (LHV)	MMBTU/hr	1,733.90	1659.4	1,585.20	1492.7	1686.1	1885
Exhaust Flow	x10 ³ lb/hr	3,780.00	3,614.00	3,469.00	3,266.00	3,616.00	3,737.00
Exhaust Temperature	°F	1,105.00	1,128.00	1,141.00	1,163.00	1,143.00	1,104.00
Exhaust MolWt	lb/lbmol	28.46	28.39	28.32	28.15	28.39	28.27
Exhaust Energy	MMBTU/hr	1043.4	1002.9	965	920.1	1018.4	1031.6
Water / Steam Flow	lb/hr						144530

EMISSIONS

NOx	ppmvd	9.00	9.00	9.00	9.00	15.00	42.00
NOx Correction O2 Value	% O2	15.00	15.00	15.00	15.00	15.00	15.00
NOx as NO2	lb/hr	62.92	60.23	57.53	54.17	101.99	330.26
CO	ppmvd	9.00	9.00	9.00	9.00	9.00	20.00
CO	lb/hr	30.85	29.39	28.07	26.15	29.36	65.19
UHC	ppmw	7.00	7.00	7.00	7.00	7.00	7.00
UHC	lb/hr	15.29	14.57	13.91	12.96	14.55	14.54
VOC	ppmw	1.40	1.40	1.40	1.40	1.40	3.50
VOC	lb/hr	3.00	2.90	2.70	2.60	2.90	7.40
SO2	ppmw						11.51
SO2	lb/hr						97.39
SO3	ppmw						0.61
SO3	lb/hr						5.13
Sulfur Mist	lb/hr						10.25
Fuel Sulfur	Wt%						0.05
Particulates	lb/hr	9.00	9.00	9.00	9.00	9.00	17.00
Particulate Basis		Front	Front	Front	Front	Front	Front



EXHAUST ANALYSIS

Argon	%VOL	0.89	0.89	0.88	0.87	0.89	0.84
Nitrogen	%VOL	74.85	74.40	73.86	72.69	74.36	70.89
Oxygen	%VOL	12.49	12.38	12.29	12.02	12.25	10.83
Carbon Dioxide	%VOL	3.90	3.90	3.87	3.85	3.96	5.65
Water	%VOL	7.87	8.43	9.10	10.57	8.55	11.79
CO2	lb/hr	227985.15	218501.84	208636.79	196534.35	221993.27	330492.55

SITE CONDITIONS

Elevation	Feet	0.00	0.00	0.00	0.00	0.00	0.00
Site Pressure	psia	14.70	14.70	14.70	14.70	14.70	14.70
Exhaust Loss	in H2O	11.30	11.30	11.30	11.30	11.30	11.30
Relative Humidity	%	60.00	60.00	60.00	60.00	60.00	60.00
Application		H2Gen	H2Gen	H2Gen	H2Gen	H2Gen	H2Gen
Power Factor (lag)		0.80	0.80	0.80	0.80	0.80	0.80
Combustion System		DLN9	DLN9	DLN9	DLN9	DLN9	DLN9

APPENDIX D





Appendix D
Hourly Acid Rain

Y:\Projects\2011\113-87631 FPL Sanford\Final\Attach\Appendix D.docx

Source: Golder, 2011.







Appendix D
Hourly Acid Rain

Y:\Projects\2011\113-87631 FPL Sanford\Final\Attach\Appendix D.docx

Source: Golder, 2011.







Appendix D
Hourly Acid Rain

Y:\Projects\2011\113-87631 FPL Sanford\Final\Attach\Appendix D.docx

Source: Golder, 2011.





Appendix D
Hourly Acid Rain

Y:\Projects\2011\113-87631 FPL Sanford\Final\Attach\Appendix D.docx

Source: Golder, 2011.



At Golder Associates we strive to be the most respected global group of companies specializing in ground engineering and environmental services. Employee owned since our formation in 1960, we have created a unique culture with pride in ownership, resulting in long-term organizational stability. Golder professionals take the time to build an understanding of client needs and of the specific environments in which they operate. We continue to expand our technical capabilities and have experienced steady growth with employees now operating from offices located throughout Africa, Asia, Australasia, Europe, North America and South America.

Africa	+ 27 11 254 4800
Asia	+ 852 2562 3658
Australasia	+ 61 3 8862 3500
Europe	+ 356 21 42 30 20
North America	+ 1 800 275 3281
South America	+ 55 21 3095 9500

solutions@golder.com
www.golder.com

Golder Associates Inc.
6026 NW 1st Place
Gainesville, FL 32607 USA
(352) 336-5600 - Phone
(352) 336-6603 - Fax

