



P.O. Box 078768, West Palm Beach, FL 33407-0768
5500 Village Blvd.

FEDERAL EXPRESS

April 17, 1991

Ms. Cindy Phillips
State of Florida Department of Environmental Regulation
2600 Blair Stone Road
Tallahassee, Florida 32301

RE: **Sanford Plant, Unit No. 4**
Orimulsion Test Burn
Monthly Compliance Reports - March, 1991

Dear Mr. Alexander:

As required by the specific conditions of the Department's permit authorizing the Orimulsion Test Burn, enclosed please find the compliance reports for the month of March, 1991 as follows:

<u>Required in</u> <u>Specific Condition No.</u>	<u>Report Title</u>
8.e) iii.	Fuel Analysis-As Fired for Sanford Units 3, 4, & 5 (previously submitted on 4/9/91-See copy of transmittal attached to report)
8.e) vi.	Frequency of Excess Emissions
8.e) vi.	SO ₂ Excess Emissions
8.e) i. & 8.e) ii.	Fuel Usage for Sanford Units 3, 4, & 5/Orimulsion Full-power Burn Days
8.e) v.	Daily Opacity Logs
8.e) iv.	Summary - NO _x & CO CEM Hourly Averages
8.e) v.	Summary - Opacity CEM 6-min. Averages

Sanford Plant, Unit No. 4
Orimulsion Test Burn
Monthly Compliance Reports-March, 1991
Page 2

For your convenience, we have compiled all the above reports into one booklet. This format will be repeated for each reporting cycle throughout the Orimulsion Test Burn.

If you have any questions, please call me at (407) 697-6926.

Sincerely,

A handwritten signature in cursive script that reads "Elsa A. Bishop".

Elsa A. Bishop
Senior Environmental Coordinator
Florida Power & Light Company

EAB:jm

Enclosure

cc: A. Alexander - DER/Orlando (w/o encl.)



FEDERAL EXPRESS

April 17, 1991

Mr. A. Alexander, Deputy Assistant Secretary
State of Florida Department of Environmental Regulation
Central Florida District
3319 Maguire Blvd., Suite 232
Orlando, Florida 32802

RE: **Sanford Plant, Unit No. 4**
Orimulsion Test Burn
Monthly Compliance Reports - March, 1991

Dear Mr. Alexander:

As required by the specific conditions of the Department's permit authorizing the Orimulsion Test Burn, enclosed please find the compliance reports for the month of March, 1991 as follows:

<u>Required in</u> <u>Specific Condition No.</u>	<u>Report Title</u>
8.e) iii.	Fuel Analysis-As Fired for Sanford Units 3, 4, & 5 (previously submitted on 4/9/91-See copy of transmittal attached to report)
8.e) vi.	Frequency of Excess Emissions
8.e) vi.	SO ₂ Excess Emissions
8.e) i. & 8.e) ii.	Fuel Usage for Sanford Units 3, 4, & 5/Orimulsion Full-power Burn Days
8.e) v.	Daily Opacity Logs
8.e) iv.	Summary - NO _x & CO CEM Hourly Averages
8.e) v.	Summary - Opacity CEM 6-min. Averages



P.O. Box 078768, West Palm Beach, FL 33407-0768
5500 Village Blvd.

April 9, 1991

Mr. A. Alexander, Deputy Assistant Secretary
State of Florida Department of Environmental Regulation
Central Florida District
3319 Maguire Blvd., Suite 232
Orlando, Florida 32803

RE: **SO₂ Emissions**
Analyses of Fuel Fired - Orimulsion
March, 1991 Sanford Power Plant, Unit No. 4

Dear Mr. Alexander:

As required by Specific Condition 7(e) of the DER Permit for the Orimulsion Test Burn at Sanford Unit No. 4, enclosed is the analysis of Orimulsion Fuel Fired for the March, 1991 sampling period.

If you have any questions, please call me at (407) 697-6926.

Sincerely,

A handwritten signature in cursive script that reads "Elsa A. Bishop".

Elsa A. Bishop
Senior Environmental Coordinator
Florida Power & Light Company

EAB:jm

Enclosure



P.O. Box 078768, West Palm Beach, FL 33407-0768
5500 Village Blvd.

April 9, 1991

Mr. A. Alexander, Deputy Assistant Secretary
State of Florida Department of Environmental Regulation
Central Florida District
3319 Maguire Blvd., Suite 232
Orlando, Florida 32803

RE: SO₂ Emissions
Analyses of Fuel Fired - Orimulsion
March, 1991 Sanford Power Plant, Unit No. 4

Dear Mr. Alexander:

As required by Specific Condition 7(e) of the DER Permit for the Orimulsion Test Burn at Sanford Unit No. 4, enclosed is the analysis of Orimulsion Fuel Fired for the March, 1991 sampling period.

If you have any questions, please call me at (407) 697-6926.

Sincerely,

A handwritten signature in cursive script that reads 'Elsa A. Bishop'.

Elsa A. Bishop
Senior Environmental Coordinator
Florida Power & Light Company

EAB:jm

Enclosure

FLORIDA POWER & LIGHT COMPANY
POWER RESOURCES CENTRAL LABORATORY

STATE OF FLORIDA LABORATORY CERTIFICATION NUMBERS
DRINKING WATER CERTIFICATION NUMBER: 56075
ENVIRONMENTAL CHEMISTRY CERTIFICATION NUMBER: 558276

SANFORD #4 (GRINDSIGN) PLANT
ANALYSES OF FUEL OIL FIRED
MARCH 1991

DATE SAMPLE RECEIVED AT LABORATORY	03-19-91		
API GRAVITY	7.4	WATER, % BY WEIGHT	0.15
DENSITY, g/CM3	1.0036		
DENSITY, LB/GAL	6.975	PARTICULATE EQUIVALENT, LB/MBTU	0.12
DENSITY, LB/BBL	651.759	VANADIUM IN OIL AS V2O5, PPM	251
DENSITY, TONS/BBL	0.1759	VANADIUM IN OIL AS V, PPM	256
HEAT OF COMBUSTION, BTU/LB	12709	VISCOSITY @ SHEAR RATE OF 139.1(1/S)	437
HEAT OF COMBUSTION, MBTU/BBL	4471	@ 30.5 C, CFS	
HEAT OF COMBUSTION, BTU/GAL	105441	ASPHALTENES, % BY WEIGHT	6.7
HEAT OF COMBUSTION, MBTU/TON	25415	MAGNESIUM IN OIL AS MG, PPM	310
HEAT OF COMBUSTION, MEGACALORIES/KG	29.54	SODIUM IN OIL AS NA, PPM	30
WATER, % BY VOLUME	30	NICKEL IN OIL AS NI, PPM	68
SEDIMENT, % BY WEIGHT	0.23	IRON IN OIL AS FE, PPM	11
SULFUR, % BY WEIGHT	2.8		
SULFUR DIOXIDE EQUIVALENT, LB/MBTU	4.4		

COPIES TO: J. W. DICKEY - PRS/EDC
M. GROSSWALD - FRB/EDC
J. STANTON - PRB/EDC
PLANT MANAGER - PSN
PSN RESULTS DEPT.

D. W. KNUTSON - PRS/EDC
K. WASHINGTON - FRB/EDC
W. WAYLETT - PRS/EDC
BOB RIGTER - PSN/PLT
ROGER MESSER - PRS/EDC

BILL PARKES - FR/60
R. LIPPMAN - FR/60
E. CALLANDER - FR/60
P.N. ALLEN - JEN/NF
M. TAYLOR - PCU/PLT
E. BISHOP - JEN/NF

ANALYZED BY: *T. Gibson / J. Uzia*

CERTIFIED BY: *H. M. Donnell*

DATE: 03-29-91

91-PEN-6

RECEIVED

APR 01 1991

ENV. PERMITTING



April 9, 1991



Mr. A. Alexander, Deputy Assistant Secretary
State of Florida
Department of Environmental Regulation
Central Florida District
3319 Maguire Blvd., Suite 232
Orlando, Florida 32803

RE: SO₂ Emissions
Analyses of Fuel Oil Fired
March, 1991 - Sanford Power Plant

Dear Mr. Alexander:

As required by the DER Air Operating Permits for the units at the above facilities, enclosed are the analyses of Fuel Oil Fired at Sanford Units 3 and 5 for the March, 1991 sampling period.

Due to the current Orimulsion Test Burn on Sanford Unit No. 4, no oil was fired in that unit during the March, 1991 sampling period. Please note that, as agreed to by FPL and as reflected in the Modified Order dated February 28, 1991 authorizing the Test Burn in Unit No. 4, Sanford Unit No. 5 was not operated at all during the March, 1991 sampling period whenever Orimulsion was being burned in Sanford Unit No. 4.

If you have any questions, please call me at (407) 697-6926.

Sincerely,

A handwritten signature in cursive script that reads 'Elsa A. Bishop'.

Elsa A. Bishop
Senior Environmental Coordinator
Florida Power & Light Company

EAB:jm

Enclosure

cc: Cindy Phillips - DER/Tall

bcc: R. N. Allen - JEN/NP
M. Grosswald - PRG/EDO
M. Harrinton - GVS/NED
R. F. Messer - PRS/EDO
R. Ruhlman - PSN

FLORIDA POWER & LIGHT COMPANY
POWER RESOURCES CENTRAL LABORATORY

STATE OF FLORIDA LABORATORY CERTIFICATION NUMBER:
DRINKING WATER CERTIFICATION NUMBER: 56275
ENVIRONMENTAL CHEMISTRY CERTIFICATION NUMBER: 658078

SANFORD #3 PLANT
ANALYSES OF FUEL OIL FILLED
MARCH 1991

DATE SAMPLE RECEIVED AT LABORATORY	03-19-91
API GRAVITY	10.8
DENSITY, LB/GAL	8.281
DENSITY, LB/BBL	347.802
HEAT OF COMBUSTION, BTU/LB	18321
HEAT OF COMBUSTION, BTU/GAL	151715
HEAT OF COMBUSTION, MBTU/BBL	6372
WATER, % BY VOLUME	0.20
SEDIMENT, % BY WEIGHT	0.04
SULFUR, % BY WEIGHT	1.0
SULFUR DIOXIDE EQUIVALENT, LB/MBTU	1.09
ASH, % BY WEIGHT	0.04
PARTICULATE EQUIVALENT, LB/MBTU	0.02
VANADIUM IN ASH AS V2O5, % BY WEIGHT	10
VANADIUM IN OIL AS V2O5, PPM	36
VANADIUM IN OIL AS V, PPM	20
VISCOSITY, SSF @ 122F	92
ASPHALTENES, % BY WEIGHT	2.9

RECEIVED

APR 01 1991

COPIES TO: FSN PLANT MGR.
R N ALLEN - JEN/EDG
PLANT RESULTS DEPT
K WASHINGTON - PRB/EDG

ENV. PERMITTING
ANALYZED BY: *Y. Harrison* / *J. Uzi*
CERTIFIED BY: *H. M. Donnell*

FLORIDA POWER & LIGHT COMPANY
POWER RESOURCES CENTRAL LABORATORY
MIAMI, FLORIDA

SANFORD #5 PLANT
ANALYSIS OF FUEL OIL FIRED
MARCH 1971

DATE SAMPLE RECEIVED AT LABORATORY	03-20-91
API GRAVITY	10.8
DENSITY, LB/GAL	8.281
DENSITY, LB/BBL	347.802
HEAT OF COMBUSTION, BTU/LB	18187
HEAT OF COMBUSTION, BTU/GAL	150607
HEAT OF COMBUSTION, MBTU/BBL	6325
WATER, % BY VOLUME	1.0
SEDIMENT, % BY WEIGHT	0.07
SULFUR, % BY WEIGHT	0.97
SULFUR DIOXIDE EQUIVALENT, LB/MBTU	1.07
ASH, % BY WEIGHT	0.05
PARTICULATE EQUIVALENT, LB/MBTU	0.03
VANADIUM IN ASH AS V ₂ O ₅ , % BY WEIGHT	5
VANADIUM IN OIL AS V ₂ O ₅ , PPM	27
VANADIUM IN OIL AS V, PPM	15
VISCOSITY, SSF @ 122F	67
ASPHALTENES, % BY WEIGHT	2.4

RECEIVED

APR 01 1991

ENV. PERMITTING

COPIES TO: PSN PLANT MGR.
R N ALLEN - JEN/EDO
PLANT RESULTS DEPT
K WASHINGTON - PRS/EDO

ANALYZED BY: *J. Uzice*

CERTIFIED BY: *H.M. McDonnell*

SANFORD PLANT UNIT 4 ORIMULSION
 EXCESS OPACITY RECORDS LOG
 SIX MINUTE INTERVALS ABOVE 80%

MONTH MARCH YEAR 1991

EXCESS EMISSIONS

* OTHER - NOT ACCEPTABLE TO D.E.R.

	START UP	SHUT DOWN	RAPID LOAD CHANGE	SOOT BLOWING	MALFUNCTION	* OTHER	TOTAL HOURS > 80%	TOTAL HOURS ON ORIMULSION
1				32			3:12	21:22
2	12						1:12	OFFLINE 24 HRS.
3				4			:24	OFFLINE 24 HRS.
4				8			:48	24:00
5				6			:36	24:00
6				6			:36	24:00
7				2			:12	24:00
8				7			:42	24:00
9				4			:24	24:00
10				9			:54	24:00
11				9			:54	24:00
12				14			1:24	24:00
13				9			:54	21:39
14								OFFLINE 24 HRS
15								OFFLINE 24 HRS
16								OFFLINE 24 HRS
17								OFFLINE 24 HRS
18								OFFLINE 24 HRS
19								OFFLINE 24 HRS
20								OFFLINE 24 HRS
21								OFFLINE 24 HRS
22								OFFLINE 24 HRS
23	16						1:36	OFFLINE 24 HRS
24				6			:36	13:34
25				10			1:00	24:00
26				8			:48	24:00
27				17			1:42	24:00
28				17			1:42	24:00
29				37			3:42	24:00
30				48			4:48	24:00
31				40			4:00	24:00



Inter-Office Correspondence

To: M. A. Smith, Ph.D. - Mgr. FPL Date: April 18, 1991
Environmental Affairs

From: R. T. Ruhlman Department: Sanford Plant

Subject: SANFORD UNIT 4 ORIMULSION PROJECT
MONTHLY SULFUR DIOXIDE
EXCESS EMISSION REPORT

During the month of March, 1991, sulfur dioxide emission did not exceed the 4.3 pounds per million BTU input allowed based on the continuous emission monitors.



R. T. Ruhlman
Plant Manager
Sanford Plant

RTR:eh

cc: PSN C-29.1

**FLORIDA POWER & LIGHT CO.
SANFORD PLANT
MONTHLY ORIMULSION AIR EMISSIONS REPORT**

MONTH OF March 1991

NUMBER OF FULL POWER BURN DAYS	<u>14.8</u>
NUMBER OF BARRELS OF ORIMULSION BURNED	<u>320958</u>
NUMBER OF DAYS ORIMULSION BURNED	<u>22</u>
ORIMULSION AS-FIRED MMBTU/BARREL	<u>4.471</u>
NUMBER OF BARRELS OF OIL BURNED	<u>0</u>
NUMBER OF DAYS OIL BURNED	<u>0</u>
OIL AS-FIRED MMBTU/BARREL	<u>6.322</u>

MARCH 1991

FLORIDA POWER & LIGHT
 ORIMULSION TEST PROJECT
 SANFORD PLANT

HEAT VALUE
 4.471

DATE	UNIT 3		UNIT 4				UNIT 5	
	#3 MCF GAS	#3 BBL OIL	#4 BBL OIL	#4 MCF GAS	#4 ORIMULSION BBL	#4 FULL POWER BURN DAYS	#5 BBL OIL	#5 MCF GAS
03/01/91	340	0	0	0	14902	0.7	0	0
03/02/91	357	0	0	0	144	0.0	0	0
03/03/91	49	0	0	0	861	0.0	0	0
03/04/91	7438	0	0	0	16050	0.7	0	0
03/05/91	2931	0	0	0	18167	0.8	0	0
03/06/91	295	0	0	0	18639	0.9	0	0
03/07/91	257	0	0	0	20159	0.9	0	0
03/08/91	13334	0	0	0	18950	0.9	0	0
03/09/91	232	0	0	0	18768	0.9	0	0
03/10/91	0	0	0	0	18257	0.8	0	0
03/11/91	7610	0	0	0	17130	0.8	0	0
03/12/91	5978	0	0	0	17870	0.8	0	0
03/13/91	5201	0	0	0	14618	0.7	173	0
03/14/91	8918	0	0	0	0	0.0	5500	0
03/15/91	12849	0	0	0	0	0.0	1599	0
03/16/91	17478	0	0	0	0	0.0	0	0
03/17/91	16836	0	0	0	0	0.0	29	0
03/18/91	14177	0	0	0	0	0.0	4998	0
03/19/91	15511	0	0	0	0	0.0	2002	0
03/20/91	11017	0	0	0	0	0.0	0	0
03/21/91	4967	0	0	0	0	0.0	1505	0
03/22/91	10922	0	0	0	0	0.0	4005	0
* 03/23/91	13513	0	0	0	262	0.0	4036	0
03/24/91	259	0	0	0	10299	0.5	0	0
03/25/91	6618	0	0	0	18808	0.9	0	0
03/26/91	4690	0	0	0	19483	0.9	0	0
03/27/91	16085	0	0	0	16763	0.8	0	0
03/28/91	22951	0	0	0	17388	0.8	0	0
03/29/91	23446	0	0	0	16192	0.7	0	0
03/30/91	12682	0	0	0	15401	0.7	0	0
03/31/91	7596	0	0	0	11847	0.5	0	0
TOTALS	264537	0	0	0	320958	14.8	23847	0

* ORIMULSION FIRE OUT #4 UNIT AT 21:40, OIL FIRES IN #5 UNIT 22:05.

** OIL FIRE OUT #5 UNIT AT 21:18, ORIMULSION FIRE IN #4 UNIT AT 21:50.



S-3^h - 58 2+3+8+2
 N-1^L - 55

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO.	DATE
4 (Orimulsion)	1 MAR 1 1991

SIX MINUTES INTERVALS GREATER THAN 80%

780%

	1	2	3	4	5	6	7	8	9	10		This Hour	Last 24 Hours
MN						87 C-2	90 C-2			88 C-2	12MIN	3	3
AM	82 C-2	81 C-2						82 C-2		88 C-2	1AM	4	7
				82 C-2				91 C-4	90 C-4	93 C-4	2	4	11
	92 C-4		88 C-4								3	2	13
			83 C-4			82 C-4					4	2	15
											5		
											6		
	81 C-2	-	80 C-2								7	2	17
					92 C-2	92 C-2					8	2	19
	82 C-2	-									9	1	20
											10		
											11		
N											12N		
P											1P		
											2		
											3		
											4		
											5		
											6		
											7	1	21
	C-291	C-286	C-289	C-286	C-284	C-289	C-290	C-289	C-286	C-289	8	9	30
	C-289					B-282					9	2	32
											10		
											11		

A MALFUNCTION

MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. 4 (Orimulbin)	DATE MAR 02 1997
----------------------------------	----------------------------

SIX MINUTE INTERVALS GREATER THAN 80 %

Time	SIX MINUTE INTERVALS GREATER THAN 80 %										This Hour Last 24 Hours		
	1	2	3	4	5	6	7	8	9	10	12MN		
12MN													
1AM													
											2		
											3		
											4		
											5		
											6		
											7		
											8		
											9		
											10		
											11		
											12N		
											1P		
											2		
											3		
											4		
											5		
											6		
											7		
											8		
								B-1 91	B-1 92	B-1 92	9	3	3
	B-1 92	B-1 92	B-1 92	B-1 92	B-1 92	B-1 92	B-1 92	B-1 90	B-1 84		10	9	12
											11		

A MALFUNCTION
MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. 4 (Orimulsion)	DATE 5 N MAR 03 1991
-----------------------------------	--------------------------------

SIX MINUTE INTERVALS *Greater Than 80%*

Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
MN											12MN	
AM											1AM	
											2	
											3	
	83 C-2	82 C-2				89 C-2	83 C-2				4	4
											5	
											6	
											7	
											8	
											9	
											10	
											11	
N											12N	
P											1P	
											2	
											3	
											4	
											5	
											6	
											7	
											8	
											9	
											10	
											11	

A MALFUNCTION

MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. 4 (Original)	DATE MON MAR 04 1991
---------------------------------	--------------------------------

SIX MINUTE INTERVALS *Greater Than 80%*

Six Minute Intervals: 78

This Hour Last 24 Hours

Time	1	2	3	4	5	6	7	8	9	10	11	12MN	1AM	2	3	4	5	6	7	8	9	10	11	12N	1P	2	3	4	5	6	7	8	9	10	11	12				
12MN																																								
1AM																																								
2																																								
3																																								
4																																								
5																																								
6																																								
7																																								
8																																								
9																																								
10																																								
11																																								
12N																																								
1P																																								
2																																								
3																																								
4																																								
5																																								
6																																								
7			8502	8102																																				
8																																								
9								8102																																
10	8202	8102	8502	8502																																				
11																																								
12																																								

- A MALFUNCTION**
- MALFUNCTION**
- 1 Monitor Out of Service
 - 2 Burner Problem
 - 3 Control Problem
 - 4 Other

- B START-UP/SHUT-DOWN**
- 1 Start-Up
 - 2 Shut-Down

- C LOAD CHANGE/SOOT-BLOWING**
- *1 Rapid Load Change
 - 2 Soot-blowing
 - 3 Liming Boiler
 - 4 Cleaning Air Pre-heater
- A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. 4 (Orimulsion)	DATE TU MAR 05 1991
-----------------------------------	-------------------------------

SIX MINUTE INTERVALS Greater Than 80%											Six Minute Intervals > 80%	
	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN												
1AM	810-2	810-2									2	2
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12N												
1P												
2												
3												
4												
5												
6												
7												
8	810-2										1	3
9									830-2		1	4
10		880-2			850-2						2	6
11												

A MALFUNCTION
MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

WED MAR 6 1991

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO.	DATE
4 (80% Orimulsion)	

Time	SIX MINUTE INTERVALS										Six Minute Intervals > 80%		
	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours	
12MN											12MN		
1AM											1AM		
2								C-81		C-81	2	2	2
3						C-81				C-85	3	2	4
4	C-81		C-82								4	11	6
5											5		
6											6		
7											7		
8											8		
9											9		
10											10		
11											11		
12N											12N		
1P											1P		
2											2		
3											3		
4											4		
5											5		
6											6		
7											7		
8											8		
9											9		
10											10		
11											11		

A MALFUNCTION
 MALFUNCTION

- * 1 Monitor Out of Service
- * 2 Burner Problem
- * 3 Control Problem
- * 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- *2 Soot-blowing
- *3 Liming Boiler
- *4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO.	DATE
4 (80% Orimulsion)	THU MAR 07 1991

Time	SIX MINUTE INTERVALS										Six Minute Intervals > 80%	
	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8								C-2 ⁸¹			8	1
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8								C-282			8	1
9											9	
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION

- * 1 Monitor Out of Service
- * 2 Burner Problem
- * 3 Control Problem
- * 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

FRI MAR 08 1991
 UNIT NO. _____ DATE _____
 4 (80% Opimulsion)

Time	SIX MINUTE INTERVALS										Six Minute Intervals > 80%	
	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7		80c-2									7	1
8									80c-2	84c-2	8	2
9	84c-2	86c-2	81c-2	86c-2							9	4
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION
 * 1 Monitor Out of Service
 * 2 Burner Problem
 * 3 Control Problem
 * 4 Other

B START-UP/SHUT-DOWN
 1 Start-Up
 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING
 * 1 Rapid Load Change
 * 2 Soot-blowing
 * 3 Liming Boiler
 * 4 Cleaning Air Pre-heater

INSTRUCTIONS
 Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.
 Use the comment column where additional explanation is appropriate.

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. **SAT** DATE **MAR 9 1991**
 4 (80% Orimulsion)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%	
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7			c-281				c-283			c-287	7	3
8				c-284							8	1
9											9	
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION

- * 1 Monitor Out of Service
- * 2 Burner Problem
- * 3 Control Problem
- * 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

SUN MAR 10 1991

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO.	DATE
4 (80% Orimulsion)	

Time	SIX MINUTE INTERVALS										Six Minute Intervals > 80%		
	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours	
12MN											12MN		
1AM											1AM		
2											2		
3											3		
4											4		
5											5		
6											6		
7											7		
8	c-2 82	c-2 83	c-2 83	c-2 81							8	#	#
9											9		
10											10		
11											11		
12N											12N		
1P											1P		
2											2		
3											3	.	
4						83c-a	83 c-a			8/c-a	4	3	7
5	c-2 84	83c-a									5	2	9
6											6		
7											7		
8											8		
9											9		
10											10		
11											11		

- A MALFUNCTION**
- MALFUNCTION
- * 1 Monitor Out of Service
 - * 2 Burner Problem
 - * 3 Control Problem
 - * 4 Other

- B START-UP/SHUT-DOWN**
- 1 Start-Up
 - 2 Shut-Down

- C LOAD CHANGE/SOOT-BLOWING**
- *1 Rapid Load Change
 - 2 Soot-blowing
 - 3 Liming Boiler
 - 4 Cleaning Air Pre-heater
- A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO.	DATE
4 (80% Orimulsion)	

SIX MINUTE INTERVALS											Six Minute Intervals > 80%	
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10			C-2 ⁸¹								10	1
11											11	
12N											12N	
1P											1P	
2											2	
3										81C-2	3	1
4	82C-2					82C-2		82C-2	82C-2		4	4
5		80C-2			86C-2	82C-2					5	3
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	

- A MALFUNCTION**
 MALFUNCTION
- * 1 Monitor Out of Service
 - * 2 Burner Problem
 - * 3 Control Problem
 - * 4 Other

- B START-UP/SHUT-DOWN**
- 1 Start-Up
 - 2 Shut-Down

- C LOAD CHANGE/SOOT-BLOWING**
- *1 Rapid Load Change
 - 2 Soot-blowing
 - 3 Liming Boiler
 - 4 Cleaning Air Pre-heater

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. DATE
 4 (80% Opacity) **TUE** MAR 12 1991

Time	SIX MINUTE INTERVALS										Six Minute Intervals > 80%		
	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours	
12MN											12MN		
1AM											1AM		
2											2		
3											3		
4											4		
5											5		
6											6		
7											7		
8											8		
9				0.781	82c2						9	2	2
10											10		
11											11		
12N											12N		
1P											1P		
2											2		
3											3		
4									95c2	81c2	4	2	4
5	81c2							81c2	92c2	89c2	5	4	8
6	82c2		84c2				88c2		72c2		6	4	12
7	85c2	88c2									7	2	14
8											8		
9											9		
10											10		
11											11		

A MALFUNCTION

MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- * 1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding start-up and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

WED MAR 13 1991

UNIT NO.	DATE
4 (80% Orimulsion)	

Time	SIX MINUTE INTERVALS										Six Minute Intervals > 80%		
	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours	
12MN											12MN		
1AM											1AM		
2											2		
3											3		
4											4		
5											5		
6											6		
7									80C-2		7	1	
8											8		
9											9		
10											10		
11											11		
12N											12N		
1P											1P		
2											2		
3											3		
4											4		
5					84C4	88-C4	84-C4				5	3	4
6									82C2		6	1	5
7					93-C2						7	1	6
8		80-C2							86-C2		8	2	8
9	88C2										9	1	9
10											10		
11											11		

- A MALFUNCTION**
 MALFUNCTION
- * 1 Monitor Out of Service
 - * 2 Burner Problem
 - * 3 Control Problem
 - * 4 Other

- B START-UP/SHUT-DOWN**
- 1 Start-Up
 - 2 Shut-Down

- C LOAD CHANGE/SOOT-BLOWING**
- *1 Rapid Load Change
 - 2 Soot-blowing
 - 3 Liming Boiler
 - 4 Cleaning Air Pre-heater
- A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional

Document chart lab will provide reason codes

TEMPORARY 80% thru 5/31/91

SANFORD PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. 4 (CALCULATED)	DATE 3-14-91
-------------------------------	-----------------

Time	SIX MINUTE INTERVALS > 80%										SIX MINUTE INTERVALS > 80%	
	1	2	3	4	5	6	7	8	9	10	THIS HOUR	LAST HOUR
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Temporary 8090 thru 5/31/91

SANFORD PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. 4 (OPIMYLSAN)	DATE 3-15-91
---------------------------	-----------------

Time	SIX MINUTE INTERVALS > 8090										SIX MINUTE INTERVALS > 8090	
	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hrs
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	

A MALFUNCTION
MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Temporary 80% thru 5/31/91

SANFORD PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. 4 (ORIMULSION)	DATE 3-16-91
----------------------------	-----------------

Time	SIX MINUTE INTERVALS > 80%										SIX MINUTE INTERVALS > 80%	
	1	2	3	4	5	6	7	8	9	10	THIS HOUR	LAST 24 HRS
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	

A MALFUNCTION
MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- * 1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. **MON** **MAR 17 1991**
4 (80% Orimulsion)

SIX MINUTE INTERVALS											<i>Six Minute Intervals > 80%</i>	
Time	1	2	3	4	5	6	7	8	9	10	<i>This Hour</i>	<i>Last 24 Hours</i>
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION

- * 1 Monitor Out of Service
- * 2 Burner Problem
- * 3 Control Problem
- * 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru May 31, 1991

SANFORDS PLANT
 DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. 4 (dimulsion)	DATE MAR 18 1991
---------------------------	---------------------

Time	SIX MINUTE INTERVALS > 80%										SIX MINUTE INTERVALS > 80%	
	1	2	3	4	5	6	7	8	9	10	THIS HOUR	LAST 24 HRS
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	

A MALFUNCTION MALFUNCTION * 1 Monitor Out of Service * 2 Burner Problem * 3 Control Problem * 4 Other	B START-UP/SHUT-DOWN 1 Start-Up 2 Shut-Down	C LOAD CHANGE/SOOT-BLOWING *1 Rapid Load Change 2 Soot-blowing 3 Liming Boiler 4 Cleaning Air Pre-heater A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.	INSTRUCTIONS Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems. Use the comment column where additional explanation is appropriate.
---	--	---	---

*Need cause + corrective action

PSN

PLANT

DAILY OPACITY EMISSIONS REPORT
Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO.	DATE
4	TUE MAR 19 1991

Time	SIX MINUTE INTERVALS										COMMENTS	
	1	2	3	4	5	6	7	8	9	10		
12MN												12MN
1AM												1AM
2												2
3												3
4												4
5												5
6												6
7												7
8												8
9												9
10												10
												11
12N												12N
1P												1P
2												2
3												3
4												4
5												5
6												6
7												7
8												8
9												9
10												10
11												11

A MALFUNCTION
MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Temporary 80% thru 5/31/91

Sanford 4 PLANT
 DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stacked) Rev. 2/84

UNIT NO. WED MAR 20 1991
 4 (80% Orimulsion)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%	
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2								15			2	/
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION
 * 1 Monitor Out of Service
 * 2 Burner Problem
 * 3 Control Problem
 * 4 Other

B START-UP/SHUT-DOWN
 1 Start-Up
 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING
 * 1 Rapid Load Change
 2 Soot-blowing
 3 Liming Boiler
 4 Cleaning Air Pre-heater
 A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS
 Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.
 Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford 4 PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. **THU** DATE **MAR 21 1991**
4 (80% Opacity)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%	
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

FRI MAR 2 2 1991
 UNIT NO.
 DATE 2 1991
 4 (80% Opacity)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%	
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION

- * 1 Monitor Out of Service
- * 2 Burner Problem
- * 3 Control Problem
- * 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. ETA DATE MAR 23 1991
4 (80% Opacity)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%	
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10		B-198	B-198	B-198	B-198			B-198	B-198	B-198	10	11 7
11	B-198	B-198	B-198	B-198	B-198	93B1	89B1	B-84	80B1		11	11 9 16

A MALFUNCTION
 MALFUNCTION

- * 1 Monitor Out of Service
- * 2 Burner Problem
- * 3 Control Problem
- * 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- *2 Soot-blowing
- *3 Liming Boiler
- *4 Cleaning Air Pre-heater

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. **SUN MAR 24 1991**
 4 (80% Orimulsion)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%		
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours	
12MN											12MN		
1AM											1AM		
2											2		
3											3		
4											4		
5											5		
6											6		
7											7		
8											8		
9											9		
10											10		
11											11		
12N											12N		
1P				0.204	92.0	81.0	89.0				4	4	
2								85.0			1	5	
3		82.0									3	1	6
4											4		
5											5		
6											6		
7											7		
8											8		
9											9		
10											10		
11											11		

A MALFUNCTION
 MALFUNCTION
 * 1 Monitor Out of Service
 * 2 Burner Problem
 * 3 Control Problem
 * 4 Other

B START-UP/SHUT-DOWN
 1 Start-Up
 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING
 *1 Rapid Load Change
 *2 Soot-blowing
 *3 Liming Boiler
 *4 Cleaning Air Pre-heater

INSTRUCTIONS
 Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.
 Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. **MON** DATE **MAR 25 1991**
 4 (80% Orimulsion)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%	
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10						C2 84		C2 81			10	2
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7	C2 88 C4 87	C2 87 C4 87	C2 84 C4 84	C2 81 C4 81			C2 80 C4 80			C2 86 C4 86	7	6
8											8	8
9						C2 84 C4 84		C2 82 C4 82			9	2
10											10	10
11											11	

A MALFUNCTION
 MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. _____ DATE **TUE MAR 26 1991**
4 (80% Orimulsion)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%	
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4											4	
5											5	
6											6	
7											7	
8			85c-2	84c-2	82c-2	87c-2	92c-2	81c-2	c-280		8	7
9	83c-4										9	8
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION

- 1 Monitor Out of Service
- 2 Burner Problem
- 3 Control Problem
- 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. **WED** DATE **MAR 27 1991**
 4 (80% Opimulsion)

Time	SIX MINUTE INTERVALS										Six Minute Intervals > 80%	
	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3									81c2	81c2	3	2
4	81c2		c2s4	85c2	83c2						4	4
5											5	
6											6	
7	c2s5	91c2				81c2					7	3
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2											2	
3											3	
4	c-2 c-4 80										4	1
5						c-2-86 c-4 86					5	1
6							c-2 81 c-4 81			82c2	6	2
7	c-2 c-4 86	c-2 c-4 84	c-2 c-4 81		c-2 c-4 82						7	4
8											8	
9											9	
10											10	
11											11	

A MALFUNCTION
 MALFUNCTION
 * 1 Monitor Out of Service
 * 2 Burner Problem
 * 3 Control Problem
 * 4 Other

B START-UP/SHUT-DOWN
 1 Start-Up
 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING
 *1 Rapid Load Change
 2 Soot-blowing
 3 Liming Boiler
 4 Cleaning Air Pre-heater
 A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding start-up and shut-down.

INSTRUCTIONS
 Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.
 Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. **THU MAR 28 1991**
 4 (80% Orimulsion)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%	
Time	1	2	3	4	5	6	7	8	9	10	This Hour	Last 24 Hours
12MN											12MN	
1AM											1AM	
2											2	
3											3	
4											4	
5								C2 85			5	1
6							C2 89				6	1
7											7	
8											8	
9											9	
10											10	
11											11	
12N											12N	
1P											1P	
2										C-2 81	2	1
3											3	3
4											4	
5										C2 98	5	1
6	C2 90	C2 94		82C2	88C2						6	4
7											7	
8								C2-81	C2-93		8	2
9					82C2	86C2	82C2	81C2	86C2		9	5
10				84C2							10	1
11					80C2						11	1

A MALFUNCTION

- MALFUNCTION**
- * 1 Monitor Out of Service
 - * 2 Burner Problem
 - * 3 Control Problem
 - * 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Santford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO. MAR 29 1991
 4 (80% Opimulsion)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%		
Time	1	2	3	4	5	6	7	8	9	10		This Hour	Last 24 Hours
12MN											12MN		
1AM							83C2		81C2	84C2	1AM	3	3
2	85C2	80C2	83C2	89C2	91C2		85C2				2	6	9
3											3		
4											4		
5										81C2	5	1	10
6	89C2	87C2	82C2	81C2	81C2			84C2	82C2		6	7	17
7											7		
8											8		
9											9		
10							89C2	83C2			10	2	19
11											11		
12N											12N		
1P											1P		
2											2		
3							C-2 82 C-4 82	C-2 83 C-4 83	C-2 80 C-4 80		3	3	22
4											4		
5											5		
6			C-2 92 C-4 92			C-2 89 C-4 89					6	2	24
7									C-2 81 C-4 81		7	1	25
8						C-2 85 C-4 85		C-2 82 C-4 82	C-2 81 C-4 81		8	3	28
9			C-2 81 C-4 81								9	1	29
10								C-2 80 C-4 80	C-2 88 C-4 88	C-2 82 C-4 82	10	3	32
11	C-2 82 C-4 82	C-2 87 C-4 87	C-2 80 C-4 80	C-2 86 C-4 86	C-2 84 C-4 84						11	5	37

A MALFUNCTION MALFUNCTION * 1 Monitor Out of Service * 2 Burner Problem * 3 Control Problem * 4 Other	B START-UP/SHUT-DOWN 1 Start-Up 2 Shut-Down	C LOAD CHANGE/SOOT-BLOWING *1 Rapid Load Change 2 Soot-blowing 3 Liming Boiler 4 Cleaning Air Pre-heater A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.	INSTRUCTIONS Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems. Use the comment column where additional explanation is appropriate.
---	--	---	---

Document chart lab will provide reason codes

operating at greater than 10% of rated capacity, excluding startup and shutdown. explanation is appropriate.

Tempor 80% thru 5/31/91

Sanford PLANT
 DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO.

SAT MAR 30 1991

4 (80% Orimulsion)

SIX MINUTE INTERVALS											Six Minute Intervals > 80%		
Time	1	2	3	4	5	6	7	8	9	10		This Hour	Last 24 Hours
12MN											12MN		
1AM											1AM		
2										C283	2	1	1
3			C282		C284	C282					3	3	3
4											4		
5											5		
6											6		
7			C281			C282	C283	C283	C282		7	5	8
8											8		
9											9		
10					C288	C284					10	2	10
11											11		
12N				C281	C285						12N	2	12
1P											1P		
2											2		
3											3		
4				C282	C280					C287	4	2	15
5						C2100	C2100	C2100	C2100	C2100	5	5	20
6	C490	C4100	100C4	92C4	100C4	100C4		85C4	92C4	82C4	6	9	29
7		83C4		81C4		81C4	91C4	93C4	100C4	90C4	7	7	36
8	C280				87C2	86C2		80C2	80C2		8	8	41
9					84C2	89C2	86C2	80C2			9	4	45
10						80C2	83C2	87C2			10	3	48
11											11		

A MALFUNCTION

MALFUNCTION

- * 1 Monitor Out of Service
- * 2 Burner Problem
- * 3 Control Problem
- * 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated capacity, excluding startup and shutdown.

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

Temporary 80% thru 5/31/91

Sanford PLANT
DAILY OPACITY EMISSIONS REPORT
 Form 4954 (Non-Stocked) Rev. 2/84

UNIT NO.	DATE
4 (80% Opacity)	MAR 31 1991

SIX MINUTE INTERVALS											Six Minute Intervals > 80%		
Time	1	2	3	4	5	6	7	8	9	10		This Hour	Last 24 Hours
12MN									90C2	92C2	12MN	2	2
1AM	91C2	97C2	82C2				81C2				1AM	4	6
2											2		
3											3		
4				81C2		83C2	83C2	83C2	81C2	82C2	4	6	11
5	82C2	82C2	81C2			82C2	82C2				5	5	16
6				81C2			81C2		81C2		6	3	19
7	85C2	80C2	81C2	82C2				86C2	88C2	87C2	7	7	25
8											8		
9											9		
10										80C2	10	1	
11					81C2						11	1	26
12N											12N		
1P											1P		
2											2		
3											3		
4											4		
5			C281	C282			C288	C286	C287	C289	5	6	32
6											6		
7											7		
8											8		
9											9		
10	C281	C281	C281	C281							10	4	35
11	C282										11	1	

A MALFUNCTION
 MALFUNCTION

- * 1 Monitor Out of Service
- * 2 Burner Problem
- * 3 Control Problem
- * 4 Other

B START-UP/SHUT-DOWN

- 1 Start-Up
- 2 Shut-Down

C LOAD CHANGE/SOOT-BLOWING

- *1 Rapid Load Change
- 2 Soot-blowing
- 3 Liming Boiler
- 4 Cleaning Air Pre-heater

A rapid load change is defined as a change that occurs at the rate of 0.5% per minute or more and exceeds 10% of the units rated capacity and occurs when the unit is operating at greater than 10% of rated

INSTRUCTIONS

Fill in the opacity and reason code or codes in the appropriate box whenever the opacity exceeds 20% for any 6 minute period on the recorder. Example: 50A3 indicates an opacity reading of 50% attributed to control problems.

Use the comment column where additional explanation is appropriate.

Document chart lab will provide reason codes

SECTION 2
NOX #/MMBTU HOURLY AVERAGES

The following data was compiled from data obtained by the data acquisition system provided with the Continuous Emissions Monitoring equipment supplied by Spectrum Systems Inc.. The DAS is a certified data collection system. The data was collected starting with the initial orimulsion test burn. The fuel factor used for calculations was 9190.

NOX IN POUNDS PER MILLION BTU, FP&L, SANFORD PLANT, UNIT 4. MONTH OF MARCH, 1991.

HR BEGIN	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23		
HR END	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
DAY OF																										DAILY
MONTH																										AVERAGE
1	0.68	0.66	0.65	0.63	0.64	0.67	0.70	0.65	0.53	0.46	0.39	0.55	0.55	0.50	0.62	0.53	0.57	0.65	0.67	0.68	0.69	0.27	-0.07	-0.07	0.53	
2	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	0.07	0.41	0.53	-0.02
3	0.54	0.53	0.40	0.52	0.44	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.07	-0.08	-0.08	-0.07	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	0.04
4	0.28	0.41	0.40	0.42	0.44	0.58	0.44	0.42	0.48	0.41	0.40	0.41	0.44	0.44	0.47	0.56	0.59	0.56	0.55	0.59	0.55	0.48	0.64	0.58	0.48	
5	0.58	0.57	0.56	0.58	0.59	0.57	0.42	0.52	0.53	0.57	0.58	0.59	0.58	0.52	0.57	0.55	0.61	0.62	0.61	0.69	0.69	0.64	0.58	0.55	0.58	
6	0.50	0.48	0.48	0.52	0.52	0.53	0.57	0.67	0.62	0.63	0.66	0.64	0.57	0.58	0.65	0.63	0.64	0.65	0.66	0.68	0.67	0.65	0.64	0.66	0.60	
7	0.66	0.62	0.64	0.70	0.65	0.64	0.70	0.71	0.70	0.69	0.69	0.67	0.67	0.74	0.74	0.68	0.66	0.67	0.66	0.68	0.68	0.63	0.61	0.65	0.65	0.67
8	0.64	0.73	0.68	0.61	0.62	0.66	0.76	0.76	0.77	0.77	0.76	0.75	0.74	0.73	0.74	0.76	0.76	0.76	0.76	0.76	0.76	0.76	0.78	0.68	0.65	0.72
9	0.74	0.74	0.75	0.61	0.61	0.64	0.75	0.73	0.74	0.63	0.75	0.58	0.72	0.46	0.50	0.84	0.83	0.71	0.72	0.77	0.71	0.72	0.72	0.73	0.74	0.70
10	0.74	0.75	0.63	0.63	0.62	0.72	0.81	0.84	0.83	0.84	0.85	0.84	0.84	0.89	0.84	0.81	0.71	0.71	0.65	0.62	0.62	0.60	0.61	0.64	0.73	
11	0.85	0.79	0.85	0.89	0.73	0.65	0.79	0.83	0.71	0.62	0.71	0.65	0.64	0.61	0.61	0.60	0.54	0.61	0.63	0.64	0.64	0.63	0.65	0.58	0.69	
12	0.57	0.56	0.56	0.56	0.56	0.56	0.63	0.56	0.52	0.59	0.49	0.61	0.71	0.72	0.70	0.64	0.63	0.65	0.57	0.57	0.56	0.53	0.63	0.58	0.59	
13	0.58	0.58	0.57	0.58	0.58	0.63	0.61	0.60	0.56	0.54	0.48	0.47	0.51	0.59	0.58	0.57	0.58	0.51	0.66	0.65	0.67	0.54	-0.08	-0.08	0.52	
14	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
15	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.07	-0.07	-0.07	-0.07	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
16	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
17	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
18	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
19	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
20	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
21	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
22	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
23	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08	-0.08
24	0.61	0.06	0.64	0.43	0.51	0.41	0.44	0.56	0.38	0.55	0.58	0.59	0.60	0.60	0.56	0.52	0.35	0.36	0.39	0.46	0.54	0.50	0.45	0.42	0.48	
25	0.57	0.62	0.54	0.48	0.52	0.49	0.48	0.40	0.66	0.77	0.82	0.82	0.77	0.50	0.54	0.52	0.50	0.49	0.51	0.58	0.63	0.73	0.62	0.66	0.59	
26	0.62	0.53	0.51	0.61	0.64	0.58	0.65	0.65	0.67	0.71	0.73	0.74	0.74	0.76	0.75	0.74	0.72	0.71	0.69	0.70	0.70	0.70	0.70	0.63	0.50	0.66
27	0.55	0.55	0.55	0.57	0.60	0.60	0.67	0.63	0.66	0.65	0.67	0.70	0.69	0.70	0.71	0.73	0.67	0.67	0.64	0.65	0.68	0.74	0.72	0.68	0.65	
28	0.68	0.68	0.68	0.68	0.67	0.66	0.63	0.52	0.60	0.84	0.62	0.62	0.64	0.64	0.61	0.61	0.57	0.57	0.61	0.59	0.54	0.58	0.53	0.48	0.61	
29	0.59	0.60	0.60	0.58	0.58	0.56	0.56	0.46	0.43	0.43	0.58	0.66	0.68													0.56
30																	0.63	0.62	0.65	0.72	0.76	0.72	0.53	0.49	0.56	0.63
31	0.63	0.65	0.66	0.66	0.66	0.65	0.64	0.64	0.65	0.65	0.65	0.65	0.65	0.65	0.65											0.65

BLACKENED SQUARES INDICATE INVALID OR INSUFFICIENT DATA (e.g. STARTUP, SHUTDOWN, INSTRUMENT OUT OF SERVICE) WAS OBTAINED TO CALCULATE AN HOURLY AVERAGE.

SECTION 3
CO PPM HOURLY AVERAGES

The following data was compiled from data obtained by the data acquisition system provided with the Continuous Emissions Monitoring equipment supplied by Spectrum Systems Inc.. The DAS is a certified data collection system. The data was collected starting with the initial orimulsion test burn.

CO IN PARTS PER MILLION, FP&L, SANFORD PLANT, UNIT 4, MONTH OF MARCH, 1991.

HR BEGIN	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	DAILY	
HR END	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	AVERAGE	
DAY OF MONTH																										
1	46	-1	0	0	0	-1	407	772	29	0	0	728	731	394	821	855	920	697	528	439	0	46	-1	-1	309	
2	0	-1	-1	-1	-1	-1	-1	-1	-1	-1	0	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	104	325	220	26
3	87	48	67	62	68	20	18	10	5	3	3	2	1	0	0	0	-1	-1	0	0	0	-1	0	0	16	
4	121	78	20	1	-1	-1	706	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002	1001	999	1002	93	-1	668
5	-1	-1	-1	-1	-1	390	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002	995	889	852	380	309	484	27	-2	597	
6	-2	-2	-2	-2	-2	-2	503	778	1002	1002	815	780	1002	735	383	525	452	377	320	238	280	379	379	451	433	
7	437	530	507	-2	-2	-2	140	60	72	126	157	234	315	407	507	580	623	529	571	476	803	944	814	633	386	
8	703	277	-2	-2	-2	-2	84	38	29	20	26	45	64	103	85	20	16	15	10	10	6	1	244	518	96	
9	110	194	87	-1	-1	-2	-1	-1	-1	-1	13	481	315	973	670	-1	2	372	412	120	294	292	283	218	201	
10	267	1	-1	-1	-1	-1	21	7	11	13	11	13	13	2	-2	-1	36	280	743	1002	978	1002	1002	864	261	
11	-1	-1	-1	-1	329	789	563	64	106	362	71	-1	-2	-2	-1	-1	-1	50	125	92	97	76	-1	-1	112	
12	-1	-1	-1	-1	-1	-1	121	885	998	788	981	612	39	42	98	192	192	154	724	334	560	781	-1	-1	312	
13	-2	-1	-1	-1	-1	-1	422	302	194	706	964	1002	1002	1002	1002	1002	1002	1002	616	448	-1	53	0	-1	446	
14	-1	-1	-1	0	0	-1	-1	0	-1	-1	0	-1	-1	-1	-1	0	-1	-1	-1	-1	0	0	-1	0	-1	
15	-1	-1	-1	0	0	-1	-1	-1	-1	-1	-1	-1	-1	-1	0	0	0	-1	0	0	0	0	-1	0	-1	
16	0	0	0	0	0	0	0	0	0	0	0	0	-1	-1	0	0	0	0	-1	0	0	0	-1	0	0	
17	-1	-1	-1	0	-1	0	0	0	0	0	-1	0	0	-1	-1	-1	-1	0	-1	-1	-1	-1	-1	-1	-1	
18	0	-1	-1	-1	-1	-1	-1	0	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	0	-1	0	-1	-1	-1	-1	
19	0	-1	0	-1	-1	0	-1	-1	-1	-1	-1				0	0	-1	0	-1	0	-1	-1	0	0	-1	
20	-1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	-1	-1	0	-1	-1	-1	0	
22	-1	0	-1	-1	-1	-1	-1	-1	-1	0	-1	-1	0	0	0	0	0	-1	-1	0	-1	-1	-1	-1	-1	
23	-1	-1	-1	-1	-1	0	-1	1	0	0	-1	-1	-1	0		-1	-1	-1	-1	0	0	9	313	529	36	
24	183	31	68	197	105	188	111	80	94	105	40	31	4	19	94	422	879	1002	901	475	65	196	424	753	269	
25	54	10	57	348	197	381	449	942	211	17	3	0	122	955	990	1002	1002	1002	987	827	465	-1	-2	-2	417	
26	-1	-1	6	2	-2	27	54	153	52	10	11	6	9	6	8	20	29	56	83	37	16	4	68	44	29	
27	-2	-2	-1	-2	-2	-2	-2	319	122	135	147	52	82	139	113	109	274	207	340	172	96	1	-1	-2	96	
28	-2	-1	-2	-1	-2	-1	85	869	464	257	376	465	428	517	786	810	984	966	606	708	714	42	-2	0	378	
29	-1	-2	-2	-2	-1	1	549	949	1002	1002	456	103	53	86	102	77	94	81	994	906	596	17	-1	-1	294	
30	-1	-2	-2	-1	-2	-1	-1	-1	-1	-1	-1	483	910	0	817	490	731	570	328	89	44	-1	-2	-2	185	
31	-2	-2	-1	-1	-1	-1	-2	-2	-2	-2	-2	-1	-2	-1	-2	-1	-2	-1	-1	-1	-1	-1	-1	-1	-1	

BLACKENED SQUARES INDICATE INVALID OR INSUFFICIENT DATA (e.g. STARTUP, SHUTDOWN, INSTRUMENT OUT OF SERVICE) WAS OBTAINED TO CALCULATE AN HOURLY AVERAGE.

**CONTINUOUS EMISSIONS MONITORING REPORT
FLORIDA POWER AND LIGHT
SANFORD PLANT
UNIT FOUR
ORIMULSION TEST BURN PROJECT
MONTH OF MARCH, 1991**

**DATA COMPILED BY
SPECTRUM SYSTEMS INC.
PENSACOLA, FL**

SECTION 1
SIX MINUTE OPACITY AVERAGES

The following data was compiled from a copy of the original strip chart recordings provided to Spectrum Systems Inc. by Florida Power and Light for unit four at the Sanford Plant. Hourly averages were obtained by taking the sum of the valid six minute averages and dividing by the number of valid averages. This gives a real average based on known good minutes. The squares on the data table that are blacked in are the six minute averages that were deemed invalid due to calibrations happening, or any reason causing the integrated output from the opacity monitor to go to zero while the unit is on-line.

Opacity Monitor Six Minute Averages, March 1, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	57	56.5	56.5	54	74	87	90	80		88	71.44
1: A.M.	82	81	66	62	71.5	62	50.5	82	72	88	71.70
2: A.M.	62	72.5	68.6	82	75.8	75.9	79.6	91	90	93	79.04
3: A.M.	90.2		88	69.5	73	66.5	73.5	66	64	59	72.19
4: A.M.	70.6	65	83.8	79	79.2	82	72.2	73	68	68	74.08
5: A.M.	62	64	64	73	67	64	63	64	65	74	66.00
6: A.M.	75	74.8	75.5	68	71	70	76	70	74	72	72.63
7: A.M.	81	72	80	65	72	78	64	58	68	60	69.80
8: A.M.	63	61	71	65.5	91.8	91.8	76	58		72	72.23
9: A.M.	82	78	63	58	58	58	63	62	62	62	64.60
10: A.M.	61	71	60.5	60.5	61.5	60	60	60	61	66	62.15
11: A.M.	71.5	69	64	49	51	51.8	51	50.8	50	50	55.81
12: NOON	51	50	50	50.1	49.5	49.5	49.5	49.5	49.5	49.5	49.81
1: P.M.	49	49	49	48.5	48.2	48	48	48	46.5	46	48.02
2: P.M.	46	45.2	45	45	51	56	56	55	54	54	50.72
3: P.M.	58	54.5	56	56	54	54	53	53.5	57.5	66	56.25
4: P.M.	62	53	56	56	53	53	53	54		52.6	54.73
5: P.M.	53	53	54	54	54	54	54	54	54	54	53.80
6: P.M.	54	54	54	54.5	54.5	54.2	54.2	54.2	54.6	54.6	54.28
7: P.M.	54.2	54.2	54.2	54.2	54.2	54.2	54.2	54.5	64	86.5	58.44
8: P.M.	90	85	88	86	83.2	89	90	89.5	87	79	86.67
9: P.M.	88.5	56.5	54	38	42.5	82	59	55	52.5	52.5	58.05
10: P.M.	53	46	29.5	29.8	21	15	11.5	9.8	16	18.4	25.00
11: P.M.	12	10	8.5	7.8	7	6	5	5	5	5	7.13

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 2, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	4	4	4	4	3	3	2.5	3		2	3.28
1: A.M.	1	0	0	0	0	0	0	0	0	0	0.10
2: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
3: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
4: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
5: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
6: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
7: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
8: A.M.	0	0	0	0	0	0	0		0	0	0.00
9: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
10: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
11: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
12: NOON	0	0	0	0	0	0	0	0	0	0	0.00
1: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
2: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
3: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
4: P.M.	0	0	0	0	0	0	0		0	0	0.00
5: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
6: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
7: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
8: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
9: P.M.	0	0	0	0	30	6	7	91	92	92	31.80
10: P.M.	92	92	92	92	92	92	92	90	92	92	91.80
11: P.M.	66	69	58.5	54	48	40	35.5	32	30	30	46.30

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 3, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	28	27	26	25	25	26	26	28		37	27.56
1: A.M.	37	27.5	31	26	52.5	46	56.5	48	45	38	40.75
2: A.M.	34	43	36	22	48	36	61	44	35	33	39.20
3: A.M.	54	48	74	45	23	37	73	69.5	70	67	56.05
4: A.M.	83.5	81.5	78	66.5	74.5	89	83	78.5	78	28	74.05
5: A.M.	6	2	1	0	0	0	0	0	0	0	0.90
6: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
7: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
8: A.M.	0	0	0	0	0	0	0		0	0	0.00
9: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
10: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
11: A.M.	0	0	0	0	0	0	0	0	0	0	0.00
12: NOON	0	0	0	0	0	0	0	0	0	0	0.00
1: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
2: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
3: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
4: P.M.	0	0	0	0	0	0	0		0	0	0.00
5: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
6: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
7: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
8: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
9: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
10: P.M.	0	0	0	0	0	0	0	0	0	0	0.00
11: P.M.	0	0	0	0	0	0	0	0	0	0	0.00

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 4, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-:18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	3	20	45.5	61	76	72	59	36		33	45.06
1: A.M.	32	30.2	29.8	29	28	30	30.2	29.5	29.5	31.5	29.97
2: A.M.	35	37	34	33	36	42	52	53	46	42	41.00
3: A.M.	46	51	54	61	68	65.6	57	60	62.5	63	58.81
4: A.M.	63	63	68	67	66	65	66	64	64	68	65.40
5: A.M.	74	66	63	62	64.6	64.8	68	64	60.3	58.3	64.50
6: A.M.	63	64	66	67	71	69	74	64	55	53	64.60
7: A.M.	52	52	52	52	52	52.5	52	52.4	53.5	53.8	52.42
8: A.M.	54	56	56	53	51	51	52	53		53	53.22
9: A.M.	53	53	54	55	55.5	56	56.5	56	55.8	55.5	55.03
10: A.M.	55	54	53.5	52.5	53	53	53.4	53.6	53.8	54	53.58
11: A.M.	53	52.5	52	52	51.2	51.2	50.5	50.5	49	48.5	51.04
12: NOON	49	49	49	49	49	49	49	49	49	49	49.00
1: P.M.	49	49	49	49	49	49	49	49	49	49	49.00
2: P.M.	48.6	48.5	49	49	49	50	50	50	50.2	50.5	49.48
3: P.M.	51	51	48	48	51	52	51	52	51.5	51.5	50.70
4: P.M.	51.5	51.5	51	51	50.5	50.5	50.5	52		50.2	50.97
5: P.M.	50.2	50	50	50	51.4	51	51	51	51	51	50.66
6: P.M.	51	51	51	51.5	51.5	51	51.2	51.5	51.5	52	51.32
7: P.M.	51	51	51	85	81	73	76.5	76.5	77.5	78	70.05
8: P.M.	72	65	60	56	69.5	65	66	67	58	54	63.25
9: P.M.	62	64	53	56.5	76	80.5	74.5	76	79	82	70.35
10: P.M.	77	82	81	85	85	64	52	51	54	52.6	68.36
11: P.M.	51	50	49.4	51	49	50	50	52	56.2	64	52.26

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 5, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	72	79	98.5	72	68	68	68	71	68.5		73.89
1: A.M.	81.5	81.5	78	66.5	55	54	55	63.5	74	73	68.20
2: A.M.	72.5	64.5	55.4	56	55.8	60	60.5	65	64	61	61.47
3: A.M.	60	62.6	67	63.5	65.5	62.5	62	57	56.2	56.2	61.25
4: A.M.	58	58.1	59	60	58	56	56	56	57	57.2	57.53
5: A.M.	58	60	62	63	62	63.8	64	60.5	63	64.2	62.05
6: A.M.	59.5	62	60.6	64	63.5	61	60	63	59.4	61	61.40
7: A.M.	55	51.8	52	54.5	56	54	54	49	49	50	52.53
8: A.M.	49.8	49.5	49.5	49	49	49	49	48.5	48		49.03
9: A.M.	48	47.8	47.8	47.8	47.4	47.4	47.4	47	47	46	47.36
10: A.M.	46	46	46	46	46	49	52	53	51	49.5	48.45
11: A.M.	49.5	55	54.5	54	53.5	50	48	46	46	45.5	50.20
12: NOON	45	45	44.8	44.6	44.4	44.2	44	44	44	44	44.40
1: P.M.	44	44	44	44	44	44	44	44.2	45	46.8	44.40
2: P.M.	47	51.5	48	48	48	50	48.5	48.5	48.5	49	48.70
3: P.M.	49	49	52	49.2	49	49	48	48	48	48	48.92
4: P.M.	48.2	48	47	47	48	48	48	48	49		47.91
5: P.M.	48.8	48.8	49	49.2	50	50	50.6	49	48	48.2	49.16
6: P.M.	48	48	47.5	47.5	47.5	48	48	48	52	54	48.85
7: P.M.	58	68	76	78	76	72	72	57	67	67.2	69.12
8: P.M.	82	78	72.6	64	57	55	62	57	68	59	65.46
9: P.M.	54	53	72.4	67	67	77.5	76	76	74	82	69.89
10: P.M.	76	88	70	78	85	74.2	56.5	56.2	55.5	53	69.24
11: P.M.	51	50	51	53	54	56	56	52	53	54	53.00

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 6, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	56	56	56.2	57	57.5	58	57	57	58		56.97
1: A.M.	58.5	59.8	60	59	59	58	60	62	61	61	59.83
2: A.M.	64	71	76	79	74	68	70	81.5	78	80	74.15
3: A.M.	79.2	74	78	74.4	76	81	79	71	71	85	76.86
4: A.M.	80.5	80	82	71	68.6	72	76	76	73	70	74.91
5: A.M.	68	68	67.5	67.5	68	70	70	73	77	71.5	70.05
6: A.M.	73	71	69	66.6	66	68	64.5	62.5	62.5	60	66.31
7: A.M.	58	56	56	56	56.5	56	56	58.5	62	61	57.60
8: A.M.	58	57	56	60	58	62	58	56	53		57.56
9: A.M.	51	51	53	58	58	55	52	53	52	52	53.50
10: A.M.	52	52	52.5	58	60	56	56	55	55	55	55.15
11: A.M.	58	58	57	57	55.5	54	53.5	53.5	53.5	54	55.40
12: NOON	56	55	60	64	55	50	56	60	62	62	58.00
1: P.M.	66	65	66	70	78	77	71	72	66	61	69.20
2: P.M.	63.5	60.5	58.5	56	55	57	58	60	61	59	58.85
3: P.M.	55	53	53	53	53	53	53	53	57	61	54.40
4: P.M.	60	62	64	62.5	62	60	67.5	61	65.5		62.72
5: P.M.	57	54.5	54	54	54	54	54	54	54	54	54.35
6: P.M.	55.8	58	63	62	64	63	63	63	69	66	62.68
7: P.M.	66	68	57	56	56	56	63	72	74	68	63.60
8: P.M.	73	69.5	60	67	63	78	63.5	60	61.5	66	66.15
9: P.M.	70.5	73.5	66	70	60	54	60	75.5	67	67	66.35
10: P.M.	75.5	74	74	74	71.5	71.5	72	71	70	68	72.15
11: P.M.	63.5	64	60.5	55	53	53	52.5	52.5	52.2	52	55.82

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 7, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	52	52	52	52	52	53	57	60.5	65		55.06
1: A.M.	62	58	58	64	65	56	56	59	58	58	59.40
2: A.M.	58	57	54	47	46	56	59	59.5	68	61	56.55
3: A.M.	66	68	64	58.5	72	57	66	52	67	54	62.45
4: A.M.	49	49	51	50	54	51	51	50	52	53	51.00
5: A.M.	62.5	60	58	60	59.5	68	64	63	66	56	61.70
6: A.M.	56	56.5	59	58	58	58	58.5	58	58	57	57.70
7: A.M.	57	57	57	57	57	57	57.5	58	59	63	57.95
8: A.M.	67	65.5	66	70.5	73.5	76	82	77		75	72.50
9: A.M.		72	68	70	69	62	60	68	64	64.5	66.39
10: A.M.	66	66	62	59.5	58	56.2	56.5	70	62	62	61.82
11: A.M.	65	61	58.5	58.5	63	66	62	65	60	58	61.70
12: NOON	56	58	57.5	61	66	68	65.5	60.5	62.5	58	61.30
1: P.M.	56	56.5	56	55	54.5	68	58	55	53	55	56.70
2: P.M.	54	53	54	52	53	56	58	57	60	54	55.10
3: P.M.	55	56	61	60	62	63	61	60	54	54	58.60
4: P.M.	57	64	66	64.5	59.5		47	52.5	52	51	57.06
5: P.M.		55	57	57	59.5	54	55.5	55.5	61	56.5	56.78
6: P.M.	56.5	54.5	54	54	59	61.5	62.5	60	59.5	59.5	58.10
7: P.M.	59	57	63	62	58	61	77	70	65	72.5	64.45
8: P.M.	62	64	74	74	61	82	68	66	79	66.5	69.65
9: P.M.	66.5	68	60.5	65	64	61	56	59	56	58	61.40
10: P.M.	64	67	66	63	60	60	54	53.5	54	54	59.55
11: P.M.	54	54	54	55	56.5	59	62.5	63	61	61	58.00

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 8, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	60	60	58		60	63	63	60	60		60.50
1: A.M.	62	63.5	58	58	66	61	68	70	73	68	64.75
2: A.M.	66	51	62	66	58	44	47	50	56	56	55.60
3: A.M.	54	55	56	56.5	61	70.5	74	70	73.5	70	64.05
4: A.M.	62	59.5	58.5	57	55	55.6	55.7	55.7	55.7	55.7	57.04
5: A.M.	55.7	56	56	56	56	58	54	56	59	55	56.17
6: A.M.	57	58	60		38	59.5	59	59	58.5	58	56.33
7: A.M.	58	58	58	58	60	60	63.5	60.5	61	59	59.60
8: A.M.	59	58	62	64.5	69	72	71	68.5		78.5	66.94
9: A.M.	73	66	70.5	66	63	60	61	60	64	66.5	65.00
10: A.M.	66	64.5	62	61	62	79	66	70	66.5	59.5	65.65
11: A.M.	61	66	66	64	62	60	64	68	62.5	68	64.15
12: NOON	64.2	64	62	63	70	67.5	69	70	63	61.5	65.42
1: P.M.	58.5	58	58	58	57	57.8	57.5	57	57	60	57.88
2: P.M.	62	65	68	70	67.5	67	67.5	67.5	62	68	66.45
3: P.M.	64	62	59	59.5	58	60	63	64	63	62	61.45
4: P.M.	60.5	60	63	62	57.5	59	59	58		57	59.56
5: P.M.	57	58	58	57.5	58	60	61	61	64	67	60.15
6: P.M.	64	58	57.5	57.5	57.5	57.5	59	59	58	58	58.60
7: P.M.	64	80	64	60	64	68	70	68	67.5	70	67.55
8: P.M.	60.5	58	61	64	62	74	73	67	80	84.5	68.40
9: P.M.	86	80	86	76	75	73	68	63	66	70	74.30
10: P.M.	70	66	62	63	66	62	65.5	65.5	65	66	65.10
11: P.M.	70	67	70	70.2	71.5	65	67	62	62	59	66.37

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 9, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	65.5	62	63	66.5	72	69	64	57		56	63.89
1: A.M.	57	57	63.5	60	56	56	62	60	60	64	59.55
2: A.M.	58.5	62	63	64	59	68.5	62	59	60	46	60.20
3: A.M.	46.5	48	50.5	60	68	70	66	66	63	58	59.60
4: A.M.	68	78	67	73	68	64	64	64	57	54	65.70
5: A.M.	54.5	54.5	63	64.5	70	66	63	66	67	53	62.15
6: A.M.	53	51.5	56	66	59		62	56	52.5	52.5	56.50
7: A.M.	54	56	54	54	54	54	54	55	55	55	54.50
8: A.M.	56	54	57	63.5	68	68.2	64	56	54		60.08
9: A.M.	50	50	52	52	52	53	53	52	54	55	52.30
10: A.M.	55.5	59	65	60	56	55	55	54.5	54.2	54.2	56.84
11: A.M.	54	53	61	68.5	70	69.5	64	60	61	70	63.10
12: NOON	78	73	78.5	78	75	72	63	59	64	66	70.65
1: P.M.	68	63	57	51	51	50	47.5	50	52	53	54.25
2: P.M.	52	52	44	49	56	58	64.5	64	62	63	56.45
3: P.M.	60	66	66	62	68	66	64	63	59	57	63.10
4: P.M.	56	55.5	55.8	55.8	57.5	63	72	71	68		61.62
5: P.M.	58	58.5	71.5	78.5	62	55	56	59	62	66	62.65
6: P.M.	69	63	70	65	62	72	64	58	60	75	65.80
7: P.M.	70	68	80	65	69	74	83	68	87	66	73.00
8: P.M.	70	62	83.5	71	65	73	71	71	70	64	70.05
9: P.M.	64	60	68	66	65	68	68.2	65	58	58	64.02
10: P.M.	58	63	60	57	57	63	62	62	70	66.5	61.85
11: P.M.	72.5	73	74	70	63	74	70	68	72	68.5	70.50

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 10, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-:18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	69			62.5	59	58.5	58.5	62.5	62.5		61.79
1: A.M.	58	57.5	53.5	49.5	49.5	52	51	45	43	48	50.70
2: A.M.	53	56	64.5	68	77.6	76.5	71	66	72	67	67.16
3: A.M.	69.5	57.5	53	53.5	53.5	54	53.5	54	54	54	55.65
4: A.M.	56.5	59	60	57	54	54	54	55	55.5	57.2	56.22
5: A.M.	61	58	58.2	60.5	60	71	61	56	58	60	60.37
6: A.M.	65	62	59.8	60	63	72	78	73	61	60	65.38
7: A.M.	58.5	58.5	58	58	58	58	58	59	61	66	59.30
8: A.M.	82	83	83	81	69.5	69.5	80	74.5		74	77.39
9: A.M.	71	64	63	61	62	68	71	69	68	64	66.10
10: A.M.	66	66	66	58	58	60	59	61	64	66	62.40
11: A.M.	65.5	63	62	66	72	77	72	76	70	67	69.05
12: NOON	70	60	60.5	64	66	66	62	58	57	57	62.05
1: P.M.	59	60	61	63	58	59	66	69	65	61	62.10
2: P.M.	58	60.5	68	63	67	67	66	63	56	55	62.35
3: P.M.	58	60.5	66	74	66	54	53.5	53	51	59	59.50
4: P.M.	58.5	57	58	69.5	74	71	83	67		78	68.44
5: P.M.	80.5	84	82.5	77	76	79.5	67.5	60.5	62	62	73.15
6: P.M.	60.5	59.4	60	60	64	66	65	64	63	59	62.09
7: P.M.	56	56	56	59	60	56.5	55	63	66.5	69	59.70
8: P.M.	74	70	70	72	71	70	72	68	71.8	70	70.88
9: P.M.	66	63.5	58	60	63.5	62	60.5	63.5	64	66.5	62.75
10: P.M.	65.5	62	64.5	62	61.5	68	70	69	63	68.5	65.40
11: P.M.	75	72	75	70	63.5	68	62	61	66	72	68.45

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 11, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	68	67	59.5	58	53	50	54	56		64	58.83
1: A.M.	63.5	63.5	58	55	55.2	60.8	59	60	63.2	59	59.72
2: A.M.	65	66	64	72	68.5	66	68.8	56	56	59	64.13
3: A.M.	65	70	71.5	68	62	62	71.8	72	69	69	68.03
4: A.M.	66	60	60	60	58	58	60	63.2	66		61.24
5: A.M.		43	77	68	61	60	59	60	66	72	62.89
6: A.M.	70	63.8	64	70.5	61.5	58.5	58.5	63.2	62	60.8	63.28
7: A.M.	60	60.2	60.2	58	55	56	56	59	68	57.5	58.99
8: A.M.	58	59.5	60	59	64.5	65	64	64.8	57.5	60	61.23
9: A.M.		60	64	60	57	57	59	63	68	64	61.33
10: A.M.	68	68	69	80.2	69	65	73	58	54	54	65.82
11: A.M.	50	49	47	52	50	53	52	48.2	49.5	57.5	50.82
12: NOON	52	49	50	56	58	60	63.5	62	65		57.28
1: P.M.	64	73	66.2	62.5	66	53	52	52	53	53	59.47
2: P.M.	54.2	53.4	53.5	53.4	54	58	61.8	62	58	55	56.33
3: P.M.	55	54	55	55	54	55	54.2	56.2	60	74	57.24
4: P.M.	81	82	78	75	70	79	81	78	82	82	78.80
5: P.M.		76.2	79	76	79	86	82	78	76.2	65	77.49
6: P.M.	65	64	64	64	63	64	64.5	70.5	72	78	66.90
7: P.M.	71.5	64	68	72	67.2	76	68	64	61.5	67	67.92
8: P.M.	65	65	67.5	60.6	63	70.5	76	73	69.2	74	68.38
9: P.M.	63	62.8	68	70	63	59	59	63.5	64	69	64.13
10: P.M.	72	69	69	65	58.5	56.5	56.5	57	60	62	62.55
11: P.M.	64	62	48			53.5	56	58	64.5	60.5	58.31

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 12, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.		65	66	73	68	66	69	56.5		53	64.56
1: A.M.	53	53	53	53	53	53	53	53	53	53	53.00
2: A.M.	53	53	55	61.5	67	70	68	63	58	67	61.55
3: A.M.		63	68	65	60	56	59	56	56	55	59.78
4: A.M.	55.2	55	55	54.5	54.5	56	57	56	54.5	55	55.27
5: A.M.	55	54.8	54	54	54	54.2	57.2	59.2	60.5	62.5	56.54
6: A.M.	64	66	66	67	67.5	67.5	67	67.2	67	61	66.02
7: A.M.	60	58	57	56	63	64	66	68	57	56	60.50
8: A.M.	60	62.5	72	74.2	70	71	71	65.6		68	68.26
9: A.M.	61	67.5	78	81	82	71	59	56	54.5	53.5	66.35
10: A.M.	53	52	51	52	52	51.5	51.5	51	50	52	51.60
11: A.M.	54	54	51	51.2	51	51	51	54	56.2	57	53.04
12: NOON	57.2	58	58	58.5	58.5	59	59	59	59	59	58.52
1: P.M.	59	59	59	59	60	59	59	59	59	66.5	59.85
2: P.M.	74	78									76.00
3: P.M.				58	58	58	58	58	58	58	58.00
4: P.M.	66.5	66	66.2	65.8	67.5	62	78	75.6	95	81	72.36
5: P.M.	81.5	79	72		72	64.6	69	80.5	92	89.5	77.79
6: P.M.	82	72	84	72	68.6	72.8	88	69	92	70	77.04
7: P.M.	85	88	74	65	66	73.8	69	62	61	60	70.38
8: P.M.	60	61.2	64	74	76.8	78	68.8	60	60.2	61.5	66.45
9: P.M.	64	78	79	74	67	60	62.5	64	74	62	68.45
10: P.M.	66	68	70.4	77		66.8	72	56	53.5	55	64.97
11: P.M.	58.5	62	74	74	69	71.5	70	64	63.5	61	66.75

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 13, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-:18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	62	67.5	75	79.5	74.5	62	58.2	58	58	58	65.27
1: A.M.	58	57.2	54.6	57	63	59	55.5	58	64	60	58.63
2: A.M.	70	72	70	74.5	77	76	76.6	74.4	65	57	71.25
3: A.M.	70	70	70.6	75	71.2	68	61	67.2	76	66	69.50
4: A.M.	72.5	68	64	58	59	59.5	56	56	56	56	60.50
5: A.M.	58	58	57.5	59.5	59.8	59	60	61	60	61	59.38
6: A.M.		64	64	61.5	63		64.5	65	61.5	56	62.44
7: A.M.	57	64.6	63	65	70	67	69	70	75	80	68.06
8: A.M.	74	72	74	64	61	64	79	56	58	62	66.40
9: A.M.	62	62	60	60	60	58	58	58	57	57	59.20
10: A.M.	56	56	56	55.5	55.5	54.5	57.5	60	54	55	56.00
11: A.M.	53	54	54	52	52	52	52	59	64	62	55.40
12: NOON	60	67.5	66	66	70	65	67	67	57	56	64.15
1: P.M.	55.5	55	55	55	55	54	54	54	54	54	54.55
2: P.M.	54	54	54	54			53.5	53.2	53.2	53.2	53.64
3: P.M.	53.2	53.2	53	53	53	53	53	53	54	54	53.24
4: P.M.	54	54	54	54	54	54	54	54.1	54	53	53.91
5: P.M.	53	52	52	56	72	84	88	84	71	66	67.80
6: P.M.	76	78	71	76	72	64	62.5	78	77.8	81.4	73.67
7: P.M.	78	73	59.5	74	62	92.5	68	65.5	62	64	69.85
8: P.M.	61	80	66	54	52	66	76	71.5	72.4	86	68.49
9: P.M.	87	64	38.5	60	75.2	29	28.4	44.5	31	14	47.16
10: P.M.	17	10	8	17		39.5	21	18	16	16	18.06
11: P.M.	16	16.2	16	15	14	14	13	12	11	11	13.82

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 14, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	11	10	10	10	9.5	10	8	0	0		7.61
1: A.M.	Unit	Off	Line								
2: A.M.	No	Fire	in	Boiler							
3: A.M.	Chart	Recorder									
4: A.M.	Turned	Off									
5: A.M.											
6: A.M.											
7: A.M.	Unit	Off	Line								
8: A.M.	No	Fire	in	Boiler							
9: A.M.	Chart	Recorder									
10: A.M.	Turned	Off									
11: A.M.											
12: NOON											
1: P.M.	Unit	Off	Line								
2: P.M.	No	Fire	in	Boiler							
3: P.M.	Chart	Recorder									
4: P.M.	Turned	Off									
5: P.M.											
6: P.M.											
7: P.M.	Unit	Off	Line								
8: P.M.	No	Fire	in	Boiler							
9: P.M.	Chart	Recorder									
10: P.M.	Turned	Off									
11: P.M.											

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 15, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.											
1: A.M.	Unit	Off	Line								
2: A.M.	No	Fire	in	Boiler							
3: A.M.	Chart	Recorder									
4: A.M.	Turned	Off									
5: A.M.											
6: A.M.											
7: A.M.	Unit	Off	Line								
8: A.M.	No	Fire	in	Boiler							
9: A.M.	Chart	Recorder									
10: A.M.	Turned	Off									
11: A.M.											
12: NOON											
1: P.M.	Unit	Off	Line								
2: P.M.	No	Fire	in	Boiler							
3: P.M.	Chart	Recorder									
4: P.M.	Turned	Off									
5: P.M.											
6: P.M.											
7: P.M.											
8: P.M.											
9: P.M.				1	1	1	1	1	1	1	1.00
10: P.M.	1	1	1	1		1	1	1	1	1	1.00
11: P.M.	1	1	1	1	1	1	1	1	1	1	1.00

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 16, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	1	1	1	1	1	1	1.2	1.2	1.5	1.5	1.14
1: A.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
2: A.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
3: A.M.	1.5	1.5	1.5	0.5	0.5		0.2	0.4	0.4	1	0.83
4: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
5: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
6: A.M.	1	1	1	1		1	1	1	1	1	1.00
7: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
8: A.M.	1	1	1	1	1	1.2	2	2	1.6	1.6	1.34
9: A.M.	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.60
10: A.M.	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.60
11: A.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
12: NOON	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
1: P.M.	1.5	1.5	1.5	1.5	1.7	2	2.8	2	2	2	1.85
2: P.M.	2	2	2	2		1.5	1.5	1.5	1.5	1.5	1.72
3: P.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
4: P.M.	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.80
5: P.M.	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.80
6: P.M.	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.80
7: P.M.	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.70
8: P.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
9: P.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
10: P.M.	1.5	1.5	1.5	1.5		1.5	1.5	1.5	1.5	1.5	1.50
11: P.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 17, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	HOUR AVERAGE
12: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
1: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
2: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
3: A.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40
4: A.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40
5: A.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40
6: A.M.	1.4	1.4	1.4	1.4		1.4	1.4	1.4	1.4	1.4	1.40
7: A.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40
8: A.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40
9: A.M.	1.4	1.4	1.4	1.4	1.4	1.2	1.2	1.2	1.2	1.2	1.30
10: A.M.	1.2	1.2	1.2	1.3	1.4	1.4	1.6	1.7	1.8	1.9	1.47
11: A.M.	2	2	2	2	2	2	1.9	1.9	1.8	1.8	1.94
12: NOON	1.8	1.8	1.7	1.7	1.7	1.6	1.6	1.5	1.5	1.5	1.64
1: P.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40
2: P.M.	1.4	1.4	1.4	1.4	1.4		1.4	1.4	1.4	1.4	1.40
3: P.M.	1	1	1	1	1	1	1	1	1	1	1.00
4: P.M.	1	1	1	1	1	1	1.2	1.3	1.4	1.5	1.14
5: P.M.	2	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.82
6: P.M.	1.8	1.8	1.8	2	2	2	2	2	2	2	1.94
7: P.M.	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.80
8: P.M.	1.8	1.8	1.8	1.8	2	2		0.8	1	1	1.56
9: P.M.	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.20
10: P.M.	1.2	1.2	1.2	1.2		1	1	1	1	1	1.09
11: P.M.	1	1	1	1	1	1	1	1	1	1	1.00

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 18, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	HOUR AVERAGE
12: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
1: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
2: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
3: A.M.	1	1	1		1	1	1	1	1	1	1.00
4: A.M.	1	1	1	1	1	1	1.5	1.5	1.5	1.5	1.20
5: A.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
6: A.M.	1.5	1.5	1.5	1.5	1.5		1.5	1.5	1.5	1.5	1.50
7: A.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
8: A.M.	1.5	2	2	2	2	2	2	2.5	2.5	2.5	2.10
9: A.M.	2.5	2	2	2	2	2	2	2	2	2	2.05
10: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
11: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
12: NOON	2	2	2	2	2	2	2	2	2	2	2.00
1: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
2: P.M.	2	2	2	2		2	2	2	2	2	2.00
3: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
4: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
5: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
6: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
7: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
8: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
9: P.M.	2	2	2	2		2	2	2	2	2	2.00
10: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
11: P.M.	1	1	1	1	1	1	1	1	1	1	1.00

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitor Six Minute Averages, March 19, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
1: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
2: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
3: A.M.	1	1	1	1	1	1		1	1	1	1.00
4: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
5: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
6: A.M.	1	1	1	1		1	1	1	1	1	1.00
7: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
8: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
9: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
10: A.M.	1	1	1	1	1	1	1.4	1.5	1.5	1.5	1.19
11: A.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
12: NOON	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
1: P.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
2: P.M.	1.5	1.5	1.5	1.5		1.5	1.5	1.5	1.5	1.5	1.50
3: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
4: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
5: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
6: P.M.	1.8	1.7	1.6	1.5	1.4	1.3	1.2	1.1	1	1	1.36
7: P.M.	1	1	1	1	1	1	1	1	1	1	1.00
8: P.M.	1	1	1	1	1	1	1	1	1	1	1.00
9: P.M.	1	1	1	1	1	1	1	1	1	1	1.00
10: P.M.	1	1	1	1		1	1	1	1	1	1.00
11: P.M.	1	1	1	1	1	1	1	1	1	1	1.00

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 20, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-:18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
1: A.M.		1	1	1	1	1	1	1	1	1	1.00
2: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
3: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
4: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
5: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
6: A.M.	1	1	1	1		1	1	1	1	1	1.00
7: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
8: A.M.	1.5	1.5	1.5	1.5	2	2	2	2	2	2	1.80
9: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
10: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
11: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
12: NOON	2	2	2	2	2	2	2	2	2	2	2.00
1: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
2: P.M.	2	2	2	2		2	2	2	2	2	2.00
3: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
4: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
5: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
6: P.M.	2	1.8	1.6	1.6	1.6	1.4	1.4	1.4	1.4	1.4	1.56
7: P.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40
8: P.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40
9: P.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40
10: P.M.	1.4	1.4	1.4	1.4		1	1	1	1	1	1.18
11: P.M.	1	1	1	1	1	1	1	1	1	1	1.00

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 21, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	HOUR AVERAGE
12: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
1: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
2: A.M.	1	1	1	1	1		1	1	1	1	1.00
3: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
4: A.M.	1	1		1	1	1	1	1	1	1	1.00
5: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
6: A.M.	1	1	1	1		1	1	1	1	1	1.00
7: A.M.	1	1	1	1	1	1	1	1.4	1.4	1.4	1.12
8: A.M.	1.4	1.6	1.8	1.8	2	2	2	2	2	2	1.86
9: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
10: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
11: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
12: NOON	2	2	2	2	2	2	2	2	2	2	2.00
1: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
2: P.M.	2	2	2	2		2	2	2	2	2	2.00
3: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
4: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
5: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
6: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
7: P.M.	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.60
8: P.M.	1.6	1.6	1.6	1.6	1.6	1.6	2	2	2	2	1.76
9: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
10: P.M.	1.8	1.8	1.8	1.8		1.4	1.4	1.4	1.4	1.4	1.58
11: P.M.	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.40

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 22, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
1: A.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
2: A.M.	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.20
3: A.M.	1.5	1.5	1.5	1.5	1.5	1.2	1.2	1.2	1.2	1.2	1.35
4: A.M.	1	1	1	1	1	1.2	1.2	1.2	1.2	1.2	1.10
5: A.M.	1.2	1.2	1.2	1.2	1.2	1.2		1	1	1	1.13
6: A.M.	1	1	1	1		1	1	1	1	1	1.00
7: A.M.	1	1	1	1	1	1	1.2	1.4	1.6	1.8	1.20
8: A.M.	1.8	1.9	2	2	2	2	2	2	2	2	1.97
9: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
10: A.M.	2	2									2.00
11: A.M.			2	2	2	2	2	2	2	2	2.00
12: NOON	2	2	2	2	2	2	2	2	2	2	2.00
1: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
2: P.M.	2	2	2							0	1.50
3: P.M.	0	2	2	2	2	2	2	2	2	2	1.80
4: P.M.	2	2	2	2	2	2	2	2	1.8	1.5	1.93
5: P.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.50
6: P.M.	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.4	1.2	1.45
7: P.M.	1	1	1	1	1	1	1	1	1	1	1.00
8: P.M.	1	1	1	1.8	1.8	1.6	1.4	1.4	1.2	1.2	1.34
9: P.M.	1.2	1.2	1	1	1	1	1	1	1	1	1.04
10: P.M.	1	1	1	1		1	1	1.2	1.2	1.2	1.07
11: P.M.	1.2	1.4	1.6	1.8	1.9	2	2	2	2	2	1.79

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 23, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
1: A.M.	2	2	2	2	1.8	1.8	1.8	1.8	1.8	1.8	1.88
2: A.M.	1.8	1.8	1.8	1.8	1.8	2	2	2	2	2	1.90
3: A.M.	2	2	2		1.5	1.5	1.5	1.5	1.5	1.5	1.67
4: A.M.	1.5	1.5	1.5	1.5	1.5	1.7	1.7	1.7	1.7	1.7	1.60
5: A.M.	2	2	2	2	2	2	2	1.8	1.7	1.7	1.92
6: A.M.	1.5	1.5	0.5	0.5	1	1		0		1	0.88
7: A.M.	1	1	1	1	1	1	1	1	1	1	1.00
8: A.M.	1	1	1	1	1	1.2	1.5	1.8	2	2	1.35
9: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
10: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
11: A.M.	2	2	2	2	2	2	2	2	2	2	2.00
12: NOON	2	2	2	2	2	2	2	2	2	2	2.00
1: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
2: P.M.	2	2	2	2	2	2		1	1.5	1.5	1.78
3: P.M.	1.5	2.2	1.5	1.8	1.8	2	2	2	2	2	1.88
4: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
5: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
6: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
7: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
8: P.M.	2	2	2	2	2	2	2	2	2	2	2.00
9: P.M.	1.8	1.7	1.6	1.5	1.2	1.2	1.2	1.2	1.2	1.2	1.38
10: P.M.	10	98	98	98	98		78	98	98	98	86.00
11: P.M.	98	98	98	98	97	93	89	84	80	69	90.40

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 24, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	60	55	49.5	44	41	38	37	35.5	35	44	43.90
1: A.M.	74	59	67	66.5	49	37	32	29		26	48.83
2: A.M.	26.1	49.5	46	42	40.5	40	35		39	37	39.46
3: A.M.	35	40	53	52.5	52.8	51.5	43	40.5	40.5	39.5	44.83
4: A.M.	36	36	36	35	34	33	32.5	32	31	31	33.65
5: A.M.	32	33.2	35	35.2	36	36.1	36.5	37.5	37	37	35.55
6: A.M.	60.8	45.5	43	40	37		26	34	37	35	39.81
7: A.M.	35.5	38.5	35	26.5	23	22	22.5	22.8	22.8	23	27.16
8: A.M.	23.6	23	22.1	21.9	22.5	24.8	24.2	24.1	24.5	26.5	23.72
9: A.M.	28	29	30	30.8	28	29	35	34	34	36	31.38
10: A.M.	33	28	29	30.2	27	23.4	28	41.2	47.2	46	33.30
11: A.M.	44	42	41.5	40.2	40.2	36	34	33	34	48	39.29
12: NOON	58	62	56.5	52	58	60	63.5	73	65.1	65	61.31
1: P.M.	67.6	70	74	84	92	80	89	73.2	71.2	68.5	76.95
2: P.M.	68.4	66	70	66	71		66	84.5	71.6	68	70.17
3: P.M.	71.2	81.5	72	68	69.8	78.5	79.5	77	67	63	72.75
4: P.M.	76	76	76	64.5	63	63	63	63	65	68.2	67.77
5: P.M.	70.8	68.5	63.5	61	60.8	60.2	62	62	64	65	63.78
6: P.M.	64	71	67	63	61.8	72	70	69	63	67	66.78
7: P.M.	60	60	62	65.9	66.4	65.2	62	61	62.4	65	62.99
8: P.M.	62	64.5	62.4	60.5	59	58.5	58	57.8	57.8	58	59.85
9: P.M.	58	60	59	61.7	64	65.2	66	64	62.4	63.2	62.35
10: P.M.	70	59	58.8		46	57.9	58	70	68.5	66	61.58
11: P.M.	60	60	59.8	59.8	60	60	59.4	59.4	59	59	59.64

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 25, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	62.2	64.5	66	66	65	66		62	60	58.5	63.36
1: A.M.	59.2	67	69.5	73.2	73	68.2	74	73	69.5	66	69.26
2: A.M.	65	59	65	71.2	75	72	66.4	60	60	59	65.26
3: A.M.	59	59	59	60	61	58	58	58	58	57.6	58.76
4: A.M.	57.4	57.2	57	57	57	57.2	57.2	57	57	57	57.10
5: A.M.	57	57	57	57	57	57	57	57	57	57	57.00
6: A.M.	57	57	57		45	56.5	56.5	57	57	57	55.56
7: A.M.	57	57	58	58	62	64	65.2	63.5	79	78	64.17
8: A.M.	64	58	58	65	63.2	70	65.2	63.5	61	60	62.79
9: A.M.	60	63.2	63.5	62	60.7	67.7	70	69	73	64.5	65.36
10: A.M.	77	76.5	64.5	65	84	65	81	71	73	61	71.80
11: A.M.	60.5	60.6	60.4	60	60	60	59.8	59.8	59.8	59	59.99
12: NOON	59	59	59	59	59	58	58	57	56	53	57.70
1: P.M.	52	48.5	49	48	48	49.5	51	49.6	49.5	49.5	49.46
2: P.M.	50	50.8	50		39.5	46.5	46		46	46	46.85
3: P.M.	46	46	46	46	46	45.8	45.8	46	46	46.2	45.98
4: P.M.	45	45.2	44.8	45	46	45	45	45	44.2	44.5	44.97
5: P.M.	44.5	44.5	44.2	44.2	44.2	44.5	44.2	45	44	44	44.33
6: P.M.	44	44	44	44	44	46	46	46	56	76	49.00
7: P.M.	87.5	86	83.5	81	69	74	80	69	86	72	78.80
8: P.M.	65	56	55	56	72	70	68.5	68	68	77	65.55
9: P.M.	63	68.5	79	77	72	84.5	82.5	74	70	48	71.85
10: P.M.	52.5	59	62		46	55.5	63.2	70	60	65	59.24
11: P.M.	60	60	54.5	54.5	54	58.4	59	60	59.6	60	58.00

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 26, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	60	67	61	65	72	71	67	73.5	72	70.5	67.90
1: A.M.	70	66	62	66	63	62.5	62	61	61.5		63.78
2: A.M.	47	68	68.5	68	66	66	65.5	64.5	64	63	64.05
3: A.M.	67	70	69.5	71	73	72	67	72	78	73	71.25
4: A.M.	74.5	67	62	64	60.5	59.5	59	61	65	65.5	63.80
5: A.M.	64.5	63	63.5	63	63	64	64.5	63.5	68	70	64.70
6: A.M.	69	69	69	71		56	66	70	68	64	66.89
7: A.M.	61	60.5	60.5	61	62	62	61	60	59	58.5	60.55
8: A.M.	57	58	60	59	59	59	59	59	59	59	58.80
9: A.M.	59.5	60	59	59	59	59	59	59	59	59	59.15
10: A.M.	59	59	59	60	59	59	59	59	59	59	59.10
11: A.M.	59	59	60	59	59	59	59	59	59	59	59.10
12: NOON	59	59	59	58.8	59.2	59	58.5	58.5	58.5	58.5	58.80
1: P.M.	58.5	58.5	58.5	59	58.5	58.5	58.5	58.5	58.5	59	58.60
2: P.M.	59	59	59	59		47	58	58	58	58.5	57.28
3: P.M.	58.5	59	58.5	58.3	58.5	58	58.5	58.5	58.5	58.5	58.48
4: P.M.	58.5	58.5	58.5	59	58.2	58.2	58	58	59	61	58.69
5: P.M.	59	59	59	58.5	58	58.2	58.2	58.2	58.5	60	58.66
6: P.M.	66.5	68	67	66	67	63	67	68.5	70.5	66	66.95
7: P.M.	61.5	60	60	64	69	61	60.5	69	72	78	65.50
8: P.M.	77.5	68.5	85	84	82	89	91.5	81.5	80	63	80.20
9: P.M.	62	83	78	74	72	62	62.5	63	61.5	62	68.00
10: P.M.	64	63.5	62		49.5	61	59	58	57	59	59.22
11: P.M.	61	61	58	61	63	73	62	60	62	62	62.30

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 27, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-:18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	62	62	62	59	59	61	62	62	62	62	61.30
1: A.M.	62	62.5	63.5	63.5	63	63		60	63.5	63	62.67
2: A.M.	63	63	63.5	64	64	65	65	66	64	64	64.15
3: A.M.	66	72	64	63	70	74	79	76	81	81	72.60
4: A.M.	81	79	84	84	83	70	62	62	62	62	72.90
5: A.M.	62	62.5	63	63	62	62	63	63.5	68	66	63.50
6: A.M.	68.5	68.5	76		51	66	72	79	79	85	71.67
7: A.M.	91	73.5	70.5	81	76	72	67	66	64	64.5	72.55
8: A.M.	64.5	65	64.2	65	64.5	62	62	60.5	60.5	60	62.82
9: A.M.	60	60	60	60	60	60	59.5	58.5	58	58.5	59.45
10: A.M.											
11: A.M.											
12: NOON	62	62	62	62	62	62	62.5	62	62	62	62.05
1: P.M.	61.5	61.5	61.5	62	61	61	60	61	63	62	61.45
2: P.M.	62	61.5	61	61	61	60.5	60.8	61	61	61	61.08
3: P.M.	61	61	62	61	61	61	61	61	61	71	62.10
4: P.M.	80	79.5	70	75.5	64	61	74	71	76.5	69.5	72.10
5: P.M.	76	65	62.5	78	68	86.5	71	65	63	61.5	69.65
6: P.M.	62	72.5	63	61	64.5	69	81	77	76	82	70.80
7: P.M.	86	84.5	81		81.5	69	62.5	64.5	64	64	73.00
8: P.M.	65	65	62	62	62	61	63	64	65	64.5	63.35
9: P.M.	63	62.2	62	62	64	64	60.5	68	66	70	64.17
10: P.M.	68.5	66	72	70	65	78	76	72	73	57	69.75
11: P.M.	55	56	56	55.5	55	54	53	54	54	54.5	54.70

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 28, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	64.5	56	56	53.8	53.5	53	58	57.5		53	56.14
1: A.M.	62	69	67	65	72	72	69.5	76	74.5	73	70.00
2: A.M.	65	54.5	55	56		33	56	55	54.5	56	53.89
3: A.M.	56	57	56		55	54.5	56	59.5	56	56	56.22
4: A.M.	58.5	63	69	65	68	71.5	69	77	74	72	68.70
5: A.M.	73	58	56	58.5	58.5	61	68	84.5	72	63	65.25
6: A.M.	65.5	66	68	68.5	70	76	89	78	72.5	69	72.25
7: A.M.	65	62	62.5	62.5	57	54	60	58	56	56	59.30
8: A.M.	56	56	56	56.5	57	57.5	57.5	58.5	57.5	59.5	57.20
9: A.M.	60	60	60	60	60	60	60	60	59.5	59.4	59.89
10: A.M.	59	58.5	58	58	57.5	57.5	57.5	57.5	57.5	57.5	57.85
11: A.M.	57	57	56.5		56	56	55.5	55	55	55	55.89
12: NOON	56	57	56	56	56	56	55	56	56	56.5	56.05
1: P.M.	57	57	57	57	54.5	54	54	54	54	55	55.35
2: P.M.	53.5	53.5	53.5	52.5	52.5	52	51.5	51.5	59	81	56.05
3: P.M.	79	75	69	56	60	67	74	64	68.5	64	67.65
4: P.M.	64	72	75	77	64	57	55	52	62	63	64.10
5: P.M.	58	52	62	66.5	73	73	77	74	78	98	71.15
6: P.M.	80	94	69	82	88	75	62	62	65	65	74.20
7: P.M.	78.5	73.5	65		66	64	63.5	59.5	56	55	64.56
8: P.M.	54	66	77	61	60	70	81.2	92.5	64	63	68.87
9: P.M.	69.5	70	74	64	82	86	81	80.5	86	74	76.70
10: P.M.	66.5	66	78	84	73.5	70.5	69	70	70.5	69	71.70
11: P.M.	69	70.5	71	74	80	78	79	70	66.5	66	72.40

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 29, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	66		57.5	66	66	66	66	66	65	66	64.94
1: A.M.	66	71	66	65	71	76	83	78.5	81	84	74.15
2: A.M.	84.5	80	83	88.5	91.5	74	85	72	66	66	79.05
3: A.M.	66	67	67.5		69.5	69	70	68.5	68	68	68.17
4: A.M.	67	67.2	67.2	67.2	66	66.5	66.5	68	68	69	67.26
5: A.M.	68	68	67.5	67.5	70	77	79	73	75.5	81	72.65
6: A.M.	89.5	87	82	81.5	81	79	74	84	82	78.5	81.85
7: A.M.	77	65	66	68	74.2	72	69	72	67	67	69.72
8: A.M.	66	67	67	62	63.5	66	63	67.5	64	62.5	64.85
9: A.M.	62.5	62.5	64	63	65	63	68	62	65	70	64.50
10: A.M.	67	66	72.5	75	73	72.5	83.5	83	78	77	74.75
11: A.M.	66.2	70	74		73.5	71	66.2	66	66	66	68.77
12: NOON	66	66	66	66	66	66	66.5	66	66	66	66.05
1: P.M.	65.5	65.5	65.5	65.6	66	65	65	65	66	66	65.51
2: P.M.	68	74	73	73	68	68	69	71.5	76	73	71.35
3: P.M.	74	76.5	78	76	76	81.5	83	80	76	68.5	76.95
4: P.M.	72	70	67	67	66.5	67	66	66	66	66	67.35
5: P.M.	66	66	66	66	66	65	67	65	67.5	70	66.45
6: P.M.	62	63	92	69	89.5	71	72	71	67	68	72.45
7: P.M.	78	77	71		62	61	77	69	81	69	71.67
8: P.M.	76	75	76	85	71	68	82	81	70.2	79	76.32
9: P.M.	71	81	70	68	65	64	66	69	66	68	68.80
10: P.M.	73.5	65.5	64	71.5	75	78.5	78	86	88	82	76.20
11: P.M.	81.5	87	85	86	84	70	64		64	66	76.39

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 30, 1991.

SIX MINUTE PERIOD	:00-:06	:06-:12	:12-18	:18-:24	:24-:30	:30-:36	:36-:42	:42-:48	:48-:54	:54-:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	65	68	68	68	64.5	64.5	64	64	64	63	65.30
1: A.M.	65.5	64	66	65	65	64	63	63	68	67	65.05
2: A.M.	70	66	63	65	72	78	68	72	79	82.5	71.55
3: A.M.	79	78	82		83	82	71	64	66.5	65	74.50
4: A.M.	65	64.6	66	66	66	66	65	66	66	66	65.66
5: A.M.	65	64	64	64.5	65	69.5	71	71	68	66	66.80
6: A.M.	65	65.5	68.5	68.5	70	66	65	69	73	77	68.75
7: A.M.	74	78	81	79	79	82	83	83	82.5	72	79.35
8: A.M.	68	66.5	65.5	66	66	66	66	66.5	66	66	66.25
9: A.M.	66	67	65	64.5	65.5	65	66.5	66	66	65	65.65
10: A.M.	66	69	72	74	88	84	77	69.5	69.5	66.5	73.55
11: A.M.	66.5	67	67		69.5	69	82	69	71	72	70.33
12: NOON	71	70	70.5	81	84.5	74.5	66.5	63.5	64	63.5	70.90
1: P.M.	64	64	64	64	64	64	64	64	64	64	64.00
2: P.M.	64	63	64	63	63	63	63	63	63	63	63.20
3: P.M.	63	63	63	63	63	62.5	62	62	62	62	62.55
4: P.M.	62	70	71	82.5	69	80	69	74	71	87	73.55
5: P.M.	78	70	63	60	58.5	99.5	100	100	100	100	82.90
6: P.M.	92	100	100	100	100	100		87	92	82	94.78
7: P.M.	72	83	81.5		81	91	93	93	100	90	87.17
8: P.M.	80	70	69	74	87	86	79	80	80	76	78.10
9: P.M.	70	70.5	75	75	84	89	86	80.5	72	72	77.40
10: P.M.	73	76	72.5	72	77	80	83	87	78	73	77.15
11: P.M.	73	74	73.5	73.5	73	69.5	68	68	66.5	66	70.50

Blackened squares indicate invalid or no data obtained for that time period.

Opacity Monitors Six Minute Averages, March 31, 1991.

SIX MINUTE PERIOD	:00--:06	:06--:12	:12--:18	:18--:24	:24--:30	:30--:36	:36--:42	:42--:48	:48--:54	:54--:60	
HOUR OF DAY											HOUR AVERAGE
12: A.M.	66	66	66	70		73	79	79.5	90	92	75.72
1: A.M.	91	97	82	71	70	79	80.2	74	79.8	74	79.80
2: A.M.	72	66	66	66	70	76	76	70	67	66	69.50
3: A.M.	65	64	64		63	63	65	65	68	64	64.56
4: A.M.	63	65.5	70.2	80.5	79.5	83	82	83	81	82	76.97
5: A.M.	82.5	82.5	82	76	74	82	82	78.5	71	77	78.75
6: A.M.	77	74	74	80.5	79	78	81	75	81	78.5	77.80
7: A.M.	85	80	80	82	78	77.5	79	86	88	87	82.25
8: A.M.	79	69	69	69	69	69	69.5	69	69	69	70.05
9: A.M.	72	75	78	76	74	71	73	77	73	75	74.40
10: A.M.	73	72.5	70	70	70	69	69	70	72.5	80	71.60
11: A.M.	72	76	76		81	79	78	73	66	66	74.11
12: NOON	68	69	74	72	71	72	70	68	67.5	67	69.85
1: P.M.	68	72.4	76	76	74.5	67.5	66	65.5	66.5	65.5	69.79
2: P.M.	66	65	66.5	68.5	72.5	73	70.5	68	64.5	65	67.95
3: P.M.	65	67	69.5	75	69	74	69	68	65	68	68.95
4: P.M.	68	70	74	66.5	66.5	74	77.5	77	66	66	70.55
5: P.M.	72.5	70	80.5	82	77	79.5	88	86	87	89	81.15
6: P.M.	78	72.5	72.5	78	75	76	75.5	73.5	71	70	74.20
7: P.M.	70	69	68		67.5	68.5	68	69	70	73	69.22
8: P.M.	76	76	74	71	69	68	68	68	70	72	71.20
9: P.M.	68	68	71.5	73.5	77	74	77	77.5	78	79	74.35
10: P.M.	81	80.5	81.5	81	72	69	69	70	72	75	75.10
11: P.M.	82	75.5	78	76		71.6	71.5	71.5	72.5	76	74.96

Blackened squares indicate invalid or no data obtained for that time period.