From: Cascio, Tom
To: Scearce, Lynn
Subject: Administrative Correction for Cape Canaveral Energy Center RICE Engine
Date: Monday, November 17, 2014 12:51:30 PM
Attachments: Pages from 0990042-008-AV Final Permit_signed.doc
Caterpillar.pdf

Hi Lynn – we need to set up an admin correction for the Cape Canaveral Energy Center (0090006) similar to Riviera Beach. Note highlight below. Title is "Model number change for emergency generator at the Cape Canaveral Energy Center".

Tom

From: Cascio, Tom
Sent: Friday, November 14, 2014 8:19 AM
To: Scearce, Lynn
Subject: Administrative Correction for Riviera Beach Energy Center RICE Engine

Hi Lynn – the admin correction is for facility 0990042 – I'm guessing the project number will be 0990042-009-AV. The project title is "Model number change for emergency generator at the Riviera Beach Energy Center".

Tom

From: Zuczek, Jeffrey [mailto:Jeffrey.Zuczek@fpl.com]
Sent: Monday, November 10, 2014 8:42 AM
To: Cascio, Tom
Cc: Rosario, Wilfredo; Hampp, John; Zuczek, Jeffrey
Subject: RE: Administrative Correction for Riviera Beach Energy Center and Cape Canaveral Energy Center RICE

Tom – Attached is a "track changes" word version that indicates the specs for the final emergency diesel to be installed at Riviera for EU013.

Please note the following:

- There will only be "one" generator to be installed for EU013 at RBEC rather than two (2) that were initially permitted.
- The same need for an administrative change also applies at our Cape Canaveral Energy Center (CCEC) for EU 015. In parallel, Cape will only have one (1) generator within EU015 instead of the initially permitted quantity of two. The engine model for RBEC and CCEC will be the same as attached (Caterpillar C175).

All of the same permit conditions will still apply.

Please let me know if you have any questions,

Jeff

Jeffrey Zuczek, M.S, B.S
Air Media Specialist | Juno Environmental Services (JES)
Florida Power & Light Company
O: 561-691-2635 | Cell: 561-568-9079

From: Cascio, Tom [mailto:Tom.Cascio@dep.state.fl.us]
Sent: Friday, November 07, 2014 3:46 PM
To: Zuczek, Jeffrey
Subject: RE: Administrative Correction for Riviera Beach Energy Center and Cape Canaveral Energy Center RICE

This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email.

Thanks, Jeff. I expect the final permit will be issued shortly. When you receive your copy, just send me an email noting the administrative changes needed to the generator description and we will initiate an administrative correction. No public notice will be required. It is a one page document.

Tom

From: Zuczek, Jeffrey [mailto:Jeffrey.Zuczek@fpl.com]
Sent: Friday, November 07, 2014 3:29 PM
To: Cascio, Tom
Cc: Hampp, John; Rosario, Wilfredo; Zuczek, Jeffrey
Subject: Administrative Correction for Riviera Beach Energy Center and Cape Canaveral Energy Center RICE

Tom – Per our phone conversation today, the final generator to be installed at Riviera is a slightly different model than the specifications identified in the AC and soon-to-be final Title V permit. The generator is still EPA Tier II certified as required. There is simply an administrative correction needed.

Please note that each facility will now only have one (1) of these generators on-site. Therefore, EU015 at Cape, and EU013 at Riviera, will now only comprise one (1) of these generators, instead of two that are permitted for use, thereby decreasing potential emissions by half.

The Caterpillar specification sheet is attached to this email.

Please let me know, at your convenience, what are next steps should be…

Thank you,

Jeff

Jeffrey Zuczek, M.S, B.S
Air Media Specialist | Juno Environmental Services (JES)
Florida Power & Light Company
O: 561-691-2635 | Cell: 561-568-9079