



# **Indian River Plant**



**Title V Operating Permit Application  
June 15, 1996**

Control No. 1

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
DIVISION OF AIR RESOURCES MANAGEMENT  
APPLICATION FOR AIR PERMIT - LONG FORM



I. APPLICATION INFORMATION

Identification of Facility Addressed in This Application

Indian River Plant  
Orlando Utilities Commission  
US 1 & Kings HWY  
Titusville, Florida 32780

**RECEIVED**  
JUN 17 1996  
BUREAU OF  
AIR REGULATION

**Owner/Authorized Representative or Responsible Official**

1. Name and Title of Owner/Authorized Representative or Responsible Official :  Name : Gregory A. DeMuth Title : Director, Environmental Division
2. Owner or Authorized Representative or Responsible Official Mailing Address :  Organization/Firm : Orlando Utilities Commission Street Address : 500 Orange Ave. City : Orlando State : FL                      Zip Code : 32801-
3. Owner/Authorized Representative or Responsible Official Telephone Numbers :  Telephone : (407)423-9141                      Fax : (407)236-9616
4. Owner/Authorized Representative or Responsible Official Statement :  <i>I, the undersigned, am the owner or authorized representative* of the facility (non-Title V source) addressed in this Application for Air Permit or the responsible official, as defined in Chapter 62-213, F.A.C., of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. Further, I agree to operate and maintain the air pollutant emissions units and air pollution control equipment described in this application so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. If the purpose of this application is to obtain an air operation permit or operation permit revision for one or more emissions units which have undergone construction or modification, I certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding applicatio for air construction permit and with all provisions contained in such permit. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i>   Signature _____   Date _____

\* Attach letter of authorization if not currently on file.

**Scope of Application**

<b>Emissions Unit ID</b>	<b>Description of Emissions Unit</b>
001	Boiler 1
002	Boiler 2
003	Boiler 3
004	Combustion Turbine A
005	Combustion Turbine B
006	Combustion Turbine C
007	Combustion Turbine D

**Scope of Application**

<b>Emissions Unit ID</b>	<b>Description of Emissions Unit</b>
08	Lime Storage Silo
No Id	Non-regulated Emissions - Exempt and Insignificant
No Id	Non-regulated Emissions - Significant

**Purpose of Application and Category**

**Category I : All Air Operation Permit Applications Subject to Processing Under Chapter 62-213, F.A.C.**

This Application for Air Permit is submitted to obtain :

Initial air operation permit under Chapter 62-213, F.A.C., for an existing facility which is classified as a Title V source.

Initial air operation permit under Chapter 62-213, F.A.C., for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number :

Air operation permit renewal under Chapter 62-213, F.A.C., for a Title V source.

Operation permit to be renewed :

Air operation permit revision for a Title V source to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number :

Operation permit to be revised :

Air operation permit revision or administrative correction for a Title V source to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application.

Operation permit to be revised/corrected :

Air operation permit revision for a Title V source for reasons other than construction or modification of an emissions unit.

Operation permit to be revised :

Reason for revision :

**Category II : All Air Operation Permit Applications Subject to Processing Under Rule 62-210.300(2)(b), F.A.C.**

This Application for Air Permit is submitted to obtain :

- Initial air operation permit under Rule 62-210.300(2)(b), F.A.C., for an existing facility seeking classification as a synthetic non-Title V source.

Current operation/construction permit number(s) :

- Renewal air operation permit under Rule 62-210.300(2)(b), F.A.C., for a synthetic non-Title V source.

Operation permit to be renewed :

- Air operation permit revision for a synthetic non-Title V source.

Operation permit to be revised :

Reason for revision :

**Category III : All Air Construction Permit Applications for All Facilities and Emissions Units**

This Application for Air Permit is submitted to obtain :

- Air construction permit to construct or modify one or more emissions units within a facility (including any facility classified as a Title V source).

Current operation permit number(s), if any :

- ] Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.

Current operation permit number(s) :

- ] Air construction permit for one or more existing, but unpermitted, emissions units.




**Application Processing Fee**

Attached - Amount : \_\_\_\_\_ NA

**Construction/Modification Information**

1. Description of Proposed Project or Alterations :
2. Projected or Actual Date of Commencement of Construction :
3. Projected Date of Completion of Construction :

**Professional Engineer Certification**

1. Professional Engineer Name : G. Preston Lewis, P.E.  Registration Number : 41755
2. Professional Engineer Mailing Address :  Organization/Firm : ENSR Street Address : P.O. Box 13206 City : Tallahassee State : FL Zip Code : 32317-3206
3. Professional Engineer Telephone Numbers :  Telephone : (904)385-0808 Fax : (904)385-5457
4. Professional Engineer Statement :  <i>I, the undersigned, hereby certified, except as particularly noted herein*, that :</i> <i>(1) To the best of my knowledge, there is reasonable assurance (a) that the air pollutant emissions unit(s) and the air pollutant control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions in the Florida Statutes and rules of the Department of Environmental Protection; or (b) for any application for a TitleV source air operation permit, that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in the application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application;</i> <i>(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application; and</i> <i>(3) For any application for an air construction permit for one or more proposed new or modified emissions units, the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.</i>   Signature  6/11/96 Date

\* Attach any exception to certification statement.

**Application Contact**

**1. Name and Title of Application Contact :**

**Name : Robert F. Hicks  
Title : Senior Environmental Engineer**

**2. Application Contact Mailing Address :**

**Organization/Firm : Orlando Utilities Commission  
Street Address : 500 South Orange Avenue  
City : Orlando  
State : FL                      Zip Code : 32802-3193**

**3. Application Contact Telephone Numbers :**

**Telephone : (407)423-9100                      Fax : (407)236-9616**

**Application Comment**

**Alternate Contacts for the Application:**

**Preston Lewis, P.E.      (904) 385-0808  
Barry Andrews, P.E.    (205) 767-1210**


## INDIAN RIVER PLANT FACILITY

ITEM ID	DESCRIPTION	WHERE REFERENCED
Figure 1	Area Map	Facility Supplemental
Figure 2	Facility Plot Plan	Facility Supplemental
Figure 3	Unit 1 Flow Diagram	Facility/E.U. Sup.
Figure 4	Unit 2 Flow Diagram	Facility/E.U. Sup.
Figure 5	Unit 3 Flow Diagram	Facility/E.U. Sup.
Figure 6	Combustion Turbine A	Facility/E.U. Sup.
Figure 7	Combustion Turbine B	Facility/E.U. Sup.
Figure 8	Combustion Turbine C	Facility/E.U. Sup.
Figure 9	Combustion Turbine D	Facility/E.U. Sup.
Figure 10	Lime Storage Silo	Facility/E.U. Sup.
Appendix A	Fugitive Emissions Ident.	Facility Supplemental
Appendix B	Insignificant Activities	Facility Supplemental
Appendix C	Alternative Methods	Facility Supplemental
Appendix D	Compliance Plan & Report	Facility Supplemental
Appendix E	Compliance Statement	Facility Supplemental
Appendix F	Fuel Analysis	E.U. Supplemental
Appendix G	Compliance Report(s)	E.U. Supplemental
Appendix H	O&M Plan/ Startup/Shutdown	E.U. Supplemental
Appendix I	Acid Rain Application(s)	E.U. Supplemental
Appendix J	Control Equipment (s)	E.U. Supplemental
Appendix K	Additional Rules	Facility/E.U. Sup.
Appendix L	ENSR MathCad/Emissions Inventory/Calcs.	Facility/E.U. Sup.
Appendix M	Title VI Information	Facility/E.U. Sup.


**FIGURE 1**

**AREA MAP**





Mapped by the U. S. Coast & Geodetic Survey  
Edited and Published by the Geological Survey  
Control by USGS, NOS/NOAA and USCE  
Culture and drainage in part compiled from  
aerial photographs taken 1949  
Topography by planetable surveys 1948. Field checked 1949  
Hydrography from charts surveyed 1876 to 1941  
Projection and 10,000-foot grid ticks: Florida coordinate  
system, east zone (transverse Mercator)  
1000-meter Universal Transverse Mercator grid ticks, zone 17, shown in blue  
1927 North American Datum (NAD 27)  
North American Datum of 1983 (NAD 83) is shown by dashed corner ticks  
The values of the shift between NAD 27 and NAD 83 for 7.5-minute  
intersections are given in USGS Bulletin 1875  
Dashed land lines indicate approximate locations  
Land lines within Delespine Grant omitted due to  
insufficient information  
Photospectored from 1989 source; no major culture or drainage  
changes observed. Boundaries revised and names verified 1992




CONTOUR INTERVAL 5 FEET  
NATIONAL GEODETIC VERTICAL DATUM OF 1929  
DEPTH CURVES AND SOUNDINGS IN FEET—DATUM IS MEAN LOW WATER  
THE RELATIONSHIP BETWEEN THE TWO DATUMS IS VARIABLE  
SHORELINE SHOWN REPRESENTS THE APPROXIMATE LINE OF MEAN HIGH WATER  
NO APPRECIABLE PERIODIC TIDES IN THIS AREA  
THIS MAP COMPLIES WITH NATIONAL MAP ACCURACY STANDARDS  
FOR SALE BY U. S. GEOLOGICAL SURVEY  
DENVER, COLORADO 80225, OR RESTON, VIRGINIA 22092  
A FOLDER DESCRIBING TOPOGRAPHIC MAPS AND SYMBOLS IS AVAILABLE ON REQUEST



QUADRANGLE LOCATION

1	2	3
4	5	6
7	8	

1 Titusville SW  
2 Titusville  
3 Orsino  
4 Lake Poinsett NW  
5 Courtenay  
6 Lake Poinsett SW  
7 Lake Poinsett  
8 Cocoa




ADJOINING 7.5' QUADRANGLE NAMES  
Revisions shown in purple compiled from aerial photographs  
taken 1984 and other sources. This information not  
field checked. Map edited 1988  
Purple tint indicates extension of urban areas

SHARPES, FLA.  
28080-D7-TF-024  
1949  
PHOTOREVISED 1988  
MINOR REVISION 1992



**FIGURE 2**  
**FACILITY PLOT PLAN**

1108585000 ACAD 10 01.00  
 07/27/93 08:11:24  
 0090008-001



**LEGEND**

- NEW ASPHALTIC SURFACING
- EXISTING ASPHALTIC SURFACING
- NEW CONCRETE SURFACING
- EXISTING CONCRETE SURFACING
- COQUINA OR LOCAL SHELL BASE SURFACE
- NEW CRUSHED ROCK SURFACING
- EXISTING CRUSHED ROCK SURFACING
- EXISTING FABRIC FORM
- NEW FENCING
- EXISTING FENCING
- NEW CONTOURS
- EXISTING CONTOURS
- NEW SPOT ELEVATIONS
- EXISTING HORIZONTAL & VERTICAL CONTROL MONUMENT

HVCM	PLANT COORDINATE		ELEVATION
	N-S	E-W	
1	S 5+14.50	E 3+10.00	23.390
2	N 1+40.50	E 3+10.00	24.741
3	N 1+40.50	W 3+40.00	25.613

- NOTES**
1. ALL WORK INDICATED ON DRAWINGS S3001 AND S3002 SHALL BE CONSTRUCTED BY CONTRACT 71.0402 UNLESS NOTED OTHERWISE.
  2. THE CONTRACTOR SHALL TAKE PRECAUTIONS TO AVOID DAMAGING THE EXISTING TEST WELLS DURING THE COURSE OF HIS WORK.
  3. PLANT DATUM IS BASED ON ELEVATION 100 BEING MEAN SEA LEVEL AND EQUAL TO UNITED STATES COAST AND GEODETIC SURVEY DATUM 00.00.
  4. ELEVATIONS INDICATED ON EXISTING CONTROL MONUMENTS ARE USGS ELEVATIONS.
  5. THE CURB CONTAINING THE CRUSHED ROCK SHALL FOLLOW THE EDGE OF PAVEMENT AS INDICATED.


NOTE: CONTRACTOR SHALL CLEAN OUT EXISTING CULVERTS  
 EXST CULVERT



**FIGURE 3**  
**UNIT 1 PROCESS**  
**FLOW DIAGRAM**

## SCHEMATIC of CONTINUOUS MONITORING SYSTEM


INDIAN RIVER PLANT  
 ORIS Code: 683  
 NADB Boiler ID: 1 & 2



### MONITOR LOCATION INFORMATION

A.	STACK HEIGHT ABOVE GRADE (FT)	297.5	E.	LOCATION OF SAMPLE PROBE. GASEOUS EXTRACTION PROBE IS IN SAME PLANE AS TEST PROBE. OPACITY PROBE IS 1 FT BELOW SAMPLE PROBE ELEVATION.	
B.	STACK DIAMETER AT TEST PORT (FT)	14.9	F.	OPACITY MONITOR CROSS SECTIONAL AREA (SQ FT)	175
C.	INSIDE CROSS-SECTIONAL AREA AT TEST PORT (SQ FT)	174	G.	INSIDE CROSS SECTIONAL AREA AT FLUE EXIT (SQ FT)	155
D.	TEST PORT ELEVATION				
	1 ABOVE GRADE (FT)	190.7			
	2 ABOVE LAST DISTURBANCE				
	A. FEET	40.0			
	B. STACK DIAMETERS	2.7			
	3 PRIOR TO NEXT DISTURBANCE				
	A. FEET	106.8			
	B. STACK DIAMETERS	7.2			

UNIT 1



**C-E REHEAT STEAM GENERATOR**

CAPACITY - 635,000 LB PER HR AT 1850 PSI AND 1005 F TEMP. - REHEAT 1005 F

Designed and Manufactured by COMBUSTION ENGINEERING, INC.


**INDIAN RIVER PLANT - UNIT No. 1**

Orlando Utilities Commission, Orlando, Florida

**FIGURE 4**  
**UNIT 2 PROCESS**  
**FLOW DIAGRAM**

## SCHEMATIC of CONTINUOUS MONITORING SYSTEM


INDIAN RIVER PLANT  
 ORIS Code: 683  
 NADB Boiler ID: 1 & 2




### MONITOR LOCATION INFORMATION

A.	STACK HEIGHT ABOVE GRADE (FT)	297.5	E.	LOCATION OF SAMPLE PROBE. GASEOUS EXTRACTION PROBE IS IN SAME PLANE AS TEST PROBE. OPACITY PROBE IS 1 FT BELOW SAMPLE PROBE ELEVATION.	
B.	STACK DIAMETER AT TEST PORT (FT)	14.9	F.	OPACITY MONITOR CROSS SECTIONAL AREA (SQ FT)	175
C.	INSIDE CROSS-SECTIONAL AREA AT TEST PORT	174	G.	INSIDE CROSS SECTIONAL AREA AT FLUE EXIT (SQ FT)	155
D.	TEST PORT ELEVATION				
	1 ABOVE GRADE (FT)	190.7			
	2 ABOVE LAST DISTURBANCE				
	A. FEET	40.0			
	B. STACK DIAMETERS	2.7			
	3 PRIOR TO NEXT DISTURBANCE				
	A. FEET	106.8			
	B. STACK DIAMETERS	7.2			

UNIT 2



SEE  
DETAIL  
"A"



tubes each corner  
headers  
corner tubes  
at headers

at headers

at headers

2" O.D. at "B"

m Drum


at "D"

EMENT  
M RCUITS

missio  
it #2  
061

**FIGURE 5**  
**UNIT 3 PROCESS**  
**FLOW DIAGRAM**

**SCHEMATIC of CONTINUOUS MONITORING SYSTEM**



**MONITOR LOCATION INFORMATION**

A. STACK HEIGHT ABOVE GRADE (FT)	297.5
B. STACK DIAMETER AT TEST PORT (FT)	16.5
C. INSIDE CROSS-SECTIONAL AREA AT TEST PORT (SQ FT)	215
D. TEST PORT ELEVATION	
1 ABOVE GRADE (FT)	160
2 ABOVE LAST DISTURBANCE	
A. FEET	36
B. STACK DIAMETERS	2.2
3 PRIOR TO NEXT DISTURBANCE	
A. FEET	137.5
B. STACK DIAMETERS	8.3

E. LOCATION OF SAMPLE PROBE. GASEOUS EXTRACTION PROBE IS IN SAME PLANE AS TEST PROBE. OPACITY PROBE IS 22 FT BELOW SAMPLE PROBE ELEVATION.	
F. OPACITY MONITOR CROSS SECTIONAL AREA (SQ FT)	225
G. INSIDE CROSS SECTIONAL AREA AT FLUF EXIT (SQ FT)	155






The information on this sheet is  
**STRICTLY CONFIDENTIAL**

It is for the use of employees of COMBUSTION ENGINEERING, INC., only  
and is not to be divulged to anyone outside of the organization.

UNIT 3




LAST COLUMN  
Added

2 blocks  
8' x 12' x 12'

**FIGURE 6**  
**COMBUSTION TURBINE A**  
**PROCESS FLOW DIAGRAM**

# SCHEMATIC of CONTINUOUS MONITORING SYSTEM

INDIAN RIVER PLANT  
 ORIS Code: 683  
 NADB Boiler ID: A




**MONITOR LOCATION INFORMATION**

A.	STACK HEIGHT ABOVE GRADE (FT)	36	G.	INSIDE CROSS SECTIONAL AREA AT FLUE EXIT (SQ FT)	120
B.	STACK DIMENSIONS (FT)	10' X 12'			
C.	INSIDE CROSS-SECTIONAL AREA AT TEST PORT (SQ FT)	120			
D.	TEST PORT ELEVATION				
	1 ABOVE GRADE (FT)	18.5			
	2 ABOVE LAST DISTURBANCE				
	A. FEET				
	B. STACK DIAMETERS	<.25			
	3 PRIOR TO NEXT DISTURBANCE				
	A. FEET				
	B. STACK DIAMETERS	<.25			

**FIGURE 7**  
**COMBUSTION TURBINE B**  
**PROCESS FLOW DIAGRAM**

## SCHEMATIC of CONTINUOUS MONITORING SYSTEM

INDIAN RIVER PLANT  
 ORIS Code: 683  
 NADB Boiler ID: B




### MONITOR LOCATION INFORMATION

A.	STACK HEIGHT ABOVE GRADE (FT)	36	G.	INSIDE CROSS SECTIONAL AREA AT FLUE EXIT (SQ FT)	120
B.	STACK DIMENSIONS (FT)	10' X 12'			
C.	INSIDE CROSS-SECTIONAL AREA AT TEST PORT (SQ FT)	120			
D.	TEST PORT ELEVATION				
	1 ABOVE GRADE (FT)	18.5			
	2 ABOVE LAST DISTURBANCE				
	A. FEET				
	B. STACK DIAMETERS	<.25			
	3 PRIOR TO NEXT DISTURBANCE				
	A. FEET				
	B. STACK DIAMETERS	<.25			

**FIGURE 8**  
**COMBUSTION TURBINE C**  
**PROCESS FLOW DIAGRAM**

## SCHEMATIC of CONTINUOUS MONITORING SYSTEM

INDIAN RIVER PLANT  
 ORIS Code: 683  
 NADB Boiler ID: C



### MONITOR LOCATION INFORMATION


A.	STACK HEIGHT ABOVE GRADE (FT)	51	G.	INSIDE CROSS SECTIONAL AREA AT FLUE EXIT (SQ FT)	382.6
B.	STACK DIMENSIONS (FT)	34.3 x 11.2			
C.	INSIDE CROSS-SECTIONAL AREA AT TEST PORT (SQ FT)	382.6			
D.	TEST PORT ELEVATION				
	1 ABOVE GRADE (FT)	41			
	2 ABOVE LAST DISTURBANCE				
	A. FEET				
	B. STACK DIAMETERS	<.25			
	3 PRIOR TO NEXT DISTURBANCE				
	A. FEET				
	B. STACK DIAMETERS	<.25			

**FIGURE 9**  
**COMBUSTION TURBINE D**  
**PROCESS FLOW DIAGRAM**



## SCHEMATIC of CONTINUOUS MONITORING SYSTEM

INDIAN RIVER PLANT  
 ORIS Code: 683  
 NADB Boiler ID: D



### MONITOR LOCATION INFORMATION

A.	STACK HEIGHT ABOVE GRADE (FT)	51	G.	INSIDE CROSS SECTIONAL AREA AT FLUE EXIT (SQ FT)	382.6
B.	STACK DIMENSIONS (FT)	34.3 x 11.2			
C.	INSIDE CROSS-SECTIONAL AREA AT TEST PORT (SQ FT)	382.6			
D.	TEST PORT ELEVATION				
	1 ABOVE GRADE (FT)	41			
	2 ABOVE LAST DISTURBANCE				
	A. FEET				
	B. STACK DIAMETERS	<.25			
	3 PRIOR TO NEXT DISTURBANCE				
	A. FEET				
	B. STACK DIAMETERS	<.25			

**FIGURE 10**  
**LIME STORAGE SILO**  
**PROCESS FLOW DIAGRAM**




Figure 1 - Super Jet Filter Assembly

**APPENDIX A**  
**FUGITIVE EMISSIONS**  
**IDENTIFICATION**

Indian River Potential Emission Source Inventory

Source ID	E.U. ID	Plant Area/ Dept.	Description	S=Significant I=Insignificant P=Presumed Exempt E=Exempt	Reference	Comment
				S=Significant I=Insignificant P=Presumed Exempt E=Exempt		
				S=Significant I=Insignificant P=Presumed Exempt E=Exempt		
		YD	Fuel Oil Tanks 1, 2 and 3	I	Dwg 17135-9STU-S1001	No. 6 Fuel. Oil. Tanks 2 less than 350 lb/yr, based on all oil through largest
		YD	Light Oil Tanks 1 and 2 and Fuel Pump	I	Dwg 17135-9STU-S1001	No. 2 Diesel. Tanks 2 less than 800 lb/yr, based on all diesel through largest (CT) tank.
		WT	Water Treatment Processes	P	Dwg 17135-9STU-S1001	Item 27 in DEP letter. Note, however, that if CI emissions are greater than 10 tons per year, exemption may not apply.
	1	PB	Unit 1 boiler	S	Dwg 17135-9STU-S1001	Shares stack with Unit 2; Natural Gas, No. 6 F.O.; No. 2 F. O.; Tangential Fired
	2	PB	Unit 2 boiler	S	Annual Operating Report RY 1994	Shares stack with Unit 1 Natural Gas, No. 6 F.O.; No. 2 F. O.; Tangential Fired
	3	PB	Unit 3 boiler	S	Dwg 17135-9STU-S1001	Natural Gas, No. 6 Oil; Tangential Fired; single stack.
		YD	Percolation Ponds	P	Dwg 17135-9STU-S1001	
		YD	Valve Stations	P	Dwg 17135-9STU-S1001	Low Vapor Pressure; Methane not a criteria pollutant or VOC.
		YD	Xformers	P	Dwg 17135-9STU-S1001	Sealed
	8	WT	Lime Storage Silo	S	Permit AO05-229996	At Water TXT Bldg, 99% eff., 28.29.32N/80.46.59W; 17-521.5 kmE, 3151.6 kmN; baghouse General Resource Corp., model 13204.8; Loading 2 hr/day; loading rate 10 t/h; 5% opacity; Method 9 30 min annually from Feb 25, 93; vents inside building. May want to modify permit conditions

Indian River Potential Emission Source Inventory

Source ID	E.U. ID	Plant Area/ Dept.	Description	S=Significant I=Insignificant P=Presumed Exempt E=Exempt	Reference	Comment
CT-A	4	CT	Combustion Turbine (35 MW)	S		H2O/Fuel Min. Table. Simple cycle GE Frame 6 CT, 35 MW cap. Water injection for NOx. BACT, PSD, NSPS; 8760 hrs; 445 MMBtu/hr max @ 59F.; startup 800 HP ICE Diesel, approx 10 min.; max allow /unit/hr. in permit; 5%/10% opacity Nat/Oil; also limited for PSD/inventory CO, PM, PM10, VOC, H2SO4 mist, Beryllium. Dist. Oil S 0.3% wt.
CT-B	5	CT	Combustion Turbine (35 MW)	S		
CT-C	7	CT	Combustion Turbine (129 MW)	S		
CT-D	6	CT	Combustion Turbine (129 MW)	S		
		YD	Propane Tank	P		Pressurized vessel; No longer used.
		PB	Nat. gas Pressure relief valves marked H2	E		CH4 not criteria or HAP
			Lube Oil reservoir vents 115 F	P		Should be Presumptive exempt, if class. as operating equipment vent (Item 18 of DEP letter). Low VP, less than 0.5
		PB				Should be presumptive exempt, based on size, lack of VOCs, and descriptions for Items 23, 27 and 28 in DEP letter. Only reason for VOC would be from diesel spill, which is not normal operating conditions.
		YD	Oil water separators (2)	P		Exempt by 62-210.300(3)(n), if used exclusively for chemical or physical analysis.
		WT	Laboratory Hood	P		
		MT	Parts washers	E		Exempt -- solvent does not contain VOC or HAPs (i.e., no pollutants). Use non-halogenated solvent only. See also rule 17-213.420(3)(c)3.b.
		MT	Welding	P		Item 18 in DEP letter.
		MT	Bead Blasting	P		Enclosed, Item 2 in DEP letter.
		YD	Unpaved Roads	S		
		YD	Paved Roads	S		

Indian River Potential Emission Source Inventory

Source ID	E.U. ID	Plant Area/ Dept.	Description	S=Significant I=Insignificant P=Presumed Exempt E=Exempt	Reference	Comment
		PB	Soot Cleanout from Boilers	P		Items 10, 35 in DEP letter.
		PB	CEM equipment	P		Item 15 in DEP letter.
		PB	Generator venting	E		Item 21 in DEP letter.
		WT	Waster Water Effluent Sewage Plant	P		Item 25 in DEP letter.
		YD	Barge No. 6 Fuel Oil Unloading	P		Low vapor pressure, no venting, other than on barge, which is taking in air during unloading. Vapor pressure of No. 6 F.O. is too low for significant levels to bleed through valves and flanges. Item 10 in DEP letter states
		YD	Painting applications for maintenance purposes	S		"Presumptive exemption except for painting/coating applications." Thus, painting for maintenance is not presumed exempt, but must be quantified.
		YD	Painting applications for construction purposes	P		Title V is not a construction permit.
		YD	Routine maintenance/repair activities other than painting	P		Item 10 in DEP letter.

**APPENDIX B**  
**INSIGNIFICANT ACTIVITIES**



Indian River Potential Emission Source Inventory

Source ID	E.U. ID	Plant Area/ Dept.	Description	S=Significant I=Insignificant P=Presumed Exempt E=Exempt	Reference	Comment
Source ID	E.U. ID	Plant Area/ Dept.	Description	S=Significant I=Insignificant P=Presumed Exempt E=Exempt	Reference	Comment
CT-A	4	CT	Combustion Turbine (35 MW)	S		H2O/Fuel Min. Table. Simple cycle GE Frame 6 CT, 35 MW cap. Water injection for NOx. BACT, PSD, NSPS; 8760 hrs; 445 MMBtu/hr max @ 59F.; startup 800 HP ICE Diesel, approx 10 min.; max allow /unit/hr. in permit; 5%/10% opacity Nat/Oil; also limited for PSD/inventory CO, PM, PM10, VOC, H2SO4 mist, Beryllium. Dist. Oil S 0.3% wt.
CT-B	5	CT	Combustion Turbine (35 MW)	S		
CT-D	6	CT	Combustion Turbine (129 MW)	S		
CT-C	7	CT	Combustion Turbine (129 MW)	S		
	1	PB	Unit 1 boiler	S	Dwg 17135-9STU-S1001	Shares stack with Unit 2; Natural Gas, No. 6 F.O.; No. 2 F. O.; Tangential Fired
	2	PB	Unit 2 boiler	S	Annual Operating Report RY 1994	Shares stack with Unit 1 Natural Gas, No. 6 F.O.; No. 2 F. O.; Tangential Fired
	3	PB	Unit 3 boiler	S	Dwg 17135-9STU-S1001	Natural Gas, No. 6 Oil; Tangential Fired; single stack.
	8	WT	Lime Storage Silo	S	Permit AO05-229996	At Water TXT Bldg, 99% eff., 28.29.32N/80.46.59W; 17-521.5 kmE, 3151.6 kmN; baghouse General Resource Corp., model 13204.8; Loading 2 hr/day; loading rate 10 t/h; 5% opacity; Method 9 30 min annually from Feb 25, 93; vents inside building. May want to modify permit conditions
		YD	Paved Roads	S		
		YD	Painting applications for maintenance purposes	S		Item 10 in DEP letter states "Presumptive exemption except for painting/coating applications." Thus, painting for maintenance is not presumed exempt, but must be quantified.
		YD	Unpaved Roads	S		
		MT	Bead Blasting	P		Enclosed, Item 2 in DEP letter.
		MT	Welding	P		Item 18 in DEP letter.
		PB	Lube Oil reservoir vents 115 F	P		Should be Presumptive exempt, if class. as operating equipment vent (Item 18 of DEP letter). Low VP, less than 0.5 mmHg
		PB	Soot Cleanout from Boilers	P		Items 10, 35 in DEP letter.
		PB	CEM equipment	P		Item 15 in DEP letter.
		WT	Laboratory Hood	P		Exempt by 62-210.300(3)(n), if used exclusively for chemical or physical analysis.
		WT	Water Treatment Processes	P	Dwg 17135-9STU-S1001	Item 27 in DEP letter. Note, however, that if Cl emissions are greater than 10 tons per year, exemption may not apply.
		WT	Waster Water Effluent Sewage Plant	P		Item 25 in DEP letter.

Indian River Potential Emission Source Inventory

Source ID	E.U. ID	Plant Area/ Dept.	Description	S=Significant I=Insignificant P=Presumed Exempt E=Exempt	Reference	Comment
		YD	Routine maintenance/repair activities other than painting	P		Item 10 in DEP letter.
		YD	Oil water separators (2)	P		Should be presumptive exempt, based on size, lack of VOCs, and descriptions for Items 23, 27 and 28 in DEP letter. Only reason for VOC would be from diesel spill, which is not normal operating conditions.
		YD	Painting applications for construction purposes	P		Title V is not a construction permit.
		YD	Propane Tank	P		Pressurized vessel; No longer used.
		YD	Xformers	P	Dwg 17135-9STU-S1001	Sealed
		YD	Valve Stations	P	Dwg 17135-9STU-S1001	Low Vapor Pressure; Methane not a criteria pollutant or VOC.
		YD	Percolation Ponds	P	Dwg 17135-9STU-S1001	
		YD	Barge No. 6 Fuel Oil Unloading	P		Low vapor pressure, no venting, other than on barge, which is taking in air during unloading. Vapor pressure of No. 6 F.O. is too low for significant levels to bleed through valves and flanges.
		YD	Fuel Oil Tanks 1, 2 and 3	I	Dwg 17135-9STU-S1001	No. 6 Fuel. Oil. Tanks 2 less than 350 lb/yr, based on all oil through largest tank.
		YD	Light Oil Tanks 1 and 2 and Fuel Pump	I	Dwg 17135-9STU-S1001	No. 2 Diesel. Tanks 2 less than 800 lb/yr, based on all diesel through largest (CT) tank.
		MT	Parts washers	E		Exempt – solvent does not contain VOC or HAPs (i.e., no pollutants). Use non-halogenated solvent only. See also rule 17-213.420(3)(c)3.b.
		PB	Generator venting	E		Item 21 in DEP letter.
		PB	Nat. gas Pressure relief valves marked H2	E		CH4 not criteria or HAP

**APPENDIX C**  
**ALTERNATIVE METHODS**  
**OF OPERATION**

## INDIAN RIVER PLANT

### ALTERNATIVE METHODS OF OPERATIONS

#### I. STEAM UNITS

##### A. UNIT 1

###### 1. Primary Methods

###### a. Oil

Maximum of 832.2 MMBtu/hr heat input to the boiler from combustion of No. 6 Fuel Oil with minor quantities of No. 2 Fuel Oil used for ignitors.

###### b. Gas

Maximum of 865.5 MMBtu/hr heat input to the boiler from combustion of pipeline natural gas with minute quantities of No. 2 Fuel Oil used for ignitors.

###### c. Mix

Mixture of No. 6 Fuel Oil and Pipeline Natural Gas, both varying in feed rate from 0 to 100% of permitted total heat input.

###### 2. Alternative Methods

###### a. Landfill Gas

Heat input no more than 10% of permitted heat input on natural gas from landfill waste gas while combusting either No. 6 Fuel Oil or Pipeline Natural Gas.

###### b. On Spec Used Oil

Heat input no more than 10% of permitted heat input on No. 6 Fuel Oil from on spec used oil while combusting either No. 6 Fuel Oil or Pipeline Natural Gas.

###### c. Higher Heat Inputs

Heat input from 865.5 MMBtu/hr to 955 MMBtu/hr on gas and from 832.2 MMBtu/hr to 910 MMBtu/hr on No. 6 Fuel Oil. While operating in this method of operation, emission limitations would be reduced by the ratio of the increased heat input (i.e. 865.5/955) so that the emission rate in lbs./hr would remain identical to the permitted rate of the primary method of operation.

##### B. UNIT 2

###### 1. Primary Methods

###### a. Oil

Maximum of 2016.5 MMBtu/hr heat input to the boiler from combustion of No. 6 Fuel Oil with minor quantities of No. 2 Fuel Oil used for ignitors.

###### b. Gas

Maximum of 2248.7 MMBtu/hr heat input to the boiler from combustion of pipeline natural gas with minute quantities of No. 2 Fuel Oil used for ignitors.

c. Mix

Mixture of No. 6 Fuel Oil and Pipeline Natural Gas, both varying in feed rate from 0 to 100% of permitted total heat input.

2. Alternative Methods

a. Landfill Gas

Heat input no more than 10% of permitted heat input on natural gas from landfill waste gas while combusting either No. 6 Fuel Oil or Pipeline Natural Gas.

b. On Spec Used Oil

Heat input no more than 10% of permitted heat input on No. 6 Fuel Oil from on spec used oil while combusting either No. 6 Fuel Oil or Pipeline Natural Gas.

c. Higher Heat Inputs

Heat input from 2016.5 MMBtu/hr on No. 6 Fuel Oil to 2065 MMBtu/hr on No. 6 Fuel Oil. While operating in this method of operation, emission limitations would be reduced by the ratio of the increased heat input (i.e. 2015.5/2065) so that the emission rate in lbs./hr would remain identical to the permitted rate of the primary method of operation.

C. UNIT 3

1. Primary Methods

a. Oil

Maximum of 3048.8 MMBtu/hr heat input to the boiler from combustion of No. 6 Fuel Oil with minor quantities of No. 2 Fuel Oil used for ignitors.

b. Gas

Maximum of 3208.5 MMBtu/hr heat input to the boiler from combustion of pipeline natural gas with minute quantities of No. 2 Fuel Oil used for ignitors.

c. Mix

Mixture of No. 6 Fuel Oil and Pipeline Natural Gas, both varying in feed rate from 0 to 100% of permitted total heat input.

2. Alternative Methods

a. Landfill Gas

Heat input no more than 10% of permitted heat input on natural gas from landfill waste gas while combusting either No. 6 Fuel Oil or Pipeline Natural Gas.

b. On Spec Used Oil

Heat input no more than 10% of permitted heat input on No. 6 Fuel Oil from on spec used oil while combusting either No. 6 Fuel Oil or Pipeline Natural Gas.

c. Higher Heat Inputs

Heat input from 3208.5 MMBtu/hr to 3500 MMBtu/hr on gas and from 3048.8 MMBtu/hr to 3350 MMBtu/hr on No. 6 Fuel Oil. While operating in this method of operation, emission limitations would be reduced by the ratio of the increased heat input (i.e. 3208.5/3500) so that the emission rate in lbs./hr would remain identical to the permitted rate of the primary method of operation.

II. COMBUSTION TURBINES

A. COMBUSTION TURBINE A

1. Primary Methods

a. Oil

Maximum of 445 MMBtu/hr heat input into the combustion turbine from No. 2 Fuel Oil.

2. Gas

Maximum of 445 MMBtu/hr heat input into the combustion turbine from Pipeline Natural Gas.

3. Mix

Maximum of 445 MMBtu/hr heat input from a mixture of 0 to 100% No. 2 Fuel Oil and 0 to 100% Pipeline Natural Gas

B. COMBUSTION TURBINE B

1. Primary methods

a. Oil

Maximum of 445 MMBtu/hr heat input into the combustion turbine from No. 2 Fuel Oil.

2. Gas

Maximum of 445 MMBtu/hr heat input into the combustion turbine from Pipeline Natural Gas.

3. Mix

Maximum of 445 MMBtu/hr heat input from a mixture of 0 to 100% No. 2 Fuel Oil and 0 to 100% Pipeline Natural Gas

C. COMBUSTION TURBINE C

1. Primary Methods

a. Oil

Maximum of 1346 MMBtu/hr heat input into the combustion turbine from No.

2 Fuel Oil.

2. Gas

Maximum of 1354 MMBtu/hr heat input into the combustion turbine from Pipeline Natural Gas.

3. Mix

Maximum of between 1354 and 1346 MMBtu/hr heat input from a mixture of 0 to 100% No. 2 Fuel Oil and 0 to 100% Pipeline Natural Gas

#### D. COMBUSTION TURBINE D

##### 1. Primary Methods

a. Oil

Maximum of 1346 MMBtu/hr heat input into the combustion turbine from No. 2 Fuel Oil.

2. Gas

Maximum of 1354 MMBtu/hr heat input into the combustion turbine from Pipeline Natural Gas.

3. Mix

Maximum of between 1354 and 1346 MMBtu/hr heat input from a mixture of 0 to 100% No. 2 Fuel Oil and 0 to 100% Pipeline Natural Gas

#### III. LIME SILO

##### 1. Primary Method

A. Permitted Rates

Current permit allows for lime to be fed at 10 tph for 2 hours per day.

##### 2. Alternative Method

B. Increased Feed Rates

Lime feed rate of 15 tph for up to 4 hours/day while maintaining permitted limit of 5% opacity.

**APPENDIX D**  
**COMPLIANCE PLAN AND REPORT**



## COMPLIANCE REPORT and PLAN


EMISSIONS UNIT	IN COMPLIANCE *	OUT OF COMPLIANCE
01 BOILER 1	X	
02 BOILER 2	X	
03 BOILER 3	X	
04 COMBUSTION TURBINE A	X	
05 COMBUSTION TURBINE B	X	
06 COMBUSTION TURBINE C	X	
07 COMBUSTION TURBINE D	X	
08 LIME STORAGE SILO	X	
No ID NON-REGULATED EMISSIONS (EX. & INSIG)	X	
No ID NON-REGULATED EMISSIONS (SIGNIFICANT)	X	

\* In compliance with all applicable regulations and requirements listed in Section II. Part 3b and Section III. Part 6b of the application.

**APPENDIX E**  
**COMPLIANCE STATEMENT**

**Compliance Certification (Hard-copy Required):**

"I, the undersigned, am the responsible official as defined in chapter 62-210.200, F.A.C., of the Title V source for which this report is being submitted. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made and data contained in the compliance report found in Appendix D are true, accurate, and complete."

  
\_\_\_\_\_  
Gregory A. DeMuth  
Director  
Environmental Division

  
\_\_\_\_\_  
Date



## ORLANDO UTILITIES COMMISSION

500 SOUTH ORANGE AVENUE • P. O. BOX 3193 • ORLANDO, FLORIDA 32802 • 407/423-9100

October 26, 1993

U. S. Environmental  
Protection Agency  
Region IV  
345 Courtland Street, N. E.  
Atlanta, GA 30365

Florida Department of  
Environmental Protection  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32301

Gentlemen:

This letter shall be the letter of authorization for Gregory A. DeMuth, Director Environmental Division for the Orlando Utilities Commission, to sign reports on behalf of the Orlando Utilities Commission as they relate to the Environmental Protection Agency and the Florida Department of Environmental Protection permits to operate and/or construct pollution sources.

Sincerely,

Troy W. Todd  
General Manager and CEO

TWT:rc  
authoriz



**APPENDIX F**  
**FUEL SPECIFICATIONS**

## FUEL SPECIFICATIONS

1. NO. 6 FUEL OIL	Density	0.9 - 1.0 s.g.
	Heat Value	6.2 - 6.4 MMBtu/bbl..
	% S	0.9 - 2.5%
	% N	< 0.5%
	% Ash	0.09 - 0.12
2. PIPELINE NATURAL GAS	Density	0.4 - 0.6 rel.
	Heat Value	980 - 1060 Btu/scf
	% S	< 1%
	% N	< 0.5%
	% Ash	< 1%
3. NO. 2 FUEL OIL	Density	0.9 - 1.0 s.g.
	Heat Value	5.0 - 5.75 MMBtu/bbl..
	% S	0.25 - 0.3%
	% N	< 0.5%
	% Ash	0.15% - 0.25%
4. LANDFILL WASTE GAS	Density	0.4 - 0.6 rel
	Heat Value	500 Btu/scf
	% S	< 1%
	% N	< 0.5%
	% Ash	< 1%
5. ON SPEC USED OIL	Density	0.9 - 1.0 s.g.
	Heat Value	4.5 - 5.5 MMBtu/bbl..
	% S	< 1%
	% N	< 0.5%
	% Ash	< 1%
6. MAGNESIUM HYDROXIDE (additive)	Density	1.3 - 1.5 s.g.
	Heat Value	0 MMBtu/gal.
	% S	< 1%
	% N	< 1%
	% Ash	< 1%



## ORLANDO UTILITIES COMMISSION

500 SOUTH ORANGE AVENUE • P. O. BOX 3193 • ORLANDO, FLORIDA 32802 • 407/423-9100

Certified Mail No. Z-215-203-287

Return Receipt Requested

November 15, 1995

Mr. Charles M. Collins, P. E.  
Program Administrator Air Section  
Florida Department of  
Environmental Protection  
3319 Maguire Blvd., Suite 232  
Orlando, FL 32803

Dear Mr. Collins:

On September 28, 1995, particulate emission tests were completed to re-verify compliance with the state regulations on the No. 1 boiler at the Indian River Plant, Operating Permit Number AO-05-183384 Unit 1. The heat input during these tests was approximately 775 M<sup>2</sup>BTU/hour.

The results, as tabulated below, show the unit to be in compliance with the State of Florida regulations of 0.1 lb/M<sup>2</sup>BTU during steady state and 0.3 lb/M<sup>2</sup>BTU during soot-blowing operation.

<u>Run No.</u>	<u>Particulate Emission (lb./10<sup>6</sup>BTU)</u>	<u>Percent Iso-Kinetics</u>	<u>Average Visible Emissions (% Opacity)</u>
STEADY STATE			
1	0.049	101.4	
5	0.037	99.2	
6	0.036	100.7	
Avg.	0.041	100.4	7.1%



**APPENDIX G**

**COMPLIANCE TEST REPORTS**



Mr. Charles M. Collins

November 15, 1995

page 2


<u>Run No.</u>	<u>Particulate Emission (lb./10<sup>6</sup>BTU)</u>	<u>Percent Iso- Kinetics</u>	<u>Average Visible Emissions (% Opacity)</u>
		SOOT-BLOWING	
2	0.030	100.8	
3	0.073	103.2	
4	0.024	99.7	
Avg.	0.042	101.2	2.7%

The on-line sample of the fuel burned during the test shows the sulfur content as 0.81% which calculates to be an emission rate of 0.88 lbs/M<sup>2</sup>BTU, well below the 2.75 lbs<sup>2</sup>/M BTU permitted by the Florida standard.

Attached is the test report for the compliance test prepared by Air Consulting & Engineering, Inc.

If you have any questions, please call me at 423-9133.

Sincerely,



Robert F. Hicks  
Sr. Environmental Engineer

RFH:rc  
Attachment

xc: F. F. Haddad  
G. M. Standridge  
G. A. DeMuth  
V. F. Gallucci w/enclosure

Table 1 Particulate Emissions Summary  
 Orlando Utilities Commission  
 Indian River Plant - Unit 1  
 Sharpes, Florida  
 September 1995

Run Number	Time	Flow Rate		Stack Temp (°F)	Moisture (%)	Oxygen (%)	Emission Rate	
		Actual (ACFM)	Standard (SCFMD)				Actual (lbs/MMBTU)	Allowable (lbs/MMBTU)
<u>Normal Operating Mode</u>								
1	9/27/95 1750-1905	271572	172478	294	9.9	6.4	0.04892	0.1
5	9/28/95 1112-1242	295051	183494	304	10.1	6.5	0.03709	0.1
6	9/28/95 1252-1406	289630	178843	304	10.8	6.4	0.03559	0.1
Normal Mode Average		285418	178272	301	10.3	6.4	0.04053	0.1
<u>Soot Blowing Mode</u>								
2	9/27/95 1919-2033	273206	174245	289	10.1	6.6	0.03029	0.3
3	9/28/95 0832-0948	286993	179472	294	10.8	6.7	0.07254	0.3
4	9/28/95 1000-1115	296194	184575	301	10.2	6.6	0.02430	0.3
Average		285464	179431	295	10.4	6.6	0.04238	0.3



## ORLANDO UTILITIES COMMISSION

500 SOUTH ORANGE AVENUE • P. O. BOX 3193 • ORLANDO, FLORIDA 32802 • 407/423-9100

Certified Mail No. Z-215-203-288

Return Receipt Requested

November 15, 1995

Mr. Charles M. Collins, P. E.  
Program Administrator Air Section  
Florida Department of  
Environmental Protection  
3319 Maguire Blvd., Suite 232  
Orlando, FL 32803

Dear Mr. Collins:

On September 25, 1995, particulate emission tests were completed to re-verify compliance with the state regulations on the No. 2 boiler at the Indian River Plant, Operating Permit Number AO 05-183384 Unit 2. The heat input during these tests was approximately 1915 M<sup>2</sup>BTU/hour.

The results, as tabulated below, show the unit to be in compliance with the State of Florida regulations of 0.1 lb/M<sup>2</sup>BTU during steady state and 0.3 lb/M<sup>2</sup>BTU during soot-blowing operation.

<u>Run No.</u>	<u>Particulate Emission (lb./10<sup>6</sup>BTU)</u>	<u>Percent Iso-Kinetics</u>	<u>Average Visible Emissions (% Opacity)</u>
<b>STEADY STATE</b>			
1	0.023	101.3	
5	0.026	102.2	
6	0.048	101.1	
Avg.	0.032	101.5	7.5%



Mr. Charles M. Collins  
November 15, 1995  
page 2

<u>Run No.</u>	<u>Particulate Emission (lb./10<sup>6</sup>BTU</u>	<u>Percent Iso- Kinetics</u>	<u>Average Visible Emissions (% Opacity)</u>
		SOOT-BLOWING	
2	0.107	101.4	
3	0.060	100.3	
4	0.055	102.3	
Avg.	0.074	101.2	13.1%

The on-line sample of the fuel burned during the test shows the sulfur content as 0.82% which calculates to be an emission rate of 0.89 lbs/M<sup>2</sup>BTU, well below the 2.75 lbs<sup>2</sup>/M BTU permitted by the Florida standard.

Attached is the test report for the compliance test prepared by Total Source Analysis, Inc.

If you have any questions, please call me at 423-9133.

Sincerely,



Robert F. Hicks  
Sr. Environmental Engineer

RFH:rc  
Attachment

xc: F. F. Haddad  
G. M. Standridge  
G. A. DeMuth  
V. F. Gallucci w/enclosure

Table 1 Particulate Emissions Summary  
 Orlando Utilities Commission  
 Indian River Plant - Unit 2  
 Sharpes, Florida  
 September 25, 1995

Run Number	Time	Flow Rate		Stack Temp (°F)	Moisture (%)	Oxygen (%)	Emission Rate	
		Actual (ACFM)	Standard (SCFMD)				Actual (lbs/MMBTU)	Allowable (lbs/MMBTU)
<u>Normal Operating Mode</u>								
1	0710-0822	885422	536425	328	9.7	7.1	0.02295	0.1
5	1256-1406	909905	542477	336	10.4	6.9	0.02599	0.1
6	1424-1534	936994	560288	336	10.1	6.9	0.04793	0.1
Normal Mode Average		910774	546397	333	10.1	7.0	0.03229	0.1
<u>Soot Blowing Mode</u>								
2	0838-0947	868047	515933	330	11.1	7.3	0.10728	0.3
3	1004-1114	896642	531851	333	11.0	7.2	0.06025	0.3
4	1128-1238	902159	536329	333	10.9	7.0	0.05522	0.3
Average		888949	528038	332	11.0	7.2	0.07425	0.3

3



## ORLANDO UTILITIES COMMISSION

500 SOUTH ORANGE AVENUE • P. O. BOX 3193 • ORLANDO, FLORIDA 32802 • 407/423-9100

Certified Mail No. Z-215-203-289

Return Receipt Requested

November 15, 1995

Mr. Charles M. Collins, P. E.  
Program Administrator Air Section  
Florida Department of  
Environmental Protection  
3319 Maguire Blvd., Suite 232  
Orlando, FL 32803

Dear Mr. Collins:

On September 27, 1995, particulate emission tests were completed to re-verify compliance with the state regulations on the No. 3 boiler at the Indian River Plant, Operating Permit Number AO 05-183384 Unit 3. The heat input during these tests was approximately 2550 M<sup>2</sup>BTU/hour.

The results, as tabulated below, show the unit to be in compliance with the State of Florida regulations of 0.1 lb/M<sup>2</sup>BTU during steady state and 0.3 lb/M<sup>2</sup>BTU during soot-blowing operation.

<u>Run No.</u>	<u>Particulate Emission (lb./10<sup>6</sup>BTU)</u>	<u>Percent Iso-Kinetics</u>	<u>Average Visible Emissions (% Opacity)</u>
<b>STEADY STATE</b>			
1	0.048	105.0	
4	0.021	103.6	
5	0.054	104.3	
Avg.	0.041	104.3	10.6%



Mr. Charles M. Collins  
November 15, 1995  
page 2

<u>Run No.</u>	<u>Particulate Emission (lb./10<sup>6</sup>BTU</u>	<u>Percent Iso- Kinetics</u>	<u>Average Visible Emissions (% Opacity)</u>
		SOOT-BLOWING	
2	0.076	104.0	
3	0.083	104.5	
6	0.080	104.1	
Avg.	0.080	104.2	17.3%

The on-line sample of the fuel burned during the test shows the sulfur content as 0.92% which calculates to be an emission rate of 1.00 lbs/M<sup>2</sup>BTU, well below the 2.75 lbs<sup>2</sup>/M BTU permitted by the Florida standard.

Attached is the test report for the compliance test prepared by Total Source Analysis, Inc.

If you have any questions, please call me at 423-9133.

Sincerely,



Robert F. Hicks  
Sr. Environmental Engineer

RFH:rc  
Attachment

xc: F. F. Haddad  
G. M. Standridge  
G. A. DeMuth  
V. F. Gallucci w/enclosure

Table 1 Particulate Emissions Summary  
 Orlando Utilities Commission  
 Indian River Plant - Unit 3  
 Sharpes, Florida  
 September 1995

Run Number	Time	Flow Rate		Stack Temp (°F)	Moisture (%)	Oxygen (%)	Emission Rate	
		Actual (ACFM)	Standard (SCFMD)				Actual (lbs/MMBTU)	Allowable (lbs/MMBTU)
<u>Normal Operating Mode</u>								
1	9/26/95 1100-1207	945741	586690	306	10.6	5.7	0.04789	0.1
4	9/26/95 1503-1609	964400	597365	308	10.5	5.5	0.02116	0.1
5	9/27/95 0930-1035	979311	602310	308	11.0	5.7	0.05413	0.1
Normal Mode Average		963142	595455	307	10.7	5.6	0.04106	0.1
<u>Soot Blowing Mode</u>								
2	9/26/95 1222-1327	953782	590961	307	10.6	5.7	0.07578	0.3
3	9/26/95 1342-1447	956762	594477	308	10.3	5.8	0.08342	0.3
6	9/27/95 1052-1156	963017	590807	309	11.1	5.7	0.07964	0.3
Average		957854	592082	308	10.7	5.7	0.07961	0.3

3





## ORLANDO UTILITIES COMMISSION

500 SOUTH ORANGE AVENUE • P. O. BOX 3193 • ORLANDO, FLORIDA 32802 • 407/423-9100

Certified Letter No. Z-215-203-431  
Return Receipt Requested

April 22, 1996

Mr. Leonard Kozlov, P. E., Administrator  
Air Resources Management  
Florida Department of Environmental Protection  
3319 Maguire Boulevard - Suite 232  
Orlando, FL 32803

Re: Annual Emissions Test Report  
Combustion Turbines A & B  
DER Permit No. A005-176351

Dear Mr. Kozlov:

Attached is the Fiscal Year 1996 Annual Emissions Test report for the above referenced units.

These tests were conducted in order to fulfill the requirements found in Specific Condition 10 of the applicable permit. Neither unit accumulated 170 hours burning fuel oil during the preceding 12 months period; therefore, tests were conducted using natural gas only.

The Lower Heating Value (LHV), as calculated from the gas analysis supplied by Florida Gas, was 947 BTU/CuFt. Average ambient temperature during CT-A and CT-B tests was 82°F and 69.5°F respectively. The allowable heat input at these temperatures is determined to be 410.7 MMBTU/HR for CT-A and 429.4 MMBTU/HR for CT-B. Based on these values from the attached "HEAT INPUT vs TEMPERATURE" curve (See Attachment A), CT-A was operating at 385.2 MMBTU/HR or 93.8% of the allowable heat input and CT-B was operating at 401 MMBTU/HR or 93.4% of the allowable heat input.



Mr. Leonard Kozlov  
Page 2  
April 22, 1996

If you have any questions, please call me at 423-9133.

Sincerely,



*W* Robert F. Hicks  
Sr. Environmental Engineer

RFH:rc  
Attachment

xc: G. A. DeMuth  
V. F. Gallucci  
J. M. Kraus, w/attach.

I:\wpfiles\reports\dep\abannual.96

Table 1 NOx Emissions and Operating Parameter Summary  
 Combustion Turbines A and B  
 Indian River Plant  
 Orlando Utilities Commission  
 February 20, 1996

Run Number	Load MW	Gaseous Fuel	HHV	Water to Fuel Ratio	NOx ppm	O2 %	NOx lbs/Hr
		Flow Rate lbs/sec	Heat Input MMBTU/Hr				
Unit A - 1	—	—	—	—	49.82	14.84	76.25
2	—	—	—	—	46.33	14.83	70.77
3	—	—	—	—	43.02	14.92	66.69
Average	34.31	5.13	426.68	0.593	46.39	14.86	71.24
Unit B - 1	—	—	—	—	35.89	14.76	56.41
2	—	—	—	—	32.51	14.74	50.98
3	—	—	—	—	31.55	14.87	48.56
Average	35.61	5.34	444.14	0.77	33.32	14.79	51.98

$$\text{HHV} = 1048.9 \text{ BTU/ft}^3$$

$$\text{Gas Density}^* = \frac{28.84 \text{ g}}{22.4} \times \frac{492}{520} \times \frac{\text{lb}}{453.6 \text{ g}} \times \frac{28.32 \text{ liters}}{\text{ft}^3} = 0.076 \text{ lbs/SCF for standard air}$$

$$0.076 \text{ lbs/SCF} \times \text{S.G.} = 0.076 \text{ lbs/SCF} \times 0.5973 = 0.454 \text{ lbs/SCF}$$

$$\text{BTU/Hr} = (\text{fuel flow}) \frac{3600 \text{ sec.}}{\text{Hr}} (1048.9 \text{ BTU/ft}^3) \frac{1}{0.0454 \text{ lbs/SCF}}$$

\*1 mole of a gas occupies 22.4 liters at zero degrees C and 29.92 "Hg



## ORLANDO UTILITIES COMMISSION

500 SOUTH ORANGE AVENUE • P. O. BOX 3193 • ORLANDO, FLORIDA 32802 • 407/423-9100

Via Hand Delivery

December 21, 1995

Ms. Vivian Garfein  
Central District Director  
Florida Department of  
Environmental Protection  
3319 Maguire Blvd., Suite 232  
Orlando, FL 32803

Re: Orlando Utilities Commission's Indian River Plant  
Combustion Turbines C & D

Dear Ms. Garfein:

We have now completed all remedial activities agreed upon at our meeting on September 20, 1995 and as outlined in my letter to you on September 27, 1995. The modifications were completed by Westinghouse as scheduled: fuel oil flow meters were recalibrated, new water injection control curves were established, alarms were hard wired to the main control room, and compliance tests were performed to verify combustion turbines' performance.

The water injection control curves which were established are found in Attachment 1. For each combustion turbine, two curves were established for each fuel. The curve of the water/fuel ratio vs. fuel flow which would result in NOx emissions at the permitted limit was determined. This curve must not be exceeded in order to maintain continuous compliance. In addition, a second more conservative water/fuel vs. fuel flow curve was established to be used as the control curve, which will allow some variation from the control curve without causing an exceedance of the emissions limit.

Also enclosed, is the Compliance Test Report covering the Annual 1995 compliance tests which were conducted on November 7 and 9, 1995, demonstrating the units are operating below the required emissions limits.

We wish to express our appreciation to the Department and especially to Anatoly Sobolevsky for the cooperation extended during the implementation of these remedial activities for Cts C and D. We believe we now have a monitoring system and control curves based on good engineering data which will allow these turbines to both operate and demonstrate full compliance with the applicable regulations.



Ms. Vivian Garfein  
December 21, 1995  
Page 2

If you have any questions, please call me at 423-9141 or Bob Hicks at 423-9133.

Very truly yours,



Gregory A. DeMuth  
Director  
Environmental Division

GAD:rc  
enclosures

xc: G. M. Standridge  
F. F. Haddad  
V. G. Gallucci  
R. F. Hicks  
J. M. Kraus, w/enclosures  
A. Sobolevsky, FDEP

i:\wpfiles\depcorr\c&dremed.wp

Table 1 Gas Turbine Emission Summary  
 Combustion Turbine – Unit CT-C - Natural Gas Firing  
 Indian River Power Plant  
 Orlando Utilities Commission  
 Frontenac, Florida  
 November 9, 1995

Run Number	Time	Power MW Ratio	Water/Fuel Ratio	Oxygen %	NOx Emissions			CO Emissions	VE %
					ppm	ppm @ 15% O <sub>2</sub>	ISO ppm	ppm	
1	1249-1351	114	1.17	14.31	27.72	24.82	24.02	4.1	
2	1406-1508	114	1.17	14.36	23.37	21.09	20.39	8.4	
3	1502-1624	114	1.17	14.31	24.41	21.81	21.09	8.2	
AVERAGE		114	1.17	14.3	25.2	22.6	21.8	6.9	0
1	1133-1149	81	1.11	16.10	17.35	21.32	20.76		
2	1148-1204	81	1.11	16.24	17.36	21.97	21.33		
3	1211-1227	81	1.11	16.30	17.46	22.40	21.76		
AVERAGE		81	1.11	16.20	17.4	21.9	21.1		0
1	0941-0957	56	1.12	17.17	14.05	22.25	21.74		
2	1007-1023	56	1.12	17.28	14.18	23.13	22.58		
3	1027-1043	56	1.12	17.29	14.11	23.02	22.46		
AVERAGE		56	1.12	17.25	14.11	22.8	22.26		0
1	0705-0739	38	1.22	18.11	10.69	22.60	22.25		
2	0748-0820	38	1.22	18.01	11.43	23.37	23.09		
3	0826-0909	38	1.22	18.04	10.99	22.67	22.36		
AVERAGE		38	1.22	18.0	11.0	22.9	22.6		0

Allowable NO<sub>x</sub> emissions = 25 ppm<sub>v</sub> @ 15% O<sub>2</sub>  
 Allowable CO emissions = 25 ppm<sub>v</sub>  
 Allowable VE emissions = 10% opacity at full load  
 = 20% opacity at other loads

**Table 2 Gas Turbine Emission Summary**  
**Combustion Turbine -- Unit CT-D - Natural Gas Firing**  
**Indian River Power Plant**  
**Orlando Utilities Commission**  
**Frontenac, Florida**  
**November 7, 1995**

Run Number	Time	Load MW	Water/Fuel Ratio	Oxygen %	NOx Emissions			CO Emissions	VE %
					ppm	ppm @ 15% O <sub>2</sub>	ISO ppm	ppm	
1	1322-1424	107	1.13	14.36	24.31	21.92	23.95	7.1	
2	1435-1537	107	1.13	14.33	25.98	23.31	25.10	6.2	
3	1509-1611	107	1.13	14.16	27.60	24.14	25.99	3.6	
AVERAGE		107	1.13	14.3	26.0	23.1	25.0	5.6	0
1	1100-1126	81	1.01	15.83	21.32	24.80	26.85		
2	1134-1150	81	1.01	15.81	21.39	24.77	27.02		
3	1157-1213	81	1.01	15.80	21.63	25.01	27.21		
AVERAGE		81	1.01	15.8	21.4	24.9	27.0		0
1	0929-0945	55	1.07	17.10	14.13	21.94	24.63		
2	0953-1009	55	1.07	17.09	14.24	22.04	24.84		
3	1021-1037	55	1.07	17.10	14.11	21.92	24.62		
AVERAGE		55	1.07	17.10	14.2	22.0	24.7		0
1	0708-0743	39	1.16	17.92	10.09	19.98	22.42		
2	0752-0822	39	1.16	17.78	10.61	20.10	22.74		
3	0831-0913	39	1.16	17.87	11.16	21.71	24.67		
AVERAGE		39	1.16	17.9	10.6	20.6	23.3		0

Allowable NO<sub>x</sub> emissions = 25 ppm, @ 15% O<sub>2</sub>  
 Allowable CO emissions = 25 ppm,  
 Allowable VE emissions = 10% opacity at full load  
 = 20% opacity at other loads

**BAGHOUSE COMPLIANCE REPORT**



EPA

VISIBLE EMISSION OBSERVATION FORM 1

Form Number 0000 Page 01  
 Continued on VEO Form Number

Method Used (Circle One)  
 Method 203A 2038 Other

Company Name Orlando Utilities Commission  
 Facility Name Indian River Plant  
 Street Address 7800 S. US. Hwy. #1  
 City Titusville State FL Zip 32780

Process lime silo Unit # Operating Mode  
 Control Equipment Baghouse Operating Mode


Describe Emission Point Vent 35' off grade

Height of Emiss. Pt. Start 45' End 40' Height of Emiss. Pt. Rel. to Observer Start 30' End 5'  
 Distance to Emiss. Pt. Start 50' End 50' Direction to Emiss. Pt. (Degrees) Start End

Vertical Angle to Obs. Pt. Start 55° End 35° Direction to Obs. Pt. (Degrees) Start 270° End 270°  
 Distance and Direction to Observation Point from Emission Point Start 50', 90° End 50', 90°

Describe Emissions Start none End none  
 Emission Color Start none End none Water Droplet Plume Attached  Detached  None

Describe Plume Background Start none End none  
 Background Color Start grey End grey Sky Conditions Start P.C. End P.C.  
 Wind Speed Start 0-5 End 0.5 Wind Direction Start 270 End 270  
 Ambient Temp. Start 84 F End 85 F Wet Bulb Temp. RH Percent



Observation Date	Time Zone	Start Time	End Time	Sec Min	0	15	30	45	Comments
		<u>6:50</u>	<u>9:20</u>						
1				0	6	0	0		
2				0	0	0	0		
3				0	0	0	0		
4				0	0	0	0		
5				0	0	0	0		
6				0	0	0	0		
7				0	0	0	0		
8				0	0	0	0		
9				0	0	0	0		
10				0	0	0	0		
11				0	0	0	0		
12				0	0	0	0		
13				0	0	0	0		
14				0	0	0	0		
15				0	0	0	0		
16				0	0	0	0		
17				0	0	0	0		
18				0	0	0	0		
19				5	5	0	0		
20				5	5	5	0		
21				5	5	5	0		
22				5	5	5	5		
23				0	5	5	0		
24				0	5	5	0		
25				10	5	5	0		
26				5	0	5	0		
27				0	0	0	0		
28				5	5	0	0		
29				5	5	0	0		
30				0	5	0	5		

Observer's Name (Print) JASON M. KRAUS  
 Observer's Signature [Signature] Date 6/12/96  
 Organization OUC  
 Certified By ETA Date 6/20/96

**APPENDIX H**  
**PROCEDURES FOR**  
**STARTUP, SHUTDOWN AND**  
**OPERATION AND MAINTENANCE PLAN**

**ORLANDO UTILITIES COMMISSION**

**INDIAN RIVER PLANT**

**OPERATION AND MAINTENANCE MANUAL**

### PURPOSE:

To ensure the correct, safe operation and maintenance of plant equipment and systems. This manual shall provide procedures for operating and maintaining plant equipment during periods of start-up, shutdown and malfunction.

### APPLICABILITY:

The procedures set forth in this plan only pertain to those items directly related to the generation and control of emissions.

### PROCEDURES:

Contained at the facility are manuals provided by the OEM (Original Equipment Manufacturer) that specify the proper operation and maintenance of each piece of equipment and systems. As these manuals are voluminous, they are only referenced in this plan. These manuals provide detailed specifications for all phases of operation and maintenance including start-up, shutdown and malfunction of this equipment.

Operators use data from the continuous emissions monitoring systems to minimize excess emissions during start-up, shutdown, malfunction and normal plant operation. If excess emissions are detected, the proper plant personnel are notified and corrective actions are taken such as performing maintenance on an item, adjusting the controls or shedding load off the unit. Recurring problems are addressed using best management practices.

### TRAINING:

Plant operations personnel first begin as apprentices, where they are allowed time to learn plant systems under the expertise of a trained plant operator. Over time, they are taught the best operational practices for each system and piece of equipment. Additionally, each operator continues training throughout his/her career through use of the NUS Power Plant Operations and Power Plant Maintenance series. Promotions are contingent upon the successful completion of each phase of this series and failure to successfully complete the training may result in demotion. Training records are maintained at the facility.

Maintenance personnel also begin as an apprentice, working under the supervision of trained maintenance personnel. Their progression is also dependant upon successful completion of the NUS Power Plant Maintenance series. Training records are maintained at the facility.

### MAINTENANCE PLANNING:

The facility uses a computerized maintenance scheduler that generates work orders based upon OEM recommendations. All work orders are completed based upon a variety of factors such as the last time the work order was completed, the availability of plant

resources or the cost to complete the work order. Furthermore, work orders may be deferred until the next scheduled outage. Additionally, maintenance is completed on an as needed basis, due to emergencies and equipment failure.

Maintenance records are kept at the facility for each work order and trouble report. Maintenance history for each system or large piece of equipment is also available.

**APPENDIX I**  
**ACID RAIN APPLICATIONS**

# PHASE II PERMIT APPLICATION

Page

For more information, see instructions and refer to 40 CFR 72.30 and 72.31 and Chapter 214, F.A.C.

This submission is:

New

Revised

**Step 1**

Identify the source by plant name, State, and ORIS code from NADB

Indian River Plant	FI	683
Plant Name	State	ORIS Code

**Step 2**

Enter the boiler ID# from NADB for each affected unit, and indicate whether a repowering plan is being submitted for the unit by entering "yes" or "no" at column c. For new units, enter the requested information in columns d and e

Compliance Plan

a Boiler ID#	b Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1)	c Repowering Plan	d New Units  Commence Operation Date	e New Units  Monitor Certification Deadline
1	Yes	No		
2	Yes	No		
3	Yes	No		
C	Yes	No	01 Sep 1992	01 Jan 1995
D	Yes	No	01 Oct 1992	01 Jan 1995
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			

**STEP 3**

Check the box if the response in column c of Step 2 is "yes" for any unit

For each unit that will be repowered, the Repowering Extension Plan form is included and the Repowering Technology Petition form has been submitted or will be submitted by June 1, 1997.

Plant Name (from Step 1)

Indian River Plant

**Step 4**

Read the standard requirements and certification, enter the name of the designated representative, and sign and date

**Standard Requirements****Permit Requirements:**

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Submit a complete Acid Rain part application (including a compliance plan) under 40 CFR part 72, Rules 62-214.320 and 330, F.A.C.; and
  - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary to review an Acid Rain part application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain part application or a superseding Acid Rain part issued by the permitting authority; and
  - (ii) Have an Acid Rain Part.

**Monitoring Requirements:**

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measured recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor the emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

**Sulfur Dioxide Requirements:**

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
  - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1)(i) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

**Nitrogen Oxides Requirements:** The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

**Excess Emissions Requirements:**

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

**Recordkeeping and Reporting Requirements:**

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
  - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certification of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR part 75;
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and



Plant Name (from Step 1)

Indian River Plant

Recordkeeping and Reporting Requirements (cont.)

(iv) Copies of all documents used to complete an Acid Rain part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability:


- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain part application, an Acid Rain part, or written exemption under 40 CFR 72.7 or 72.8, including any requirement for payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 including 40 CFR 75.16, 75.17, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40CFR parts 72, 73, 75, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities: No provision of the Acid Rain Program, an Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any provision of the Act, including the provisions of title I of the Act relating to applicable National Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudent review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name		Fred F. Haddad, Jr.
Signature		Date 12/15/95

**APPENDIX J**  
**DESCRIPTION OF**  
**CONTROL EQUIPMENT**

## CONTROL EQUIPMENT

### 1. COMBUSTION TURBINE A

Combustion Turbine A employs water injection to control NOx emissions. Emissions limits are set at 75.1 lb/hr while combusting Pipeline Natural Gas and at 118.3 lb/hr while combusting No. 2 Fuel oil, at sea level and 59F. Water injection rates are programmed to ensure that these emission rates are not exceeded.

### 2. COMBUSTION TURBINE B

Combustion Turbine B employs water injection to control NOx emissions. Emissions limits are set at 75.1 lb/hr while combusting Pipeline Natural Gas and at 118.3 lb/hr while combusting No. 2 Fuel oil, at sea level and 59F. Water injection rates are programmed to ensure that these emission rates are not exceeded.

### 3. COMBUSTION TURBINE C

Combustion Turbine C employs water injection to control NOx emissions. Emissions limits are set at 25 ppmvd while combusting Pipeline Natural Gas and at 42 ppmvd while combusting No. 2 Fuel oil, 15% oxygen. Water injection rates are programmed to ensure that these emission rates are not exceeded.

### 4. COMBUSTION TURBINE D

Combustion Turbine D employs water injection to control NOx emissions. Emissions limits are set at 25 ppmvd while combusting Pipeline Natural Gas and at 42 ppmvd while combusting No. 2 Fuel oil, 15% oxygen. Water injection rates are programmed to ensure that these emission rates are not exceeded.

### 5. LIME STORAGE SILO

The Lime Storage Silo uses a fabric filter baghouse during lime feed operations to control particulate emissions. This filter is approximately 99% efficient in particulate matter removal.

**APPENDIX K**  
**ADDITIONAL RULES**

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
<p>*This list includes only those applicable requirements typically associated with an electric power plant. For example, NSPS Subpart O for sewage treatment plants has not been included. If rules other than those listed herein apply to your source, they should be included in your source's application even if they are not listed below.  <b><sup>b</sup>Please refer to HGSS's June 6, 1995 memorandum explaining how this list was developed and how applicable requirements should be addressed in an application.</b></p>						
<b>Part 60 - EPA Regulations on Standards of Performance for New Stationary Sources</b>						
<b>Subpart A — General Provisions</b>						
60.7	Notification and record keeping.	004, 005, 006, 007	X			Unit
60.8	Performance tests.	004, 005, 006, 007	X			Unit
60.11	Compliance with standards and maintenance requirements.	004, 005, 006, 007	X			Unit
60.12	Circumvention.	004, 005, 006, 007	X			Unit
60.13	Monitoring requirements.	004, 005, 006, 007	X			Unit
60.19	General notifications and reporting requirements.	004, 005, 006, 007	X			Unit
<b>Subpart D — Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971</b>						
60.42	Standard for particulate matter.			X		Unit
60.43	Standard for sulfur dioxide.			X		Unit
60.44	Standard for nitrogen oxides.			X		Unit
60.45	Emission and fuel monitoring.			X		Unit
60.46	Test methods and procedures.			X		Unit
<b>Subpart Da — Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978</b>						

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
60.42a	Standard for particulate matter.			X		Unit
60.43a	Standard for sulfur dioxide.			X		Unit
60.44a	Standard for nitrogen oxides.			X		Unit
60.45a	Commercial demonstration permit.			X		Unit
60.46a	Compliance provisions.			X		Unit
60.47a	Emission monitoring.			X		Unit
60.48a	Compliance determination procedures and methods.			X		Unit
60.49a	Reporting requirements.			X		Unit
Subpart Db — Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units						
60.42b	Standard for sulfur dioxide.			X		Unit
60.43b	Standard for particulate matter.			X		Unit
60.44b	Standard for nitrogen oxides.			X		Unit
60.45b	Compliance and performance test methods and procedures for sulfur dioxide.			X		Unit
60.46b	Compliance and performance test methods and procedures for particulate matter and nitrogen oxides.			X		Unit
60.47b	Emission monitoring for sulfur dioxide.			X		Unit
60.48b	Emission monitoring for particulate matter and nitrogen oxides.			X		Unit
60.49b	Reporting and recordkeeping.			X		Unit
Subpart Dc — Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units						
N60.42c	Standard for sulfur dioxide.			X		Unit
60.43c	Standard for particulate matter.			X		Unit

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
60.44c	Compliance and performance test methods and procedures for sulfur dioxide.			X		Unit
60.45c	Compliance and performance test methods and procedures for particulate matter.			X		Unit
60.46c	Emission monitoring for sulfur dioxide.			X		Unit
60.47c	Emission monitoring for particulate matter.			X		Unit
60.48c	Reporting and recordkeeping.			X		Unit
<b>Subpart K — Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After June 11, 1973, and Prior to May 19, 1978</b>						
60.112	Standard for volatile organic compounds (VOC).			X		Unit
60.113	Monitoring of operations.			X		Unit
<b>Subpart Ka — Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After May 18, 1978, and Prior to July 23, 1984</b>						
60.112a	Standard for volatile organic compounds (VOC).			X		Unit
60.113a	Testing and procedures.			X		Unit
60.114a	Alternative means of emission limitations.			X		Unit
60.115a	Monitoring of operations.			X		Unit
<b>Subpart Kb — Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984</b>						
60.112b	Standard for volatile organic compounds (VOC).			X		Unit
60.113b	Testing and procedures.			X		Unit
60.114b	Alternative means of emission limitations.			X		Unit
60.115b	Recordkeeping and reporting requirements.			X		Unit
60.116b	Monitoring of operations.			X		Unit

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
<b>Subpart Y — Standards of Performance for Coal Preparation Plants</b>						
60.252	Standard for particulate matter.			X		Unit
60.253	Monitoring of operations.			X		Unit
60.254	Test methods and procedures.			X		Unit
<b>Subpart GG — Standards of Performance for Stationary Gas Turbines</b>						
60.332	Standard for nitrogen oxides.	006, 007	X			Unit
60.333	Standard for sulfur dioxide.	006, 007	X			Unit
60.334	Monitoring of operations.	006, 007	X			Unit
60.335	Test methods and procedures.	006, 007	X			Unit
<b>Subpart OOO — Standards of Performance for Nonmetallic Mineral Processing Plants</b>						
60.672	Standard for Particulate Matter.			X		Unit
60.674	Monitoring of Operations.			X		Unit
60.676	Reporting and Recordkeeping.			X		Unit
<b>Part 61 - EPA Regulations on National Emission Standards for Hazardous Air Pollutants</b>						
<b>Subpart A — General Provisions</b>						
61.05	Prohibited Activities.		X			Facility
61.09	Notification of Startup.		X			Facility
61.10	Source Reporting and Request for Waiver of Compliance.		X			Facility
61.11	Waiver of Compliance.		X			Facility
61.12	Compliance with Standards and Maintenance Requirements.		X			Facility
61.13	Emission Tests and Waiver of Emission Tests.		X			Facility
61.14	Monitoring Requirements.		X			Facility



EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
61.19	Circumvention.		X			Facility
Subpart M — National Emission Standards for Asbestos			X			Facility
Appendix C to Part 61 — Quality Assurance Procedures			X			Facility
<b>Part 63 - EPA Regulations on National Emission Standards for Hazardous Air Pollutants for Source Categories</b>						
Subpart A — General Provisions						
63.4	Prohibited Activities and Circumvention.			X		Unit
63.6	Compliance with Standards and Maintenance Requirements.			X		Unit
63.7	Performance Testing Requirements.			X		Unit
63.8	Monitoring Requirements.			X		Unit
63.9	Notification Requirements.			X		Unit
63.10	Reporting and Recordkeeping Requirements.			X		Unit
63.11	Control Device Requirements.			X		Unit
Subpart Q — National Emission Standards for Industrial Process Cooling Towers						
63.402	Standard.			X		Unit
63.403	Compliance Dates.			X		Unit
63.404	Compliance Demonstrations.			X		Unit
63.405	Notification Requirements.			X		Unit
63.406	Recordkeeping and Reporting Requirements.			X		Unit
Subpart T — National Emission Standards for Halogenated Solvent Cleaning						
63.462	Batch Cold Cleaning Machine Standards.		X			Facility
63.463	Batch Vapor and In-Line Cleaning Machine Standards.		X			Facility
63.464	Alternative Standards.		X			Facility

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
63.465	Test Methods.		X			Facility
63.466	Monitoring Procedures.		X			Facility
63.467	Recordkeeping Requirements.		X			Facility
63.468	Reporting Requirements.		X			Facility
<b>Part 72 - EPA Acid Rain Program Permits</b>						
<b>Subpart A — General Provisions</b>						
72.7	New Units Exemption.	001, 002, 003, 006, 007	X			Unit
72.8	Retired Units Exemption.	001, 002, 003, 006, 007	X			Unit
72.9	Standard Requirements.	001, 002, 003, 006, 007	X			Unit
<b>Subpart B — Designated Representative</b>						
72.20	Authorization and Responsibilities of the Designated Representative	001, 002, 003, 006, 007	X			Unit
72.21	Submissions.	001, 002, 003, 006, 007	X			Unit
72.22	Alternate Designated Representative.	001, 002, 003, 006, 007	X			Unit
72.23	Changing the Designated Representative, Alternate Designated Representative; Changes in the Owners and Operators.	001, 002, 003, 006, 007	X			Unit
<b>Subpart C — Acid Rain Applications</b>						
72.30	Requirements to Apply.	001, 002, 003, 006, 007	X			Unit
72.32	Permit Applications Shield and Binding Effect of Permit Application.	001, 002, 003, 006, 007	X			Unit

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
72.33	Identification of Dispatch System.	001, 002, 003, 006, 007	X			Unit
<b>Subpart D — Acid Rain Compliance Plan and Compliance Options</b>						
72.40	General.	001, 002, 003, 006, 007	X			Unit
72.41	Phase I Substitution Plans.	001, 002, 003, 006, 007	X			Unit
72.42	Phase I Extension Plans.	001, 002, 003, 006, 007	X			Unit
72.43	Phase I Reduced Utilization Plans.	001, 002, 003, 006, 007	X			Unit
72.44	Phase II Repowering Extensions.	001, 002, 003, 006, 007	X			Unit
<b>Subpart E — Acid Rain Permit Contents</b>						
72.51	Permit Shield.	001, 002, 003, 006, 007	X			Unit
<b>Subpart I - Compliance Certification</b>						
72.90	Annual Compliance Certification Report.	001, 002, 003, 006, 007	X			Unit
72.91	Phase I Unit Adjusted Utilization.	001, 002, 003, 006, 007	X			Unit
72.92	Phase I Unit Allowance Surrender.	001, 002, 003, 006, 007	X			Unit
72.93	Units with Phase I Extension Plans.	001, 002, 003, 006, 007	X			Unit
72.94	Units with Repowering Extension Plans.	001, 002, 003, 006, 007	X			Unit

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
<b>Part 73 - EPA Acid Rain Program Sulfur Dioxide Allowance System</b>						
Subpart C — Allowance Tracking System						
73.35	Compliance.	001, 002, 003, 006, 007	X			Unit
<b>Part 75 - EPA Acid Rain Program For Continuous Emission Monitoring</b>						
Subpart A — General						
75.4	Compliance Dates.	001, 002, 003, 006, 007	X			Unit
75.5	Prohibitions.	001, 002, 003, 006, 007	X			Unit
Subpart B — Monitoring Provisions						
75.10	General Operating Requirements.	001, 002, 003, 006, 007	X			Unit
75.11	Specific Provisions for Monitoring SO <sub>2</sub> Emissions (SO <sub>2</sub> and Flow Monitors).	001, 002, 003, 006, 007	X			Unit
75.12	Specific Provisions for Monitoring NO <sub>x</sub> Emissions (NO <sub>x</sub> and Diluent Gas Monitors).	001, 002, 003, 006, 007	X			Unit
75.13	Specific Provisions for Monitoring CO <sub>2</sub> Emissions.	001, 002, 003, 006, 007	X			Unit
75.14	Specific Provisions for Monitoring Opacity.	001, 002, 003, 006, 007	X			Unit
75.15	Specific Provisions for Monitoring SO <sub>2</sub> Emissions Removal by Qualifying Phase I Technology.	001, 002, 003, 006, 007	X			Unit
75.16	Specific Provisions for Monitoring Emissions from Common, By-Pass, and Multiple Stacks for SO <sub>2</sub> Emissions and Heat Input Determinations.	001, 002, 003, 006, 007	X			Unit

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
75.17	Specific Provisions for Monitoring Emissions from Common, Bypass, and Multiple Stacks for NO <sub>x</sub> Emission Rate.	001, 002, 003, 006, 007	X			Unit
75.18	Specific Provisions for Monitoring Emissions from Common, Bypass, and Multiple Stacks for Opacity.	001, 002, 003, 006, 007	X			Unit
<b>Subpart C — Operation and Maintenance Requirements</b>						
75.20	Certification and Recertification Procedures.	001, 002, 003, 006, 007	X			Unit
75.21	Quality Assurance and Quality Control Requirements.	001, 002, 003, 006, 007	X			Unit
75.22	Reference Test Methods.	001, 002, 003, 006, 007	X			Unit
75.24	Out-of-Control Periods.	001, 002, 003, 006, 007	X			Unit
<b>Subpart D — Missing Data Substitution Procedures</b>						
75.30	General Provisions.	001, 002, 003, 006, 007	X			Unit
75.31	Initial Missing Data Procedures.	001, 002, 003, 006, 007	X			Unit
75.32	Determination of Monitor Data Availability for Standard Missing Data Procedures.	001, 002, 003, 006, 007	X			Unit
75.33	Standard Missing Data Procedures.	001, 002, 003, 006, 007	X			Unit
75.34	Units with Add-On Emission Controls.	001, 002, 003, 006, 007	X			Unit
<b>Subpart E — Alternative Monitoring Systems</b>						
75.40	General Demonstration Requirements.	001, 002, 003, 006, 007	X			Unit

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
75.41	Precision Criteria.	001, 002, 003, 006, 007	X			Unit
75.42	Reliability Criteria.	001, 002, 003, 006, 007	X			Unit
75.43	Accessibility Criteria.	001, 002, 003, 006, 007	X			Unit
75.44	Timeliness Criteria.	001, 002, 003, 006, 007	X			Unit
75.45	Daily Quality Assurance Criteria.	001, 002, 003, 006, 007	X			Unit
75.46	Missing Data Substitution Criteria.	001, 002, 003, 006, 007	X			Unit
75.47	Criteria for a Class of Affected Units.	001, 002, 003, 006, 007	X			Unit
75.48	Petition for an Alternative Monitoring System.	001, 002, 003, 006, 007	X			Unit
<b>Subpart F — Recordkeeping Requirements</b>						
75.50	General Recordkeeping Provisions.	001, 002, 003, 006, 007	X			Unit
75.51	General Recordkeeping Provisions for Specific Situations.	001, 002, 003, 006, 007	X			Unit
75.52	Certification, Quality Assurance, and Quality Control Record Provisions.	001, 002, 003, 006, 007	X			Unit
75.53	Monitoring Plan.	001, 002, 003, 006, 007	X			Unit
<b>Subpart G — Reporting Requirements</b>						

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
75.60	General Provisions.	001, 002, 003, 006, 007	X			Unit
75.61	Notification of Certification and Recertification Test Dates.	001, 002, 003, 006, 007	X			Unit
75.62	Monitoring Plan.	001, 002, 003, 006, 007	X			Unit
75.63	Certification or Recertification Applications.	001, 002, 003, 006, 007	X			Unit
75.64	Quarterly Reports.	001, 002, 003, 006, 007	X			Unit
75.65	Opacity Reports.	001, 002, 003, 006, 007	X			Unit
Appendix A to Part 75 — Specifications and Test Procedures		001, 002, 003, 006, 007	X			Unit
Appendix B to Part 75 — Quality Assurance and Quality Control Procedures		001, 002, 003, 006, 007	X			Unit
Appendix C to Part 75 — Missing Data Statistical Estimation Procedures		001, 002, 003, 006, 007	X			Unit
Appendix D to Part 75 — Optional SO <sub>2</sub> Emissions Data Protocol for Gas-Fired Units and Oil-Fired Units		001, 002, 003, 006, 007	X			Unit
Appendix E to Part 75 — Optional NO <sub>x</sub> Emissions Estimation Protocol for Gas-Fired Peaking Units and Oil-Fired Peaking Units		001, 002, 003, 006, 007	X			Unit
<b>EPA Part 76 - Acid Rain Nitrogen Oxides Emission Reduction Program</b>						
76.5	NO <sub>x</sub> Emission Limitations for Group 1 Boilers.	001, 002, 003, 006, 007	X			Unit

EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
76.8	Early Election for Group 1, Phase II Boilers.	001, 002, 003, 006, 007	X			Unit
76.9	Permit Applications and Compliance Plans.	001, 002, 003, 006, 007	X			Unit
76.10	Alternative Emission Limitations.	001, 002, 003, 006, 007	X			Unit
76.11	Emissions Averaging.	001, 002, 003, 006, 007	X			Unit
76.12	Phase I NO <sub>x</sub> Compliance Extensions.	001, 002, 003, 006, 007	X			Unit
76.14	Monitoring, Recordkeeping, and Reporting.	001, 002, 003, 006, 007	X			Unit
76.15	Test Methods and Procedures.	001, 002, 003, 006, 007	X			Unit
<b>EPA Part 82 - Protection Of Stratospheric Ozone</b>						
<b>Subpart B - Servicing of Motor Vehicle Air Conditioners</b>						
82.34	Prohibitions.			X		Facility
82.36	Approved refrigerant recycling equipment.			X		Facility
82.38	Approved independent standards testing organizations.			X		Facility
82.40	Technician training and certification.			X		Facility
82.42	Certification, recordkeeping and public notification requirements.			X		Facility
<b>Subpart F - Recycling and Emissions Reduction</b>						
82.154	Prohibitions.		X			Facility
82.156	Required practice.		X			Facility
82.158	Standards for recycling and recovery equipment.		X			Facility



EPA Rule	EPA Title	Facility Emission Unit Identification Number(s)	Applicable Requirement		Comments/Discussion	Potential Applicability
			Yes	No/NA		
82.160	Approved equipment testing organizations.		X			Facility
82.161	Technician certification.		X			Facility
82.162	Certification by owners of recovery and recycling equipment.		X			Facility
82.164	Reclaimer certification.		X			Facility
82.166(k)	Reporting and recordkeeping requirements for owners/operators.		X			Facility



Consulting • Engineering • Remediation

May 8, 1996

P.O. Box 13206  
Tallahassee, FL 32317-3206(904) 385-0808  
FAX(904) 385-5457

Mr. Bob Hicks  
Orlando Utilities Commission  
500 South Orange Avenue  
Orlando, FL 32802

**REVISED**

**Subject - Regulatory Applicability for Indian River Plant**  
ENSR Project No. 9420-030 Orlando P.O. Ref. C 96802 E

Dear Bob:

ENSR is providing a **Revised Determination of Regulatory Applicable** for the Indian River Plant. The determination is based upon the following information:

<u>UNIT</u>	<u>INSTAL</u>	<u>MW</u>	<u>MMBTU/HR</u>	<u>MMBTU/HR</u>	<u>BACT</u>	<u>NSPS</u>
BOILER 1	1959	87	832.2 OIL	865.5 NG	NO	NO
BOILER 2	1968	192	2016.5 OIL	2248.7 NG	NO	NO
BOILER 3	1970	328	3048.8 OIL	3208.5 NG	NO	NO
CT A & B	1990	35	445 OIL	445 NG	YES	SUBPART GG
CT C & D	1991	129	1346 OIL	1354 NG	YES	SUBPART GG
LIME SILO	1992	-	WATER	TREAT	NO	NO

**Facility Regulatory Applicability - the Indian River Plant as a whole is subject to the "Title V Core List of Rules dated 3-25-96" except 40 CFR 61 (NESHAP), 40 CFR 82 (ozone, etc.), 62-296.400 (incinerators) and 62-281 (motor vehicle a/c)**

- 40 CFR 60.1 Applicability
- 40 CFR 60.2 Definitions
- 40 CFR 60.3 Units and Abbreviations
- 40 CFR 60.4 Address
- 40 CFR 60.5 Determination of Construction or Modification
- 40 CFR 60.6 Review of Plans
- 40 CFR 60.7 Notification and Recordkeeping
- 40 CFR 60.8 Performance Tests
- 40 CFR 60.9 Availability of Information
- 40 CFR 60.10 State Authority
- 40 CFR 60.11 Compliance with Standards and Maintenance Requirements
- 40 CFR 60.12 Circumvention
- 40 CFR 60.13 Monitoring Requirements
- 40 CFR 60.14 Modification
- 40 CFR 60.15 Reconstruction
- 40 CFR 60.16 Priority List
- 40 CFR 60.17 Incorporation by Reference



Page 2  
Bob Hicks

- 62-210.700 Excess Emissions
- 62-212.300 General Preconstruction Review (future major modifications)
- 62-212.400 PSD (future major modifications)
- 62-213.415 Trading of Emissions within a Source
- 62-213.450 EPA and Affected States Review
- 62-296.600(5) Record Keeping/Reporting (Permit Condition)
- 62-297.100 Monitoring Purpose/Scope
- 62-297.310 General Test Requirements
- 62-297.401 Compliance Test Methods
- 62-297.440 Supplementary Test (ASTM, EPA Reports, etc.)
- 62-297.620 Exceptions and Approval of Alternate Procedures

**Emission Unit Regulatory Applicability - Boilers 1, 2 and 3** are subject to the following additional state and federal regulations:

- 62-213.413 Fast Track Permitting for Acid Rain Sources
- 62-214 Requirements for Sources Subject to Acid Rain Program
- 62-296.405 Fossil Fuel Steam Generators >250 MMBtu/hr heat input

**Emission Unit Regulatory Applicability - Combustion Turbines A, B, C and D** are subject to the following additional state and federal regulations:

- Subpart GG Standards for Performance for Stationary Gas Turbines
- 62-214 Requirements for Sources Subject to Acid Rain Program (CT C & D only)

**Emission Unit Regulatory Applicability - LIME SILO** is subject to the following additional state and federal regulations:

- 62-296.320 (2) No Objectionable Odors
- 62-296.414 Concrete Batching Plants (permit)

Please review this list to assure that I have included only the regulations which are appropriate, have not omitted any applicable regulations and include any comments on the above determination by 4/26/96.

Sincerely,

Preston Lewis, P.E.  
Senior Project Manager

cc. Barry Andrews and Keith Field

**APPENDIX L**

**EMISSIONS INVENTORY**

**SUPPORTING CALCULATIONS**

OUC - Indian River

MMBtu := 1000000·BTU  
Btu := BTU  
bbl := 42·gal  
MMscf := 1000000·scf

cfm :=  $\frac{\text{ft}^3}{\text{min}}$

gr :=  $\frac{\text{lb}}{7000}$

tpy :=  $\frac{\text{ton}}{\text{yr}}$

scf :=  $\text{ft}^3$

ppm :=  $\frac{1}{1000000}$

tph :=  $\frac{\text{ton}}{\text{hr}}$

## OUC - Indian River

## Boiler 1, Emission Unit 01

## Permit Restrictions:

Btu Oil: 832.2 MMBtu/hr

Btu Gas: 865.5 MMBtu/hr

Operating Hours: 8400 hr/yr

Up to 1% of total Btu input may be  
from On-spec Used Oil

PM Steady state: 0.1 lb/MMBtu

PM Soot Blowing: 0.3 lb/MMBtu for &lt; 3 hrs

SO2: 2.76 lb/MMBtu

$$\text{OilBtu} := 6.0 \cdot \frac{\text{MMBtu}}{\text{bbl}}$$

$$\text{GasBtu} := 1000 \cdot \frac{\text{Btu}}{\text{scf}}$$

## PM Emissions (from permit)

## Max Hourly

$$\text{PM} := 0.3 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 832.2 \cdot \frac{\text{MMBtu}}{\text{hr}} \quad \text{PM} = 249.7 \cdot \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{PM} := 0.1 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 832.2 \cdot \frac{\text{MMBtu}}{\text{hr}} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} \quad \text{PM} = 349.5 \cdot \text{tpy}$$

## PM10 Emissions

AP42, 5th ed., indicates while burning residual oil, PM10 makes up about 71% of uncontrolled PM emissions

## Max Hourly

$$\text{PM10} := 0.71 \cdot 0.3 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 832.2 \cdot \frac{\text{MMBtu}}{\text{hr}} \quad \text{PM10} = 177.3 \cdot \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{PM10} := 0.71 \cdot 0.1 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 832.2 \cdot \frac{\text{MMBtu}}{\text{hr}} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} \quad \text{PM10} = 248.2 \cdot \text{tpy}$$

## OUC - Indian River

## SO2 Emissions (from permit)

## Max Hourly

$$\text{SO}_2 := 2.75 \frac{\text{lb}}{\text{MMBtu}} \cdot 832.2 \frac{\text{MMBtu}}{\text{hr}} \quad \text{SO}_2 = 2288.5 \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{SO}_2 := 2.75 \frac{\text{lb}}{\text{MMBtu}} \cdot 832.2 \frac{\text{MMBtu}}{\text{hr}} \cdot 8400 \frac{\text{hr}}{\text{yr}} \quad \text{SO}_2 = 9611.9 \cdot \text{tpy}$$

## NOx Emissions (AP42, 5th ed.)

## Max Hourly

$$\text{GasHour} := 865.5 \frac{\text{MMBtu}}{\text{hr}} \cdot \frac{1}{\text{GasBtu}} \quad \text{GasHour} = 8.655 \cdot 10^5 \frac{\text{scf}}{\text{hr}}$$

$$\text{NO}_x := 275 \frac{\text{lb}}{\text{MMscf}} \cdot \text{GasHour} \quad \text{NO}_x = 238.012 \frac{\text{lb}}{\text{hr}} \quad (\text{Tangential Fire})$$

$$\text{OilHour} := 832.2 \frac{\text{MMBtu}}{\text{hr}} \cdot \frac{1}{\text{OilBtu}} \quad \text{OilHour} = 5825.4 \frac{\text{gal}}{\text{hr}}$$

$$\text{NO}_x := 67 \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot \text{OilHour} \quad \text{NO}_x = 390.302 \frac{\text{lb}}{\text{hr}} \quad \text{Higher Potential}$$

## Potential Annual

$$8400 \frac{\text{hr}}{\text{yr}} \cdot \text{NO}_x = 1639.267 \cdot \text{tpy}$$

## CO Emissions (AP42, 5th ed.)

## Max Hourly

$$\text{CO} := 5 \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot \text{OilHour} \quad \text{CO} = 29.127 \frac{\text{lb}}{\text{hr}}$$

$$\text{CO} := 40 \frac{\text{lb}}{\text{MMscf}} \cdot \text{GasHour} \quad \text{CO} = 34.62 \frac{\text{lb}}{\text{hr}} \quad \text{Higher Potential}$$

## Potential Annual

$$8400 \frac{\text{hr}}{\text{yr}} \cdot \text{CO} = 145.404 \cdot \text{tpy}$$

## OUC - Indian River

## Non-Methane TOC Emissions (AP-42, 5th ed.)

## Max Hourly

$$\text{TOC} := 0.83 \cdot 1.7 \cdot \frac{\text{lb}}{\text{MMscf}} \cdot \text{GasHour} \quad \text{TOC} = 1.221 \cdot \frac{\text{lb}}{\text{hr}}$$

$$\text{TOC} := 0.76 \cdot \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot \text{OilHour} \quad \text{TOC} = 4.427 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{Higher Potential}$$

## Potential Annual

$$\text{TOC} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 18.595 \cdot \text{tpy}$$

## Formaldehyde Emissions (AP42, 5th ed.), range 161 to 405 lb/10E12 Btu

## Max Hourly

$$\text{HCOH} := 405 \cdot \frac{\text{lb}}{10^{12} \cdot \text{Btu}} \cdot 832.2 \cdot \frac{\text{MMBtu}}{\text{hr}} \quad \text{HCOH} = 0.337 \cdot \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{HCOH} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 1.416 \cdot \text{tpy}$$



## OUC - Indian River

Trace Elements (AP42, 5th ed.), using high end of range

	Max Hourly	Annual Potential
Sb :- $46 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Sb} = 0.038 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Sb} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.161 \cdot \text{tpy}$
As :- $114 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{As} = 0.095 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{As} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.398 \cdot \text{tpy}$
Ba :- $4.2 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Ba} = 0.003 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Ba} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.015 \cdot \text{tpy}$
Cd :- $211 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Cd} = 0.176 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Cd} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.737 \cdot \text{tpy}$
Cr :- $128 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Cr} = 0.107 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Cr} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.447 \cdot \text{tpy}$
Co :- $121 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Co} = 0.101 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Co} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.423 \cdot \text{tpy}$
Pb :- $194 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Pb} = 0.161 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Pb} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.678 \cdot \text{tpy}$
Mn :- $74 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Mn} = 0.062 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Mn} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.259 \cdot \text{tpy}$
Hg :- $32 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Hg} = 0.027 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Hg} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.112 \cdot \text{tpy}$
Ni :- $2330 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Ni} = 1.939 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Ni} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 8.144 \cdot \text{tpy}$
Se :- $38 \cdot \text{lb} \cdot 10^{12} \cdot \text{Btu}^{-1} \cdot 832.2 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Se} = 0.032 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Se} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.133 \cdot \text{tpy}$

Contribution of metals from Used Oil, per correspondence from OUC 5/23/95

$$\text{Metals} :- 100 \cdot \text{ppm} \cdot 1\% \cdot \text{Oil} \cdot \text{Hour} \cdot 8 \cdot \frac{\text{lb}}{\text{gal}} \quad \text{Metals} = 0.047 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{Metals} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 0.196 \cdot \text{tpy}$$

Assume Metals could be primarily either Pb or Ni, add to each of Pb and Ni from above:

$$\begin{aligned} \text{Pb} & :- \text{Pb} + \text{Metals} & \text{Pb} & = 0.208 \cdot \text{lb} \cdot \text{hr}^{-1} & \text{Pb} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} & = 0.874 \cdot \text{tpy} \\ \text{Ni} & :- \text{Ni} + \text{Metals} & \text{Ni} & = 1.986 \cdot \text{lb} \cdot \text{hr}^{-1} & \text{Ni} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} & = 8.34 \cdot \text{tpy} \end{aligned}$$

Assume Maximum Cl in used oil = 1000 ppm

$$\text{HCl} :- 66 \cdot 1\% \cdot 1000 \cdot \text{ppm} \cdot 8 \cdot \frac{\text{lb}}{\text{gal}} \cdot \text{Oil} \cdot \text{Hour} \quad \text{HCl} = 30.758 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{HCl} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 129.184 \cdot \text{tpy}$$

The remaining pollutants in the AP-42 used oil table (1.11-4,5) are assigned an emission factor rating of "D", which is probably not well represented by the used oil burned by OUC, since that used oil is specifically generated by OUC. At only 1% of the total Btu input, the metals output should not be significantly affected. This is illustrated using As as an example. Also, the AP42 Used Oil tables only provide information for SMALL boilers and space heaters.

$$\text{AsU} :- 0.11 \cdot \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot 1\% \cdot \text{Oil} \cdot \text{Hour} \quad \text{AsU} = 0.006 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{As} = 0.095 \cdot \frac{\text{lb}}{\text{hr}}$$

## OUC - Indian River

## Boiler 2, Emission Unit 02

## Permit Restrictions:

Btu Oil: 2016.5 MMBtu/hr

Btu Gas: 2248.7 MMBtu/hr

Operating Hours: 8400 hr/yr

Up to 1% of total Btu Input may be  
from On-spec Used Oil

PM Steady state: 0.1 lb/MMBtu

PM Soot Blowing: 0.3 lb/MMBtu for &lt; 3 hrs

SO2: 2.75 lb/MMBtu

$$\text{OilBtu} := 6.0 \cdot \frac{\text{MMBtu}}{\text{bbl}}$$

$$\text{GasBtu} := 1000 \cdot \frac{\text{Btu}}{\text{scf}}$$

## PM Emissions (from permit)

## Max Hourly

$$\text{PM} := 0.3 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 2016.5 \cdot \frac{\text{MMBtu}}{\text{hr}} \quad \text{PM} = 604.9 \cdot \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{PM} := 0.1 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 2016.5 \cdot \frac{\text{MMBtu}}{\text{hr}} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} \quad \text{PM} = 846.9 \cdot \text{tpy}$$

## PM10 Emissions

AP42, 5th ed., indicates while burning residual oil, PM10 makes up about 71% of uncontrolled PM emissions

## Max Hourly

$$\text{PM10} := 0.71 \cdot 0.3 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 2016.5 \cdot \frac{\text{MMBtu}}{\text{hr}} \quad \text{PM10} = 429.5 \cdot \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{PM10} := 0.71 \cdot 0.1 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 2016.5 \cdot \frac{\text{MMBtu}}{\text{hr}} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} \quad \text{PM10} = 601.3 \cdot \text{tpy}$$

## OUC - Indian River

SO<sub>2</sub> Emissions (from permit)

## Max Hourly

$$\text{SO}_2 = 2.75 \frac{\text{lb}}{\text{MMBtu}} \cdot 2016.5 \frac{\text{MMBtu}}{\text{hr}} \quad \text{SO}_2 = 5545.4 \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{SO}_2 = 2.75 \frac{\text{lb}}{\text{MMBtu}} \cdot 2016.5 \frac{\text{MMBtu}}{\text{hr}} \cdot 8400 \frac{\text{hr}}{\text{yr}} \quad \text{SO}_2 = 23290.6 \cdot \text{tpy}$$

NO<sub>x</sub> Emissions (AP42, 5th ed.)

## Max Hourly

$$\text{GasHour} = 2248.7 \frac{\text{MMBtu}}{\text{hr}} \cdot \frac{1}{\text{GasBtu}} \quad \text{GasHour} = 2.249 \cdot 10^6 \frac{\text{scf}}{\text{hr}}$$

$$\text{NO}_x = 275 \frac{\text{lb}}{\text{MMscf}} \cdot \text{GasHour} \quad \text{NO}_x = 618.392 \frac{\text{lb}}{\text{hr}} \quad (\text{Tangential Fire})$$

$$\text{OilHour} = 2016.5 \frac{\text{MMBtu}}{\text{hr}} \cdot \frac{1}{\text{OilBtu}} \quad \text{OilHour} = 14115.5 \frac{\text{gal}}{\text{hr}}$$

$$\text{NO}_x = 67 \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot \text{OilHour} \quad \text{NO}_x = 945.738 \frac{\text{lb}}{\text{hr}} \quad \text{Higher Potential}$$

## Potential Annual

$$8400 \frac{\text{hr}}{\text{yr}} \cdot \text{NO}_x = 3972.101 \cdot \text{tpy}$$

## CO Emissions (AP42, 5th ed.)

## Max Hourly

$$\text{CO} = 5 \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot \text{OilHour} \quad \text{CO} = 70.578 \frac{\text{lb}}{\text{hr}}$$

$$\text{CO} = 40 \frac{\text{lb}}{\text{MMscf}} \cdot \text{GasHour} \quad \text{CO} = 89.948 \frac{\text{lb}}{\text{hr}} \quad \text{Higher Potential}$$

## Potential Annual

$$8400 \frac{\text{hr}}{\text{yr}} \cdot \text{CO} = 377.782 \cdot \text{tpy}$$

## OUC - Indian River

## Non-Methane TOC Emissions (AP-42, 5th ed.)

## Max Hourly

$$\text{TOC} = 0.83 \cdot 1.7 \cdot \frac{\text{lb}}{\text{MMscf}} \cdot \text{GasHour}$$

$$\text{TOC} = 3.173 \cdot \frac{\text{lb}}{\text{hr}}$$

$$\text{TOC} = 0.76 \cdot \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot \text{OilHour}$$

$$\text{TOC} = 10.728 \cdot \frac{\text{lb}}{\text{hr}}$$

Higher Potential

## Potential Annual

$$\text{TOC} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 45.057 \cdot \text{tpy}$$

## Formaldehyde Emissions (AP42, 5th ed.), range 181 to 405 lb/10E12 Btu

## Max Hourly

$$\text{HCOH} = 405 \cdot \frac{\text{lb}}{10^{12} \cdot \text{Btu}} \cdot 2016.5 \cdot \frac{\text{MMBtu}}{\text{hr}}$$

$$\text{HCOH} = 0.817 \cdot \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{HCOH} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 3.43 \cdot \text{tpy}$$

## OUC - Indian River

Trace Elements (AP42, 5th ed.), using high end of range

	Max Hourly	Annual Potential
Sb :- $46 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Sb} = 0.093 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Sb} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.39 \cdot \text{tpy}$
As :- $114 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{As} = 0.23 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{As} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.965 \cdot \text{tpy}$
Be :- $4.2 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Be} = 0.008 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Be} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.036 \cdot \text{tpy}$
Cd :- $211 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Cd} = 0.425 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Cd} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 1.787 \cdot \text{tpy}$
Cr :- $128 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Cr} = 0.258 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Cr} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 1.084 \cdot \text{tpy}$
Co :- $121 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Co} = 0.244 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Co} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 1.025 \cdot \text{tpy}$
Pb :- $194 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Pb} = 0.391 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Pb} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 1.643 \cdot \text{tpy}$
Mn :- $74 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Mn} = 0.149 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Mn} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.627 \cdot \text{tpy}$
Hg :- $32 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Hg} = 0.065 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Hg} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.271 \cdot \text{tpy}$
Ni :- $2330 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Ni} = 4.698 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Ni} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 19.733 \cdot \text{tpy}$
Se :- $38 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 2016.5 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Se} = 0.077 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Se} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.322 \cdot \text{tpy}$

Contribution of metals from Used Oil, per correspondence from OUC 5/23/95

$$\text{Metals} :- 100 \cdot \text{ppm} \cdot 1\% \cdot \text{OilHour} \cdot 8 \cdot \frac{\text{lb}}{\text{gal}} \quad \text{Metals} = 0.113 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{Metals} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 0.474 \cdot \text{tpy}$$

Assume Metals could be primarily either Pb or Ni, add to each of Pb and Ni from above:

$$\text{Pb} :- \text{Pb} + \text{Metals} \quad \text{Pb} = 0.504 \cdot \text{lb} \cdot \text{hr}^{-1} \quad \text{Pb} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 2.117 \cdot \text{tpy}$$

$$\text{Ni} :- \text{Ni} + \text{Metals} \quad \text{Ni} = 4.811 \cdot \text{lb} \cdot \text{hr}^{-1} \quad \text{Ni} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 20.208 \cdot \text{tpy}$$

Assume Maximum Cl in used oil = 1000 ppm

$$\text{HCl} :- 66 \cdot 1\% \cdot 1000 \cdot \text{ppm} \cdot 8 \cdot \frac{\text{lb}}{\text{gal}} \cdot \text{OilHour} \quad \text{HCl} = 74.53 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{HCl} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 313.025 \cdot \text{tpy}$$

The remaining pollutants in the AP-42 used oil table (1.11-4,5) are assigned an emission factor rating of "D", which is probably not well represented by the used oil burned by OUC, since that used oil is specifically generated by OUC. At only 1% of the total Btu input, the metals output should not be significantly affected. This is illustrated using As as an example. Also, the AP42 Used Oil tables only provide information for SMALL boilers and space heaters.

$$\text{AsU} :- 0.11 \cdot \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot 1\% \cdot \text{OilHour} \quad \text{AsU} = 0.016 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{As} = 0.23 \cdot \frac{\text{lb}}{\text{hr}}$$

## OUC - Indian River

## Boiler 3, Emission Unit 03

## Permit Restrictions:

Btu Oil: 3048.8 MMBtu/hr

PM Steady state: 0.1 lb/MMBtu

Btu Gas: 3208.5 MMBtu/hr

PM Soot Blowing: 0.3 lb/MMBtu for &lt; 3 hrs

Operating Hours: 8400 hr/yr

SO<sub>2</sub>: 2.75 lb/MMBtuUp to 1% of total Btu Input may be  
from On-spec Used Oil

$$\text{Oil Btu} := 6.0 \frac{\text{MMBtu}}{\text{bbl}}$$

$$\text{Gas Btu} := 1000 \frac{\text{Btu}}{\text{scf}}$$

## PM Emissions (from permit)

## Max Hourly

$$\text{PM} := 0.3 \frac{\text{lb}}{\text{MMBtu}} \cdot 3048.8 \frac{\text{MMBtu}}{\text{hr}} \quad \text{PM} = 914.6 \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{PM} := 0.1 \frac{\text{lb}}{\text{MMBtu}} \cdot 3048.8 \frac{\text{MMBtu}}{\text{hr}} \cdot 8400 \frac{\text{hr}}{\text{yr}} \quad \text{PM} = 1.3 \cdot 10^3 \text{ tpy}$$

## PM10 Emissions

AP42, 5th ed., indicates while burning residual oil, PM10 makes up about 71% of uncontrolled PM emissions

## Max Hourly

$$\text{PM}_{10} := 0.71 \cdot 0.3 \frac{\text{lb}}{\text{MMBtu}} \cdot 3048.8 \frac{\text{MMBtu}}{\text{hr}} \quad \text{PM}_{10} = 649.4 \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{PM}_{10} := 0.71 \cdot 0.1 \frac{\text{lb}}{\text{MMBtu}} \cdot 3048.8 \frac{\text{MMBtu}}{\text{hr}} \cdot 8400 \frac{\text{hr}}{\text{yr}} \quad \text{PM}_{10} = 909.2 \text{ tpy}$$

## OUC - Indian River

SO<sub>2</sub> Emissions (from permit)

## Max Hourly

$$\text{SO}_2 := 2.75 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 3048.8 \cdot \frac{\text{MMBtu}}{\text{hr}} \quad \text{SO}_2 = 8384.2 \cdot \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{SO}_2 := 2.75 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot 3048.8 \cdot \frac{\text{MMBtu}}{\text{hr}} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} \quad \text{SO}_2 = 35213.6 \cdot \text{tpy}$$

NO<sub>x</sub> Emissions (AP42, 5th ed.)

## Max Hourly

$$\text{GasHour} := 3208.5 \cdot \frac{\text{MMBtu}}{\text{hr}} \cdot \frac{1}{\text{GasBtu}} \quad \text{GasHour} = 3.209 \cdot 10^6 \cdot \frac{\text{scf}}{\text{hr}}$$

$$\text{NO}_x := 275 \cdot \frac{\text{lb}}{\text{MMscf}} \cdot \text{GasHour} \quad \text{NO}_x = 882.337 \cdot \frac{\text{lb}}{\text{hr}} \quad (\text{Tangential Fire})$$

$$\text{OilHour} := 3048.8 \cdot \frac{\text{MMBtu}}{\text{hr}} \cdot \frac{1}{\text{OilBtu}} \quad \text{OilHour} = 21341.6 \cdot \frac{\text{gal}}{\text{hr}}$$

$$\text{NO}_x := 67 \cdot \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot \text{OilHour} \quad \text{NO}_x = 1429.887 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{Higher Potential}$$

## Potential Annual

$$8400 \cdot \frac{\text{hr}}{\text{yr}} \cdot \text{NO}_x = 6005.525 \cdot \text{tpy}$$

## CO Emissions (AP42, 5th ed.)

## Max Hourly

$$\text{CO} := 5 \cdot \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot \text{OilHour} \quad \text{CO} = 106.708 \cdot \frac{\text{lb}}{\text{hr}}$$

$$\text{CO} := 40 \cdot \frac{\text{lb}}{\text{MMscf}} \cdot \text{GasHour} \quad \text{CO} = 128.34 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{Higher Potential}$$

## Potential Annual

$$8400 \cdot \frac{\text{hr}}{\text{yr}} \cdot \text{CO} = 539.028 \cdot \text{tpy}$$

## OUC - Indian River

## Non-Methane TOC Emissions (AP-42, 5th ed.)

## Max Hourly

$$\text{TOC} := 0.83 \cdot 1.7 \cdot \frac{\text{lb}}{\text{MMscf}} \cdot \text{GasHour} \quad \text{TOC} = 4.527 \cdot \frac{\text{lb}}{\text{hr}}$$

$$\text{TOC} := 0.76 \cdot \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot \text{OilHour} \quad \text{TOC} = 16.22 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{Higher Potential}$$

## Potential Annual

$$\text{TOC} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 68.122 \cdot \text{tpy}$$

## Formaldehyde Emissions (AP42, 5th ed.), range 161 to 405 lb/10E12 Btu

## Max Hourly

$$\text{HCOH} := 405 \cdot \frac{\text{lb}}{10^{12} \cdot \text{Btu}} \cdot 3048.8 \cdot \frac{\text{MMBtu}}{\text{hr}} \quad \text{HCOH} = 1.235 \cdot \frac{\text{lb}}{\text{hr}}$$

## Potential Annual

$$\text{HCOH} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 5.186 \cdot \text{tpy}$$



## OUC - Indian River

Trace Elements (AP42, 5th ed.), using high end of range

	Max Hourly	Annual Potential
Sb :- $46 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Sb} = 0.14 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Sb} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.589 \cdot \text{tpy}$
As :- $114 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{As} = 0.348 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{As} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 1.46 \cdot \text{tpy}$
Bc :- $4.2 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Bc} = 0.013 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Bc} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.054 \cdot \text{tpy}$
Cd :- $211 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Cd} = 0.643 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Cd} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 2.702 \cdot \text{tpy}$
Cr :- $128 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Cr} = 0.39 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Cr} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 1.639 \cdot \text{tpy}$
Co :- $121 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Co} = 0.369 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Co} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 1.549 \cdot \text{tpy}$
Pb :- $194 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Pb} = 0.591 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Pb} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 2.484 \cdot \text{tpy}$
Mn :- $74 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Mn} = 0.226 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Mn} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.948 \cdot \text{tpy}$
Hg :- $32 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Hg} = 0.098 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Hg} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.41 \cdot \text{tpy}$
Ni :- $2330 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Ni} = 7.104 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Ni} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 29.836 \cdot \text{tpy}$
Se :- $38 \cdot \text{lb} \cdot 10^{-12} \cdot \text{Btu}^{-1} \cdot 3048.8 \cdot \text{MMBtu} \cdot \text{hr}^{-1}$	$\text{Se} = 0.116 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Se} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.487 \cdot \text{tpy}$

Contribution of metals from Used Oil, per correspondence from OUC 5/23/95

$$\text{Metals} :- 100 \cdot \text{ppm} \cdot 1\% \cdot \text{OilHour} \cdot 8 \cdot \frac{\text{lb}}{\text{gal}} \quad \text{Metals} = 0.171 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{Metals} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 0.717 \cdot \text{tpy}$$

Assume Metals could be primarily either Pb or Ni, add to each of Pb and Ni from above:

$$\begin{aligned} \text{Pb} & :- \text{Pb} + \text{Metals} & \text{Pb} & = 0.762 \cdot \text{lb} \cdot \text{hr}^{-1} & \text{Pb} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} & = 3.201 \cdot \text{tpy} \\ \text{Ni} & :- \text{Ni} + \text{Metals} & \text{Ni} & = 7.274 \cdot \text{lb} \cdot \text{hr}^{-1} & \text{Ni} \cdot 8400 \cdot \text{hr} \cdot \text{yr}^{-1} & = 30.553 \cdot \text{tpy} \end{aligned}$$

Assume Maximum Cl in used oil = 1000 ppm

$$\text{HCl} :- 66 \cdot 1\% \cdot 1000 \cdot \text{ppm} \cdot 8 \cdot \frac{\text{lb}}{\text{gal}} \cdot \text{OilHour} \quad \text{HCl} = 112.684 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{HCl} \cdot 8400 \cdot \frac{\text{hr}}{\text{yr}} = 473.271 \cdot \text{tpy}$$

The remaining pollutants in the AP-42 used oil table (1.11-4,5) are assigned an emission factor rating of "D", which is probably not well represented by the used oil burned by OUC, since that used oil is specifically generated by OUC. At only 1% of the total Btu input, the metals output should not be significantly affected. This is illustrated using As as an example. Also, the AP42 Used Oil tables only provide information for SMALL boilers and space heaters.

$$\text{AsU} :- 0.11 \cdot \frac{\text{lb}}{1000 \cdot \text{gal}} \cdot 1\% \cdot \text{OilHour} \quad \text{AsU} = 0.023 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{As} = 0.348 \cdot \frac{\text{lb}}{\text{hr}}$$

## OUC - Indian River

Lime Storage Silo, Emission Unit 08, PM emissions = PM10 emissions:

## Permit Restrictions:

Load Rate 10 tph

Load Time 2 hr/day (Would like to change to 4 hr/day)

Per OUC, Usage = 80 tpy; ACFM determined by truck, @35 lb/scf per lime company

$$\text{SCFM} := \frac{1 \cdot \text{scf} \cdot 2000 \cdot \text{lb} \cdot 10 \cdot \text{ton}}{35 \cdot \text{lb} \cdot \text{ton}} \cdot \frac{\text{hr}}{60 \cdot \text{min}} \quad \text{SCFM} = 9.524 \cdot \text{cfm}$$

$$\text{PM} := 0.02 \cdot \frac{\text{gr}}{\text{scf}} \cdot \text{SCFM} \quad \text{PM} = 0.002 \cdot \frac{\text{lb}}{\text{hr}}$$

$$\text{LoadTime} := 80 \cdot \frac{\text{tpy}}{10 \cdot \text{tph}} \quad \text{LoadTime} = 8 \cdot \frac{\text{hr}}{\text{yr}} \quad \text{PM} \cdot 8760 \cdot \frac{\text{hr}}{\text{yr}} = 0.007 \cdot \text{tpy} \quad \text{Max Annual}$$

$$\text{PM} \cdot 8 \cdot \frac{\text{hr}}{\text{yr}} = 6.531 \cdot 10^{-6} \cdot \text{tpy} \quad \text{Estimated Annual}$$

Potential Emissions:

$$\text{PM} \cdot 2 \cdot \frac{\text{hr}}{\text{day}} \cdot 365 \cdot \frac{\text{day}}{\text{yr}} = 0.001 \cdot \text{tpy}$$

This should be an insignificant source, with or without permit restrictions on operating hours.

## OUC - Indian River

Combustion Turbines A, B (each), Emission Units 04 (A); 05 (B)

## Permit Restrictions:

$$\text{OP\_HOURS} := 8760 \frac{\text{hr}}{\text{yr}} \quad \text{CT\_Btu} := 445 \frac{\text{MMBtu}}{\text{hr}} \quad @ 59 \text{ F}$$

$$\text{Gas:} \quad \text{NOx} := 75.1 \frac{\text{lb}}{\text{hr}} \quad \text{NOx} \cdot \text{OP\_HOURS} = 328.9 \cdot \text{tpy}$$

$$\text{Oil:} \quad \text{NOx} := 118.3 \frac{\text{lb}}{\text{hr}} \quad \text{NOx} \cdot \text{OP\_HOURS} = 518.2 \cdot \text{tpy}$$

$$\text{Gas:} \quad \text{SO}_2 := 0.34 \frac{\text{lb}}{\text{hr}} \quad \text{SO}_2 \cdot \text{OP\_HOURS} = 1.5 \cdot \text{tpy}$$

$$\text{Oil:} \quad \text{SO}_2 := 142.7 \frac{\text{lb}}{\text{hr}} \quad \text{SO}_2 \cdot \text{OP\_HOURS} = 625 \cdot \text{tpy}$$

Although the following are "tabulated for PSD and Inventory purposes" in the latest permit, but were max. allowables in previous edition of permit, based on BACT.

$$\text{Gas:} \quad \text{CO} := 10 \frac{\text{lb}}{\text{hr}} \quad \text{CO} \cdot \text{OP\_HOURS} = 43.8 \cdot \text{tpy}$$

$$\text{Oil:} \quad \text{CO} := 10.1 \frac{\text{lb}}{\text{hr}} \quad \text{CO} \cdot \text{OP\_HOURS} = 44.2 \cdot \text{tpy}$$

$$\text{Gas:} \quad \text{PM} := 2.5 \frac{\text{lb}}{\text{hr}} \quad \text{PM} \cdot \text{OP\_HOURS} = 10.9 \cdot \text{tpy}$$

$$\text{Oil:} \quad \text{PM} := 10 \frac{\text{lb}}{\text{hr}} \quad \text{PM} \cdot \text{OP\_HOURS} = 43.8 \cdot \text{tpy}$$

$$\text{Gas:} \quad \text{PM}_{10} := 2.5 \frac{\text{lb}}{\text{hr}} \quad \text{PM}_{10} \cdot \text{OP\_HOURS} = 10.9 \cdot \text{tpy}$$

$$\text{Oil:} \quad \text{PM}_{10} := 10 \frac{\text{lb}}{\text{hr}} \quad \text{PM}_{10} \cdot \text{OP\_HOURS} = 43.8 \cdot \text{tpy}$$

$$\text{Gas:} \quad \text{VOC} := 4 \frac{\text{lb}}{\text{hr}} \quad \text{VOC} \cdot \text{OP\_HOURS} = 17.5 \cdot \text{tpy}$$

$$\text{Oil:} \quad \text{VOC} := 4 \frac{\text{lb}}{\text{hr}} \quad \text{VOC} \cdot \text{OP\_HOURS} = 17.5 \cdot \text{tpy}$$

$$\text{Oil:} \quad \text{H}_2\text{SO}_4 := 10 \frac{\text{lb}}{\text{hr}} \quad \text{H}_2\text{SO}_4 := 44.0 \cdot \text{tpy}$$

$$\text{Oil:} \quad \text{Bc} := 0.0001 \frac{\text{lb}}{\text{hr}} \quad \text{Bc} := 0.0005 \cdot \text{tpy}$$

## OUC - Indian River

From AP-42, 5th ed. (CTs A, B cont'd)

HCOH, only info is for SCR with water injection:

$$\text{HCOH} = 0.0027 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot \text{CT\_Btu} \quad \text{HCOH} = 1.2 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{HCOH} = 5.3 \cdot \text{tpy}$$

Trace Elements, HAPS, not otherwise restricted by permit, distillate-oil fired:

Sb :- $2.2 \cdot 10^{-5} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	Sb = $0.01 \cdot \text{lb} \cdot \text{hr}^{-1}$	Sb = $0.043 \cdot \text{tpy}$
As :- $4.9 \cdot 10^{-6} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	As = $0.002 \cdot \text{lb} \cdot \text{hr}^{-1}$	As = $0.01 \cdot \text{tpy}$
Cd :- $4.2 \cdot 10^{-6} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	Cd = $0.002 \cdot \text{lb} \cdot \text{hr}^{-1}$	Cd = $0.008 \cdot \text{tpy}$
Cr - $4.7 \cdot 10^{-5} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	Cr = $0.021 \cdot \text{lb} \cdot \text{hr}^{-1}$	Cr = $0.092 \cdot \text{tpy}$
Co :- $9.1 \cdot 10^{-6} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	Co = $0.004 \cdot \text{lb} \cdot \text{hr}^{-1}$	Co = $0.018 \cdot \text{tpy}$
Pb - $5.8 \cdot 10^{-5} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	Pb = $0.026 \cdot \text{lb} \cdot \text{hr}^{-1}$	Pb = $0.113 \cdot \text{tpy}$
Mn - $3.4 \cdot 10^{-4} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	Mn = $0.151 \cdot \text{lb} \cdot \text{hr}^{-1}$	Mn = $0.663 \cdot \text{tpy}$
Hg :- $9.1 \cdot 10^{-7} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	Hg = $0 \cdot \text{lb} \cdot \text{hr}^{-1}$	Hg = $0.002 \cdot \text{tpy}$
Ni :- $1.2 \cdot 10^{-3} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	Ni = $0.534 \cdot \text{lb} \cdot \text{hr}^{-1}$	Ni = $2.34 \cdot \text{tpy}$
P :- $3.0 \cdot 10^{-4} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	P = $0.133 \cdot \text{lb} \cdot \text{hr}^{-1}$	P = $0.585 \cdot \text{tpy}$
Se :- $5.3 \cdot 10^{-6} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu}$	Se = $0.002 \cdot \text{lb} \cdot \text{hr}^{-1}$	Se = $0.01 \cdot \text{tpy}$

## OUC - Indian River

Combustion Turbines C, D (each), Emission Units 06 (C); 07 (D)

## Permit Restrictions:

$$\begin{aligned} \text{OP\_HOURS} & := 4380 \frac{\text{hr}}{\text{yr}} & \text{CT\_Btu\_Gas} & := 1354 \frac{\text{MMBtu}}{\text{hr}} & \text{CT\_Btu\_Oil} & := 1346 \frac{\text{MMBtu}}{\text{hr}} \\ \text{MaxFO} & := 10282 \frac{\text{gal}}{\text{hr}} & \text{OP\_HOURS\_FO} & := 2190 \frac{\text{hr}}{\text{yr}} \\ \text{MaxFO} \cdot \text{OP\_HOURS\_FO} & = 22517580 \frac{\text{gal}}{\text{yr}} \end{aligned}$$

## Worst case pollutants operating scenarios:

NOX := 801.8 tpy	(Gas & Oil)	$506 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 28.843 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)
SO2 := 954.1 tpy	(Gas & Oil)	$953 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 54.323 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)
PM := 246.8 tpy	(Gas & Oil)	$237 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 13.509 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)
PM10 := 246.8 tpy	(Gas & Oil)	$237 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 13.509 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)
CO := 315.5 tpy	(Gas & Oil)	$159 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 9.063 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)
VOC := 130.5 tpy	(Gas & Oil)	$112 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 6.384 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)
H2SO4 := 28.5 tpy	(Gas & Oil)	$28.5 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 1.625 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)
Be := 0.01 tpy	(Gas & Oil)	$0.01 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.001 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)
Hg := 0.01 tpy	(Gas & Oil)	$0.01 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.001 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)
Pb := 0.08 tpy	(Gas & Oil)	$0.08 \cdot \text{tpy} \cdot 2190 \cdot \text{hr} \cdot \text{yr}^{-1} = 0.005 \cdot \text{lb} \cdot \text{hr}^{-1}$	(Oil)

## OUC - Indian River

From AP-42, 5th ed. (CTs C, D cont'd)

HCOH, only Info is for SCR with water injection:

$$\text{HCOH} := 0.0027 \cdot \frac{\text{lb}}{\text{MMBtu}} \cdot \text{CT\_Btu\_Gas} \quad \text{HCOH} = 3.7 \cdot \frac{\text{lb}}{\text{hr}} \quad \text{HCOH} \cdot 4390 \cdot \frac{\text{hr}}{\text{yr}} = 8.024 \cdot \text{tpy}$$

Trace Elements, HAPS, not otherwise restricted by permit, distillate-oil fired:

$\text{Sb} := 2.2 \cdot 10^{-5} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu\_Oil}$	$\text{Sb} = 0.03 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Sb} = 0.13 \cdot \text{tpy}$
$\text{As} := 4.9 \cdot 10^{-6} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu\_Oil}$	$\text{As} = 0.007 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{As} = 0.029 \cdot \text{tpy}$
$\text{Cd} := 4.2 \cdot 10^{-6} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu\_Oil}$	$\text{Cd} = 0.006 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Cd} = 0.025 \cdot \text{tpy}$
$\text{Cr} := 4.7 \cdot 10^{-5} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu\_Oil}$	$\text{Cr} = 0.063 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Cr} = 0.277 \cdot \text{tpy}$
$\text{Co} := 9.1 \cdot 10^{-6} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu\_Oil}$	$\text{Co} = 0.012 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Co} = 0.054 \cdot \text{tpy}$
$\text{Mn} := 3.4 \cdot 10^{-4} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu\_Oil}$	$\text{Mn} = 0.458 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Mn} = 2.006 \cdot \text{tpy}$
$\text{Ni} := 1.2 \cdot 10^{-3} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu\_Oil}$	$\text{Ni} = 1.615 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Ni} = 7.079 \cdot \text{tpy}$
$\text{P} := 3.0 \cdot 10^{-4} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu\_Oil}$	$\text{P} = 0.404 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{P} = 1.77 \cdot \text{tpy}$
$\text{Se} := 5.3 \cdot 10^{-6} \cdot \text{lb} \cdot \text{MMBtu}^{-1} \cdot \text{CT\_Btu\_Oil}$	$\text{Se} = 0.007 \cdot \text{lb} \cdot \text{hr}^{-1}$	$\text{Se} = 0.031 \cdot \text{tpy}$

## OUC - Indian River

## Unpaved Roads

$$\text{VMT} := 216540 \cdot \frac{\text{mi}}{\text{yr}} \cdot 25\% \quad \text{VMT} = 54135 \cdot \frac{\text{mi}}{\text{yr}}$$

k := 0.8 particle size multiplier, TSP. Use 0.36 for PM10 (AP-42, 4th ed.)

s := 5 silt content

S := 20 mean vehicle speed, mph

W := 5 mean vehicle weight, ton (includes some hvy eqpt + cars)

w := 5 mean number of wheels

p := 115.3 mean number days > 0.01 in. precipitation

EIF := 0% Control by wetting

For TSP,

$$E := 5.9 \cdot k \cdot \frac{s}{12} \cdot \frac{S}{30} \cdot \frac{W^{0.7}}{3} \cdot \frac{w^{0.5}}{4} \cdot \frac{365 - p}{365} \cdot \frac{\text{lb}}{\text{mi}} \quad E = 1.434 \cdot \frac{\text{lb}}{\text{mi}}$$

$$\text{VMT} \cdot E \cdot (1 - \text{Eff}) = 38.812 \cdot \text{tpy} \quad 20 \cdot \frac{\text{mi}}{\text{hr}} \cdot E \cdot (1 - \text{Eff}) = 28.678 \cdot \frac{\text{lb}}{\text{hr}}$$

For PM10, k := 0.36

$$E := 5.9 \cdot k \cdot \frac{s}{12} \cdot \frac{S}{30} \cdot \frac{W^{0.7}}{3} \cdot \frac{w^{0.5}}{4} \cdot \frac{365 - p}{365} \cdot \frac{\text{lb}}{\text{mi}} \quad E = 0.645 \cdot \frac{\text{lb}}{\text{mi}}$$

$$\text{VMT} \cdot E \cdot (1 - \text{Eff}) = 17.465 \cdot \text{tpy} \quad 20 \cdot \frac{\text{mi}}{\text{hr}} \cdot E \cdot (1 - \text{Eff}) = 12.905 \cdot \frac{\text{lb}}{\text{hr}}$$

## OUC - Indian River

## Paved Roads

$$\text{VMT} = 216540 \cdot \frac{\text{mi}}{\text{yr}} \cdot 75\% \quad \text{VMT} = 162405 \cdot \frac{\text{mi}}{\text{yr}}$$

TSP - use "local streets" lb/VMT factor, AP-42, 4th ed.

$$0.053 \cdot \frac{\text{lb}}{\text{mi}} \cdot \text{VMT} = 4.304 \cdot \text{tpy} \quad 20 \cdot \text{mph} \cdot 0.053 \cdot \frac{\text{lb}}{\text{mi}} = 1.06 \cdot \frac{\text{lb}}{\text{hr}}$$

PM10 - use "local streets" lb/VMT factor, AP-42, 4th ed.

$$0.018 \cdot \frac{\text{lb}}{\text{mi}} \cdot \text{VMT} = 1.462 \cdot \text{tpy} \quad 20 \cdot \text{mph} \cdot 0.018 \cdot \frac{\text{lb}}{\text{mi}} = 0.36 \cdot \frac{\text{lb}}{\text{hr}}$$

## Maintenance Painting Activities (Contractor Data for 1994)

Assume same VOC content as for Stanton

$$Q = 1389 \cdot \frac{\text{gal}}{\text{yr}} \cdot 1.1 \quad Q = 1527.9 \cdot \frac{\text{gal}}{\text{yr}} \quad \text{Scaled to 10\% more than 1994 for flexibility}$$

$$Q \cdot 3.5 \cdot \frac{\text{lb}}{\text{gal}} = 2.674 \cdot \text{tpy} \quad \text{based on maximum VOC content 3.5 lb/gal}$$

$$\text{Hours} = 8760 \cdot \frac{\text{hr}}{\text{yr}} \cdot \frac{8}{24} \cdot \frac{5}{7} \cdot \frac{1}{4} \quad Q \cdot 3.5 \cdot \frac{\text{lb}}{\text{gal}} \cdot \frac{1}{\text{Hours}} = 10.256 \cdot \frac{\text{lb}}{\text{hr}}$$



Indian River Potential Emission Source Inventory

E.U. Description		Status?	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	S
E.U. Description		Status?	VOC		PM		PM10			
E.U. Description		Status?	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	
		I								
		I								
		P								
1	Unit 1 boiler	S	4.43	18.6	249.7	349.5	177.3	248.2	2289	
2	Unit 2 boiler	S	10.73	45.1	604.9	846.9	429.5	601.3	5545	
3	Unit 3 boiler	S	16.22	68.1	914.6	1280	649.4	909.2	8384	
		P								
		P								
		P								
8	Lime Storage Silo	S			0.002	0.001	0.002	0.001		
4	Combustion Turbine (35 MW)	S	4	17.5	10	43.8	10	43.8	142.7	
5	Combustion Turbine (35 MW)	S	4	17.5	10	43.8	10	43.8	142.7	
7	Combustion Turbine (129 MW)	S	102.3	130.5	216.4	246.8	216.4	246.8	870.3	
6	Combustion Turbine (129 MW)	S	102.3	130.5	216.4	246.8	216.4	246.8	870.3	
		P								
		E								
		P								
		P								
		P								
		E								
		P								
		P								
	Unpaved Roads	S			28.7	38.8	12.9	17.5		
	Paved Roads	S			1.06	4.3	0.36	1.46		
		P								
		P								
		E								
		P								
		P								
	Painting applications for mainten	S	10.3	2.67						
		P								
	Totals	P	254.28	430.47	2251.762	3100.701	1722.262	2358.861	18244	









TANKS PROGRAM 2.0  
EMISSIONS REPORT - SUMMARY FORMAT  
TANK IDENTIFICATION AND PHYSICAL CHARACTERISTICS

06/01/95  
PAGE 1

Identification

Identification No.: CT Tank  
City: Titusville  
State: FL  
Company: OUC - Indian River Plant  
Type of Tank: Vertical Fixed Roof

Tank Dimensions

Shell Height (ft): 26  
Diameter (ft): 32  
Liquid Height (ft): 26  
Avg. Liquid Height (ft): 13  
Volume (gallons): 156437  
Turnovers: 700  
Net Throughput (gal/yr): 109505900

- Worst case for single tank assumes ALL No. 2 oil passes through largest tank.

Paint Characteristics

Shell Color/Shade: White/White  
Shell Condition: Good  
Roof Color/Shade: White/White  
Roof Condition: Good

Roof Characteristics

Type: Dome  
Height (ft): 4.00  
Radius (ft) (Dome Roof): 16.00  
Slope (ft/ft) (Cone Roof): 0.0000

Weather Vent Settings

Vacuum Setting (psig): -0.15  
Pressure Setting (psig): 0.15

Meteorological Data Used in Emission Calculations: Orlando, Florida

TANKS PROGRAM 2.0  
EMISSIONS REPORT - SUMMARY FORMAT  
TANK IDENTIFICATION AND PHYSICAL CHARACTERISTICS

06/12/95  
PAGE 1

Identification  
Identification No.: Tank 3  
City: Titusville  
State: FL  
Company: OUC  
Type of Tank: Vertical Fixed Roof

Fuel Oil No. 6

Worst case assumes entire throughput  
through single (largest) tank.

Tank Dimensions  
Shell Height (ft): 32  
Diameter (ft): 200  
Liquid Height (ft): 32  
Avg. Liquid Height (ft): 16  
Volume (gallons): 7521020  
Turnovers: 46  
Net Throughput (gal/yr): 348223226

Paint Characteristics  
Shell Color/Shade: White/White  
Shell Condition: Good  
Roof Color/Shade: White/White  
Roof Condition: Good

Roof Characteristics  
Type: Dome  
Height (ft): 5.00  
Radius (ft) (Dome Roof): 100.0  
Slope (ft/ft) (Cone Roof): 0.0000

Weather Vent Settings  
Vacuum Setting (psig): -0.15  
Pressure Setting (psig): 0.15

Metereological Data Used in Emission Calculations: Orlando, Florida

Annual Emissions Report

Liquid Contents	Losses (lbs.):		Total
	Standing	Withdrawal	
distillate fuel oil no. 2	33.80	730.99	764.79
Total:	33.80	730.99	764.79



TANKS PROGRAM 2.0  
 EMISSIONS REPORT - SUMMARY FORMAT  
 LIQUID CONTENTS OF STORAGE TANK

06/01/95  
 PAGE 2

Name/Component	Month	Daily Liquid Surf. Temperatures (deg F)			Liquid Bulk Temp. (deg F)		Vapor Pressures (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.	Avg.	Min.	Max.	Avg.	Min.	Max.				
Stillate fuel oil no. 2	All	74.41	68.90	79.92	72.42		0.0103	0.0087	0.0122	130.000			130.00	Option 4: A=12.1010, B=8907.0

TANKS PROGRAM 2.0  
 EMISSIONS REPORT - SUMMARY FORMAT  
 LIQUID CONTENTS OF STORAGE TANK

Structure/Component	Month	Daily Liquid Surf. Temperatures (deg F)			Liquid Bulk Temp. (deg F)	Vapor Pressures (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Residual Oil No. 6	All	120.00	114.49	125.51	72.42	0.0002	0.0002	0.0003	190.000			190.00	Option 4: A=10.1040, B=10475.0

TANKS PROGRAM 2.0  
EMISSIONS REPORT - SUMMARY FORMAT  
INDIVIDUAL TANK EMISSION TOTALS06/12/95  
PAGE 3

## Annual Emissions Report

Liquid Contents	Losses (lbs.):		Total
	Standing	Withdrawal	
Individual Oil No. 6	102.04	256.65	358.70
Total:	102.04	256.65	358.70

= 0.18 tpy

RESIDUAL OIL NO. 6

T f	40	50	60	70	80	90	100	110	120	125	130
T r	500	510	520	530	540	550	560	570	580	585	590
P	0.00002	0.00003	0.00004	0.00006	0.00009	0.00013	0.00019	0.000213	0.00025	0.000269	0.000287

10/92

Storage of Organic Liquids

TABLE 12.3-2. PROPERTIES ( $M_V$ ,  $W_{VC}$ ,  $P_{VA}$ ,  $W_L$ ) OF SELECTED PETROLEUM LIQUIDS<sup>a</sup>

Petroleum liquid	Vapor molecular weight (at 60°F) $M_V$ (lb/lb-mole)	Condensed vapor density (at 60°F) $W_{VC}$ (lb/gal)	Liquid density, lb/gal at 60°F	True vapor pressure in psi at						
				40°C	50°F	60°F	70°F	80°F	90°F	100°F
Gasoline RVP 13	62	4.9	4.9	4.7	5.7	6.9	8.3	9.9	11.7	13.8
Gasoline RVP 10	66	5.1	5.1	3.4	5.7	5.2	6.2	7.4	8.8	10.5
Gasoline RVP 7	68	5.2	5.2	2.3	2.9	3.5	4.3	5.2	6.2	7.4
Crude Oil RVP 5	50	4.5	4.5	1.8	2.3	2.8	3.4	4.0	4.8	5.7
Jet naphtha (JP-4)	80	5.4	5.4	0.8	1.0	1.3	1.6	1.9	2.4	2.7
Jet kerosene	130	6.1	6.1	0.0041	0.0060	0.0085	0.011	0.015	0.021	0.029
Distillate fuel oil No. 2	130	6.1	6.1	0.0031	0.0045	0.0074	0.0090	0.012	0.016	0.022
Residual oil No. 6	190	6.4	6.4	0.00002	0.00003	0.00004	0.00006	0.00009	0.00013	0.00019

Notes:

<sup>a</sup>References 7 and 8.

12-39

**APPENDIX M**  
**TITLE VI INFORMATION**

## TITLE VI INFORMATION

As requested in the 'Facility Supplemental Information' section the following pieces of equipment may be found at the Indian River Plant Facility, and must be included within the Title V application:

<b>EQUIPMENT</b>	<b>REFRIGERANT</b>	<b>AMOUNT</b>
Office Unit	R12	100 lbs.
Unit 1 Computer Room	R12	50 lbs.
Control Room Unit	R12	50 lbs.
Unit 3 Lab	R22	90 lbs.

Recovery Unit: National Refrigeration Products  
Model/Year: LV 8 / 1994  
Serial Number: 107339  
Certified: ARI for R12, R22, R500, R502, R134a