



4400 South State Road 7  
Ft. Lauderdale, FL 33314  
(954) 581-6606  
(954) 581-6705 Fax

A Waste Management Company

April 30, 2009

UPS# 1Z2AW7390196131219

RECEIVED

MAY 01 2009

BUREAU OF AIR REGULATION

Mr. Lennon Anderson  
Air Program Administrator  
Florida Department of Environmental Protection  
Southeast District  
400 North Congress Ave., Suite 200  
West Palm Beach, FL 33401

Re: Wheelabrator South Broward  
2009 Annual Compliance Stack Test and RATA Reports

Dear Mr. Anderson:

Please find enclosed a copy of the final compliance stack test report and the continuous emissions monitoring system certification RATA report for testing conducted on March 17-19 of this year by Clean Air Engineering, Inc.

I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this submittal. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements and information in this document are true, accurate and complete.

If there are any questions, please contact this office at (954) 581-6606.

Sincerely,

Jairaj Gosine  
Plant Manager

cc: USEPA, Region IV, Pesticides and Toxics Management Division, Air & EPCRA Enforcement Branch, Air Enforcement Section (with) UPS# 1Z2AW7390195843176

FDEP, Tallahassee, Bureau of Air Regulation, New Source Review Section, (with) UPS# 1Z2AW7390196779995

Broward County Department of Planning and Environmental Protection, Air Quality Division (with) UPS# 1Z2AW7390198352227

Chuck Faller (with)  
Ram Tewari - BCWRS (without)  
Tim Porter (without)  
Rob French - MPI (with)

JG/YR090430





Wheelabrator South Broward, Inc.  
4400 South State Road 7  
Ft. Lauderdale, FL 33314

RECEIVED

MAY 01 2009

BUREAU OF AIR REGULATION

---

**REPORT ON COMPLIANCE TESTING**

Performed for:


**WHEELABRATOR SOUTH BROWARD, INC.  
ASH HANDLING SYSTEM, LIME SILO VENTS,  
UNITS 1, 2 AND 3 SDA INLETS, FF OUTLETS AND STACKS  
FT. LAUDERDALE, FL  
VOLUME I OF II**

CleanAir Project No: 10735-4  
Revision 0: April 28, 2009

---

To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the actual emissions during the test program.

Submitted by,

  
\_\_\_\_\_  
Scott Brown  
Project Manager  
sbrown@cleanair.com  
(800) 627-0033 ext. 4544

Reviewed by,

  
\_\_\_\_\_  
Mark Roach, P.E.  
Engineering Group Technical Leader  
mroach@cleanair.com  
(800) 627-0033 ext. 4599

**REVISION HISTORY**

**REPORT ON COMPLIANCE TESTING**

***DRAFT REPORT REVISION HISTORY***

<b>Revision:</b>	<b>Date</b>	<b>Pages</b>	<b>Comments</b>
D0a	04/20/09	All	Draft version of original document.

***FINAL REPORT REVISION HISTORY***

<b>Revision:</b>	<b>Date</b>	<b>Pages</b>	<b>Comments</b>
0	04/28/09	All	Final version of original document.

**CONTENTS**

<b>1</b>	<b>PROJECT OVERVIEW .....</b>	<b>1-1</b>
	INTRODUCTION .....	1-1
	Key Project Participants .....	1-1
	Test Program Parameters.....	1-2
	TEST PROGRAM SYNOPSIS.....	1-3
	Test Schedule .....	1-3
	Table 1-1: Schedule of Activities.....	1-3
	Results Summary.....	1-4
	Table 1-2: Summary of Test Results.....	1-4
	Table 1-3: Subpart Cb Required Operating Data .....	1-5
	Table 1-4: Opacity and Fugitive Emission Test Results.....	1-5
	Discussion of Test Program .....	1-5
<b>2</b>	<b>RESULTS .....</b>	<b>2-1</b>
	Table 2-1: Unit 1 FF Outlet – Particulate and Metals .....	2-1
	Table 2-2: Unit 1 SDA Inlet and FF Outlet – Mercury.....	2-2
	Table 2-3: Unit 1 FF Outlet - Fluorides.....	2-3
	Table 2-4: Unit 1 FF Outlet - PCDDs/PCDFs .....	2-4
	Table 2-5: Unit 1 FF Outlet and SDA Inlet - Hydrogen Chloride .....	2-5
	Table 2-6: Unit 2 FF Outlet – Particulate and Metals .....	2-6
	Table 2-7: Unit 2 SDA Inlet and FF Outlet – Mercury.....	2-7
	Table 2-8: Unit 2 FF Outlet - Fluorides.....	2-8
	Table 2-9: Unit 2 FF Outlet and SDA Inlet - Hydrogen Chloride .....	2-9
	Table 2-10: Unit 3 FF Outlet – Particulate and Metals .....	2-10
	Table 2-11: Unit 3 SDA Inlet and FF Outlet – Mercury.....	2-11
	Table 2-12: Unit 3 FF Outlet - Fluorides.....	2-12
	Table 2-13: Unit 3 FF Outlet and SDA Inlet - Hydrogen Chloride .....	2-13
	Table 2-14: Units 1, 2 and 3 FF Outlets – Opacity by COMS.....	2-14
	Table 2-15: Ash Handling System - Fugitive Emissions.....	2-15
	Table 2-16: Lime Silo Fabric Filter Outlet - Visible Emissions .....	2-15
	Table 2-17: Air Flow Summary.....	2-16
	Table 2-18: Quality Control and Quality Assurance PCDD/PCDF - Extraction Standard Percent Recoveries .....	2-17
	Table 2-19: Quality Control and Quality Assurance PCDD/PCDF – CS/SS Percent Recoveries .....	2-17
	Table 2-20: Quality Control and Quality Assurance - Metals .....	2-18
	Table 2-22: Quality Control and Quality Assurance – Method and Field Blanks.....	2-20
	Table 2-23: Quality Control and Quality Assurance - Miscellaneous .....	2-21

**CONTENTS**

**3 DESCRIPTION OF INSTALLATION ..... 3-1**  
PROCESS DESCRIPTION..... 3-1  
    Figure 3-1: General Process Schematic ..... 3-1  
    Figure 3-2: Process Schematic ..... 3-2  
    Table 3-1: Unit 1 Compliance Test Process Data ..... 3-3  
    Table 3-2: Unit 2 Compliance Test Process Data ..... 3-4  
    Table 3-3: Unit 3 Compliance Test Process Data ..... 3-5  
DESCRIPTION OF SAMPLING LOCATIONS..... 3-6  
    Table 3-4: Sampling Points ..... 3-6  
    Figure 3-3: SDA Inlets - Sampling Point Determination (HCl Sampling)..... 3-7  
    Figure 3-4: SDA Inlets - Sampling Point Determination (Hg Sampling) ..... 3-8  
    Figure 3-5: FF Outlets - Sampling Point Determination ..... 3-9

**4 METHODOLOGY ..... 4-1**  
    Table 4-1: Summary of Sampling Procedures ..... 4-1

**5 APPENDIX..... 5-1**  
TEST METHOD SPECIFICATIONS..... A  
SAMPLE CALCULATIONS..... B  
PLANT DATA..... C  
PARAMETERS ..... D  
QA/QC DATA..... E  
FIELD DATA ..... F  
FIELD DATA PRINTOUTS ..... G  
LABORATORY DATA..... H  
PERTINENT CERTIFICATIONS ..... I  
CLARIFICATIONS ..... J

**PROJECT OVERVIEW**

1-1

**INTRODUCTION**

Wheelabrator South Broward, Inc. operates a Refuse to Energy facility, located in Ft. Lauderdale, Florida. The facility's emission levels are regulated by the Florida Department of Environmental Protection (FDEP). Clean Air Engineering (CleanAir) was contracted to perform a compliance test program at its municipal waste combustor (MWC) facility, located in Ft. Lauderdale, Florida.

The visual emissions were determined by the facility's continuous opacity monitor system (COMS) data, as allowed under Title V Conditions B.53(6), B.76 and B.81. The lime silo fabric filter vent was observed for visual emissions (VEs) and the ash handling system was observed for fugitive emissions. Testing was conducted in accordance with the Wheelabrator North and South Broward Protocol on Compliance, dated February 5, 2009, 40 CFR 60 Subpart Cb, and applicable sections of the facility's Title V Permit No. 0112119-009-AV.

All testing was conducted in accordance with the regulations set-forth by the United States Environmental Protection Agency (EPA) and the FDEP.

**Key Project Participants**

Individuals responsible for coordinating and conducting the test program were:

- C. Faller – Wheelabrator South Broward
- S. Brown – CleanAir

Patty Tampas of the FDEP was present for portions of the test program.

The CleanAir test crew consisted of the following individuals:

- B. Wiltse
- R. Vicere
- P. Bihun
- C. Slimp
- P. Collins
- S. Joint
- I. Lopez
- K. Kirchner

**PROJECT OVERVIEW**

1-2

***Test Program Parameters***

The sampling conducted at the Units 1, 2 and 3 Spray Dry Absorption (SDA) Inlet and Fabric Filter (FF) Outlets from March 16 through 18, 2009, included the following emissions measurements:

- beryllium;
- cadmium;
- lead;
- mercury;
- PCDDs and PCDFs (Unit 1 only);
- total suspended particulate (TSP);
- hydrogen chloride;
- fluoride;
- visual emissions;
- fugitive emissions.

**PROJECT OVERVIEW**

**TEST PROGRAM SYNOPSIS**

**Test Schedule**

The on-site schedule followed during the test program is outlined in Table 1-1.

**Table 1-1:  
Schedule of Activities**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	Unit 1 SDA Inlet/FF Outlet	USEPA Mod. M26A	HCl	03/16/09	06:44	07:44
1	Unit 2 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/16/09	06:56	09:20
1	Unit 2 SDA Inlet	USEPA Method 29	Mercury	03/16/09	06:58	09:20
1	Unit 3 FF Outlet	USEPA Method 13B	Total Fluorides	03/16/09	07:20	08:38
2	Unit 1 SDA Inlet/FF Outlet	USEPA Mod. M26A	HCl	03/16/09	08:22	09:22
2	Unit 3 FF Outlet	USEPA Method 13B	Total Fluorides	03/16/09	09:30	10:47
3	Unit 1 SDA Inlet/FF Outlet	USEPA Mod. M26A	HCl	03/16/09	09:50	10:50
2	Unit 2 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/16/09	09:58	12:09
2	Unit 2 SDA Inlet	USEPA Method 29	Mercury	03/16/09	09:58	12:09
1	Unit 1 FF Outlet	USEPA Method 23	PCDD/F	03/16/09	11:07	15:32
3	Unit 3 FF Outlet	USEPA Method 13B	Total Fluorides	03/16/09	11:20	12:41
3	Unit 2 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/16/09	12:45	14:59
3	Unit 2 SDA Inlet	USEPA Method 29	Mercury	03/16/09	12:45	14:59
2	Unit 1 FF Outlet	USEPA Method 23	PCDD/F	03/17/09	06:08	10:27
1	Unit 2 SDA Inlet/FF Outlet	USEPA Mod. M26A	HCl	03/17/09	06:33	07:33
1	Unit 3 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/17/09	06:33	08:42
1	Unit 3 SDA Inlet	USEPA Method 29	Mercury	03/17/09	06:33	08:42
2	Unit 2 SDA Inlet/FF Outlet	USEPA Mod. M26A	HCl	03/17/09	08:26	09:26
2	Unit 3 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/17/09	09:15	11:24
2	Unit 3 SDA Inlet	USEPA Method 29	Mercury	03/17/09	09:15	11:24
3	Unit 2 SDA Inlet/FF Outlet	USEPA Mod. M26A	HCl	03/17/09	10:15	11:15
3	Unit 1 FF Outlet	USEPA Method 23	PCDD/F	03/17/09	10:54	15:18
1	Unit 2 FF Outlet	USEPA Method 13B	Total Fluorides	03/17/09	11:43	12:55
3	Unit 3 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/17/09	11:56	14:07
3	Unit 3 SDA Inlet	USEPA Method 29	Mercury	03/17/09	11:56	14:07
1	Ash Handling Sysytem	USEPA Method 22	Fugitive Emissions	03/17/09	12:53	16:33
2	Unit 2 FF Outlet	USEPA Method 13B	Total Fluorides	03/17/09	13:15	14:27
3	Unit 2 FF Outlet	USEPA Method 13B	Total Fluorides	03/17/09	14:40	15:49
1	Unit 1 FF Outlet	USEPA Method 13B	Total Fluorides	03/18/09	06:38	07:50
1	Unit 1 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/18/09	06:41	08:52
1	Unit 1 SDA Inlet	USEPA Method 29	Mercury	03/18/09	06:41	08:52
1	Unit 3 SDA Inlet/FF Outlet	USEPA Mod. M26A	HCl	03/18/09	06:56	07:56
2	Unit 1 FF Outlet	USEPA Method 13B	Total Fluorides	03/18/09	08:06	09:21
2	Unit 3 SDA Inlet/FF Outlet	USEPA Mod. M26A	HCl	03/18/09	09:13	10:13
2	Unit 1 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/18/09	09:19	11:30
2	Unit 1 SDA Inlet	USEPA Method 29	Mercury	03/18/09	09:19	11:30
1	Lime Silo FF Outlet	USEPA Method 9	Opacity	03/18/09	09:30	11:16
3	Unit 1 FF Outlet	USEPA Method 13B	Total Fluorides	03/18/09	09:47	11:00
3	Unit 3 SDA Inlet/FF Outlet	USEPA Mod. M26A	HCl	03/18/09	10:40	11:40
3	Unit 1 SDA Inlet	USEPA Method 29	Mercury	03/18/09	12:12	14:22
3	Unit 1 FF Outlet	USEPA Method 5/29	Particulate/Metals	03/18/09	12:12	14:22



**PROJECT OVERVIEW**

**TEST PROGRAM SYNOPSIS (CONTINUED)**

**Results Summary**

Table 1-2 summarizes the results of the test program. A more detailed presentation of the test conditions and results of analysis are shown in Tables 2-1 through 2-23 on pages 2-1 through 2-21. Subpart Cb required operating data is summarized in Table 1-3 and opacity and fugitive emission results are presented in Table 1-4, both on page 1-5.

**Table 1-2:  
Summary of Test Results**

<u>Source</u>	<u>Average Unit 1</u>	<u>Average Unit 2</u>	<u>Average Unit 3</u>	<u>Permit Limit<sup>1</sup></u>
<b>Constituent</b>				
Particulate (mg/dscm @7% O <sub>2</sub> )	1.7	1.2	1.4	27/25
Visual Emissions (% by COMS) <sup>2</sup>	0	0	0	10
Fluoride (lb/MMBtu as HF) <sup>3</sup>	<0.0000060	<0.0000055	<0.0000058	0.0040
Total PCCD/PCDF (ng/dscm @ 7% O <sub>2</sub> )	3.8	NA	NA	30
Hydrogen Chloride (ppmdv @ 7% O <sub>2</sub> ) <u>or</u> Hydrogen Chloride Removal (%) <sup>4</sup>	15 96%	24 95%	24 96%	29 >95
Beryllium (mg/dscm @ 7% O <sub>2</sub> )	<0.000031	<0.000030	<0.000030	0.001
Cadmium (mg/dscm @ 7% O <sub>2</sub> )	0.00037	0.00022	<0.00015	0.040/0.035
Lead (mg/dscm @ 7% O <sub>2</sub> )	0.0012	0.0014	0.00067	0.44/0.40
Mercury (µg/dscm @ 7% O <sub>2</sub> )	2.3	4.3	4.1	70/50
Mercury Removal (%) <sup>4</sup>	97%	88%	92%	>85
Carbon Feed Rate (lbs/hr) <sup>5</sup>	5	6	6	NA
Average Steam Flow (Klbs/hr) <sup>6</sup>	184.0	184.2	184.1	192
Average FF Inlet Temperature (°F) <sup>6</sup>	312	317	313	NA

<sup>1</sup> Limits obtained from facilities Title V Permit 01121 19-009-AV. If a second limit is shown that limit is being implemented by the EPA as of April 28, 2009.

<sup>2</sup> Visual Emissions (opacity) was obtained from the facilities COMS data as allowed under Title V Conditions B.53(6), B.76 and B.81.

<sup>3</sup> lb/MMBtu calculations used Fd of 9,570 for MSW as per Method 19.

<sup>4</sup> Removal for mercury and hydrogen chloride calculated in the unit of its standard (ppmdv @ 7% O<sub>2</sub>). The hydrogen chloride limit is 29 ppmdv @ 7% O<sub>2</sub> or 95% removal and the mercury limit is 70/50 µg/dscm @ 7% O<sub>2</sub> or 85% removal, whichever is less stringent.

<sup>5</sup> From 40CFR60.58b (m)(1)(i) an average mass carbon rate during mercury or dioxin testing. The minimum carbon feed rate is established as the lower of the average carbon feed rates measured during the mercury or dioxin testing

<sup>6</sup> From all compliance test runs.

**PROJECT OVERVIEW**

1-5

**Table 1-3:  
Subpart Cb Required Operating Data**

<u>Process Condition</u>	
Unit 1 Maximum Demonstrated Combustor Load (Klbs/hr) <sup>1</sup>	184.2
Unit 2 Maximum Demonstrated Combustor Load (Klbs/hr) <sup>1</sup>	183.9 <sup>2</sup>
Unit 3 Maximum Demonstrated Combustor Load (Klbs/hr) <sup>1</sup>	184.1 <sup>3</sup>
Unit 1 Maximum Particulate Control Device Inlet Temperature (°F) <sup>4</sup>	320
Unit 2 Maximum Particulate Control Device Inlet Temperature (°F) <sup>4</sup>	325 <sup>2</sup>
Unit 3 Maximum Particulate Control Device Inlet Temperature (°F) <sup>4</sup>	325 <sup>3</sup>
Unit 1 Carbon Feed Rate (lbs/hr) <sup>5</sup>	5
Unit 2 Carbon Feed Rate (lbs/hr) <sup>5</sup>	6
Unit 3 Carbon Feed rate (Klbs/hr) <sup>5</sup>	6

<sup>1</sup> From 40CFR60.58b (i) (8) the maximum demonstrated load during PCDD/PCDF testing, four hour average.

<sup>2</sup> From CleanAir Cb test report dated April 19, 2007.

<sup>3</sup> From CleanAir Cb test report dated April 24, 2008.

<sup>4</sup> From 40CFR60.58b (i) (9) the highest four hour average during PCDD/PCDF testing.

<sup>5</sup> From 40CFR60.58b (m)(1)(i) an average mass carbon rate during mercury or dioxin testing. The minimum carbon feed rate is established as the lower of the average carbon feed rates measured during the mercury or dioxin testing.

**Table 1-4:  
Opacity and Fugitive Emission Test Results**

<u>Source</u>	<u>Constituent</u>	<u>Sampling Method</u>	<u>Results</u>	<u>Permit Limit<sup>1</sup></u>
<u>Ash Handling System<sup>2</sup></u>				
	Fugitive Emissions (%)	EPA M22	0	5% of observation time
	Fugitive Emissions (minutes)		0	9 minutes
<u>Lime Silo<sup>3</sup></u>				
	Visual Emissions (%)	EPA M9	0	5%

<sup>1</sup> Limits obtained from 40 Code of Federal Register part 60 Subpart Cb - Emission Guidelines and Compliance Times for Large Municipal Waste Combustors That Are Constructed on or Before September 20, 1994 published in Federal Register as 62 FR 45123 on December 19, 1995 as modified on August 25, 1997, Florida's Rule 62-296.416, F.A.C. and PSD-FL-105.

<sup>2</sup> The Ash Handling System was observed at various locations for a total of 3 hours.

<sup>3</sup> The Lime Silo was observed for one complete truck unloading.

**Discussion of Test Program**

All test methods were done in triplicate. All data that is reported in the units of lb/MMBTU utilized the Fd of 9,570 as per EPA Method 19.

**PROJECT OVERVIEW**

1-6

All equipment utilized for compliance testing was manufactured by Clean Air Engineering, except for the Servomex O<sub>2</sub>/CO<sub>2</sub> analyzer utilized for all of the integrated gas sample bag analysis.

During compliance testing, all three (3) boilers were operated within 10% of the 192,000 lb/hr maximum steam flow rating. The result tables present each boilers steam output for every test run.

Shawn Joint performed the fugitive emission readings (per EPA Method 22) on the ash handling system. Ben Wiltse conducted the VE readings (per EPA Method 9) on the Lime Silo during one (1) entire truck unloading. Mr. Wiltse's VE evaluation certificate is presented in Appendix I.

Any fractions of the mercury analysis that were reported as not detected were summed as zero if there was at least one (1) fraction detected in that run. The beryllium, cadmium and lead front- and back-half fractions were combined proportionately for analysis per EPA Method 29, Section 5.4.

Field blanks were collected for the Method 23 and 29 testing by assembling a used set of glassware, taking the complete train to the outlet location and performing a leak check. These samples were treated exactly as the other samples. The results for the Method field blanks are presented in Table 2-22 on page 2-20, as well as Appendix H. The results of the Method 29 reagent blank analysis were used to correct any data, as outlined in Method 29.

All Method 23 samples were analyzed with the DB-5S column with modified calibration and additional quality assurance procedures as a direct substitute for the DB-5 and DB-225 columns. Confirmation of the 2,3,7,8 TCDF and TCDD 2,3,7,8 isomers was performed on the DB-5S column. The DB-5S column and modified calibration procedures meets the column separation requirement and can be used as a direct substitute for the DB-5 and DB-225 columns, in accordance with Method 23 as approved by the EPA. All QA/QC data (spikes and recoveries) for Method 23, as well as the EPA Audit Sample results, are presented in Appendix H.

The Method 23 results for Runs 1 and 2 each contained at least one (1) estimated maximum possible concentration (EMPC) value. EMPC results do not meet all the identification criteria required by Method 23 to be positively identified as a dioxin or furan. Specifically, the integrated ion abundance ratios were not within 15% of the theoretical value limits specified in Method 23 Section 5.3.2.5, Table 4. The laboratory reports EMPC results as zero and, for this reason, all EMPC results are enclosed in brackets and are considered zero when calculating total dioxin/furans.

**PROJECT OVERVIEW**

1-7

For analytical results that are below the detection limit, values are reported as ND, with the detection limit in parenthesis and are considered zero for calculating total catch weights per Method 23, Section 9.9.

Chuck Faller of Wheelabrator South Broward Inc. provided the process (operating) data. This data is presented in its entirety in Appendix C. All process data and CleanAir run times are based on facility CEM time, which is 66 minutes earlier than actual Eastern Standard Time (EST) and the plant's Bailey Computer Time. The Lime Silo opacity start and stop times are based on EST, since the initial and final truck weights were recorded using "real" time.

Integrated gas samples (IGS) were collected in a vinyl sample bag from every sample train. The contents of the bag were then analyzed for O<sub>2</sub> and CO<sub>2</sub> concentrations using an O<sub>2</sub>/CO<sub>2</sub> continuous monitoring analyzer calibrated with EPA Protocol gases. A linearity and bias check was performed on the analyzers before each set of bags was analyzed and then a post bias check was performed after each set of bags was analyzed. All data was recorded using CleanAir's data acquisition system. The results of the IGS bag analyses are presented in Appendix G.

Metals and particulate matter sampling were combined during this test program per the Method 29 Section 1.2 Principle, "This method may be used to determine particulate emissions in addition to the metals emissions if the prescribed procedures and precautions are followed".

Additionally, 120-minute mercury measurements were conducted, using EPA Method 29, at the SDA Inlets, simultaneously with the Method 5/29. The SDA Inlet mercury testing was performed because the facility recently added carbon injection systems for mercury removal on all three (3) units. The carbon injection rate is set for the following year based on the results of these tests. The carbon rates established are presented in Table 1-3 on page 1-5.

Sixty-minute Method 26A sample trains at the SDA Inlets and FF Outlets were utilized to exhibit compliance with each unit's HCl limit(s). The Method 26A was modified to a single-point constant sampling rate at all test locations.

The FDEP supplied audit samples for metals, HF and HCl to CleanAir. The analytical results of these samples are presented in Appendix H, along with each respective lab report.

---

*End of Section 1 – Project Overview*

**RESULTS**

2-1

**Table 2-1:  
Unit 1 FF Outlet – Particulate and Metals**

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:41	09:19	12:12	
Stop Time (approx.)		08:52	11:30	14:22	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hr)	183.6	183.4	184.0	<b>183.7</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	313	305	305	<b>308</b>
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.4	9.2	9.2	<b>9.3</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.2	10.6	10.5	<b>10.4</b>
T <sub>s</sub>	Sample temperature (°F)	296	290	290	<b>292</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.9	22.4	22.5	<b>22.3</b>
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	168,899	165,781	164,975	<b>166,552</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	89,921	88,392	87,831	<b>88,715</b>
<b>Sampling Data</b>					
V <sub>metd</sub>	Volume metered, standard (dscf)	68.76	67.60	67.88	<b>68.08</b>
%I	Isokinetic sampling (%)	100.0	100.0	101.1	<b>100.4</b>
<b>Particulate Laboratory Data</b>					
m <sub>n</sub>	Net matter collected (g)	0.0009	0.0038	0.0034	
<b>Filterable Particulate Results</b>					
C <sub>sd</sub>	Particulate Concentration (mg/dscm)	0.46	2.0	1.8	<b>1.4</b>
C <sub>sd7</sub>	Particulate Concentration @7% O <sub>2</sub> (mg/dscm)	0.56	2.4	2.1	<b>1.7</b>
<b>Beryllium Results - Total</b>					
C <sub>sd</sub>	Concentration (mg/dscm)	<0.000026	<0.000026	<0.000026	<b>&lt;0.000026</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<0.000031	<0.000031	<0.000031	<b>&lt;0.000031</b>
<b>Cadmium Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	0.3934	0.3103	1.0930	
<b>Cadmium Results - Total</b>					
C <sub>sd</sub>	Concentration (mg/dscm)	0.00020	0.00016	0.00057	<b>0.00031</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	0.00024	0.00019	0.00067	<b>0.00037</b>
<b>Lead Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	2.2834	1.3454	2.3089	
<b>Lead Results - Total</b>					
C <sub>sd</sub>	Concentration (mg/dscm)	0.0012	0.00070	0.0012	<b>0.0010</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	0.0014	0.00083	0.0014	<b>0.0012</b>

**RESULTS****Table 2-2:  
Unit 1 SDA Inlet and FF Outlet – Mercury**

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:41	09:19	12:12	
Stop Time (approx.)		08:52	11:30	14:22	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hr)	183.6	183.4	184.0	<b>183.7</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	313	305	305	<b>308</b>
P <sub>2</sub>	Carbon Feed rate (lb/hr)	7	6	5	<b>6</b>
<b>SDA Inlet Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.7	8.9	8.9	<b>9.2</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.0	10.8	10.9	<b>10.5</b>
T <sub>s</sub>	Sample temperature (°F)	505	506	508	<b>506</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	16.0	16.9	17.5	<b>16.8</b>
<b>SDA Inlet Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	176,323	173,916	177,125	<b>175,788</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	81,161	79,153	79,904	<b>80,073</b>
<b>SDA Inlet Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	69.41	69.31	69.73	<b>69.48</b>
%I	Isokinetic sampling (%)	104.0	106.4	106.1	<b>105.5</b>
<b>SDA Inlet Mercury Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	105.1263	116.8821	116.3232	
<b>SDA Inlet Mercury Results - Total</b>					
C <sub>std</sub>	Concentration (µg/dscm)	53	60	59	<b>57</b>
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	66	69	68	<b>68</b>
<b>FF Outlet Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.4	9.2	9.2	<b>9.3</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.2	10.6	10.5	<b>10.4</b>
T <sub>s</sub>	Sample temperature (°F)	296	290	290	<b>292</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.9	22.4	22.5	<b>22.3</b>
<b>FF Outlet Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	168,899	165,781	164,975	<b>166,552</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	89,921	88,392	87,831	<b>88,715</b>
<b>FF Outlet Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	68.76	67.60	67.88	<b>68.08</b>
%I	Isokinetic sampling (%)	100.0	100.0	101.1	<b>100.4</b>
<b>FF Outlet Mercury Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	4.4126	3.1426	3.4661	
<b>FF Outlet Mercury Results - Total</b>					
C <sub>std</sub>	Concentration (µg/dscm)	2.3	1.6	1.8	<b>1.9</b>
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	2.7	1.9	2.1	<b>2.3</b>
	Removal Efficiency (µg/dscm @ 7% O <sub>2</sub> based)	96%	97%	97%	<b>97%</b>

**RESULTS**

2-3

**Table 2-3:  
Unit 1 FF Outlet - Fluorides**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:38	08:06	09:47	
Stop Time (approx.)	07:50	09:21	11:00	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hr)	184.3	183.8	184.1	<b>184.1</b>
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	308	305	<b>309</b>
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.4	9.3	10.1	<b>9.6</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.2	10.3	9.6	<b>10.0</b>
T <sub>s</sub> Sample temperature (°F)	293	290	287	<b>290</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.6	22.3	22.7	<b>22.2</b>
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	178,264	180,189	180,383	<b>179,612</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	95,670	96,275	96,295	<b>96,080</b>
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	37.65	37.76	37.69	<b>37.70</b>
%I Isokinetic sampling (%)	99.9	99.6	99.4	<b>99.6</b>
<b>Laboratory Data</b>				
m <sub>n</sub> Total HF collected (mg)	<0.00606	<0.00547	<0.00597	
<b>Hydrogen Fluoride (HF) Results</b>				
C <sub>sd</sub> HF Concentration (ppmdv)	<0.0068	<0.0062	<0.0067	<b>&lt;0.0066</b>
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (ppmdv)	<0.0082	<0.0074	<0.0087	<b>&lt;0.0081</b>
C <sub>sd</sub> HF Concentration (mg/dscm)	<0.0057	<0.0051	<0.0056	<b>&lt;0.0055</b>
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (mg/dscm)	<0.0068	<0.0061	<0.0072	<b>&lt;0.0067</b>
E <sub>lb/hr</sub> HF Rate (lb/hr)	<0.0020	<0.0018	<0.0020	<b>&lt;0.0020</b>
E <sub>Fd</sub> HF Rate - Fd-based (lb/MMBtu)	<0.000062	<0.000055	<0.000065	<b>&lt;0.000060</b>

**RESULTS****Table 2-4:  
Unit 1 FF Outlet - PCDDs/PCDFs**

Run No.		1	2	3	Average
Date (2009)		Mar 16	Mar 17	Mar 17	
Start Time (approx.)		11:07	06:08	10:54	
Stop Time (approx.)		15:32	10:27	15:18	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hr)	184.0	183.4	184.2	<b>183.9</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	320	320	320	<b>320</b>
P <sub>2</sub>	Carbon Feed Rate (lb/hr)	6	5	5	<b>5</b>
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.5	9.7	9.4	<b>9.5</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.3	9.9	10.2	<b>10.1</b>
T <sub>s</sub>	Sample temperature (°F)	301	301	301	<b>301</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.3	21.3	21.0	<b>21.2</b>
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	176,448	182,079	175,503	<b>178,010</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	94,787	96,525	93,680	<b>94,997</b>
<b>Sampling Data</b>					
V <sub>msd</sub>	Volume metered, standard (dscf)	142.32	144.13	138.82	<b>141.76</b>
%I	Isokinetic sampling (%)	99.7	99.1	98.4	<b>99.0</b>
<b>Results (ND and EMPC = 0)</b>					
<b>Laboratory Data from USEPA Method 23</b>					
m <sub>n</sub>	Total PCDDs & PCDFs (ng)	12.700	12.300	12.300	
m <sub>n,TEQ</sub>	Total TEQ PCDDs & PCDFs (ng)	0.133	0.127	0.129	
<b>Total PCDD/F Results (TEF=1)</b>					
C <sub>sd</sub>	PCDD/F Concentration (ng/dscm)	3.2	3.0	3.1	<b>3.1</b>
C <sub>sd7</sub>	PCDD/F Concentration @7% O <sub>2</sub> (ng/dscm)	3.9	3.7	3.8	<b>3.8</b>
E <sub>lb/hr</sub>	PCDD/F Rate (lb/hr)	1.119E-06	1.090E-06	1.098E-06	<b>1.102E-06</b>
E <sub>Fd</sub>	PCDD/F Rate - F <sub>p</sub> -based (lb/MMBtu)	3.464E-09	3.349E-09	3.398E-09	<b>3.404E-09</b>
<b>Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)</b>					
C <sub>sdTEQ</sub>	TEQ Concentration (ng/dscm)	0.033	0.031	0.033	<b>0.032</b>
C <sub>sd7TEQ</sub>	TEQ Concentration @7% O <sub>2</sub> (ng/dscm)	0.040	0.038	0.040	<b>0.040</b>
E <sub>lb/hrTEQ</sub>	TEQ Rate (lb/hr)	1.2E-08	1.1E-08	1.2E-08	<b>1.1E-08</b>
E <sub>FdTEQ</sub>	TEQ Rate - F <sub>p</sub> -based (lb/MMBtu)	3.6E-11	3.5E-11	3.6E-11	<b>3.5E-11</b>
<b>Results (ND and EMPC = actual value)</b>					
<b>Laboratory Data from USEPA Method 23, including NDs and EMPCs</b>					
m <sub>n</sub>	Total PCDDs & PCDFs (ng)	12.700	12.500	12.400	
m <sub>n,TEQ</sub>	Total TEQ PCDDs & PCDFs (ng)	0.136	0.131	0.129	
<b>Total PCDD/F Results (TEF=1)</b>					
C <sub>sd</sub>	PCDD/F Concentration (ng/dscm)	3.2	3.1	3.2	<b>3.1</b>
C <sub>sd7</sub>	PCDD/F Concentration @7% O <sub>2</sub> (ng/dscm)	3.9	3.8	3.8	<b>3.8</b>
E <sub>lb/hr</sub>	PCDD/F Rate (lb/hr)	1.1E-06	1.1E-06	1.1E-06	<b>1.1E-06</b>
E <sub>Fd</sub>	PCDD/F Rate - F <sub>p</sub> -based (lb/MMBtu)	3.5E-09	3.4E-09	3.4E-09	<b>3.4E-09</b>
<b>Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)</b>					
C <sub>sdTEQ</sub>	TEQ Concentration (ng/dscm)	0.034	0.032	0.033	<b>0.033</b>
C <sub>sd7TEQ</sub>	TEQ Concentration @7% O <sub>2</sub> (ng/dscm)	0.041	0.040	0.040	<b>0.040</b>
E <sub>lb/hrTEQ</sub>	TEQ Rate (lb/hr)	1.2E-08	1.2E-08	1.2E-08	<b>1.2E-08</b>
E <sub>FdTEQ</sub>	TEQ Rate - F <sub>p</sub> -based (lb/MMBtu)	3.7E-11	3.6E-11	3.6E-11	<b>3.6E-11</b>



**RESULTS**

2-5

**Table 2-5:  
Unit 1 FF Outlet and SDA Inlet - Hydrogen Chloride**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:44	08:22	09:50	
Stop Time (approx.)	07:44	09:22	10:50	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hr)	184.7	184.7	183.5	<b>184.3</b>
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	320	320	320	<b>320</b>
<b>SDA Inlet Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	8.0	7.7	8.5	<b>8.1</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	11.4	11.7	11.0	<b>11.4</b>
T <sub>s</sub> Sample temperature (°F)	492	488	487	<b>489</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	18.2	16.2	16.6	<b>17.0</b>
<b>SDA Inlet Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	33.11	34.24	33.92	<b>33.76</b>
<b>SDA Inlet Laboratory Data</b>				
m <sub>n</sub> Total HCl collected (mg)	593.6855	508.7987	529.3518	
<b>SDA Inlet Hydrogen Chloride (HCl) Results</b>				
C <sub>sd</sub> HCl Concentration (ppmdv)	418	346	364	<b>376</b>
C <sub>sd7</sub> HCl Concentration @7% O <sub>2</sub> (ppmdv)	450	366	406	<b>407</b>
<b>FF Outlet Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.2	9.0	9.5	<b>9.2</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.4	10.6	10.1	<b>10.3</b>
T <sub>s</sub> Sample temperature (°F)	304	307	306	<b>305</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	22.7	21.5	20.6	<b>21.6</b>
<b>FF Outlet Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	39.71	39.12	38.83	<b>39.22</b>
<b>FF Outlet Laboratory Data</b>				
m <sub>n</sub> Total HCl collected (mg)	17.6057	20.2666	24.8532	
<b>FF Outlet Hydrogen Chloride (HCl) Results</b>				
C <sub>sd</sub> HCl Concentration (ppmdv)	10	12	15	<b>12</b>
C <sub>sd7</sub> HCl Concentration @7% O <sub>2</sub> (ppmdv)	12	14	18	<b>15</b>
RE Reduction Efficiency (% Removal)	97%	96%	96%	<b>96%</b>

**RESULTS****Table 2-6:  
Unit 2 FF Outlet – Particulate and Metals**

Run No.		1	2	3	Average
Date (2009)		Mar 16	Mar 16	Mar 16	
Start Time (approx.)		06:56	09:58	12:45	
Stop Time (approx.)		09:20	12:09	14:59	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hr)	184.1	184.9	183.9	<b>184.3</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	315	<b>315</b>
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.9	9.9	9.8	<b>9.9</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.7	9.8	10.0	<b>9.8</b>
T <sub>s</sub>	Sample temperature (°F)	298	297	298	<b>298</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.3	20.7	21.4	<b>21.1</b>
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	178,836	178,004	180,235	<b>179,025</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	96,412	96,780	97,128	<b>96,773</b>
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	74.28	73.05	74.63	<b>73.99</b>
%I	Isokinetic sampling (%)	100.7	98.7	100.5	<b>100.0</b>
<b>Particulate Laboratory Data</b>					
m <sub>n</sub>	Net matter collected (g)	0.0020	0.0010	0.0032	
<b>Filterable Particulate Results</b>					
C <sub>sd</sub>	Particulate Concentration (mg/dscm)	0.95	0.48	1.5	<b>0.98</b>
C <sub>sd7</sub>	Particulate Concentration @7% O <sub>2</sub> (mg/dscm)	1.2	0.61	1.9	<b>1.2</b>
<b>Beryllium Results - Total</b>					
C <sub>sd</sub>	Concentration (mg/dscm)	<0.000024	<0.000024	<0.000024	<b>&lt;0.000024</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<0.000030	<0.000030	<0.000030	<b>&lt;0.000030</b>
<b>Cadmium Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	0.4125	0.3372	0.3416	
<b>Cadmium Results - Total</b>					
C <sub>sd</sub>	Concentration (mg/dscm)	0.00020	0.00016	0.00016	<b>0.00017</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	0.00025	0.00021	0.00020	<b>0.00022</b>
<b>Lead Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	1.9770	2.3462	2.5954	
<b>Lead Results - Total</b>					
C <sub>sd</sub>	Concentration (mg/dscm)	0.00094	0.0011	0.0012	<b>0.0011</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	0.0012	0.0014	0.0015	<b>0.0014</b>

**RESULTS**

2-7

**Table 2-7:  
Unit 2 SDA Inlet and FF Outlet – Mercury**

Run No.		1	2	3	Average
Date (2009)		Mar 16	Mar 16	Mar 16	
Start Time (approx.)		06:58	09:58	12:45	
Stop Time (approx.)		09:20	12:09	14:59	
<b>Process Conditions</b>					
R <sub>P</sub>	Steam Production Rate (Klbs/hr)	184.1	184.9	183.9	<b>184.3</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	315	<b>315</b>
P <sub>2</sub>	Carbon Feed Rate (lb/hr)	5	7	6	<b>6</b>
<b>SDA Inlet Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	8.8	9.2	9.0	<b>9.0</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.7	10.5	10.8	<b>10.7</b>
T <sub>s</sub>	Sample temperature (°F)	513	514	514	<b>514</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	15.8	16.1	16.1	<b>16.0</b>
<b>SDA Inlet Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	188,570	187,625	186,789	<b>187,661</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	86,559	85,767	85,339	<b>85,889</b>
<b>SDA Inlet Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	72.69	72.64	73.32	<b>72.88</b>
%I	Isokinetic sampling (%)	102.1	102.9	104.4	<b>103.2</b>
<b>SDA Inlet Mercury Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	62.3587	81.4920	57.0036	
<b>SDA Inlet Mercury Results - Total</b>					
C <sub>sd</sub>	Concentration (µg/dscm)	30	40	27	<b>32</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	35	47	32	<b>38</b>
<b>FF Outlet Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.9	9.9	9.8	<b>9.9</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.7	9.8	10.0	<b>9.8</b>
T <sub>s</sub>	Sample temperature (°F)	298	297	298	<b>298</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.3	20.7	21.4	<b>21.1</b>
<b>FF Outlet Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	178,836	178,004	180,235	<b>179,025</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	96,412	96,780	97,128	<b>96,773</b>
<b>FF Outlet Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	74.28	73.05	74.63	<b>73.99</b>
%I	Isokinetic sampling (%)	100.7	98.7	100.5	<b>100.0</b>
<b>FF Outlet Mercury Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	6.8700	6.5842	7.8493	
<b>FF Outlet Mercury Results - Total</b>					
C <sub>sd</sub>	Concentration (µg/dscm)	3.3	3.2	3.7	<b>3.4</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	4.1	4.0	4.7	<b>4.3</b>
RE	Reduction Efficiency (% Removal)	88%	91%	85%	<b>88%</b>

**RESULTS****Table 2-8:  
Unit 2 FF Outlet - Fluorides**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	11:43	13:15	14:40	
Stop Time (approx.)	12:55	14:27	15:49	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hr)	185.1	184.7	183.9	<b>184.6</b>
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	320	320	320	<b>320</b>
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.6	9.5	9.4	<b>9.5</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.1	10.2	10.2	<b>10.2</b>
T <sub>s</sub> Sample temperature (°F)	301	301	302	<b>301</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	20.4	20.3	20.1	<b>20.3</b>
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	191,827	184,660	186,228	<b>187,571</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	103,823	100,086	101,073	<b>101,660</b>
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	41.11	40.38	40.45	<b>40.65</b>
%I Isokinetic sampling (%)	100.5	102.4	101.6	<b>101.5</b>
<b>Laboratory Data</b>				
m <sub>n</sub> Total HF collected (mg)	<0.00596	<0.00581	<0.00556	
<b>Hydrogen Fluoride (HF) Results</b>				
C <sub>sd</sub> HF Concentration (ppmdv)	<0.0062	<0.0061	<0.0058	<b>&lt;0.0060</b>
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (ppmdv)	<0.0076	<0.0074	<0.0071	<b>&lt;0.0073</b>
C <sub>sd</sub> HF Concentration (mg/dscm)	<0.0051	<0.0051	<0.0049	<b>&lt;0.0050</b>
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (mg/dscm)	<0.0063	<0.0062	<0.0059	<b>&lt;0.0061</b>
E <sub>lb/hr</sub> HF Rate (lb/hr)	<0.0020	<0.0019	<0.0018	<b>&lt;0.0019</b>
E <sub>Fd</sub> HF Rate - Fd-based (lb/MMBtu)	<0.0000057	<0.0000055	<0.0000053	<b>&lt;0.0000055</b>

**RESULTS**

2-9

**Table 2-9:  
Unit 2 FF Outlet and SDA Inlet - Hydrogen Chloride**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	08:26	10:15	
Stop Time (approx.)	07:33	09:26	11:15	
<b>Process Conditions</b>				
R <sub>P</sub> Steam Production Rate (Klbs/hr)	182.6	185.2	183.2	<b>183.7</b>
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	320	<b>317</b>
<b>SDA Inlet Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	8.3	8.3	8.6	<b>8.4</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	11.3	11.3	10.9	<b>11.2</b>
T <sub>s</sub> Sample temperature (°F)	506	506	518	<b>510</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	16.5	16.9	15.6	<b>16.3</b>
<b>SDA Inlet Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	32.81	33.19	34.54	<b>33.51</b>
<b>SDA Inlet Laboratory Data</b>				
m <sub>n</sub> Total HCl collected (mg)	503.5662	598.0783	603.5410	
<b>SDA Inlet Hydrogen Chloride (HCl) Results</b>				
C <sub>sd</sub> HCl Concentration (ppmdv)	358	420	407	<b>395</b>
C <sub>sd7</sub> HCl Concentration @7% O <sub>2</sub> (ppmdv)	395	463	459	<b>439</b>
<b>FF Outlet Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.7	9.1	9.5	<b>9.4</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.0	10.6	10.6	<b>10.4</b>
T <sub>s</sub> Sample temperature (°F)	295	296	299	<b>297</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	20.2	21.4	20.5	<b>20.7</b>
<b>FF Outlet Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	35.83	34.32	36.39	<b>35.52</b>
<b>FF Outlet Laboratory Data</b>				
m <sub>n</sub> Total HCl collected (mg)	29.5404	25.8516	34.0382	
<b>FF Outlet Hydrogen Chloride (HCl) Results</b>				
C <sub>sd</sub> HCl Concentration (ppmdv)	19	18	22	<b>20</b>
C <sub>sd7</sub> HCl Concentration @7% O <sub>2</sub> (ppmdv)	24	21	26	<b>24</b>
RE Reduction Efficiency (% Removal)	94%	96%	94%	<b>95%</b>

**RESULTS****Table 2-10:  
Unit 3 FF Outlet – Particulate and Metals**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hr)	184.0	184.0	184.1	<b>184.0</b>
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	315	<b>315</b>
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	10.7	10.4	10.3	<b>10.4</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.1	9.2	9.4	<b>9.2</b>
T <sub>s</sub> Sample temperature (°F)	295	296	296	<b>296</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	19.8	20.0	19.9	<b>19.9</b>
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	186,547	183,521	178,024	<b>182,697</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	102,140	100,105	97,228	<b>99,824</b>
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	79.35	77.16	75.17	<b>77.23</b>
%I Isokinetic sampling (%)	101.6	100.8	101.1	<b>101.2</b>
<b>Particulate Laboratory Data</b>				
m <sub>n</sub> Net matter collected (g)	0.0036	0.0024	0.0008	
<b>Filterable Particulate Results</b>				
C <sub>sd</sub> Particulate Concentration (mg/dscm)	1.6	1.1	0.38	<b>1.0</b>
C <sub>sd7</sub> Particulate Concentration @7% O <sub>2</sub> (mg/dscm)	2.2	1.4	0.49	<b>1.4</b>
<b>Beryllium Results - Total</b>				
C <sub>sd</sub> Concentration (mg/dscm)	<0.000022	<0.000023	<0.000023	<b>&lt;0.000023</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	<0.000030	<0.000030	<0.000031	<b>&lt;0.000030</b>
<b>Cadmium Laboratory Data</b>				
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	<0.2000	0.2333	0.2845	
<b>Cadmium Results - Total</b>				
C <sub>sd</sub> Concentration (mg/dscm)	<0.000089	0.00011	0.00013	<b>&lt;0.00011</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	<0.00012	0.00014	0.00018	<b>&lt;0.00015</b>
<b>Lead Laboratory Data</b>				
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	0.6091	1.6247	1.0876	
<b>Lead Results - Total</b>				
C <sub>sd</sub> Concentration (mg/dscm)	0.00027	0.00074	0.00051	<b>0.00051</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	0.00037	0.00098	0.00067	<b>0.00067</b>

**RESULTS**

2-11

**Table 2-11:  
Unit 3 SDA Inlet and FF Outlet – Mercury**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hr)	184.0	184.0	184.1	184.0
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	315	315
P <sub>2</sub> Carbon Feed Rate (lb/hr)	6	6	5	6
<b>SDA Inlet Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.6	9.5	9.6	9.5
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.2	10.1	10.0	10.1
T <sub>s</sub> Sample temperature (°F)	488	490	493	491
B <sub>w</sub> Actual water vapor in gas (% by volume)	16.3	16.0	15.8	16.0
<b>SDA Inlet Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	196,240	192,853	190,845	193,313
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	91,644	90,198	89,201	90,348
<b>SDA Inlet Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	74.14	71.87	72.15	72.72
%I Isokinetic sampling (%)	98.3	96.9	98.3	97.8
<b>SDA Inlet Mercury Laboratory Data</b>				
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	76.7234	89.6076	95.0869	
<b>SDA Inlet Mercury Results - Total</b>				
C <sub>sd</sub> Concentration (µg/dscm)	37	44	47	42
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	45	54	57	52
<b>FF Outlet Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	10.7	10.4	10.3	10.4
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.1	9.2	9.4	9.2
T <sub>s</sub> Sample temperature (°F)	295	296	296	296
B <sub>w</sub> Actual water vapor in gas (% by volume)	19.8	20.0	19.9	19.9
<b>FF Outlet Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	186,547	183,521	178,024	182,697
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	102,140	100,105	97,228	99,824
<b>FF Outlet Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	79.35	77.16	75.17	77.23
%I Isokinetic sampling (%)	101.6	100.8	101.1	101.2
<b>FF Outlet Mercury Laboratory Data</b>				
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	6.6466	7.0201	6.5708	
<b>FF Outlet Mercury Results - Total</b>				
C <sub>sd</sub> Concentration (µg/dscm)	3.0	3.2	3.1	3.1
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	4.0	4.2	4.1	4.1
Removal Efficiency (µg/dscm @ 7% O <sub>2</sub> based)	91%	92%	93%	92%

**RESULTS**

2-12

**Table 2-12:  
Unit 3 FF Outlet - Fluorides**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	07:20	09:30	11:20	
Stop Time (approx.)	00:00	10:47	12:41	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hr)	184.2	184.0	184.4	<b>184.2</b>
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	315	<b>315</b>
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.7	11.1	10.3	<b>10.4</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.8	8.5	9.3	<b>9.2</b>
T <sub>s</sub> Sample temperature (°F)	296	294	294	<b>295</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.1	19.8	19.8	<b>20.2</b>
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	193,361	192,674	191,991	<b>192,675</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	104,075	106,228	106,037	<b>105,447</b>
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	41.77	41.58	41.69	<b>41.68</b>
%I Isokinetic sampling (%)	101.9	99.4	99.8	<b>100.4</b>
<b>Laboratory Data</b>				
m <sub>n</sub> Total HF collected (mg)	<0.00615	<0.00547	<0.00560	
<b>Hydrogen Fluoride (HF) Results</b>				
C <sub>sd</sub> HF Concentration (ppmdv)	<0.0063	<0.0056	<0.0057	<b>&lt;0.0058</b>
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (ppmdv)	<0.0078	<0.0079	<0.0075	<b>&lt;0.0077</b>
C <sub>sd</sub> HF Concentration (mg/dscm)	<0.0052	<0.0046	<0.0047	<b>&lt;0.0049</b>
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (mg/dscm)	<0.0065	<0.0065	<0.0062	<b>&lt;0.0064</b>
E <sub>lb/hr</sub> HF Rate (lb/hr)	<0.0020	<0.0018	<0.0019	<b>&lt;0.0019</b>
E <sub>Fd</sub> HF Rate - Fd-based (lb/MMBtu)	<0.0000058	<0.0000059	<0.0000056	<b>&lt;0.0000058</b>



**RESULTS**

2-13

**Table 2-13:  
Unit 3 FF Outlet and SDA Inlet - Hydrogen Chloride**

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:56	09:13	10:40	
Stop Time (approx.)		07:56	10:13	11:40	
<b>Process Conditions</b>					
R <sub>P</sub>	Steam Production Rate (Klbs/hr)	184.1	184.2	183.9	<b>184.1</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	305	305	<b>308</b>
<b>SDA Inlet Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.8	9.7	9.7	<b>9.7</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.8	10.1	9.8	<b>9.9</b>
T <sub>s</sub>	Sample temperature (°F)	487	494	489	<b>490</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	16.2	15.6	16.6	<b>16.1</b>
<b>SDA Inlet Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	32.04	33.22	33.30	<b>32.86</b>
<b>SDA Inlet Laboratory Data</b>					
m <sub>n</sub>	Total HCl collected (mg)	617.4202	601.5257	646.3785	
<b>SDA Inlet Hydrogen Chloride (HCl) Results</b>					
C <sub>sd</sub>	HCl Concentration (ppmdv)	449	422	452	<b>441</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (ppmdv)	560	525	562	<b>549</b>
<b>FF Outlet Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	10.3	9.9	9.7	<b>10.0</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.4	9.8	9.9	<b>9.7</b>
T <sub>s</sub>	Sample temperature (°F)	292	286	284	<b>287</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	19.3	21.9	21.4	<b>20.9</b>
<b>FF Outlet Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	41.44	41.26	40.90	<b>41.20</b>
<b>FF Outlet Laboratory Data</b>					
m <sub>n</sub>	Total HCl collected (mg)	41.0379	22.1246	34.7200	
<b>FF Outlet Hydrogen Chloride (HCl) Results</b>					
C <sub>sd</sub>	HCl Concentration (ppmdv)	23	13	20	<b>18</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (ppmdv)	30	16	25	<b>24</b>
RE	Reduction Efficiency (% Removal)	95%	97%	96%	<b>96%</b>

**RESULTS**

**Table 2-14:  
Units 1, 2 and 3 FF Outlets – Opacity by COMS**

Run No.	1	2	3	Average
<b>Unit 1</b>				
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:41	09:19	12:12	
Stop Time (approx.)	08:52	11:30	14:22	
<b>Visible Emissions (%)<sup>1</sup></b>				
Average Opacity	0	0	0	0
Maximum Reading	0	0	0	0
Minimum Reading	0	0	0	0
<b>Unit 2</b>				
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:56	09:58	12:45	
Stop Time (approx.)	10:20	12:09	14:59	
<b>Visible Emissions (%)<sup>1</sup></b>				
Average Opacity	0	0	0	0
Maximum Reading	0	0	0	0
Minimum Reading	0	0	0	0
<b>Unit 3</b>				
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	
<b>Visible Emissions (%)<sup>1</sup></b>				
Average Opacity	0	0	0	0
Maximum Reading	0	0	0	0
Minimum Reading	0	0	0	0

<sup>1</sup> Reading obtained from facility's continuous opacity monitoring system (COMS) as provided under 40 CFR 60.11(e) and Title V Conditions A.36(6), A.53 and A.54 and coincide with Method 5/29 test runs.

**RESULTS**

2-15

**Table 2-15:  
 Ash Handling System - Fugitive Emissions**

<u>Source</u> Constituent	<u>Date</u> (2009)	<u>Start Time</u> (approx.)	<u>Stop Time</u> (approx.)	<u>Observation</u> Duration (minutes)	<u>Accumulated</u> Emission Duration (seconds)	
<u>Ash Conveyor/Doors to Baghouse</u>						
Visual Opacity (%)	March 17	12:43	14:03	60	0	
<u>Ash Unloading/Conveyor</u>						
Visual Opacity (%)	March 17	14:08	15:18	60	0	
<u>Rolling Door/Door to Baghouse</u>						
Visual Opacity (%)	March 17	15:23	16:33	60	0	<u>Permit Limit</u>
Total (% of observation time) = 0					< 5% of observation Time	
Total (minutes) = 0					< 9 minutes	

**Table 2-16:  
 Lime Silo Fabric Filter Outlet - Visible Emissions**

<b>Run No.</b>	<b>1</b>
Date (2009)	Mar 18
Start Time (approx.)	09:30
Stop Time (approx.)	11:16
<u>Process Conditions</u>	
Total lime unloaded (tons)	25.38
Rate of unloading (tons/hr)	14.4
<u>Visible Emissions</u>	
Average (percent opacity)	0
Maximum reading (percent opacity)	0

**RESULTS**

**Table 2-17:  
Air Flow Summary**

Run Number	Run Date	Run Time	Steam Flow Klbs/hour	Flue Gas Temp Deg F	Air Flow ACFM	O <sub>2</sub> %	CO <sub>2</sub> %	Air Flow, DSCFM	Air Flow, DSCFM@ 7%O <sub>2</sub>
1-O-M5/29-1	3/18/2009	06:41-08:52	183.6	296	168,899	9.4	10.2	89,921	74,201
1-O-M5/29-2	3/18/2009	09:19-11:30	183.4	290	165,781	9.2	10.6	88,392	74,656
1-O-M5/29-3	3/18/2009	12:12-14:22	184.0	290	164,975	9.2	10.5	87,831	74,182
1-O-M13B-1	3/18/2009	06:38-07:50	184.3	293	178,264	9.4	10.2	95,670	79,426
1-O-M13B-2	3/18/2009	08:06-09:21	183.8	290	180,189	9.3	10.3	96,275	80,345
1-O-M13B-3	3/18/2009	09:47-11:00	184.1	287	180,383	10.1	9.6	96,295	74,680
1-O-M23-1	3/16/2009	11:07-15:32	184.0	301	176,448	9.5	10.3	94,787	77,466
1-O-M23-2	3/17/2009	06:08-10:27	183.4	301	182,079	9.7	9.9	96,525	78,053
1-O-M23-3	3/17/2009	10:54-15:18	184.2	301	175,503	9.4	10.2	93,680	77,505
		<b>Average</b>	<b>183.9</b>	<b>294</b>	<b>174,725</b>	<b>9.5</b>	<b>10.2</b>	<b>93,264</b>	<b>76,724</b>
2-O-M5/29-1	3/16/2009	06:56-09:20	184.1	298	178,836	9.9	9.7	96,412	76,436
2-O-M5/29-2	3/16/2009	09:58-12:09	184.9	297	178,004	9.9	9.8	96,780	76,798
2-O-M5/29-3	3/16/2009	12:45-14:59	183.9	298	180,235	9.8	10.0	97,128	77,353
2-O-M13B-1	3/17/2009	11:43-12:55	185.1	301	191,827	9.6	10.1	103,823	84,552
2-O-M13B-2	3/17/2009	13:15-14:27	184.7	301	184,660	9.5	10.2	100,086	82,445
2-O-M13B-3	3/17/2009	14:40-15:49	183.9	302	186,228	9.4	10.2	101,073	83,694
		<b>Average</b>	<b>184.4</b>	<b>300</b>	<b>183,298</b>	<b>9.7</b>	<b>10.0</b>	<b>99,217</b>	<b>80,213</b>
3-O-M5/29-1	3/17/2009	06:33-08:42	184.0	295	186,547	10.7	9.1	102,140	75,319
3-O-M5/29-2	3/17/2009	09:15-11:24	184.0	296	183,521	10.4	9.2	100,105	75,979
3-O-M5/29-3	3/17/2009	11:56-14:07	184.1	296	178,024	10.3	9.4	97,228	74,005
3-O-M13B-1	3/16/2009	07:20-08:38	184.2	296	193,361	9.7	9.8	104,075	83,560
3-O-M13B-2	3/16/2009	09:30-10:47	184.0	294	192,674	11.1	8.5	106,228	75,277
3-O-M13B-3	3/16/2009	11:20-12:41	184.4	294	191,991	10.3	9.3	106,037	80,710
		<b>Average</b>	<b>184.1</b>	<b>295</b>	<b>187,686</b>	<b>10.4</b>	<b>9.2</b>	<b>102,636</b>	<b>77,475</b>
<b>Facility Average</b>			<b>184.1</b>	<b>296</b>	<b>181,903</b>	<b>9.8</b>	<b>9.8</b>	<b>98,372</b>	<b>78,137</b>

**RESULTS**

2-17

**Table 2-18:  
Quality Control and Quality Assurance  
PCDD/PCDF - Extraction Standard Percent Recoveries**

Sample Number	Extraction Standard Percent Recoveries, %						
	<sup>13</sup> C- TCDD	<sup>13</sup> C- PeCDD	<sup>13</sup> C- HxCDD	<sup>13</sup> C- HxCDD	<sup>13</sup> C- HxCDD	<sup>13</sup> C- HpCDD	<sup>13</sup> C- OCDD
0_6688_MB001	91.8	92.7	85.8	84.3	86.3	83.8	80.7
Field Blank	89.8	89.2	88.2	89.1	90.5	87.1	84.2
Run 1-Unit 1-FF-Outlet	97.7	95.9	88.8	90.1	93.2	87.5	85
Run 2-Unit 1-FF-Outlet	89.5	88.6	83.7	82.5	85.1	80.4	75.8
Run 3-Unit 1-FF-Outlet	92.1	92.4	86.5	84.8	88.3	83.1	82.9

Average	92	92	87	86	89	84	82
SD	3	3	2	3	3	3	4
Min	89.5	88.6	83.7	82.5	85.1	80.4	75.8
Max	97.7	95.9	88.8	90.1	93.2	87.5	85
Within M23 QC	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE

Sample Number	Extraction Standard Percent Recoveries, %									
	<sup>13</sup> C- TCDF	<sup>13</sup> C- PeCDF	<sup>13</sup> C- PeCDF	<sup>13</sup> C- HxCDF	<sup>13</sup> C- HxCDF	<sup>13</sup> C- HxCDF	<sup>13</sup> C- HxCDF	<sup>13</sup> C- HpCDF	<sup>13</sup> C- HpCDF	<sup>13</sup> C- OCDF
0_6688_MB001	93.9	91.1	90.8	83.6	84.5	84.7	79.6	82.4	82.6	79.9
Field Blank	86.8	89.8	86.9	84.9	87.7	88.4	81.7	83.8	84.2	82.3
Run 1-Unit 1-FF-Outlet	98.6	95.1	93.7	88	89.6	89.3	82.8	84.3	85.8	83.9
Run 2-Unit 1-FF-Outlet	89.1	88.3	87.1	82.4	84	82.5	77.3	76.9	78.8	74.2
Run 3-Unit 1-FF-Outlet	93.5	90.7	90.9	85.4	85.2	85.7	80.3	81	80.9	80.7

Average	92	91	90	85	86	86	80	82	82	80
SD	5	3	3	2	2	3	2	3	3	4
Min	86.8	88.3	86.9	82.4	84	82.5	77.3	76.9	78.8	74.2
Max	98.6	95.1	93.7	88	89.6	89.3	82.8	84.3	85.8	83.9
Within M23 QC	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE

**Table 2-19:  
Quality Control and Quality Assurance  
PCDD/PCDF - CS/SS Percent Recoveries**

Sample Number	CS/SS Percent Recoveries, %				
	<sup>37</sup> Cl- TCDD	<sup>13</sup> C- PeCDD	<sup>13</sup> C- PeCDF	<sup>13</sup> C- HxCDF	<sup>13</sup> C- HpCDF
0_6688_MB001	-	-	-	-	-
Field Blank	99.2	99.4	92.4	99.6	101
Run 1-Unit 1-FF-Outlet	97.6	99	98.2	97.8	101
Run 2-Unit 1-FF-Outlet	98	98.6	101	99.2	99.4
Run 3-Unit 1-FF-Outlet	96.7	98.6	104	100	100

Average	98	99	99	99	100
SD	1	0	5	1	1
Min	96.7	98.6	92.4	97.8	99.4
Max	99.2	99.4	104	100	101
Min within M23 QC	TRUE	TRUE	TRUE	TRUE	TRUE

**RESULTS**

**Table 2-20:  
 Quality Control and Quality Assurance - Metals**

Run Number	RPD RESULTS				
	FH	BH	A	B	C
	Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>4</sub>	Empty Impinger	KMnO <sub>4</sub>	HCl
U1 Inlet R1	0.5%	2.1%	NA	0.9%	0.5%
U1 Inlet R2	0.1%	3.2%	NA	1.3%	0.3%
U1 Inlet R3	0.2%	8.2%	NA	0.3%	0.6%
U1 Stack R1	NA	0.5%	NA	NA	NA
U1 Stack R2	NA	0.0%	NA	NA	NA
U1 Stack R3	NA	3.0%	NA	NA	NA
U2 Inlet R1	1.5%	1.3%	NA	NA	NA
U2 Inlet R2	0.0%	0.9%	NA	NA	0.5%
U2 Inlet R3	0.0%	1.2%	NA	NA	0.5%
U2 Stack R1	NA	0.1%	NA	NA	NA
U2 Stack R2	NA	0.2%	NA	NA	NA
U2 Stack R3	NA	2.6%	NA	NA	NA
U3 Inlet R1	0.0%	1.2%	NA	NA	0.9%
U3 Inlet R2	1.1%	0.5%	NA	NA	NA
U3 Inlet R3	1.8%	1.9%	NA	NA	1.2%
U3 Stack R1	NA	1.1%	NA	NA	NA
U3 Stack R2	NA	1.2%	NA	NA	NA
U3 Stack R3	NA	1.7%	NA	NA	NA
Reagent Blank	NA	NA	NA	NA	NA
Inlet Filter Blank	NA	NA	NA	NA	NA
		<b>U1-FF-O-R2</b>	<b>U2-FF-O-R2</b>	<b>U3-FF-O-R2</b>	
<b>Element</b>		<b>RPD</b>	<b>RPD</b>	<b>RPD</b>	
		<b>12233-5</b>	<b>12233-11</b>	<b>12233-17</b>	
<b>Beryllium</b>		NA	NA	NA	
<b>Cadmium</b>		0.0%	5.1%	1.1%	
<b>Lead</b>		2.0%	3.6%	0.2%	

**RESULTS**

2-19

**Table 2-21:  
Quality Control and Quality Assurance – Metals (Continued)**

Run Number	Sample Spike and Recovery					
	FH	BH	A	B	C	
	Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>4</sub>	Empty Impinger	KMnO <sub>4</sub>	HCl	
U1 Inlet R3	#1	90%	98%	107%	99%	89%
	#2	90%	86%	107%	99%	88%
U1 Stack R3	#1	101%	90%	105%	100%	92%
	#2	100%	90%	106%	99%	92%
U2 Inlet R3	#1	106%	91%	103%	103%	90%
	#2	106%	90%	103%	104%	90%
U2 Stack R3	#1	94%	85%	104%	92%	90%
	#2	95%	86%	103%	91%	91%
U3 Inlet R3	#1	99%	85%	97%	92%	93%
	#2	96%	83%	95%	91%	92%
U3 Stack R3	#1	98%	88%	105%	95%	90%
	#2	99%	88%	103%	94%	90%
	Element	U1-FF-O-R3 Recovery	U2-FF-O-R3 Recovery	U3-FF-O-R3 Recovery		
		12233-6	12233-12	12233-18		
	Beryllium	81%	82%	86%		
	Cadmium	87%	89%	93%		
	Lead	99%	100%	103%		
	Second Source Calibration Verification					
Element	.25 ppb	1 ppb	50 ppb	100 ppb	250 ppb	
	QC Std 8	QC Std 2	QC Std 5	QC Std 4	QC Std 3	
Beryllium	104%	110%	103%	108%	104%	
Cadmium		112%	105%	110%	104%	
Lead		105%	99%	104%	99%	

**RESULTS**

**Table 2-22:  
Quality Control and Quality Assurance – Method and Field Blanks**

Method 29		Average Total Catch ug	FH Front Half	BH H <sub>2</sub> O <sub>2</sub> /HNO <sub>4</sub>	A Empty Impinger	B KMnO <sub>4</sub>	C HCl
Reagent Blank	#1	< 0.5	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
Inlet Filter Blank	#1	< 0.5	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.2	< 0.2	< 0.5	< 0.4

Method 23	0_6688_MB001	Field Blank
	pg	pg
<b>Totals</b>		
TCDDs	0	2.77
PeCDDs	0	0
HxCDDs	0	6.32
HpCDDs	2.69	5.45
OCDD	0	10.2
TCDFs	0	0
PeCDFs	0	0
HxCDFs	7.91	0
HpCDFs	12.3	1.72
OCDF	8.74	0
Total PCDD/Fs (ND=0; EMPC=0)	31.6	26.5
Total PCDD/Fs (ND=0; EMPC=EMPC)	40.5	35.4
Total PCDD/Fs (2378-X ND=DL; EMPC=EMPC)	49.8	47.0
Total 2378s (ND=0; EMPC=0)	12.3	15.6
Total 2378s (ND=0.5; EMPC=0)	34.4	29.0
Total 2378s (ND=1; EMPC=0)	56.5	42.3
Total 2378s (ND=0; EMPC=1)	12.3	15.6
Total 2378s (ND=0.5; EMPC=1)	34.4	29.0
Total 2378s (ND=1; EMPC=1)	56.5	42.3



**RESULTS**

2-21

**Table 2-23:  
Quality Control and Quality Assurance - Miscellaneous**

<b>Blanks</b>	<b>Result</b>	
Acetone (g)	<0.0001	
HCl DI H <sub>2</sub> O (mg/l)	<0.024	
HCl 0.1 N H <sub>2</sub> SO <sub>4</sub> (mg/l)	<0.024	
HF DI H <sub>2</sub> O (mg/l)	<0.006	
<b>Meters - Post Cal</b>	<b>Result</b>	<b>Limit</b>
61-6	-0.9%	≤ ± 5%
61-7	3.6%	≤ ± 5%
61-8	-3.4%	≤ ± 5%
66-6	-1.7%	≤ ± 5%
66-7	2.3%	≤ ± 5%
66-11	-0.9%	≤ ± 5%
66-16	3.4%	≤ ± 5%
66-22	-1.1%	≤ ± 5%

---

*End of Section 2 – Results*

**DESCRIPTION OF INSTALLATION**

3-1

**PROCESS DESCRIPTION**

The South Broward Resource Recovery facility operates three (3) 750-tons-per-day municipal refuse-fired, water-wall boiler trains. The trains were manufactured by Babcock and Wilcox to produce electricity for sale to a local utility company. The boilers are rated at a maximum steam flow of 192,000 lbs/hr. Each boiler is equipped with an SDA for acid gas removal, followed by an FF baghouse for the control of particulate emissions and selective non-catalytic reduction for NO<sub>x</sub> control. The control equipment is manufactured by Wheelabrator Air Pollution Control, Inc.

A carbon injection system was recently installed at South Broward for mercury control. All pertinent equipment for the carbon injection system was supplied by Chemco Systems of Monongahela, Pennsylvania, with the carbon rate scales being supplied by Merrick Industries of Lynn Haven, Florida. Each FF baghouse is followed by an induced draft fan that directs the flue gas to a dedicated flue in a common stack.

Figure 3-1 shows a general schematic of the facility. The general sampling locations for the Units 1, 2 and 3 SDA Inlets and FF Outlets are shown in Figure 3-2 on page 3-2.




Figure 3-1: General Process Schematic

**DESCRIPTION OF INSTALLATION**

3-2




Figure 3-2: Process Schematic

**DESCRIPTION OF INSTALLATION**

3-3

CleanAir

**Table 3-1:  
 Unit 1 Compliance Test Process Data**

PLANT NAME: SOUTH BROWARD					Data from DCS Printouts							Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCl	1	1	3/24/2008	0619	0719	184.5	315.0	5.7	493.0	36.0	29.0	7.1	19.8	1.090	0.941	398.6	All times based on CEMS time
		2	3/24/2008	0755	0855	183.6	314.8	5.8	495.1	36.3	29.0	7.3	19.8	1.090	0.941	411.0	
		3	3/24/2008	0954	1056	184.2	315.1	5.8	490.7	34.8	27.5	7.3	20.7	1.090	0.941	409.9	
		Avg				184.1	315.0	5.7	492.9	35.7	28.5	7.2	20.1	1.090	0.941	406.5	
M-29/5 Metals PM	1	1	3/25/2008	0606	0819	186.6	318.2	5.7	493.7	35.5	29.7	5.8	20.5	1.090	0.941	329.2	All times based on CEMS time
		2	3/25/2008	0841	1052	184.3	315.2	5.8	492.6	34.9	28.4	6.5	20.6	1.090	0.941	368.7	
		3	3/25/2008	1116	1330	184.1	315.8	5.8	503.0	38.4	32.7	5.7	16.0	1.099	1.039	357.2	
		Avg				185.0	316.4	5.8	496.4	36.3	30.2	6.0	19.0	1.093	0.974	351.7	
M-13B HF	1	1	3/24/2008	0924	1039	183.8	315.1	5.8	489.6	34.2	26.9	7.3	21.0	1.090	0.941	411.6	All times based on CEMS time
		2	3/24/2008	1117	1227	184.3	315.0	5.6	489.5	33.5	26.3	7.2	21.4	1.090	0.941	408.2	
		3	3/24/2008	1245	1406	184.6	314.9	5.7	486.9	32.1	24.8	7.4	22.4	1.090	0.941	415.5	
		Avg				184.2	315.0	5.7	488.7	33.3	26.0	7.3	21.6	1.090	0.941	411.8	
M-29 Mercury	1	4	3/26/2008	0546	0822	176.1	315.0	5.7	500.3	38.9	31.9	7.0	17.7	1.094	0.985	413.1	All times based on CEMS time
		5	3/26/2008	0859	1141	184.1	315.0	5.7	497.4	36.3	28.7	7.6	20.9	1.094	0.985	450.3	
		6	3/26/2008	1203	1413	183.8	315.0	5.9	501.6	37.6	27.5	10.1	26.7	1.094	0.985	596.3	
		Avg				181.3	315.0	5.8	499.8	37.6	29.4	8.2	21.7	1.094	0.985	486.6	

**DESCRIPTION OF INSTALLATION**

3-4

CleanAir

**Table 3-2:  
 Unit 2 Compliance Test Process Data**

PLANT NAME: SOUTH BROWARD					Data From DCS Printouts							Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow kibs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	Slurry CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCl	2	1	3/26/2008	0606	0706	183.4	314.9	7.3	517.4	41.7	34.9	6.9	16.5	1.093	0.974	400.9	All times based on CEMS time
		2	3/26/2008	0732	0832	185.8	314.8	7.2	518.2	41.2	34.5	6.8	16.5	1.094	0.985	400.1	
		3	3/26/2008	0921	1021	185.2	314.5	7.0	518.1	40.8	33.7	7.1	17.1	1.094	0.985	419.0	
		<b>Avg</b>				184.8	314.7	7.1	517.9	41.3	34.3	6.9	16.7	1.094	0.981	406.7	
M-29/5 Metals PM	2	1	3/24/2008	0619	0947	182.3	315.2	8.4	525.0	36.3	29.2	7.2	15.5	1.090	0.941	404.3	All times based on CEMS time
		2	3/24/2008	1122	1333	184.5	327.7	7.3	517.6	38.0	34.2	3.8	20.9	1.090	0.941	215.1	
		3	3/24/2008	1400	1611	183.0	326.6	7.8	528.1	41.3	41.5	-0.1	17.6	1.090	0.941	-6.2	
		<b>Avg</b>				183.3	323.2	7.8	523.6	38.5	34.9	3.6	18.0	1.090	0.941	204.4	
M-13B HF	2	1	3/25/2008	1103	1212	183.1	322.1	7.0	505.8	34.5	30.0	4.6	18.5	1.090	0.941	256.9	All times based on CEMS time
		2	3/25/2008	1236	1347	184.4	319.4	7.0	509.2	36.3	31.7	4.6	17.7	1.099	1.039	283.6	
		3	3/25/2008	1420	1531	184.5	316.5	7.0	511.5	36.8	32.6	4.2	16.5	1.099	1.039	258.7	
		<b>Avg</b>				184.0	319.3	7.0	508.8	35.9	31.4	4.4	17.6	1.096	1.006	266.4	
M-29 Mercury	2	4	3/25/2008	0613	0820	186.6	317.9	7.2	512.4	39.1	32.0	7.0	18.6	1.090	0.941	395.8	All times based on CEMS time
		5	3/25/2008	0851	1107	184.3	315.5	6.9	502.8	35.5	29.2	6.3	20.2	1.090	0.941	352.9	
		6	3/25/2008	1134	1349	183.7	321.2	7.0	509.0	36.0	31.4	4.6	18.0	1.099	1.039	283.6	
		<b>Avg</b>				184.9	318.2	7.0	508.1	36.8	30.9	5.9	18.9	1.093	0.974	344.1	

**DESCRIPTION OF INSTALLATION**

3-5

CleanAir

**Table 3-3:  
 Unit 3 Compliance Test Process Data**

PLANT NAME: SOUTH BROWARD					Data From DCS Printouts							Calculated		Lime Feed Rate			Test Run Comments
Test	Unit No.	Run No.	Date	Time		Steam Flow klbs/hr	FF Inlet Temp deg F	Fabric Filter Delta In. H2O	SDA Inlet Temp deg F	Total SDA Flow gpm	Diluton H2O flow gpm	Slurry Flow gpm	Slurry Conc. %	Slurry Specific Gravity	CaO Density lb/gal	CaO Flow lbs/hr	
				Start	Stop												
M-26A HCl	3	1	3/25/2008	0617	0728	182.8	315.5	6.4	485.0	37.4	31.1	6.3	22.6	1.090	0.941	356.3	All times based on CEMS time
		2	3/25/2008	0754	0854	183.6	314.3	6.5	480.7	35.0	27.5	7.5	23.9	1.090	0.941	422.9	
		3	3/25/2008	0922	1022	184.4	313.8	6.2	484.4	36.6	28.9	7.6	23.7	1.090	0.941	430.2	
		Avg				183.6	314.5	6.4	483.3	36.3	29.1	7.1	23.4	1.090	0.941	403.1	
M-29/5 Metals PM	3	1	3/24/2008	0622	0836	184.1	318.5	6.4	477.5	46.2	39.1	7.1	23.7	1.090	0.941	399.7	All times based on CEMS time
		2	3/24/2008	0912	1126	184.3	315.2	6.2	480.4	37.0	31.5	5.5	21.8	1.090	0.941	310.0	
		3	3/24/2008	1208	1424	184.3	320.3	6.3	479.4	32.7	30.1	2.7	24.3	1.090	0.941	149.6	
		Avg				184.2	318.0	6.3	479.1	38.6	33.6	5.1	23.3	1.090	0.941	286.4	
M-23 dioxins	3	1	3/24/2008	1037	1522	184.0	318.6	6.3	482.7	34.8	30.0	4.8	22.6	1.090	0.941	268.7	All times based on CEMS time
		2	3/25/2008	0603	1038	183.1	315.4	6.4	483.7	36.6	30.3	6.3	23.0	1.090	0.941	358.0	
		3	3/25/2008	1058	1534	181.9	316.1	6.4	487.7	37.4	33.4	4.0	20.2	1.099	1.039	251.2	
		Avg				183.0	316.7	6.4	484.7	36.3	31.2	5.0	22.0	1.093	0.974	292.6	
M-13B HF	3	1	3/26/2008	0630	0741	184.1	315.0	6.3	466.2	31.0	23.6	7.4	23.8	1.093	0.974	431.3	All times based on CEMS time
		2	3/26/2008	0757	0907	184.3	315.4	6.5	478.4	35.5	28.2	7.3	21.2	1.094	0.985	433.2	
		3	3/26/2008	0926	1036	184.3	314.8	6.2	490.9	39.4	31.8	7.6	19.3	1.094	0.985	447.4	
		Avg				184.2	315.1	6.3	478.5	35.3	27.9	7.4	21.4	1.094	0.981	437.3	
M-29 Mercury	3	4	3/26/2008	0545	0759	185.5	314.9	6.3	469.0	31.8	24.4	7.4	23.2	1.093	0.974	430.7	All times based on CEMS time
		5	3/26/2008	0817	1030	184.0	315.1	6.4	488.8	39.2	31.8	7.4	19.2	1.094	0.985	438.5	
		6	3/26/2008	1055	1306	184.0	314.9	6.4	478.8	33.9	24.8	9.2	27.3	1.904	0.985	542.5	
		Avg				184.5		6.4	478.9	35.0	27.0	8.0	23.2	1.364	0.981	470.6	

**DESCRIPTION OF INSTALLATION**

**DESCRIPTION OF SAMPLING LOCATIONS**

Sampling point locations were determined according to EPA Method 1.

Table 3-4 outlines the sampling point configurations. Figures 3-3 through 3-5, on pages 3-7 through 3-9, illustrate the sampling points and orientation of sampling ports for each of the sources that were tested in the program.


**Table 3-4:  
Sampling Points**

Location	Constituent	Method	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
<u>Units 1,2 and 3 SDA Inlets</u>								
	Hydrogen Chloride	26A <sup>1</sup>	1-3	1	1	60	60	3-3
	Mercury	29	1-3	1	1	5	120	3-4
<u>Units 1,2 and 3 FF Outlets</u>								
	Particulate, Be, Cd, Pb and Hg	5/29 <sup>2</sup>	1-3	5	5	5	125	3-5
	Hydrogen Chloride	26A <sup>1</sup>	1-3	1	1	60	60	NA
	Fluorides	13B	1-3	5	5	2.5	62.5	3-5
	PCDDs/PCDFs (Unit 1 only)	23	1-3	5	5	10	250	3-5

<sup>1</sup> Hydrogen chloride inlet testing utilized a modification of EPA Method 26A (single point constant sampling rate).

<sup>2</sup> FF Outlet metals testing was done in conjunction with EPA Method 5 particulate sampling.

**DESCRIPTION OF INSTALLATION**  
**DESCRIPTION OF SAMPLING LOCATIONS (CONTINUED)**



Sampling Point  
1

Port to Point Distance (in.)  
approximate center

Equivalent diameters to upstream disturbance: 2.0  
Equivalent diameters to downstream disturbance: 0.5


Limit: 2.0  
Limit: 0.5

**Figure 3-3: SDA Inlets - Sampling Point Determination (HCl Sampling)**  
**(Units 1, 2 and 3 are identical)**



**DESCRIPTION OF INSTALLATION**  
**SAMPLING POINT DETERMINATION (CONTINUED)**

3-8



<u>Sampling Point</u>	<u>Port to Point Distance (in.)</u>
1	102.8
2	98.0
3	92.6
4	86.4
5	78.9
6	67.7
7	37.3
8	26.3
9	18.6
10	12.4
11	7.0
12	2.2


Diameters to upstream disturbance: >2.0  
 Diameters to downstream disturbance: >0.5

Limit: 2.0  
 Limit: 0.5

**Figure 3-4: SDA Inlets - Sampling Point Determination (Hg Sampling)**  
 (Units 1, 2 and 3 are identical)

**DESCRIPTION OF INSTALLATION**  
**DESCRIPTION OF SAMPLING LOCATIONS (CONTINUED)**

3-9



Sampling Point	Port to Point Distance (in.)
1	86.4
2	67.2
3	48.0
4	28.8
5	9.6

Equivalent diameters to upstream disturbance: 2.0      Limit: 2.0  
 Equivalent diameters to downstream disturbance: 0.5      Limit: 0.5

**Figure 3-5: FF Outlets - Sampling Point Determination  
 (Units 1, 2 and 3 are identical)**

*End of Section 3 – Description of Installation*

**METHODOLOGY**

4-1

Clean Air Engineering followed procedures as detailed in EPA Methods 1, 2, 3, 3A, 3B, 4, 5, 9, 13B, 22, 23, mod. 26A and 29. The following table summarizes the methods and their respective sources.

**Table 4-1:  
Summary of Sampling Procedures**

---

Title 40 CFR Part 60 Appendix A

Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
Method 3	"Gas Analysis for the Determination of Dry Molecular Weight"
Method 3A	"Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)"
Method 3B	"Gas Analysis for the Determination of Emission Rate Correction Factor or Excess Air"
Method 5	"Determination of Particulate Matter Emissions from Stationary Sources"
Method 9	"Visual Determination of the Opacity of Emissions from Stationary Sources"
Method 13B	"Determination of Total Fluoride Emissions from Stationary Sources (Specific Ion Electrode Method)"
Method 23	"Determination of Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans from Municipal Waste Conductors"
Method 22	"Visual Determination of Fugitive Emissions from Material Sources and Smoke Emissions from Flares"
Mod.Method 26A <sup>1</sup>	"Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources Isokinetic Method"
Method 29	"Determination of Metals Emissions from Stationary Sources"

---

<sup>1</sup> Method 26A was modified at the inlet using single point constant sampling rate, and at the outlet it was done in conjunction with Method 5.

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and on the World Wide Web at <http://www.cleanair.com>.

Diagrams of the sampling apparatus and major specifications of the sampling, recovery and analytical procedures are summarized for each method in Appendix A.

CleanAir followed specific quality assurance and quality control (QA/QC) procedures as outlined in the individual methods and in EPA "Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III Stationary Source-Specific Methods", EPA/600/R-94/038C. Additional QA/QC methods, as prescribed in CleanAir's internal Quality Manual, were also followed. Results of all QA/QC activities performed by CleanAir are summarized in Appendix E.

---

*End of Section 4 – Methodology*

**APPENDIX**

TEST METHOD SPECIFICATIONS.....	A
SAMPLE CALCULATIONS.....	B
PLANT DATA.....	C
PARAMETERS.....	D
QA/QC DATA.....	E
FIELD DATA.....	F
FIELD DATA PRINTOUTS.....	G
LABORATORY DATA.....	H
PERTINENT CERTIFICATIONS.....	I
CLARIFICATIONS.....	J

WHEELABRATOR SOUTH BROWARD, INC.  
FT. LAUDERDALE, FL

CleanAir Project No: 10735-4

**TEST METHOD SPECIFICATIONS**

**A**

**This Page Intentionally Left Blank**

## Specification Sheet for

## EPA Method 5/29

Source Location Name(s) Units 1, 2 and 3 FF Outlets  
 Pollutant(s) to be Determined Particulate Matter (PM) and Trace Metals (including Mercury)  
 Other Parameters to be Determined from Train Gas Density, Moisture, Flow Rate

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Pollutant Sampling Information</b>		
Duration of Run	N/A	125 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	5 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
<b>Sampling Probe</b>		
Nozzle Material	Borosilicate or Quartz Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
<b>Velocity Measuring Equipment</b>		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.812
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
<b>Metering System Console</b>		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
<b>Filter Description</b>		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Teflon (or other non-metallic material)	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Quartz or Fiberglass Fiber	Quartz Fiber
<b>Other Components</b>		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A


## Specification Sheet for

## EPA Method 5/29

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Impinger Train Description</b>		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	7	7
<b>Impinger Stem Types</b>		
Impinger 1	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 2	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 3	Greenburg-Smith	Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 6	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 7	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 8	Modified Greenburg-Smith	Modified Greenburg-Smith
<b>Gas Density Determination</b>		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	CEM
<b>Sample Recovery Information</b>		
Probe Brush Material	Non-metallic swab or bristle	Teflon Mat
Probe Rinse Reagent	Acetone/0.1N Nitric Acid	Acetone/0.1N. Nitric Acid
Probe Rinse Wash Bottle Material	Glass or Teflon	Teflon
Probe Rinse Storage Container	See Method 29 Recovery Flow Chart	See Recovery Flow Chart
Filter Recovered?	Yes	Yes
Filter Storage Container	Petri Dish - Glass or Polystyrene	Glass
Impinger Contents Recovered?	Yes	Yes
Impinger Rinse Reagent	See Method 29 Recovery Flow Chart	See Recovery Flow Chart
Impinger Wash Bottle	Glass or Teflon	Teflon
Impinger Storage Container	See Recovery Flow Chart	See Recovery Flow Chart
<b>Analytical Information</b>		
Method 4 H <sub>2</sub> O Determination by	Volumetric or Gravimetric	Gravimetric and Volumetric
Filter Preparation Conditions	See Method 29 Analytical Flow Chart	For Metals Analysis
Front-Half Rinse Preparation	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Back-Half Analysis	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Additional Analysis	Gravimetric (EPA Method 5)	Gravimetric (EPA Method 5)




## EPA Method 5/29 Sampling Train Configuration



### Impinger Contents

Impinger 1	Empty
Impinger 2	100 ml 5% HNO <sub>3</sub> / 10% H <sub>2</sub> O <sub>2</sub>
Impinger 3	100 ml 5% HNO <sub>3</sub> / 10% H <sub>2</sub> O <sub>2</sub>
Impinger 4	Empty
Impinger 5	100 ml 4% KMnO <sub>4</sub> / 10% H <sub>2</sub> SO <sub>4</sub>
Impinger 6	100 ml 4% KMnO <sub>4</sub> / 10% H <sub>2</sub> SO <sub>4</sub>
Impinger 7	Silica Gel

# EPA Method 29 SDA Inlet Sampling Train Configuration



### Impinger Contents

Impinger 1	Empty
Impinger 2	100 ml 5% HNO <sub>3</sub> / 10% H <sub>2</sub> O <sub>2</sub>
Impinger 3	100 ml 5% HNO <sub>3</sub> / 10% H <sub>2</sub> O <sub>2</sub>
Impinger 4	Empty
Impinger 5	100 ml 4% KMnO <sub>4</sub> / 10% H <sub>2</sub> SO <sub>4</sub>
Impinger 6	100 ml 4% KMnO <sub>4</sub> / 10% H <sub>2</sub> SO <sub>4</sub>
Impinger 7	Silica Gel

## Specification Sheet for EPA Method 29

Source Location Name(s) Units 1,2 and 3 SDA Inlets  
 Pollutant(s) to be Determined Trace Metals (including Mercury)  
 Other Parameters to be Determined from Train Gas Density, Moisture, Flow Rate


	Standard Method Specification	Actual Specification Used
<b>Pollutant Sampling Information</b>		
Duration of Run	N/A	120 minutes
No. of Sample Traverse Points	N/A	24
Sample Time per Point	N/A	5 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
<b>Sampling Probe</b>		
Nozzle Material	Borosilicate or Quartz Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	10'
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
<b>Velocity Measuring Equipment</b>		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.82
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe
<b>Metering System Console</b>		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
<b>Filter Description</b>		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Teflon (or other non-metallic)	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Quartz or Glass Fiber	Quartz Fiber
<b>Other Components</b>		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

## Specification Sheet for

## EPA Method 29


	<b>Standard Method Specification</b>	<b>Actual Specification Used</b>
<b>Impinger Train Description</b>		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	7	7
Impinger Stem Types		
Impinger 1	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 2	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 3	Greenburg-Smith	Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 6	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 7	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 8		
<b>Gas Density Determination</b>		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	CEM
<b>Sample Recovery Information</b>		
Probe Brush Material	Non-metallic swab or bristle	Teflon Mat
Probe Rinse Reagent	0.1N Nitric Acid	0.1 N Nitric Acid
Probe Rinse Wash Bottle Material	Glass or Teflon	Teflon
Probe Rinse Storage Container	Polyethylene or glass	Polyethylene
Filter Recovered?	Yes	Yes
Filter Storage Container	Petri Dish - Glass or Polystyrene	Polyethylene
Impinger Contents Recovered?	Yes	Yes
Impinger Rinse Reagent	See Method 29 Recovery Flow Chart	See Recovery Flow Chart
Impinger Wash Bottle	Glass or Teflon	Teflon
Impinger Storage Container	See Recovery Flow Chart	See Recovery Flow Chart
<b>Analytical Information</b>		
Method 4 H <sub>2</sub> O Determination by	Volumetric or Gravimetric	Gravimetric and Volumetric
Filter Preparation Conditions	See Method 29 Analytical Flow Chart	For Metals Analysis
Front-Half Rinse Preparation	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Back-Half Analysis	See Method 29 Analytical Flow Chart	See Analytical Flow Chart
Additional Analysis	None	None

## EPA Method 29 Glassware Preparation Procedures




## EPA Method 29 Sample Recovery Flowchart (includes Mercury and Particulate Matter)

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)
- Collect one complete blank set per field test



**EPA Method 29**  
**Analytical Flowchart**  
 (Includes Mercury and Particulate Matter)



## Specification Sheet for EPA Method 13B

Source Location Name(s) Units 1 ,2 and 3 FF Outlets  
 Pollutant(s) to be Determined Total Fluoride (F)  
 Other Parameters to be Determined from Trai Gas Density, Moisture, Flow Rate

### Pollutant Sampling Information

	Standard Method Specification	Actual Specification Used
Duration of Run	N/A	62.5 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	2.5 minutes
Sampling Rate	Isokinetic (90-110%) 1 cfm maximum	Isokinetic (90-110%) 1 cfm maximum

### Sampling Probe

	Standard Method Specification	Actual Specification Used
Nozzle Material	Stainless Steel or Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Stainless Steel or Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F (optional)	248°F±25°F

### Velocity Measuring Equipment

	Standard Method Specification	Actual Specification Used
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.825
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe

### Metering System Console

	Standard Method Specification	Actual Specification Used
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid

### Filter Description

	Standard Method Specification	Actual Specification Used
Filter Location	Exit of Probe or Between 3rd and 4th impingers	Exit of Probe
Filter Holder Material	Borosilicate Glass or Stainless Steel	Borosilicate Glass
Filter Support Material	Stainless Steel if filter at probe exit; Glass Frit if filter after 3rd impinger	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F if after probe, unheated if after 3rd imp.	248°F±25°F
Filter Material	Low F Quartz or Fiberglass if after probe, Whatman No. 1 if after 3rd impinger	Whatman No. 1 (Ashless)

### Other Components

	Standard Method Specification	Actual Specification Used
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A



## Specification Sheet for

## EPA Method 13B

### Impinger Train Description

Type of Glassware Connections  
 Connection to Probe or Filter by  
 Number of Impingers  
 Impinger Stem Types  
   Impinger 1  
   Impinger 2  
   Impinger 3  
   Impinger 4  
   Impinger 5  
   Impinger 6  
   Impinger 7  
   Impinger 8

### Gas Density Determination

Sample Collection  
 Sample Collection Medium  
 Sample Analysis

### Sample Recovery Information

Probe Brush Material  
 Probe Rinse Reagent  
 Probe Rinse Wash Bottle Material  
 Probe Rinse Storage Container  
 Filter Recovered?  
 Filter Storage Container  
 Impinger Contents Recovered?  
 Impinger Rinse Reagent  
 Impinger Wash Bottle  
 Impinger Storage Container

### Analytical Information

Method 4 H<sub>2</sub>O Determination by  
 Filter Preparation Conditions  
 Front-Half Rinse Preparation  
 Back-Half Analysis  
 Additional Analysis

### Standard Method Specification

Ground Glass or Equivalent  
 Direct Glass Connection  
 4

Modified Greenburg-Smith  
 Greenburg-Smith  
 Modified Greenburg-Smith  
 Modified Greenburg-Smith

Multi-point integrated  
 Flexible Gas Bag  
 Orsat or Fyrite Analyzer

Nylon Bristle  
 Deionized distilled water  
 Glass or Polyethylene  
 Polyethylene  
 Yes  
 Polyethylene  
 Yes  
 Deionized Distilled Water  
 Glass or Polyethylene  
 Polyethylene

Volumetric or Gravimetric  
 See analytical flow chart  
 See analytical flow chart  
 Ion Specific Electrode  
 N/A

### Actual Specification Used

Screw Joint with Silicone Gasket  
 Direct Glass Connection  
 4


Modified Greenburg-Smith  
 Greenburg-Smith  
 Modified Greenburg-Smith  
 Modified Greenburg-Smith

Multi-Point Integrated  
 Vinyl Bag  
 CEM

Nylon Bristle  
 Deionized Distilled Water  
 Teflon  
 Polyethylene  
 Yes  
 Polyethylene  
 Yes  
 Deionized Distilled Water  
 Teflon  
 Polyethylene

Gravimetric and Volumetric  
 See Analytical Flow Chart  
 See Analytical Flow Chart  
 Ion Chromatography  
 None


# EPA Method 13B Sampling Train Configuration



### Impinger Contents


Impinger 1	100 ml DI H <sub>2</sub> O
Impinger 2	100 ml DI H <sub>2</sub> O
Impinger 3	Empty
Impinger 4	Silica Gel

## EPA Method 13B Glassware Preparation Procedures




## EPA Method 13B Sample Recovery Flowchart

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)



# EPA Method 13B Analytical Flowchart



## Specification Sheet for

## EPA Method 23

Source Location Name(s)  
Pollutant(s) to be Determined  
Other Parameters to be Determined from Train

Unit 1 FF Outlet  
Polychlorinated Dibenzo-p-Dioxins and Polychlorinated Dibenzofurans (PCDD/PCDF)  
Gas Density, Moisture, Flow Rate

### Pollutant Sampling Information

	Standard Method Specification	Actual Specification Used
Duration of Run	N/A	250 minutes
No. of Sample Traverse Points	N/A	25
Sample Time per Point	N/A	10 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)

### Sampling Probe

	Standard Method Specification	Actual Specification Used
Nozzle Material	Nickel, Quartz, Stainless Steel or Glass	Borosilicate Glass
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Borosilicate Glass
Effective Probe Length	N/A	8 feet
Probe Temperature Set-Point	248°F±25°F	248°F±25°F

### Velocity Measuring Equipment

	Standard Method Specification	Actual Specification Used
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.833
Pitot Tube Calibration by	Geometric or Wind Tunnel	Wind-Tunnel
Pitot Tube Attachment	Attached to Probe	Attached to Probe

### Metering System Console

	Standard Method Specification	Actual Specification Used
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid

### Filter Description

	Standard Method Specification	Actual Specification Used
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Borosilicate Glass	Borosilicate Glass
Filter Support Material	Glass Frit	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Glass Fiber - Toluene Extracted	Glass Fiber - Toluene Extracted

### Other Components


	Standard Method Specification	Actual Specification Used
Adsorbent Module	XAD-2 Trap	XAD-II Adsorbent Trap
Location	After filter and condenser	After filter and condenser
Operating Temperature	< 68°F	<68°F

## Specification Sheet for

## EPA Method 23

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Impinger Train Description</b>		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	5	5
<b>Impinger Stem Types</b>		
Impinger 1	Modified Greenburg-Smith	Shortened Stem (open tip)
Impinger 2	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 3	Greenburg-Smith	Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 6		
Impinger 7		
Impinger 8		
<b>Gas Density Determination</b>		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	CEM
<b>Sample Recovery Information</b>		
Probe Brush Material	Inert Bristle	Teflon Mat
Probe Rinse Reagent	Acetone/Methylene Chloride/Toluene	Acetone/Toluene (see Appendix J)
Probe Rinse Wash Bottle Material	Glass or Teflon	Teflon
Probe Rinse Storage Container	Glass	Glass
Filter Recovered?	Yes	Yes
Filter Storage Container	Petri Dish - Glass or Polystyrene	Glass
Impinger Contents Recovered?	No	Archived
Impinger Rinse Reagent	N/A	HPLC Water
Impinger Wash Bottle	N/A	Teflon
Impinger Storage Container	N/A	Polyethylene
<b>Analytical Information</b>		
Method 4 H <sub>2</sub> O Determination by	Volumetric or Gravimetric	Gravimetric
Filter Preparation Conditions	See Method 23 Analytical Flow Chart	For Organic Analysis
Front-Half Rinse Preparation	See Method 23 Analytical Flow Chart	Organic Analysis
Back-Half Analysis	N/A	Archive
Additional Analysis	None	None

# EPA Method 23 Sampling Train Configuration




Impinger Contents

Impinger 1	Empty
Impinger 2	100 ml HPLC H <sub>2</sub> O
Impinger 3	100 ml HPLC H <sub>2</sub> O
Impinger 4	Empty
Impinger 5	Silica Gel




## EPA Method 23 Glassware Preparation Procedures




## EPA Method 23 Sample Recovery Flowchart

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)



## EPA Method 23 Analytical Flowchart

- Log each sample in shipment and verify against chain-of-custody sheet
- Note liquid levels in the sample containers and confirm on the chain-of-custody sheet condition
- All samples must be extracted within 30 days of collection
- All samples must be analyzed within 45 days of extraction
- All laboratory glassware must be cleaned as described in Section 3A of the "Manual of Analytical Methods for the Analysis of Pesticides"



## Specification Sheet for

## EPA Method 26A (modified)

Note: Modification includes the use of full-size impingers instead of midget impingers.

Source Location Name(s) Units 1-3 SDA Inlets and Units 1-3 FF Outlets  
 Pollutant(s) to be Determined Hydrogen Chloride (HCl)  
 Other Parameters to be Determined from Train Gas Density, Moisture


	Standard Method Specification	Actual Specification Used
<b>Pollutant Sampling Information</b>		
Duration of Run	N/A	60 minutes
No. of Sample Traverse Points	N/A	1
Sample Time per Point	N/A	60 minutes
Sampling Rate	Constant Rate ( $\pm 10\%$ )	Constant Rate ( $\pm 10\%$ )
<b>Sampling Probe</b>		
Nozzle Material	N/A	None
Nozzle Design	N/A	N/A
Probe Liner Material	Borosilicate Glass	Borosilicate Glass
Effective Probe Length	N/A	5 feet
Probe Temperature Set-Point	>248°F	350°F @ Inlet, Stack Temp @ FF Outlet
<b>Velocity Measuring Equipment</b>		
Pitot Tube Design	None	None
Pitot Tube Coefficient	N/A	N/A
Pitot Tube Calibration by	N/A	N/A
Pitot Tube Attachment	N/A	N/A
<b>Metering System Console</b>		
Meter Type	Dry Gas Meter or Critical Orifice	Dry Gas Meter
Meter Accuracy	$\pm 2\%$	$\pm 1\%$
Meter Resolution	N/A	0.01 cubic feet
Meter Size	2 liters/minute	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter	Wet Test Meter
Pump Type	Diaphragm or equivalent	Rotary Vane
Temperature Measurements	Dial Thermometer or equivalent	Type K Thermocouple/Pyrometer
Temperature Resolution	2°F-5.4°F	1.0°F
$\Delta P$ Differential Pressure Gauge	N/A	N/A
$\Delta H$ Differential Pressure Gauge	N/A	Inclined Manometer
Barometer	Mercury, aneroid or other.	Digital Barometer calibrated w/Mercury Aneroid
<b>Filter Description</b>		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Teflon or Quartz	Borosilicate Glass
Filter Support Material	Teflon Frit	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	>248°F	350°F @ Inlet, Stack Temp @ FF Outlet
Filter Material	Teflon/Glass Mat (Quartz, Optional High Temp>410F)	Quartz Fiber @ Inlet, Teflon on Glass @ Outlet
<b>Other Components</b>		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

## Specification Sheet for

## EPA Method 26A (modified)

	<b>Standard Method Specification</b>	<b>Actual Specification Used</b>
<b>Impinger Train Description</b>		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	5 or 6 (Midget Impingers)	5
<b>Impinger Stem Types</b>		
Impinger 1	Midget Shortened Stem	Shortened Stem (open tip)
Impinger 2	Midget Bubbler	Greenburg-Smith
Impinger 3	Midget Bubbler	Greenburg-Smith
Impinger 4	Midget Bubbler	Modified Greenburg-Smith
Impinger 5	Midget Bubbler	Modified Greenburg-Smith
Impinger 6	Mae West	
Impinger 7		
Impinger 8		
<b>Gas Density Determination</b>		
Sample Collection	N/A	Single Point Integrated
Sample Collection Medium	N/A	Vinyl Bag
Sample Analysis	N/A	CEM
<b>Sample Recovery Information</b>		
Probe Brush Material	N/A	N/A
Probe Rinse Reagent	N/A	N/A
Probe Rinse Wash Bottle Material	N/A	N/A
Probe Rinse Storage Container	N/A	N/A
Filter Recovered?	No	No
Filter Storage Container	N/A	N/A
Impinger Contents Recovered?	Yes	Yes
Impinger Rinse Reagent	Deionized Distilled Water	Deionized Distilled Water
Impinger Wash Bottle	Polyethylene or glass	Polyethylene
Impinger Storage Container	Polyethylene	Polyethylene
<b>Analytical Information</b>		
Method 4 H <sub>2</sub> O Determination by	N/A	Gravimetric
Filter Preparation Conditions	N/A	N/A
Front-Half Rinse Preparation	N/A	N/A
Back-Half Analysis	Ion Chromatography	Ion Chromatography
Additional Analysis	None	None


## Modified EPA Method 26A Sampling Train Configuration



### Impinger Contents


Impinger 1	50 ml 0.1 N H <sub>2</sub> SO <sub>4</sub>
Impinger 2	100 ml 0.1 N H <sub>2</sub> SO <sub>4</sub>
Impinger 3	100 ml 0.1 N H <sub>2</sub> SO <sub>4</sub>
Impinger 4	Empty
Impinger 5	Silica Gel

## EPA Method 26A Glassware Preparation Procedures



**EPA Method 26**  
**Sample Recovery Flowchart**  
(without Cl<sub>2</sub>)  
(Modified)


- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)





**EPA Method 26  
Analytical Flowchart  
(without Cl2)  
(Modified)**

- Log each sample in shipment and verify against chain-of-custody sheet
- Note liquid levels in the sample containers and confirm on the chain-of-custody sheet condition



**This Page Intentionally Left Blank**

WHEELABRATOR SOUTH BROWARD, INC.  
FT. LAUDERDALE, FL

CleanAir Project No: 10735-4

**SAMPLE CALCULATIONS**

**B**

**This Page Intentionally Left Blank**

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 SDA Inlet

**USEPA Method 29 (Mercury)  
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041509 082539

L

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

$V_{lc}$	= total volume of liquid collected in impingers and silica gel (ml)	=	281.7	ml
0.04706	= ideal gas conversion factor (ft <sup>3</sup> water vapor/ml or gm)	=	0.04706	ft <sup>3</sup> /ml
$V_{wstd}$	= volume of water vapor collected at standard conditions (ft <sup>3</sup> )	=	13.26	ft <sup>3</sup>

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.10	in. Hg
$T_m$	= average dry gas meter temperature (°F)	=	76.92	°F
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	69.46	dcf
$Y_d$	= gas meter correction factor (dimensionless)	=	1.0079	
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.05	in. H <sub>2</sub> O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	69.410	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left( \frac{P_g}{13.6} \right)$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.10	in. Hg
$P_g$	= sample gas static pressure (in. H <sub>2</sub> O)	=	-1.50	in. H <sub>2</sub> O
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.99	in. Hg

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 SDA Inlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left( \frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

$T_s$	= average sample gas temperature (°F)	=	505.38	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
$P_v$	= vapor pressure, actual (in. Hg)	=	29.99	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.99	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.99	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	69.410	dscf
$V_{wstd}$	= volume of water collected at standard conditions (scf)	=	13.26	scf
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.1604	%
		=	16.04	%

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.99	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.99	in. Hg
$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	%
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.1604	
$B_w$	= actual water vapor in gas	=	0.1604	%
		=	16.04	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.7	%
100	= conversion factor (%)	=	100	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.33	%

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 SDA Inlet

## 10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2 + CO)}{(100)}$$

Where:

$M_{CO_2}$	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
$M_{O_2}$	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
$M_{N_2+CO}$	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.7	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.3	%
100	= conversion factor (%)	=	100	%
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	29.98	lb/lb-mole

## 11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.1604	
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	29.98	lb/lb-mole
$M_{H_2O}$	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
$M_s$	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	28.06	lb/lb-mole

## 12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p) \left( \sqrt{\Delta P} \right) \left( \sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

$K_p$	= velocity pressure constant	=	85.49	
$C_p$	= pitot tube coefficient	=	0.82	
$M_s$	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	28.06	lb/lb-mole
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.99	in. Hg
$T_s$	= average sample gas temperature (°F)	=	505.38	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H <sub>2</sub> O)	=	0.651	√in. H <sub>2</sub> O
460	= °F to °R conversion constant	=	460	
$V_s$	= sample gas velocity (ft/sec)	=	48.87	ft/sec



Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 SDA Inlet

## 13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

$A_s$	= cross sectional area of sampling location (ft <sup>2</sup> )	=	60.13	ft <sup>2</sup>
$V_s$	= sample gas velocity (ft/sec)	=	48.87	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	176,323	acfm

## 14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left( \frac{P_s}{29.92} \right) \left( \frac{68 + 460}{T_s + 460} \right)$$

Where:

$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	176,323	acfm
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.99	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
$T_s$	= average sample gas temperature (°F)	=	505.4	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	96,662	scfm

## 15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.1604	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	96,662	scfm
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	81,161	dscfm

16. Dry flow of sample gas corrected to 7%O<sub>2</sub> (dscfm)

$$Q_{std7} = (Q_{std}) \left( \frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	81,161	dscfm
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.7	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
$Q_{std7}$	= volumetric flow rate at STP and 7%O <sub>2</sub> , dry basis (dscfm)	=	65,279	dscfm

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 SDA Inlet

17. Hourly time basis conversion of volumetric flow rate ( $Q_{std}$  example)

$$Q_{std-hr} = (Q_{std-min})(60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	81,161	dscfm
60	= conversion factor (min/hr)	=	60	min/hr

$Q_{std-hr}$	= volumetric flow rate, hourly basis (dscf/hr)	=	4,869,674	dscf/hr
--------------	--	---	-----------	---------

18. Metric Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{std-metric} = (Q_{std-english}) \left( \frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	81,161	dscfm
35.31	= conversion factor (ft <sup>3</sup> /m <sup>3</sup> )	=	35.31	ft <sup>3</sup> /m <sup>3</sup>
60	= conversion factor (min/hr)	=	60	min/hr

$Q_{std-metric}$	= volumetric flow rate, metric units (m <sup>3</sup> /hr)	=	137,912	dry std m <sup>3</sup> /hr
------------------	---	---	---------	----------------------------

19. Standard to Normal Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{Normal} = (Q_{std-metric}) \left( \frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m <sup>3</sup> /hr)	=	137,912	dry std m <sup>3</sup> /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	

$Q_{Normal}$	= volumetric flow rate, metric units (dry Nm <sup>3</sup> /hr)	=	128,509	dry Nm <sup>3</sup> /hr
--------------	--	---	---------	-------------------------

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 SDA Inlet

## 20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\overline{T_s} + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n}{144}\right)^2\left(\frac{\pi}{4}\right)\theta(1 - B_w)}$$

Where:

$D_n$	= diameter of nozzle (in)	=	0.275	in.
$B_w$	= proportion of water vapor in the gas stream by volume	=	0.1604	
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.99	in. Hg
$T_s$	= average sample gas temperature (°F)	=	505.4	°F
$V_{mstd}$	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	69.410	dscf
$V_s$	= sample gas velocity (ft/sec)	=	48.87	ft/sec
$\theta$	= total sampling time (min)	=	120	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
$I$	= percent of isokinetic sampling (%)	=	103.96	%

## 21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{\theta})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

$\theta$	= total sampling time (min)	=	120	min
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	69.46	dcf
$T_m$	= average dry gas meter temperature (°F)	=	76.92	°F
$\Delta H_{\theta}$	= dry gas meter orifice coefficient	=	1.7934	
$P_{bar}$	= barometric pressure (in. Hg)	=	30.10	in. Hg
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.048	in. H <sub>2</sub> O
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	29.98	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.020	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$Y_{qa}$	= alternative Method 5 post-test meter calibration factor	=	0.9740	

## LOGIC FOR TREATING DETECTION LIMITS

(mercury only)

### 1. Logic for Determining Total Blank ( $m_{\text{Total-B}}$ ) from 5 Fractions

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 fractions are ND	<b>CASE 3</b> All 5 fractions are ND
<b>Rule</b>			
$ND = 0$	$m_{\text{Total-B}} = \text{Sum D, 1-5}$	$m_{\text{Total-B}} = \text{Sum D}$	$m_{\text{Total-B}} = < \text{Sum ND}$
$ND = 1x$	$m_{\text{Total-B}} = \text{Sum D, 1-5}$	$m_{\text{Total-B}} = \text{Sum D}$	$m_{\text{Total-B}} = < \text{Sum ND}$
$ND = 0.5x$	$m_{\text{Total-B}} = \text{Sum D, 1-5}$	$m_{\text{Total-B}} = \text{Sum D}$	$m_{\text{Total-B}} = < 0.5 \text{ Sum ND}$

### 2. Logic for Determining Total Sample ( $m_{\text{Total-S}}$ ) from 5 Fractions

	<b>CASE 1</b> All 5 fractions are D.	<b>CASE 2</b> 1 to 4 fractions are ND	<b>CASE 3</b> All 5 fractions are ND
<b>Rule</b>			
$ND = 0$	$m_{\text{Total-S}} = \text{Sum D, 1-5}$	$m_{\text{Total-S}} = \text{Sum D}$	$m_{\text{Total-S}} = < \text{Sum ND}$
$ND = 1x$	$m_{\text{Total-S}} = \text{Sum D, 1-5}$	$m_{\text{Total-S}} = < [\text{Sum D} + \text{Sum ND}]$	$m_{\text{Total-S}} = < \text{Sum ND}$
$ND = 0.5x$	$m_{\text{Total-S}} = \text{Sum D, 1-5}$	$m_{\text{Total-S}} = < [\text{Sum D} + 0.5 \text{ Sum ND}]$	$m_{\text{Total-S}} = < 0.5 \text{ Sum ND}$

### 3. Logic for Determining Maximum Allowable Blank Correction ( $m_{\text{T-B-allow}}$ )

	<b>CASE 1</b> All 5 fractions are D. $m_{\text{Total-B}} = D$	<b>CASE 2</b> 1 to 4 sample fractions are ND $m_{\text{Total-B}} = D$	<b>CASE 3</b> All 5 fractions are ND $m_{\text{Total-B}} = D$	<b>CASE 4</b> Any type of fractions $m_{\text{Total-B}} = ND$
<b>Rule</b>				
$ND = 0$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = 0$	$m_{\text{T-B-allow}} = 0$
$ND = 1x$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = 0$	$m_{\text{T-B-allow}} = 0$
$ND = 0.5x$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = \text{M29 Rule}$	$m_{\text{T-B-allow}} = 0$	$m_{\text{T-B-allow}} = 0$

\* M29 rule using only detected sample quantiles for logical comparisons.

### 4. Logic for Determining Blank-Corrected Sample Amount ( $m_n$ )

	<b>CASE 1</b> All 5 fractions are D. $m_{\text{Total-S}} - m_{\text{T-B-allow}} \geq \text{MIN(MDL)}$	<b>CASE 2</b> 1 to 4 sample fractions are ND $m_{\text{Total-S}} - m_{\text{T-B-allow}} \geq \text{MIN(MDL)}$	<b>CASE 3</b> All 5 fractions are ND $m_{\text{Total-S}}$ and $m_{\text{T-B-allow}}$ anything	<b>CASE 4</b> Any type of fractions $m_{\text{Total-S}} - m_{\text{T-B-allow}} < \text{MIN(MDL)}$
<b>Rule</b>				
$ND = 0$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = < m_{\text{Total-S}}$	$m_n = < \text{MIN(MDL)}$
$ND = 1x$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = < [m_{\text{Total-S}} - m_{\text{T-B-allow}}]$	$m_n = < m_{\text{Total-S}}$	$m_n = < \text{MIN(MDL)}$
$ND = 0.5x$	$m_n = m_{\text{Total-S}} - m_{\text{T-B-allow}}$	$m_n = < [m_{\text{Total-S}} - m_{\text{T-B-allow}}]$	$m_n = < m_{\text{Total-S}}$	$m_n = < \text{MIN(MDL)}$

#### Definitions and Notes

The term "Rule" refers to the rule being implemented for handling non-detectable quantities in summations.

MDL = minimum detection limit.

D = Detectable quantity reported as D.

ND = Non-Detectable quantity reported at a value of ND.

MIN(MDL) = lowest quantity of all detection limits for 5 fractions.

**USEPA Method 29  
 Mercury Analyte Calculations**

**Sample data taken from Run 1**

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

041609 082539  
 P

**1. Total blank amount (µg)**

$$m_{total-B} = \sum_{i=1}^n m_{i-B}$$

Where:

$m_{1b-B}$	= mercury amount in blank for Fraction 1b	=	<0.1000	µg
$m_{2b-B}$	= mercury amount in blank for Fraction 2b	=	<0.3000	µg
$m_{3a-B}$	= mercury amount in blank for Fraction 3a	=	<0.2000	µg
$m_{3b-B}$	= mercury amount in blank for Fraction 3b	=	<0.5000	µg
$m_{3c-B}$	= mercury amount in blank for Fraction 3c	=	<0.4000	µg
$m_{total-B}$	= total amount of mercury in blank	=	<1.5000	µg

**2. Total sample amount (µg)**

$$m_{total-S} = \sum_{i=1}^n m_{i-S}$$

Where:

$m_{1b-S}$	= mercury amount in sample for Fraction 1b	=	61.7408	µg
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	=	39.5721	µg
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	=	<0.0200	µg
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	=	0.7568	µg
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	=	3.0567	µg
$m_{total-S}$	= total amount of mercury in sample	=	105.1263	µg

**3. Allowable blank correction (µg)**

$$m_{T-B-allow} = m_{total-B} \text{ if } m_{total-B} \leq 0.6$$

$$m_{T-B-allow} = MAX [0.6, MIN (m_{total-B}, 0.05 \times m_{total-S})] \text{ if } m_{total-B} > 0.6$$

Where:

$m_{total-B}$	= total amount of mercury in blank	=	<1.5000	µg
$m_{total-S}$	= total amount of mercury in sample	=	105.1263	µg
$0.05 \times m_{total-S}$	= 5% of $m_{total-S}$	=	5.2563	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
$m_{T-B-allow}$	= total allowable blank correction	=	0.0000	µg

NOTE: In this case, the second criteria applies.

4. Sample corrected for allowable blank - Total ( $\mu\text{g}$ )

$$m_n = m_{\text{total-S}} - m_{\text{T-B-allow}}$$

Where:

$m_{\text{total-S}}$	= total amount of mercury in sample	= 105.1263	$\mu\text{g}$
$m_{\text{T-B-allow}}$	= total allowable blank correction	= 0.0000	$\mu\text{g}$
$m_n$	= total mercury in sample corrected for allowable blank	= 105.1263	$\mu\text{g}$

5. Sample corrected for allowable blank - Prorated for each fraction ( $\mu\text{g}$ )

$$m_{n-i} = \left( \frac{m_{i-S}}{m_{\text{total-S}}} \right) (m_n)$$

Where:

$m_n$	= total mercury in sample corrected for allowable blank	= 105.1263	$\mu\text{g}$
$m_{1b-S}$	= mercury amount in sample for Fraction 1b	= 61.7408	$\mu\text{g}$
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	= 39.5721	$\mu\text{g}$
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	= <0.0200	$\mu\text{g}$
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	= 0.7568	$\mu\text{g}$
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	= 3.0567	$\mu\text{g}$
$m_{\text{total-S}}$	= total amount of mercury in sample	= 105.1263	$\mu\text{g}$
$m_{n-1b}$	= mercury corrected for blank - prorated for Fraction 1b	= 61.7408	$\mu\text{g}$
$m_{n-2b}$	= mercury corrected for blank - prorated for Fraction 2b	= 39.5721	$\mu\text{g}$
$m_{n-3a}$	= mercury corrected for blank - prorated for Fraction 3a	= <0.0200	$\mu\text{g}$
$m_{n-3b}$	= mercury corrected for blank - prorated for Fraction 3b	= 0.7568	$\mu\text{g}$
$m_{n-3c}$	= mercury corrected for blank - prorated for Fraction 3c	= 3.0567	$\mu\text{g}$

**USEPA Method 29  
 Mercury Sample Calculations**

**Sample data taken from Run 1**

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041509 082538  
 L.P

**1. Mercury concentration (lb/dscf)**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 105.1263 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 69.4099 dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03 lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06 $\mu\text{g/g}$
$C_{sd}$	= mercury concentration (lb/dscf)	= 3.3396E-09 lb/dscf

**2. Mercury concentration ( $\mu\text{g/dscm}$ )**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 105.1263 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 69.4099 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm
$C_{sd}$	= mercury concentration ( $\mu\text{g/dscm}$ )	= 5.3480E+01 $\mu\text{g/dscm}$

**3. Mercury concentration (mg/dscm)**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{35.31}{1000} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 105.1263 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 69.4099 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm
1000	= conversion factor ( $\mu\text{g/mg}$ )	= 1000 $\mu\text{g/mg}$
$C_{sd}$	= mercury concentration (mg/dscm)	= 5.3480E-02 mg/dscm

4. Mercury concentration ( $\mu\text{g}/\text{Nm}^3$  dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 105.1263 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 69.4099 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm
68	= standard temperature ( $^{\circ}\text{F}$ )	= 68 $^{\circ}\text{F}$
32	= normal temperature ( $^{\circ}\text{F}$ )	= 32 $^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460
$C_{sd}$	= mercury concentration ( $\mu\text{g}/\text{Nm}^3$ dry)	= 5.7393E+01 $\mu\text{g}/\text{Nm}^3$ dry

5. Mercury concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 3.3396E-09 lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0 %
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.7 %
20.9	= oxygen content of ambient air (%)	= 20.9 %
$C_{sdx}$	= mercury concentration corrected to x% oxygen (lb/dscf)	= 4.1521E-09 lb/dscf @ x% $O_2$

6. Mercury concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 3.3396E-09 lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0 %
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	= 10.0 %
$C_{sdy}$	= mercury conc. corrected to y% carbon dioxide (lb/dscf)	= 4.0277E-09 lb/dscf @ y% $CO_2$

7. Mercury concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 3.3396E-09 lb/dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 81,161 dscfm
$Q_a$	= volumetric flow rate at actual conditions (acfm)	= 176,323 acfm
$C_a$	= mercury concentration at actual gas conditions (lb/acf)	= 1.5372E-09 lb/acf



8. Mercury emission rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 105.1263	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 69.4099	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 81,161	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$E_{lb/hr}$	= mercury emission rate (lb/hr)	= 1.6263E-02	lb/hr

9. Mercury emission rate (g/s)

$$E_{g/s} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 105.1263	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 69.4099	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 81,161	dscfm
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60	sec/min
$E_{g/s}$	= mercury emission rate (g/s)	= 2.0487E-03	g/s

10. Mercury emission rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 105.1263	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 69.4099	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 81,161	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2000	lb/Ton
$E_{T/yr}$	= mercury emission rate (Ton/yr)	= 7.1232E-02	Ton/yr

11. Mercury emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 105.1263	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 69.4099	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.7	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$E_{Fd}$	= mercury emission rate - Fd-based (lb/MMBtu)	= 5.9747E-05	lb/MMBtu

12. Mercury emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 105.1263	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 69.4099	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	= 10.0	%
100	= conversion factor	= 100	
$E_{Fc}$	= mercury emission rate - Fc-based (lb/MMBtu)	= 6.1087E-05	lb/MMBtu

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041509 090948

L

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

$V_{lc}$	= total volume of liquid collected in impingers and silica gel (ml)	=	410.6	ml
0.04706	= ideal gas conversion factor (ft <sup>3</sup> water vapor/ml or gm)	=	0.04706	ft <sup>3</sup> /ml
$V_{wstd}$	= volume of water vapor collected at standard conditions (ft <sup>3</sup> )	=	19.32	ft <sup>3</sup>

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.10	in. Hg
$T_m$	= average dry gas meter temperature (°F)	=	75.96	°F
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	70.02	dcf
$Y_d$	= gas meter correction factor (dimensionless)	=	0.9886	
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.05	in. H <sub>2</sub> O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	68.757	dscf
------------	---	---	--------	------

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left( \frac{P_g}{13.6} \right)$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.10	in. Hg
$P_g$	= sample gas static pressure (in. H <sub>2</sub> O)	=	-12.00	in. H <sub>2</sub> O
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left( \frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

$T_s$	= average sample gas temperature (°F)	=	296.00	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
$P_v$	= vapor pressure, actual (in. Hg)	=	29.22	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.22	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	68.757	dscf
$V_{wstd}$	= volume of water collected at standard conditions (scf)	=	19.32	scf
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2194	
		=	21.94	%

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

## 7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.22	in. Hg
$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

## 8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2194	
$B_w$	= actual water vapor in gas	=	0.2194	
		=	21.94	%

## 9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
100	= conversion factor (%)	=	100	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.38	%

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

## 10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2 + CO)}{(100)}$$

Where:

$M_{CO_2}$	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
$M_{O_2}$	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
$M_{N_2+CO}$	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.4	%
100	= conversion factor (%)	=	100	%
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.01	lb/lb-mole

## 11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2194	
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.01	lb/lb-mole
$M_{H_2O}$	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
$M_s$	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.37	lb/lb-mole

## 12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left( \sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

$K_p$	= velocity pressure constant	=	85.49	
$C_p$	= pitot tube coefficient	=	0.81	
$M_s$	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.37	lb/lb-mole
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
$T_s$	= average sample gas temperature (°F)	=	296.00	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H <sub>2</sub> O)	=	0.652	√in. H <sub>2</sub> O
460	= °F to °R conversion constant	=	460	
$V_s$	= sample gas velocity (ft/sec)	=	43.98	ft/sec

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

$A_s$	= cross sectional area of sampling location (ft <sup>2</sup> )	=	64.00	ft <sup>2</sup>
$V_s$	= sample gas velocity (ft/sec)	=	43.98	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	168,899	acfm

14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left( \frac{P_s}{29.92} \right) \left( \frac{68 + 460}{T_s + 460} \right)$$

Where:

$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	168,899	acfm
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
$T_s$	= average sample gas temperature (°F)	=	296.0	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	115,192	scfm

15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2194	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	115,192	scfm
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,921	dscfm

16. Dry flow of sample gas corrected to 7%O<sub>2</sub> (dscfm)

$$Q_{std7} = (Q_{std}) \left( \frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,921	dscfm
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
$Q_{std7}$	= volumetric flow rate at STP and 7%O <sub>2</sub> , dry basis (dscfm)	=	74,201	dscfm

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

17. Hourly time basis conversion of volumetric flow rate ( $Q_{std}$  example)

$$Q_{std-hr} = (Q_{std-min}) (60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	89,921	dscfm
60	= conversion factor (min/hr)	=	60	min/hr

$Q_{std-hr}$	= volumetric flow rate, hourly basis (dscf/hr)	=	5,395,281	dscf/hr
--------------	--	---	-----------	---------

18. Metric Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{std-metric} = (Q_{std-english}) \left( \frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	89,921	dscfm
35.31	= conversion factor (ft <sup>3</sup> /m <sup>3</sup> )	=	35.31	ft <sup>3</sup> /m <sup>3</sup>
60	= conversion factor (min/hr)	=	60	min/hr

$Q_{std-metric}$	= volumetric flow rate, metric units (m <sup>3</sup> /hr)	=	152,798	dry std m <sup>3</sup> /hr
------------------	---	---	---------	----------------------------

19. Standard to Normal Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{Normal} = (Q_{std-metric}) \left( \frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m <sup>3</sup> /hr)	=	152,798	dry std m <sup>3</sup> /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	

$Q_{Normal}$	= volumetric flow rate, metric units (dry Nm <sup>3</sup> /hr)	=	142,380	dry Nm <sup>3</sup> /hr
--------------	--	---	---------	-------------------------



Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

### 20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\bar{T}_s + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n^2(\pi)}{(1.44)(4)}\right)(\theta)(1 - B_w)}$$

Where:

$D_n$	= diameter of nozzle (in)	=	0.268	in.
$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2194	
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
$T_s$	= average sample gas temperature (°F)	=	296.0	°F
$V_{mstd}$	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	68.757	dscf
$V_s$	= sample gas velocity (ft/sec)	=	43.98	ft/sec
$\theta$	= total sampling time (min)	=	125	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
$I$	= percent of isokinetic sampling (%)	=	100.00	%

### 21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{\oplus})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

$\theta$	= total sampling time (min)	=	125	min
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	70.02	dcf
$T_m$	= average dry gas meter temperature (°F)	=	75.96	°F
$\Delta H_{\oplus}$	= dry gas meter orifice coefficient	=	1.7796	
$P_{bar}$	= barometric pressure (in. Hg)	=	30.10	in. Hg
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.048	in. H <sub>2</sub> O
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.01	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.012	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$Y_{qa}$	= alternative Method 5 post-test meter calibration factor	=	1.0014	

**USEPA Method 5/29  
 Filterable Particulate Gravimetric Analysis Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041509 090948  
 1

1. Total residue from gravimetric analysis of filters (g)

$$m_{fr} = \sum_{i=1}^n m_{fi}$$

Where:

$m_{f1}$	= residual mass of filter "1" from gravimetric analysis (g)	= 0.00080 g
$m_{f2}$	= residual mass of filter "2" from gravimetric analysis (g)	= 0.00000 g
$m_{f3}$	= residual mass of filter "3" from gravimetric analysis (g)	= 0.00000 g
$m_{f4}$	= residual mass of filter "4" from gravimetric analysis (g)	= 0.00000 g
$m_{fr}$	= total filter residue from gravimetric analysis (g)	= 0.00080 g

2. Total particulate collected on filters (g)

$$m_{filter} = m_{fr} \text{ if } m_{fr} \geq 0$$

$$m_{filter} = 0 \text{ if } m_{fr} < 0$$

Where:

$m_{fr}$	= total filter residue from gravimetric analysis (g)	= 0.00080 g
$m_{filter}$	= total particulate collected on filters (g)	= 0.00080 g

3. Solvent rinse - sample residue mass (g)

$$r_{si} = r_{ai} \left( \frac{v_{si}}{v_{ai}} \right)$$

Where:

$r_{ai}$	= aliquot residue mass for solvent "i" (g)	= 0.00010 g	Acetone
$v_{si}$	= sample liquid volume for solvent rinse "i" (ml)	= 118.0 ml	
$v_{ai}$	= aliquot liquid volume for solvent rinse "i" (ml)	= 118.0 ml	
$r_{si}$	= solvent rinse "i" - sample residue mass (g)	= 0.00010 g	

4. Solvent rinse - blank residue (g)

$$m_{i-blank} = r_{ai-blank} \text{ if } r_{ai-blank} \geq 0$$

$$m_{i-blank} = 0 \text{ if } r_{ai-blank} < 0$$

Where:

$r_{ai-blank}$	= blank residue for solvent "i" from gravimetric analysis (g)	= 0.00010 g	Acetone
$m_{i-blank}$	= solvent rinse - blank residue (g)	= 0.00010 g	

5. Solvent rinse - maximum allowable blank correction (g)

$$m_{bi} = \text{MINIMUM} \left[ \left( \frac{m_{i-blank}(v_{si})}{v_{ai-blank}} \right) \text{ or } (0.00001)(\rho_i)(v_{si}) \text{ or } (r_{si}) \right] \text{ if } r_{si} \geq 0$$

$$m_{bi} = 0 \text{ if } r_{si} < 0$$

Where:

$m_{i-blank}$	= solvent rinse - blank residue (g)	Acetone	= 0.00010 g
$v_{si}$	= sample liquid volume for solvent rinse "i" (ml)		= 118.0 ml
$v_{ai-blank}$	= blank liquid volume for solvent rinse "i" (ml)		= 100.0 ml
0.00001	= EPA M5 fraction of total rinse that can be subtracted (g)		= 0.00001 g
$\rho_i$	= density of solvent rinse "i" (g/ml)		= 0.7845 g/ml
$r_{si}$	= solvent rinse "i" - sample residue mass (g)		= 0.00010 g
$m_{bi}$	= solvent rinse "i" - maximum allowable blank correction (g)		= 0.00000 g

6. Solvent rinse - net residue (g)

$$m_i = (r_{si} - m_{bi}) \text{ if } r_{si} \geq m_{bi}$$

$$m_i = 0 \text{ if } r_{si} < m_{bi}$$

Where:

$r_{si}$	= solvent rinse "i" - sample residue mass (g)	Acetone	= 0.00010 g
$m_{bi}$	= solvent rinse "i" - maximum allowable blank correction (g)		= 0.00000 g
$m_i$	= solvent rinse "i" - net residue (g)		= 0.00010 g

7. Total solvent residue - (g)

$$m_s = \sum_{i=1}^n m_i$$

Where:

$m_1$	= solvent rinse "1" - net residue (g)		= 0.00010 g
$m_2$	= solvent rinse "2" - net residue (g)		= N/A g
$m_3$	= solvent rinse "3" - net residue (g)		= N/A g
$m_s$	= total solvent residue (g)		= 0.00010 g

8. Total gravimetric result (g)

$$m_T = m_{filter} + m_s$$

Where:

$m_{filter}$	= total particulate collected on filters (g)		= 0.00080 g
$m_s$	= total solvent residue (g)		= 0.00010 g
$m_T$	= total gravimetric result (g)		= 0.00090 g

9. Total gravimetric detection limit (g)

$$m_D = (MDL_{filter})(n_f) + (MDL_{rinse})(n_r)$$

Where:

$MDL_{filter}$	= minimum detection limit for single filter analysis (g)	= 0.00010 g
$n_f$	= number of filters in analysis	= 1
$MDL_{rinse}$	= minimum detection limit for single rinse analysis (g)	= 0.00010 g
$n_r$	= number of rinses in analysis	= 1
$m_D$	= total gravimetric detection limit (g)	= 0.00020 g

10. Total particulate matter (g)

$$m_n = \text{MAXIMUM}[m_T \text{ or } < m_D]$$

Where:

$m_T$	= total gravimetric result (g)	= 0.00090 g
$m_D$	= total gravimetric detection limit (g)	= 0.00020 g
$m_n$	= total particulate matter (g)	= 0.00090 g

**USEPA Method 5/29  
 Filterable Particulate Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041509 090948  
 L.J

1. Particulate concentration (lb/dscf)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3})$$

Where:

$m_n$	= total particulate matter (g)	= 0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$C_{sd}$	= particulate concentration (lb/dscf)	= 2.8863E-08	lb/dscf

2. Particulate concentration (gr/dscf)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (15.43)$$

Where:

$m_n$	= total particulate matter (g)	= 0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
15.43	= conversion factor (gr/g)	= 15.43	gr/g
$C_{sd}$	= particulate concentration (gr/dscf)	= 0.00020	gr/dscf

3. Particulate concentration (mg/dscm)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (1000)(35.31)$$

Where:

$m_n$	= total particulate matter (g)	= 0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
1,000	= conversion factor (mg/g)	= 1,000	mg/g
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
$C_{sd}$	= particulate concentration (mg/dscm)	= 0.46219	mg/dscm

4. Particulate concentration (mg/Nm<sup>3</sup> dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (1000)(35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= total particulate matter (g)	=	0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	=	68.7570	dscf
1,000	= conversion factor (mg/g)	=	1,000	mg/g
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature (°F)	=	68	°F
32	= normal temperature (°F)	=	32	°F
460	= °F to °R conversion constant	=	460	

$C_{sd}$	= particulate concentration (mg/Nm <sup>3</sup> dry)	=	0.49601	mg/Nm <sup>3</sup> dry
----------	--	---	---------	------------------------

5. Particulate concentration corrected to x% O<sub>2</sub> (gr/dscf example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= particulate concentration (gr/dscf)	=	0.00020	gr/dscf
x	= oxygen content of corrected gas (%)	=	7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
20.9	= oxygen content of ambient air (%)	=	20.9	%

$C_{sdx}$	= particulate concentration corrected to x%O <sub>2</sub> (gr/dscf)	=	0.00024	gr/dscf @ x%O <sub>2</sub>
-----------	---	---	---------	----------------------------

6. Particulate concentration corrected to y% CO<sub>2</sub> (gr/dscf example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= particulate concentration (gr/dscf)	=	0.00020	gr/dscf
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%

$C_{sdy}$	= particulate concentration corrected to y%CO <sub>2</sub> (gr/dscf)	=	0.00024	gr/dscf @ y%CO <sub>2</sub>
-----------	--	---	---------	-----------------------------

7. Particulate concentration at actual gas conditions (gr/acf example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= particulate concentration (gr/dscf)	=	0.00020	gr/dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,921	dscfm
$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	168,899	acfm

$C_a$	= particulate concentration at actual gas conditions (gr/acf)	=	0.00011	gr/acf
-------	---	---	---------	--------

8. Particulate rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (Q_{std}) (60)$$

Where:

$m_n$	= total particulate matter (g)	=	0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	=	68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,921	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
$E_{lb/hr}$	= particulate rate (lb/hr)	=	0.1557	lb/hr

9. Particulate rate (kg/hr)

$$E_{kg/hr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{Q_{std} (60)}{1000} \right)$$

Where:

$m_n$	= total particulate matter (g)	=	0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	=	68.7570	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,921	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
1,000	= conversion factor (g/kg)	=	1,000	g/kg
$E_{kg/hr}$	= particulate rate (kg/hr)	=	0.0706	kg/hr

10. Particulate rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (Q_{std}) (60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_n$	= total particulate matter (g)	=	0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	=	68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	89,921	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
Cap	= capacity factor for process (hours operated/year)	=	8,760	hours/yr
2,000	= conversion factor (lb/Ton)	=	2,000	lb/Ton
$E_{T/yr}$	= particulate rate (Ton/yr)	=	0.6821	Ton/yr

11. Particulate rate -  $F_d$ -based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= total particulate matter (g)	= 0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$E_{Fd}$	= particulate rate - $F_d$ - based (lb/MMBtu)	= 0.00050	lb/MMBtu

12. Particulate rate -  $F_c$ -based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= total particulate matter (g)	= 0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	= 10.2	%
100	= conversion factor	= 100	
$E_{Fc}$	= particulate rate - $F_c$ - based (lb/MMBtu)	= 0.00052	lb/MMBtu

13. Particulate rate - Heat Input-based (lb/MMBtu)

$$E_{Hi} = \left( \frac{m_n}{V_{mstd}} \right) (2.205 \times 10^{-3}) \left( \frac{Q_{std} (60)}{H_i} \right)$$

Where:

$m_n$	= total particulate matter (g)	= 0.00090	g
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$H_i$	= actual heat input (MMBtu/hr)	=	MMBtu/hr
$E_{Hi}$	= particulate rate - Heat based (lb/MMBtu)	= N/A	lb/MMBtu



**USEPA Method 5/29  
 Mercury Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

041508 080948  
 o

1. Total blank amount (µg)

$$m_{total-B} = \sum_{i=1}^n m_{i-B}$$

Where:

$m_{1b-B}$	= mercury amount in blank for Fraction 1b	=	<0.1000	µg
$m_{2b-B}$	= mercury amount in blank for Fraction 2b	=	<0.3000	µg
$m_{3a-B}$	= mercury amount in blank for Fraction 3a	=	<0.2000	µg
$m_{3b-B}$	= mercury amount in blank for Fraction 3b	=	<0.5000	µg
$m_{3c-B}$	= mercury amount in blank for Fraction 3c	=	<0.4000	µg
$m_{total-B}$	= total amount of mercury in blank	=	<1.5000	µg

2. Total sample amount (µg)

$$m_{total-S} = \sum_{i=1}^n m_{i-S}$$

Where:

$m_{1b-S}$	= mercury amount in sample for Fraction 1b	=	<0.1000	µg
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	=	4.4126	µg
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	=	<0.2000	µg
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	=	<0.5000	µg
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	=	<0.4000	µg
$m_{total-S}$	= total amount of mercury in sample	=	4.4126	µg

3. Allowable blank correction (µg)

$$m_{T-B-allow} = m_{total-B} \text{ if } m_{total-B} \leq 0.6$$

$$m_{T-B-allow} = \text{MAX} [0.6, \text{MIN} (m_{total-B}, 0.05 \times m_{total-S})] \text{ if } m_{total-B} > 0.6$$

Where:

$m_{total-B}$	= total amount of mercury in blank	=	<1.5000	µg
$m_{total-S}$	= total amount of mercury in sample	=	4.4126	µg
$0.05 \times m_{total-S}$	= 5% of $m_{total-S}$	=	0.2206	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
$m_{T-B-allow}$	= total allowable blank correction	=	0.0000	µg

NOTE: In this case, the second criteria applies.

4. Sample corrected for allowable blank - Total (µg)

$$m_n = m_{total-S} - m_{T-B-allow}$$

Where:

$m_{total-S}$	= total amount of mercury in sample	= 4.4126	µg
$m_{T-B-allow}$	= total allowable blank correction	= 0.0000	µg
$m_n$	= total mercury in sample corrected for allowable blank	= 4.4126	µg

5. Sample corrected for allowable blank - Prorated for each fraction (µg)

$$m_{n-i} = \left( \frac{m_{i-S}}{m_{total-S}} \right) (m_n)$$

Where:

$m_n$	= total mercury in sample corrected for allowable blank	= 4.4126	µg
$m_{1b-S}$	= mercury amount in sample for Fraction 1b	= <0.1000	µg
$m_{2b-S}$	= mercury amount in sample for Fraction 2b	= 4.4126	µg
$m_{3a-S}$	= mercury amount in sample for Fraction 3a	= <0.2000	µg
$m_{3b-S}$	= mercury amount in sample for Fraction 3b	= <0.5000	µg
$m_{3c-S}$	= mercury amount in sample for Fraction 3c	= <0.4000	µg
$m_{total-S}$	= total amount of mercury in sample	= 4.4126	µg
$m_{n-1b}$	= mercury corrected for blank - prorated for Fraction 1b	= <0.1000	µg
$m_{n-2b}$	= mercury corrected for blank - prorated for Fraction 2b	= 4.4126	µg
$m_{n-3a}$	= mercury corrected for blank - prorated for Fraction 3a	= <0.2000	µg
$m_{n-3b}$	= mercury corrected for blank - prorated for Fraction 3b	= <0.5000	µg
$m_{n-3c}$	= mercury corrected for blank - prorated for Fraction 3c	= <0.4000	µg

**USEPA Method 5/29  
 Mercury Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041509 000948  
 L\_O

1. Mercury concentration (lb/dscf)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	4.4126	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$C_{sd}$	= mercury concentration (lb/dscf)	=	1.4151E-10	lb/dscf

2. Mercury concentration ( $\mu\text{g/dscm}$ )

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	4.4126	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	68.7570	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
$C_{sd}$	= mercury concentration ( $\mu\text{g/dscm}$ )	=	2.2661E+00	$\mu\text{g/dscm}$

3. Mercury concentration (mg/dscm)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{35.31}{1000} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	=	4.4126	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	68.7570	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
1000	= conversion factor ( $\mu\text{g/mg}$ )	=	1000	$\mu\text{g/mg}$
$C_{sd}$	= mercury concentration (mg/dscm)	=	2.2661E-03	mg/dscm

4. Mercury concentration ( $\mu\text{g}/\text{Nm}^3$  dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 4.4126	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ( $^{\circ}\text{F}$ )	= 68	$^{\circ}\text{F}$
32	= normal temperature ( $^{\circ}\text{F}$ )	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	

$C_{sd}$  = mercury concentration ( $\mu\text{g}/\text{Nm}^3$  dry) = 2.4319E+00  $\mu\text{g}/\text{Nm}^3$  dry

5. Mercury concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 1.4151E-10	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

$C_{sdx}$  = mercury concentration corrected to x% oxygen (lb/dscf) = 1.7149E-10 lb/dscf @ x% $O_2$

6. Mercury concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 1.4151E-10	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	= 10.2	%

$C_{sdy}$  = mercury conc. corrected to y% carbon dioxide (lb/dscf) = 1.6665E-10 lb/dscf @ y% $CO_2$

7. Mercury concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= mercury concentration (lb/dscf)	= 1.4151E-10	lb/dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
$Q_a$	= volumetric flow rate at actual conditions (acfm)	= 168,899	acfm

$C_a$  = mercury concentration at actual gas conditions (lb/acf) = 7.5340E-11 lb/acf

8. Mercury emission rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 4.4126	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$E_{lb/hr}$	= mercury emission rate (lb/hr)	= 7.6349E-04	lb/hr

9. Mercury emission rate (g/s)

$$E_{g/s} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 4.4126	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60	sec/min
$E_{g/s}$	= mercury emission rate (g/s)	= 9.6181E-05	g/s

10. Mercury emission rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 4.4126	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2000	lb/Ton
$E_{T/yr}$	= mercury emission rate (Ton/yr)	= 3.3441E-03	Ton/yr

11. Mercury emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 4.4126	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$E_{Fd}$	= mercury emission rate - Fd-based (lb/MMBtu)	= 2.4676E-06	lb/MMBtu

12. Mercury emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= mercury collected in sample (total $\mu\text{g}$ )	= 4.4126	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	= 10.2	%
100	= conversion factor	= 100	
$E_{Fc}$	= mercury emission rate - Fc-based (lb/MMBtu)	= 2.5275E-06	lb/MMBtu

## LOGIC FOR TREATING DETECTION LIMITS

*(all metals except mercury)*

### 1. Logic for Determining Maximum Allowable Front-Half Blank Correction ( $m_{FB-allow}$ )

	<b>CASE 1</b>	<b>CASE 2</b>
	$m_{FB} = D$	$m_{FB} = ND$
<b>Rule</b>		
$ND = 0$	$m_{FB-allow} = M29 \text{ Rule}$	$m_{FB-allow} = 0$
$ND = 1x$	$m_{FB-allow} = M29 \text{ Rule}$	$m_{FB-allow} = 0$
$ND = 0.5x$	$m_{FB-allow} = M29 \text{ Rule}$	$m_{FB-allow} = 0$

### 2. Logic for Determining Blank-Corrected Front-Half Sample Amount ( $m_F$ )

	<b>CASE 1</b>	<b>CASE 2</b>
	$m_{FS} - m_{FB-allow} \geq MDL$	$m_{FS} - m_{FB-allow} < MDL$
<b>Rule</b>		
$ND = 0$	$m_F = m_{FS} - m_{FB-allow}$	$m_F = < MDL$
$ND = 1x$	$m_F = m_{FS} - m_{FB-allow}$	$m_F = < MDL$
$ND = 0.5x$	$m_F = m_{FS} - m_{FB-allow}$	$m_F = < MDL$

### 3. Logic for Determining Maximum Allowable Back-Half Blank Correction ( $m_{BB-allow}$ )

	<b>CASE 1</b>	<b>CASE 2</b>
	$m_{BB} = D$	$m_{BB} = ND$
<b>Rule</b>		
$ND = 0$	$m_{BB-allow} = M29 \text{ Rule}$	$m_{BB-allow} = 0$
$ND = 1x$	$m_{BB-allow} = M29 \text{ Rule}$	$m_{BB-allow} = 0$
$ND = 0.5x$	$m_{BB-allow} = M29 \text{ Rule}$	$m_{BB-allow} = 0$

### 4. Logic for Determining Blank-Corrected Back-Half Sample Amount ( $m_B$ )

	<b>CASE 1</b>	<b>CASE 2</b>
	$m_{BS} - m_{BB-allow} \geq MDL$	$m_{BS} - m_{BB-allow} < MDL$
<b>Rule</b>		
$ND = 0$	$m_B = m_{BS} - m_{BB-allow}$	$m_B = < MDL$
$ND = 1x$	$m_B = m_{BS} - m_{BB-allow}$	$m_B = < MDL$
$ND = 0.5x$	$m_B = m_{BS} - m_{BB-allow}$	$m_B = < MDL$

### 5. Logic for Adding Front and Back-Half Corrected Samples ( $m_n$ )

	<b>CASE 1</b>	<b>CASE 2</b>	<b>CASE 3</b>
	Both are D	One is D, other is ND	Both are ND
<b>Rule</b>			
$ND = 0$	$m_n = m_F + m_B$	$m_n = D$	$m_n = < \text{Sum ND}$
$ND = 1x$	$m_n = m_F + m_B$	$m_n = < [D + ND]$	$m_n = < \text{Sum ND}$
$ND = 0.5x$	$m_n = m_F + m_B$	$m_n = < [D + 0.5ND]$	$m_n = < 0.5 \text{ Sum ND}$

#### Definitions and Notes

The term "Rule" refers to the rule being implemented for handling non-detectable quantities in summations

MDL = minimum detection limit.

D = Detectable quantity reported as D.

ND = Non-Detectable quantity reported at a value of ND.

If Front and Back-Half fractions are combined, then only Items 1 and 2 are used.

**USEPA Method 5/29  
 Beryllium Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.

041509 090648  
 P

1. Maximum front-half blank correction criteria ( $\mu\text{g}$ )

$$A = (1.4) \left( \frac{3.141593}{4} \right) \left( \frac{D}{2.54} \right)^2$$

Where:

D	= diameter of filter used in sample apparatus	=	8.2	cm
1.4	= allowable blank per square inch of filter area	=	1.4	$\mu\text{g}/\text{in}^2$
2.54	= conversion constant	=	2.54	cm/in
4	= conversion constant	=	4	
3.141593	= conversion constant (pi)	=	3.141593	
A	= maximum front-half blank correction criteria	=	12.46	$\mu\text{g}$

2. Allowable blank correction - combined front and back-half sample fractions ( $\mu\text{g}$ )

$$m_{FB-allow} = m_{FB} \text{ if } m_{FB} \leq A + 1$$

$$m_{FB-allow} = \text{MAX} [A + 1, \text{MIN} (m_{FB}, 0.05 \times m_{FS})] \text{ if } m_{FB} > A + 1$$

Where:

$m_{FB}$	= beryllium amount in combined front- and back-half blank	=	<0.0500	$\mu\text{g}$
$m_{FS}$	= beryllium amount in combined front- and back-half sample	=	<0.0500	$\mu\text{g}$
A+1	= max combined front- & back-half blank correction criteria	=	12.46	$\mu\text{g}$
$0.05 \times m_{FS}$	= 5% of combined front- and back-half sample amount	=	<0.0025	$\mu\text{g}$
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			

$m_{FB-allow}$	= allowable combined Beryllium blank correction	=	0.0000	$\mu\text{g}$
----------------	---	---	--------	---------------

NOTE: In this case, the first criteria applies.

3. Combined front- and back-half sample corrected for allowable blank ( $\mu\text{g}$ )

$$m_n = m_{FS} - m_{FB-allow}$$

Where:

$m_{FS}$	= beryllium amount in combined front- and back-half sample	=	<0.0500	$\mu\text{g}$
$m_{FB-allow}$	= allowable combined beryllium blank correction	=	0.0000	$\mu\text{g}$
$m_n$	= blank-corrected beryllium in combined sample	=	<0.0500	$\mu\text{g}$



**USEPA Method 5/29  
 Beryllium Sample Calculations**

**Sample data taken from Run 1**

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041509 060648  
 L\_P

**1. Beryllium concentration (lb/dscf)**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

$m_n$	= beryllium collected in sample (total $\mu\text{g}$ )	= <0.0500 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570 dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03 lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06 $\mu\text{g/g}$
$C_{sd}$	= beryllium concentration (lb/dscf)	= <1.6035E-12 lb/dscf

**2. Beryllium concentration ( $\mu\text{g/dscm}$ )**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= beryllium collected in sample (total $\mu\text{g}$ )	= <0.0500 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm
$C_{sd}$	= beryllium concentration ( $\mu\text{g/dscm}$ )	= <2.5677E-02 $\mu\text{g/dscm}$

**3. Beryllium concentration (mg/dscm)**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{35.31}{1000} \right)$$

Where:

$m_n$	= beryllium collected in sample (total $\mu\text{g}$ )	= <0.0500 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm
1000	= conversion factor ( $\mu\text{g/mg}$ )	= 1000 $\mu\text{g/mg}$
$C_{sd}$	= beryllium concentration (mg/dscm)	= <2.5677E-05 mg/dscm

4. Beryllium concentration ( $\mu\text{g}/\text{Nm}^3$  dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= beryllium collected in sample (total $\mu\text{g}$ )	= <0.0500	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ( $^{\circ}\text{F}$ )	= 68	$^{\circ}\text{F}$
32	= normal temperature ( $^{\circ}\text{F}$ )	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	

$C_{sd}$  = beryllium concentration ( $\mu\text{g}/\text{Nm}^3$  dry) = <2.7556E-02  $\mu\text{g}/\text{Nm}^3$  dry

5. Beryllium concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= beryllium concentration (lb/dscf)	= <1.6035E-12	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

$C_{sdx}$  = beryllium concentration corrected to x% oxygen (lb/dscf) = <1.9432E-12 lb/dscf @ x% $O_2$

6. Beryllium concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= beryllium concentration (lb/dscf)	= <1.6035E-12	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	= 10.2	%

$C_{sdy}$  = beryllium conc. corrected to y% carbon dioxide (lb/dscf) = <1.8883E-12 lb/dscf @ y% $CO_2$

7. Beryllium concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= beryllium concentration (lb/dscf)	= <1.6035E-12	lb/dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
$Q_a$	= volumetric flow rate at actual conditions (acfm)	= 168,899	acfm

$C_a$  = beryllium concentration at actual gas conditions (lb/acf) = <8.5369E-13 lb/acf

8. Beryllium emission rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

$m_n$	= beryllium collected in sample (total $\mu\text{g}$ )	= <0.0500	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$E_{lb/hr}$	= beryllium emission rate (lb/hr)	= <8.6512E-06	lb/hr

9. Beryllium emission rate (g/s)

$$E_{g/s} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

$m_n$	= beryllium collected in sample (total $\mu\text{g}$ )	= <0.0500	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60	sec/min
$E_{g/s}$	= beryllium emission rate (g/s)	= <1.0898E-06	g/s

10. Beryllium emission rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_n$	= beryllium collected in sample (total $\mu\text{g}$ )	= <0.0500	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2000	lb/Ton
$E_{Ton/yr}$	= beryllium emission rate (Ton/yr)	= <3.7892E-05	Ton/yr

11. Beryllium emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= beryllium collected in sample (total $\mu\text{g}$ )	=	<0.0500	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
$E_{Fd}$	= beryllium emission rate - Fd-based (lb/MMBtu)	=	<2.7961E-08	lb/MMBtu

12. Beryllium emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= beryllium collected in sample (total $\mu\text{g}$ )	=	<0.0500	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	=	68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	=	1.0E+06	$\mu\text{g/g}$
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	=	10.2	%
100	= conversion factor	=	100	
$E_{Fc}$	= beryllium emission rate - Fc-based (lb/MMBtu)	=	<2.8639E-08	lb/MMBtu

**USEPA Method 5/29  
 Cadmium Analyte Calculations**

**Sample data taken from Run 1**

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

*Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.*

041508 091743  
 P

**1. Maximum front-half blank correction criteria (µg)**

$$A = (1.4) \left( \frac{3.141593}{4} \right) \left( \frac{D}{2.54} \right)^2$$

Where:

D	= diameter of filter used in sample apparatus	=	8.2	cm
1.4	= allowable blank per square inch of filter area	=	1.4	µg/in <sup>2</sup>
2.54	= conversion constant	=	2.54	cm/in
4	= conversion constant	=	4	
3.141593	= conversion constant (pi)	=	3.141593	
A	= maximum front-half blank correction criteria	=	12.46	µg

**2. Allowable blank correction - combined front and back-half sample fractions (µg)**

$$m_{FB-allow} = m_{FB} \text{ if } m_{FB} \leq A + 1$$

$$m_{FB-allow} = MAX [A + 1, MIN (m_{FB}, 0.05 \times m_{FS})] \text{ if } m_{FB} > A + 1$$

Where:

m <sub>FB</sub>	= cadmium amount in combined front- and back-half blank	=	<0.2000	µg
m <sub>FS</sub>	= cadmium amount in combined front- and back-half sample	=	0.3934	µg
A+1	= max combined front- & back-half blank correction criteria	=	12.46	µg
0.05 x m <sub>FS</sub>	= 5% of combined front- and back-half sample amount	=	0.0197	µg
MAX	= arithmetic operator that returns the maximum of two values			
MIN	= arithmetic operator that returns the minimum of two values			
m <sub>FB-allow</sub>	= allowable combined Cadmium blank correction	=	0.0000	µg

NOTE: In this case, the first criteria applies.

**3. Combined front- and back-half sample corrected for allowable blank (µg)**

$$m_n = m_{FS} - m_{FB-allow}$$

Where:

m <sub>FS</sub>	= cadmium amount in combined front- and back-half sample	=	0.3934	µg
m <sub>FB-allow</sub>	= allowable combined cadmium blank correction	=	0.0000	µg
m <sub>n</sub>	= blank-corrected cadmium in combined sample	=	0.3934	µg

**USEPA Method 5/29  
 Cadmium Sample Calculations**

**Sample data taken from Run 1**

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041508 091758  
 L\_P

**1. Cadmium concentration (lb/dscf)**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

$m_n$	= cadmium collected in sample (total $\mu\text{g}$ )	= 0.3934	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$C_{sd}$	= cadmium concentration (lb/dscf)	= 1.2616E-11	lb/dscf

**2. Cadmium concentration ( $\mu\text{g/dscm}$ )**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= cadmium collected in sample (total $\mu\text{g}$ )	= 0.3934	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
$C_{sd}$	= cadmium concentration ( $\mu\text{g/dscm}$ )	= 2.0203E-01	$\mu\text{g/dscm}$

**3. Cadmium concentration (mg/dscm)**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{35.31}{1000} \right)$$

Where:

$m_n$	= cadmium collected in sample (total $\mu\text{g}$ )	= 0.3934	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
1000	= conversion factor ( $\mu\text{g/mg}$ )	= 1000	$\mu\text{g/mg}$
$C_{sd}$	= cadmium concentration (mg/dscm)	= 2.0203E-04	mg/dscm

4. Cadmium concentration ( $\mu\text{g}/\text{Nm}^3$  dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= cadmium collected in sample (total $\mu\text{g}$ )	= 0.3934	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ( $^{\circ}\text{F}$ )	= 68	$^{\circ}\text{F}$
32	= normal temperature ( $^{\circ}\text{F}$ )	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	

$C_{sd}$	= cadmium concentration ( $\mu\text{g}/\text{Nm}^3$ dry)	= 2.1681E-01	$\mu\text{g}/\text{Nm}^3$ dry
----------	--	--------------	-------------------------------

5. Cadmium concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= cadmium concentration (lb/dscf)	= 1.2616E-11	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%

$C_{sdx}$	= cadmium concentration corrected to x% oxygen (lb/dscf)	= 1.5289E-11	lb/dscf @ x% $O_2$
-----------	--	--------------	--------------------

6. Cadmium concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= cadmium concentration (lb/dscf)	= 1.2616E-11	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	= 10.2	%

$C_{sdy}$	= cadmium conc. corrected to y% carbon dioxide (lb/dscf)	= 1.4857E-11	lb/dscf @ y% $CO_2$
-----------	--	--------------	---------------------

7. Cadmium concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= cadmium concentration (lb/dscf)	= 1.2616E-11	lb/dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
$Q_a$	= volumetric flow rate at actual conditions (acfm)	= 168,899	acfm

$C_a$	= cadmium concentration at actual gas conditions (lb/acf)	= 6.7168E-12	lb/acf
-------	---	--------------	--------

8. Cadmium emission rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60)$$

Where:

$m_n$	= cadmium collected in sample (total $\mu\text{g}$ )	= 0.3934	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$E_{lb/hr}$	= cadmium emission rate (lb/hr)	= 6.8068E-05	lb/hr

9. Cadmium emission rate (g/s)

$$E_{g/s} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

$m_n$	= cadmium collected in sample (total $\mu\text{g}$ )	= 0.3934	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60	sec/min
$E_{g/s}$	= cadmium emission rate (g/s)	= 8.5749E-06	g/s

10. Cadmium emission rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std})(60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_n$	= cadmium collected in sample (total $\mu\text{g}$ )	= 0.3934	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2000	lb/Ton
$E_{Ton/yr}$	= cadmium emission rate (Ton/yr)	= 2.9814E-04	Ton/yr



11. Cadmium emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= cadmium collected in sample (total $\mu\text{g}$ )	= 0.3934	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$E_{Fd}$	= cadmium emission rate - Fd-based (lb/MMBtu)	= 2.2000E-07	lb/MMBtu

12. Cadmium emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= cadmium collected in sample (total $\mu\text{g}$ )	= 0.3934	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	= 10.2	%
100	= conversion factor	= 100	
$E_{Fc}$	= cadmium emission rate - Fc-based (lb/MMBtu)	= 2.2533E-07	lb/MMBtu

**USEPA Method 5/29  
 Lead Analyte Calculations**

**Sample data taken from Run 1**

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

*Note: Please see the preceding page concerning treatment of minimum detection limits and mathematical operations on values that are below minimum detection limits.*

041500 061859  
 P

**1. Maximum front-half blank correction criteria (µg)**

$$A = (1.4) \left( \frac{3.141593}{4} \right) \left( \frac{D}{2.54} \right)^2$$

Where:

D	= diameter of filter used in sample apparatus	= 8.2	cm
1.4	= allowable blank per square inch of filter area	= 1.4	µg/in <sup>2</sup>
2.54	= conversion constant	= 2.54	cm/in
4	= conversion constant	= 4	
3.141593	= conversion constant (pi)	= 3.141593	
A	= maximum front-half blank correction criteria	= 12.46	µg

**2. Allowable blank correction - combined front and back-half sample fractions (µg)**

$$m_{FB-allow} = m_{FB} \text{ if } m_{FB} \leq A + 1$$

$$m_{FB-allow} = \text{MAX} [A + 1, \text{MIN} (m_{FB}, 0.05 \times m_{FS})] \text{ if } m_{FB} > A + 1$$

Where:

m <sub>FB</sub>	= lead amount in combined front- and back-half blank	= <0.2000	µg
m <sub>FS</sub>	= lead amount in combined front- and back-half sample	= 2.2834	µg
A+1	= max combined front- & back-half blank correction criteria	= 12.46	µg
0.05 x m <sub>FS</sub>	= 5% of combined front- and back-half sample amount	= 0.1142	µg
MAX	= arithmetic operator that returns the maximum of two values		
MIN	= arithmetic operator that returns the minimum of two values		
m <sub>FB-allow</sub>	= allowable combined Lead blank correction	= 0.0000	µg

*NOTE: In this case, the first criteria applies.*

**3. Combined front- and back-half sample corrected for allowable blank (µg)**

$$m_n = m_{FS} - m_{FB-allow}$$

Where:

m <sub>FS</sub>	= lead amount in combined front- and back-half sample	= 2.2834	µg
m <sub>FB-allow</sub>	= allowable combined lead blank correction	= 0.0000	µg
m <sub>n</sub>	= blank-corrected lead in combined sample	= 2.2834	µg

**USEPA Method 5/29  
 Lead Sample Calculations**

**Sample data taken from Run 1**

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041508 091856  
 L\_P

**1. Lead concentration (lb/dscf)**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right)$$

Where:

$m_n$	= lead collected in sample (total $\mu\text{g}$ )	= 2.2834 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570 dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03 lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06 $\mu\text{g/g}$
$C_{sd}$	= lead concentration (lb/dscf)	= 7.3227E-11 lb/dscf

**2. Lead concentration ( $\mu\text{g/dscm}$ )**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= lead collected in sample (total $\mu\text{g}$ )	= 2.2834 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm
$C_{sd}$	= lead concentration ( $\mu\text{g/dscm}$ )	= 1.1726E+00 $\mu\text{g/dscm}$

**3. Lead concentration (mg/dscm)**

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{35.31}{1000} \right)$$

Where:

$m_n$	= lead collected in sample (total $\mu\text{g}$ )	= 2.2834 $\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570 dscf
35.31	= conversion factor (dscf/dscm)	= 35.31 dscf/dscm
1000	= conversion factor ( $\mu\text{g/mg}$ )	= 1000 $\mu\text{g/mg}$
$C_{sd}$	= lead concentration (mg/dscm)	= 1.1726E-03 mg/dscm

4. Lead concentration ( $\mu\text{g}/\text{Nm}^3$  dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= lead collected in sample (total $\mu\text{g}$ )	= 2.2834	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature ( $^{\circ}\text{F}$ )	= 68	$^{\circ}\text{F}$
32	= normal temperature ( $^{\circ}\text{F}$ )	= 32	$^{\circ}\text{F}$
460	= $^{\circ}\text{F}$ to $^{\circ}\text{R}$ conversion constant	= 460	
$C_{sd}$	= lead concentration ( $\mu\text{g}/\text{Nm}^3$ dry)	= 1.2584E+00	$\mu\text{g}/\text{Nm}^3$ dry

5. Lead concentration corrected to x% oxygen (lb/dscf example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= lead concentration (lb/dscf)	= 7.3227E-11	lb/dscf
x	= oxygen content of corrected gas (%)	= 7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$C_{sdx}$	= lead concentration corrected to x% oxygen (lb/dscf)	= 8.8741E-11	lb/dscf @ x% $O_2$

6. Lead concentration corrected to y% carbon dioxide (lb/dscf example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= lead concentration (lb/dscf)	= 7.3227E-11	lb/dscf
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	= 10.2	%
$C_{sdy}$	= lead conc. corrected to y% carbon dioxide (lb/dscf)	= 8.6234E-11	lb/dscf @ y% $CO_2$

7. Lead concentration at actual gas conditions (lb/acf example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= lead concentration (lb/dscf)	= 7.3227E-11	lb/dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
$Q_a$	= volumetric flow rate at actual conditions (acfm)	= 168,899	acfm
$C_a$	= lead concentration at actual gas conditions (lb/acf)	= 3.8986E-11	lb/acf

8. Lead emission rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60)$$

Where:

$m_n$	= lead collected in sample (total $\mu\text{g}$ )	= 2.2834	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$E_{lb/hr}$	= lead emission rate (lb/hr)	= 3.9508E-04	lb/hr

9. Lead emission rate (g/s)

$$E_{g/s} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{Q_{std}}{(10^6)(60)} \right)$$

Where:

$m_n$	= lead collected in sample (total $\mu\text{g}$ )	= 2.2834	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
60	= conversion factor (sec/min)	= 60	sec/min
$E_{g/s}$	= lead emission rate (g/s)	= 4.9771E-05	g/s

10. Lead emission rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (Q_{std}) (60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_n$	= lead collected in sample (total $\mu\text{g}$ )	= 2.2834	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 89,921	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
Cap	= capacity factor for process (hours operated/year)	= 8,760	hours/yr
2000	= conversion factor (lb/Ton)	= 2000	lb/Ton
$E_{Ton/yr}$	= lead emission rate (Ton/yr)	= 1.7305E-03	Ton/yr

11. Lead emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= lead collected in sample (total $\mu\text{g}$ )	= 2.2834	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.4	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$E_{Fd}$	= lead emission rate - Fd-based (lb/MMBtu)	= 1.2769E-06	lb/MMBtu

12. Lead emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{10^6} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= lead collected in sample (total $\mu\text{g}$ )	= 2.2834	$\mu\text{g}$
$V_{mstd}$	= volume metered, standard (dscf)	= 68.7570	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
$10^6$	= conversion factor ( $\mu\text{g/g}$ )	= 1.0E+06	$\mu\text{g/g}$
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	= 10.2	%
100	= conversion factor	= 100	
$E_{Fc}$	= lead emission rate - Fc-based (lb/MMBtu)	= 1.3079E-06	lb/MMBtu

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

**USEPA Method 23 (PCDD/F)  
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041509 092112  
P

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

$V_{lc}$	= total volume of liquid collected in impingers and silica gel (ml)	=	817.5	ml
0.04706	= ideal gas conversion factor (ft <sup>3</sup> water vapor/ml or gm)	=	0.04706	ft <sup>3</sup> /ml
$V_{wstd}$	= volume of water vapor collected at standard conditions (ft <sup>3</sup> )	=	38.47	ft <sup>3</sup>

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.20	in. Hg
$T_m$	= average dry gas meter temperature (°F)	=	85.52	°F
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	146.57	dcf
$Y_d$	= gas meter correction factor (dimensionless)	=	0.9916	
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.13	in. H <sub>2</sub> O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	142.320	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left( \frac{P_g}{13.6} \right)$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.20	in. Hg
$P_g$	= sample gas static pressure (in. H <sub>2</sub> O)	=	-10.40	in. H <sub>2</sub> O
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.44	in. Hg

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left( \frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

$T_s$	= average sample gas temperature (°F)	=	301.20	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
$P_v$	= vapor pressure, actual (in. Hg)	=	29.44	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.44	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.44	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	142.320	dscf
$V_{wstd}$	= volume of water collected at standard conditions (scf)	=	38.47	scf
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2128	
		=	21.28	%



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.44	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.44	in. Hg
$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2128	
$B_w$	= actual water vapor in gas	=	0.2128	
		=	21.28	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.3	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.5	%
100	= conversion factor (%)	=	100	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.21	%

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

## 10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2 + CO)}{(100)}$$

Where:

$M_{CO_2}$	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
$M_{O_2}$	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
$M_{N_2+CO}$	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.3	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.5	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.2	%
100	= conversion factor (%)	=	100	%
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.02	lb/lb-mole

## 11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2128	
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.02	lb/lb-mole
$M_{H_2O}$	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
$M_s$	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.46	lb/lb-mole

## 12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p) \left( \sqrt{\Delta P} \right) \left( \sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

$K_p$	= velocity pressure constant	=	85.49	
$C_p$	= pitot tube coefficient	=	0.83	
$M_s$	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.46	lb/lb-mole
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.44	in. Hg
$T_s$	= average sample gas temperature (°F)	=	301.20	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H <sub>2</sub> O)	=	0.665	√in. H <sub>2</sub> O
460	= °F to °R conversion constant	=	460	
$V_s$	= sample gas velocity (ft/sec)	=	45.95	ft/sec

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

## 13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

$A_s$	= cross sectional area of sampling location (ft <sup>2</sup> )	=	64.00	ft <sup>2</sup>
$V_s$	= sample gas velocity (ft/sec)	=	45.95	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	176,448	acfm

## 14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left( \frac{P_s}{29.92} \right) \left( \frac{68 + 460}{T_s + 460} \right)$$

Where:

$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	176,448	acfm
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.44	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
$T_s$	= average sample gas temperature (°F)	=	301.2	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	120,409	scfm

## 15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2128	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	120,409	scfm
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,787	dscfm

16. Dry flow of sample gas corrected to 7% O<sub>2</sub> (dscfm)

$$Q_{std7} = (Q_{std}) \left( \frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,787	dscfm
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.5	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
$Q_{std7}$	= volumetric flow rate at STP and 7% O <sub>2</sub> , dry basis (dscfm)	=	77,466	dscfm

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

17. Hourly time basis conversion of volumetric flow rate ( $Q_{std}$  example)

$$Q_{std-hr} = (Q_{std-min})(60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	94,787	dscfm
60	= conversion factor (min/hr)	=	60	min/hr

$Q_{std-hr}$	= volumetric flow rate, hourly basis (dscf/hr)	=	5,687,202	dscf/hr
--------------	--	---	-----------	---------

18. Metric Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{std-metric} = (Q_{std-english}) \left( \frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft <sup>3</sup> /min)	=	94,787	dscfm
35.31	= conversion factor (ft <sup>3</sup> /m <sup>3</sup> )	=	35.31	ft <sup>3</sup> /m <sup>3</sup>
60	= conversion factor (min/hr)	=	60	min/hr

$Q_{std-metric}$	= volumetric flow rate, metric units (m <sup>3</sup> /hr)	=	161,065	dry std m <sup>3</sup> /hr
------------------	---	---	---------	----------------------------

19. Standard to Normal Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{Normal} = (Q_{std-metric}) \left( \frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m <sup>3</sup> /hr)	=	161,065	dry std m <sup>3</sup> /hr
32	= normal temperature (°F)	=	32	°F
68	= standard temperature (°F)	=	68	°F
460	= standard temperature in Rankine (68°F)	=	460	

$Q_{Normal}$	= volumetric flow rate, metric units (dry Nm <sup>3</sup> /hr)	=	150,083	dry Nm <sup>3</sup> /hr
--------------	--	---	---------	-------------------------

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

## 20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\overline{T_s} + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n Y(\pi)}{144(4)}\right)(\theta)(1 - B_w)}$$

Where:

$D_n$	= diameter of nozzle (in)	=	0.266	in.
$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2128	
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.44	in. Hg
$T_s$	= average sample gas temperature (°F)	=	301.2	°F
$V_{mstd}$	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	142.320	dscf
$V_s$	= sample gas velocity (ft/sec)	=	45.95	ft/sec
$\theta$	= total sampling time (min)	=	250	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
$I$	= percent of isokinetic sampling (%)	=	99.66	%

## 21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{\theta})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

$\theta$	= total sampling time (min)	=	250	min
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	146.57	dcf
$T_m$	= average dry gas meter temperature (°F)	=	85.52	°F
$\Delta H_{\theta}$	= dry gas meter orifice coefficient	=	1.8053	
$P_{bar}$	= barometric pressure (in. Hg)	=	30.20	in. Hg
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.128	in. H <sub>2</sub> O
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.02	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.056	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$Y_{qa}$	= alternative Method 5 post-test meter calibration factor	=	0.9984	

**USEPA Method 23  
 PCDD/PCDF Emissions Calculations**

**Sample data taken from Run 1**

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

Note: PCDD/F results may be presented in two formats - normally expected levels and the maximum possible levels. In the normal case, data classified as ND (non-detect) or EMPC (estimated maximum possible concentration) are not counted. In the maximum possible emissions case, NDs and EMPCs are fully counted.

041509 092138  
 P\_K

	Normal Case (ND & EMPC = 0)	Maximum Case (ND & EMPC fully counted)
--	--------------------------------	---

1. TEQ concentration (ng/dscm)

$$C_{sd} = \left( \frac{m_{n-TEQ}}{V_{mstd}} \right) \times 35.31$$

Where:

$m_{n-TEQ}$	= total TEQ mass for PCDDs and PCDFs (ng)	= 1.3300E-01	ng	1.3600E-01	ng
$V_{mstd}$	= volume metered, standard (dscf)	= 142.3205	dscf	142.3205	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm	35.31	dscf/dscm
$C_{sd}$	= PCDD/F TEQ concentration (ng/dscm)	= 3.2998E-02	ng/dscm	3.3742E-02	ng/dscm

2. TEQ concentration (ng/Nm<sup>3</sup> dry)

$$C_{sd} = \left( \frac{m_{n-TEQ}}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_{n-TEQ}$	= total TEQ mass for PCDDs and PCDFs (ng)	= 1.3300E-01	ng	1.3600E-01	ng
$V_{mstd}$	= volume metered, standard (dscf)	= 142.3205	dscf	142.3205	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm	35.31	dscf/dscm
68	= standard temperature (°F)	= 68	°F	68	°F
32	= normal temperature (°F)	= 32	°F	32	°F
460	= °F to °R conversion constant	= 460		460	
$C_{sd}$	= PCDD/F TEQ concentration (ng/Nm <sup>3</sup> dry)	= 3.5412E-02	ng/Nm <sup>3</sup> dry	3.6211E-02	ng/Nm <sup>3</sup> dry

3. TEQ concentration at actual gas conditions (ng/acm example)

$$C_a = C_{sd} \left( \frac{Q_{std}}{Q_a} \right)$$

Where:

$C_{sd}$	= PCDD/F TEQ concentration (ng/dscm)	= 3.2998E-02	ng/dscm	3.3742E-02	ng/dscm
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscm/h)	= 161,065	dry std m <sup>3</sup> /hr	161,065	dry std m <sup>3</sup> /hr
$Q_a$	= volumetric flow rate at actual conditions (acm/h)	= 299,827	actual m <sup>3</sup> /hr	299,827	actual m <sup>3</sup> /hr
$C_a$	= PCDD/F TEQ concentration at actual gas conditions (ng/acm)	= 1.7726E-02	ng/acm	1.8126E-02	ng/acm

4. TEQ concentration corrected to x% O2 (ng/dscm example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= PCDD/F TEQ concentration (ng/dscm)	= 3.2998E-02	ng/dscm	3.3742E-02	ng/dscm
x	= oxygen content of corrected gas (%)	= 7.0	%	7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.5	%	9.5	%
20.9	= oxygen content of ambient air (%)	= 20.9	%	20.9	%
$C_{sdx}$	= PCDD/F TEQ concentration (ng/dscm corrected to x% O <sub>2</sub> )	= 4.0376E-02	ng/dscm @ x% O <sub>2</sub>	4.1286E-02	ng/dscm @ x% O <sub>2</sub>

5. TEQ concentration corrected to y% CO2 (ng/dscm example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= PCDD/F TEQ concentration (ng/dscm)	= 3.2998E-02	ng/dscm	3.3742E-02	ng/dscm
y	= carbon dioxide content of corrected gas (%)	= 12.0	%	12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	= 10.3	%	10.3	%
$C_{sdy}$	= PCDD/F TEQ concentration (ng/dscm corrected to y% CO <sub>2</sub> )	= 3.8631E-02	ng/dscm @ y% CO <sub>2</sub>	3.9503E-02	ng/dscm @ y% CO <sub>2</sub>

6. TEQ Emission rate (lb/hr)

$$E_{lb/hr} = \left( \frac{m_{n\_TEQ}}{V_{mstd}} \right) (2.205 \times 10^{-3}) (Q_{std}) \left( \frac{60}{10^9} \right)$$

Where:

$m_{n\_TEQ}$	= total TEQ mass for PCDDs and PCDFs (ng)	= 1.3300E-01	ng	1.3600E-01	ng
$V_{mstd}$	= volume metered, standard (dscf)	= 142.3205	dscf	142.3205	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g	2.205E-03	lb/g
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,787	dscfm	94,787	dscfm
60	= conversion factor (min/hr)	= 60	min/hr	60	min/hr
$10^9$	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
$E_{lb/hr}$	= PCDDF TEQ Emission rate (lb/hr)	= 1.1719E-08	lb/hr	1.1983E-08	lb/hr

7. TEQ Emission rate (g/sec)

$$E_{g/sec} = \left( \frac{m_{n\_TEQ}}{V_{mstd}} \right) \left( \frac{Q_{std}}{60 \times 10^9} \right)$$

Where:

$m_{n\_TEQ}$	= total TEQ mass for PCDDs and PCDFs (ng)	= 1.3300E-01	ng	1.3600E-01	ng
$V_{mstd}$	= volume metered, standard (dscf)	= 142.3205	dscf	142.3205	dscf
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	= 94,787	dscfm	94,787	dscfm
60	= conversion factor (sec/min)	= 60	sec/min	60	sec/min
$10^9$	= conversion factor to convert from ng to grams	= 1.0E+09	ng/g	1.0E+09	ng/g
$E_{g/sec}$	= PCDDF TEQ Emission rate (g/sec)	= 1.4763E-09	g/sec	1.5096E-09	g/sec

8. TEQ emission rate (Ton/yr)

$$E_{T/yr} = \left( \frac{m_{n\_TEQ}}{V_{msid}} \right) \left( \frac{2.205 \times 10^{-3}}{10^9} \right) (Q_{std}) (60) \left( \frac{Cap}{2000} \right)$$

Where:

$m_{n\_TEQ}$	= total TEQ mass for PCDDs and PCDFs (ng)	=	1.3300E-01	ng	1.3600E-01	ng
$V_{msid}$	= volume metered, standard (dscf)	=	142.3205	dscf	142.3205	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g	2.205E-03	lb/g
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	94,787	dscfm	94,787	dscfm
60	= conversion factor (min/hr)	=	60	min/hr	60	min/hr
Cap	= capacity factor for process (hours operated/year)	=	8,760	hours/yr	8,760	hours/yr
2000	= conversion factor (lb/Ton)	=	2,000	lb/Ton	2,000	lb/Ton
$10^9$	= conversion factor to convert from ng to grams	=	1.0E+09	ng/g	1.0E+09	ng/g
$E_{T/yr}$	= PCDDF TEQ Emission rate (Ton/yr)	=	5.1329E-08	Ton/yr	5.2487E-08	Ton/yr

9. TEQ emission rate - Fd-based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_{n\_TEQ}}{V_{msid}} \right) \left( \frac{2.205 \times 10^{-3}}{10^9} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_{n\_TEQ}$	= total TEQ mass for PCDDs and PCDFs (ng)	=	1.3300E-01	ng	1.3600E-01	ng
$V_{msid}$	= volume metered, standard (dscf)	=	142.3205	dscf	142.3205	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g	2.205E-03	lb/g
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu	9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.5	%	9.5	%
20.9	= oxygen content of ambient air (%)	=	20.9	%	20.9	%
$10^9$	= conversion factor to convert from ng to grams	=	1.0E+09	ng/g	1.0E+09	ng/g
$E_{Fd}$	= PCDDF TEQ Emission rate (lb/MMBtu)	=	3.6280E-11	lb/MMBtu	3.7099E-11	lb/MMBtu

10. TEQ emission rate - Fc-based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_{n\_TEQ}}{V_{msid}} \right) \left( \frac{2.205 \times 10^{-3}}{10^9} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_{n\_TEQ}$	= total TEQ mass for PCDDs and PCDFs (ng)	=	1.3300E-01	ng	1.3600E-01	ng
$V_{msid}$	= volume metered, standard (dscf)	=	142.3205	dscf	142.3205	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g	2.205E-03	lb/g
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu	1,820	dscf/MMBtu
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.3	%	10.3	%
100	= conversion factor	=	100		100	
$10^9$	= conversion factor to convert from ng to grams	=	1.0E+09	ng/g	1.0E+09	ng/g
$E_{Fc}$	= PCDDF TEQ Emission rate (lb/MMBtu)	=	3.6588E-11	lb/MMBtu	3.7413E-11	lb/MMBtu



Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

**USEPA Method 13B (Total Fluorides)  
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041509 092155  
M

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

$V_{lc}$	= total volume of liquid collected in impingers and silica gel (ml)	=	220.6	ml
0.04706	= ideal gas conversion factor (ft <sup>3</sup> water vapor/ml or gm)	=	0.04706	ft <sup>3</sup> /ml
$V_{wstd}$	= volume of water vapor collected at standard conditions (ft <sup>3</sup> )	=	10.38	ft <sup>3</sup>

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.10	in. Hg
$T_m$	= average dry gas meter temperature (°F)	=	71.00	°F
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	37.86	dcf
$Y_d$	= gas meter correction factor (dimensionless)	=	0.9916	
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.23	in. H <sub>2</sub> O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	37.647	dscf

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left( \frac{P_g}{13.6} \right)$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.10	in. Hg
$P_g$	= sample gas static pressure (in. H <sub>2</sub> O)	=	-12.00	in. H <sub>2</sub> O
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left( \frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

$T_s$	= average sample gas temperature (°F)	=	293.08	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
$P_v$	= vapor pressure, actual (in. Hg)	=	29.22	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.22	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	37.647	dscf
$V_{wstd}$	= volume of water collected at standard conditions (scf)	=	10.38	scf
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2162	%
		=	21.62	%

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

## 7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.22	in. Hg
$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

## 8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2162	
$B_w$	= actual water vapor in gas	=	0.2162	
		=	21.62	%

## 9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
100	= conversion factor (%)	=	100	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.41	%

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

## 10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2 + CO)}{(100)}$$

Where:

$M_{CO_2}$	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
$M_{O_2}$	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
$M_{N_2+CO}$	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.4	%
100	= conversion factor (%)	=	100	%
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.01	lb/lb-mole

## 11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2162	
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.01	lb/lb-mole
$M_{H_2O}$	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
$M_s$	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.41	lb/lb-mole

## 12. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left( \sqrt{\frac{(T_s + 460)}{(M_s)(P_s)}} \right)$$

Where:

$K_p$	= velocity pressure constant	=	85.49	
$C_p$	= pitot tube coefficient	=	0.83	
$M_s$	= wet molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.41	lb/lb-mole
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
$T_s$	= average sample gas temperature (°F)	=	293.08	°F
$\sqrt{\Delta P}$	= average square roots of velocity heads of sample gas (in. H <sub>2</sub> O)	=	0.679	$\sqrt{\text{in. H}_2\text{O}}$
460	= °F to °R conversion constant	=	460	
$V_s$	= sample gas velocity (ft/sec)	=	46.42	ft/sec

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

## 13. Volumetric flow rate of sample gas at actual gas conditions (acfm)

$$Q_a = (60)(A_s)(V_s)$$

Where:

$A_s$	= cross sectional area of sampling location (ft <sup>2</sup> )	=	64.00	ft <sup>2</sup>
$V_s$	= sample gas velocity (ft/sec)	=	46.42	ft/sec
60	conversion factor (sec/min)	=	60	sec/min
$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	178,264	acfm

## 14. Total flow of sample gas (scfm)

$$Q_s = (Q_a) \left( \frac{P_s}{29.92} \right) \left( \frac{68 + 460}{T_s + 460} \right)$$

Where:

$Q_a$	= volumetric flow rate at actual conditions (acfm)	=	178,264	acfm
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
29.92	= standard pressure (in. Hg)	=	29.92	in. Hg
$T_s$	= average sample gas temperature (°F)	=	293.1	°F
68	= standard temperature (°F)	=	68	°F
460	= °F to °R conversion constant	=	460	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	122,051	scfm

## 15. Dry flow of sample gas (dscfm)

$$Q_{std} = (Q_s)(1 - B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2162	
$Q_s$	= volumetric flow rate at standard conditions, wet basis (scfm)	=	122,051	scfm
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	95,670	dscfm

16. Dry flow of sample gas corrected to 7%O<sub>2</sub> (dscfm)

$$Q_{std7} = (Q_{std}) \left( \frac{20.9 - O_2}{20.9 - 7} \right)$$

Where:

$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	95,670	dscfm
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
7	= oxygen content of corrected gas (%)	=	7.0	%
$Q_{std7}$	= volumetric flow rate at STP and 7%O <sub>2</sub> , dry basis (dscfm)	=	79,426	dscfm

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

17. Hourly time basis conversion of volumetric flow rate ( $Q_{std}$  example)

$$Q_{std-hr} = (Q_{std-min})(60)$$

Where

$Q_{std-min}$	= volumetric flow rate, english units (ft <sup>3</sup> /min)	= 95,670	dscfm
60	= conversion factor (min/hr)	= 60	min/hr
$Q_{std-hr}$	= volumetric flow rate, hourly basis (dscf/hr)	= 5,740,172	dscf/hr

18. Metric Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{std-metric} = (Q_{std-english}) \left( \frac{60}{35.31} \right)$$

Where:

$Q_{std-english}$	= volumetric flow rate, english units (ft <sup>3</sup> /min)	= 95,670	dscfm
35.31	= conversion factor (ft <sup>3</sup> /m <sup>3</sup> )	= 35.31	ft <sup>3</sup> /m <sup>3</sup>
60	= conversion factor (min/hr)	= 60	min/hr
$Q_{std-metric}$	= volumetric flow rate, metric units (m <sup>3</sup> /hr)	= 162,565	dry std m <sup>3</sup> /hr

19. Standard to Normal Conversion of Gas Volumes ( $Q_{std}$  example)

$$Q_{Normal} = (Q_{std-metric}) \left( \frac{32 + 460}{68 + 460} \right)$$

Where:

$Q_{std-metric}$	= volumetric flow rate, metric units (dry std m <sup>3</sup> /hr)	= 162,565	dry std m <sup>3</sup> /hr
32	= normal temperature (°F)	= 32	°F
68	= standard temperature (°F)	= 68	°F
460	= standard temperature in Rankine (68°F)	= 460	
$Q_{Normal}$	= volumetric flow rate, metric units (dry Nm <sup>3</sup> /hr)	= 151,481	dry Nm <sup>3</sup> /hr

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

## 20. Percent isokinetic (%)

$$I = \frac{(0.09450)(\overline{T}_s + 460)(V_{mstd})}{(P_s)(V_s)\left(\frac{D_n^2(\pi)}{(144)(4)}\right)(\theta)(1 - B_w)}$$

Where:

$D_n$	= diameter of nozzle (in)	=	0.272	in.
$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2162	
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.22	in. Hg
$T_s$	= average sample gas temperature (°F)	=	293.1	°F
$V_{mstd}$	= volume of gas sample through the dry gas meter at standard conditions (dscf)	=	37.647	dscf
$V_s$	= sample gas velocity (ft/sec)	=	46.42	ft/sec
$\theta$	= total sampling time (min)	=	63	min
0.0945	= conversion constant	=	0.0945	
460	= °F to °R conversion constant	=	460	
$I$	= percent of isokinetic sampling (%)	=	99.92	%

## 21. Alternative Method 5 Post-Test Meter Calibration Factor

$$Y_{qa} = \frac{\theta}{V_m} \sqrt{\frac{(0.0319)(T_m + 460)(28.96)}{(\Delta H_{\theta})(P_{bar} + \frac{\Delta H}{13.6})(M_d)}} (\sqrt{\Delta H})_{avg}$$

Where:

$\theta$	= total sampling time (min)	=	63	min
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	37.86	dcf
$T_m$	= average dry gas meter temperature (°F)	=	71.00	°F
$\Delta H_{\theta}$	= dry gas meter orifice coefficient	=	1.8053	
$P_{bar}$	= barometric pressure (in. Hg)	=	30.10	in. Hg
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.231	in. H <sub>2</sub> O
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.01	lb/lb-mole
$\sqrt{\Delta H}_{avg}$	= average of square root of pressure drop across meter orifice	=	1.106	$\sqrt{\text{in. H}_2\text{O}}$
0.0319	= conversion constant	=	0.0319	
28.96	= molecular weight of ambient air (lb/lb-mole)	=	28.96	lb/lb-mole
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in.H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$Y_{qa}$	= alternative Method 5 post-test meter calibration factor	=	1.0001	

**USEPA Method 13B  
 HF Analyte Calculations**

**Sample data taken from Run 1**

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041509 092155  
 N

1. Fluoride to HF conversion factor

$$K_{HF} = \frac{MW_{HF}}{n \times MW_{F^-}}$$

Where:

MW <sub>HF</sub>	= molecular weight of HF (mg/mg-mole)	=	20.006	mg/mg-mole
MW <sub>F<sup>-</sup></sub>	= molecular weight of fluoride ion (mg/mg-mole)	=	18.998	mg/mg-mole
n	= molar ratio of fluoride to HF	=	1.0	mole F/mole HF
K <sub>HF</sub>	= conversion factor to convert mass F <sup>-</sup> to mass HF	=	1.053	

2. Total HF collected (mg)

$$m_{HF} = K_{HF} \times \frac{(S_{F-1}v_1 + S_{F-2}v_2)}{1000}$$

Where:

K <sub>HF</sub>	= conversion factor to convert mass F <sup>-</sup> to mass HF	=	1.053	
S <sub>F-1</sub>	= fluoride concentration of sample fraction 1 (mg/liter)	=	<0.0060	mg/liter
v <sub>1</sub>	= liquid volume of sample fraction 1 (ml)	=	959.0	ml
S <sub>F-2</sub>	= fluoride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v <sub>2</sub>	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m <sub>HF</sub>	= total HF collected in sample (mg)	=	<0.0061	mg

Note: Non-detects are treated as zero in summations.

**DEFINITION**

Fraction 1 = entire sample except last impinger containing applicable absorbing reagent.  
 Fraction 2 = last impinger containing applicable absorbing reagent, analyzed separately to evaluate collection efficiency.  
 If entire sample is analyzed as a single fraction, then data is included as Fraction 1 (Fraction 2 = 0).

3. Allowable blank subtraction (mg)

$$m_b = K_{HF} \times B_F \times \frac{(v_1 + v_2)}{1000}$$

$$m_b = 0 \text{ if } B_F < MDL$$

Where:

K <sub>HF</sub>	= conversion factor to convert mass F <sup>-</sup> to mass HF	=	1.053	
B <sub>F</sub>	= fluoride concentration of blank (mg/liter)	=	<0.0060	mg/liter
v <sub>1</sub>	= liquid volume of sample fraction 1 (ml)	=	959.0	ml
v <sub>2</sub>	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m <sub>b</sub>	= allowable blank subtraction (mg)	=	0.0000	mg



4. Total HF collected, corrected for blank (mg)

$$m_{nb} = m_{HF} - m_b$$

Where:

$m_{HF}$	= total HF collected in sample (mg)	=	<0.0061	mg
$m_b$	= allowable blank subtraction (mg)	=	0.0000	mg
$m_{nb}$	= total HF collected, corrected for blank (mg)	=	<0.0061	mg

5. Minimum detectable HF (mg)

$$m_{MDL} = K_{HF} \times MDL \times \frac{(v_1 + v_2)}{1000}$$

Where:

$K_{HF}$	= conversion factor to convert mass F to mass HF	=	1.053	
MDL	= minimum detectable fluoride concentration	=	0.001	mg/liter
$v_1$	= liquid volume of sample fraction 1 (ml)	=	959.0	ml
$v_2$	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
$m_{MDL}$	= minimum detectable HF (mg)	=	0.0010	mg

6. Total HF value used in emission calculations (mg)

$$m_n = \text{MAXIMUM} [m_{nb} \text{ or } < m_{MDL}]$$

Where:

$m_{nb}$	= total HF collected, corrected for blank (mg)	=	<0.0061	mg
$m_{MDL}$	= minimum detectable HF (mg)	=	0.0010	mg
$m_n$	= total HF value used in emission calculations (mg)	=	<0.0061	mg

7. Collection QC check (% mass collected in second fraction)

$$EFF = 100 \times \frac{K_{HF} \times S_{F-2} \times \frac{v_2}{1000}}{m_{HF}}$$

Where:

$K_{HF}$	= conversion factor to convert mass F to mass HF	=	1.053	
$S_{F-2}$	= fluoride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
$v_2$	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
$m_{HF}$	= total HF collected in sample (mg)	=	<0.0061	mg
1000	= conversion factor (ml/liter)	=	1000	ml/liter
100	= conversion factor	=	100	%
EFF	= Collection QC check (% mass collected in second fraction)	=	0.00	%

**USEPA Method 13B  
 HF Sample Calculations**

**Sample data taken from Run 1**

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041500 082156  
 M\_N

1. HF concentration (lb/dscf)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right)$$

Where:

$m_n$	= total HF collected, corrected for applicable blank (mg)	= <0.0061	mg
$V_{mstd}$	= volume metered, standard (dscf)	= 37.6474	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
$C_{sd}$	= HF concentration (lb/dscf)	= <3.5487E-10	lb/dscf

2. HF concentration (ppmdv)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{0.850}{1000} \right) \left( \frac{10^6}{MW} \right)$$

Where:

$m_n$	= total HF collected, corrected for applicable blank (mg)	= <0.0061	mg
$V_{mstd}$	= volume metered, standard (dscf)	= 37.6474	dscf
MW	= molecular weight of HF (g/g-mole)	= 20.006	g/g-mole
0.850	= conversion factor (dscf/g-mole)	= 0.850	dscf/g-mole
1000	= conversion factor (mg/g)	= 1,000	mg/g
$10^6$	= conversion factor (ppm)	= $10^6$	ppm
$C_{sd}$	= HF concentration (ppmdv)	= <0.0068	ppmdv

3. HF concentration (ppmwv)

$$C_w = C_{sd} \left( 1 - \frac{B_w}{100} \right)$$

Where:

$C_{sd}$	= HF concentration (ppmdv)	= <0.0068	ppmdv
$B_w$	= actual water vapor in gas (% v/v)	= 21.6150	% v/v
100	= conversion factor (%)	= 100	%
$C_w$	= HF concentration (ppmwv)	= <0.0054	ppmwv

4. HF concentration (mg/dscm)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= total HF collected, corrected for applicable blank (mg)	=	<0.0061	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	37.6474	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
$C_{sd}$	= HF concentration (mg/dscm)	=	<0.0057	mg/dscm

5. HF concentration (mg/Nm<sup>3</sup> dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= total HF collected, corrected for applicable blank (mg)	=	<0.0061	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	37.6474	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature (°F)	=	68	°F
32	= normal temperature (°F)	=	32	°F
460	= °F to °R conversion constant	=	460	
$C_{sd}$	= HF concentration (mg/Nm <sup>3</sup> dry)	=	<0.0061	mg/Nm <sup>3</sup> dry

6. HF concentration corrected to x% O<sub>2</sub> (ppmdv example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= HF concentration (ppmdv)	=	<0.0068	ppmdv
x	= oxygen content of corrected gas (%)	=	7.0	%
O <sub>2</sub>	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
$C_{sdx}$	= HF concentration corrected to x%O <sub>2</sub> (ppmdv)	=	<0.0082	ppmdv @ x%O <sub>2</sub>

7. HF concentration corrected to y% CO<sub>2</sub> (ppmdv example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= HF concentration (ppmdv)	=	<0.0068	ppmdv
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
CO <sub>2</sub>	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.2	%
$C_{sdy}$	= HF concentration corrected to y%CO <sub>2</sub> (ppmdv)	=	<0.0080	ppmdv @ y%CO <sub>2</sub>

12. HF rate -  $F_d$ -based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= total HF collected, corrected for applicable blank (mg)	=	<0.0061	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	37.6474	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.4	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
$E_{Fd}$	= HF rate (lb/MMBtu)	=	<6.1507E-06	lb/MMBtu

13. HF rate -  $F_c$ -based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= total HF collected, corrected for applicable blank (mg)	=	<0.0061	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	37.6474	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	=	10.2	%
100	= conversion factor	=	100	
$E_{Fc}$	= HF rate (lb/MMBtu)	=	<6.3135E-06	lb/MMBtu

14. HF rate - Heat Input-based (lb/MMBtu)

$$E_{Hi} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right) \left( \frac{Q_{std}(60)}{H_i} \right)$$

Where:

$m_n$	= total HF collected, corrected for applicable blank (mg)	=	<0.0061	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	37.6474	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
$Q_{std}$	= volumetric flow rate at standard conditions, dry basis (dscfm)	=	95,670	dscfm
60	= conversion factor (min/hr)	=	60	min/hr
$H_i$	= actual heat input (MMBtu/hr)	=		MMBtu/hr
$E_{Hi}$	= HF rate (lb/MMBtu)	=	N/A	lb/MMBtu

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 SDA Inlet

**USEPA Method 26A (HCl)  
Sampling, Velocity and Moisture Sample Calculations**

**Sample data taken from Run 1**

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041509 102810  
L

**1. Volume of water collected (wscf)**

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

$V_{lc}$	= total volume of liquid collected in impingers and silica gel (ml)	=	157.0	ml
0.04706	= ideal gas conversion factor (ft <sup>3</sup> water vapor/ml or gm)	=	0.04706	ft <sup>3</sup> /ml
$V_{wstd}$	= volume of water vapor collected at standard conditions (ft <sup>3</sup> )	=	7.39	ft <sup>3</sup>

**2. Volume of gas metered, standard conditions (dscf)**

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.20	in. Hg
$T_m$	= average dry gas meter temperature (°F)	=	81.04	°F
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	33.56	dcf
$Y_d$	= gas meter correction factor (dimensionless)	=	0.9992	
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.09	in. H <sub>2</sub> O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	
$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	33.105	dscf

**3. Sample gas pressure (in. Hg)**

$$P_s = P_{bar} + \left( \frac{P_g}{13.6} \right)$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.20	in. Hg
$P_g$	= sample gas static pressure (in. H <sub>2</sub> O)	=	-1.30	in. H <sub>2</sub> O
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
$P_s$	= absolute sample gas pressure (in. Hg)	=	30.10	in. Hg

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left( \frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

$T_s$	= average sample gas temperature (°F)	=	492.33	°F
18.3036	= Antoine coefficient	=	18.3036	°K
3816.44	= Antoine coefficient	=	3816.44	°K
273.15	= temperature conversion factor	=	273.15	°K
46.13	= Antoine coefficient	=	46.13	°K
25.4	= conversion factor	=	25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	=	5/9	°C/°F
32	= temperature conversion (°F)	=	32	°F
$P_v$	= vapor pressure, actual (in. Hg)	=	30.10	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	30.10	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	30.10	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	33.105	dscf
$V_{wstd}$	= volume of water collected at standard conditions (scf)	=	7.39	scf
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.1825	
		=	18.25	%

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	30.10	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	30.10	in. Hg
$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.1825	
$B_w$	= actual water vapor in gas	=	0.1825	
		=	18.25	%

9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.4	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	8.0	%
100	= conversion factor (%)	=	100	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.59	%

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2+CO)}{(100)}$$

Where:

$M_{CO_2}$	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
$M_{O_2}$	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
$M_{N_2+CO}$	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	11.4	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	8.0	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.6	%
100	= conversion factor (%)	=	100	%
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.15	lb/lb-mole

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.1825	
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.15	lb/lb-mole
$M_{H_2O}$	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
$M_s$	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.93	lb/lb-mole



**USEPA Method 26A  
 HCl Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041509 102810

1. Chloride to HCl conversion factor

$$K_{HCl} = \frac{MW_{HCl}}{n \times MW_{Cl^-}}$$

Where:

MW <sub>HCl</sub>	= molecular weight of HCl (mg/mg-mole)	=	36.461	mg/mg-mole
MW <sub>Cl<sup>-</sup></sub>	= molecular weight of chloride ion (mg/mg-mole)	=	35.453	mg/mg-mole
n	= molar ratio of chloride to HCl	=	1.0	mole Cl/mole HCl
K <sub>HCl</sub>	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	=	1.028	

2. Total HCl collected (mg)

$$m_{HCl} = K_{HCl} \times \frac{(S_{Cl-1} v_1 + S_{Cl-2} v_2)}{1000}$$

Where:

K <sub>HCl</sub>	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	=	1.028	
S <sub>Cl-1</sub>	= chloride concentration of sample fraction 1 (mg/liter)	=	818.0100	mg/liter
v <sub>1</sub>	= liquid volume of sample fraction 1 (ml)	=	706.0	ml
S <sub>Cl-2</sub>	= chloride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v <sub>2</sub>	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m <sub>HCl</sub>	= total HCl collected in sample (mg)	=	593.6855	mg

Note: Non-detects are treated as zero in summations.

**DEFINITION**

Fraction 1 = entire sample except last impinger containing applicable absorbing reagent.  
 Fraction 2 = last impinger containing applicable absorbing reagent, analyzed separately to evaluate collection efficiency.  
 If entire sample is analyzed as a single fraction, then data is included as Fraction 1 (Fraction 2 = 0).

3. Allowable blank subtraction (mg)

$$m_b = K_{HCl} \times B_{Cl} \times \frac{(v_1 + v_2)}{1000}$$

$$m_b = 0 \text{ if } B_{Cl} < MDL$$

Where:

K <sub>HCl</sub>	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	=	1.0280	
B <sub>Cl</sub>	= chloride concentration of blank (mg/liter)	=	<0.1	mg/liter
v <sub>1</sub>	= liquid volume of sample fraction 1 (ml)	=	706.0	ml
v <sub>2</sub>	= liquid volume of sample fraction 2 (ml)	=	0	ml
1000	= conversion factor (ml/liter)	=	1000.0000	ml/liter
m <sub>b</sub>	= allowable blank subtraction (mg)	=	0.0000	mg

4. Total HCl collected, corrected for blank (mg)

$$m_{nb} = m_{HCl} - m_b$$

Where:

$m_{HCl}$	= total HCl collected in sample (mg)	= 593.6855	mg
$m_b$	= allowable blank subtraction (mg)	= 0.0000	mg
$m_{nb}$	= total HCl collected, corrected for blank (mg)	= 593.6854817	mg

5. Minimum detectable HCl (mg)

$$m_{MDL} = K_{HCl} \times MDL \times \frac{(v_1 + v_2)}{1000}$$

Where:

$K_{HCl}$	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	= 1.028	
MDL	= minimum detectable chloride concentration	= 0.0	mg/liter
$v_1$	= liquid volume of sample fraction 1 (ml)	= 706.0	ml
$v_2$	= liquid volume of sample fraction 2 (ml)	= 0	ml
1000	= conversion factor (ml/liter)	= 1000	ml/liter
$m_{MDL}$	= minimum detectable HCl (mg)	= 0.010160752	mg

6. Total HCl value used in emission calculations (mg)

$$m_n = \text{MAXIMUM} [m_{nb} \text{ or } < m_{MDL}]$$

Where:

$m_{nb}$	= total HCl collected, corrected for blank (mg)	= 593.6855	mg
$m_{MDL}$	= minimum detectable HCl (mg)	= 0.010160752	mg
$m_n$	= total HCl value used in emission calculations (mg)	= 593.6854817	mg

7. Collection QC check (% mass collected in second fraction)

$$EFF = 100 \times \frac{K_{HCl} \times S_{Cl-2} \times \frac{v_2}{1000}}{m_{HCl}}$$

Where:

$K_{HCl}$	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	= 1.0280	
$S_{Cl-2}$	= chloride concentration of sample fraction 2 (mg/liter)	= 0.0	mg/liter
$v_2$	= liquid volume of sample fraction 2 (ml)	= 0.0000	ml
$m_{HCl}$	= total HCl collected in sample (mg)	= 594	mg
1000	= conversion factor (ml/liter)	= 1000	ml/liter
100	= conversion factor	= 100	%
EFF	= Collection QC check (% mass collected in second fraction)	= 0	%

**USEPA Method 26A  
 HCl Sample Calculations**

**Sample data taken from Run 1**

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041509 102810  
 L\_@

1. HCl concentration (lb/dscf)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	= 593.6855	mg
$V_{mstd}$	= volume metered, standard (dscf)	= 33.1054	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
$C_{sd}$	= HCl concentration (lb/dscf)	= 3.9543E-05	lb/dscf

2. HCl concentration (ppmdv)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{0.850}{1000} \right) \left( \frac{10^6}{MW} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	= 593.6855	mg
$V_{mstd}$	= volume metered, standard (dscf)	= 33.1054	dscf
MW	= molecular weight of HCl (g/g-mole)	= 36.461	g/g-mole
0.850	= conversion factor (dscf/g-mole)	= 0.850	dscf/g-mole
1000	= conversion factor (mg/g)	= 1,000	mg/g
$10^6$	= conversion factor (ppm)	= $10^6$	ppm
$C_{sd}$	= HCl concentration (ppmdv)	= 418.0693	ppmdv

3. HCl concentration (ppmwv)

$$C_w = C_{sd} \left( 1 - \frac{B_w}{100} \right)$$

Where:

$C_{sd}$	= HCl concentration (ppmdv)	= 418.0693	ppmdv
$B_w$	= actual water vapor in gas (% v/v)	= 18.2458	% v/v
100	= conversion factor (%)	= 100	%
$C_w$	= HCl concentration (ppmwv)	= 341.7892	ppmwv

4. HCl concentration (mg/dscm)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	= 593.6855	mg
$V_{mstd}$	= volume metered, standard (dscf)	= 33.1054	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
$C_{sd}$	= HCl concentration (mg/dscm)	= 633.2215	mg/dscm

5. HCl concentration (mg/Nm<sup>3</sup> dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	= 593.6855	mg
$V_{mstd}$	= volume metered, standard (dscf)	= 33.1054	dscf
35.31	= conversion factor (dscf/dscm)	= 35.31	dscf/dscm
68	= standard temperature (°F)	= 68	°F
32	= normal temperature (°F)	= 32	°F
460	= °F to °R conversion constant	= 460	
$C_{sd}$	= HCl concentration (mg/Nm <sup>3</sup> dry)	= 679.5548	mg/Nm <sup>3</sup> dry

6. HCl concentration corrected to x% O<sub>2</sub> (ppmdv example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= HCl concentration (ppmdv)	= 418.0693	ppmdv
x	= oxygen content of corrected gas (%)	= 7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 8.0	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$C_{sdx}$	= HCl concentration corrected to x%O <sub>2</sub> (ppmdv)	= 450.4778	ppmdv @ x%O <sub>2</sub>

7. HCl concentration corrected to y% CO<sub>2</sub> (ppmdv example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= HCl concentration (ppmdv)	= 418.0693	ppmdv
y	= carbon dioxide content of corrected gas (%)	= 12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	= 11.4	%
$C_{sdy}$	= HCl concentration corrected to y%CO <sub>2</sub> (ppmdv)	= 439.6873	ppmdv @ y%CO <sub>2</sub>

8. HCl rate -  $F_d$ -based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	=	593.6855	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	33.1054	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	8.0	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
$E_{Fd}$	= HCl rate (lb/MMBtu)	=	6.1311E-01	lb/MMBtu

9. HCl rate -  $F_c$ -based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	=	593.6855	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	33.1054	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	=	1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	=	11.4	%
100	= conversion factor	=	100	
$E_{Fc}$	= HCl rate (lb/MMBtu)	=	6.3074E-01	lb/MMBtu

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

**EPA Modified Method 26A (HCI)  
Sampling, Velocity and Moisture Sample Calculations**

Sample data taken from Run 1

*Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.*

041508 102858  
Q

1. Volume of water collected (wscf)

$$V_{wstd} = (0.04706)(V_{lc})$$

Where:

$V_{lc}$	= total volume of liquid collected in impingers and silica gel (ml)	=	248.4	ml
0.04706	= ideal gas conversion factor (ft <sup>3</sup> water vapor/ml or gm)	=	0.04706	ft <sup>3</sup> /ml
$V_{wstd}$	= volume of water vapor collected at standard conditions (ft <sup>3</sup> )	=	11.69	ft <sup>3</sup>

2. Volume of gas metered, standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{bar} + \frac{\Delta H}{13.6} \right) (Y_d)}{(460 + T_m)}$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.20	in. Hg
$T_m$	= average dry gas meter temperature (°F)	=	81.46	°F
$V_m$	= volume of gas sample through the dry gas meter at meter conditions (dcf)	=	40.68	dcf
$Y_d$	= gas meter correction factor (dimensionless)	=	0.9886	
$\Delta H$	= average pressure drop across meter box orifice (in. H <sub>2</sub> O)	=	1.50	in. H <sub>2</sub> O
17.64	= standard temperature to pressure ratio (°R/in. Hg)	=	17.64	°R/in. Hg
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in.H <sub>2</sub> O/in. Hg
460	= °F to °R conversion constant	=	460	

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	=	39.712	dscf
------------	---	---	--------	------

3. Sample gas pressure (in. Hg)

$$P_s = P_{bar} + \left( \frac{P_g}{13.6} \right)$$

Where:

$P_{bar}$	= barometric pressure (in. Hg)	=	30.20	in. Hg
$P_g$	= sample gas static pressure (in. H <sub>2</sub> O)	=	-10.40	in. H <sub>2</sub> O
13.6	= conversion factor (in. H <sub>2</sub> O/in. Hg)	=	13.6	in. H <sub>2</sub> O/in. Hg
$P_s$	= absolute sample gas pressure (in. Hg)	=	29.44	in. Hg

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

4. Actual water vapor pressure at sample gas temperature less than 212°F (in. Hg)

$$P_v = \frac{e^{\left( \frac{18.3036 - \frac{3816.44}{\frac{5}{9}(T_s - 32) + 273.15 - 46.13}}{25.4} \right)}}{25.4}$$

Where:

$T_s$	= average sample gas temperature (°F)	= 304.08	°F
18.3036	= Antoine coefficient	= 18.3036	°K
3816.44	= Antoine coefficient	= 3816.44	°K
273.15	= temperature conversion factor	= 273.15	°K
46.13	= Antoine coefficient	= 46.13	°K
25.4	= conversion factor	= 25.4	mm Hg/in. Hg
5/9	= Fahrenheit to Celsius conversion factor	= 5/9	°C/°F
32	= temperature conversion (°F)	= 32	°F
$P_v$	= vapor pressure, actual (in. Hg)	= 29.44	in. Hg

5. Water vapor pressure at gas temperature greater than 212°F (in. Hg)

$$P_v = P_s$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	= 29.44	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	= 29.44	in. Hg

6. Moisture measured in sample (% by volume)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

Where:

$V_{mstd}$	= volume of gas sampled through the dry gas meter at standard conditions (dscf)	= 39.712	dscf
$V_{wstd}$	= volume of water collected at standard conditions (scf)	= 11.69	scf
$B_{wo}$	= proportion of water measured in the gas stream by volume	= 0.2274	
		= 22.74	%

Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

## 7. Saturated moisture content (% by volume)

$$B_{ws} = \frac{P_v}{P_s}$$

Where:

$P_s$	= absolute sample gas pressure (in. Hg)	=	29.44	in. Hg
$P_v$	= water vapor pressure, actual (in. Hg)	=	29.44	in. Hg
$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
		=	100.00	%

## 8. Actual water vapor in gas (% by volume)

$$B_w = \text{MINIMUM} [B_{wo}, B_{ws}]$$

Where:

$B_{ws}$	= proportion of water vapor in the gas stream by volume at saturated conditions	=	1.0000	
$B_{wo}$	= proportion of water measured in the gas stream by volume	=	0.2274	
$B_w$	= actual water vapor in gas	=	0.2274	
		=	22.74	%

## 9. Nitrogen (plus carbon monoxide) in gas stream (% by volume, dry)

$$N_2 + CO = 100 - CO_2 - O_2$$

Where:

$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.4	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
100	= conversion factor (%)	=	100	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.40	%



Wheelabrator South Broward, Inc.  
Clean Air Project No: 10735  
Unit 1 FF Outlet

10. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = (M_{CO_2}) \frac{(CO_2)}{(100)} + (M_{O_2}) \frac{(O_2)}{(100)} + (M_{N_2+CO}) \frac{(N_2 + CO)}{(100)}$$

Where:

$M_{CO_2}$	= molecular weight of carbon dioxide (lb/lb-mole)	=	44.00	lb/lb-mole
$M_{O_2}$	= molecular weight of oxygen (lb/lb-mole)	=	32.00	lb/lb-mole
$M_{N_2+CO}$	= molecular weight of nitrogen and carbon monoxide (lb/lb-mole)	=	28.00	lb/lb-mole
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.4	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
$N_2+CO$	= proportion of nitrogen and CO in the gas stream by volume (%)	=	80.4	%
100	= conversion factor (%)	=	100	%
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.03	lb/lb-mole

11. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_w) + (M_{H_2O})(B_w)$$

Where:

$B_w$	= proportion of water vapor in the gas stream by volume	=	0.2274	
$M_d$	= dry molecular weight of sample gas (lb/lb-mole)	=	30.03	lb/lb-mole
$M_{H_2O}$	= molecular weight of water (lb/lb-mole)	=	18.00	lb/lb-mole
$M_s$	= molecular weight of sample gas, wet basis (lb/lb-mole)	=	27.30	lb/lb-mole

**EPA Modified Method 26A  
 HCl Analyte Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041609 102856  
 ©

1. Chloride to HCl conversion factor

$$K_{HCl} = \frac{MW_{HCl}}{n \times MW_{Cl^-}}$$

Where:

MW <sub>HCl</sub>	= molecular weight of HCl (mg/mg-mole)	=	36.461	mg/mg-mole
MW <sub>Cl<sup>-</sup></sub>	= molecular weight of chloride ion (mg/mg-mole)	=	35.453	mg/mg-mole
n	= molar ratio of chloride to HCl	=	1.0	mole Cl <sup>-</sup> /mole HCl
K <sub>HCl</sub>	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	=	1.028	

2. Total HCl collected (mg)

$$m_{HCl} = K_{HCl} \times \frac{(S_{Cl-1}v_1 + S_{Cl-2}v_2)}{1000}$$

Where:

K <sub>HCl</sub>	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	=	1.028	
S <sub>Cl-1</sub>	= chloride concentration of sample fraction 1 (mg/liter)	=	18.2000	mg/liter
v <sub>1</sub>	= liquid volume of sample fraction 1 (ml)	=	941.0	ml
S <sub>Cl-2</sub>	= chloride concentration of sample fraction 2 (mg/liter)	=	0.0000	mg/liter
v <sub>2</sub>	= liquid volume of sample fraction 2 (ml)	=	0.0	ml
1000	= conversion factor (ml/liter)	=	1000	ml/liter
m <sub>HCl</sub>	= total HCl collected in sample (mg)	=	17.6057	mg

Note: Non-detects are treated as zero in summations.

**DEFINITION**

Fraction 1 = entire sample except last impinger containing applicable absorbing reagent.  
 Fraction 2 = last impinger containing applicable absorbing reagent, analyzed separately to evaluate collection efficiency.  
 If entire sample is analyzed as a single fraction, then data is included as Fraction 1 (Fraction 2 = 0).

3. Allowable blank subtraction (mg)

$$m_b = K_{HCl} \times B_{Cl} \times \frac{(v_1 + v_2)}{1000}$$

$$m_b = 0 \text{ if } B_{Cl} < MDL$$

Where:

K <sub>HCl</sub>	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	=	1.0280	
B <sub>Cl</sub>	= chloride concentration of blank (mg/liter)	=	<0.1	mg/liter
v <sub>1</sub>	= liquid volume of sample fraction 1 (ml)	=	941.0	ml
v <sub>2</sub>	= liquid volume of sample fraction 2 (ml)	=	0	ml
1000	= conversion factor (ml/liter)	=	1000.0000	ml/liter
m <sub>b</sub>	= allowable blank subtraction (mg)	=	0.0000	mg

4. Total HCl collected, corrected for blank (mg)

$$m_{nb} = m_{HCl} - m_b$$

Where:

$m_{HCl}$	= total HCl collected in sample (mg)	= 17.6057	mg
$m_b$	= allowable blank subtraction (mg)	= 0.0000	mg
$m_{nb}$	= total HCl collected, corrected for blank (mg)	= 17.6057336	mg

5. Minimum detectable HCl (mg)

$$m_{MDL} = K_{HCl} \times MDL \times \frac{(v_1 + v_2)}{1000}$$

Where:

$K_{HCl}$	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	= 1.028	
MDL	= minimum detectable chloride concentration	= 0.0	mg/liter
$v_1$	= liquid volume of sample fraction 1 (ml)	= 941.0	ml
$v_2$	= liquid volume of sample fraction 2 (ml)	= 0	ml
1000	= conversion factor (ml/liter)	= 1000	ml/liter
$m_{MDL}$	= minimum detectable HCl (mg)	= 0.013542872	mg

6. Total HCl value used in emission calculations (mg)

$$m_n = \text{MAXIMUM} [m_{nb} \text{ or } < m_{MDL}]$$

Where:

$m_{nb}$	= total HCl collected, corrected for blank (mg)	= 17.6057	mg
$m_{MDL}$	= minimum detectable HCl (mg)	= 0.013542872	mg
$m_n$	= total HCl value used in emission calculations (mg)	= 17.6057336	mg

7. Collection QC check (% mass collected in second fraction)

$$EFF = 100 \times \frac{K_{HCl} \times S_{Cl-2} \times \frac{v_2}{1000}}{m_{HCl}}$$

Where:

$K_{HCl}$	= conversion factor to convert mass Cl <sup>-</sup> to mass HCl	= 1.0280	
$S_{Cl-2}$	= chloride concentration of sample fraction 2 (mg/liter)	= 0.0	mg/liter
$v_2$	= liquid volume of sample fraction 2 (ml)	= 0.0000	ml
$m_{HCl}$	= total HCl collected in sample (mg)	= 18	mg
1000	= conversion factor (ml/liter)	= 1000	ml/liter
100	= conversion factor	= 100	%
EFF	= Collection QC check (% mass collected in second fraction)	= 0	%

**EPA Modified Method 26A  
 HCl Sample Calculations**

Sample data taken from Run 1

Note: The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results, and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

041508 102856  
 Q\_@

1. HCl concentration (lb/dscf)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	=	17.6057	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	39.7123	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	=	2.205E-03	lb/g
1000	= conversion factor (mg/g)	=	1,000	mg/g
$C_{sd}$	= HCl concentration (lb/dscf)	=	9.7755E-07	lb/dscf

2. HCl concentration (ppmdv)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{0.850}{1000} \right) \left( \frac{10^6}{MW} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	=	17.6057	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	39.7123	dscf
MW	= molecular weight of HCl (g/g-mole)	=	36.461	g/g-mole
0.850	= conversion factor (dscf/g-mole)	=	0.850	dscf/g-mole
1000	= conversion factor (mg/g)	=	1,000	mg/g
$10^6$	= conversion factor (ppm)	=	$10^6$	ppm
$C_{sd}$	= HCl concentration (ppmdv)	=	10.3352	ppmdv

3. HCl concentration (ppmwv)

$$C_w = C_{sd} \left( 1 - \frac{B_w}{100} \right)$$

Where:

$C_{sd}$	= HCl concentration (ppmdv)	=	10.3352	ppmdv
$B_w$	= actual water vapor in gas (% v/v)	=	22.7417	% v/v
100	= conversion factor (%)	=	100	%
$C_w$	= HCl concentration (ppmwv)	=	7.9848	ppmwv

4. HCl concentration (mg/dscm)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	=	17.6057	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	39.7123	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
$C_{sd}$	= HCl concentration (mg/dscm)	=	15.6540	mg/dscm

5. HCl concentration (mg/Nm<sup>3</sup> dry)

$$C_{sd} = \left( \frac{m_n}{V_{mstd}} \right) (35.31) \left( \frac{68 + 460}{32 + 460} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	=	17.6057	mg
$V_{mstd}$	= volume metered, standard (dscf)	=	39.7123	dscf
35.31	= conversion factor (dscf/dscm)	=	35.31	dscf/dscm
68	= standard temperature (°F)	=	68	°F
32	= normal temperature (°F)	=	32	°F
460	= °F to °R conversion constant	=	460	
$C_{sd}$	= HCl concentration (mg/Nm <sup>3</sup> dry)	=	16.7995	mg/Nm <sup>3</sup> dry

6. HCl concentration corrected to x% O<sub>2</sub> (ppmdv example)

$$C_{sdx} = C_{sd} \left( \frac{20.9 - x}{20.9 - O_2} \right)$$

Where:

$C_{sd}$	= HCl concentration (ppmdv)	=	10.3352	ppmdv
x	= oxygen content of corrected gas (%)	=	7.0	%
$O_2$	= proportion of oxygen in the gas stream by volume (%)	=	9.2	%
20.9	= oxygen content of ambient air (%)	=	20.9	%
$C_{sdx}$	= HCl concentration corrected to x%O <sub>2</sub> (ppmdv)	=	12.2786	ppmdv @ x%O <sub>2</sub>

7. HCl concentration corrected to y% CO<sub>2</sub> (ppmdv example)

$$C_{sdy} = C_{sd} \left( \frac{y}{CO_2} \right)$$

Where:

$C_{sd}$	= HCl concentration (ppmdv)	=	10.3352	ppmdv
y	= carbon dioxide content of corrected gas (%)	=	12.0	%
$CO_2$	= proportion of carbon dioxide in the gas stream by volume (%)	=	10.4	%
$C_{sdy}$	= HCl concentration corrected to y%CO <sub>2</sub> (ppmdv)	=	11.9252	ppmdv @ y%CO <sub>2</sub>

8. HCl rate -  $F_d$ -based (lb/MMBtu)

$$E_{Fd} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right) (F_d) \left( \frac{20.9}{20.9 - O_2} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	= 17.6057	mg
$V_{mstd}$	= volume metered, standard (dscf)	= 39.7123	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
$F_d$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 9,570	dscf/MMBtu
$O_2$	= proportion of oxygen in the gas stream by volume (%)	= 9.2	%
20.9	= oxygen content of ambient air (%)	= 20.9	%
$E_{Fd}$	= HCl rate (lb/MMBtu)	= 1.6711E-02	lb/MMBtu

9. HCl rate -  $F_c$ -based (lb/MMBtu)

$$E_{Fc} = \left( \frac{m_n}{V_{mstd}} \right) \left( \frac{2.205 \times 10^{-3}}{1000} \right) (F_c) \left( \frac{100}{CO_2} \right)$$

Where:

$m_n$	= total HCl collected, corrected for applicable blank (mg)	= 17.6057	mg
$V_{mstd}$	= volume metered, standard (dscf)	= 39.7123	dscf
$2.205 \times 10^{-3}$	= conversion factor (lb/g)	= 2.205E-03	lb/g
1000	= conversion factor (mg/g)	= 1,000	mg/g
$F_c$	= ratio of gas volume to heat content of fuel (dscf/MMBtu)	= 1,820	dscf/MMBtu
$CO_2$	= proportion of oxygen in the gas stream by volume (%)	= 10.4	%
100	= conversion factor	= 100	
$E_{Fc}$	= HCl rate (lb/MMBtu)	= 1.7107E-02	lb/MMBtu

WHEELABRATOR SOUTH BROWARD, INC.  
FT. LAUDERDALE, FL

CleanAir Project No: 10735-4

**PLANT DATA**

C

**This Page Intentionally Left Blank**



**WHEELABRATOR SOUTH BROWARD  
TONS OF REFUSE PROCESSED PER STACK TEST RUN LOG (2009)**

<b>UNIT #1</b>						
Date	Test	Method #	Run #	Steam (lb/hr)	Run Length (hr)	Trash Processed (tons)
3/16/2009	HCl	26A	1	184.7	1.00	31.8
3/16/2009	HCl	26A	2	184.7	1.00	31.8
3/16/2009	HCl	26A	3	183.5	1.00	31.6
3/18/2009	Particulate/Metals	5/29	1	183.6	2.18	69.0
3/18/2009	Particulate/Metals	5/29	2	183.4	2.18	68.9
3/18/2009	Particulate/Metals	5/29	3	184.0	2.17	68.9
3/18/2009	Fluorides	13B	1	184.3	1.33	42.3
3/18/2009	Fluorides	13B	2	183.8	1.32	41.8
3/18/2009	Fluorides	13B	3	184.1	1.23	39.0
3/16/2009	Dioxins/Furans	23	1	184.0	4.42	140.2
3/17/2009	Dioxins/Furans	23	2	183.4	4.32	136.6
3/17/2009	Dioxins/Furans	23	3	184.2	4.40	139.8

<b>UNIT #2</b>						
Date	Test	Method #	Run #	Steam (lb/hr)	Run Length (hr)	Trash Processed (tons)
3/17/2009	HCl	26A	1	182.6	1.00	31.5
3/17/2009	HCl	26A	2	185.2	1.00	31.9
3/17/2009	HCl	26A	3	183.2	1.00	31.6
3/16/2009	Particulate/Metals	5/29	1	184.1	2.40	76.2
3/16/2009	Particulate/Metals	5/29	2	184.9	2.18	69.5
3/16/2009	Particulate/Metals	5/29	3	183.9	2.23	70.7
3/17/2009	Fluorides	13B	1	185.1	1.18	37.6
3/17/2009	Fluorides	13B	2	184.7	1.20	38.2
3/17/2009	Fluorides	13B	3	183.9	1.15	36.5
n/a	Dioxins/Furans	23	1	n/a	n/a	n/a
n/a	Dioxins/Furans	23	2	n/a	n/a	n/a
n/a	Dioxins/Furans	23	3	n/a	n/a	n/a

<b>UNIT #3</b>						
Date	Test	Method #	Run #	Steam (lb/hr)	Run Length (hr)	Trash Processed (tons)
3/18/2009	HCl	26A	1	184.1	1.00	31.7
3/18/2009	HCl	26A	2	184.2	1.00	31.8
3/18/2009	HCl	26A	3	183.9	1.00	31.7
3/17/2009	Particulate/Metals	5/29	1	184.0	2.15	68.2
3/17/2009	Particulate/Metals	5/29	2	184.0	2.15	68.2
3/17/2009	Particulate/Metals	5/29	3	184.1	2.18	69.2
3/16/2009	Fluorides	13B	1	184.2	1.30	41.3
3/16/2009	Fluorides	13B	2	184.0	1.28	40.6
3/16/2009	Fluorides	13B	3	184.4	1.35	42.9
n/a	Dioxins/Furans	23	1	n/a	n/a	n/a
n/a	Dioxins/Furans	23	2	n/a	n/a	n/a
n/a	Dioxins/Furans	23	3	n/a	n/a	n/a

Metals: Cd (cadmium) Hg (mercury) Be (beryllium) Pb (lead)

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/18/2009  
Start Time: 7:47:00  
End Time: 9:58:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
-------------------	--------------------	----------------------	-------------------	--------------	----------------	----------	-------------------	---------------

Unit	Run	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	5/29 run 1	516.30	313.25	37.07	30.68	11.76	290.74	6.38	-11.75	183.58
Unit 2		513.06	313.41	37.75	30.96	11.52	295.90	6.58	-10.40	183.97
Unit 3		485.28	313.15	35.73	25.48	12.47	294.50	6.84	-10.32	184.02

C-4

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	FCONG OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------	--------------

Unit	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.71	910.44	826.38	88.34	-0.10	431.47	1096.53	3.83	6.30	9.27
Unit 2	185.13	908.50	822.69	86.74	-0.10	420.87	1085.42	3.58	5.92	9.38
Unit 3	187.71	900.17	825.44	81.34	-0.11	398.06	1086.58	4.13	6.83	9.81

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/18/2009  
Start Time: 10:25:00  
End Time: 12:36:00

		SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME % CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
		DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	5/29 run 2	519.07	305.02	38.71	33.51	12.79	286.46	6.42	-11.72	183.41
Unit 2		519.96	305.12	41.97	32.98	11.76	288.51	6.56	-10.22	183.48
Unit 3		493.98	304.92	40.05	34.27	14.04	289.33	6.83	-10.56	184.13

C - 5

		FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOTAL AIR FLOW	FURNACE DRAFT	SCONG OUT TEMP	SHROBE AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
		KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1		185.37	910.69	824.75	86.78	-0.10	430.82	1120.26	5.60	6.15	9.11
Unit 2		184.36	908.61	821.40	89.12	-0.10	422.83	1097.96	4.38	6.27	9.61
Unit 3		187.30	900.31	822.37	80.81	-0.10	399.12	1106.64	5.30	6.43	9.57

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/18/2009  
Start Time: 13:18:00  
End Time: 15:28:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	WME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
-------------------	--------------------	--------------------	-------------------	-------------	----------------	----------	-------------------	---------------

		DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBs/hr
Unit 1	5/29 run 3	520.38	304.96	38.62	32.73	13.78	287.20	6.35	-11.57	184.03
Unit 2		521.65	305.02	41.50	34.42	12.79	288.50	6.52	-10.12	183.79
Unit 3		490.41	304.96	37.48	31.68	15.17	287.67	6.72	-10.11	183.99

C - 6

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGONG OUT TEMP	SHROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
------------------	---------------------	-------------------	-----------------	------------------	-------------------	---------------	-------------------	---------------	--------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.83	911.09	824.57	86.50	-0.11	430.54	1120.51	4.87	6.05	9.06
Unit 2	184.83	908.95	822.29	88.60	-0.10	421.91	1091.50	4.92	6.25	9.57
Unit 3	187.72	900.71	825.00	79.29	-0.10	393.10	1112.35	4.34	6.50	9.25

## General Average Report

Reporting Period: 03/18/2009 to 03/18/2009

Site Name: UNIT1

Time of Report: 03/18/09 14:46

Data Averaging Type: 6m

Rolling Average Interval: 1

Date	Time	OPACITY1 (PERCENT )
03/18/09	06:42	0
	06:48	0
	06:54	0
	07:00	0
	07:06	0
	07:12	0
	07:18	0
	07:24	0
	07:30	0
	07:36	0
	07:42	0
	07:48	0
	07:54	0
	08:00	0
	08:06	0
	08:12	0
	08:18	0
	08:24	0
	08:30	0
	08:36	0
	08:42	0
	08:48	0

---

Average =	0
Geometric Avg. =	0
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	6

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing  
 T - out-of-control  
 I - invalid  
 S - suspect  
 H - exceedance  
 F - stack not operating  
 B - invalid (PADER)  
 U - missing data substituted  
 -999 - missing value  
 -888 - value could not be calculated

## General Average Report

Reporting Period: 03/18/2009 to 03/18/2009

Site Name: UNIT1

Data Averaging Type: 6m

Time of Report: 03/18/09 14:46

Rolling Average Interval: 1

Date	Time	OPACITY1 (PERCENT )
03/18/09	09:24	0
	09:30	0
	09:36	0
	09:42	0
	09:48	0
	09:54	0
	10:00	0
	10:06	0
	10:12	0
	10:18	0
	10:24	0
	10:30	0
	10:36	0
	10:42	0
	10:48	0
	10:54	0
	11:00	0
	11:06	0
	11:12	0
	11:18	0
	11:24	0
	11:30	0

---

Average =	0
Geometric Avg. =	0
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	7

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing  
 T - out-of-control  
 I - invalid  
 S - suspect  
 H - exceedance  
 F - stack not operating  
 B - invalid (PADER)  
 U - missing data substituted  
 -999 - missing value  
 -888 - value could not be calculated

## General Average Report

Reporting Period: 03/18/2009 to 03/18/2009

Site Name: UNIT1

Data Averaging Type: 6m

Time of Report: 03/18/09 14:46

Rolling Average Interval: 1

Date	Time	OPACITY1 (PERCENT )
03/18/09	12:12	0
	12:18	0
	12:24	0
	12:30	0
	12:36	0
	12:42	0
	12:48	0
	12:54	0
	13:00	0
	13:06	0
	13:12	0
	13:18	0
	13:24	0
	13:30	0
	13:36	0
	13:42	0
	13:48	0
	13:54	0
	14:00	0
	14:06	0
	14:12	0
	14:18	0

---

Average =	0
Geometric Avg. =	0
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	6

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing  
 T - out-of-control  
 I - invalid  
 S - suspect  
 H - exceedance  
 F - stack not operating  
 B - invalid (PADER)  
 U - missing data substituted  
 -999 - missing value  
 -888 - value could not be calculated

Reporting Period: 03/18/2009 to 03/18/2009

Site Name: UNIT1  
Data Averaging Type: 1m

Time of Report: 03/18/09 14:43  
Rolling Average Interval: 1

CARFESD1  
(LBS/HR )

---

Average =	7
Geometric Avg. =	6
Maximum =	8
Minimum =	3
Possible Values =	131
Included Values =	131
Total =	854



General Average Report

Reporting Period: 03/18/2009 to 03/18/2009

Site Name: UNIT1  
Data Averaging Type: 1m

Time of Report: 03/18/09 14:43  
Rolling Average Interval: 1

CARFEED1  
(LBS/HR )

---

Average =	6
Geometric Avg. =	6
Maximum =	8
Minimum =	3
Possible Values =	132
Included Values =	132
Total =	748

General Average Report

Reporting Period: 03/18/2009 to 03/18/2009

Site Name: UNIT1

Time of Report: 03/18/09 14:42

Data Averaging Type: 1m

Rolling Average Interval: 1

CARFED1  
(LBS/HR )

---

Average =	5
Geometric Avg. =	5
Maximum =	7
Minimum =	3
Possible Values =	132
Included Values =	132
Total =	703

# Wheelabrator SOUTH BROWARD Emission Test Log

Date: 3/18/2009  
Start Time: 7:36:00  
End Time: 8:56:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY/FL	DIL WATER FLOW	IME GONG	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
-------------------	--------------------	--------------------	-------------------	-------------	----------------	----------	-------------------	---------------

		DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	13B run 1	514.14	314.98	35.97	27.45	12.00	290.71	6.38	-11.65	184.25
Unit 2		512.36	314.89	36.91	29.89	11.68	295.76	6.56	-10.45	184.49
Unit 3		485.11	314.84	35.23	24.64	12.27	294.45	6.88	-10.38	184.21

C-13

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEMIFLOW	FURNACE O2	OUTLET O2
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------	--------------

		KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1		186.68	910.70	828.19	87.77	-0.10	429.77	1095.87	3.51	6.24	9.20
Unit 2		185.61	908.72	822.60	86.90	-0.11	420.88	1080.94	3.40	5.99	9.48
Unit 3		187.86	900.24	824.94	81.22	-0.10	398.63	1086.04	4.07	6.79	9.88

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/18/2009  
Start Time: 9:08:00  
End Time: 10:27:00

		SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	IME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
		DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	13B run 2	517.31	308.40	38.18	33.43	11.69	289.06	6.30	-11.66	183.79
Unit 2		514.84	308.67	39.63	32.82	11.24	293.93	6.52	-10.22	183.79
Unit 3		486.89	308.58	37.67	30.53	12.86	292.79	6.79	-10.40	183.96

C - 14

		FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOTAL AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
		KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1		185.76	910.58	824.39	87.54	-0.10	432.31	1112.17	5.15	6.15	9.12
Unit 2		184.75	908.49	821.99	86.65	-0.10	421.70	1092.84	4.70	5.84	9.23
Unit 3		187.41	900.25	824.93	82.32	-0.11	397.83	1092.89	4.49	6.80	9.68

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/18/2009  
Start Time: 10:53:00  
End Time: 12:07:00

		SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY / FL	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
		DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	13B run 3	519.77	305.01	38.90	33.81	12.71	286.67	6.50	-11.80	184.12
Unit 2		522.04	305.03	43.10	32.85	11.44	288.46	6.65	-10.40	183.71
Unit 3		494.80	304.94	40.10	34.45	13.98	289.91	6.84	-10.56	184.14

C - 15

		FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
		KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1		185.86	910.89	823.99	86.72	-0.10	431.55	1119.63	5.98	6.06	9.04
Unit 2		184.65	908.78	820.98	89.87	-0.10	424.69	1096.18	5.24	6.27	9.63
Unit 3		187.10	900.37	821.24	80.85	-0.10	399.11	1108.12	5.15	6.32	9.50

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 12:13:00  
End Time: 16:38:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
-------------------	--------------------	----------------------	-------------------	--------------	----------------	----------	-------------------	---------------

Unit	Run	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBs/hr
Unit 1	23 run 1	520.61	320.08	37.22	32.14	11.97	300.70	6.42	-11.80	184.02
Unit 2		517.26	315.04	37.53	31.44	11.80	300.87	6.56	-9.77	183.46
Unit 3		497.15	314.99	38.08	32.23	11.60	299.10	6.79	-10.61	184.09

FEED H2O FLOW	SH OUT STMPRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EC ONC OUT TEMP	SH BOIL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
------------------	--------------------	-------------------	-----------------	------------------	--------------------	----------------	-------------------	---------------	--------------

Unit	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.47	913.61	825.01	87.08	-0.10	432.44	1107.87	3.36	6.53	9.56
Unit 2	184.56	908.83	821.00	84.61	-0.10	420.01	1105.57	4.34	6.40	9.85
Unit 3	187.56	901.06	825.00	80.52	-0.11	399.00	1067.15	3.79	7.05	10.09

C - 16

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/17/2009  
Start Time: 7:14:00  
End Time: 11:33:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY/RL	DIC WATER FLOW	LIME CONC	FF OUT TEMP	FF OP	ID INLET PRESS	STEAM FLOW
-------------------	--------------------	--------------------	-------------------	--------------	----------------	----------	-------------------	---------------

Unit	Run	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	23-run 2	521.07	320.01	37.24	31.41	11.81	300.00	6.45	-11.83	183.42
Unit 2		507.91	315.53	35.55	28.30	12.47	298.18	6.54	-10.08	183.46
Unit 3		489.84	315.00	37.40	29.99	10.74	299.53	6.86	-10.57	183.99

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROTL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------	--------------

Unit	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	184.90	912.62	824.46	90.68	-0.10	433.77	1104.79	3.17	6.49	9.57
Unit 2	184.44	908.55	821.06	84.80	-0.10	417.34	1092.08	4.27	5.94	9.54
Unit 3	187.26	900.58	823.21	83.71	-0.11	400.74	1069.87	3.40	6.85	10.16

C - 17

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/17/2009  
Start Time: 12:00:00  
End Time: 16:24:00

		SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DR	ID INLET PRESS	STEAM FLOW
		DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	23 run 3	520.37	320.02	35.96	30.11	12.46	301.50	6.41	-11.62	184.22
Unit 2		512.07	320.22	34.92	25.64	13.37	302.70	6.51	-9.44	184.38
Unit 3		498.57	314.95	39.29	32.38	11.40	301.26	6.86	-10.84	184.09

		FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
		KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1		185.55	914.85	825.44	88.06	-0.10	430.81	1113.13	3.18	6.34	9.35
Unit 2		185.69	909.60	822.54	83.94	-0.10	415.96	1105.23	3.67	5.82	9.45
Unit 3		187.53	901.49	824.32	85.36	-0.10	400.47	1095.26	3.96	6.94	10.20

C - 18



Plant Name: SBWD  
General Average Report

Reporting Period: 03/16/2009 to 03/16/2009

Site Name: UNIT1  
Data Averaging Type: 1m

Time of Report: 04/10/09 06:13  
Rolling Average Interval: 1

CARFRED1  
(LBS/HR )

---

Average =	6
Geometric Avg. =	6
Maximum =	8
Minimum =	1
Possible Values =	256
Included Values =	256
Total =	1601

Plant Name: SHWD  
General Average Report

Reporting Period: 03/17/2009 to 03/17/2009

Site Name: UNIT1  
Data Averaging Type: 1m

Time of Report: 04/10/09 06:13  
Rolling Average Interval: 1

CARFEE01  
(LBS/HR )

---

Average =	5
Geometric Avg. =	5
Maximum =	7
Minimum =	3
Possible Values =	260
Included Values =	260
Total =	1392

Plant Name: SBWD  
General Average Report

Page: 1

Reporting Period: 03/17/2009 to 03/17/2009

Site Name: UNIT1  
Data Averaging Type: 1m

Time of Report: 04/10/09 06:13  
Rolling Average Interval: 1

CARFEED1  
(LBS/KR )

---

Average =	5
Geometric Avg. =	5
Maximum =	11
Minimum =	2
Possible Values =	265
Included Values =	265
Total =	1386

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 7:50:00  
End Time: 8:50:00

		SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	WME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
		DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	26A run 1	516.47	320.00	37.05	30.70	17.05	298.89	6.44	-11.84	184.72
Unit 2		521.24	314.68	41.20	33.47	15.35	299.39	6.50	-10.31	184.61
Unit 3		492.92	314.90	38.45	31.71	17.17	299.16	6.72	-10.46	184.33

		FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
		KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1		186.65	912.97	826.42	86.66	-0.11	433.45	1105.81	5.37	6.24	9.28
Unit 2		185.57	909.35	822.43	84.62	-0.10	427.45	1091.56	5.14	6.38	9.85
Unit 3		187.85	901.00	824.02	84.91	-0.11	403.78	1033.21	6.69	6.88	9.69

C - 22

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 9:28:00  
End Time: 10:28:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	H <sub>2</sub> O OUT TEMP	REF DP	ID INLET PRESS	STEAM FLOW
-------------------	--------------------	--------------------	-------------------	--------------	------------------------------	-----------	-------------------	---------------

Unit	Run	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBs/hr
Unit 1	26A run 2	512.41	319.83	33.97	28.36	16.15	301.93	6.34	-11.47	184.67
Unit 2		511.88	315.06	35.98	30.49	15.26	301.98	6.61	-9.94	183.32
Unit 3		490.25	315.09	36.06	30.19	16.36	298.11	6.71	-10.33	183.99

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROIL AVG	SNCR CHEM FLOW	FURNACE O <sub>2</sub>	OUTLET O <sub>2</sub>
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------------------	--------------------------

Unit	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	186.23	913.30	824.30	84.66	-0.10	430.35	1110.84	3.94	6.10	9.13
Unit 2	185.29	908.88	823.83	83.96	-0.10	419.19	1098.33	4.81	6.30	9.59
Unit 3	187.47	900.81	822.07	83.64	-0.11	398.59	1043.18	4.20	6.46	9.82

C - 23

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 10:56:00  
End Time: 11:56:00

		SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY/FI	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
		DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	26A run 3	512.25	320.05	33.86	29.54	12.43	300.32	6.41	-11.52	183.45
Unit 2		515.04	314.87	36.94	31.07	11.33	299.92	6.43	-9.78	184.50
Unit 3		496.40	315.03	38.24	32.91	10.94	297.17	6.84	-10.66	183.92

C - 24

		FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SHROUL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
		KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1		184.95	913.65	825.03	85.70	-0.12	428.15	1112.82	1.34	6.52	9.51
Unit 2		185.20	909.20	820.31	85.78	-0.10	420.83	1095.10	2.91	6.31	9.76
Unit 3		187.37	901.17	824.25	82.38	-0.10	400.77	1035.70	2.42	7.04	10.23

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 8:02:00  
End Time: 10:26:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIE WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
-------------------	--------------------	--------------------	-------------------	--------------	----------------	----------	-------------------	---------------

	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	514.58	319.88	35.57	29.90	15.75	300.74	6.40	-11.67	184.51
Unit 2 5/29 run 1	515.74	314.84	38.07	32.00	14.70	300.91	6.52	-10.02	184.11
Unit 3	491.42	315.05	37.00	31.05	16.12	299.12	6.74	-10.40	183.90

C - 26

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNOR CHEM FLOW	FURNACE O2	OUTLET O2
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------	--------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	186.30	913.13	825.78	85.62	-0.10	432.15	1110.58	5.07	6.15	9.18
Unit 2	185.70	909.13	823.50	84.02	-0.10	422.77	1094.59	5.05	6.31	9.58
Unit 3	187.37	900.85	823.17	84.71	-0.11	400.89	1041.09	6.27	6.69	9.75

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 11:04:00  
End Time: 13:15:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	SLIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
-------------------	--------------------	--------------------	-------------------	---------------	----------------	----------	-------------------	---------------

	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBs/hr
Unit 1	514.64	320.01	34.53	30.09	12.31	300.73	6.35	-11.51	183.57
Unit 2 5/29 run 2	514.53	314.98	36.91	30.86	11.48	299.98	6.48	-9.75	184.93
Unit 3	497.44	314.99	38.47	33.39	11.00	298.17	6.77	-10.68	184.14

C - 26

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOTAL FLOW	FURNACE DRAFT	FCONG OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
------------------	---------------------	-------------------	---------------	------------------	-------------------	----------------	-------------------	---------------	--------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.12	913.93	825.02	86.42	-0.10	429.27	1112.77	2.20	6.47	9.50
Unit 2	185.99	909.48	821.69	84.06	-0.10	419.33	1098.78	3.33	6.33	9.75
Unit 3	187.43	901.38	824.30	81.71	-0.11	400.88	1050.18	2.99	7.13	10.28



**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 13:51:00  
End Time: 16:05:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	FEEDOUT TEMP	FEED DP	ID INLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	520.16	320.09	37.09	32.30	12.20	300.68	6.44	-11.79	184.32
Unit 2 5/29 run 3	517.96	315.01	37.61	31.20	11.96	301.28	6.58	-9.72	183.93
Unit 3	497.07	315.03	38.14	32.26	11.76	299.14	6.81	-10.63	184.03

	FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.84	913.77	824.60	87.25	-0.10	432.09	1103.81	3.49	6.49	9.51
Unit 2	185.36	909.23	823.73	84.76	-0.10	419.93	1111.67	4.36	6.19	9.64
Unit 3	187.26	901.14	823.19	80.91	-0.11	398.40	1076.84	4.24	7.00	10.04

C - 27

## General Average Report

Reporting Period: 03/16/2009 to 03/16/2009

Site Name: UNIT2

Time of Report: 03/17/09 07:26

Data Averaging Type: 6m

Rolling Average Interval: 1

Date	Time	OPACITY2 (PERCENT )
03/16/09	12:48	0
	12:54	0
	13:00	0
	13:06	0
	13:12	0
	13:18	0
	13:24	0
	13:30	0
	13:36	0
	13:42	0
	13:48	0
	13:54	0
	14:00	0
	14:06	0
	14:12	0
	14:18	0
	14:24	0
	14:30	0
	14:36	0
	14:42	0
	14:48	0
	14:54	0

---

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	0

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing  
 T - out-of-control  
 I - invalid  
 S - suspect  
 H - exceedance  
 F - stack not operating  
 B - invalid (PADER)  
 U - missing data substituted  
 -999 - missing value  
 -888 - value could not be calculated

## General Average Report

Reporting Period: 03/16/2009 to 03/16/2009

Site Name: UNIT2

Time of Report: 03/17/09 07:26

Data Averaging Type: 6m

Rolling Average Interval: 1

Date	Time	OPACITY2 (PERCENT )
03/16/09	10:00	0
	10:06	0
	10:12	0
	10:18	0
	10:24	0
	10:30	0
	10:36	0
	10:42	0
	10:48	0
	10:54	0
	11:00	0
	11:06	0
	11:12	0
	11:18	0
	11:24	0
	11:30	0
	11:36	0
	11:42	0
	11:48	0
	11:54	0
	12:00	0
	12:06	0

---

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	0

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing  
 T - out-of-control  
 I - invalid  
 S - suspect  
 H - exceedance  
 F - stack not operating  
 B - invalid (PADER)  
 U - missing data substituted  
 -999 - missing value  
 -888 - value could not be calculated

## General Average Report

Reporting Period: 03/16/2009 to 03/16/2009

Site Name: UNIT2

Time of Report: 03/17/09 07:26

Data Averaging Type: 6m

Rolling Average Interval: 1

Date	Time	OPACITY2 (PERCENT )
03/16/09	07:00	0
	07:06	0
	07:12	0
	07:18	0
	07:24	0
	07:30	0
	07:36	0
	07:42	0
	07:48	0
	07:54	0
	08:00	0
	08:06	0
	08:12	0
	08:18	0
	08:24	0
	08:30	0
	08:36	0
	08:42	0
	08:48	0
	08:54	0
	09:00	0
	09:06	0
	09:12	0
	09:18	0

---

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	24
Included Values =	24
Total =	0

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing  
 T - out-of-control  
 I - invalid  
 S - suspect  
 H - exceedance  
 F - stack not operating  
 B - invalid (PADER)  
 U - missing data substituted  
 -999 - missing value  
 -888 - value could not be calculated

General Average Report

Reporting Period: 03/16/2009 to 03/16/2009

Site Name: UNIT2

Time of Report: 03/17/09 07:27

Data Averaging Type: 1m

Rolling Average Interval: 1

CARFED2  
(LBS/HR )

---

Average =	5
Geometric Avg. =	5
Maximum =	8
Minimum =	3
Possible Values =	135
Included Values =	135
Total =	727

General Average Report

Reporting Period: 03/16/2009 to 03/16/2009

Site Name: UNIT2

Time of Report: 03/17/09 07:27

Data Averaging Type: 1m

Rolling Average Interval: 1

CARFRED2  
(LBS/HR )

---

Average =	7
Geometric Avg. =	6
Maximum =	11
Minimum =	3
Possible Values =	132
Included Values =	132
Total =	859

General Average Report

Reporting Period: 03/16/2009 to 03/16/2009

Site Name: UNIT2  
Data Averaging Type: 1m

Time of Report: 03/17/09 07:27  
Rolling Average Interval: 1

CARFEED2  
(LBS/HR )

---

Average =	6
Geometric Avg. =	6
Maximum =	11
Minimum =	3
Possible Values =	145
Included Values =	145
Total =	942

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/17/2009  
Start Time: 12:50:00  
End Time: 14:01:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	WME CONC	FE OUT TEMP	FF DP	TD INLET PRESS	STEAM FLOW
----------------	-----------------	-------------------	----------------	----------	-------------	-------	----------------	------------

	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	519.12	320.07	35.57	30.99	12.45	301.58	6.42	-11.62	184.26
Unit 2 13B run 1	513.72	319.90	35.92	26.98	12.56	302.16	6.48	-9.41	185.05
Unit 3	497.73	314.93	38.89	33.19	11.36	302.04	6.76	-10.77	184.25

C - 34

FEED H2O FLOW	SH OUT SIM PRESS	FINAL SIM TEMP	ROT AIR FLOW	FURNACE DRAFT	SECOND OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
---------------	------------------	----------------	--------------	---------------	-----------------	-------------	----------------	------------	-----------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.74	915.21	825.73	87.30	-0.11	430.49	1113.84	4.10	6.31	9.27
Unit 2	186.01	909.77	821.51	85.11	-0.10	417.28	1108.14	4.23	5.94	9.48
Unit 3	187.98	901.82	826.39	86.13	-0.10	400.39	1100.30	3.22	7.13	10.22



**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/17/2009  
Start Time: 14:21:00  
End Time: 15:33:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	WME CONC	EVAPOR TEMP	EVAPOR DR	DINLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	523.90	319.95	37.21	29.52	12.34	301.72	6.40	-11.68	184.32
Unit 2 13B run 2	509.18	319.88	33.42	25.13	13.68	302.36	6.51	-9.25	184.69
Unit 3	497.93	314.94	38.67	31.54	11.84	300.49	6.87	-10.75	183.92

C - 35

	HEAD H2O FLOW	SH OUT STMPRESS	FINAL STIM TEMP	TOTAL AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.39	914.81	822.32	89.72	-0.10	433.02	1111.50	3.47	6.55	9.57
Unit 2	186.09	909.69	823.22	81.89	-0.11	413.26	1102.63	2.92	5.59	9.27
Unit 3	187.67	901.35	823.61	85.17	-0.10	399.51	1090.93	3.49	6.75	10.07

## Wheelabrator SOUTH BROWARD Emission Test Log

Date: 3/17/2009  
 Start Time: 15:46:00  
 End Time: 16:55:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
-------------------	--------------------	----------------------	-------------------	--------------	----------------	----------	-------------------	---------------

	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBs/hr
Unit 1	517.36	319.95	34.09	28.01	13.71	300.34	6.37	-11.49	184.91
Unit 2 13B run 3	510.50	320.26	34.00	22.22	13.85	302.48	6.41	-9.49	183.85
Unit 3	502.00	314.96	40.36	31.23	11.71	299.86	6.87	-10.74	183.76

C - 36

FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
------------------	---------------------	-------------------	-----------------	------------------	-------------------	----------------	-------------------	---------------	--------------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	186.69	914.11	826.49	85.53	-0.11	427.95	1111.55	1.97	5.98	9.01
Unit 2	185.03	909.26	821.68	82.56	-0.10	413.42	1100.66	2.66	5.73	9.32
Unit 3	186.89	900.90	823.21	84.71	-0.10	401.14	1093.59	2.98	7.17	10.41

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/17/2009  
Start Time: 7:39:00  
End Time: 8:39:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	519.00	320.16	36.36	30.10	10.95	298.47	6.53	-11.87	181.80
Unit 2 26A run 1	505.22	315.22	34.87	28.86	11.32	297.27	6.60	-10.24	182.58
Unit 3	485.89	315.22	35.90	27.20	11.10	298.86	6.97	-10.65	183.37

C - 37

	FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	183.47	911.17	824.31	90.02	-0.10	432.51	1096.32	2.98	6.54	9.66
Unit 2	182.82	907.68	818.95	84.75	-0.10	417.05	1091.11	3.52	5.99	9.74
Unit 3	187.01	899.84	825.85	82.26	-0.11	399.19	1066.73	3.14	7.03	10.47

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/17/2009  
Start Time: 9:32:00  
End Time: 10:32:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	524.47	319.99	38.45	33.38	12.68	301.50	6.50	-11.95	184.86
Unit 2 26A run 2	508.22	314.59	35.30	28.94	13.82	299.34	6.41	-9.77	185.20
Unit 3	489.40	314.97	37.08	30.74	10.82	300.03	6.74	-10.35	183.99

C - 38

	FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	186.34	914.08	825.99	91.77	-0.10	435.51	1111.25	3.68	6.41	9.50
Unit 2	186.66	910.01	824.69	83.63	-0.10	416.30	1094.87	5.16	5.70	9.15
Unit 3	187.79	901.84	827.73	82.56	-0.11	399.79	1074.23	3.51	6.72	9.80

## Wheelabrator SOUTH BROWARD Emission Test Log

Date: 3/17/2009  
 Start Time: 11:21:00  
 End Time: 12:21:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBs/hr
Unit 1	517.94	319.86	35.40	27.78	12.98	302.28	6.40	-11.56	185.31
Unit 2 26A run 3	518.88	319.94	38.51	29.65	13.17	302.01	6.63	-10.18	183.23
Unit 3	498.15	314.97	39.89	34.00	10.23	301.70	6.86	-10.94	184.04

C - 39

	FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	186.67	914.57	823.57	88.00	-0.10	430.30	1111.73	2.27	6.19	9.20
Unit 2	184.38	908.98	821.59	88.52	-0.10	422.82	1107.94	5.61	6.32	9.95
Unit 3	187.11	901.32	823.18	86.84	-0.10	403.03	1084.38	3.52	7.06	10.39

## Wheelabrator SOUTH BROWARD Emission Test Log

Date: 3/17/2009  
 Start Time: 7:39:00  
 End Time: 9:48:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	FE OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW	
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr	
Unit 1	520.98	320.10	37.33	31.60	11.06	299.40	6.46	-11.87	182.78	
Unit 2	507.12	315.29	35.25	29.00	11.74	297.95	6.54	-10.17	183.40	
Unit 3	5/29 run 1	490.63	314.99	37.90	30.49	10.65	299.37	6.89	-10.65	183.95

C - 40

	FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	EGGNO OUT TEMP	SH ROIL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	184.40	911.94	824.75	91.21	-0.09	434.21	1102.75	3.22	6.57	9.67
Unit 2	184.25	908.35	821.15	84.83	-0.10	417.49	1091.33	4.24	5.95	9.59
Unit 3	187.28	900.29	823.25	84.22	-0.11	402.65	1063.20	3.75	6.97	10.36

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/17/2009  
Start Time: 10:21:00  
End Time: 12:30:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	FEED TEMP	FEED DP	ID INLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	520.31	319.94	36.54	30.08	12.74	301.85	6.40	-11.64	184.75
Unit 2	514.47	318.04	37.22	28.92	13.41	300.25	6.60	-10.05	182.93
Unit 3	495.38	314.98	39.05	32.56	10.32	300.68	6.88	-10.82	183.99

C-41

	FEED H2O FLOW	SH OUT SLIM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.90	914.05	823.84	89.33	-0.11	432.27	1110.68	3.08	6.33	9.36
Unit 2	183.76	908.63	819.96	86.94	-0.10	420.24	1101.90	4.75	6.21	9.85
Unit 3	187.22	901.02	822.71	85.79	-0.10	401.87	1084.81	3.76	6.88	10.22

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/17/2009  
Start Time: 13:02:00  
End Time: 15:13:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	521.62	320.04	36.50	30.95	12.40	301.86	6.45	-11.73	183.56
Unit 2	511.17	319.79	34.70	25.90	13.03	302.12	6.46	-9.23	185.33
Unit 3 5/29 run 3	497.84	315.00	38.88	32.20	11.61	301.38	6.84	-10.81	184.10

C - 42

	FEED H2O FLOW	SH OUT STM PRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROLL AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	184.63	915.00	824.40	88.65	-0.10	431.81	1111.83	3.65	6.50	9.49
Unit 2	186.52	909.89	822.52	83.25	-0.11	415.25	1108.20	3.64	5.66	9.29
Unit 3	187.43	901.65	825.01	85.90	-0.10	399.78	1095.52	3.69	6.95	10.16



## General Average Report

Reporting Period: 03/17/2009 to 03/17/2009

Site Name: UNIT3

Data Averaging Type: 6m

Time of Report: 03/18/09 05:50

Rolling Average Interval: 1

Date	Time	OPACITY3 (PERCENT )
03/17/09	06:36	0
	06:42	0
	06:48	0
	06:54	0
	07:00	0
	07:06	0
	07:12	0
	07:18	0
	07:24	0
	07:30	0
	07:36	0
	07:42	0
	07:48	0
	07:54	0
	08:00	0
	08:06	0
	08:12	0
	08:18	0
	08:24	0
	08:30	0
	08:36	0
	08:42	0

---

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	0

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing  
 T - out-of-control  
 I - invalid  
 S - suspect  
 H - exceedance  
 F - stack not operating  
 B - invalid (PADER)  
 U - missing data substituted  
 -999 - missing value  
 -888 - value could not be calculated

## General Average Report

Reporting Period: 03/17/2009 to 03/17/2009

Site Name: UNIT3

Time of Report: 03/18/09 05:50

Data Averaging Type: 6m

Rolling Average Interval: 1

Date	Time	OPACITY3 (PERCENT )
03/17/09	09:18	0
	09:24	0
	09:30	0
	09:36	0
	09:42	0
	09:48	0
	09:54	0
	10:00	0
	10:06	0
	10:12	0
	10:18	0
	10:24	0
	10:30	0
	10:36	0
	10:42	0
	10:48	0
	10:54	0
	11:00	0
	11:06	0
	11:12	0
	11:18	0
	11:24	0

---

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	0

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing  
 T - out-of-control  
 I - invalid  
 S - suspect  
 H - exceedance  
 F - stack not operating  
 B - invalid (FADER)  
 U - missing data substituted  
 -999 - missing value  
 -888 - value could not be calculated

## General Average Report

Reporting Period: 03/17/2009 to 03/17/2009

Site Name: UNIT3

Data Averaging Type: 6m

Time of Report: 03/18/09 05:51

Rolling Average Interval: 1

Date	Time	OPACITY3 (PERCENT )
03/17/09	12:00	0
	12:06	0
	12:12	0
	12:18	0
	12:24	0
	12:30	0
	12:36	0
	12:42	0
	12:48	0
	12:54	0
	13:00	0
	13:06	0
	13:12	0
	13:18	0
	13:24	0
	13:30	0
	13:36	0
	13:42	0
	13:48	0
	13:54	0
	14:00	0
	14:06	0

---

Average =	0
Geometric Avg. =	
Maximum =	0
Minimum =	0
Possible Values =	22
Included Values =	22
Total =	0

\* - excluded values (missing, OOC, invalid, suspect)  
 < - missing  
 T - out-of-control  
 I - invalid  
 S - suspect  
 H - exceedance  
 F - stack not operating  
 B - invalid (PADER)  
 U - missing data substituted  
 -999 - missing value  
 -888 - value could not be calculated

Plant Name: SBWD  
General Average Report

Site Name: UNIT3  
Data Averaging Type: 1m

Reporting Period: 03/17/2009 to 03/17/2009

Time of Report: 03/18/09 05:49  
Rolling Average Interval: 1

CARFEED3  
(LBS/HR )

---

Average =	6
Geometric Avg. =	6
Maximum =	10
Minimum =	3
Possible Values =	130
Included Values =	130
Total =	830

General Average Report

Reporting Period: 03/17/2009 to 03/17/2009

Site Name: UNIT3

Time of Report: 03/18/09 05:50

Data Averaging Type: LM

Rolling Average Interval: 1

CARFRED3  
(LBS/HR )

---

Average =	6
Geometric Avg. =	6
Maximum =	11
Minimum =	3
Possible Values =	130
Included Values =	130
Total =	763

General Average Report

Reporting Period: 03/17/2009 to 03/17/2009

Site Name: UNIT3

Data Averaging Type: 1m

Time of Report: 03/18/09 05:50

Rolling Average Interval: 1

CARFEED3  
(LBS/HR )

---

Average =	5
Geometric Avg. =	5
Maximum =	9
Minimum =	3
Possible Values =	132
Included Values =	132
Total =	724

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 8:26:00  
End Time: 9:44:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	TD INLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBs/hr
Unit 1	515.51	319.86	36.25	30.77	14.94	300.78	6.39	-11.70	184.76
Unit 2	516.11	314.55	37.99	32.30	14.27	300.83	6.45	-9.94	184.65
Unit 3 13B run 1	491.88	314.97	37.17	31.48	15.50	299.97	6.75	-10.42	184.20

C - 49

	FEED H2O FLOW	SH OUT STIMPRESS	FINAL STM TEMP	TOT AIR FLOW	FURNACE DRAFT	RECONG OUT TEMP	SH ROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	186.32	913.29	826.07	85.68	-0.11	433.05	1109.77	6.81	6.05	9.10
Unit 2	186.45	909.43	824.18	83.68	-0.10	423.15	1094.71	5.30	6.26	9.48
Unit 3	187.69	901.09	823.31	85.18	-0.11	401.76	1043.56	6.97	6.75	9.75

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 10:36:00  
End Time: 11:53:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DIL WATER FLOW	LINE CONC	PF OUT TEMP	PF DR	IND INLET PRESS	STEAM FLOW
-------------------	--------------------	----------------------	-------------------	--------------	----------------	----------	--------------------	---------------

	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	511.59	320.00	33.47	29.20	12.45	300.54	6.39	-11.46	183.77
Unit 2	515.87	314.96	37.40	31.66	11.08	300.44	6.41	-9.79	184.05
Unit 3 13B run 2	495.35	314.95	37.77	32.76	11.00	297.21	6.79	-10.57	183.97

C - 50

FEED H2O FLOW	SH OUT STMPRESS	FINAL STIM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SHROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
------------------	--------------------	--------------------	-----------------	------------------	-------------------	---------------	-------------------	---------------	--------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.10	913.48	823.84	85.25	-0.11	427.98	1110.33	1.35	6.47	9.46
Unit 2	184.67	908.84	818.83	86.20	-0.11	422.05	1093.87	3.63	6.37	9.82
Unit 3	187.29	900.94	823.08	82.53	-0.10	400.48	1037.18	2.55	6.93	10.19



**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/16/2009  
Start Time: 12:26:00  
End Time: 13:47:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FLOW	DILUTE WATER FLOW	LIME CONC	FF OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
----------------	-----------------	-------------------	-------------------	-----------	-------------	-------	----------------	------------

	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBs/hr
Unit 1	517.74	320.10	35.88	30.79	11.99	301.50	6.45	-11.74	183.49
Unit 2	514.38	314.87	36.52	31.25	11.73	300.25	6.48	-9.67	184.50
Unit 3 13B run 3	496.62	314.94	37.84	32.56	11.30	298.79	6.74	-10.58	184.36

C - 51

FEED H2O FLOW	SH OUT SIM PRESS	FINAL STM TEMP	TOTAL AIR FLOW	FURNACE DRAFT	FOONO OUT TEMP	SHIRON AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
---------------	------------------	----------------	----------------	---------------	----------------	------------	----------------	------------	-----------

	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.32	913.92	826.23	87.33	-0.10	430.88	1111.01	3.21	6.41	9.48
Unit 2	185.60	909.24	820.69	82.18	-0.10	418.24	1105.08	3.29	6.48	9.84
Unit 3	187.90	901.45	825.92	79.53	-0.11	399.63	1052.37	3.64	7.08	10.15

## Wheelabrator SOUTH BROWARD Emission Test Log

Date: 3/18/2009  
 Start Time: 8:02:00  
 End Time: 9:02:00

SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY/L	DIP WATER FLOW	LIME CONC	F FOUT TEMP	F PH	DIP INLET PRESS	STEAM FLOW
-------------------	--------------------	-------------------	-------------------	--------------	----------------	---------	--------------------	---------------

	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	515.04	315.13	36.30	29.88	11.93	290.94	6.43	-11.75	183.94
Unit 2	512.58	314.97	37.03	29.98	11.69	296.04	6.58	-10.44	184.43
Unit 3 26A run 1	485.74	315.11	35.23	23.11	12.33	294.79	6.87	-10.35	184.06

C - 52

FEBD H2O FLOW	SHOUT TEMP	F INKUSTM TEMP	TOT AIR FLOW	FURNACE DRAFT	SECOND OUT TEMP	SHROB AVG	SNGR CHEM FLOW	FURNACE O2	OUTLET O2
------------------	---------------	-------------------	-----------------	------------------	--------------------	--------------	-------------------	---------------	--------------

	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	186.28	910.52	827.89	87.94	-0.10	430.48	1090.70	3.86	6.25	9.20
Unit 2	185.61	908.57	821.79	86.89	-0.10	420.86	1083.41	3.44	5.98	9.48
Unit 3	187.79	900.11	824.98	80.62	-0.11	398.85	1085.83	4.17	6.92	10.02

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/18/2009  
Start Time: 10:19:00  
End Time: 11:19:00

	SDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY FL	DIL WATER FLOW	LIME CONC	FE OUT TEMP	FF DP	ID INLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBs/hr
Unit 1	516.93	305.07	38.34	33.27	12.44	286.22	6.43	-11.77	182.99
Unit 2	517.40	305.13	41.31	32.63	11.49	289.68	6.58	-10.25	182.99
Unit 3 26A run 2	495.36	304.92	41.42	35.56	13.11	290.22	6.99	-10.93	184.16

C - 53

	FEED H2O FLOW	SH OUT TEMP PRESS	FINAL STIM TEMP	TOT AIR FLOW	FURNACE DRAFT	ECONO OUT TEMP	SH ROIL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBs/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.10	910.51	826.78	86.44	-0.10	430.37	1130.67	5.76	6.09	9.05
Unit 2	183.44	908.17	820.07	88.18	-0.10	422.51	1093.21	4.88	6.19	9.58
Unit 3	187.33	900.06	821.79	81.94	-0.11	402.11	1097.51	5.98	6.67	9.73

**Wheelabrator  
SOUTH BROWARD  
Emission Test Log**

Date: 3/18/2009  
Start Time: 11:46:00  
End Time: 12:46:00

	SIDA INLET TEMP	SDA OUTLET TEMP	TOTAL SLURRY/FI	DILWATER FLOW	IRME %CONC	FE OUT TEMP	FE DP	ID INLET PRESS	STEAM FLOW
	DEG F	DEG F	GPM	GPM	%	DEG F	" H2O	" H2O	KLBS/hr
Unit 1	519.90	304.89	38.52	33.19	13.40	286.62	6.35	-11.56	183.94
Unit 2	520.28	304.38	41.31	33.57	12.45	287.45	6.44	-9.94	185.32
Unit 3 26A run 3	492.32	304.95	38.84	32.99	15.03	287.85	6.64	-10.21	183.91

C - 54

	FEED H2O FLOW	SHOUT SIM PRESS	FINAL SIM TEMP	TOT AIR FLOW	FURNACE DRAFT	FE CONC OUT TEMP	SHROLL AVG	SNCR CHEM FLOW	FURNACE O2	OUTLET O2
	KLBS/hr	DEG F	DEG F	KSCFM	" H2O	DEG F	DEG F	GPH	%	%
Unit 1	185.65	911.14	824.49	86.61	-0.09	430.59	1113.98	3.82	6.23	9.15
Unit 2	185.87	909.49	822.77	88.47	-0.10	422.17	1102.08	2.70	6.17	9.42
Unit 3	187.10	900.74	824.17	80.07	-0.10	396.61	1111.76	4.64	6.38	9.53

**Wheelabrator - S. Broward**

4400 South State Road 7  
 Fort Lauderdale, FL 33314  
 Tel: (954) 581-6606 Fax: (954) 581-6705

**Ticket 716488**

3/18/2009  
 In 9:06:25AM  
 Out 11:27:04AM

**Account** 623030  
**Customer** Chemical Lime  
 Chemical Lime  
 PO Box 7247-8945  
 Philadelphia, PA

**Decal #** LIME1  
**Vehicle #** LIME1  
**Auto ID** 0  
**Other** 2357474  
**Product** 9020 Lime  
**Qty** 25.38 Ton  
**Origin** Wheelabrator So  
**Operator** Joyce Tate

**Price/Ton** 0.00  
**Fees** 0.00  
**Other** 0.00  
**Total** 0.00

	<u>Pounds</u>	<u>Tons</u>
<b>Gross</b>	78160	39.08
<b>Tare</b>	27400	13.70
<b>Net</b>	50760	25.38

**Wheelabrator - S. Broward**

4400 South State Road 7  
 Fort Lauderdale, FL 33314  
 Tel: (954) 581-6606 Fax: (954) 581-6705

**Ticket 716488**

3/18/2009  
 In 9:06:25AM  
 Out 11:27:04AM

**Account** 623030  
**Customer** Chemical Lime  
 Chemical Lime  
 PO Box 7247-8945  
 Philadelphia, PA

**Decal #** LIME1  
**Vehicle #** LIME1  
**Auto ID** 0  
**Other** 2357474  
**Product** 9020  
**Qty** 25.38 Ton  
**Origin** Wheelabrator So  
**Operator** Joyce Tate

**Price/Ton** 0.00  
**Fees** 0.00  
**Other** 0.00  
**Total** 0.00

	<u>Pounds</u>	<u>Tons</u>
<b>Gross</b>	78160	39.08
<b>Tare</b>	27400	13.70
<b>Net</b>	50760	25.38

**This Page Intentionally Left Blank**

WHEELABRATOR SOUTH BROWARD, INC.  
FT. LAUDERDALE, FL

CleanAir Project No: 10735-4

**PARAMETERS**

D

**This Page Intentionally Left Blank**



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

**USEPA Method 29 (Mercury)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average	
Date (2009)	Mar 18	Mar 18	Mar 18		
Start Time (approx.)	06:41	09:19	12:12		
Stop Time (approx.)	08:52	11:30	14:22		
<b>Sampling Conditions</b>					
Y <sub>d</sub>	Dry gas meter correction factor	1.0079	1.0079	1.0079	
C <sub>p</sub>	Pitot tube coefficient	0.8200	0.8200	0.8200	
P <sub>g</sub>	Static pressure (in. H <sub>2</sub> O)	-1.5000	-1.7000	-1.5000	
A <sub>s</sub>	Sample location area (ft <sup>2</sup> )	60.1320	60.1320	60.1320	
P <sub>bar</sub>	Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
D <sub>n</sub>	Nozzle diameter (in.)	0.2750	0.2750	0.2750	
O <sub>2</sub>	Oxygen (dry volume %)	9.7200	8.8900	8.8500	<b>9.1533</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.9500	10.8300	10.8500	<b>10.5433</b>
N <sub>2</sub> +CO	Nitrogen plus carbon monoxide (dry volume %)	80.3300	80.2800	80.3000	<b>80.3033</b>
V <sub>lc</sub>	Total Liquid collected (ml)	281.70	299.70	314.20	
V <sub>m</sub>	Volume metered, meter conditions (ft <sup>3</sup> )	69.4600	68.8700	69.1900	
T <sub>m</sub>	Dry gas meter temperature (°F)	76.9167	73.0625	72.3333	
T <sub>s</sub>	Sample temperature (°F)	505.3750	505.7500	507.9167	<b>506.3472</b>
ΔH	Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.0483	1.0204	1.0271	
θ	Total sampling time (min)	120.0	120.0	120.0	
<b>Flow Results</b>					
V <sub>wstd</sub>	Volume of water collected (ft <sup>3</sup> )	13.2568	14.1039	14.7863	<b>14.0490</b>
V <sub>mstd</sub>	Volume metered, standard (dscf)	69.4099	69.3132	69.7317	<b>69.4849</b>
P <sub>s</sub>	Sample gas pressure, absolute (in. Hg)	29.9897	29.9750	29.9897	<b>29.9848</b>
P <sub>v</sub>	Vapor pressure, actual (in. Hg)	29.9897	29.9750	29.9897	<b>29.9848</b>
B <sub>wo</sub>	Moisture measured in sample (% by volume)	16.0365	16.9077	17.4948	<b>16.8130</b>
B <sub>ws</sub>	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	16.0365	16.9077	17.4948	<b>16.8130</b>
√ΔP	Velocity head (√in. H <sub>2</sub> O)	0.6509	0.6415	0.6520	<b>0.6481</b>
M <sub>d</sub>	MW of sample gas, dry (lb/lb-mole)	29.9808	30.0884	30.0900	<b>30.0531</b>
M <sub>s</sub>	MW of sample gas, wet (lb/lb-mole)	28.0595	28.0445	27.9749	<b>28.0263</b>
V <sub>s</sub>	Velocity of sample (ft/sec)	48.8711	48.2040	49.0932	<b>48.7228</b>
%I	Isokinetic sampling (%)	103.9585	106.4474	106.0843	<b>105.4967</b>
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	176,323	173,916	177,125	<b>175,788</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	96,662	95,259	96,847	<b>96,256</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	81,161	79,153	79,904	<b>80,073</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	65,279	68,391	69,269	<b>67,646</b>
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,579,391	10,434,974	10,627,473	<b>10,547,279</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	5,799,748	5,715,552	5,810,809	<b>5,775,370</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	4,869,674	4,749,185	4,794,220	<b>4,804,360</b>
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	299,615	295,525	300,976	<b>298,705</b>
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	164,252	161,868	164,566	<b>163,562</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	137,912	134,500	135,775	<b>136,062</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	110,925	116,212	117,704	<b>114,947</b>
Q <sub>a</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	153,053	150,831	153,345	<b>152,410</b>
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	128,509	125,329	126,518	<b>126,785</b>
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	103,362	108,288	109,679	<b>107,110</b>

Comments:

Average includes 3 runs.

041509 115435  
 LON@

**USEPA Method 29  
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:41	09:19	12:12	
Stop Time (approx.)		08:52	11:30	14:22	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	183.6	183.4	184.0	183.7
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	313	305	305	308
P <sub>2</sub>	Carbon Feed rate (lb/hr)	7	6	5	6
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.7200	8.8900	8.8500	9.1533
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.9500	10.8300	10.8500	10.5433
T <sub>s</sub>	Sample temperature (°F)	505.3750	505.7500	507.9167	506.3472
B <sub>w</sub>	Actual water vapor in gas (% by volume)	16.0365	16.9077	17.4948	16.8130
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	176,323	173,916	177,125	175,788
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	96,662	95,259	96,847	96,256
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	81,161	79,153	79,904	80,073
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	65,279	68,391	69,269	67,646
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,579,391	10,434,974	10,627,473	10,547,279
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	5,799,748	5,715,552	5,810,809	5,775,370
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	4,869,674	4,749,185	4,794,220	4,804,360
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	299,615	295,525	300,976	298,705
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	164,252	161,868	164,566	163,562
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	137,912	134,500	135,775	136,062
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	110,925	116,212	117,704	114,947
Q <sub>s</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	153,053	150,831	153,345	152,410
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	128,509	125,329	126,518	126,785
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	103,362	108,288	109,679	107,110
<b>Sampling Data</b>					
V <sub>std</sub>	Volume metered, standard (dscf)	69.4099	69.3132	69.7317	69.4849
%I	Isokinetic sampling (%)	103.9585	106.4474	106.0843	105.4967
<b>Laboratory Data</b>					
m <sub>n-1b</sub>	Fraction 1B (µg)	61.7408	61.4205	72.7139	
m <sub>n-2b</sub>	Fraction 2B (µg)	39.5721	47.6470	37.0594	
m <sub>n-3a</sub>	Fraction 3A (µg)	<0.0200	<0.0200	<0.0200	
m <sub>n-3b</sub>	Fraction 3B (µg)	0.7568	1.5232	1.0325	
m <sub>n-3c</sub>	Fraction 3C (µg)	3.0567	6.2913	5.5174	
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	105.1263	116.8821	116.3232	
<b>Mercury Results - Total</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	3.3396E-09	3.7183E-09	3.6783E-09	3.5787E-09
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	4.1521E-09	4.3034E-09	4.2430E-09	4.2328E-09
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	4.0277E-09	4.1200E-09	4.0681E-09	4.0719E-09
C <sub>a</sub>	Concentration (lb/acf)	1.5372E-09	1.6923E-09	1.6593E-09	1.6298E-09
C <sub>sd</sub>	Concentration (µg/dscm)	5.3480E+01	5.9543E+01	5.8902E+01	5.7308E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	6.6491E+01	6.8913E+01	6.7946E+01	6.7783E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	6.4498E+01	6.5975E+01	6.5146E+01	6.5206E+01
C <sub>sd</sub>	Concentration (mg/dscm)	5.3480E-02	5.9543E-02	5.8902E-02	5.7308E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	6.6491E-02	6.8913E-02	6.7946E-02	6.7783E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	6.4498E-02	6.5975E-02	6.5146E-02	6.5206E-02
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	2.4617E+01	2.7099E+01	2.6572E+01	2.6098E+01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	5.7393E+01	6.3900E+01	6.3212E+01	6.1502E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	7.1356E+01	7.3955E+01	7.2917E+01	7.2743E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	6.9217E+01	7.0803E+01	6.9912E+01	6.9978E+01
E <sub>lb/hr</sub>	Rate (lb/hr)	1.6263E-02	1.7659E-02	1.7634E-02	1.7185E-02
E <sub>g/s</sub>	Rate (g/s)	2.0487E-03	2.2246E-03	2.2215E-03	2.1650E-03
E <sub>T/yr</sub>	Rate (Ton/yr)	7.1232E-02	7.7345E-02	7.7239E-02	7.5272E-02
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	5.9747E-05	6.1924E-05	6.1054E-05	6.0908E-05
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	6.1087E-05	6.2486E-05	6.1700E-05	6.1758E-05

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Front Half Results**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:41	09:19	12:12	
Stop Time (approx.)	08:52	11:30	14:22	

**Mercury Results - Front Half**

C <sub>sd</sub>	Concentration (lb/dscf)	1.9614E-09	1.9539E-09	2.2993E-09	<b>2.0715E-09</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	2.4386E-09	2.2614E-09	2.6523E-09	<b>2.4508E-09</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	2.3655E-09	2.1650E-09	2.5430E-09	<b>2.3578E-09</b>
C <sub>a</sub>	Concentration (lb/acf)	9.0282E-10	8.8927E-10	1.0372E-09	<b>9.4311E-10</b>
C <sub>sd</sub>	Concentration (µg/dscm)	3.1409E+01	3.1289E+01	3.6820E+01	<b>3.3173E+01</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	3.9050E+01	3.6213E+01	4.2473E+01	<b>3.9245E+01</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	3.7880E+01	3.4670E+01	4.0723E+01	<b>3.7757E+01</b>
C <sub>sd</sub>	Concentration (mg/dscm)	3.1409E-02	3.1289E-02	3.6820E-02	<b>3.3173E-02</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	3.9050E-02	3.6213E-02	4.2473E-02	<b>3.9245E-02</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	3.7880E-02	3.4670E-02	4.0723E-02	<b>3.7757E-02</b>
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.4457E+01	1.4240E+01	1.6610E+01	<b>1.5103E+01</b>
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	3.3707E+01	3.3579E+01	3.9514E+01	<b>3.5600E+01</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.1907E+01	3.8863E+01	4.5581E+01	<b>4.2117E+01</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.0651E+01	3.7206E+01	4.3702E+01	<b>4.0520E+01</b>
E <sub>lb/hr</sub>	Rate (lb/hr)	9.5512E-03	9.2795E-03	1.1023E-02	<b>9.9514E-03</b>
E <sub>g/s</sub>	Rate (g/s)	1.2032E-03	1.1690E-03	1.3887E-03	<b>1.2536E-03</b>
E <sub>T/yr</sub>	Rate (Ton/yr)	4.1834E-02	4.0644E-02	4.8282E-02	<b>4.3587E-02</b>
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	3.5089E-05	3.2540E-05	3.8165E-05	<b>3.5265E-05</b>
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	3.5876E-05	3.2836E-05	3.8569E-05	<b>3.5760E-05</b>

041506 115435  
 L O H @ P

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:41	09:19	12:12	
Stop Time (approx.)	08:52	11:30	14:22	

**Mercury Results - Impingers 1-3 Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	1.2571E-09	1.5158E-09	1.1719E-09	1.3149E-09
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	1.5630E-09	1.7543E-09	1.3518E-09	1.5563E-09
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	1.5161E-09	1.6795E-09	1.2961E-09	1.4972E-09
C <sub>a</sub>	Concentration (lb/acf)	5.7865E-10	6.8985E-10	5.2865E-10	5.9905E-10
C <sub>sd</sub>	Concentration (µg/dscm)	2.0131E+01	2.4273E+01	1.8766E+01	2.1056E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	2.5029E+01	2.8092E+01	2.1647E+01	2.4923E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	2.4279E+01	2.6895E+01	2.0755E+01	2.3976E+01
C <sub>sd</sub>	Concentration (mg/dscm)	2.0131E-02	2.4273E-02	1.8766E-02	2.1056E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	2.5029E-02	2.8092E-02	2.1647E-02	2.4923E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	2.4279E-02	2.6895E-02	2.0755E-02	2.3976E-02
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	9.2663E+00	1.1047E+01	8.4655E+00	9.5929E+00
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	2.1604E+01	2.6049E+01	2.0139E+01	2.2597E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.6860E+01	3.0148E+01	2.3231E+01	2.6746E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.6055E+01	2.8863E+01	2.2273E+01	2.5730E+01
E <sub>10/hr</sub>	Rate (lb/hr)	6.1218E-03	7.1986E-03	5.6182E-03	6.3128E-03
E <sub>g/s</sub>	Rate (g/s)	7.7120E-04	9.0685E-04	7.0776E-04	7.9527E-04
E <sub>7/yr</sub>	Rate (Ton/yr)	2.6813E-02	3.1530E-02	2.4608E-02	2.7650E-02
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	2.2490E-05	2.5243E-05	1.9451E-05	2.2395E-05
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	2.2995E-05	2.5473E-05	1.9657E-05	2.2708E-05

041508 115435  
 L O N @ \_ P

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 4 Results**

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:41	09:19	12:12	
Stop Time (approx.)		08:52	11:30	14:22	
<b>Mercury Results - Impinger 4 Solution</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	<6.3536E-13	<6.3624E-13	<6.3242E-13	<6.3467E-13
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<7.8993E-13	<7.3637E-13	<7.2952E-13	<7.5194E-13
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<7.6626E-13	<7.0498E-13	<6.9945E-13	<7.2356E-13
C <sub>a</sub>	Concentration (lb/acf)	<2.9245E-13	<2.8957E-13	<2.8530E-13	<2.8911E-13
C <sub>sd</sub>	Concentration (µg/dscm)	<1.0174E-02	<1.0189E-02	<1.0127E-02	<1.0163E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<1.2650E-02	<1.1792E-02	<1.1682E-02	<1.2041E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<1.2271E-02	<1.1289E-02	<1.1201E-02	<1.1587E-02
C <sub>sd</sub>	Concentration (mg/dscm)	<1.0174E-05	<1.0189E-05	<1.0127E-05	<1.0163E-05
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<1.2650E-05	<1.1792E-05	<1.1682E-05	<1.2041E-05
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<1.2271E-05	<1.1289E-05	<1.1201E-05	<1.1587E-05
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<4.6832E-03	<4.6370E-03	<4.5686E-03	<4.6296E-03
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<1.0919E-02	<1.0934E-02	<1.0868E-02	<1.0907E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.3575E-02	<1.2655E-02	<1.2537E-02	<1.2922E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.3168E-02	<1.2115E-02	<1.2020E-02	<1.2435E-02
E <sub>lb/hr</sub>	Rate (lb/hr)	<3.0940E-06	<3.0216E-06	<3.0320E-06	<3.0482E-06
E <sub>g/s</sub>	Rate (g/s)	<3.8977E-07	<3.8065E-07	<3.8196E-07	<3.8413E-07
E <sub>T/yr</sub>	Rate (Ton/yr)	<1.3552E-05	<1.3235E-05	<1.3280E-05	<1.3355E-05
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<1.1367E-08	<1.0596E-08	<1.0497E-08	<1.0820E-08
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<1.1622E-08	<1.0692E-08	<1.0608E-08	<1.0974E-08

041508 115435  
 LON@LP

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:41	09:19	12:12	
Stop Time (approx.)	08:52	11:30	14:22	

**Mercury Results - Filtered Permanganate Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	2.4041E-11	4.8456E-11	3.2648E-11	<b>3.5048E-11</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	2.9889E-11	5.6081E-11	3.7660E-11	<b>4.1210E-11</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	2.8994E-11	5.3691E-11	3.6109E-11	<b>3.9598E-11</b>
C <sub>a</sub>	Concentration (lb/acf)	1.1068E-11	2.2053E-11	1.4728E-11	<b>1.5949E-11</b>
C <sub>sd</sub>	Concentration (µg/dscm)	3.8498E-01	7.7595E-01	5.2281E-01	<b>5.6125E-01</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	4.7864E-01	8.9806E-01	6.0308E-01	<b>6.5993E-01</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	4.6429E-01	8.5978E-01	5.7823E-01	<b>6.3410E-01</b>
C <sub>sd</sub>	Concentration (mg/dscm)	3.8498E-04	7.7595E-04	5.2281E-04	<b>5.6125E-04</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	4.7864E-04	8.9806E-04	6.0308E-04	<b>6.5993E-04</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	4.6429E-04	8.5978E-04	5.7823E-04	<b>6.3410E-04</b>
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.7720E-01	3.5315E-01	2.3585E-01	<b>2.5540E-01</b>
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	4.1314E-01	8.3273E-01	5.6107E-01	<b>6.0231E-01</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	5.1366E-01	9.6377E-01	6.4721E-01	<b>7.0821E-01</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.9826E-01	9.2269E-01	6.2054E-01	<b>6.8050E-01</b>
E <sub>lb/hr</sub>	Rate (lb/hr)	1.1707E-04	2.3013E-04	1.5652E-04	<b>1.6791E-04</b>
E <sub>g/s</sub>	Rate (g/s)	1.4748E-05	2.8990E-05	1.9718E-05	<b>2.1152E-05</b>
E <sub>T/yr</sub>	Rate (Ton/yr)	5.1276E-04	1.0079E-03	6.8557E-04	<b>7.3543E-04</b>
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	4.3009E-07	8.0698E-07	5.4191E-07	<b>5.9299E-07</b>
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	4.3974E-07	8.1431E-07	5.4765E-07	<b>6.0056E-07</b>

**Mercury Results - HCl Rinse + HCl/MnO<sub>2</sub> Precipitate**

C <sub>sd</sub>	Concentration (lb/dscf)	9.7103E-11	2.0014E-10	1.7447E-10	<b>1.5724E-10</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	1.2073E-10	2.3164E-10	2.0125E-10	<b>1.8454E-10</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	1.1711E-10	2.2176E-10	1.9296E-10	<b>1.7728E-10</b>
C <sub>a</sub>	Concentration (lb/acf)	4.4697E-11	9.1088E-11	7.8705E-11	<b>7.1497E-11</b>
C <sub>sd</sub>	Concentration (µg/dscm)	1.5550E+00	3.2050E+00	2.7938E+00	<b>2.5179E+00</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	1.9333E+00	3.7093E+00	3.2228E+00	<b>2.9551E+00</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	1.8753E+00	3.5512E+00	3.0900E+00	<b>2.8388E+00</b>
C <sub>sd</sub>	Concentration (mg/dscm)	1.5550E-03	3.2050E-03	2.7938E-03	<b>2.5179E-03</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	1.9333E-03	3.7093E-03	3.2228E-03	<b>2.9551E-03</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	1.8753E-03	3.5512E-03	3.0900E-03	<b>2.8388E-03</b>
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	7.1575E-01	1.4587E+00	1.2603E+00	<b>1.1449E+00</b>
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	1.6688E+00	3.4395E+00	2.9983E+00	<b>2.7022E+00</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.0747E+00	3.9808E+00	3.4586E+00	<b>3.1714E+00</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.0126E+00	3.8111E+00	3.3161E+00	<b>3.0466E+00</b>
E <sub>lb/hr</sub>	Rate (lb/hr)	4.7286E-04	9.5051E-04	8.3643E-04	<b>7.5327E-04</b>
E <sub>g/s</sub>	Rate (g/s)	5.9569E-05	1.1974E-04	1.0537E-04	<b>9.4894E-05</b>
E <sub>T/yr</sub>	Rate (Ton/yr)	2.0711E-03	4.1632E-03	3.6636E-03	<b>3.2993E-03</b>
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	1.7372E-06	3.3331E-06	2.8959E-06	<b>2.6554E-06</b>
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	1.7762E-06	3.3634E-06	2.9265E-06	<b>2.6887E-06</b>

041508 115435  
 LON@P

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average	
Date (2009)	Mar 18	Mar 18	Mar 18		
Start Time (approx.)	06:41	09:19	12:12		
Stop Time (approx.)	08:52	11:30	14:22		
<b>Sampling Conditions</b>					
Y <sub>d</sub>	Dry gas meter correction factor	0.9886	0.9886	0.9886	
C <sub>p</sub>	Pitot tube coefficient	0.8120	0.8120	0.8120	
P <sub>g</sub>	Static pressure (in. H <sub>2</sub> O)	-12.0000	-12.0000	-12.0000	
A <sub>s</sub>	Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub>	Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
D <sub>n</sub>	Nozzle diameter (in.)	0.2680	0.2680	0.2680	
O <sub>2</sub>	Oxygen (dry volume %)	9.4300	9.1600	9.1600	<b>9.2500</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.1900	10.5500	10.5000	<b>10.4133</b>
N <sub>2</sub> +CO	Nitrogen plus carbon monoxide (dry volume %)	80.3800	80.2900	80.3400	<b>80.3367</b>
V <sub>lc</sub>	Total Liquid collected (ml)	410.60	414.70	419.00	
V <sub>m</sub>	Volume metered, meter conditions (ft <sup>3</sup> )	70.0250	69.6650	69.5300	
T <sub>m</sub>	Dry gas meter temperature (°F)	75.9600	82.2800	79.0000	
T <sub>s</sub>	Sample temperature (°F)	296.0000	290.4000	290.4800	<b>292.2933</b>
ΔH	Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.0480	1.0180	1.0220	
θ	Total sampling time (min)	125.0	125.0	125.0	
<b>Flow Results</b>					
V <sub>weld</sub>	Volume of water collected (ft <sup>3</sup> )	19.3228	19.5158	19.7181	<b>19.5189</b>
V <sub>matd</sub>	Volume metered, standard (dscf)	68.7570	67.6014	67.8816	<b>68.0800</b>
P <sub>s</sub>	Sample gas pressure, absolute (in. Hg)	29.2176	29.2176	29.2176	<b>29.2176</b>
P <sub>v</sub>	Vapor pressure, actual (in. Hg)	29.2176	29.2176	29.2176	<b>29.2176</b>
B <sub>wo</sub>	Moisture measured in sample (% by volume)	21.9379	22.4018	22.5094	<b>22.2830</b>
B <sub>ws</sub>	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.9379	22.4018	22.5094	<b>22.2830</b>
√ΔP	Velocity head (√in. H <sub>2</sub> O)	0.6517	0.6418	0.6384	<b>0.6440</b>
M <sub>d</sub>	MW of sample gas, dry (lb/lb-mole)	30.0076	30.0544	30.0464	<b>30.0361</b>
M <sub>s</sub>	MW of sample gas, wet (lb/lb-mole)	27.3734	27.3540	27.3348	<b>27.3541</b>
V <sub>s</sub>	Velocity of sample (ft/sec)	43.9841	43.1723	42.9622	<b>43.3729</b>
%I	Isokinetic sampling (%)	99.9960	100.0164	101.0729	<b>100.3617</b>
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	168,899	165,781	164,975	<b>166,552</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	115,192	113,910	113,343	<b>114,148</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	89,921	88,392	87,831	<b>88,715</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,201	74,656	74,182	<b>74,347</b>
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,133,929	9,946,890	9,898,500	<b>9,993,106</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	6,911,521	6,834,583	6,800,610	<b>6,848,905</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,395,281	5,303,516	5,269,836	<b>5,322,877</b>
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	286,999	281,702	280,331	<b>283,011</b>
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	195,738	193,559	192,597	<b>193,965</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	152,798	150,199	149,245	<b>150,747</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,085	126,858	126,053	<b>126,332</b>
Q <sub>a</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	182,393	180,362	179,466	<b>180,740</b>
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	142,380	139,958	139,069	<b>140,469</b>
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	117,489	118,209	117,458	<b>117,719</b>

**Comments:**

Average includes 3 runs.

041509 111945  
 L O O @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29  
 Filterable Particulate Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:41	09:19	12:12	
Stop Time (approx.)		08:52	11:30	14:22	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	183.6	183.4	184.0	183.7
P <sub>f</sub>	Fabric Filter Inlet Temperature (°F)	313	305	305	308
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.4300	9.1600	9.1600	9.2500
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.1900	10.5500	10.5000	10.4133
T <sub>s</sub>	Sample temperature (°F)	296.0000	290.4000	290.4800	292.2933
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.9379	22.4018	22.5094	22.2830
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	168,899	165,781	164,975	166,552
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	115,192	113,910	113,343	114,148
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	89,921	88,392	87,831	88,715
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,201	74,656	74,182	74,347
Q <sub>sa</sub>	Volumetric flow rate, actual (acf/hr)	10,133,929	9,946,890	9,898,500	9,993,106
Q <sub>ss</sub>	Volumetric flow rate, standard (scf/hr)	6,911,521	6,834,583	6,800,610	6,848,905
Q <sub>sstd</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,395,281	5,303,516	5,269,836	5,322,877
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	286,999	281,702	280,331	283,011
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	195,738	193,559	192,597	193,965
Q <sub>sstd</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	152,798	150,199	149,245	150,747
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,085	126,858	126,053	126,332
Q <sub>ns</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	182,393	180,362	179,466	180,740
Q <sub>sstd</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	142,380	139,958	139,069	140,469
Q <sub>sstd7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	117,489	118,209	117,458	117,719
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	68.7570	67.6014	67.8816	68.0800
%I	Isokinetic sampling (%)	99.9960	100.0164	101.0729	100.3617
<b>Laboratory Data</b>					
m <sub>filter</sub>	Matter collected on filter(s) (g)	0.00080	0.00010	0.00010	
m <sub>a</sub>	Matter collected in solvent rinse(s) (g)	0.00010	0.00380	0.00340	
m <sub>t</sub>	Total particulate matter collected (g)	0.00090	0.00380	0.00340	
<b>Filterable Particulate Results</b>					
C <sub>std</sub>	Particulate Concentration (lb/dscf)	2.8863E-08	1.2395E-07	1.1044E-07	8.7751E-08
C <sub>std7</sub>	Particulate Concentration @7% O <sub>2</sub> (lb/dscf)	3.4977E-08	1.4675E-07	1.3076E-07	1.0416E-07
C <sub>std12</sub>	Particulate Concentration @12% CO <sub>2</sub> (lb/dscf)	3.3989E-08	1.4098E-07	1.2622E-07	1.0040E-07
C <sub>a</sub>	Particulate Concentration (lb/acf)	1.5366E-08	6.6087E-08	5.8798E-08	4.6750E-08
C <sub>std</sub>	Particulate Concentration (gr/dscf)	0.0002	0.0009	0.0008	0.0006
C <sub>std7</sub>	Particulate Concentration @7% O <sub>2</sub> (gr/dscf)	0.0002	0.0010	0.0009	0.0007
C <sub>std12</sub>	Particulate Concentration @12% CO <sub>2</sub> (gr/dscf)	0.0002	0.0010	0.0009	0.0007
C <sub>a</sub>	Particulate Concentration (gr/acf)	0.0001	0.0005	0.0004	0.0003
C <sub>std</sub>	Particulate Concentration (mg/dscm)	0.4622	1.9848	1.7686	1.4052
C <sub>std7</sub>	Particulate Concentration @7% O <sub>2</sub> (mg/dscm)	0.5601	2.3500	2.0940	1.6680
C <sub>std12</sub>	Particulate Concentration @12% CO <sub>2</sub> (mg/dscm)	0.5443	2.2576	2.0212	1.6077
C <sub>a</sub>	Particulate Concentration (mg/m <sup>3</sup> (actual,wet))	0.2461	1.0583	0.9416	0.7486
C <sub>std</sub>	Particulate Concentration (mg/Nm <sup>3</sup> dry)	0.4960	2.1301	1.8980	1.5080
C <sub>std7</sub>	Particulate Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	0.6011	2.5220	2.2472	1.7901
C <sub>std12</sub>	Particulate Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	0.5841	2.4228	2.1691	1.7254
E <sub>lb/hr</sub>	Particulate Rate (lb/hr)	0.1557	0.6574	0.5820	0.4650
E <sub>kg/hr</sub>	Particulate Rate (kg/hr)	0.0706	0.2981	0.2640	0.2109
E <sub>T/yr</sub>	Particulate Rate (Ton/yr)	0.6821	2.8792	2.5492	2.0368
E <sub>Fd</sub>	Particulate Rate - F <sub>d</sub> -based (lb/MMBtu)	0.0005	0.0021	0.0019	0.0015
E <sub>Fc</sub>	Particulate Rate - F <sub>c</sub> -based (lb/MMBtu)	0.0005	0.0021	0.0019	0.0015

**Comments:**

Average includes 3 runs.

041509 111645  
 L O O @ J



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:41	09:19	12:12	
Stop Time (approx.)	08:52	11:30	14:22	
<b>Process Conditions</b>				
R <sub>P</sub> Steam Production Rate (Klbs/hour)	183.6	183.4	184.0	183.7
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	313	305	305	308
P <sub>2</sub> Carbon Feed rate (lb/hr)	7	6	5	6
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.4300	9.1600	9.1600	9.2500
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.1900	10.5500	10.5000	10.4133
T <sub>s</sub> Sample temperature (°F)	296.0000	290.4000	290.4800	292.2933
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.9379	22.4018	22.5094	22.2830
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	168,899	165,781	164,975	166,552
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	115,192	113,910	113,343	114,148
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	89,921	88,392	87,831	88,715
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,201	74,656	74,182	74,347
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	10,133,929	9,946,890	9,898,500	9,993,106
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	6,911,521	6,834,583	6,800,610	6,848,905
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	5,395,281	5,303,516	5,269,836	5,322,877
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	286,999	281,702	280,331	283,011
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	195,738	193,559	192,597	193,965
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	152,798	150,199	149,245	150,747
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,085	126,858	126,053	126,332
Q <sub>s</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	182,393	180,362	179,466	180,740
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	142,380	139,958	139,069	140,469
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	117,489	118,209	117,458	117,719
<b>Sampling Data</b>				
V <sub>std</sub> Volume metered, standard (dscf)	68.7570	67.6014	67.8816	68.0800
%I Isokinetic sampling (%)	99.9960	100.0164	101.0729	100.3617
<b>Laboratory Data</b>				
m <sub>n-1b</sub> Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	
m <sub>n-2b</sub> Fraction 2B (µg)	4.4126	3.1426	3.4661	
m <sub>n-3a</sub> Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m <sub>n-3b</sub> Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m <sub>n-3c</sub> Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	4.4126	3.1426	3.4661	
<b>Mercury Results - Total</b>				
C <sub>std</sub> Concentration (lb/dscf)	1.4151E-10	1.0250E-10	1.1259E-10	1.1887E-10
C <sub>std7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	1.7149E-10	1.2136E-10	1.3331E-10	1.4205E-10
C <sub>std12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	1.6665E-10	1.1659E-10	1.2867E-10	1.3730E-10
C <sub>a</sub> Concentration (lb/acf)	7.5340E-11	5.4654E-11	5.9942E-11	6.3312E-11
C <sub>sd</sub> Concentration (µg/dscfm)	2.2661E+00	1.6415E+00	1.8030E+00	1.9035E+00
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscfm)	2.7462E+00	1.9435E+00	2.1347E+00	2.2748E+00
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscfm)	2.6686E+00	1.8671E+00	2.0605E+00	2.1987E+00
C <sub>sd</sub> Concentration (mg/dscfm)	2.2661E-03	1.6415E-03	1.8030E-03	1.9035E-03
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscfm)	2.7462E-03	1.9435E-03	2.1347E-03	2.2748E-03
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscfm)	2.6686E-03	1.8671E-03	2.0605E-03	2.1987E-03
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	1.2065E+00	8.7521E-01	9.5988E-01	1.0138E+00
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	2.4319E+00	1.7616E+00	1.9349E+00	2.0428E+00
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.9471E+00	2.0857E+00	2.2909E+00	2.4412E+00
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.8639E+00	2.0037E+00	2.2113E+00	2.3596E+00
E <sub>lb/hr</sub> Rate (lb/hr)	7.6349E-04	5.4364E-04	5.9333E-04	6.3349E-04
E <sub>g/s</sub> Rate (g/s)	9.6181E-05	6.8485E-05	7.4746E-05	7.9804E-05
E <sub>T/yr</sub> Rate (Ton/yr)	3.3441E-03	2.3811E-03	2.5988E-03	2.7747E-03
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	2.4676E-06	1.7464E-06	1.9182E-06	2.0441E-06
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	2.5275E-08	1.7683E-06	1.9516E-06	2.0825E-06

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Front Half Results**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:41	09:19	12:12	
Stop Time (approx.)	08:52	11:30	14:22	

**Mercury Results - Front Half**

C <sub>ad</sub>	Concentration (lb/dscf)	<3.2069E-12	<3.2618E-12	<3.2483E-12	<3.2390E-12
C <sub>ad7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<3.8864E-12	<3.8619E-12	<3.8459E-12	<3.8647E-12
C <sub>ad12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<3.7766E-12	<3.7101E-12	<3.7123E-12	<3.7330E-12
C <sub>a</sub>	Concentration (lb/acf)	<1.7074E-12	<1.7391E-12	<1.7294E-12	<1.7253E-12
C <sub>ad</sub>	Concentration (µg/dscm)	<5.1355E-02	<5.2233E-02	<5.2017E-02	<5.1868E-02
C <sub>ad7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<6.2235E-02	<6.1843E-02	<6.1587E-02	<6.1888E-02
C <sub>ad12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<6.0477E-02	<5.9412E-02	<5.9448E-02	<5.9779E-02
C <sub>ad</sub>	Concentration (mg/dscm)	<5.1355E-05	<5.2233E-05	<5.2017E-05	<5.1868E-05
C <sub>ad7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<6.2235E-05	<6.1843E-05	<6.1587E-05	<6.1888E-05
C <sub>ad12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<6.0477E-05	<5.9412E-05	<5.9448E-05	<5.9779E-05
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<2.7341E-02	<2.7850E-02	<2.7693E-02	<2.7828E-02
C <sub>ad</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<5.5112E-02	<5.6055E-02	<5.5823E-02	<5.5663E-02
C <sub>ad7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<6.6788E-02	<6.6368E-02	<6.6094E-02	<6.6417E-02
C <sub>ad12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<6.4902E-02	<6.3759E-02	<6.3798E-02	<6.4153E-02
E <sub>lb/hr</sub>	Rate (lb/hr)	<1.7302E-05	<1.7299E-05	<1.7118E-05	<1.7240E-05
E <sub>g/s</sub>	Rate (g/s)	<2.1797E-06	<2.1792E-06	<2.1565E-06	<2.1718E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<7.5784E-05	<7.5769E-05	<7.4977E-05	<7.5510E-05
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<5.5922E-08	<5.5570E-08	<5.5341E-08	<5.5611E-08
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<5.7278E-08	<5.6269E-08	<5.6304E-08	<5.6617E-08

041806 111845  
 L O O @ \_ O

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:41	09:19	12:12	
Stop Time (approx.)	08:52	11:30	14:22	

**Mercury Results - Impingers 1-3 Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	1.4151E-10	1.0250E-10	1.1259E-10	1.1887E-10
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	1.7149E-10	1.2136E-10	1.3331E-10	1.4205E-10
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	1.6665E-10	1.1659E-10	1.2867E-10	1.3730E-10
C <sub>a</sub>	Concentration (lb/acf)	7.5340E-11	5.4654E-11	5.9942E-11	6.3312E-11
C <sub>sd</sub>	Concentration (µg/dscm)	2.2661E+00	1.6415E+00	1.8030E+00	1.9035E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	2.7462E+00	1.9435E+00	2.1347E+00	2.2748E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	2.6686E+00	1.8671E+00	2.0605E+00	2.1987E+00
C <sub>sd</sub>	Concentration (mg/dscm)	2.2661E-03	1.6415E-03	1.8030E-03	1.9035E-03
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	2.7462E-03	1.9435E-03	2.1347E-03	2.2748E-03
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	2.6686E-03	1.8671E-03	2.0605E-03	2.1987E-03
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.2065E+00	8.7521E-01	9.5988E-01	1.0138E+00
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	2.4319E+00	1.7616E+00	1.9349E+00	2.0428E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.9471E+00	2.0857E+00	2.2909E+00	2.4412E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.8639E+00	2.0037E+00	2.2113E+00	2.3596E+00
E <sub>lb/hr</sub>	Rate (lb/hr)	7.6349E-04	5.4364E-04	5.9333E-04	6.3349E-04
E <sub>g/s</sub>	Rate (g/s)	9.6181E-05	6.8485E-05	7.4746E-05	7.9804E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	3.3441E-03	2.3811E-03	2.5988E-03	2.7747E-03
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	2.4676E-06	1.7464E-06	1.9182E-06	2.0441E-06
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	2.5275E-06	1.7683E-06	1.9516E-06	2.0825E-06

041509 111946  
 L O O @ \_ O

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 4 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:41	09:19	12:12	
Stop Time (approx.)	08:52	11:30	14:22	

**Mercury Results - Impinger 4 Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	<6.4139E-12	<6.5235E-12	<6.4966E-12	<6.4780E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<7.7727E-12	<7.7238E-12	<7.6919E-12	<7.7295E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<7.5532E-12	<7.4201E-12	<7.4247E-12	<7.4680E-12
C <sub>a</sub>	Concentration (lb/acf)	<3.4147E-12	<3.4782E-12	<3.4587E-12	<3.4506E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<1.0271E-01	<1.0447E-01	<1.0403E-01	<1.0374E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<1.2447E-01	<1.2369E-01	<1.2317E-01	<1.2378E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<1.2095E-01	<1.1882E-01	<1.1890E-01	<1.1956E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<1.0271E-04	<1.0447E-04	<1.0403E-04	<1.0374E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<1.2447E-04	<1.2369E-04	<1.2317E-04	<1.2378E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<1.2095E-04	<1.1882E-04	<1.1890E-04	<1.1956E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<5.4682E-02	<5.5699E-02	<5.5386E-02	<5.5258E-02
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<1.1022E-01	<1.1211E-01	<1.1165E-01	<1.1133E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.3358E-01	<1.3274E-01	<1.3219E-01	<1.3283E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2980E-01	<1.2752E-01	<1.2760E-01	<1.2831E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<3.4605E-05	<3.4598E-05	<3.4236E-05	<3.4479E-05
E <sub>g/s</sub>	Rate (g/s)	<4.3594E-06	<4.3585E-06	<4.3129E-06	<4.3436E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<1.5157E-04	<1.5154E-04	<1.4995E-04	<1.5102E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<1.1184E-07	<1.1114E-07	<1.1068E-07	<1.1122E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<1.1456E-07	<1.1254E-07	<1.1261E-07	<1.1323E-07

041509 11/04/5  
 L O O @ \_ 0

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 18.	Mar 18	Mar 18	
Start Time (approx.)	06:41	09:19	12:12	
Stop Time (approx.)	08:52	11:30	14:22	

**Mercury Results - Filtered Permanganate Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	<1.6035E-11	<1.6309E-11	<1.6242E-11	<1.6195E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.9432E-11	<1.9309E-11	<1.9230E-11	<1.9324E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.8883E-11	<1.8550E-11	<1.8562E-11	<1.8665E-11
C <sub>a</sub>	Concentration (lb/acf)	<8.5369E-12	<8.6956E-12	<8.6468E-12	<8.6264E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<2.5677E-01	<2.6116E-01	<2.6009E-01	<2.5934E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<3.1117E-01	<3.0921E-01	<3.0794E-01	<3.0944E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<3.0238E-01	<2.9706E-01	<2.9724E-01	<2.9889E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<2.5677E-04	<2.6116E-04	<2.6009E-04	<2.5934E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<3.1117E-04	<3.0921E-04	<3.0794E-04	<3.0944E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<3.0238E-04	<2.9706E-04	<2.9724E-04	<2.9889E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<1.3671E-01	<1.3925E-01	<1.3847E-01	<1.3814E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.7556E-01	<2.8027E-01	<2.7912E-01	<2.7832E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.3394E-01	<3.3184E-01	<3.3047E-01	<3.3208E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.2451E-01	<3.1879E-01	<3.1899E-01	<3.2076E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<8.6512E-05	<8.6494E-05	<8.5590E-05	<8.6199E-05
E <sub>g/s</sub>	Rate (g/s)	<1.0898E-05	<1.0896E-05	<1.0782E-05	<1.0859E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	<3.7892E-04	<3.7884E-04	<3.7488E-04	<3.7755E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.7961E-07	<2.7785E-07	<2.7670E-07	<2.7806E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.8639E-07	<2.8135E-07	<2.8152E-07	<2.8309E-07

**Mercury Results - HCl Rinse + HCl/MnO2 Precipitate**

C <sub>sd</sub>	Concentration (lb/dscf)	<1.2828E-11	<1.3047E-11	<1.2993E-11	<1.2956E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.5545E-11	<1.5448E-11	<1.5384E-11	<1.5459E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.5106E-11	<1.4840E-11	<1.4849E-11	<1.4932E-11
C <sub>a</sub>	Concentration (lb/acf)	<6.8295E-12	<6.9565E-12	<6.9174E-12	<6.9011E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<2.0542E-01	<2.0893E-01	<2.0807E-01	<2.0747E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<2.4894E-01	<2.4737E-01	<2.4635E-01	<2.4755E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.4191E-01	<2.3765E-01	<2.3779E-01	<2.3912E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<2.0542E-04	<2.0893E-04	<2.0807E-04	<2.0747E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<2.4894E-04	<2.4737E-04	<2.4635E-04	<2.4755E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.4191E-04	<2.3765E-04	<2.3779E-04	<2.3912E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<1.0936E-01	<1.1140E-01	<1.1077E-01	<1.1051E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.2045E-01	<2.2422E-01	<2.2329E-01	<2.2265E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.6715E-01	<2.6547E-01	<2.6438E-01	<2.6567E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.5961E-01	<2.5504E-01	<2.5519E-01	<2.5661E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<6.9210E-05	<6.9195E-05	<6.8472E-05	<6.8959E-05
E <sub>g/s</sub>	Rate (g/s)	<8.7188E-06	<8.7170E-06	<8.6259E-06	<8.6872E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<3.0314E-04	<3.0308E-04	<2.9991E-04	<3.0204E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.2369E-07	<2.2228E-07	<2.2136E-07	<2.2245E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.2911E-07	<2.2508E-07	<2.2522E-07	<2.2647E-07

041609 111945  
 LOO@\_O

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29  
 Beryllium (Be) Emission Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:41	09:19	12:12	
Stop Time (approx.)		08:52	11:30	14:22	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Kibs/hour)	183.6	183.4	184.0	<b>183.7</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	313	305	305	<b>308</b>
P <sub>2</sub>	Carbon Feed rate (lb/hr)	7	6	5	<b>6</b>
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	<b>9,570</b>
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	<b>1,820</b>
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	<b>8,760</b>
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.4300	9.1600	9.1600	<b>9.2500</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.1900	10.5500	10.5000	<b>10.4133</b>
T <sub>s</sub>	Sample temperature (°F)	296.0000	290.4000	290.4800	<b>292.2933</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.9379	22.4018	22.5094	<b>22.2830</b>
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	168,899	165,781	164,975	<b>166,552</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	115,192	113,910	113,343	<b>114,148</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	89,921	88,392	87,831	<b>88,715</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,201	74,656	74,182	<b>74,347</b>
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,133,929	9,946,890	9,898,500	<b>9,993,106</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	6,911,521	6,834,583	6,800,610	<b>6,848,905</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,395,281	5,303,516	5,269,836	<b>5,322,877</b>
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	286,999	281,702	280,331	<b>283,011</b>
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	195,738	193,559	192,597	<b>193,965</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	152,798	150,199	149,245	<b>150,747</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,085	126,858	126,053	<b>126,332</b>
Q <sub>a</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	182,393	180,362	179,466	<b>180,740</b>
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	142,380	139,958	139,069	<b>140,469</b>
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	117,489	118,209	117,458	<b>117,719</b>
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	68.7570	67.6014	67.8816	<b>68.0800</b>
%I	Isokinetic sampling (%)	99.9960	100.0164	101.0729	<b>100.3617</b>
<b>Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
<b>Beryllium Results - Total</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	<1.6035E-12	<1.6309E-12	<1.6242E-12	<b>&lt;1.6195E-12</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.9432E-12	<1.9309E-12	<1.9230E-12	<b>&lt;1.9324E-12</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.8883E-12	<1.8550E-12	<1.8562E-12	<b>&lt;1.8665E-12</b>
C <sub>a</sub>	Concentration (lb/acf)	<8.5369E-13	<8.6956E-13	<8.6468E-13	<b>&lt;8.6264E-13</b>
C <sub>sd</sub>	Concentration (µg/dscm)	<2.5677E-02	<2.6116E-02	<2.6009E-02	<b>&lt;2.5934E-02</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<3.1117E-02	<3.0921E-02	<3.0794E-02	<b>&lt;3.0944E-02</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<3.0238E-02	<2.9706E-02	<2.9724E-02	<b>&lt;2.9889E-02</b>
C <sub>sd</sub>	Concentration (mg/dscm)	<2.5677E-05	<2.6116E-05	<2.6009E-05	<b>&lt;2.5934E-05</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<3.1117E-05	<3.0921E-05	<3.0794E-05	<b>&lt;3.0944E-05</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<3.0238E-05	<2.9706E-05	<2.9724E-05	<b>&lt;2.9889E-05</b>
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<1.3671E-02	<1.3925E-02	<1.3847E-02	<b>&lt;1.3814E-02</b>
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.7556E-02	<2.8027E-02	<2.7912E-02	<b>&lt;2.7832E-02</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.3394E-02	<3.3184E-02	<3.3047E-02	<b>&lt;3.3208E-02</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.2451E-02	<3.1879E-02	<3.1899E-02	<b>&lt;3.2076E-02</b>
E <sub>lb/hr</sub>	Rate (lb/hr)	<8.6512E-06	<8.6494E-06	<8.5590E-06	<b>&lt;8.6199E-06</b>
E <sub>g/s</sub>	Rate (g/s)	<1.0898E-06	<1.0896E-06	<1.0782E-06	<b>&lt;1.0859E-06</b>
E <sub>T/yr</sub>	Rate (Ton/yr)	<3.7892E-05	<3.7884E-05	<3.7488E-05	<b>&lt;3.7755E-05</b>
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.7961E-08	<2.7785E-08	<2.7670E-08	<b>&lt;2.7806E-08</b>
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.8639E-08	<2.8135E-08	<2.8152E-08	<b>&lt;2.8309E-08</b>

Prepared by Clean Air Engineering Inc.  
 SS Metals-1 Version 2006-12a  
 Copyright © 2006 Clean Air Engineering Inc.

QA/QC \_\_\_\_\_  
 Date \_\_\_\_\_

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29  
 Cadmium (Cd) Emission Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:41	09:19	12:12	
Stop Time (approx.)		08:52	11:30	14:22	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	183.6	183.4	184.0	183.7
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	313	305	305	308
P <sub>2</sub>	Carbon Feed rate (lb/hr)	7	6	5	6
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.4300	9.1600	9.1600	9.2500
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.1900	10.5500	10.5000	10.4133
T <sub>s</sub>	Sample temperature (°F)	296.0000	290.4000	290.4800	292.2933
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.9379	22.4018	22.5094	22.2830
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	168,899	165,781	164,975	166,552
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	115,192	113,910	113,343	114,148
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	89,921	88,392	87,831	88,715
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,201	74,656	74,182	74,347
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,133,929	9,946,890	9,898,500	9,993,106
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	6,911,521	6,834,583	6,800,610	6,848,905
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,395,281	5,303,516	5,269,836	5,322,877
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	286,999	281,702	280,331	283,011
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	195,738	193,559	192,597	193,965
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	152,798	150,199	149,245	150,747
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,085	126,858	126,053	126,332
Q <sub>s</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	182,393	180,362	179,466	180,740
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	142,380	139,958	139,069	140,469
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	117,489	118,209	117,458	117,719
<b>Sampling Data</b>					
V <sub>std</sub>	Volume metered, standard (dscf)	68.7570	67.6014	67.8816	68.0800
%I	Isokinetic sampling (%)	99.9960	100.0164	101.0729	100.3617
<b>Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	0.3934	0.3103	1.0930	
<b>Cadmium Results - Total</b>					
C <sub>std</sub>	Concentration (lb/dscf)	1.2616E-11	1.0120E-11	3.5504E-11	1.9413E-11
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	1.5289E-11	1.1982E-11	4.2036E-11	2.3102E-11
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	1.4857E-11	1.1511E-11	4.0576E-11	2.2315E-11
C <sub>a</sub>	Concentration (lb/acf)	6.7168E-12	5.3960E-12	1.8902E-11	1.0338E-11
C <sub>std</sub>	Concentration (µg/dscm)	2.0203E-01	1.6206E-01	5.6854E-01	3.1088E-01
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	2.4483E-01	1.9188E-01	6.7315E-01	3.6995E-01
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	2.3792E-01	1.8434E-01	6.4976E-01	3.5734E-01
C <sub>std</sub>	Concentration (mg/dscm)	2.0203E-04	1.6206E-04	5.6854E-04	3.1088E-04
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	2.4483E-04	1.9188E-04	6.7315E-04	3.6995E-04
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	2.3792E-04	1.8434E-04	6.4976E-04	3.5734E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.0756E-01	8.6409E-02	3.0269E-01	1.6555E-01
C <sub>std</sub>	Concentration (µg/Nm <sup>3</sup> dry)	2.1681E-01	1.7392E-01	6.1014E-01	3.3363E-01
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.6275E-01	2.0592E-01	7.2240E-01	3.9702E-01
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.5532E-01	1.9783E-01	6.9731E-01	3.8349E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	6.8068E-05	5.3673E-05	1.8710E-04	1.0295E-04
E <sub>g/s</sub>	Rate (g/s)	8.5749E-06	6.7616E-06	2.3570E-05	1.2969E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	2.9814E-04	2.3509E-04	8.1949E-04	4.5091E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	2.2000E-07	1.7242E-07	6.0487E-07	3.3243E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	2.2533E-07	1.7459E-07	6.1540E-07	3.3844E-07

Prepared by Clean Air Engineering Inc.  
 SS Metals-1 Version 2008-12a

Copyright © 2008 Clean Air Engineering Inc.

QA/QC \_\_\_\_\_  
 Date \_\_\_\_\_

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29  
 Lead (Pb) Emission Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:41	09:19	12:12	
Stop Time (approx.)		08:52	11:30	14:22	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	183.6	183.4	184.0	183.7
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	313	305	305	308
P <sub>2</sub>	Carbon Feed rate (lb/hr)	7	6	5	6
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.4300	9.1600	9.1600	9.2500
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.1900	10.5500	10.5000	10.4133
T <sub>a</sub>	Sample temperature (°F)	296.0000	290.4000	290.4800	292.2933
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.9379	22.4018	22.5094	22.2830
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	168,899	165,781	164,975	166,552
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	115,192	113,910	113,343	114,148
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	89,921	88,392	87,831	88,715
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,201	74,656	74,182	74,347
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,133,929	9,946,890	9,898,500	9,993,106
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	6,911,521	6,834,583	6,800,610	6,848,905
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,395,281	5,303,516	5,269,836	5,322,877
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	286,999	281,702	280,331	283,011
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	195,738	193,559	192,597	193,965
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	152,798	150,199	149,245	150,747
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,085	126,858	126,053	126,332
Q <sub>a</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	182,393	180,362	179,466	180,740
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	142,380	139,958	139,069	140,469
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	117,489	118,209	117,458	117,719
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	68.7570	67.6014	67.8816	68.0800
%I	Isokinetic sampling (%)	99.9960	100.0164	101.0729	100.3617
<b>Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	2.2834	1.3454	2.3089	
<b>Lead Results - Total</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	7.3227E-11	4.3885E-11	7.4999E-11	6.4037E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	8.8741E-11	5.1959E-11	8.8798E-11	7.6499E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	8.6234E-11	4.9916E-11	8.5713E-11	7.3955E-11
C <sub>a</sub>	Concentration (lb/acf)	3.8986E-11	2.3398E-11	3.9929E-11	3.4104E-11
C <sub>sd</sub>	Concentration (µg/dscm)	1.1726E+00	7.0275E-01	1.2010E+00	1.0255E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	1.4211E+00	8.3205E-01	1.4220E+00	1.2250E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	1.3809E+00	7.9934E-01	1.3726E+00	1.1843E+00
C <sub>sd</sub>	Concentration (mg/dscm)	1.1726E-03	7.0275E-04	1.2010E-03	1.0255E-03
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	1.4211E-03	8.3205E-04	1.4220E-03	1.2250E-03
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	1.3809E-03	7.9934E-04	1.3726E-03	1.1843E-03
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	6.2431E-01	3.7469E-01	6.3940E-01	5.4613E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	1.2584E+00	7.5417E-01	1.2889E+00	1.1005E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.5250E+00	8.9293E-01	1.5260E+00	1.3147E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.4820E+00	8.5782E-01	1.4730E+00	1.2709E+00
E <sub>lb/hr</sub>	Rate (lb/hr)	3.9508E-04	2.3274E-04	3.9523E-04	3.4102E-04
E <sub>g/s</sub>	Rate (g/s)	4.9771E-05	2.9320E-05	4.9790E-05	4.2960E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	1.7305E-03	1.0194E-03	1.7311E-03	1.4937E-03
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	1.2769E-06	7.4766E-07	1.2778E-06	1.1008E-06
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	1.3079E-06	7.5706E-07	1.3000E-06	1.1218E-06

Prepared by Clean Air Systems Inc. on 03/20/09  
 SS Metals-1 Version 2008-12a

Copyright © 2008 Clean Air Engineering Inc.

QA/QC \_\_\_\_\_  
 Date \_\_\_\_\_



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 13B (Total Fluorides)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:38	08:06	09:47	
Stop Time (approx.)	07:50	09:21	11:00	
<b>Sampling Conditions</b>				
Y <sub>d</sub> Dry gas meter correction factor	0.9916	0.9916	0.9916	
C <sub>p</sub> Pitot tube coefficient	0.8250	0.8250	0.8250	
P <sub>g</sub> Static pressure (in. H <sub>2</sub> O)	-12.0000	-12.0000	-12.0000	
A <sub>s</sub> Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub> Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
D <sub>n</sub> Nozzle diameter (in.)	0.2720	0.2720	0.2720	
O <sub>2</sub> Oxygen (dry volume %)	9.3600	9.3000	10.1200	<b>9.5933</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.2300	10.3400	9.5600	<b>10.0433</b>
N <sub>2</sub> +CO Nitrogen plus carbon monoxide (dry volume %)	80.4100	80.3600	80.3200	<b>80.3633</b>
V <sub>lc</sub> Total Liquid collected (ml)	220.60	230.00	234.70	
V <sub>m</sub> Volume metered, meter conditions (ft <sup>3</sup> )	37.8550	38.2900	38.4800	
T <sub>m</sub> Dry gas meter temperature (°F)	71.0000	75.6000	79.2200	
T <sub>s</sub> Sample temperature (°F)	293.0800	290.0000	286.9600	<b>290.0133</b>
ΔH Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.2312	1.2612	1.2868	
θ Total sampling time (min)	62.5	62.5	62.5	
<b>Flow Results</b>				
V <sub>wstd</sub> Volume of water collected (ft <sup>3</sup> )	10.3814	10.8238	11.0450	<b>10.7501</b>
V <sub>mstd</sub> Volume metered, standard (dscf)	37.6474	37.7557	37.6907	<b>37.6979</b>
P <sub>s</sub> Sample gas pressure, absolute (in. Hg)	29.2176	29.2176	29.2176	<b>29.2176</b>
P <sub>v</sub> Vapor pressure, actual (in. Hg)	29.2176	29.2176	29.2176	<b>29.2176</b>
B <sub>wb</sub> Moisture measured in sample (% by volume)	21.6150	22.2806	22.6630	<b>22.1862</b>
B <sub>wb</sub> Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.6150	22.2806	22.6630	<b>22.1862</b>
√ΔP Velocity head (√in. H <sub>2</sub> O)	0.6788	0.6887	0.6874	<b>0.6843</b>
M <sub>d</sub> MW of sample gas, dry (lb/lb-mole)	30.0112	30.0264	29.9344	<b>29.9907</b>
M <sub>s</sub> MW of sample gas, wet (lb/lb-mole)	27.4150	27.3468	27.2297	<b>27.3305</b>
V <sub>s</sub> Velocity of sample (ft/sec)	46.4230	46.9242	46.9747	<b>46.7740</b>
%I Isokinetic sampling (%)	99.9197	99.5770	99.3851	<b>99.6272</b>
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	178,264	180,189	180,383	<b>179,612</b>
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	122,051	123,875	124,513	<b>123,480</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	95,670	96,275	96,295	<b>96,080</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	79,426	80,345	74,680	<b>78,150</b>
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	10,695,858	10,811,326	10,822,977	<b>10,776,721</b>
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,323,052	7,432,506	7,470,798	<b>7,408,785</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	5,740,172	5,776,499	5,777,687	<b>5,764,786</b>
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	302,913	306,183	306,513	<b>305,203</b>
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	207,393	210,493	211,577	<b>209,821</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	162,565	163,594	163,628	<b>163,262</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	134,964	136,524	126,900	<b>132,796</b>
Q <sub>a</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	193,253	196,141	197,152	<b>195,515</b>
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	151,481	152,440	152,471	<b>152,131</b>
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	125,762	127,216	118,247	<b>123,742</b>

**Comments:**

Average includes 3 runs.

041509 116264  
 MIN@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 13B  
 HF Parameters**

Run No.	1	2	3	Average	
Date (2009)	Mar 18	Mar 18	Mar 18		
Start Time (approx.)	06:38	08:06	09:47		
Stop Time (approx.)	07:50	09:21	11:00		
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.3	183.8	184.1	<b>184.1</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	308	305	<b>309</b>
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	<b>9,570</b>
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	<b>1,820</b>
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	<b>8,760</b>
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.3600	9.3000	10.1200	<b>9.5933</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.2300	10.3400	9.5600	<b>10.0433</b>
T <sub>s</sub>	Sample temperature (°F)	293.0800	290.0000	286.9600	<b>290.0133</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.6150	22.2806	22.6630	<b>22.1862</b>
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	178,264	180,189	180,383	<b>179,612</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	122,051	123,875	124,513	<b>123,480</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	95,670	96,275	96,295	<b>96,080</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	79,426	80,345	74,680	<b>78,150</b>
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,695,858	10,811,326	10,822,977	<b>10,776,721</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,323,052	7,432,506	7,470,798	<b>7,408,785</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,740,172	5,776,499	5,777,687	<b>5,764,786</b>
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	302,913	306,183	306,513	<b>305,203</b>
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	207,393	210,493	211,577	<b>209,821</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	162,565	163,594	163,628	<b>163,262</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	134,964	136,524	126,900	<b>132,796</b>
Q <sub>s</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	193,253	196,141	197,152	<b>195,515</b>
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	151,481	152,440	152,471	<b>152,131</b>
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	125,762	127,216	118,247	<b>123,742</b>
<b>Sampling Data</b>					
V <sub>metd</sub>	Volume metered, standard (dscf)	37.6474	37.7557	37.6907	<b>37.8979</b>
%I	Isokinetic sampling (%)	99.9197	99.5770	99.3851	<b>99.6272</b>
<b>Laboratory Data</b>					
m <sub>n</sub>	Total HF collected (mg)	<0.0061	<0.0055	<0.0060	
<b>Hydrogen Fluoride (HF) Results</b>					
C <sub>sd</sub>	HF Concentration (lb/dscf)	<3.5487E-10	<3.1954E-10	<3.4929E-10	<b>&lt;3.4123E-10</b>
C <sub>sd7</sub>	HF Concentration @7% O <sub>2</sub> (lb/dscf)	<4.2745E-10	<3.8290E-10	<4.5038E-10	<b>&lt;4.2024E-10</b>
C <sub>sd12</sub>	HF Concentration @12% CO <sub>2</sub> (lb/dscf)	<4.1627E-10	<3.7084E-10	<4.3844E-10	<b>&lt;4.0852E-10</b>
C <sub>a</sub>	HF Concentration (lb/acf)	<1.9045E-10	<1.7073E-10	<1.8646E-10	<b>&lt;1.8255E-10</b>
C <sub>sd</sub>	HF Concentration (ppmdv)	<0.0068	<0.0062	<0.0067	<b>&lt;0.0066</b>
C <sub>sd7</sub>	HF Concentration @7% O <sub>2</sub> (ppmdv)	<0.0082	<0.0074	<0.0087	<b>&lt;0.0081</b>
C <sub>sd12</sub>	HF Concentration @12% CO <sub>2</sub> (ppmdv)	<0.0080	<0.0071	<0.0084	<b>&lt;0.0079</b>
C <sub>w</sub>	HF Concentration (ppmwv)	<0.0054	<0.0048	<0.0052	<b>&lt;0.0051</b>
C <sub>sd</sub>	HF Concentration (mg/dscm)	<0.0057	<0.0051	<0.0056	<b>&lt;0.0055</b>
C <sub>sd7</sub>	HF Concentration @7% O <sub>2</sub> (mg/dscm)	<0.0068	<0.0061	<0.0072	<b>&lt;0.0067</b>
C <sub>sd12</sub>	HF Concentration @12% CO <sub>2</sub> (mg/dscm)	<0.0067	<0.0059	<0.0070	<b>&lt;0.0065</b>
C <sub>a</sub>	HF Concentration (mg/m <sup>3</sup> (actual,wet))	<0.0030	<0.0027	<0.0030	<b>&lt;0.0029</b>
C <sub>sd</sub>	HF Concentration (mg/Nm <sup>3</sup> dry)	<0.0061	<0.0055	<0.0060	<b>&lt;0.0059</b>
C <sub>sd7</sub>	HF Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	<0.0073	<0.0066	<0.0077	<b>&lt;0.0072</b>
C <sub>sd12</sub>	HF Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	<0.0072	<0.0064	<0.0075	<b>&lt;0.0070</b>
E <sub>lb/hr</sub>	HF Rate (lb/hr)	<0.0020	<0.0018	<0.0020	<b>&lt;0.0020</b>
E <sub>kg/hr</sub>	HF Rate (kg/hr)	<0.0009	<0.0008	<0.0009	<b>&lt;0.0009</b>
E <sub>T/yr</sub>	HF Rate (Ton/yr)	<0.0089	<0.0081	<0.0088	<b>&lt;0.0086</b>
E <sub>Fd</sub>	HF Rate - Fd-based (lb/MMBtu)	<0.0000062	<0.0000055	<0.0000065	<b>&lt;0.0000060</b>
E <sub>Fc</sub>	HF Rate - Fc-based (lb/MMBtu)	<0.0000063	<0.0000056	<0.0000066	<b>&lt;0.0000062</b>

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 23 (PCDD/F)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 17	Mar 17	
Start Time (approx.)	11:07	06:08	10:54	
Stop Time (approx.)	15:32	10:27	15:18	
<b>Sampling Conditions</b>				
Y <sub>d</sub> Dry gas meter correction factor	0.9916	0.9916	0.9916	
C <sub>p</sub> Pitot tube coefficient	0.8330	0.8330	0.8330	
P <sub>g</sub> Static pressure (in. H <sub>2</sub> O)	-10.4000	-14.3000	-13.1000	
A <sub>s</sub> Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub> Barometric pressure (in. Hg)	30.20	30.10	30.10	<b>30.1333</b>
D <sub>n</sub> Nozzle diameter (in.)	0.2660	0.2660	0.2660	
O <sub>2</sub> Oxygen (dry volume %)	9.5400	9.6600	9.4000	<b>9.5333</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.2500	9.9400	10.1700	<b>10.1200</b>
N <sub>2</sub> +CO Nitrogen plus carbon monoxide (dry volume %)	80.2100	80.4000	80.4300	<b>80.3467</b>
V <sub>lc</sub> Total Liquid collected (ml)	817.50	830.20	784.30	
V <sub>m</sub> Volume metered, meter conditions (ft <sup>3</sup> )	146.5700	147.1850	144.4350	
T <sub>m</sub> Dry gas meter temperature (°F)	85.5200	79.1800	89.2600	
T <sub>s</sub> Sample temperature (°F)	301.2000	300.7600	300.9600	<b>300.9733</b>
ΔH Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.1278	1.1482	1.0964	
θ Total sampling time (min)	250.0	250.0	250.0	
<b>Flow Results</b>				
V <sub>wstd</sub> Volume of water collected (ft <sup>3</sup> )	38.4716	39.0692	36.9092	<b>38.1500</b>
V <sub>mstd</sub> Volume metered, standard (dscf)	142.3205	144.1278	138.8218	<b>141.7567</b>
P <sub>s</sub> Sample gas pressure, absolute (in. Hg)	29.4353	29.0485	29.1368	<b>29.2069</b>
P <sub>v</sub> Vapor pressure, actual (in. Hg)	29.4353	29.0485	29.1368	<b>29.2069</b>
B <sub>wo</sub> Moisture measured in sample (% by volume)	21.2795	21.3263	21.0032	<b>21.2030</b>
B <sub>wa</sub> Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.2795	21.3263	21.0032	<b>21.2030</b>
√ΔP Velocity head (√in. H <sub>2</sub> O)	0.6649	0.6813	0.6584	<b>0.6682</b>
M <sub>d</sub> MW of sample gas, dry (lb/lb-mole)	30.0216	29.9768	30.0032	<b>30.0005</b>
M <sub>s</sub> MW of sample gas, wet (lb/lb-mole)	27.4635	27.4226	27.4821	<b>27.4561</b>
V <sub>s</sub> Velocity of sample (ft/sec)	45.9501	47.4165	45.7038	<b>46.3568</b>
%I Isokinetic sampling (%)	99.6609	99.1092	98.3598	<b>99.0433</b>
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	176,448	182,079	175,503	<b>178,010</b>
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	120,409	122,690	118,587	<b>120,562</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	94,787	96,525	93,680	<b>94,997</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	77,466	78,053	77,505	<b>77,675</b>
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	10,586,895	10,924,751	10,530,158	<b>10,680,602</b>
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,224,546	7,361,399	7,115,194	<b>7,233,713</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	5,687,202	5,791,482	5,620,774	<b>5,699,820</b>
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	299,827	309,395	298,220	<b>302,481</b>
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	204,603	208,479	201,506	<b>204,863</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	161,065	164,018	159,184	<b>161,422</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	131,633	132,631	131,699	<b>131,987</b>
Q <sub>s</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	190,653	194,265	187,767	<b>190,895</b>
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	150,083	152,835	148,330	<b>150,416</b>
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	122,658	123,588	122,719	<b>122,988</b>

**Comments:**

Average includes 3 runs.

041509 115712  
 PNO

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 23 Parameters (NDs & EMPCs counted as Zero)**  
**Total Tetra- through Octa-PCDD/F Results (using USEPA/INTL 1989 TEFs)**

Run No.	1	2	3	Average	
Date (2009)	Mar 16	Mar 17	Mar 17		
Start Time (approx.)	11:07	06:08	10:54		
Stop Time (approx.)	15:32	10:27	15:18		
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.0	183.4	184.2	183.9
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	320	320	320	320
P <sub>2</sub>	Carbon Feed Rate (lb/hr)	6	5	5	5
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.5400	9.6600	9.4000	9.5333
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.2500	9.9400	10.1700	10.1200
T <sub>s</sub>	Sample temperature (°F)	301.2	300.8	301.0	301.0
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.2795	21.3263	21.0032	21.2030
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	176,448	182,079	175,503	178,010
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	120,409	122,690	118,587	120,562
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	94,787	96,525	93,680	94,997
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	77,466	78,053	77,505	77,675
Q <sub>a</sub>	Volumetric flow rate, actual (act/hr)	10,586,895	10,924,751	10,530,158	10,680,602
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,224,546	7,361,399	7,115,194	7,233,713
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,687,202	5,791,482	5,620,774	5,699,820
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	299,827	309,395	298,220	302,481
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	204,603	208,479	201,506	204,863
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	161,065	164,018	159,184	161,422
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	131,633	132,631	131,699	131,987
Q <sub>a</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	190,653	194,265	187,767	190,895
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	150,083	152,835	148,330	150,416
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	122,658	123,588	122,719	122,988
<b>Sampling Data</b>					
V <sub>m,Std</sub>	Volume metered, standard (dscf)	142.3205	144.1278	138.8218	141.7567
%I	Isokinetic sampling (%)	99.8609	99.1092	98.3598	99.0433
<b>Laboratory Data from USEPA Method 23</b>					
	Total PCDDs (ng)	9.19300	9.08100	9.01300	
	Total PCDFs (ng)	3.47830	3.21770	3.28990	
m <sub>n</sub>	Total PCDDs & PCDFs (ng)	12.70000	12.30000	12.30000	
m <sub>n,TEQ</sub>	Total TEQ PCDDs & PCDFs (ng)	0.13300	0.12700	0.12900	
<b>Total PCDD/F Results (TEF=1)</b>					
C <sub>std</sub>	PCDD/F Concentration (ng/dscm)	3.1509E+00	3.0134E+00	3.1286E+00	3.0976E+00
C <sub>std7</sub>	PCDD/F Concentration @7% O <sub>2</sub> (ng/dscm)	3.8554E+00	3.7265E+00	3.7815E+00	3.7878E+00
C <sub>std12</sub>	PCDD/F Concentration @12% CO <sub>2</sub> (ng/dscm)	3.6889E+00	3.6379E+00	3.6915E+00	3.6728E+00
C <sub>std</sub>	PCDD/F Concentration (ng/Nm <sup>3</sup> dry)	3.3814E+00	3.2339E+00	3.3575E+00	3.3243E+00
C <sub>std7</sub>	PCDD/F Concentration @7% O <sub>2</sub> (ng/Nm <sup>3</sup> dry)	4.1375E+00	3.9992E+00	4.0582E+00	4.0650E+00
C <sub>std12</sub>	PCDD/F Concentration @12% CO <sub>2</sub> (ng/Nm <sup>3</sup> dry)	3.9588E+00	3.9041E+00	3.9616E+00	3.9415E+00
E <sub>lb/hr</sub>	PCDD/F Rate (lb/hr)	1.1190E-06	1.0898E-06	1.0981E-06	1.1023E-06
E <sub>g/s</sub>	PCDD/F Rate (g/s)	1.4097E-07	1.3729E-07	1.3834E-07	1.3887E-07
E <sub>Ton/yr</sub>	PCDD/F Rate (Ton/yr)	4.9014E-06	4.7734E-06	4.8098E-06	4.8282E-06
E <sub>Fd</sub>	PCDD/F Rate - F <sub>d</sub> -based (lb/MMBtu)	3.4644E-09	3.3486E-09	3.3979E-09	3.4036E-09
E <sub>Fc</sub>	PCDD/F Rate - F <sub>c</sub> -based (lb/MMBtu)	3.4938E-09	3.4455E-09	3.4963E-09	3.4785E-09
<b>Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)</b>					
C <sub>stdTEQ</sub>	TEQ Concentration (ng/dscm)	3.2998E-02	3.1114E-02	3.2812E-02	3.2308E-02
C <sub>std7TEQ</sub>	TEQ Concentration @7% O <sub>2</sub> (ng/dscm)	4.0376E-02	3.8477E-02	3.9659E-02	3.9504E-02
C <sub>std12TEQ</sub>	TEQ Concentration @12% CO <sub>2</sub> (ng/dscm)	3.8631E-02	3.7562E-02	3.8716E-02	3.8303E-02
C <sub>stdTEQ</sub>	TEQ Concentration (ng/Nm <sup>3</sup> dry)	3.5412E-02	3.3390E-02	3.5213E-02	3.4672E-02
C <sub>std7TEQ</sub>	TEQ Concentration @7% O <sub>2</sub> (ng/Nm <sup>3</sup> dry)	4.3330E-02	4.1292E-02	4.2561E-02	4.2395E-02
C <sub>std12TEQ</sub>	TEQ Concentration @12% CO <sub>2</sub> (ng/Nm <sup>3</sup> dry)	4.1458E-02	4.0310E-02	4.1549E-02	4.1106E-02
E <sub>lb/hrTEQ</sub>	TEQ Rate (lb/hr)	1.1719E-08	1.1253E-08	1.1517E-08	1.1496E-08
E <sub>g/secTEQ</sub>	TEQ Rate (g/sec)	1.4763E-09	1.4176E-09	1.4509E-09	1.4482E-09
E <sub>Ton/yrTEQ</sub>	TEQ Rate (Ton/yr)	5.1329E-08	4.9287E-08	5.0444E-08	5.0353E-08
E <sub>FdTEQ</sub>	TEQ Rate - F <sub>d</sub> -based (lb/MMBtu)	3.6280E-11	3.4575E-11	3.5637E-11	3.5497E-11
E <sub>FcTEQ</sub>	TEQ Rate - F <sub>c</sub> -based (lb/MMBtu)	3.6588E-11	3.5575E-11	3.6668E-11	3.6277E-11

04/100 115712  
 P N O @ X

**USEPA Method 23 Maximum Emissions Parameters (NDs & EMPCs included)  
 Total Tetra- through Octa-PCDD/F Results (TEQ based on USEPA/INTL 1989 TEFs)**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 17	Mar 17	
Start Time (approx.)	11:07	06:08	10:54	
Stop Time (approx.)	15:32	10:27	15:18	
<b>Process Conditions</b>				
R <sub>p</sub>	184.0	183.4	184.2	183.9
P <sub>1</sub>	320	320	320	320
P <sub>2</sub>	6	5	5	5
F <sub>d</sub>	9,570	9,570	9,570	9,570
F <sub>c</sub>	1,820	1,820	1,820	1,820
C <sub>ap</sub>	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>				
O <sub>2</sub>	9.5400	9.6600	9.4000	9.5333
CO <sub>2</sub>	10.2500	9.9400	10.1700	10.1200
T <sub>s</sub>	301.2	300.8	301.0	301.0
B <sub>w</sub>	21.2795	21.3263	21.0032	21.2030
<b>Gas Flow Rate</b>				
Q <sub>a</sub>	176,448	182,079	175,503	178,010
Q <sub>s</sub>	120,409	122,690	118,587	120,562
Q <sub>std</sub>	94,787	96,525	93,680	94,997
Q <sub>std7</sub>	77,466	78,053	77,505	77,675
Q <sub>a</sub>	10,586,895	10,924,751	10,530,158	10,680,602
Q <sub>s</sub>	7,224,546	7,361,399	7,115,194	7,233,713
Q <sub>std</sub>	5,687,202	5,791,482	5,620,774	5,699,820
Q <sub>a</sub>	299,827	309,395	298,220	302,481
Q <sub>s</sub>	204,603	208,479	201,506	204,863
Q <sub>std</sub>	161,065	164,018	159,184	161,422
Q <sub>std7</sub>	131,633	132,631	131,699	131,987
Q <sub>a</sub>	190,653	194,265	187,767	190,895
Q <sub>std</sub>	150,083	152,835	148,330	150,416
Q <sub>std7</sub>	122,658	123,588	122,719	122,988
<b>Sampling Data</b>				
V <sub>mstd</sub>	142.3205	144.1278	138.8218	141.7567
%I	99.6609	99.1092	98.3598	99.0433
<b>Laboratory Data from USEPA Method 23, including NDs and EMPCs</b>				
m <sub>n</sub>	12.70000	12.50000	12.40000	
m <sub>n,TEQ</sub>	0.13600	0.13100	0.12900	
<b>Total PCDD/F Results (TEF=1)</b>				
C <sub>sd</sub>	3.1509E+00	3.0624E+00	3.1540E+00	3.1224E+00
C <sub>sd7</sub>	3.8554E+00	3.7871E+00	3.8122E+00	3.8183E+00
C <sub>sd12</sub>	3.6889E+00	3.6970E+00	3.7215E+00	3.7025E+00
C <sub>sd</sub>	3.3814E+00	3.2865E+00	3.3848E+00	3.3509E+00
C <sub>sd7</sub>	4.1375E+00	4.0642E+00	4.0912E+00	4.0976E+00
C <sub>sd12</sub>	3.9588E+00	3.9676E+00	3.9938E+00	3.9734E+00
E <sub>sb/hr</sub>	1.1190E-06	1.1075E-06	1.1071E-06	1.1112E-06
E <sub>g/s</sub>	1.4097E-07	1.3952E-07	1.3946E-07	1.3999E-07
E <sub>T/yr</sub>	4.9014E-06	4.8510E-06	4.8489E-06	4.8671E-06
E <sub>Fd</sub>	3.4644E-09	3.4030E-09	3.4256E-09	3.4310E-09
E <sub>Fc</sub>	3.4938E-09	3.5015E-09	3.5247E-09	3.5067E-09
E <sub>H</sub>	N/A	N/A	N/A	N/A
E <sub>Rp</sub>	6.0817E-09	6.0389E-09	6.0101E-09	6.0436E-09
E <sub>Rfp</sub>	2.7581E-06	2.7388E-06	2.7257E-06	2.7408E-06
<b>Total PCDD/F TEQ Results (using USEPA/INTL 1989 TEFs)</b>				
C <sub>sdTEQ</sub>	3.3742E-02	3.2094E-02	3.2812E-02	3.2882E-02
C <sub>sd7TEQ</sub>	4.1286E-02	3.9689E-02	3.9659E-02	4.0212E-02
C <sub>sd12TEQ</sub>	3.9503E-02	3.8745E-02	3.8716E-02	3.8988E-02
C <sub>sdTEQ</sub>	3.6211E-02	3.4442E-02	3.5213E-02	3.5289E-02
C <sub>sd7TEQ</sub>	4.4307E-02	4.2593E-02	4.2561E-02	4.3154E-02
C <sub>sd12TEQ</sub>	4.2393E-02	4.1580E-02	4.1549E-02	4.1841E-02
E <sub>sb/hrTEQ</sub>	1.1983E-08	1.1607E-08	1.1517E-08	1.1702E-08
E <sub>g/secTEQ</sub>	1.5096E-09	1.4622E-09	1.4509E-09	1.4742E-09
E <sub>T/yrTEQ</sub>	5.2487E-08	5.0839E-08	5.0444E-08	5.1257E-08
E <sub>FdTEQ</sub>	3.7099E-11	3.5664E-11	3.5637E-11	3.6133E-11
E <sub>FcTEQ</sub>	3.7413E-11	3.6696E-11	3.6668E-11	3.6926E-11
E <sub>HTEQ</sub>	N/A	N/A	N/A	N/A
E <sub>RpTEQ</sub>	6.5127E-11	6.3288E-11	6.2524E-11	6.3646E-11
E <sub>RfpTEQ</sub>	2.9536E-08	2.8702E-08	2.8358E-08	2.8865E-08

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

### USEPA Method 26A (HCl) Sampling, Velocity and Moisture Parameters

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:44	08:22	09:50	
Stop Time (approx.)	07:44	09:22	10:50	
<b>Sampling Conditions</b>				
$Y_d$ Dry gas meter correction factor	0.9992	0.9992	0.9992	
$P_g$ Static pressure (in. H <sub>2</sub> O)	-1.3000	-1.3000	-1.3000	
$A_s$ Sample location area (ft <sup>2</sup> )	60.1320	60.1320	60.1320	
$P_{bar}$ Barometric pressure (in. Hg)	30.20	30.20	30.20	<b>30.2000</b>
$O_2$ Oxygen (dry volume %)	8.0000	7.7300	8.4500	<b>8.0600</b>
$CO_2$ Carbon dioxide (dry volume %)	11.4100	11.6800	10.9900	<b>11.3600</b>
$N_2+CO$ Nitrogen plus carbon monoxide (dry volume %)	80.5900	80.5900	80.5600	<b>80.5800</b>
$V_{lc}$ Total Liquid collected (ml)	157.00	140.80	143.80	
$V_m$ Volume metered, meter conditions (ft <sup>3</sup> )	33.5600	35.4400	35.2900	
$T_m$ Dry gas meter temperature (°F)	81.0417	92.5833	95.3333	
$T_s$ Sample temperature (°F)	492.3333	487.5833	487.3333	<b>489.0833</b>
$\Delta H$ Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.0883	1.1833	1.1833	
$\theta$ Total sampling time (min)	60.0	60.0	60.0	
<b>Flow Results</b>				
$V_{wstd}$ Volume of water collected (ft <sup>3</sup> )	7.3884	6.6260	6.7672	<b>6.9272</b>
$V_{mstd}$ Volume metered, standard (dscf)	33.1054	34.2376	33.9239	<b>33.7556</b>
$P_s$ Sample gas pressure, absolute (in. Hg)	30.1044	30.1044	30.1044	<b>30.1044</b>
$P_v$ Vapor pressure, actual (in. Hg)	30.1044	30.1044	30.1044	<b>30.1044</b>
$B_{wo}$ Moisture measured in sample (% by volume)	18.2458	16.2150	16.6307	<b>17.0305</b>
$B_{ws}$ Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
$B_w$ Actual water vapor in gas (% by volume)	18.2458	16.2150	16.6307	<b>17.0305</b>
$M_d$ MW of sample gas, dry (lb/lb-mole)	30.1456	30.1780	30.0964	<b>30.1400</b>
$M_s$ MW of sample gas, wet (lb/lb-mole)	27.9295	28.2033	28.0847	<b>28.0725</b>

Comments:

Average includes 3 runs.

041509 102856  
 LLL@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

## USEPA Method 26A HCl Parameters

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:44	08:22	09:50	
Stop Time (approx.)	07:44	09:22	10:50	
<b>Process Conditions</b>				
R <sub>P</sub> Steam Production Rate (Klbs/hour)	184.7	184.7	183.5	184.3
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	320	320	320	320
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	8.0000	7.7300	8.4500	8.0600
CO <sub>2</sub> Carbon dioxide (dry volume %)	11.4100	11.6800	10.9900	11.3600
T <sub>s</sub> Sample temperature (°F)	492.3333	487.5833	487.3333	489.0833
B <sub>w</sub> Actual water vapor in gas (% by volume)	18.2458	16.2150	16.6307	17.0305
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	33.1054	34.2376	33.9239	33.7556
<b>Laboratory Data</b>				
m <sub>n</sub> Total HCl collected (mg)	593.6855	508.7987	529.3518	
<b>Hydrogen Chloride (HCl) Results</b>				
C <sub>sd</sub> HCl Concentration (lb/dscf)	3.9543E-05	3.2768E-05	3.4407E-05	3.5573E-05
C <sub>sd7</sub> HCl Concentration @7% O <sub>2</sub> (lb/dscf)	4.2608E-05	3.4584E-05	3.8414E-05	3.8536E-05
C <sub>sd12</sub> HCl Concentration @12% CO <sub>2</sub> (lb/dscf)	4.1587E-05	3.3666E-05	3.7569E-05	3.7607E-05
C <sub>sd</sub> HCl Concentration (ppmdv)	418.0693	346.4440	363.7721	376.0952
C <sub>sd7</sub> HCl Concentration @7% O <sub>2</sub> (ppmdv)	450.4778	365.6470	406.1392	407.4213
C <sub>sd12</sub> HCl Concentration @12% CO <sub>2</sub> (ppmdv)	439.6873	355.9356	397.2034	397.6088
C <sub>w</sub> HCl Concentration (ppmwv)	341.7892	290.2680	303.2742	311.7771
C <sub>sd</sub> HCl Concentration (mg/dscm)	633.2215	524.7354	550.9812	569.6461
C <sub>sd7</sub> HCl Concentration @7% O <sub>2</sub> (mg/dscm)	682.3085	553.8210	615.1517	617.0937
C <sub>sd12</sub> HCl Concentration @12% CO <sub>2</sub> (mg/dscm)	665.9648	539.1118	601.6174	602.2313
C <sub>sd</sub> HCl Concentration (mg/Nm <sup>3</sup> dry)	679.5548	563.1307	591.2969	611.3275
C <sub>sd7</sub> HCl Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	732.2335	594.3445	660.1628	662.2469
C <sub>sd12</sub> HCl Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	714.6939	578.5590	645.6381	646.2970
E <sub>Fd</sub> HCl Rate - Fd-based (lb/MMBtu)	0.6131	0.4976	0.5528	0.5545
E <sub>Fc</sub> HCl Rate - Fc-based (lb/MMBtu)	0.6307	0.5106	0.5698	0.5704

041509 102856  
 LLL@. @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**EPA Modified Method 26A (HCl)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:44	08:22	09:50	
Stop Time (approx.)	07:44	09:22	10:50	
<b>Sampling Conditions</b>				
Y <sub>d</sub> Dry gas meter correction factor	0.9886	0.9886	0.9886	
P <sub>g</sub> Static pressure (in. H <sub>2</sub> O)	-10.4000	-10.4000	-10.5000	
A <sub>s</sub> Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub> Barometric pressure (in. Hg)	30.20	30.20	30.20	<b>30.2000</b>
O <sub>2</sub> Oxygen (dry volume %)	9.2000	8.9700	9.5000	<b>9.2233</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.4000	10.5500	10.0700	<b>10.3400</b>
N <sub>2</sub> +CO Nitrogen plus carbon monoxide (dry volume %)	80.4000	80.4800	80.4300	<b>80.4367</b>
V <sub>lc</sub> Total Liquid collected (ml)	248.40	228.20	213.90	
V <sub>m</sub> Volume metered, meter conditions (ft <sup>3</sup> )	40.6800	40.4500	40.3900	
T <sub>m</sub> Dry gas meter temperature (°F)	81.4583	86.5833	89.8750	
T <sub>s</sub> Sample temperature (°F)	304.0833	306.6667	305.5833	<b>305.4444</b>
ΔH Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.5000	1.5000	1.5000	
θ Total sampling time (min)	60.0	60.0	60.0	
<b>Flow Results</b>				
V <sub>wstd</sub> Volume of water collected (ft <sup>3</sup> )	11.6897	10.7391	10.0661	<b>10.8316</b>
V <sub>mstd</sub> Volume metered, standard (dscf)	39.7123	39.1175	38.8257	<b>39.2185</b>
P <sub>s</sub> Sample gas pressure, absolute (in. Hg)	29.4353	29.4353	29.4279	<b>29.4328</b>
P <sub>v</sub> Vapor pressure, actual (in. Hg)	29.4353	29.4353	29.4279	<b>29.4328</b>
B <sub>wo</sub> Moisture measured in sample (% by volume)	22.7417	21.5399	20.5886	<b>21.6234</b>
B <sub>ws</sub> Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	22.7417	21.5399	20.5886	<b>21.6234</b>
M <sub>d</sub> MW of sample gas, dry (lb/lb-mole)	30.0320	30.0468	29.9912	<b>30.0233</b>
M <sub>s</sub> MW of sample gas, wet (lb/lb-mole)	27.2957	27.4519	27.5224	<b>27.4233</b>

Comments:

Average includes 3 runs.

041509 102856  
 QLP@



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

### EPA Modified Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 16	Mar 16	Mar 16	
Start Time (approx.)		06:44	08:22	09:50	
Stop Time (approx.)		07:44	09:22	10:50	
<b>Process Conditions</b>					
R <sub>P</sub>	Steam Production Rate (Klbs/hour)	184.7	184.7	183.5	<b>184.3</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	320	320	320	<b>320</b>
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	<b>9,570</b>
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	<b>1,820</b>
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	<b>8,760</b>
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.2000	8.9700	9.5000	<b>9.2233</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.4000	10.5500	10.0700	<b>10.3400</b>
T <sub>s</sub>	Sample temperature (°F)	304.0833	306.6667	305.5833	<b>305.4444</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	22.7417	21.5399	20.5886	<b>21.6234</b>
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	39.7123	39.1175	38.8257	<b>39.2185</b>
<b>Laboratory Data</b>					
m <sub>n</sub>	Total HCl collected (mg)	17.6057	20.2666	24.8532	
<b>Hydrogen Chloride (HCl) Results</b>					
C <sub>sd</sub>	HCl Concentration (lb/dscf)	9.7755E-07	1.1424E-06	1.4115E-06	<b>1.1771E-06</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (lb/dscf)	1.1614E-06	1.3310E-06	1.7210E-06	<b>1.4045E-06</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (lb/dscf)	1.1279E-06	1.2994E-06	1.6820E-06	<b>1.3698E-06</b>
C <sub>sd</sub>	HCl Concentration (ppmdv)	10.3352	12.0781	14.9229	<b>12.4454</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (ppmdv)	12.2786	14.0726	18.1955	<b>14.8489</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (ppmdv)	11.9252	13.7381	17.7830	<b>14.4821</b>
C <sub>w</sub>	HCl Concentration (ppmwv)	7.9848	9.4765	11.8505	<b>9.7706</b>
C <sub>sd</sub>	HCl Concentration (mg/dscm)	15.6540	18.2939	22.6027	<b>18.8502</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/dscm)	18.5975	21.3148	27.5595	<b>22.4906</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/dscm)	18.0624	20.8082	26.9347	<b>21.9351</b>
C <sub>sd</sub>	HCl Concentration (mg/Nm <sup>3</sup> dry)	16.7995	19.6325	24.2566	<b>20.2295</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	19.9583	22.8744	29.5760	<b>24.1363</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	19.3840	22.3308	28.9056	<b>23.5401</b>
E <sub>Fd</sub>	HCl Rate - Fd-based (lb/MMBtu)	0.0167	0.0192	0.0248	<b>0.0202</b>
E <sub>Fc</sub>	HCl Rate - Fc-based (lb/MMBtu)	0.0171	0.0197	0.0255	<b>0.0208</b>

041509 102856  
 QLP@. @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 SDA Inlet

### USEPA Method 29 (Mercury) Sampling, Velocity and Moisture Parameters

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:58	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	
<b>Sampling Conditions</b>				
Y <sub>d</sub>	1.0079	1.0079	1.0079	
C <sub>p</sub>	0.8200	0.8200	0.8200	
P <sub>g</sub>	-1.9000	-1.7000	-1.8000	
A <sub>s</sub>	60.1320	60.1320	60.1320	
P <sub>bar</sub>	30.20	30.20	30.20	<b>30.2000</b>
D <sub>n</sub>	0.2750	0.2750	0.2750	
O <sub>2</sub>	8.8300	9.2100	8.9800	<b>9.0067</b>
CO <sub>2</sub>	10.7300	10.4900	10.7700	<b>10.6633</b>
N <sub>2</sub> +CO	80.4400	80.3000	80.2500	<b>80.3300</b>
V <sub>lc</sub>	289.70	297.10	299.80	
V <sub>m</sub>	73.9160	75.0900	75.0900	
T <sub>m</sub>	87.6250	96.7083	91.5417	
T <sub>s</sub>	513.1250	513.6250	513.9583	<b>513.5694</b>
ΔH	1.2142	1.2083	1.2079	
θ	120.0	120.0	120.0	
<b>Flow Results</b>				
V <sub>wstd</sub>	13.6333	13.9815	14.1086	<b>13.9078</b>
V <sub>mstd</sub>	72.6876	72.6362	73.3166	<b>72.8801</b>
P <sub>g</sub>	30.0603	30.0750	30.0676	<b>30.0676</b>
P <sub>v</sub>	30.0603	30.0750	30.0676	<b>30.0676</b>
B <sub>wo</sub>	15.7937	16.1416	16.1379	<b>16.0244</b>
B <sub>wa</sub>	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub>	15.7937	16.1416	16.1379	<b>16.0244</b>
√ΔP	0.6954	0.6912	0.6883	<b>0.6916</b>
M <sub>d</sub>	30.0700	30.0468	30.0824	<b>30.0664</b>
M <sub>s</sub>	28.1637	28.1022	28.1326	<b>28.1328</b>
V <sub>s</sub>	52.2654	52.0035	51.7720	<b>52.0136</b>
%I	102.0785	102.9480	104.4336	<b>103.1534</b>
Q <sub>a</sub>	188,570	187,625	186,789	<b>187,661</b>
Q <sub>s</sub>	102,794	102,277	101,761	<b>102,277</b>
Q <sub>std</sub>	86,559	85,767	85,339	<b>85,889</b>
Q <sub>std7</sub>	75,163	72,131	73,183	<b>73,492</b>
Q <sub>a</sub>	11,314,177	11,257,482	11,207,359	<b>11,259,673</b>
Q <sub>s</sub>	6,167,652	6,136,596	6,105,689	<b>6,136,646</b>
Q <sub>std</sub>	5,193,550	5,146,048	5,120,359	<b>5,153,319</b>
Q <sub>a</sub>	320,424	318,819	317,399	<b>318,881</b>
Q <sub>s</sub>	174,672	173,792	172,917	<b>173,793</b>
Q <sub>std</sub>	147,084	145,739	145,012	<b>145,945</b>
Q <sub>std7</sub>	127,720	122,568	124,355	<b>124,881</b>
Q <sub>a</sub>	162,762	161,943	161,127	<b>161,944</b>
Q <sub>std</sub>	137,056	135,802	135,124	<b>135,994</b>
Q <sub>std7</sub>	119,012	114,211	115,876	<b>116,366</b>

**Comments:**

Average includes 3 runs.

041509 122455  
 P Q K @

**USEPA Method 29  
 Mercury (Hg) Emission Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 16	Mar 16	Mar 16	
Start Time (approx.)		06:58	09:58	12:45	
Stop Time (approx.)		09:20	12:09	14:59	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.1	184.9	183.9	184.3
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P <sub>2</sub>	Carbon Feed rate (lb/hr)	5	7	6	6
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,780
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	8.8300	9.2100	8.9800	9.0067
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.7300	10.4900	10.7700	10.6633
T <sub>s</sub>	Sample temperature (°F)	513.1250	513.6250	513.9583	513.5694
B <sub>w</sub>	Actual water vapor in gas (% by volume)	15.7937	16.1416	16.1379	16.0244
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	188,570	187,625	186,789	187,661
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	102,794	102,277	101,761	102,277
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	86,559	85,767	85,339	85,889
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	75,163	72,131	73,183	73,492
Q <sub>a</sub>	Volumetric flow rate, actual (actf/hr)	11,314,177	11,257,482	11,207,359	11,259,673
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	6,167,652	6,136,596	6,105,689	6,136,846
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,193,550	5,146,048	5,120,359	5,153,319
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	320,424	318,819	317,399	318,881
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	174,672	173,792	172,917	173,793
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	147,084	145,739	145,012	145,945
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	127,720	122,568	124,355	124,881
Q <sub>a</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	162,762	161,943	161,127	161,944
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	137,056	135,802	135,124	135,994
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	119,012	114,211	115,876	116,366
<b>Sampling Data</b>					
V <sub>matd</sub>	Volume metered, standard (dscf)	72.6876	72.6362	73.3166	72.8801
%I	Isokinetic sampling (%)	102.0785	102.9480	104.4336	103.1534
<b>Laboratory Data</b>					
m <sub>n-1b</sub>	Fraction 1B (µg)	54.8752	57.1172	50.7188	
m <sub>n-2b</sub>	Fraction 2B (µg)	7.4834	22.2673	5.7219	
m <sub>n-3a</sub>	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m <sub>n-3b</sub>	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m <sub>n-3c</sub>	Fraction 3C (µg)	<0.4000	2.1075	0.5629	
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	62.3587	81.4920	57.0036	
<b>Mercury Results - Total</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	1.8917E-09	2.4738E-09	1.7144E-09	2.0266E-09
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	2.1785E-09	2.9415E-09	1.9992E-09	2.3730E-09
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	2.1156E-09	2.8299E-09	1.9102E-09	2.2852E-09
C <sub>a</sub>	Concentration (lb/acf)	8.6833E-10	1.1308E-09	7.8326E-10	9.2748E-10
C <sub>sd</sub>	Concentration (µg/dscm)	3.0292E+01	3.9615E+01	2.7453E+01	3.2454E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	3.4885E+01	4.7104E+01	3.2014E+01	3.8001E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	3.3878E+01	4.5317E+01	3.0589E+01	3.6595E+01
C <sub>sd</sub>	Concentration (mg/dscm)	3.0292E-02	3.9615E-02	2.7453E-02	3.2454E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	3.4885E-02	4.7104E-02	3.2014E-02	3.8001E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	3.3878E-02	4.5317E-02	3.0589E-02	3.6595E-02
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.3905E+01	1.8109E+01	1.2543E+01	1.4852E+01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	3.2509E+01	4.2514E+01	2.9462E+01	3.4828E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	3.7438E+01	5.0551E+01	3.4356E+01	4.0782E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	3.6357E+01	4.8633E+01	3.2827E+01	3.9272E+01
E <sub>lb/hr</sub>	Rate (lb/hr)	9.8245E-03	1.2730E-02	8.7783E-03	1.0444E-02
E <sub>g/s</sub>	Rate (g/s)	1.2377E-03	1.6037E-03	1.1059E-03	1.3157E-03
E <sub>T/yr</sub>	Rate (Ton/yr)	4.3031E-02	5.5759E-02	3.8449E-02	4.5747E-02
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	3.1347E-05	4.2327E-05	2.8767E-05	3.4147E-05
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	3.2086E-05	4.2921E-05	2.8971E-05	3.4659E-05

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Front Half Results**

Run No.		1	2	3	Average
Date (2009)		Mar 16	Mar 16	Mar 16	
Start Time (approx.)		06:58	09:58	12:45	
Stop Time (approx.)		09:20	12:09	14:59	
<b>Mercury Results - Front Half</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	1.6647E-09	1.7339E-09	1.5254E-09	1.6413E-09
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	1.9170E-09	2.0617E-09	1.7787E-09	1.9192E-09
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	1.8617E-09	1.9835E-09	1.6996E-09	1.8482E-09
C <sub>a</sub>	Concentration (lb/acf)	7.6413E-10	7.9260E-10	6.9690E-10	7.5121E-10
C <sub>sd</sub>	Concentration (µg/dscm)	2.6657E+01	2.7766E+01	2.4427E+01	2.6283E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	3.0699E+01	3.3015E+01	2.8484E+01	3.0733E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	2.9812E+01	3.1763E+01	2.7216E+01	2.9597E+01
C <sub>sd</sub>	Concentration (mg/dscm)	2.6657E-02	2.7766E-02	2.4427E-02	2.6283E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	3.0699E-02	3.3015E-02	2.8484E-02	3.0733E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	2.9812E-02	3.1763E-02	2.7216E-02	2.9597E-02
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.2236E+01	1.2692E+01	1.1160E+01	1.2030E+01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	2.8608E+01	2.9798E+01	2.6214E+01	2.8206E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	3.2945E+01	3.5431E+01	3.0568E+01	3.2981E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	3.1994E+01	3.4087E+01	2.9208E+01	3.1763E+01
E <sub>lb/hr</sub>	Rate (lb/hr)	8.6455E-03	8.9227E-03	7.8104E-03	8.4595E-03
E <sub>g/s</sub>	Rate (g/s)	1.0891E-03	1.1240E-03	9.8393E-04	1.0657E-03
E <sub>T/yr</sub>	Rate (Ton/yr)	3.7867E-02	3.9081E-02	3.4210E-02	3.7053E-02
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	2.7585E-05	2.9666E-05	2.5595E-05	2.7816E-05
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	2.8236E-05	3.0083E-05	2.5777E-05	2.8032E-05
E <sub>Hi</sub>	Rate - Heat input-based (lb/MMBtu)	N/A	N/A	N/A	
E <sub>Rp</sub>	Rate - Production-based (lb/xxxx)	4.6961E-05	4.8257E-05	4.2471E-05	4.5896E-05
E <sub>Rp</sub>	Rate - Production-based (g/xxxx)	2.1297E-02	2.1885E-02	1.9261E-02	2.0815E-02

041509 122455  
 P O K 0\_3

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:58	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	
<b>Mercury Results - Impingers 1-3 Solution</b>				
C <sub>sd</sub> Concentration (lb/dscf)	2.2701E-10	6.7596E-10	1.7209E-10	<b>3.5835E-10</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	2.6143E-10	8.0376E-10	2.0067E-10	<b>4.2195E-10</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	2.5388E-10	7.7327E-10	1.9174E-10	<b>4.0630E-10</b>
C <sub>a</sub> Concentration (lb/acf)	1.0421E-10	3.0900E-10	7.8622E-11	<b>1.6394E-10</b>
C <sub>ed</sub> Concentration (µg/dscm)	3.6353E+00	1.0825E+01	2.7557E+00	<b>5.7385E+00</b>
C <sub>ed7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	4.1865E+00	1.2871E+01	3.2135E+00	<b>6.7570E+00</b>
C <sub>ed12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	4.0656E+00	1.2383E+01	3.0704E+00	<b>6.5063E+00</b>
C <sub>sd</sub> Concentration (mg/dscm)	3.6353E-03	1.0825E-02	2.7557E-03	<b>5.7385E-03</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	4.1865E-03	1.2871E-02	3.2135E-03	<b>6.7570E-03</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	4.0656E-03	1.2383E-02	3.0704E-03	<b>6.5063E-03</b>
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	1.6687E+00	4.9482E+00	1.2590E+00	<b>2.6253E+00</b>
C <sub>ed</sub> Concentration (µg/Nm <sup>3</sup> dry)	3.9013E+00	1.1617E+01	2.9574E+00	<b>6.1584E+00</b>
C <sub>ed7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.4928E+00	1.3813E+01	3.4486E+00	<b>7.2514E+00</b>
C <sub>ed12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.3630E+00	1.3289E+01	3.2951E+00	<b>6.9823E+00</b>
E <sub>lb/hr</sub> Rate (lb/hr)	1.1790E-03	3.4785E-03	8.8115E-04	<b>1.8462E-03</b>
E <sub>g/s</sub> Rate (g/s)	1.4853E-04	4.3821E-04	1.1100E-04	<b>2.3258E-04</b>
E <sub>T/yr</sub> Rate (Ton/yr)	5.1640E-03	1.5236E-02	3.8594E-03	<b>8.0865E-03</b>
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	3.7618E-06	1.1566E-05	2.8875E-06	<b>6.0717E-06</b>
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	3.8505E-06	1.1728E-05	2.9081E-06	<b>6.1622E-06</b>
E <sub>Hi</sub> Rate - Heat Input-based (lb/MMBtu)	N/A	N/A	N/A	
E <sub>Rp</sub> Rate - Production-based (lb/xxxxx)	6.4041E-06	1.8813E-05	4.7914E-06	<b>1.0003E-05</b>
E <sub>Rp</sub> Rate - Production-based (g/xxxxx)	2.9044E-03	8.5320E-03	2.1730E-03	<b>4.5365E-03</b>

041908 122455  
 P O K @ \_ 5

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 4 Results**

Run No.		1	2	3	Average
Date (2009)		Mar 16	Mar 16	Mar 16	
Start Time (approx.)		06:58	09:58	12:45	
Stop Time (approx.)		09:20	12:09	14:59	
<b>Mercury Results - Impinger 4 Solution</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	<6.0671E-12	<6.0714E-12	<6.0150E-12	<6.0511E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<6.9869E-12	<7.2191E-12	<7.0141E-12	<7.0734E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<6.7852E-12	<6.9453E-12	<6.7020E-12	<6.8108E-12
C <sub>a</sub>	Concentration (lb/acf)	<2.7850E-12	<2.7754E-12	<2.7481E-12	<2.7695E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<9.7156E-02	<9.7224E-02	<9.6322E-02	<9.6901E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<1.1189E-01	<1.1560E-01	<1.1232E-01	<1.1327E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<1.0865E-01	<1.1122E-01	<1.0732E-01	<1.0907E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<9.7156E-05	<9.7224E-05	<9.6322E-05	<9.6901E-05
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<1.1189E-04	<1.1560E-04	<1.1232E-04	<1.1327E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<1.0865E-04	<1.1122E-04	<1.0732E-04	<1.0907E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<4.4597E-02	<4.4443E-02	<4.4007E-02	<4.4349E-02
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<1.0426E-01	<1.0434E-01	<1.0337E-01	<1.0399E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2007E-01	<1.2406E-01	<1.2054E-01	<1.2156E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.1661E-01	<1.1936E-01	<1.1518E-01	<1.1705E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<3.1510E-05	<3.1243E-05	<3.0799E-05	<3.1184E-05
E <sub>g/s</sub>	Rate (g/s)	<3.9685E-06	<3.9359E-06	<3.8799E-06	<3.9284E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<1.3801E-04	<1.3685E-04	<1.3490E-04	<1.3659E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<1.0054E-07	<1.0388E-07	<1.0093E-07	<1.0178E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<1.0291E-07	<1.0534E-07	<1.0165E-07	<1.0330E-07
E <sub>Hi</sub>	Rate - Heat Input-based (lb/MMBtu)	N/A	N/A	N/A	
E <sub>Rp</sub>	Rate - Production-based (lb/xxxxx)	<1.7115E-07	<1.6897E-07	<1.6748E-07	<1.6920E-07
E <sub>Rp</sub>	Rate - Production-based (g/xxxxx)	<7.7621E-05	<7.6633E-05	<7.5953E-05	<7.6736E-05

041509 122455  
 P Q K 0.5

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average	
Date (2009)	Mar 16	Mar 16	Mar 16		
Start Time (approx.)	06:58	09:58	12:45		
Stop Time (approx.)	09:20	12:09	14:59		
<b>Mercury Results - Filtered Permanganate Solution</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	<1.5168E-11	<1.5178E-11	<1.5038E-11	<1.5128E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.7467E-11	<1.8048E-11	<1.7535E-11	<1.7684E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.6963E-11	<1.7363E-11	<1.6755E-11	<1.7027E-11
C <sub>a</sub>	Concentration (lb/acf)	<6.9624E-12	<6.9384E-12	<6.8703E-12	<6.9237E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<2.4289E-01	<2.4306E-01	<2.4081E-01	<2.4225E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<2.7971E-01	<2.8901E-01	<2.8080E-01	<2.8318E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.7164E-01	<2.7805E-01	<2.6831E-01	<2.7266E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<2.4289E-04	<2.4306E-04	<2.4081E-04	<2.4225E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<2.7971E-04	<2.8901E-04	<2.8080E-04	<2.8318E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.7164E-04	<2.7805E-04	<2.6831E-04	<2.7266E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<1.1149E-01	<1.1111E-01	<1.1002E-01	<1.1087E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.6066E-01	<2.6085E-01	<2.5842E-01	<2.5998E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.0018E-01	<3.1016E-01	<3.0135E-01	<3.0390E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.9151E-01	<2.9839E-01	<2.8794E-01	<2.9262E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<7.8774E-05	<7.8109E-05	<7.6998E-05	<7.7960E-05
E <sub>g/s</sub>	Rate (g/s)	<9.9237E-06	<9.8398E-06	<9.6999E-06	<9.8211E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<3.4503E-04	<3.4212E-04	<3.3725E-04	<3.4147E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.5134E-07	<2.5970E-07	<2.5232E-07	<2.5446E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.5727E-07	<2.6334E-07	<2.5412E-07	<2.5824E-07
E <sub>Hi</sub>	Rate - Heat Input-based (lb/MMBtu)	N/A	N/A	N/A	
E <sub>Rp</sub>	Rate - Production-based (lb/xxxxx)	<4.2789E-07	<4.2244E-07	<4.1869E-07	<4.2301E-07
E <sub>Rp</sub>	Rate - Production-based (g/xxxxx)	<1.9405E-04	<1.9158E-04	<1.8988E-04	<1.9184E-04
<b>Mercury Results - HCl Rinse + HCl/MnO2 Precipitate</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	<1.2134E-11	6.3977E-11	1.6928E-11	<3.1013E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.3974E-11	7.6072E-11	1.9740E-11	<3.6595E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.3570E-11	7.3188E-11	1.8862E-11	<3.5206E-11
C <sub>a</sub>	Concentration (lb/acf)	<5.5699E-12	2.9245E-11	7.7341E-12	<1.4183E-11
C <sub>sd</sub>	Concentration (µg/dscm)	<1.9431E-01	1.0245E+00	2.7108E-01	<4.9663E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<2.2377E-01	1.2182E+00	3.1611E-01	<5.8602E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.1731E-01	1.1720E+00	3.0204E-01	<5.6378E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<1.9431E-04	1.0245E-03	2.7108E-04	<4.9663E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<2.2377E-04	1.2182E-03	3.1611E-04	<5.8602E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.1731E-04	1.1720E-03	3.0204E-04	<5.6378E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<8.9195E-02	4.6832E-01	1.2385E-01	<2.2712E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.0853E-01	1.0995E+00	2.9092E-01	<5.3297E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.4015E-01	1.3073E+00	3.3924E-01	<6.2890E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.3321E-01	1.2577E+00	3.2414E-01	<6.0503E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<6.3019E-05	3.2923E-04	8.6679E-05	<1.5964E-04
E <sub>g/s</sub>	Rate (g/s)	<7.9389E-06	4.1475E-05	1.0920E-05	<2.0111E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	<2.7602E-04	1.4420E-03	3.7965E-04	<6.9923E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.0108E-07	1.0946E-06	2.8405E-07	<5.2659E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.0582E-07	1.1100E-06	2.8607E-07	<5.3398E-07
E <sub>Hi</sub>	Rate - Heat Input-based (lb/MMBtu)	N/A	N/A	N/A	
E <sub>Rp</sub>	Rate - Production-based (lb/xxxxx)	<3.4231E-07	1.7806E-06	4.7134E-07	<8.6474E-07
E <sub>Rp</sub>	Rate - Production-based (g/xxxxx)	<1.5524E-04	8.0752E-04	2.1376E-04	<3.9217E-04

041509 122455  
 P Q X @ \_ S

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
 Sampling, Velocity and Moisture Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 16	Mar 16	Mar 16	
Start Time (approx.)		06:56	09:58	12:45	
Stop Time (approx.)		09:20	12:09	14:59	
<b>Sampling Conditions</b>					
Y <sub>d</sub>	Dry gas meter correction factor	0.9897	0.9897	0.9897	
C <sub>p</sub>	Pitot tube coefficient	0.8120	0.8120	0.8120	
P <sub>g</sub>	Static pressure (in. H <sub>2</sub> O)	-10.5000	-10.5000	-10.5000	
A <sub>s</sub>	Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub>	Barometric pressure (in. Hg)	30.20	30.20	30.20	<b>30.2000</b>
D <sub>n</sub>	Nozzle diameter (in.)	0.2680	0.2680	0.2680	
O <sub>2</sub>	Oxygen (dry volume %)	9.8800	9.8700	9.8300	<b>9.8600</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.6700	9.8300	9.9500	<b>9.8167</b>
N <sub>2</sub> +CO	Nitrogen plus carbon monoxide (dry volume %)	80.4500	80.3000	80.2200	<b>80.3233</b>
V <sub>lc</sub>	Total Liquid collected (ml)	428.30	405.10	430.50	
V <sub>m</sub>	Volume metered, meter conditions (ft <sup>3</sup> )	76.8700	75.6350	77.3000	
T <sub>m</sub>	Dry gas meter temperature (°F)	87.3400	87.5400	87.7800	
T <sub>s</sub>	Sample temperature (°F)	297.6800	297.4800	297.9200	<b>297.6933</b>
ΔH	Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.2640	1.2440	1.2720	
θ	Total sampling time (min)	125.0	125.0	125.0	
<b>Flow Results</b>					
V <sub>wstd</sub>	Volume of water collected (ft <sup>3</sup> )	20.1558	19.0640	20.2593	<b>19.8264</b>
V <sub>mstd</sub>	Volume metered, standard (dscf)	74.2751	73.0516	74.6320	<b>73.9862</b>
P <sub>s</sub>	Sample gas pressure, absolute (in. Hg)	29.4279	29.4279	29.4279	<b>29.4279</b>
P <sub>v</sub>	Vapor pressure, actual (in. Hg)	29.4279	29.4279	29.4279	<b>29.4279</b>
B <sub>wo</sub>	Moisture measured in sample (% by volume)	21.3445	20.6957	21.3500	<b>21.1301</b>
B <sub>ws</sub>	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.3445	20.6957	21.3500	<b>21.1301</b>
√ΔP	Velocity head (√in. H <sub>2</sub> O)	0.6920	0.6901	0.6977	<b>0.6933</b>
M <sub>d</sub>	MW of sample gas, dry (lb/lb-mole)	29.9424	29.9676	29.9852	<b>29.9651</b>
M <sub>s</sub>	MW of sample gas, wet (lb/lb-mole)	27.3934	27.4908	27.4264	<b>27.4368</b>
V <sub>s</sub>	Velocity of sample (ft/sec)	46.5718	46.3552	46.9362	<b>46.6211</b>
%I	Isokinetic sampling (%)	100.7493	98.7122	100.4864	<b>99.9826</b>
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	178,836	178,004	180,235	<b>179,025</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	122,575	122,037	123,495	<b>122,702</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	96,412	96,780	97,128	<b>96,773</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	76,436	76,798	77,353	<b>76,862</b>
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,730,142	10,680,234	10,814,095	<b>10,741,491</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,354,478	7,322,204	7,409,673	<b>7,362,118</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,784,702	5,806,819	5,827,706	<b>5,806,409</b>
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	303,884	302,471	306,262	<b>304,205</b>
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	208,283	207,369	209,846	<b>208,500</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	163,826	164,453	165,044	<b>164,441</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	129,882	130,497	131,442	<b>130,607</b>
Q <sub>s</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	194,082	193,230	195,539	<b>194,284</b>
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	152,656	153,240	153,791	<b>153,229</b>
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	121,027	121,600	122,480	<b>121,702</b>

**Comments:**

Average includes 3 runs.

D41509 122719  
 S O P @



**USEPA Method 5/29  
 Filterable Particulate Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:56	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hour)	184.1	184.9	183.9	<b>184.3</b>
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	315	<b>315</b>
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	<b>9,570</b>
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	<b>1,820</b>
Cap Capacity factor (hours/year)	8,760	8,760	8,760	<b>8,760</b>
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.8800	9.8700	9.8300	<b>9.8600</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.6700	9.8300	9.9500	<b>9.8167</b>
T <sub>s</sub> Sample temperature (°F)	297.6800	297.4800	297.9200	<b>297.6933</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.3445	20.6957	21.3500	<b>21.1301</b>
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	178,836	178,004	180,235	<b>179,025</b>
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	122,575	122,037	123,495	<b>122,702</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	96,412	96,780	97,128	<b>96,773</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	76,436	76,798	77,353	<b>76,862</b>
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	10,730,142	10,680,234	10,814,095	<b>10,741,491</b>
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,354,478	7,322,204	7,409,673	<b>7,362,118</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	5,784,702	5,806,819	5,827,706	<b>5,806,409</b>
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	303,884	302,471	306,262	<b>304,205</b>
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	208,283	207,369	209,846	<b>208,500</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	163,826	164,453	165,044	<b>164,441</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	129,882	130,497	131,442	<b>130,607</b>
Q <sub>s</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	194,082	193,230	195,539	<b>194,284</b>
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	152,656	153,240	153,791	<b>153,229</b>
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	121,027	121,600	122,480	<b>121,702</b>
<b>Sampling Data</b>				
V <sub>metd</sub> Volume metered, standard (dscf)	74.2751	73.0516	74.6320	<b>73.9862</b>
%I Isokinetic sampling (%)	100.7493	98.7122	100.4864	<b>99.9826</b>
<b>Laboratory Data</b>				
m <sub>filter</sub> Matter collected on filter(s) (g)	0.00060	0.00070	0.00070	
m <sub>s</sub> Matter collected in solvent rinse(s) (g)	0.00140	0.00030	0.00250	
m <sub>n</sub> Total particulate matter collected (g)	0.00200	0.00100	0.00320	
<b>Filterable Particulate Results</b>				
C <sub>sd</sub> Particulate Concentration (lb/dscf)	5.9374E-08	3.0184E-08	9.4544E-08	<b>6.1367E-08</b>
C <sub>sd7</sub> Particulate Concentration @7% O <sub>2</sub> (lb/dscf)	7.4891E-08	3.8038E-08	1.1871E-07	<b>7.7214E-08</b>
C <sub>sd12</sub> Particulate Concentration @12% CO <sub>2</sub> (lb/dscf)	7.3680E-08	3.6847E-08	1.1402E-07	<b>7.4850E-08</b>
C <sub>a</sub> Particulate Concentration (lb/acf)	3.2009E-08	1.6411E-08	5.0950E-08	<b>3.3123E-08</b>
C <sub>sd</sub> Particulate Concentration (gr/dscf)	0.0004	0.0002	0.0007	<b>0.0004</b>
C <sub>sd7</sub> Particulate Concentration @7% O <sub>2</sub> (gr/dscf)	0.0005	0.0003	0.0008	<b>0.0005</b>
C <sub>sd12</sub> Particulate Concentration @12% CO <sub>2</sub> (gr/dscf)	0.0005	0.0003	0.0008	<b>0.0005</b>
C <sub>a</sub> Particulate Concentration (gr/acf)	0.0002	0.0001	0.0004	<b>0.0002</b>
C <sub>sd</sub> Particulate Concentration (mg/dscm)	0.9508	0.4834	1.5140	<b>0.9827</b>
C <sub>sd7</sub> Particulate Concentration @7% O <sub>2</sub> (mg/dscm)	1.1993	0.6091	1.9010	<b>1.2365</b>
C <sub>sd12</sub> Particulate Concentration @12% CO <sub>2</sub> (mg/dscm)	1.1799	0.5901	1.8259	<b>1.1986</b>
C <sub>a</sub> Particulate Concentration (mg/m <sup>3</sup> (actual,wet))	0.5126	0.2628	0.8159	<b>0.5304</b>
C <sub>sd</sub> Particulate Concentration (mg/Nm <sup>3</sup> dry)	1.0204	0.5187	1.6248	<b>1.0546</b>
C <sub>sd7</sub> Particulate Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	1.2870	0.6537	2.0401	<b>1.3270</b>
C <sub>sd12</sub> Particulate Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	1.2662	0.6332	1.9595	<b>1.2863</b>
E <sub>b/hr</sub> Particulate Rate (lb/hr)	0.3435	0.1753	0.5510	<b>0.3566</b>
E <sub>kg/hr</sub> Particulate Rate (kg/hr)	0.1558	0.0795	0.2499	<b>0.1617</b>
E <sub>T/yr</sub> Particulate Rate (Ton/yr)	1.5044	0.7677	2.4133	<b>1.5618</b>
E <sub>Fd</sub> Particulate Rate - F <sub>d</sub> -based (lb/MMBtu)	0.0011	0.0005	0.0017	<b>0.0011</b>
E <sub>Fc</sub> Particulate Rate - F <sub>c</sub> -based (lb/MMBtu)	0.0011	0.0006	0.0017	<b>0.0011</b>

**Comments:**

Average includes 3 runs.

041508 122719  
 SOP@\_N

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:56	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hour)	184.1	184.9	183.9	184.3
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	315	315
P <sub>2</sub> Carbon Feed rate (lb/hr)	5	7	6	6
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.8800	9.8700	9.8300	9.8600
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.6700	9.8300	9.9500	9.8167
T <sub>s</sub> Sample temperature (°F)	297.6800	297.4800	297.9200	297.6933
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.3445	20.6957	21.3500	21.1301
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	178,836	178,004	180,235	179,025
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	122,575	122,037	123,495	122,702
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	96,412	96,780	97,128	96,773
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	76,436	76,798	77,353	76,862
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	10,730,142	10,680,234	10,814,095	10,741,491
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,354,478	7,322,204	7,409,673	7,362,118
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	5,784,702	5,806,819	5,827,706	5,806,409
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	303,884	302,471	306,262	304,205
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	208,283	207,369	209,846	208,500
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	163,826	164,453	165,044	164,441
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	129,882	130,497	131,442	130,607
Q <sub>a</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	194,082	193,230	195,539	194,284
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	152,656	153,240	153,791	153,229
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	121,027	121,600	122,480	121,702
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	74.2751	73.0516	74.6320	73.9862
%I Isokinetic sampling (%)	100.7493	98.7122	100.4864	99.9826
<b>Laboratory Data</b>				
m <sub>n-1b</sub> Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	
m <sub>n-2b</sub> Fraction 2B (µg)	6.8700	6.5842	7.8493	
m <sub>n-3a</sub> Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m <sub>n-3b</sub> Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m <sub>n-3c</sub> Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	6.8700	6.5842	7.8493	
<b>Mercury Results - Total</b>				
C <sub>sd</sub> Concentration (lb/dscf)	2.0395E-10	1.9874E-10	2.3191E-10	2.1153E-10
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	2.5725E-10	2.5045E-10	2.9119E-10	2.6630E-10
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	2.5309E-10	2.4261E-10	2.7969E-10	2.5846E-10
C <sub>a</sub> Concentration (lb/acf)	1.0985E-10	1.0805E-10	1.2498E-10	1.1433E-10
C <sub>sd</sub> Concentration (µg/dscm)	3.2660E+00	3.1825E+00	3.7137E+00	3.3874E+00
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	4.1195E+00	4.0106E+00	4.6631E+00	4.2644E+00
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	4.0529E+00	3.8851E+00	4.4788E+00	4.1389E+00
C <sub>sd</sub> Concentration (mg/dscm)	3.2660E-03	3.1825E-03	3.7137E-03	3.3874E-03
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	4.1195E-03	4.0106E-03	4.6631E-03	4.2644E-03
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	4.0529E-03	3.8851E-03	4.4788E-03	4.1389E-03
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	1.7607E+00	1.7303E+00	2.0013E+00	1.8308E+00
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	3.5050E+00	3.4154E+00	3.9854E+00	3.6353E+00
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.4209E+00	4.3041E+00	5.0043E+00	4.5764E+00
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.3495E+00	4.1693E+00	4.8065E+00	4.4418E+00
E <sub>lb/hr</sub> Rate (lb/hr)	1.1798E-03	1.1540E-03	1.3515E-03	1.2284E-03
E <sub>g/s</sub> Rate (g/s)	1.4863E-04	1.4538E-04	1.7026E-04	1.5475E-04
E <sub>T/yr</sub> Rate (Ton/yr)	5.1675E-03	5.0547E-03	5.9195E-03	5.3806E-03
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	3.7017E-06	3.6038E-06	4.1901E-06	3.8319E-06
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	3.8386E-06	3.6796E-06	4.2419E-06	3.9200E-06

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Front Half Results**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:56	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	
<b>Mercury Results - Front Half</b>				
C <sub>sd</sub> Concentration (lb/dscf)	<2.9687E-12	<3.0184E-12	<2.9545E-12	<2.9805E-12
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	<3.7445E-12	<3.8038E-12	<3.7098E-12	<3.7527E-12
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	<3.6840E-12	<3.6847E-12	<3.5632E-12	<3.6440E-12
C <sub>a</sub> Concentration (lb/acf)	<1.6004E-12	<1.6411E-12	<1.5922E-12	<1.6112E-12
C <sub>sd</sub> Concentration (µg/dscm)	<4.7539E-02	<4.8336E-02	<4.7312E-02	<4.7729E-02
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	<5.9964E-02	<6.0913E-02	<5.9407E-02	<6.0095E-02
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	<5.8994E-02	<5.9006E-02	<5.7060E-02	<5.8353E-02
C <sub>sd</sub> Concentration (mg/dscm)	<4.7539E-05	<4.8336E-05	<4.7312E-05	<4.7729E-05
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	<5.9964E-05	<6.0913E-05	<5.9407E-05	<6.0095E-05
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	<5.8994E-05	<5.9006E-05	<5.7060E-05	<5.8353E-05
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	<2.5629E-02	<2.6280E-02	<2.5496E-02	<2.5802E-02
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	<5.1018E-02	<5.1872E-02	<5.0774E-02	<5.1221E-02
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<6.4351E-02	<6.5370E-02	<6.3754E-02	<6.4492E-02
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<6.3311E-02	<6.3323E-02	<6.1235E-02	<6.2623E-02
E <sub>lb/hr</sub> Rate (lb/hr)	<1.7173E-05	<1.7527E-05	<1.7218E-05	<1.7306E-05
E <sub>g/s</sub> Rate (g/s)	<2.1634E-06	<2.2080E-06	<2.1691E-06	<2.1802E-06
E <sub>T/yr</sub> Rate (Ton/yr)	<7.5218E-05	<7.6770E-05	<7.5415E-05	<7.5801E-05
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	<5.3882E-08	<5.4735E-08	<5.3382E-08	<5.3999E-08
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	<5.5874E-08	<5.5885E-08	<5.4042E-08	<5.5267E-08

041509 122719  
 S O P @ J

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:56	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	

**Mercury Results - Impingers 1-3 Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	2.0395E-10	1.9874E-10	2.3191E-10	2.1153E-10
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	2.5725E-10	2.5045E-10	2.9119E-10	2.6630E-10
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	2.5309E-10	2.4261E-10	2.7969E-10	2.5846E-10
C <sub>a</sub>	Concentration (lb/acf)	1.0995E-10	1.0805E-10	1.2498E-10	1.1433E-10
C <sub>sd</sub>	Concentration (µg/dscm)	3.2660E+00	3.1825E+00	3.7137E+00	3.3874E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	4.1195E+00	4.0106E+00	4.6631E+00	4.2844E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	4.0529E+00	3.8851E+00	4.4788E+00	4.1389E+00
C <sub>d</sub>	Concentration (mg/dscm)	3.2660E-03	3.1825E-03	3.7137E-03	3.3874E-03
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	4.1195E-03	4.0106E-03	4.6631E-03	4.2644E-03
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	4.0529E-03	3.8851E-03	4.4788E-03	4.1389E-03
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.7607E+00	1.7303E+00	2.0013E+00	1.8308E+00
C <sub>d</sub>	Concentration (µg/Nm <sup>3</sup> dry)	3.5050E+00	3.4154E+00	3.9854E+00	3.6353E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.4209E+00	4.3041E+00	5.0043E+00	4.5764E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.3495E+00	4.1693E+00	4.8065E+00	4.4418E+00
E <sub>lb/hr</sub>	Rate (lb/hr)	1.1798E-03	1.1540E-03	1.3515E-03	1.2284E-03
E <sub>g/s</sub>	Rate (g/s)	1.4863E-04	1.4538E-04	1.7026E-04	1.5475E-04
E <sub>T/yr</sub>	Rate (Ton/yr)	5.1675E-03	5.0547E-03	5.9195E-03	5.3806E-03
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	3.7017E-06	3.6038E-06	4.1901E-06	3.8319E-06
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	3.8386E-06	3.6796E-06	4.2419E-06	3.9200E-06

041509 122719  
 S O P B \_ J

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 4 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:58	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	
<b>Mercury Results - Impinger 4 Solution</b>				
C <sub>sd</sub> Concentration (lb/dscf)	<5.9374E-12	<6.0368E-12	<5.9090E-12	<b>&lt;5.9611E-12</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	<7.4891E-12	<7.6076E-12	<7.4196E-12	<b>&lt;7.5054E-12</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	<7.3680E-12	<7.3695E-12	<7.1264E-12	<b>&lt;7.2880E-12</b>
C <sub>a</sub> Concentration (lb/acf)	<3.2009E-12	<3.2822E-12	<3.1843E-12	<b>&lt;3.2225E-12</b>
C <sub>sd</sub> Concentration (µg/dscm)	<9.5079E-02	<9.6671E-02	<9.4624E-02	<b>&lt;9.5458E-02</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	<1.1993E-01	<1.2183E-01	<1.1881E-01	<b>&lt;1.2019E-01</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	<1.1799E-01	<1.1801E-01	<1.1412E-01	<b>&lt;1.1671E-01</b>
C <sub>sd</sub> Concentration (mg/dscm)	<9.5079E-05	<9.6671E-05	<9.4624E-05	<b>&lt;9.5458E-05</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	<1.1993E-04	<1.2183E-04	<1.1881E-04	<b>&lt;1.2019E-04</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	<1.1799E-04	<1.1801E-04	<1.1412E-04	<b>&lt;1.1671E-04</b>
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	<5.1258E-02	<5.2560E-02	<5.0993E-02	<b>&lt;5.1604E-02</b>
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	<1.0204E-01	<1.0374E-01	<1.0155E-01	<b>&lt;1.0244E-01</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2870E-01	<1.3074E-01	<1.2751E-01	<b>&lt;1.2898E-01</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2662E-01	<1.2665E-01	<1.2247E-01	<b>&lt;1.2525E-01</b>
E <sub>lb/hr</sub> Rate (lb/hr)	<3.4346E-05	<3.5055E-05	<3.4436E-05	<b>&lt;3.4612E-05</b>
E <sub>g/s</sub> Rate (g/s)	<4.3268E-06	<4.4161E-06	<4.3381E-06	<b>&lt;4.3603E-06</b>
E <sub>T/yr</sub> Rate (Ton/yr)	<1.5044E-04	<1.5354E-04	<1.5083E-04	<b>&lt;1.5160E-04</b>
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	<1.0776E-07	<1.0947E-07	<1.0676E-07	<b>&lt;1.0800E-07</b>
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	<1.1175E-07	<1.1177E-07	<1.0808E-07	<b>&lt;1.1053E-07</b>

041909 122719  
 S O P @\_J

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:56	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	

**Mercury Results - Filtered Permanganate Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	<1.4843E-11	<1.5092E-11	<1.4772E-11	<1.4903E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.8723E-11	<1.9019E-11	<1.8549E-11	<1.8764E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.8420E-11	<1.8424E-11	<1.7816E-11	<1.8220E-11
C <sub>a</sub>	Concentration (lb/acf)	<8.0022E-12	<8.2055E-12	<7.9609E-12	<8.0562E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<2.3770E-01	<2.4168E-01	<2.3656E-01	<2.3865E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<2.9982E-01	<3.0456E-01	<2.9704E-01	<3.0047E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.9497E-01	<2.9503E-01	<2.8530E-01	<2.9177E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<2.3770E-04	<2.4168E-04	<2.3656E-04	<2.3865E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<2.9982E-04	<3.0456E-04	<2.9704E-04	<3.0047E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.9497E-04	<2.9503E-04	<2.8530E-04	<2.9177E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<1.2814E-01	<1.3140E-01	<1.2748E-01	<1.2901E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.5509E-01	<2.5936E-01	<2.5387E-01	<2.5611E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.2176E-01	<3.2685E-01	<3.1877E-01	<3.2246E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.1655E-01	<3.1662E-01	<3.0617E-01	<3.1312E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<8.5865E-05	<8.7637E-05	<8.6090E-05	<8.6531E-05
E <sub>g/s</sub>	Rate (g/s)	<1.0817E-05	<1.1040E-05	<1.0845E-05	<1.0901E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	<3.7609E-04	<3.8385E-04	<3.7707E-04	<3.7900E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.6941E-07	<2.7367E-07	<2.6691E-07	<2.7000E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.7937E-07	<2.7943E-07	<2.7021E-07	<2.7634E-07

**Mercury Results - HCl Rinse + HCl/MnO2 Precipitate**

C <sub>sd</sub>	Concentration (lb/dscf)	<1.1875E-11	<1.2074E-11	<1.1818E-11	<1.1922E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.4978E-11	<1.5215E-11	<1.4839E-11	<1.5011E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.4738E-11	<1.4739E-11	<1.4253E-11	<1.4576E-11
C <sub>a</sub>	Concentration (lb/acf)	<6.4018E-12	<6.5644E-12	<6.3687E-12	<6.4450E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<1.9016E-01	<1.9334E-01	<1.8925E-01	<1.9092E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<2.3985E-01	<2.4365E-01	<2.3763E-01	<2.4038E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.3598E-01	<2.3602E-01	<2.2824E-01	<2.3341E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<1.9016E-04	<1.9334E-04	<1.8925E-04	<1.9092E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<2.3985E-04	<2.4365E-04	<2.3763E-04	<2.4038E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.3598E-04	<2.3602E-04	<2.2824E-04	<2.3341E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<1.0252E-01	<1.0512E-01	<1.0199E-01	<1.0321E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.0407E-01	<2.0749E-01	<2.0310E-01	<2.0489E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.5740E-01	<2.6148E-01	<2.5502E-01	<2.5797E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.5324E-01	<2.5329E-01	<2.4494E-01	<2.5049E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<6.8692E-05	<7.0110E-05	<6.8872E-05	<6.9224E-05
E <sub>g/s</sub>	Rate (g/s)	<8.6536E-06	<8.8321E-06	<8.6762E-06	<8.7206E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<3.0087E-04	<3.0708E-04	<3.0166E-04	<3.0320E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.1553E-07	<2.1894E-07	<2.1353E-07	<2.1600E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.2350E-07	<2.2354E-07	<2.1617E-07	<2.2107E-07

041509 122719  
 S O P @ J

**USEPA Method 5/29  
 Beryllium (Be) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:56	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hour)	184.1	184.9	183.9	184.3
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	315	315
P <sub>2</sub> Carbon Feed rate (lb/hr)	5	7	6	6
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.8800	9.8700	9.8300	9.8600
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.6700	9.8300	9.9500	9.8167
T <sub>s</sub> Sample temperature (°F)	297.6800	297.4800	297.9200	297.6933
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.3445	20.6957	21.3500	21.1301
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	178,836	178,004	180,235	179,025
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	122,575	122,037	123,495	122,702
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	96,412	96,780	97,128	96,773
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	76,436	76,798	77,353	76,862
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	10,730,142	10,680,234	10,814,095	10,741,491
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,354,478	7,322,204	7,409,673	7,362,118
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	5,784,702	5,806,819	5,827,706	5,806,409
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	303,884	302,471	306,262	304,205
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	208,283	207,369	209,846	208,500
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	163,826	164,453	165,044	164,441
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	129,882	130,497	131,442	130,607
Q <sub>n</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	194,082	193,230	195,539	194,284
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	152,656	153,240	153,791	153,229
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	121,027	121,600	122,480	121,702
<b>Sampling Data</b>				
V <sub>std</sub> Volume metered, standard (dscf)	74.2751	73.0516	74.6320	73.9862
%I Isokinetic sampling (%)	100.7493	98.7122	100.4864	99.9826
<b>Laboratory Data</b>				
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
<b>Beryllium Results - Total</b>				
C <sub>sd</sub> Concentration (lb/dscf)	<1.4843E-12	<1.5092E-12	<1.4772E-12	<1.4903E-12
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	<1.8723E-12	<1.9019E-12	<1.8549E-12	<1.8764E-12
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.8420E-12	<1.8424E-12	<1.7816E-12	<1.8220E-12
C <sub>a</sub> Concentration (lb/acf)	<8.0022E-13	<8.2055E-13	<7.9609E-13	<8.0562E-13
C <sub>sd</sub> Concentration (µg/dscm)	<2.3770E-02	<2.4168E-02	<2.3656E-02	<2.3865E-02
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	<2.9982E-02	<3.0456E-02	<2.9704E-02	<3.0047E-02
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.9497E-02	<2.9503E-02	<2.8530E-02	<2.9177E-02
C <sub>sd</sub> Concentration (mg/dscm)	<2.3770E-05	<2.4168E-05	<2.3656E-05	<2.3865E-05
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	<2.9982E-05	<3.0456E-05	<2.9704E-05	<3.0047E-05
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.9497E-05	<2.9503E-05	<2.8530E-05	<2.9177E-05
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	<1.2814E-02	<1.3140E-02	<1.2748E-02	<1.2901E-02
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	<2.5509E-02	<2.5936E-02	<2.5387E-02	<2.5611E-02
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.2176E-02	<3.2685E-02	<3.1877E-02	<3.2246E-02
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.1655E-02	<3.1662E-02	<3.0617E-02	<3.1312E-02
E <sub>lb/hr</sub> Rate (lb/hr)	<8.5865E-06	<8.7637E-06	<8.6090E-06	<8.6531E-06
E <sub>g/s</sub> Rate (g/s)	<1.0817E-06	<1.1040E-06	<1.0845E-06	<1.0901E-06
E <sub>T/yr</sub> Rate (Ton/yr)	<3.7609E-05	<3.8385E-05	<3.7707E-05	<3.7900E-05
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	<2.6941E-08	<2.7367E-08	<2.6691E-08	<2.7000E-08
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	<2.7937E-08	<2.7943E-08	<2.7021E-08	<2.7634E-08

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 5/29  
 Cadmium (Cd) Emission Parameters**

Run No.	1	2	3	Average	
Date (2009)	Mar 16	Mar 16	Mar 16		
Start Time (approx.)	06:56	09:58	12:45		
Stop Time (approx.)	09:20	12:09	14:59		
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.1	184.9	183.9	184.3
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P <sub>2</sub>	Carbon Feed rate (lb/hr)	5	7	6	6
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.8800	9.8700	9.8300	9.8600
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.6700	9.8300	9.9500	9.8167
T <sub>s</sub>	Sample temperature (°F)	297.6800	297.4800	297.9200	297.6933
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.3445	20.6957	21.3500	21.1301
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	178,836	178,004	180,235	179,025
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	122,575	122,037	123,495	122,702
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	96,412	96,780	97,128	96,773
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	76,436	76,798	77,353	76,862
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	10,730,142	10,680,234	10,814,095	10,741,491
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,354,478	7,322,204	7,409,673	7,362,118
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,784,702	5,806,819	5,827,706	5,806,409
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	303,884	302,471	306,262	304,205
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	208,283	207,369	209,846	208,500
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	163,826	164,453	165,044	164,441
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	129,882	130,497	131,442	130,607
Q <sub>n</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	194,082	193,230	195,539	194,284
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	152,656	153,240	153,791	153,229
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	121,027	121,600	122,480	121,702
<b>Sampling Data</b>					
V <sub>std</sub>	Volume metered, standard (dscf)	74.2751	73.0516	74.6320	73.9862
%i	Isokinetic sampling (%)	100.7493	98.7122	100.4864	99.9826
<b>Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	0.4125	0.3372	0.3416	
<b>Cadmium Results - Total</b>					
C <sub>std</sub>	Concentration (lb/dscf)	1.2246E-11	1.0179E-11	1.0093E-11	1.0839E-11
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	1.5446E-11	1.2827E-11	1.2673E-11	1.3649E-11
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	1.5197E-11	1.2426E-11	1.2172E-11	1.3265E-11
C <sub>a</sub>	Concentration (lb/acf)	6.6019E-12	5.5341E-12	5.4390E-12	5.8583E-12
C <sub>std</sub>	Concentration (µg/dscm)	1.9610E-01	1.6300E-01	1.6162E-01	1.7357E-01
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	2.4735E-01	2.0541E-01	2.0294E-01	2.1857E-01
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	2.4335E-01	1.9898E-01	1.9492E-01	2.1242E-01
C <sub>std</sub>	Concentration (mg/dscm)	1.9610E-04	1.6300E-04	1.6162E-04	1.7357E-04
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	2.4735E-04	2.0541E-04	2.0294E-04	2.1857E-04
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	2.4335E-04	1.9898E-04	1.9492E-04	2.1242E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual, wet))	1.0572E-01	8.8621E-02	8.7097E-02	9.3813E-02
C <sub>std</sub>	Concentration (µg/Nm <sup>3</sup> dry)	2.1045E-01	1.7492E-01	1.7345E-01	1.8627E-01
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.6545E-01	2.2044E-01	2.1779E-01	2.3456E-01
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	2.6116E-01	2.1354E-01	2.0918E-01	2.2796E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	7.0840E-05	5.9106E-05	5.8817E-05	6.2921E-05
E <sub>g/s</sub>	Rate (g/s)	8.9241E-06	7.4459E-06	7.4096E-06	7.9266E-06
E <sub>Tyr</sub>	Rate (Ton/yr)	3.1028E-04	2.5888E-04	2.5762E-04	2.7559E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	2.2227E-07	1.8458E-07	1.8236E-07	1.9640E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	2.3048E-07	1.8846E-07	1.8461E-07	2.0118E-07

041609 122718  
 SOP\_0



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 5/29  
 Lead (Pb) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	06:56	09:58	12:45	
Stop Time (approx.)	09:20	12:09	14:59	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hour)	184.1	184.9	183.9	<b>184.3</b>
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	315	<b>315</b>
P <sub>2</sub> Carbon Feed rate (lb/hr)	5	7	6	<b>6</b>
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	<b>9,570</b>
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	<b>1,820</b>
Cap Capacity factor (hours/year)	8,760	8,760	8,760	<b>8,760</b>
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.8800	9.8700	9.8300	<b>9.8600</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.6700	9.8300	9.9500	<b>9.8167</b>
T <sub>s</sub> Sample temperature (°F)	297.6800	297.4800	297.9200	<b>297.6933</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.3445	20.6957	21.3500	<b>21.1301</b>
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	178,836	178,004	180,235	<b>179,025</b>
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	122,575	122,037	123,495	<b>122,702</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	96,412	96,780	97,128	<b>96,773</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	76,436	76,798	77,353	<b>76,862</b>
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	10,730,142	10,680,234	10,814,095	<b>10,741,491</b>
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,354,478	7,322,204	7,409,673	<b>7,362,118</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	5,784,702	5,806,819	5,827,706	<b>5,806,409</b>
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	303,884	302,471	306,262	<b>304,205</b>
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	208,283	207,369	209,846	<b>208,500</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	163,826	164,453	165,044	<b>164,441</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	129,882	130,497	131,442	<b>130,607</b>
Q <sub>s</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	194,082	193,230	195,539	<b>194,284</b>
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	152,656	153,240	153,791	<b>153,229</b>
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	121,027	121,600	122,480	<b>121,702</b>
<b>Sampling Data</b>				
V <sub>std</sub> Volume metered, standard (dscf)	74.2751	73.0516	74.6320	<b>73.9862</b>
%I Isokinetic sampling (%)	100.7493	98.7122	100.4864	<b>99.9826</b>
<b>Laboratory Data</b>				
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	1.9770	2.3462	2.5954	
<b>Lead Results - Total</b>				
C <sub>std</sub> Concentration (lb/dscf)	5.8692E-11	7.0818E-11	7.6681E-11	<b>6.8730E-11</b>
C <sub>std7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	7.4031E-11	8.9245E-11	9.6284E-11	<b>8.6520E-11</b>
C <sub>std12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	7.2834E-11	8.6451E-11	9.2479E-11	<b>8.3922E-11</b>
C <sub>a</sub> Concentration (lb/acf)	3.1642E-11	3.8504E-11	4.1323E-11	<b>3.7156E-11</b>
C <sub>std</sub> Concentration (µg/dscm)	9.3988E-01	1.1340E+00	1.2279E+00	<b>1.1006E+00</b>
C <sub>std7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	1.1855E+00	1.4291E+00	1.5418E+00	<b>1.3855E+00</b>
C <sub>std12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	1.1663E+00	1.3844E+00	1.4809E+00	<b>1.3439E+00</b>
C <sub>std</sub> Concentration (mg/dscm)	9.3988E-04	1.1340E-03	1.2279E-03	<b>1.1006E-03</b>
C <sub>std7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	1.1855E-03	1.4291E-03	1.5418E-03	<b>1.3855E-03</b>
C <sub>std12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	1.1663E-03	1.3844E-03	1.4809E-03	<b>1.3439E-03</b>
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	5.0669E-01	6.1658E-01	6.6173E-01	<b>5.9500E-01</b>
C <sub>std</sub> Concentration (µg/Nm <sup>3</sup> dry)	1.0086E+00	1.2170E+00	1.3178E+00	<b>1.1812E+00</b>
C <sub>std7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.2723E+00	1.5337E+00	1.6547E+00	<b>1.4869E+00</b>
C <sub>std12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.2517E+00	1.4857E+00	1.5893E+00	<b>1.4422E+00</b>
E <sub>lb/hr</sub> Rate (lb/hr)	3.3952E-04	4.1123E-04	4.4687E-04	<b>3.9921E-04</b>
E <sub>g/s</sub> Rate (g/s)	4.2771E-05	5.1805E-05	5.6295E-05	<b>5.0290E-05</b>
E <sub>T/yr</sub> Rate (Ton/yr)	1.4871E-03	1.8012E-03	1.9573E-03	<b>1.7485E-03</b>
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	1.0653E-06	1.2842E-06	1.3855E-06	<b>1.2450E-06</b>
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	1.1047E-06	1.3112E-06	1.4026E-06	<b>1.2728E-06</b>

Prepared by Clean Air Engineering Inc.  
 SS Metals-1 Version 2006-12a

Copyright © 2006 Clean Air Engineering Inc.

QA/QC \_\_\_\_\_  
 Date \_\_\_\_\_

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 13B (Total Fluorides)  
 Sampling, Velocity and Moisture Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 17	Mar 17	Mar 17	
Start Time (approx.)		11:43	13:15	14:40	
Stop Time (approx.)		12:55	14:27	15:49	
<b>Sampling Conditions</b>					
Y <sub>d</sub>	Dry gas meter correction factor	1.0028	1.0028	1.0028	
C <sub>p</sub>	Pitot tube coefficient	0.8250	0.8250	0.8250	
P <sub>g</sub>	Static pressure (in. H <sub>2</sub> O)	-10.4000	-10.4000	-10.5000	
A <sub>s</sub>	Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub>	Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
D <sub>n</sub>	Nozzle diameter (in.)	0.2720	0.2720	0.2720	
O <sub>2</sub>	Oxygen (dry volume %)	9.5800	9.4500	9.3900	<b>9.4733</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.0900	10.2000	10.1800	<b>10.1567</b>
N <sub>2</sub> +CO	Nitrogen plus carbon monoxide (dry volume %)	80.3300	80.3500	80.4300	<b>80.3700</b>
V <sub>lc</sub>	Total Liquid collected (ml)	224.30	218.20	216.30	
V <sub>m</sub>	Volume metered, meter conditions (ft <sup>3</sup> )	42.1400	41.4600	41.2600	
T <sub>m</sub>	Dry gas meter temperature (°F)	87.6600	88.5400	84.8800	
T <sub>s</sub>	Sample temperature (°F)	301.0800	301.4800	301.8800	<b>301.4800</b>
ΔH	Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.4320	1.3640	1.3440	
θ	Total sampling time (min)	62.5	62.5	62.5	
<b>Flow Results</b>					
V <sub>wstd</sub>	Volume of water collected (ft <sup>3</sup> )	10.5556	10.2685	10.1791	<b>10.3344</b>
V <sub>mstd</sub>	Volume metered, standard (dscf)	41.1130	40.3780	40.4512	<b>40.6474</b>
P <sub>a</sub>	Sample gas pressure, absolute (in. Hg)	29.3353	29.3353	29.3279	<b>29.3328</b>
P <sub>v</sub>	Vapor pressure, actual (in. Hg)	29.3353	29.3353	29.3279	<b>29.3328</b>
B <sub>wo</sub>	Moisture measured in sample (% by volume)	20.4294	20.2748	20.1047	<b>20.2696</b>
B <sub>ws</sub>	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	20.4294	20.2748	20.1047	<b>20.2696</b>
√ΔP	Velocity head (√in. H <sub>2</sub> O)	0.7298	0.7027	0.7086	<b>0.7137</b>
M <sub>d</sub>	MW of sample gas, dry (lb/lb-mole)	29.9976	30.0100	30.0044	<b>30.0040</b>
M <sub>s</sub>	MW of sample gas, wet (lb/lb-mole)	27.5466	27.5750	27.5909	<b>27.5708</b>
V <sub>s</sub>	Velocity of sample (ft/sec)	49.9548	48.0885	48.4969	<b>48.8467</b>
%I	Isokinetic sampling (%)	100.5485	102.4385	101.6221	<b>101.5363</b>
Q <sub>o</sub>	Volumetric flow rate, actual (acfm)	191,827	184,660	186,228	<b>187,571</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	130,479	125,538	126,506	<b>127,508</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	103,823	100,086	101,073	<b>101,660</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	84,552	82,445	83,694	<b>83,564</b>
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	11,509,596	11,079,588	11,173,681	<b>11,254,288</b>
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,828,752	7,532,305	7,590,381	<b>7,650,480</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	6,229,389	6,005,143	6,064,356	<b>6,099,629</b>
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	325,959	313,780	316,445	<b>318,728</b>
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	221,715	213,319	214,964	<b>216,666</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	176,420	170,069	171,746	<b>172,745</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	143,674	140,093	142,216	<b>141,994</b>
Q <sub>a</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	206,598	198,775	200,307	<b>201,893</b>
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	164,391	158,474	160,036	<b>160,967</b>
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	133,878	130,541	132,519	<b>132,313</b>

**Comments:**

Average includes 3 runs.

042709 081220  
 N.M.L. @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 13B  
 HF Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	11:43	13:15	14:40	
Stop Time (approx.)	12:55	14:27	15:49	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hour)	185.1	184.7	183.9	184.6
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	320	320	320	320
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.5800	9.4500	9.3900	9.4733
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.0900	10.2000	10.1800	10.1567
T <sub>a</sub> Sample temperature (°F)	301.0800	301.4800	301.8800	301.4800
B <sub>w</sub> Actual water vapor in gas (% by volume)	20.4294	20.2748	20.1047	20.2696
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	191,827	184,660	186,228	187,571
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	130,479	125,538	126,506	127,508
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	103,823	100,086	101,073	101,660
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	84,552	82,445	83,694	83,564
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	11,509,596	11,079,588	11,173,681	11,254,288
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,828,752	7,532,305	7,590,381	7,650,480
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	6,229,389	6,005,143	6,064,356	6,099,629
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	325,959	313,780	316,445	318,728
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	221,715	213,319	214,964	216,666
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	176,420	170,069	171,746	172,745
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	143,674	140,093	142,216	141,994
Q <sub>s</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	206,598	198,775	200,307	201,893
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	164,391	158,474	160,036	160,967
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	133,878	130,541	132,519	132,313
<b>Sampling Data</b>				
V <sub>metd</sub> Volume metered, standard (dscf)	41.1130	40.3780	40.4512	40.6474
%I Isokinetic sampling (%)	100.5485	102.4385	101.6221	101.5363
<b>Laboratory Data</b>				
m <sub>n</sub> Total HF collected (mg)	<0.0060	<0.0058	<0.0056	
<b>Hydrogen Fluoride (HF) Results</b>				
C <sub>sd</sub> HF Concentration (lb/dscf)	<3.1988E-10	<3.1742E-10	<3.0307E-10	<3.1345E-10
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (lb/dscf)	<3.9278E-10	<3.8534E-10	<3.6600E-10	<3.8137E-10
C <sub>sd12</sub> HF Concentration @12% CO <sub>2</sub> (lb/dscf)	<3.8043E-10	<3.7343E-10	<3.5725E-10	<3.7037E-10
C <sub>a</sub> HF Concentration (lb/acf)	<1.7313E-10	<1.7204E-10	<1.6449E-10	<1.6988E-10
C <sub>sd</sub> HF Concentration (ppmdv)	<0.0062	<0.0061	<0.0058	<0.0060
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (ppmdv)	<0.0076	<0.0074	<0.0071	<0.0073
C <sub>sd12</sub> HF Concentration @12% CO <sub>2</sub> (ppmdv)	<0.0073	<0.0072	<0.0069	<0.0071
C <sub>w</sub> HF Concentration (ppmwv)	<0.0049	<0.0049	<0.0047	<0.0048
C <sub>sd</sub> HF Concentration (mg/dscm)	<0.0051	<0.0051	<0.0049	<0.0050
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (mg/dscm)	<0.0063	<0.0062	<0.0059	<0.0061
C <sub>sd12</sub> HF Concentration @12% CO <sub>2</sub> (mg/dscm)	<0.0061	<0.0060	<0.0057	<0.0059
C <sub>a</sub> HF Concentration (mg/m <sup>3</sup> actual,wet)	<0.0028	<0.0028	<0.0026	<0.0027
C <sub>sd</sub> HF Concentration (mg/Nm <sup>3</sup> dry)	<0.0055	<0.0055	<0.0052	<0.0054
C <sub>sd7</sub> HF Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	<0.0068	<0.0066	<0.0063	<0.0066
C <sub>sd12</sub> HF Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	<0.0065	<0.0064	<0.0061	<0.0064
E <sub>lb/hr</sub> HF Rate (lb/hr)	<0.0020	<0.0019	<0.0018	<0.0019
E <sub>kg/hr</sub> HF Rate (kg/hr)	<0.0009	<0.0009	<0.0008	<0.0009
E <sub>T/yr</sub> HF Rate (Ton/yr)	<0.0087	<0.0083	<0.0081	<0.0084
E <sub>Fd</sub> HF Rate - Fd-based (lb/MMBtu)	<0.0000057	<0.0000055	<0.0000053	<0.0000055
E <sub>Fc</sub> HF Rate - Fc-based (lb/MMBtu)	<0.0000058	<0.0000057	<0.0000054	<0.0000056

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 SDA Inlet

**USEPA Method 26A (HCI)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	08:26	10:15	
Stop Time (approx.)	07:33	09:26	11:15	
<b>Sampling Conditions</b>				
$Y_d$ Dry gas meter correction factor	1.0079	1.0079	1.0079	
$P_g$ Static pressure (in. H <sub>2</sub> O)	-1.7000	-1.7000	-1.7000	
$A_s$ Sample location area (ft <sup>2</sup> )	60.1320	60.1320	60.1320	
$P_{bar}$ Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
$O_2$ Oxygen (dry volume %)	8.3200	8.3000	8.5600	<b>8.3933</b>
$CO_2$ Carbon dioxide (dry volume %)	11.2500	11.3100	10.9100	<b>11.1567</b>
$N_2+CO$ Nitrogen plus carbon monoxide (dry volume %)	80.4300	80.3900	80.5300	<b>80.4500</b>
$V_{lc}$ Total Liquid collected (ml)	137.40	143.70	135.40	
$V_m$ Volume metered, meter conditions (ft <sup>3</sup> )	32.9500	34.2700	36.1500	
$T_m$ Dry gas meter temperature (°F)	78.7500	94.1250	101.7500	
$T_s$ Sample temperature (°F)	505.8333	505.9167	518.3333	<b>510.0278</b>
$\Delta H$ Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.0158	1.0908	1.1467	
$\theta$ Total sampling time (min)	60.0	60.0	60.0	
<b>Flow Results</b>				
$V_{wstd}$ Volume of water collected (ft <sup>3</sup> )	6.4660	6.7625	6.3719	<b>6.5335</b>
$V_{mstd}$ Volume metered, standard (dscf)	32.8116	33.1852	34.5352	<b>33.5107</b>
$P_s$ Sample gas pressure, absolute (in. Hg)	29.9750	29.9750	29.9750	<b>29.9750</b>
$P_v$ Vapor pressure, actual (in. Hg)	29.9750	29.9750	29.9750	<b>29.9750</b>
$B_{wo}$ Moisture measured in sample (% by volume)	16.4624	16.9284	15.5765	<b>16.3225</b>
$B_{ws}$ Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
$B_w$ Actual water vapor in gas (% by volume)	16.4624	16.9284	15.5765	<b>16.3225</b>
$M_d$ MW of sample gas, dry (lb/lb-mole)	30.1328	30.1416	30.0880	<b>30.1208</b>
$M_s$ MW of sample gas, wet (lb/lb-mole)	28.1354	28.0862	28.2051	<b>28.1423</b>

Comments:

Average includes 3 runs.

041509 123416  
 K P M @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 SDA Inlet

**USEPA Method 26A  
 HCl Parameters**

Run No.		1	2	3	Average
Date (2009)		Mar 17	Mar 17	Mar 17	
Start Time (approx.)		06:33	08:26	10:15	
Stop Time (approx.)		07:33	09:26	11:15	
<b>Process Conditions</b>					
R <sub>P</sub>	Steam Production Rate (Klbs/hour)	182.6	185.2	183.2	183.7
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	320	317
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	8.3200	8.3000	8.5600	8.3933
CO <sub>2</sub>	Carbon dioxide (dry volume %)	11.2500	11.3100	10.9100	11.1567
T <sub>s</sub>	Sample temperature (°F)	505.8333	505.9167	518.3333	510.0278
B <sub>w</sub>	Actual water vapor in gas (% by volume)	16.4624	16.9284	15.5765	16.3225
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	32.8116	33.1852	34.5352	33.5107
<b>Laboratory Data</b>					
m <sub>n</sub>	Total HCl collected (mg)	503.5662	598.0783	603.5410	
<b>Hydrogen Chloride (HCl) Results</b>					
C <sub>sd</sub>	HCl Concentration (lb/dscf)	3.3841E-05	3.9739E-05	3.8535E-05	3.7372E-05
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (lb/dscf)	3.7391E-05	4.3840E-05	4.3406E-05	4.1546E-05
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (lb/dscf)	3.6097E-05	4.2164E-05	4.2385E-05	4.0215E-05
C <sub>sd</sub>	HCl Concentration (ppmdv)	357.7832	420.1494	407.4127	395.1151
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (ppmdv)	395.3248	463.4982	458.9170	439.2467
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (ppmdv)	381.6354	445.7819	448.1166	425.1779
C <sub>w</sub>	HCl Concentration (ppmwv)	298.8834	349.0247	343.9519	330.6200
C <sub>sd</sub>	HCl Concentration (mg/dscm)	541.9101	636.3721	617.0806	598.4543
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/dscm)	598.7719	702.0295	695.0908	665.2974
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/dscm)	578.0375	675.1958	678.7321	643.9885
C <sub>sd</sub>	HCl Concentration (mg/Nm <sup>3</sup> dry)	581.5621	682.9359	662.2329	642.2436
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	642.5845	753.3975	745.9511	713.9777
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	620.3329	724.6004	728.3955	691.1096
E <sub>Fd</sub>	HCl Rate - Fd-based (lb/MMBtu)	0.5380	0.6308	0.6246	0.5978
E <sub>Fc</sub>	HCl Rate - Fc-based (lb/MMBtu)	0.5475	0.6395	0.6428	0.6099

041509 123416  
 K P M @ \_ @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**EPA Modified Method 26A (HCl)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	08:26	10:15	
Stop Time (approx.)	07:33	09:26	11:15	
<b>Sampling Conditions</b>				
Y <sub>d</sub> Dry gas meter correction factor	0.9897	0.9897	0.9897	
P <sub>g</sub> Static pressure (in. H <sub>2</sub> O)	-10.5000	-10.4000	-10.5000	
A <sub>s</sub> Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub> Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
O <sub>2</sub> Oxygen (dry volume %)	9.7300	9.1000	9.4600	<b>9.4300</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.0000	10.6000	10.6000	<b>10.4000</b>
N <sub>2</sub> +CO Nitrogen plus carbon monoxide (dry volume %)	80.2700	80.3000	79.9400	<b>80.1700</b>
V <sub>lc</sub> Total Liquid collected (ml)	192.40	198.80	199.10	
V <sub>m</sub> Volume metered, meter conditions (ft <sup>3</sup> )	36.7800	36.4800	38.1300	
T <sub>m</sub> Dry gas meter temperature (°F)	80.9583	100.1250	92.4583	
T <sub>s</sub> Sample temperature (°F)	295.4167	296.3333	299.0000	<b>296.9167</b>
ΔH Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.2083	1.1750	1.3500	
θ Total sampling time (min)	60.0	60.0	60.0	
<b>Flow Results</b>				
V <sub>wstd</sub> Volume of water collected (ft <sup>3</sup> )	9.0543	9.3555	9.3696	<b>9.2598</b>
V <sub>mstd</sub> Volume metered, standard (dscf)	35.8341	34.3228	36.3886	<b>35.5152</b>
P <sub>s</sub> Sample gas pressure, absolute (in. Hg)	29.3279	29.3353	29.3279	<b>29.3304</b>
P <sub>v</sub> Vapor pressure, actual (in. Hg)	29.3279	29.3353	29.3279	<b>29.3304</b>
B <sub>wc</sub> Moisture measured in sample (% by volume)	20.1708	21.4191	20.4764	<b>20.6888</b>
B <sub>ws</sub> Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	20.1708	21.4191	20.4764	<b>20.6888</b>
M <sub>d</sub> MW of sample gas, dry (lb/lb-mole)	29.9892	30.0600	30.0744	<b>30.0412</b>
M <sub>s</sub> MW of sample gas, wet (lb/lb-mole)	27.5709	27.4769	27.6020	<b>27.5499</b>
V <sub>s</sub> Velocity of sample (ft/sec)	45.0147	44.2434	47.4550	<b>45.5710</b>

Comments:

Average includes 3 runs.

041509 123416  
 I M O @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

### EPA Modified Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 17	Mar 17	Mar 17	
Start Time (approx.)		06:33	08:26	10:15	
Stop Time (approx.)		07:33	09:26	11:15	
<b>Process Conditions</b>					
R <sub>P</sub>	Steam Production Rate (Klbs/hour)	182.6	185.2	183.2	183.7
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	320	317
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.7300	9.1000	9.4600	9.4300
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.0000	10.6000	10.6000	10.4000
T <sub>s</sub>	Sample temperature (°F)	295.4167	296.3333	299.0000	296.9167
B <sub>w</sub>	Actual water vapor in gas (% by volume)	20.1708	21.4191	20.4764	20.6888
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	35.8341	34.3228	36.3886	35.5152
<b>Laboratory Data</b>					
m <sub>n</sub>	Total HCl collected (mg)	29.5404	25.8516	34.0382	
<b>Hydrogen Chloride (HCl) Results</b>					
C <sub>sd</sub>	HCl Concentration (lb/dscf)	1.8177E-06	1.6608E-06	2.0626E-06	1.8470E-06
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (lb/dscf)	2.2620E-06	1.9563E-06	2.5061E-06	2.2415E-06
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (lb/dscf)	2.1813E-06	1.8801E-06	2.3350E-06	2.1321E-06
C <sub>a</sub>	HCl Concentration (lb/acf)	9.9416E-07	8.9326E-07	1.1185E-06	1.0020E-06
C <sub>sd</sub>	HCl Concentration (ppmdv)	19.2181	17.5588	21.8068	19.5279
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (ppmdv)	23.9150	20.6837	26.4960	23.6982
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (ppmdv)	23.0617	19.8779	24.6869	22.5421
C <sub>w</sub>	HCl Concentration (ppmwv)	15.3416	13.7979	17.3415	15.4937
C <sub>sd</sub>	HCl Concentration (mg/dscm)	29.1083	26.5951	33.0292	29.5776
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/dscm)	36.2225	31.3282	40.1317	35.8941
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/dscm)	34.9300	30.1077	37.3916	34.1431
C <sub>a</sub>	HCl Concentration (mg/m <sup>3</sup> (actual,wet))	15.9201	14.3044	17.9105	16.0450
C <sub>sd</sub>	HCl Concentration (mg/Nm <sup>3</sup> dry)	31.2382	28.5411	35.4460	31.7418
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	38.8729	33.6205	43.0681	38.5205
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	37.4858	32.3107	40.1275	36.6414
E <sub>Fd</sub>	HCl Rate - Fd-based (lb/MMBtu)	0.0325	0.0282	0.0361	0.0323
E <sub>Fc</sub>	HCl Rate - Fc-based (lb/MMBtu)	0.0331	0.0285	0.0354	0.0323

041509 123416  
 I M O @ \_ @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 SDA Inlet

### USEPA Method 29 (Mercury) Sampling, Velocity and Moisture Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 17	Mar 17	Mar 17	
Start Time (approx.)		06:33	09:15	11:56	
Stop Time (approx.)		08:42	11:24	14:07	
<b>Sampling Conditions</b>					
Y <sub>d</sub>	Dry gas meter correction factor	0.9992	0.9992	0.9992	
C <sub>p</sub>	Pitot tube coefficient	0.8200	0.8200	0.8200	
P <sub>g</sub>	Static pressure (in. H <sub>2</sub> O)	-1.8000	-1.7000	-1.7000	
A <sub>s</sub>	Sample location area (ft <sup>2</sup> )	60.1320	60.1320	60.1320	
P <sub>bar</sub>	Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
D <sub>n</sub>	Nozzle diameter (in.)	0.2750	0.2750	0.2750	
O <sub>2</sub>	Oxygen (dry volume %)	9.5700	9.4900	9.5500	<b>9.5367</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	10.1500	10.0700	10.0000	<b>10.0733</b>
N <sub>2</sub> +CO	Nitrogen plus carbon monoxide (dry volume %)	80.2800	80.4400	80.4500	<b>80.3900</b>
V <sub>lc</sub>	Total Liquid collected (ml)	305.90	290.90	286.90	
V <sub>m</sub>	Volume metered, meter conditions (ft <sup>3</sup> )	76.3500	75.9000	75.8600	
T <sub>m</sub>	Dry gas meter temperature (°F)	88.1042	102.0000	99.5208	
T <sub>s</sub>	Sample temperature (°F)	488.2917	490.0417	493.3333	<b>490.5556</b>
ΔH	Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.3121	1.2600	1.2625	
θ	Total sampling time (min)	120.0	120.0	120.0	
<b>Flow Results</b>					
V <sub>wstd</sub>	Volume of water collected (ft <sup>3</sup> )	14.3957	13.6898	13.5015	<b>13.8623</b>
V <sub>mstd</sub>	Volume metered, standard (dscf)	74.1401	71.8717	72.1525	<b>72.7214</b>
P <sub>s</sub>	Sample gas pressure, absolute (in. Hg)	29.9676	29.9750	29.9750	<b>29.9725</b>
P <sub>v</sub>	Vapor pressure, actual (in. Hg)	29.9676	29.9750	29.9750	<b>29.9725</b>
B <sub>w0</sub>	Moisture measured in sample (% by volume)	16.2597	15.9999	15.7628	<b>16.0075</b>
B <sub>ws</sub>	Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	16.2597	15.9999	15.7628	<b>16.0075</b>
√ΔP	Velocity head (√in. H <sub>2</sub> O)	0.7306	0.7176	0.7092	<b>0.7191</b>
M <sub>d</sub>	MW of sample gas, dry (lb/lb-mole)	30.0068	29.9908	29.9820	<b>29.9932</b>
M <sub>s</sub>	MW of sample gas, wet (lb/lb-mole)	28.0545	28.0723	28.0933	<b>28.0734</b>
V <sub>s</sub>	Velocity of sample (ft/sec)	54.3914	53.4527	52.8961	<b>53.5801</b>
%i	Isokinetic sampling (%)	98.3413	96.8610	98.3258	<b>97.8427</b>
Q <sub>sa</sub>	Volumetric flow rate, actual (acfm)	196,240	192,853	190,845	<b>193,313</b>
Q <sub>ss</sub>	Volumetric flow rate, standard (scfm)	109,439	107,378	105,893	<b>107,570</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	91,644	90,198	89,201	<b>90,348</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,700	74,040	72,837	<b>73,859</b>
Q <sub>sa</sub>	Volumetric flow rate, actual (acf/hr)	11,774,391	11,571,203	11,450,703	<b>11,598,766</b>
Q <sub>ss</sub>	Volumetric flow rate, standard (scf/hr)	6,566,312	6,442,692	6,353,586	<b>6,454,197</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	5,498,649	5,411,867	5,352,079	<b>5,420,865</b>
Q <sub>sa</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	333,458	327,703	324,291	<b>328,484</b>
Q <sub>ss</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	185,962	182,461	179,937	<b>182,787</b>
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	155,725	153,267	151,574	<b>153,522</b>
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,933	125,811	123,767	<b>125,504</b>
Q <sub>sa</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	173,283	170,020	167,669	<b>170,324</b>
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	145,107	142,817	141,239	<b>143,055</b>
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	118,278	117,233	115,329	<b>116,947</b>

**Comments:**

Average includes 3 runs.

041509 123608  
 M J N ®



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hour)	184.0	184.0	184.1	184.0
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	315	315
P <sub>2</sub> Carbon Feed rate (lb/hr)	6	6	5	6
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	9.5700	9.4900	9.5500	9.5367
CO <sub>2</sub> Carbon dioxide (dry volume %)	10.1500	10.0700	10.0000	10.0733
T <sub>s</sub> Sample temperature (°F)	488.2917	490.0417	493.3333	490.5556
B <sub>w</sub> Actual water vapor in gas (% by volume)	16.2597	15.9999	15.7628	16.0075
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	196,240	192,853	190,845	193,313
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	109,439	107,378	105,893	107,570
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	91,644	90,198	89,201	90,348
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	74,700	74,040	72,837	73,859
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	11,774,391	11,571,203	11,450,703	11,598,766
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	6,566,312	6,442,892	6,353,586	6,454,197
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	5,498,649	5,411,867	5,352,079	5,420,865
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	333,458	327,703	324,291	328,484
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	185,962	182,461	179,937	182,787
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	155,725	153,267	151,574	153,522
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	126,933	125,811	123,767	125,504
Q <sub>n</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	173,283	170,020	167,669	170,324
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	145,107	142,817	141,239	143,055
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	118,278	117,233	115,329	116,947
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	74.1401	71.8717	72.1525	72.7214
%I Isokinetic sampling (%)	98.3413	96.8610	98.3258	97.8427
<b>Laboratory Data</b>				
m <sub>n-1b</sub> Fraction 1B (µg)	51.7021	62.7160	78.8613	
m <sub>n-2b</sub> Fraction 2B (µg)	23.1328	26.8916	14.6764	
m <sub>n-3a</sub> Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m <sub>n-3b</sub> Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m <sub>n-3c</sub> Fraction 3C (µg)	1.8885	<0.4000	1.5492	
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	76.7234	89.6076	95.0869	
<b>Mercury Results - Total</b>				
C <sub>sd</sub> Concentration (lb/dscf)	2.2818E-09	2.7491E-09	2.9059E-09	2.6456E-09
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	2.7994E-09	3.3491E-09	3.5587E-09	3.2357E-09
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	2.6977E-09	3.2760E-09	3.4871E-09	3.1536E-09
C <sub>a</sub> Concentration (lb/acf)	1.0656E-09	1.2858E-09	1.3582E-09	1.2365E-09
C <sub>sd</sub> Concentration (µg/dscm)	3.6540E+01	4.4024E+01	4.6534E+01	4.2366E+01
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	4.4829E+01	5.3631E+01	5.6988E+01	5.1816E+01
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	4.3200E+01	5.2461E+01	5.5840E+01	5.0501E+01
C <sub>sd</sub> Concentration (mg/dscm)	3.6540E-02	4.4024E-02	4.6534E-02	4.2366E-02
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	4.4829E-02	5.3631E-02	5.6988E-02	5.1816E-02
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	4.3200E-02	5.2461E-02	5.5840E-02	5.0501E-02
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	1.7064E+01	2.0590E+01	2.1750E+01	1.9801E+01
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	3.9214E+01	4.7245E+01	4.9939E+01	4.5466E+01
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.8109E+01	5.7555E+01	6.1158E+01	5.5607E+01
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.6361E+01	5.6300E+01	5.9926E+01	5.4196E+01
E <sub>lb/hr</sub> Rate (lb/hr)	1.2547E-02	1.4878E-02	1.5553E-02	1.4326E-02
E <sub>g/s</sub> Rate (g/s)	1.5806E-03	1.8743E-03	1.8929E-03	1.8047E-03
E <sub>T/yr</sub> Rate (Ton/yr)	5.4956E-02	6.5165E-02	6.8120E-02	6.2747E-02
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	4.0282E-05	4.8191E-05	5.1208E-05	4.6561E-05
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	4.0916E-05	4.9686E-05	5.2887E-05	4.7830E-05

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Front Half Results**

Run No.		1	2	3	Average
Date (2009)		Mar 17	Mar 17	Mar 17	
Start Time (approx.)		06:33	09:15	11:56	
Stop Time (approx.)		08:42	11:24	14:07	
<b>Mercury Results - Front Half</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	1.5377E-09	1.9241E-09	2.4100E-09	1.9573E-09
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	1.8865E-09	2.3440E-09	2.9515E-09	2.3940E-09
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	1.8179E-09	2.2929E-09	2.8920E-09	2.3343E-09
C <sub>a</sub>	Concentration (lb/acf)	7.1809E-10	8.9991E-10	1.1264E-09	9.1482E-10
C <sub>sd</sub>	Concentration (µg/dscm)	2.4624E+01	3.0812E+01	3.8593E+01	3.1343E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	3.0209E+01	3.7536E+01	4.7264E+01	3.8338E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	2.9112E+01	3.6717E+01	4.6312E+01	3.7380E+01
C <sub>sd</sub>	Concentration (mg/dscm)	2.4624E-02	3.0812E-02	3.8593E-02	3.1343E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	3.0209E-02	3.7536E-02	4.7264E-02	3.8338E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	2.9112E-02	3.6717E-02	4.6312E-02	3.7380E-02
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.1499E+01	1.4411E+01	1.8038E+01	1.4650E+01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	2.6425E+01	3.3066E+01	4.1417E+01	3.3636E+01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	3.2419E+01	4.0282E+01	5.0722E+01	4.1141E+01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	3.1242E+01	3.9404E+01	4.9700E+01	4.0115E+01
E <sub>lb/hr</sub>	Rate (lb/hr)	8.4551E-03	1.0413E-02	1.2899E-02	1.0589E-02
E <sub>g/s</sub>	Rate (g/s)	1.0651E-03	1.3118E-03	1.6249E-03	1.3340E-03
E <sub>T/yr</sub>	Rate (Ton/yr)	3.7033E-02	4.5609E-02	5.6496E-02	4.6379E-02
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	2.7145E-05	3.3729E-05	4.2470E-05	3.4448E-05
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	2.7572E-05	3.4775E-05	4.3862E-05	3.5403E-05

041509 123808  
 M J N @ J N

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	
<b>Mercury Results - Impingers 1-3 Solution</b>				
C <sub>sd</sub> Concentration (lb/dscf)	6.8799E-10	8.2503E-10	4.4851E-10	<b>6.5384E-10</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	8.4405E-10	1.0051E-09	5.4928E-10	<b>7.9947E-10</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	8.1339E-10	9.8315E-10	5.3822E-10	<b>7.7825E-10</b>
C <sub>a</sub> Concentration (lb/acf)	3.2129E-10	3.8587E-10	2.0864E-10	<b>3.0560E-10</b>
C <sub>sd</sub> Concentration (µg/dscm)	1.1017E+01	1.3212E+01	7.1823E+00	<b>1.0470E+01</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	1.3516E+01	1.6095E+01	8.7960E+00	<b>1.2802E+01</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	1.3025E+01	1.5744E+01	8.6188E+00	<b>1.2463E+01</b>
C <sub>sd</sub> Concentration (mg/dscm)	1.1017E-02	1.3212E-02	7.1823E-03	<b>1.0470E-02</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	1.3516E-02	1.6095E-02	8.7960E-03	<b>1.2802E-02</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	1.3025E-02	1.5744E-02	8.6188E-03	<b>1.2463E-02</b>
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	5.1451E+00	6.1791E+00	3.3570E+00	<b>4.8937E+00</b>
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	1.1823E+01	1.4178E+01	7.7079E+00	<b>1.1237E+01</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.4505E+01	1.7272E+01	9.4396E+00	<b>1.3739E+01</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.3978E+01	1.6896E+01	9.2495E+00	<b>1.3375E+01</b>
E <sub>lb/hr</sub> Rate (lb/hr)	3.7830E-03	4.4649E-03	2.4005E-03	<b>3.5495E-03</b>
E <sub>g/s</sub> Rate (g/s)	4.7657E-04	5.6248E-04	3.0240E-04	<b>4.4715E-04</b>
E <sub>T/yr</sub> Rate (Ton/yr)	1.6570E-02	1.9556E-02	1.0514E-02	<b>1.5547E-02</b>
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	1.2145E-05	1.4462E-05	7.9039E-06	<b>1.1504E-05</b>
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	1.2336E-05	1.4911E-05	8.1630E-06	<b>1.1804E-05</b>

041509 123608  
 M J N @ \_ N

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 SDA Inlet

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 4 Results**

Run No.		1	2	3	Average
Date (2009)		Mar 17	Mar 17	Mar 17	
Start Time (approx.)		06:33	09:15	11:56	
Stop Time (approx.)		08:42	11:24	14:07	
<b>Mercury Results - Impinger 4 Solution</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	<5.0482E-12	<6.1359E-12	<6.1121E-12	<6.0654E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<7.2974E-12	<7.4750E-12	<7.4852E-12	<7.4192E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<7.0324E-12	<7.3119E-12	<7.3345E-12	<7.2263E-12
C <sub>a</sub>	Concentration (lb/acf)	<2.7778E-12	<2.8698E-12	<2.8568E-12	<2.8348E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<9.5252E-02	<9.8258E-02	<9.7876E-02	<9.7129E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<1.1686E-01	<1.1970E-01	<1.1987E-01	<1.1881E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<1.1261E-01	<1.1709E-01	<1.1745E-01	<1.1572E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<9.5252E-05	<9.8258E-05	<9.7876E-05	<9.7129E-05
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<1.1686E-04	<1.1970E-04	<1.1987E-04	<1.1881E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<1.1261E-04	<1.1709E-04	<1.1745E-04	<1.1572E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<4.4483E-02	<4.5956E-02	<4.5747E-02	<4.5395E-02
C <sub>d</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<1.0222E-01	<1.0545E-01	<1.0504E-01	<1.0424E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2541E-01	<1.2846E-01	<1.2864E-01	<1.2750E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2085E-01	<1.2566E-01	<1.2605E-01	<1.2419E-01
E <sub>10/hr</sub>	Rate (lb/hr)	<3.2707E-05	<3.3207E-05	<3.2712E-05	<3.2875E-05
E <sub>g/s</sub>	Rate (g/s)	<4.1203E-06	<4.1833E-06	<4.1210E-06	<4.1415E-06
E <sub>17/yr</sub>	Rate (Ton/yr)	<1.4326E-04	<1.4545E-04	<1.4328E-04	<1.4399E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<1.0501E-07	<1.0756E-07	<1.0771E-07	<1.0676E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<1.0666E-07	<1.1090E-07	<1.1124E-07	<1.0960E-07

041509 123808  
 M.J.N.@.N

**USEPA Method 29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	

**Mercury Results - Filtered Permanganate Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	<1.4870E-11	<1.5340E-11	<1.5280E-11	<1.5163E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.8244E-11	<1.8687E-11	<1.8713E-11	<1.8548E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.7581E-11	<1.8280E-11	<1.8336E-11	<1.8066E-11
C <sub>a</sub>	Concentration (lb/acf)	<6.9445E-12	<7.1745E-12	<7.1420E-12	<7.0870E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<2.3813E-01	<2.4565E-01	<2.4469E-01	<2.4282E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<2.9215E-01	<2.9925E-01	<2.9966E-01	<2.9702E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.8153E-01	<2.9273E-01	<2.9363E-01	<2.8930E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<2.3813E-04	<2.4565E-04	<2.4469E-04	<2.4282E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<2.9215E-04	<2.9925E-04	<2.9966E-04	<2.9702E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.8153E-04	<2.9273E-04	<2.9363E-04	<2.8930E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<1.1121E-01	<1.1489E-01	<1.1437E-01	<1.1349E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.5555E-01	<2.6362E-01	<2.6259E-01	<2.6059E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.1352E-01	<3.2115E-01	<3.2159E-01	<3.1875E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.0213E-01	<3.1415E-01	<3.1511E-01	<3.1046E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<8.1768E-05	<8.3017E-05	<8.1780E-05	<8.2188E-05
E <sub>g/s</sub>	Rate (g/s)	<1.0301E-05	<1.0458E-05	<1.0302E-05	<1.0354E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	<3.5814E-04	<3.6362E-04	<3.5820E-04	<3.5999E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.6251E-07	<2.6890E-07	<2.6927E-07	<2.6690E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.6664E-07	<2.7724E-07	<2.7810E-07	<2.7400E-07

**Mercury Results - HCl Rinse + HCl/MnO2 Precipitate**

C <sub>sd</sub>	Concentration (lb/dscf)	5.6165E-11	<1.2272E-11	4.7345E-11	<3.8594E-11
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	6.8905E-11	<1.4950E-11	5.7982E-11	<4.7279E-11
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	6.6402E-11	<1.4624E-11	5.6814E-11	<4.5947E-11
C <sub>a</sub>	Concentration (lb/acf)	2.6229E-11	<5.7396E-12	2.2129E-11	<1.8033E-11
C <sub>sd</sub>	Concentration (µg/dscm)	8.9941E-01	<1.9652E-01	7.5817E-01	<6.1803E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	1.1034E+00	<2.3940E-01	9.2850E-01	<7.5711E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	1.0633E+00	<2.3418E-01	9.0980E-01	<7.3577E-01
C <sub>sd</sub>	Concentration (mg/dscm)	8.9941E-04	<1.9652E-04	7.5817E-04	<6.1803E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	1.1034E-03	<2.3940E-04	9.2850E-04	<7.5711E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	1.0633E-03	<2.3418E-04	9.0980E-04	<7.3577E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	4.2002E-01	<9.1911E-02	3.5437E-01	<2.8877E-01
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	9.6522E-01	<2.1090E-01	8.1364E-01	<6.6325E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.1842E+00	<2.5692E-01	9.9644E-01	<8.1251E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	1.1411E+00	<2.5132E-01	9.7637E-01	<7.8961E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	3.0883E-04	<6.6414E-05	2.5339E-04	<2.0955E-04
E <sub>g/s</sub>	Rate (g/s)	3.8906E-05	<8.3666E-06	3.1922E-05	<2.6398E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	1.3527E-03	<2.9089E-04	1.1099E-03	<9.1782E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	9.9151E-07	<2.1512E-07	8.3433E-07	<6.8032E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	1.0071E-06	<2.2180E-07	8.6168E-07	<6.9686E-07

041509 123508  
 M.J.N @.N

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

### USEPA Method 5/29 (Particulate/Metals) Sampling, Velocity and Moisture Parameters

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	
<b>Sampling Conditions</b>				
Y <sub>d</sub> Dry gas meter correction factor	0.9937	0.9937	0.9937	
C <sub>p</sub> Pitot tube coefficient	0.8120	0.8120	0.8120	
P <sub>g</sub> Static pressure (in. H <sub>2</sub> O)	-12.0000	-12.0000	-12.0000	
A <sub>s</sub> Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub> Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
D <sub>n</sub> Nozzle diameter (in.)	0.2680	0.2680	0.2680	
O <sub>2</sub> Oxygen (dry volume %)	10.6500	10.3500	10.3200	<b>10.4400</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.1000	9.2000	9.4200	<b>9.2400</b>
N <sub>2</sub> +CO Nitrogen plus carbon monoxide (dry volume %)	80.2500	80.4500	80.2600	<b>80.3200</b>
V <sub>lc</sub> Total Liquid collected (ml)	416.60	411.10	397.60	
V <sub>m</sub> Volume metered, meter conditions (ft <sup>3</sup> )	80.9450	80.6450	78.6700	
T <sub>m</sub> Dry gas meter temperature (°F)	79.9400	93.1200	93.7800	
T <sub>s</sub> Sample temperature (°F)	295.1200	295.7600	295.9200	<b>295.6000</b>
ΔH Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.2892	1.2464	1.1972	
θ Total sampling time (min)	125.0	125.0	125.0	
<b>Flow Results</b>				
V <sub>wstd</sub> Volume of water collected (ft <sup>3</sup> )	19.6052	19.3464	18.7111	<b>19.2209</b>
V <sub>mstd</sub> Volume metered, standard (dscf)	79.3470	77.1612	75.1728	<b>77.2270</b>
P <sub>s</sub> Sample gas pressure, absolute (in. Hg)	29.2176	29.2176	29.2176	<b>29.2176</b>
P <sub>v</sub> Vapor pressure, actual (in. Hg)	29.2176	29.2176	29.2176	<b>29.2176</b>
B <sub>wo</sub> Moisture measured in sample (% by volume)	19.8128	20.0465	19.9300	<b>19.9298</b>
B <sub>ws</sub> Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	19.8128	20.0465	19.9300	<b>19.9298</b>
√ΔP Velocity head (√in. H <sub>2</sub> O)	0.7222	0.7099	0.6891	<b>0.7071</b>
M <sub>d</sub> MW of sample gas, dry (lb/lb-mole)	29.8820	29.8860	29.9200	<b>29.8960</b>
M <sub>s</sub> MW of sample gas, wet (lb/lb-mole)	27.5278	27.5033	27.5443	<b>27.5252</b>
V <sub>s</sub> Velocity of sample (ft/sec)	48.5799	47.7918	46.3604	<b>47.5773</b>
%I Isokinetic sampling (%)	101.5932	100.8025	101.1112	<b>101.1690</b>
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	186,547	183,521	178,024	<b>182,697</b>
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	127,376	125,204	121,428	<b>124,670</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	102,140	100,105	97,228	<b>99,824</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	75,319	75,979	74,005	<b>75,101</b>
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	11,192,801	11,011,232	10,681,426	<b>10,961,820</b>
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,642,587	7,512,242	7,285,695	<b>7,480,175</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	6,128,377	6,006,302	5,833,655	<b>5,989,444</b>
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	316,987	311,845	302,504	<b>310,445</b>
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	216,443	212,751	206,335	<b>211,843</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	173,559	170,102	165,213	<b>169,625</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	127,984	129,106	125,752	<b>127,614</b>
Q <sub>a</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	201,685	198,245	192,267	<b>197,399</b>
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	161,726	158,504	153,948	<b>158,059</b>
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	119,258	120,303	117,178	<b>118,913</b>

**Comments:**

Average includes 3 runs.

041508 123608  
 M P C ®

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

**USEPA Method 5/29  
 Filterable Particulate Parameters**

Run No.	1	2	3	Average	
Date (2009)	Mar 17	Mar 17	Mar 17		
Start Time (approx.)	06:33	09:15	11:56		
Stop Time (approx.)	08:42	11:24	14:07		
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.0	184.0	184.1	184.0
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	315	315
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	10.6500	10.3500	10.3200	10.4400
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.1000	9.2000	9.4200	9.2400
T <sub>s</sub>	Sample temperature (°F)	295.1200	295.7600	295.9200	295.6000
B <sub>w</sub>	Actual water vapor in gas (% by volume)	19.8128	20.0465	19.9300	19.9298
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	186,547	183,521	178,024	182,697
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	127,376	125,204	121,428	124,670
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	102,140	100,105	97,228	99,824
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	75,319	75,979	74,005	75,101
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	11,192,801	11,011,232	10,681,426	10,961,820
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,642,587	7,512,242	7,285,695	7,480,175
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	6,128,377	6,006,302	5,833,655	5,989,444
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	316,987	311,845	302,504	310,445
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	216,443	212,751	206,335	211,843
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	173,559	170,102	165,213	169,625
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	127,984	129,106	125,752	127,614
Q <sub>s</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	201,685	198,245	192,267	197,399
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	161,726	158,504	153,948	158,059
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	119,258	120,303	117,178	118,913
<b>Sampling Data</b>					
V <sub>std</sub>	Volume metered, standard (dscf)	79.3470	77.1612	75.1728	77.2270
%I	Isokinetic sampling (%)	101.5932	100.8025	101.1112	101.1690
<b>Laboratory Data</b>					
m <sub>filter</sub>	Matter collected on filter(s) (g)	0.00010	0.00090	0.00010	
m <sub>s</sub>	Matter collected in solvent rinse(s) (g)	0.00360	0.00150	0.00080	
m <sub>n</sub>	Total particulate matter collected (g)	0.00360	0.00240	0.00080	
<b>Filterable Particulate Results</b>					
C <sub>sd</sub>	Particulate Concentration (lb/dscf)	1.0004E-07	6.8584E-08	2.3466E-08	6.4030E-08
C <sub>sd7</sub>	Particulate Concentration @7% O <sub>2</sub> (lb/dscf)	1.3567E-07	9.0361E-08	3.0830E-08	8.5619E-08
C <sub>sd12</sub>	Particulate Concentration @12% CO <sub>2</sub> (lb/dscf)	1.3192E-07	8.9457E-08	2.9893E-08	8.3758E-08
C <sub>a</sub>	Particulate Concentration (lb/acf)	5.4776E-08	3.7410E-08	1.2816E-08	3.5001E-08
C <sub>sd</sub>	Particulate Concentration (gr/dscf)	0.0007	0.0005	0.0002	0.0004
C <sub>sd7</sub>	Particulate Concentration @7% O <sub>2</sub> (gr/dscf)	0.0009	0.0006	0.0002	0.0006
C <sub>sd12</sub>	Particulate Concentration @12% CO <sub>2</sub> (gr/dscf)	0.0009	0.0006	0.0002	0.0006
C <sub>a</sub>	Particulate Concentration (gr/acf)	0.0004	0.0003	0.0001	0.0002
C <sub>sd</sub>	Particulate Concentration (mg/dscm)	1.6020	1.0983	0.3758	1.0254
C <sub>sd7</sub>	Particulate Concentration @7% O <sub>2</sub> (mg/dscm)	2.1725	1.4470	0.4937	1.3711
C <sub>sd12</sub>	Particulate Concentration @12% CO <sub>2</sub> (mg/dscm)	2.1126	1.4325	0.4787	1.3413
C <sub>a</sub>	Particulate Concentration (mg/m <sup>3</sup> (actual,wet))	0.8772	0.5991	0.2052	0.5605
C <sub>sd</sub>	Particulate Concentration (mg/Nm <sup>3</sup> dry)	1.7192	1.1786	0.4033	1.1004
C <sub>sd7</sub>	Particulate Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	2.3315	1.5529	0.5298	1.4714
C <sub>sd12</sub>	Particulate Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	2.2671	1.5373	0.5137	1.4394
E <sub>lb/hr</sub>	Particulate Rate (lb/hr)	0.6131	0.4119	0.1369	0.3873
E <sub>kg/hr</sub>	Particulate Rate (kg/hr)	0.2780	0.1868	0.0621	0.1756
E <sub>T/yr</sub>	Particulate Rate (Ton/yr)	2.6853	1.8043	0.5996	1.6964
E <sub>Fd</sub>	Particulate Rate - F <sub>d</sub> -based (lb/MMBtu)	0.0020	0.0013	0.0004	0.0012
E <sub>Fc</sub>	Particulate Rate - F <sub>c</sub> -based (lb/MMBtu)	0.0020	0.0014	0.0005	0.0013

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters**

Run No.	1	2	3	Average	
Date (2009)	Mar 17	Mar 17	Mar 17		
Start Time (approx.)	06:33	09:15	11:56		
Stop Time (approx.)	08:42	11:24	14:07		
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.0	184.0	184.1	184.0
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P <sub>2</sub>	Carbon Feed rate (lb/hr)	6	6	5	6
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	10.6500	10.3500	10.3200	10.4400
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.1000	9.2000	9.4200	9.2400
T <sub>s</sub>	Sample temperature (°F)	295.1200	295.7600	295.9200	295.6000
B <sub>w</sub>	Actual water vapor in gas (% by volume)	19.8128	20.0465	19.9300	19.9298
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	186,547	183,521	178,024	182,697
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	127,376	125,204	121,428	124,670
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	102,140	100,105	97,228	99,824
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	75,319	75,979	74,005	75,101
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	11,192,801	11,011,232	10,681,426	10,961,820
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,642,587	7,512,242	7,285,695	7,480,175
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	6,128,377	6,006,302	5,833,655	5,989,444
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	316,987	311,845	302,504	310,445
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	216,443	212,751	206,335	211,843
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	173,559	170,102	165,213	169,625
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	127,984	129,106	125,752	127,614
Q <sub>a</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	201,685	198,245	192,267	197,399
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	161,726	158,504	153,948	158,059
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	119,258	120,303	117,178	118,913
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	79.3470	77.1612	75.1728	77.2270
%I	Isokinetic sampling (%)	101.5932	100.8025	101.1112	101.1690
<b>Laboratory Data</b>					
m <sub>n-1b</sub>	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	
m <sub>n-2b</sub>	Fraction 2B (µg)	6.6466	7.0201	6.5708	
m <sub>n-3a</sub>	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	
m <sub>n-3b</sub>	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	
m <sub>n-3c</sub>	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	6.6466	7.0201	6.5708	
<b>Mercury Results - Total</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	1.8470E-10	2.0061E-10	1.9274E-10	1.9268E-10
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	2.5048E-10	2.6431E-10	2.5322E-10	2.5600E-10
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	2.4357E-10	2.6167E-10	2.4552E-10	2.5025E-10
C <sub>a</sub>	Concentration (lb/acf)	1.0113E-10	1.0943E-10	1.0526E-10	1.0527E-10
C <sub>sd</sub>	Concentration (µg/dscm)	2.9578E+00	3.2125E+00	3.0864E+00	3.0856E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	4.0110E+00	4.2326E+00	4.0549E+00	4.0995E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	3.9004E+00	4.1902E+00	3.9317E+00	4.0074E+00
C <sub>sd</sub>	Concentration (mg/dscm)	2.9578E-03	3.2125E-03	3.0864E-03	3.0856E-03
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	4.0110E-03	4.2326E-03	4.0549E-03	4.0995E-03
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	3.9004E-03	4.1902E-03	3.9317E-03	4.0074E-03
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.6195E+00	1.7523E+00	1.6856E+00	1.6858E+00
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	3.1742E+00	3.4476E+00	3.3122E+00	3.3113E+00
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.3045E+00	4.5423E+00	4.3516E+00	4.3995E+00
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.1858E+00	4.4968E+00	4.2194E+00	4.3007E+00
E <sub>lb/hr</sub>	Rate (lb/hr)	1.1319E-03	1.2049E-03	1.1244E-03	1.1537E-03
E <sub>g/s</sub>	Rate (g/s)	1.4260E-04	1.5179E-04	1.4164E-04	1.4534E-04
E <sub>T/yr</sub>	Rate (Ton/yr)	4.9579E-03	5.2776E-03	4.9247E-03	5.0534E-03
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	3.6042E-06	3.8033E-06	3.6437E-06	3.6837E-06
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	3.6941E-06	3.9686E-06	3.7238E-06	3.7955E-06



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Front Half Results**

Run No.	1	2	3	Average	
Date (2009)	Mar 17	Mar 17	Mar 17		
Start Time (approx.)	06:33	09:15	11:56		
Stop Time (approx.)	08:42	11:24	14:07		
<b>Mercury Results - Front Half</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	<2.7789E-12	<2.8577E-12	<2.9332E-12	<2.8586E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<3.7685E-12	<3.7651E-12	<3.8537E-12	<3.7958E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<3.6645E-12	<3.7274E-12	<3.7366E-12	<3.7095E-12
C <sub>a</sub>	Concentration (lb/acf)	<1.5215E-12	<1.5588E-12	<1.6020E-12	<1.5608E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<4.4501E-02	<4.5761E-02	<4.6972E-02	<4.5745E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<6.0347E-02	<6.0292E-02	<6.1712E-02	<6.0784E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<5.8682E-02	<5.9689E-02	<5.9837E-02	<5.9403E-02
C <sub>sd</sub>	Concentration (mg/dscm)	<4.4501E-05	<4.5761E-05	<4.6972E-05	<4.5745E-05
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<6.0347E-05	<6.0292E-05	<6.1712E-05	<6.0784E-05
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<5.8682E-05	<5.9689E-05	<5.9837E-05	<5.9403E-05
C <sub>B</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<2.4365E-02	<2.4961E-02	<2.5654E-02	<2.4994E-02
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<4.7757E-02	<4.9110E-02	<5.0409E-02	<4.9092E-02
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<6.4763E-02	<6.4704E-02	<6.6227E-02	<6.5231E-02
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<6.2976E-02	<6.4056E-02	<6.4215E-02	<6.3749E-02
E <sub>lb/hr</sub>	Rate (lb/hr)	<1.7030E-05	<1.7164E-05	<1.7112E-05	<1.7102E-05
E <sub>g/s</sub>	Rate (g/s)	<2.1454E-06	<2.1622E-06	<2.1556E-06	<2.1544E-06
E <sub>Tyr</sub>	Rate (Ton/yr)	<7.4593E-05	<7.5178E-05	<7.4948E-05	<7.4906E-05
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<5.4227E-08	<5.4177E-08	<5.5452E-08	<5.4619E-08
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<5.5579E-08	<5.6532E-08	<5.6672E-08	<5.6261E-08

041509 123808  
 M P O @ \_ M

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 1-3 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	

**Mercury Results - Impingers 1-3 Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	1.8470E-10	2.0061E-10	1.9274E-10	<b>1.9268E-10</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	2.5048E-10	2.6431E-10	2.5322E-10	<b>2.5600E-10</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	2.4357E-10	2.6167E-10	2.4552E-10	<b>2.5025E-10</b>
C <sub>a</sub>	Concentration (lb/acf)	1.0113E-10	1.0943E-10	1.0526E-10	<b>1.0527E-10</b>
C <sub>sd</sub>	Concentration (µg/dscm)	2.9578E+00	3.2125E+00	3.0864E+00	<b>3.0858E+00</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	4.0110E+00	4.2326E+00	4.0549E+00	<b>4.0995E+00</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	3.9004E+00	4.1902E+00	3.9317E+00	<b>4.0074E+00</b>
C <sub>sd</sub>	Concentration (mg/dscm)	2.9578E-03	3.2125E-03	3.0864E-03	<b>3.0856E-03</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	4.0110E-03	4.2326E-03	4.0549E-03	<b>4.0995E-03</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	3.9004E-03	4.1902E-03	3.9317E-03	<b>4.0074E-03</b>
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.6195E+00	1.7523E+00	1.6856E+00	<b>1.6858E+00</b>
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	3.1742E+00	3.4476E+00	3.3122E+00	<b>3.3113E+00</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.3045E+00	4.5423E+00	4.3516E+00	<b>4.3995E+00</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	4.1858E+00	4.4968E+00	4.2194E+00	<b>4.3007E+00</b>
E <sub>lb/hr</sub>	Rate (lb/hr)	1.1319E-03	1.2049E-03	1.1244E-03	<b>1.1537E-03</b>
E <sub>g/s</sub>	Rate (g/s)	1.4260E-04	1.5179E-04	1.4164E-04	<b>1.4534E-04</b>
E <sub>T/yr</sub>	Rate (Ton/yr)	4.9579E-03	5.2776E-03	4.9247E-03	<b>5.0534E-03</b>
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	3.6042E-06	3.8033E-06	3.6437E-06	<b>3.6837E-06</b>
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	3.6941E-06	3.9686E-06	3.7238E-06	<b>3.7955E-06</b>

041908 123658  
 N P O @ \_ M

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 4 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	
<b>Mercury Results - Impinger 4 Solution</b>				
C <sub>sd</sub> Concentration (lb/dscf)	<5.5579E-12	<5.7153E-12	<5.8665E-12	<b>&lt;5.7132E-12</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	<7.5370E-12	<7.5301E-12	<7.7074E-12	<b>&lt;7.5915E-12</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	<7.3291E-12	<7.4548E-12	<7.4732E-12	<b>&lt;7.4190E-12</b>
C <sub>a</sub> Concentration (lb/acf)	<3.0431E-12	<3.1175E-12	<3.2040E-12	<b>&lt;3.1215E-12</b>
C <sub>sd</sub> Concentration (µg/dscm)	<8.9001E-02	<9.1523E-02	<9.3944E-02	<b>&lt;9.1489E-02</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	<1.2069E-01	<1.2058E-01	<1.2342E-01	<b>&lt;1.2157E-01</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	<1.1736E-01	<1.1938E-01	<1.1967E-01	<b>&lt;1.1881E-01</b>
C <sub>sd</sub> Concentration (mg/dscm)	<8.9001E-05	<9.1523E-05	<9.3944E-05	<b>&lt;9.1489E-05</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	<1.2069E-04	<1.2058E-04	<1.2342E-04	<b>&lt;1.2157E-04</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	<1.1736E-04	<1.1938E-04	<1.1967E-04	<b>&lt;1.1881E-04</b>
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	<4.8731E-02	<4.9923E-02	<5.1307E-02	<b>&lt;4.9987E-02</b>
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	<9.5514E-02	<9.8220E-02	<1.0082E-01	<b>&lt;9.8184E-02</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2953E-01	<1.2941E-01	<1.3245E-01	<b>&lt;1.3046E-01</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2595E-01	<1.2811E-01	<1.2843E-01	<b>&lt;1.2750E-01</b>
E <sub>lb/hr</sub> Rate (lb/hr)	<3.4061E-05	<3.4328E-05	<3.4223E-05	<b>&lt;3.4204E-05</b>
E <sub>g/s</sub> Rate (g/s)	<4.2908E-06	<4.3245E-06	<4.3113E-06	<b>&lt;4.3089E-06</b>
E <sub>Tyr</sub> Rate (Ton/yr)	<1.4919E-04	<1.5036E-04	<1.4990E-04	<b>&lt;1.4981E-04</b>
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	<1.0845E-07	<1.0835E-07	<1.1090E-07	<b>&lt;1.0924E-07</b>
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	<1.1116E-07	<1.1306E-07	<1.1334E-07	<b>&lt;1.1252E-07</b>

041509 125508  
 M P O @ \_ M

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

**USEPA Method 5/29  
 Mercury (Hg) Emission Parameters (continued)  
 Separate Impinger 5-6 Results**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	

**Mercury Results - Filtered Permanganate Solution**

C <sub>sd</sub>	Concentration (lb/dscf)	<1.3895E-11	<1.4288E-11	<1.4666E-11	<b>&lt;1.4283E-11</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.8843E-11	<1.8825E-11	<1.9268E-11	<b>&lt;1.8979E-11</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.8323E-11	<1.8637E-11	<1.8683E-11	<b>&lt;1.8548E-11</b>
C <sub>a</sub>	Concentration (lb/acf)	<7.6077E-12	<7.7938E-12	<8.0099E-12	<b>&lt;7.8038E-12</b>
C <sub>sd</sub>	Concentration (µg/dscm)	<2.2250E-01	<2.2881E-01	<2.3486E-01	<b>&lt;2.2872E-01</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<3.0174E-01	<3.0146E-01	<3.0856E-01	<b>&lt;3.0392E-01</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.9341E-01	<2.9844E-01	<2.9918E-01	<b>&lt;2.9701E-01</b>
C <sub>sd</sub>	Concentration (mg/dscm)	<2.2250E-04	<2.2881E-04	<2.3486E-04	<b>&lt;2.2872E-04</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<3.0174E-04	<3.0146E-04	<3.0856E-04	<b>&lt;3.0392E-04</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.9341E-04	<2.9844E-04	<2.9918E-04	<b>&lt;2.9701E-04</b>
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<1.2183E-01	<1.2481E-01	<1.2827E-01	<b>&lt;1.2497E-01</b>
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<2.3878E-01	<2.4555E-01	<2.5204E-01	<b>&lt;2.4546E-01</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.2382E-01	<3.2352E-01	<3.3114E-01	<b>&lt;3.2616E-01</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.1488E-01	<3.2028E-01	<3.2107E-01	<b>&lt;3.1875E-01</b>
E <sub>lb/hr</sub>	Rate (lb/hr)	<8.5152E-05	<8.5820E-05	<8.5558E-05	<b>&lt;8.5510E-05</b>
E <sub>g/s</sub>	Rate (g/s)	<1.0727E-05	<1.0811E-05	<1.0778E-05	<b>&lt;1.0772E-05</b>
E <sub>T/yr</sub>	Rate (Ton/yr)	<3.7296E-04	<3.7589E-04	<3.7474E-04	<b>&lt;3.7453E-04</b>
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.7113E-07	<2.7089E-07	<2.7726E-07	<b>&lt;2.7309E-07</b>
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.7789E-07	<2.8266E-07	<2.8336E-07	<b>&lt;2.8130E-07</b>

**Mercury Results - HCl Rinse + HCl/MnO2 Precipitate**

C <sub>sd</sub>	Concentration (lb/dscf)	<1.1116E-11	<1.1431E-11	<1.1733E-11	<b>&lt;1.1426E-11</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<1.5074E-11	<1.5060E-11	<1.5415E-11	<b>&lt;1.5183E-11</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.4658E-11	<1.4910E-11	<1.4946E-11	<b>&lt;1.4838E-11</b>
C <sub>a</sub>	Concentration (lb/acf)	<6.0862E-12	<6.2351E-12	<6.4080E-12	<b>&lt;6.2431E-12</b>
C <sub>sd</sub>	Concentration (µg/dscm)	<1.7800E-01	<1.8305E-01	<1.8789E-01	<b>&lt;1.8298E-01</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<2.4139E-01	<2.4117E-01	<2.4685E-01	<b>&lt;2.4313E-01</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.3473E-01	<2.3875E-01	<2.3935E-01	<b>&lt;2.3761E-01</b>
C <sub>sd</sub>	Concentration (mg/dscm)	<1.7800E-04	<1.8305E-04	<1.8789E-04	<b>&lt;1.8298E-04</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<2.4139E-04	<2.4117E-04	<2.4685E-04	<b>&lt;2.4313E-04</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.3473E-04	<2.3875E-04	<2.3935E-04	<b>&lt;2.3761E-04</b>
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<9.7462E-02	<9.9846E-02	<1.0261E-01	<b>&lt;9.9974E-02</b>
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<1.9103E-01	<1.9644E-01	<2.0164E-01	<b>&lt;1.9637E-01</b>
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.5905E-01	<2.5882E-01	<2.6491E-01	<b>&lt;2.6093E-01</b>
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<2.5190E-01	<2.5622E-01	<2.5686E-01	<b>&lt;2.5500E-01</b>
E <sub>lb/hr</sub>	Rate (lb/hr)	<6.8121E-05	<6.8656E-05	<6.8446E-05	<b>&lt;6.8408E-05</b>
E <sub>g/s</sub>	Rate (g/s)	<8.5817E-06	<8.6490E-06	<8.6226E-06	<b>&lt;8.6178E-06</b>
E <sub>T/yr</sub>	Rate (Ton/yr)	<2.9837E-04	<3.0071E-04	<2.9979E-04	<b>&lt;2.9963E-04</b>
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<2.1691E-07	<2.1671E-07	<2.2181E-07	<b>&lt;2.1847E-07</b>
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<2.2231E-07	<2.2613E-07	<2.2669E-07	<b>&lt;2.2504E-07</b>

D41509 123008  
 M P O @\_M

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

**USEPA Method 5/29  
 Beryllium (Be) Emission Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 17	Mar 17	Mar 17	
Start Time (approx.)	06:33	09:15	11:56	
Stop Time (approx.)	08:42	11:24	14:07	
<b>Process Conditions</b>				
R <sub>p</sub> Steam Production Rate (Klbs/hour)	184.0	184.0	184.1	<b>184.0</b>
P <sub>1</sub> Fabric Filter Inlet Temperature (°F)	315	315	315	<b>315</b>
P <sub>2</sub> Carbon Feed rate (lb/hr)	6	6	5	<b>6</b>
F <sub>d</sub> Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	<b>9,570</b>
F <sub>c</sub> Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	<b>1,820</b>
Cap Capacity factor (hours/year)	8,760	8,760	8,760	<b>8,760</b>
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	10.6500	10.3500	10.3200	<b>10.4400</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.1000	9.2000	9.4200	<b>9.2400</b>
T <sub>s</sub> Sample temperature (°F)	295.1200	295.7600	295.9200	<b>295.6000</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	19.8128	20.0465	19.9300	<b>19.9298</b>
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	186,547	183,521	178,024	<b>182,697</b>
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	127,376	125,204	121,428	<b>124,670</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	102,140	100,105	97,228	<b>99,824</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	75,319	75,979	74,005	<b>75,101</b>
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	11,192,801	11,011,232	10,681,426	<b>10,961,820</b>
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,642,587	7,512,242	7,285,695	<b>7,480,175</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	6,128,377	6,006,302	5,833,655	<b>5,989,444</b>
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	316,987	311,845	302,504	<b>310,445</b>
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	216,443	212,751	206,335	<b>211,843</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	173,559	170,102	165,213	<b>169,625</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	127,984	129,106	125,752	<b>127,614</b>
Q <sub>a</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	201,685	198,245	192,267	<b>197,399</b>
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	161,726	158,504	153,948	<b>158,059</b>
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	119,258	120,303	117,178	<b>118,913</b>
<b>Sampling Data</b>				
V <sub>msld</sub> Volume metered, standard (dscf)	79.3470	77.1612	75.1728	<b>77.2270</b>
%I Isokinetic sampling (%)	101.5932	100.8025	101.1112	<b>101.1690</b>
<b>Laboratory Data</b>				
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	<0.0500	<0.0500	<0.0500	
<b>Beryllium Results - Total</b>				
C <sub>sd</sub> Concentration (lb/dscf)	<1.3895E-12	<1.4288E-12	<1.4666E-12	<b>&lt;1.4283E-12</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (lb/dscf)	<1.8843E-12	<1.8825E-12	<1.9268E-12	<b>&lt;1.8979E-12</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (lb/dscf)	<1.8323E-12	<1.8637E-12	<1.8683E-12	<b>&lt;1.8548E-12</b>
C <sub>a</sub> Concentration (lb/acf)	<7.6077E-13	<7.7938E-13	<8.0099E-13	<b>&lt;7.8038E-13</b>
C <sub>sd</sub> Concentration (µg/dscm)	<2.2250E-02	<2.2881E-02	<2.3486E-02	<b>&lt;2.2872E-02</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/dscm)	<3.0174E-02	<3.0146E-02	<3.0856E-02	<b>&lt;3.0392E-02</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/dscm)	<2.9341E-02	<2.9844E-02	<2.9918E-02	<b>&lt;2.9701E-02</b>
C <sub>sd</sub> Concentration (mg/dscm)	<2.2250E-05	<2.2881E-05	<2.3486E-05	<b>&lt;2.2872E-05</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (mg/dscm)	<3.0174E-05	<3.0146E-05	<3.0856E-05	<b>&lt;3.0392E-05</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (mg/dscm)	<2.9341E-05	<2.9844E-05	<2.9918E-05	<b>&lt;2.9701E-05</b>
C <sub>a</sub> Concentration (µg/m <sup>3</sup> (actual,wet))	<1.2183E-02	<1.2481E-02	<1.2827E-02	<b>&lt;1.2497E-02</b>
C <sub>sd</sub> Concentration (µg/Nm <sup>3</sup> dry)	<2.3878E-02	<2.4555E-02	<2.5204E-02	<b>&lt;2.4546E-02</b>
C <sub>sd7</sub> Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.2382E-02	<3.2352E-02	<3.3114E-02	<b>&lt;3.2616E-02</b>
C <sub>sd12</sub> Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<3.1488E-02	<3.2028E-02	<3.2107E-02	<b>&lt;3.1875E-02</b>
E <sub>lb/hr</sub> Rate (lb/hr)	<8.5152E-06	<8.5820E-06	<8.5558E-06	<b>&lt;8.5510E-06</b>
E <sub>g/s</sub> Rate (g/s)	<1.0727E-06	<1.0811E-06	<1.0778E-06	<b>&lt;1.0772E-06</b>
E <sub>T/yr</sub> Rate (Ton/yr)	<3.7296E-05	<3.7589E-05	<3.7474E-05	<b>&lt;3.7453E-05</b>
E <sub>Fd</sub> Rate - Fd-based (lb/MMBtu)	<2.7113E-08	<2.7089E-08	<2.7726E-08	<b>&lt;2.7309E-08</b>
E <sub>Fc</sub> Rate - Fc-based (lb/MMBtu)	<2.7789E-08	<2.8266E-08	<2.8336E-08	<b>&lt;2.8130E-08</b>

Prepared by Clean Air Engineering Inc. based on data from  
 SS Metals-1 Version 2006-12a

Copyright © 2008 Clean Air Engineering Inc.

QA/QC \_\_\_\_\_  
 Date \_\_\_\_\_

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

### USEPA Method 5/29 Cadmium (Cd) Emission Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 17	Mar 17	Mar 17	
Start Time (approx.)		06:33	09:15	11:56	
Stop Time (approx.)		08:42	11:24	14:07	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.0	184.0	184.1	184.0
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P <sub>2</sub>	Carbon Feed rate (lb/hr)	6	6	5	6
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	10.6500	10.3500	10.3200	10.4400
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.1000	9.2000	9.4200	9.2400
T <sub>a</sub>	Sample temperature (°F)	295.1200	295.7600	295.9200	295.6000
B <sub>w</sub>	Actual water vapor in gas (% by volume)	19.8128	20.0465	19.9300	19.9298
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	186,547	183,521	178,024	182,697
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	127,376	125,204	121,428	124,670
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	102,140	100,105	97,228	99,824
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	75,319	75,979	74,005	75,101
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	11,192,801	11,011,232	10,681,426	10,961,820
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,642,587	7,512,242	7,285,695	7,480,175
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	6,128,377	6,006,302	5,833,655	5,989,444
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	316,987	311,845	302,504	310,445
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	216,443	212,751	206,335	211,843
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	173,559	170,102	165,213	169,625
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	127,984	129,106	125,752	127,614
Q <sub>n</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	201,685	198,245	192,267	197,399
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	161,726	158,504	153,948	158,059
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	119,258	120,303	117,178	118,913
<b>Sampling Data</b>					
V <sub>std</sub>	Volume metered, standard (dscf)	79.3470	77.1612	75.1728	77.2270
%I	isokinetic sampling (%)	101.5932	100.8025	101.1112	101.1690
<b>Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	<0.2000	0.2333	0.2845	
<b>Cadmium Results - Total</b>					
C <sub>sd</sub>	Concentration (lb/dscf)	<5.5579E-12	6.6657E-12	8.3454E-12	<6.8563E-12
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	<7.5370E-12	8.7822E-12	1.0964E-11	<9.0945E-12
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	<7.3291E-12	8.6943E-12	1.0631E-11	<8.8848E-12
C <sub>a</sub>	Concentration (lb/acf)	<3.0431E-12	3.6359E-12	4.5578E-12	<3.7456E-12
C <sub>sd</sub>	Concentration (µg/dscm)	<8.9001E-02	1.0674E-01	1.3364E-01	<1.0979E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	<1.2069E-01	1.4064E-01	1.7558E-01	<1.4564E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	<1.1736E-01	1.3923E-01	1.7024E-01	<1.4228E-01
C <sub>sd</sub>	Concentration (mg/dscm)	<8.9001E-05	1.0674E-04	1.3364E-04	<1.0979E-04
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	<1.2069E-04	1.4064E-04	1.7558E-04	<1.4564E-04
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	<1.1736E-04	1.3923E-04	1.7024E-04	<1.4228E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	<4.8731E-02	5.8224E-02	7.2987E-02	<5.9981E-02
C <sub>sd</sub>	Concentration (µg/Nm <sup>3</sup> dry)	<9.5514E-02	1.1455E-01	1.4342E-01	<1.1783E-01
C <sub>sd7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2953E-01	1.5093E-01	1.8842E-01	<1.5629E-01
C <sub>sd12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	<1.2595E-01	1.4941E-01	1.8270E-01	<1.5269E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	<3.4061E-05	4.0036E-05	4.8684E-05	<4.0927E-05
E <sub>g/s</sub>	Rate (g/s)	<4.2908E-06	5.0436E-06	6.1330E-06	<5.1558E-06
E <sub>T/yr</sub>	Rate (Ton/yr)	<1.4919E-04	1.7536E-04	2.1324E-04	<1.7926E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	<1.0845E-07	1.2637E-07	1.5777E-07	<1.3086E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	<1.1116E-07	1.3186E-07	1.6124E-07	<1.3475E-07

Prepared by Clean Air Engineering, Inc.  
 SS Metals-1 Version 2006-12a

Copyright © 2006 Clean Air Engineering Inc.

QA/QC \_\_\_\_\_  
 Date \_\_\_\_\_

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

### USEPA Method 5/29 Lead (Pb) Emission Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 17	Mar 17	Mar 17	
Start Time (approx.)		06:33	09:15	11:56	
Stop Time (approx.)		08:42	11:24	14:07	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.0	184.0	184.1	184.0
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	315	315
P <sub>2</sub>	Carbon Feed rate (lb/hr)	6	6	5	6
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	10.6500	10.3500	10.3200	10.4400
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.1000	9.2000	9.4200	9.2400
T <sub>a</sub>	Sample temperature (°F)	295.1200	295.7600	295.9200	295.6000
B <sub>w</sub>	Actual water vapor in gas (% by volume)	19.8128	20.0465	19.9300	19.9298
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	186,547	183,521	178,024	182,697
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	127,376	125,204	121,428	124,670
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	102,140	100,105	97,228	99,824
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	75,319	75,979	74,005	75,101
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	11,192,801	11,011,232	10,681,426	10,961,820
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,642,587	7,512,242	7,285,695	7,480,175
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	6,128,377	6,006,302	5,833,655	5,989,444
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	316,987	311,845	302,504	310,445
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	216,443	212,751	206,335	211,843
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	173,559	170,102	165,213	169,625
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	127,984	129,106	125,752	127,614
Q <sub>e</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	201,685	198,245	192,267	197,399
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	161,726	158,504	153,948	158,059
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	119,258	120,303	117,178	118,913
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	79.3470	77.1612	75.1728	77.2270
%I	Isokinetic sampling (%)	101.5932	100.8025	101.1112	101.1690
<b>Laboratory Data</b>					
m <sub>n</sub>	Total matter corrected for allowable blanks (µg)	0.6091	1.6247	1.0876	
<b>Lead Results - Total</b>					
C <sub>std</sub>	Concentration (lb/dscf)	1.6928E-11	4.6427E-11	3.1901E-11	3.1752E-11
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (lb/dscf)	2.2955E-11	6.1169E-11	4.1912E-11	4.2012E-11
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (lb/dscf)	2.2322E-11	6.0557E-11	4.0638E-11	4.1173E-11
C <sub>a</sub>	Concentration (lb/acf)	9.2683E-12	2.5325E-11	1.7423E-11	1.7339E-11
C <sub>std</sub>	Concentration (µg/dscm)	2.7107E-01	7.4346E-01	5.1085E-01	5.0846E-01
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (µg/dscm)	3.6760E-01	9.7954E-01	6.7116E-01	6.7277E-01
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (µg/dscm)	3.5746E-01	9.6974E-01	6.5077E-01	6.5932E-01
C <sub>std</sub>	Concentration (mg/dscm)	2.7107E-04	7.4346E-04	5.1085E-04	5.0846E-04
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (mg/dscm)	3.6760E-04	9.7954E-04	6.7116E-04	6.7277E-04
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (mg/dscm)	3.5746E-04	9.6974E-04	6.5077E-04	6.5932E-04
C <sub>a</sub>	Concentration (µg/m <sup>3</sup> (actual,wet))	1.4842E-01	4.0554E-01	2.7900E-01	2.7765E-01
C <sub>std</sub>	Concentration (µg/Nm <sup>3</sup> dry)	2.9091E-01	7.9786E-01	5.4823E-01	5.4567E-01
C <sub>std7</sub>	Concentration @7% O <sub>2</sub> (µg/Nm <sup>3</sup> dry)	3.9450E-01	1.0512E+00	7.2027E-01	7.2199E-01
C <sub>std12</sub>	Concentration @12% CO <sub>2</sub> (µg/Nm <sup>3</sup> dry)	3.8361E-01	1.0407E+00	6.9839E-01	7.0756E-01
E <sub>lb/hr</sub>	Rate (lb/hr)	1.0374E-04	2.7885E-04	1.8610E-04	1.8956E-04
E <sub>g/s</sub>	Rate (g/s)	1.3069E-05	3.5129E-05	2.3444E-05	2.3881E-05
E <sub>T/yr</sub>	Rate (Ton/yr)	4.5437E-04	1.2214E-03	8.1512E-04	8.3029E-04
E <sub>Fd</sub>	Rate - Fd-based (lb/MMBtu)	3.3031E-07	8.8019E-07	6.0309E-07	6.0453E-07
E <sub>Fc</sub>	Rate - Fc-based (lb/MMBtu)	3.3855E-07	9.1845E-07	6.1635E-07	6.2445E-07

Prepared by Clean Air Engineering Inc.  
 SS Metals-1 Version 2006-12a

Copyright © 2008 Clean Air Engineering Inc.

QA/QC \_\_\_\_\_  
 Date \_\_\_\_\_

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

**USEPA Method 13B (Total Fluorides)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 16	Mar 16	Mar 16	
Start Time (approx.)	07:20	09:30	11:20	
Stop Time (approx.)	00:00	10:47	12:41	
<b>Sampling Conditions</b>				
Y <sub>d</sub> Dry gas meter correction factor	0.9937	0.9937	0.9937	
C <sub>p</sub> Pitot tube coefficient	0.8250	0.8250	0.8250	
P <sub>g</sub> Static pressure (in. H <sub>2</sub> O)	-13.0000	-11.4000	-10.8000	
A <sub>s</sub> Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub> Barometric pressure (in. Hg)	30.20	30.20	30.20	<b>30.2000</b>
D <sub>n</sub> Nozzle diameter (in.)	0.2720	0.2720	0.2720	
O <sub>2</sub> Oxygen (dry volume %)	9.7400	11.0500	10.3200	<b>10.3700</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.7800	8.4800	9.2600	<b>9.1733</b>
N <sub>2</sub> +CO Nitrogen plus carbon monoxide (dry volume %)	80.4800	80.4700	80.4200	<b>80.4567</b>
V <sub>lc</sub> Total Liquid collected (ml)	237.60	217.50	218.60	
V <sub>m</sub> Volume metered, meter conditions (ft <sup>3</sup> )	42.6500	42.9500	43.1150	
T <sub>m</sub> Dry gas meter temperature (°F)	82.3600	88.7200	89.4400	
T <sub>s</sub> Sample temperature (°F)	296.3600	294.1600	293.6000	<b>294.7067</b>
ΔH Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.4420	1.4344	1.4492	
θ Total sampling time (min)	62.5	62.5	62.5	
<b>Flow Results</b>				
V <sub>wstd</sub> Volume of water collected (ft <sup>3</sup> )	11.1815	10.2356	10.2873	<b>10.5681</b>
V <sub>mstd</sub> Volume metered, standard (dscf)	41.7748	41.5803	41.6868	<b>41.6806</b>
P <sub>a</sub> Sample gas pressure, absolute (in. Hg)	29.2441	29.3618	29.4059	<b>29.3373</b>
P <sub>v</sub> Vapor pressure, actual (in. Hg)	29.2441	29.3618	29.4059	<b>29.3373</b>
B <sub>wo</sub> Moisture measured in sample (% by volume)	21.1145	19.7537	19.7932	<b>20.2205</b>
B <sub>wa</sub> Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	21.1145	19.7537	19.7932	<b>20.2205</b>
√ΔP Velocity head (√in. H <sub>2</sub> O)	0.7353	0.7357	0.7349	<b>0.7353</b>
M <sub>d</sub> MW of sample gas, dry (lb/lb-mole)	29.9544	29.7988	29.8944	<b>29.8825</b>
M <sub>s</sub> MW of sample gas, wet (lb/lb-mole)	27.4303	27.4681	27.5401	<b>27.4795</b>
V <sub>s</sub> Velocity of sample (ft/sec)	50.3544	50.1756	49.9977	<b>50.1759</b>
%I Isokinetic sampling (%)	101.9192	99.3890	99.8229	<b>100.3770</b>
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	193,361	192,674	191,991	<b>192,675</b>
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	131,932	132,378	132,205	<b>132,172</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	104,075	106,228	106,037	<b>105,447</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	83,560	75,277	80,710	<b>79,849</b>
Q <sub>a</sub> Volumetric flow rate, actual (acf/hr)	11,601,662	11,560,447	11,519,481	<b>11,560,530</b>
Q <sub>s</sub> Volumetric flow rate, standard (scf/hr)	7,915,940	7,942,653	7,932,290	<b>7,930,294</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscf/hr)	6,244,528	6,373,684	6,362,240	<b>6,326,817</b>
Q <sub>a</sub> Volumetric flow rate, actual (m <sup>3</sup> /hr)	328,566	327,399	326,238	<b>327,401</b>
Q <sub>s</sub> Volumetric flow rate, standard (m <sup>3</sup> /hr)	224,184	224,941	224,647	<b>224,591</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	176,849	180,506	180,182	<b>179,179</b>
Q <sub>std7</sub> Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	141,988	127,913	137,146	<b>135,682</b>
Q <sub>s</sub> Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	208,899	209,604	209,330	<b>209,278</b>
Q <sub>std</sub> Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	164,791	168,199	167,897	<b>166,962</b>
Q <sub>std7</sub> Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	132,307	119,192	127,795	<b>126,431</b>

Comments:

Average includes 3 runs.

041508 123716  
 KKN@



**USEPA Method 13B  
 HF Parameters**

Run No.	1	2	3	Average	
Date (2009)	Mar 16	Mar 16	Mar 16		
Start Time (approx.)	07:20	09:30	11:20		
Stop Time (approx.)	00:00	10:47	12:41		
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.2	184.0	184.4	184.2
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	315	315	315
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	9,570
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	1,820
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.7400	11.0500	10.3200	10.3700
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.7800	8.4800	9.2600	9.1733
T <sub>a</sub>	Sample temperature (°F)	296.3600	294.1600	293.6000	294.7067
B <sub>w</sub>	Actual water vapor in gas (% by volume)	21.1145	19.7537	19.7932	20.2205
<b>Gas Flow Rate</b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	193,361	192,674	191,991	192,675
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	131,932	132,378	132,205	132,172
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	104,075	106,228	106,037	105,447
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dscfm)	83,560	75,277	80,710	79,849
Q <sub>a</sub>	Volumetric flow rate, actual (acf/hr)	11,601,662	11,560,447	11,519,481	11,560,530
Q <sub>s</sub>	Volumetric flow rate, standard (scf/hr)	7,915,940	7,942,653	7,932,290	7,930,294
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscf/hr)	6,244,528	6,373,684	6,362,240	6,326,817
Q <sub>a</sub>	Volumetric flow rate, actual (m <sup>3</sup> /hr)	328,566	327,399	326,238	327,401
Q <sub>s</sub>	Volumetric flow rate, standard (m <sup>3</sup> /hr)	224,184	224,941	224,647	224,591
Q <sub>std</sub>	Volumetric flow rate, dry standard (dry m <sup>3</sup> /hr)	176,849	180,506	180,182	179,179
Q <sub>std7</sub>	Volumetric flow rate, dry std@7%O <sub>2</sub> (dry m <sup>3</sup> /hr)	141,988	127,913	137,146	135,682
Q <sub>a</sub>	Volumetric flow rate, normal (Nm <sup>3</sup> /hr)	208,899	209,604	209,330	209,278
Q <sub>std</sub>	Volumetric flow rate, dry normal (Nm <sup>3</sup> /hr)	164,791	168,199	167,897	166,962
Q <sub>std7</sub>	Volumetric flow rate, dry normal @7%O <sub>2</sub> (Nm <sup>3</sup> /hr)	132,307	119,192	127,795	126,431
<b>Sampling Data</b>					
V <sub>metd</sub>	Volume metered, standard (dscf)	41.7748	41.5803	41.6868	41.6806
%I	Isokinetic sampling (%)	101.9192	99.3890	99.8229	100.3770
<b>Laboratory Data</b>					
m <sub>n</sub>	Total HF collected (mg)	<0.0061	<0.0055	<0.0056	
<b>Hydrogen Fluoride (HF) Results</b>					
C <sub>sd</sub>	HF Concentration (lb/dscf)	<3.2448E-10	<2.8981E-10	<2.9642E-10	<3.0357E-10
C <sub>sd7</sub>	HF Concentration @7% O <sub>2</sub> (lb/dscf)	<4.0415E-10	<4.0897E-10	<3.8944E-10	<4.0085E-10
C <sub>sd12</sub>	HF Concentration @12% CO <sub>2</sub> (lb/dscf)	<3.9813E-10	<4.1011E-10	<3.8413E-10	<3.9746E-10
C <sub>a</sub>	HF Concentration (lb/acf)	<1.7465E-10	<1.5978E-10	<1.6372E-10	<1.6605E-10
C <sub>sd</sub>	HF Concentration (ppmdv)	<0.0063	<0.0056	<0.0057	<0.0058
C <sub>sd7</sub>	HF Concentration @7% O <sub>2</sub> (ppmdv)	<0.0078	<0.0079	<0.0075	<0.0077
C <sub>sd12</sub>	HF Concentration @12% CO <sub>2</sub> (ppmdv)	<0.0077	<0.0079	<0.0074	<0.0077
C <sub>w</sub>	HF Concentration (ppmwv)	<0.0049	<0.0045	<0.0046	<0.0047
C <sub>sd</sub>	HF Concentration (mg/dscm)	<0.0052	<0.0046	<0.0047	<0.0049
C <sub>sd7</sub>	HF Concentration @7% O <sub>2</sub> (mg/dscm)	<0.0065	<0.0065	<0.0062	<0.0064
C <sub>sd12</sub>	HF Concentration @12% CO <sub>2</sub> (mg/dscm)	<0.0064	<0.0066	<0.0062	<0.0064
C <sub>a</sub>	HF Concentration (mg/m <sup>3</sup> (actual,wet))	<0.0028	<0.0026	<0.0026	<0.0027
C <sub>sd</sub>	HF Concentration (mg/Nm <sup>3</sup> dry)	<0.0056	<0.0050	<0.0051	<0.0052
C <sub>sd7</sub>	HF Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	<0.0069	<0.0070	<0.0067	<0.0069
C <sub>sd12</sub>	HF Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	<0.0068	<0.0070	<0.0066	<0.0068
E <sub>lb/hr</sub>	HF Rate (lb/hr)	<0.0020	<0.0018	<0.0019	<0.0019
E <sub>kg/hr</sub>	HF Rate (kg/hr)	<0.0009	<0.0008	<0.0009	<0.0009
E <sub>T/yr</sub>	HF Rate (Ton/yr)	<0.0089	<0.0081	<0.0083	<0.0084
E <sub>Fd</sub>	HF Rate - Fd-based (lb/MMBtu)	<0.0000058	<0.0000059	<0.0000056	<0.0000058
E <sub>Fc</sub>	HF Rate - Fc-based (lb/MMBtu)	<0.0000060	<0.0000062	<0.0000058	<0.0000060

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 SDA Inlet

### USEPA Method 26A (HCI) Sampling, Velocity and Moisture Parameters

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:56	09:13	10:40	
Stop Time (approx.)	07:56	10:13	11:40	
<b>Sampling Conditions</b>				
Y <sub>d</sub> Dry gas meter correction factor	0.9992	0.9992	0.9992	
P <sub>g</sub> Static pressure (in. H <sub>2</sub> O)	-1.2000	-1.2000	-1.2000	
A <sub>s</sub> Sample location area (ft <sup>2</sup> )	60.1320	60.1320	60.1320	
P <sub>bar</sub> Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
O <sub>2</sub> Oxygen (dry volume %)	9.7500	9.7300	9.7100	<b>9.7300</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.7900	10.0600	9.8400	<b>9.8967</b>
N <sub>2</sub> +CO Nitrogen plus carbon monoxide (dry volume %)	80.4600	80.2100	80.4500	<b>80.3733</b>
V <sub>lc</sub> Total Liquid collected (ml)	131.60	130.00	141.30	
V <sub>m</sub> Volume metered, meter conditions (ft <sup>3</sup> )	32.1000	33.5800	33.7400	
T <sub>m</sub> Dry gas meter temperature (°F)	72.7917	77.7083	78.9583	
T <sub>s</sub> Sample temperature (°F)	486.6667	494.0000	488.9167	<b>489.8611</b>
ΔH Meter box orifice pressure drop (in. H <sub>2</sub> O)	0.9992	1.0817	1.1150	
θ Total sampling time (min)	60.0	60.0	60.0	
<b>Flow Results</b>				
V <sub>wstd</sub> Volume of water collected (ft <sup>3</sup> )	6.1931	6.1178	6.6496	<b>6.3202</b>
V <sub>mstd</sub> Volume metered, standard (dscf)	32.0423	33.2198	33.3034	<b>32.8552</b>
P <sub>s</sub> Sample gas pressure, absolute (in. Hg)	30.0118	30.0118	30.0118	<b>30.0118</b>
P <sub>v</sub> Vapor pressure, actual (in. Hg)	30.0118	30.0118	30.0118	<b>30.0118</b>
B <sub>wo</sub> Moisture measured in sample (% by volume)	16.1973	15.5520	16.6435	<b>16.1309</b>
B <sub>ws</sub> Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	16.1973	15.5520	16.6435	<b>16.1309</b>
M <sub>d</sub> MW of sample gas, dry (lb/lb-mole)	29.9564	29.9988	29.9628	<b>29.9727</b>
M <sub>s</sub> MW of sample gas, wet (lb/lb-mole)	28.0198	28.1327	27.9718	<b>28.0414</b>

Comments:

Average includes 3 runs.

041508 123843  
 I O N @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 SDA Inlet

## USEPA Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:56	09:13	10:40	
Stop Time (approx.)		07:56	10:13	11:40	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.1	184.2	183.9	<b>184.1</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	305	305	<b>308</b>
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	<b>9,570</b>
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	<b>1,820</b>
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	<b>8,760</b>
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	9.7500	9.7300	9.7100	<b>9.7300</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.7900	10.0600	9.8400	<b>9.8967</b>
T <sub>s</sub>	Sample temperature (°F)	486.6667	494.0000	488.9167	<b>489.8611</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	16.1973	15.5520	16.6435	<b>16.1309</b>
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	32.0423	33.2198	33.3034	<b>32.8552</b>
<b>Laboratory Data</b>					
m <sub>n</sub>	Total HCl collected (mg)	617.4202	601.5257	646.3785	
<b>Hydrogen Chloride (HCl) Results</b>					
C <sub>sd</sub>	HCl Concentration (lb/dscf)	4.2488E-05	3.9927E-05	4.2796E-05	<b>4.1737E-05</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (lb/dscf)	5.2967E-05	4.9685E-05	5.3161E-05	<b>5.1938E-05</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (lb/dscf)	5.2079E-05	4.7626E-05	5.2191E-05	<b>5.0632E-05</b>
C <sub>sd</sub>	HCl Concentration (ppmdv)	449.2078	422.1308	452.4687	<b>441.2691</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (ppmdv)	559.9990	525.3015	562.0478	<b>549.1161</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (ppmdv)	550.6122	503.5358	551.7911	<b>535.3130</b>
C <sub>w</sub>	HCl Concentration (ppmwv)	376.4484	356.4809	377.1620	<b>370.0304</b>
C <sub>sd</sub>	HCl Concentration (mg/dscm)	680.3849	639.3732	685.3240	<b>668.3607</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/dscm)	848.1928	795.6390	851.2961	<b>831.7093</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/dscm)	833.9754	762.6718	835.7609	<b>810.8027</b>
C <sub>sd</sub>	HCl Concentration (mg/Nm <sup>3</sup> dry)	730.1692	686.1566	735.4696	<b>717.2651</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	910.2557	853.8564	913.5860	<b>892.5661</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	894.9980	818.4770	896.9142	<b>870.1297</b>
E <sub>Fd</sub>	HCl Rate - Fd-based (lb/MMBtu)	0.7622	0.7149	0.7650	<b>0.7474</b>
E <sub>Fc</sub>	HCl Rate - Fc-based (lb/MMBtu)	0.7899	0.7223	0.7916	<b>0.7679</b>

041509 123843  
 ION@\_@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

**EPA Modified Method 26A (HCl)  
 Sampling, Velocity and Moisture Parameters**

Run No.	1	2	3	Average
Date (2009)	Mar 18	Mar 18	Mar 18	
Start Time (approx.)	06:56	09:13	10:40	
Stop Time (approx.)	07:56	10:13	11:40	
<b>Sampling Conditions</b>				
Y <sub>d</sub> Dry gas meter correction factor	0.9937	0.9937	0.9937	
P <sub>g</sub> Static pressure (in. H <sub>2</sub> O)	-10.6000	-10.5000	-10.4000	
A <sub>s</sub> Sample location area (ft <sup>2</sup> )	64.0000	64.0000	64.0000	
P <sub>bar</sub> Barometric pressure (in. Hg)	30.10	30.10	30.10	<b>30.1000</b>
O <sub>2</sub> Oxygen (dry volume %)	10.2800	9.8500	9.7300	<b>9.9533</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	9.4000	9.7600	9.9300	<b>9.6967</b>
N <sub>2</sub> +CO Nitrogen plus carbon monoxide (dry volume %)	80.3200	80.3900	80.3400	<b>80.3500</b>
V <sub>lc</sub> Total Liquid collected (ml)	210.90	245.50	236.50	
V <sub>m</sub> Volume metered, meter conditions (ft <sup>3</sup> )	41.8900	41.8200	41.6400	
T <sub>m</sub> Dry gas meter temperature (°F)	75.3333	76.7917	79.1250	
T <sub>s</sub> Sample temperature (°F)	292.4167	285.7500	283.5833	<b>287.2500</b>
ΔH Meter box orifice pressure drop (in. H <sub>2</sub> O)	1.5000	1.5000	1.5000	
θ Total sampling time (min)	60.0	60.0	60.0	
<b>Flow Results</b>				
V <sub>wstd</sub> Volume of water collected (ft <sup>3</sup> )	9.9250	11.5532	11.1297	<b>10.8693</b>
V <sub>mstd</sub> Volume metered, standard (dscf)	41.4376	41.2560	40.9006	<b>41.1981</b>
P <sub>s</sub> Sample gas pressure, absolute (in. Hg)	29.3206	29.3279	29.3353	<b>29.3279</b>
P <sub>v</sub> Vapor pressure, actual (in. Hg)	29.3206	29.3279	29.3353	<b>29.3279</b>
B <sub>wo</sub> Moisture measured in sample (% by volume)	19.3233	21.8773	21.3908	<b>20.8638</b>
B <sub>ws</sub> Saturated moisture content (% by volume)	100.0000	100.0000	100.0000	<b>100.0000</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	19.3233	21.8773	21.3908	<b>20.8638</b>
M <sub>d</sub> MW of sample gas, dry (lb/lb-mole)	29.9152	29.9556	29.9780	<b>29.9496</b>
M <sub>s</sub> MW of sample gas, wet (lb/lb-mole)	27.6128	27.3400	27.4158	<b>27.4562</b>

Comments:

Average includes 3 runs.

041509 123843  
 ORL@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

### EPA Modified Method 26A HCl Parameters

Run No.		1	2	3	Average
Date (2009)		Mar 18	Mar 18	Mar 18	
Start Time (approx.)		06:56	09:13	10:40	
Stop Time (approx.)		07:56	10:13	11:40	
<b>Process Conditions</b>					
R <sub>p</sub>	Steam Production Rate (Klbs/hour)	184.1	184.2	183.9	<b>184.1</b>
P <sub>1</sub>	Fabric Filter Inlet Temperature (°F)	315	305	305	<b>308</b>
F <sub>d</sub>	Oxygen-based F-factor (dscf/MMBtu)	9,570	9,570	9,570	<b>9,570</b>
F <sub>c</sub>	Carbon dioxide-based F-factor (dscf/MMBtu)	1,820	1,820	1,820	<b>1,820</b>
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	<b>8,760</b>
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	10.2800	9.8500	9.7300	<b>9.9533</b>
CO <sub>2</sub>	Carbon dioxide (dry volume %)	9.4000	9.7600	9.9300	<b>9.6967</b>
T <sub>s</sub>	Sample temperature (°F)	292.4167	285.7500	283.5833	<b>287.2500</b>
B <sub>w</sub>	Actual water vapor in gas (% by volume)	19.3233	21.8773	21.3908	<b>20.8638</b>
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	41.4376	41.2560	40.9006	<b>41.1981</b>
<b>Laboratory Data</b>					
m <sub>n</sub>	Total HCl collected (mg)	41.0379	22.1246	34.7200	
<b>Hydrogen Chloride (HCl) Results</b>					
C <sub>sd</sub>	HCl Concentration (lb/dscf)	2.1837E-06	1.1825E-06	1.8718E-06	<b>1.7460E-06</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (lb/dscf)	2.8582E-06	1.4875E-06	2.3293E-06	<b>2.2250E-06</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (lb/dscf)	2.7877E-06	1.4539E-06	2.2620E-06	<b>2.1679E-06</b>
C <sub>sd</sub>	HCl Concentration (ppmdv)	23.0877	12.5020	19.7897	<b>18.4598</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (ppmdv)	30.2184	15.7265	24.6264	<b>23.5238</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (ppmdv)	29.4737	15.3713	23.9151	<b>22.9200</b>
C <sub>w</sub>	HCl Concentration (ppmwv)	18.6264	9.7669	15.5565	<b>14.6499</b>
C <sub>sd</sub>	HCl Concentration (mg/dscm)	34.9694	18.9359	29.9742	<b>27.9598</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/dscm)	45.7697	23.8198	37.3000	<b>35.6299</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/dscm)	44.6418	23.2819	36.2226	<b>34.7154</b>
C <sub>sd</sub>	HCl Concentration (mg/Nm <sup>3</sup> dry)	37.5281	20.3215	32.1674	<b>30.0057</b>
C <sub>sd7</sub>	HCl Concentration @7% O <sub>2</sub> (mg/Nm <sup>3</sup> dry)	49.1188	25.5627	40.0293	<b>38.2369</b>
C <sub>sd12</sub>	HCl Concentration @12% CO <sub>2</sub> (mg/Nm <sup>3</sup> dry)	47.9083	24.9854	38.8730	<b>37.2556</b>
E <sub>Fd</sub>	HCl Rate - Fd-based (lb/MMBtu)	0.0411	0.0214	0.0335	<b>0.0320</b>
E <sub>Fc</sub>	HCl Rate - Fc-based (lb/MMBtu)	0.0423	0.0221	0.0343	<b>0.0329</b>

041509 123843  
 O R L @ \_ @

Wheelabrator North Broward, Inc.  
 CleanAir Project No. 10735  
 Lime Silo

**Visible Emission Parameters**

Run	1	Time (min)	Time (sec)				Time (min)	Time (sec)					
			15	30	45	60		15	30	45	60		
Date (2009)	Mar 18	0	0	0	0	0	0	0	0	0	0	0	0
Start Time	9:30	1	0	0	0	0	1	0	0	0	0	0	0
		2	0	0	0	0	2	0	0	0	0	0	0
		3	0	0	0	0	3	0	0	0	0	0	0
		4	0	0	0	0	4	0	0	0	0	0	0
		5	0	0	0	0	5	0	0	0	0	0	0
		6	0	0	0	0	6	0	0	0	0	0	0
		7	0	0	0	0	7	0	0	0	0	0	0
		8	0	0	0	0	8	0	0	0	0	0	0
		9	0	0	0	0	9	0	0	0	0	0	0
		10	0	0	0	0	10	0	0	0	0	0	0
		11	0	0	0	0	11	0	0	0	0	0	0
		12	0	0	0	0	12	0	0	0	0	0	0
		13	0	0	0	0	13	0	0	0	0	0	0
		14	0	0	0	0	14	0	0	0	0	0	0
		15	0	0	0	0	15	0	0	0	0	0	0
		16	0	0	0	0	16	0	0	0	0	0	0
		17	0	0	0	0	17	0	0	0	0	0	0
		18	0	0	0	0	18	0	0	0	0	0	0
		19	0	0	0	0	19	0	0	0	0	0	0
		20	0	0	0	0	20	0	0	0	0	0	0
		21	0	0	0	0	21	0	0	0	0	0	0
		22	0	0	0	0	22	0	0	0	0	0	0
		23	0	0	0	0	23	0	0	0	0	0	0
		24	0	0	0	0	24	0	0	0	0	0	0
		25	0	0	0	0	25	0	0	0	0	0	0
		26	0	0	0	0	26	0	0	0	0	0	0
		27	0	0	0	0	27	0	0	0	0	0	0
		28	0	0	0	0	28	0	0	0	0	0	0
		29	0	0	0	0	29	0	0	0	0	0	0
		30	0	0	0	0	30	0	0	0	0	0	0
		31	0	0	0	0	31	0	0	0	0	0	0
		32	0	0	0	0	32	0	0	0	0	0	0
		33	0	0	0	0	33	0	0	0	0	0	0
		34	0	0	0	0	34	0	0	0	0	0	0
		35	0	0	0	0	35	0	0	0	0	0	0
		36	0	0	0	0	36	0	0	0	0	0	0
		37	0	0	0	0	37	0	0	0	0	0	0
		38	0	0	0	0	38	0	0	0	0	0	0
		39	0	0	0	0	39	0	0	0	0	0	0
		40	0	0	0	0	40	0	0	0	0	0	0
		41	0	0	0	0	41	0	0	0	0	0	0
		42	0	0	0	0	42	0	0	0	0	0	0
		43	0	0	0	0	43	0	0	0	0	0	0
		44	0	0	0	0	44	0	0	0	0	0	0
		45	0	0	0	0	45	0	0	0	0	0	0
		46	0	0	0	0	46	0	0	0	0	0	0
		47	0	0	0	0	47	0	0	0	0	0	0
		48	0	0	0	0	48	0	0	0	0	0	0
		49	0	0	0	0	49	0	0	0	0	0	0
		50	0	0	0	0	50	0	0	0	0	0	0
		51	0	0	0	0	51	0	0	0	0	0	0
		52	0	0	0	0	52	0	0	0	0	0	0
		53	0	0	0	0	53	0	0	0	0	0	0
		54	0	0	0	0	54	0	0	0	0	0	0
		55	0	0	0	0	55	0	0	0	0	0	0
		56	0	0	0	0	56	0	0	0	0	0	0
		57	0	0	0	0	57	0	0	0	0	0	0
		58	0	0	0	0	58	0	0	0	0	0	0
		59	0	0	0	0	59	0	0	0	0	0	0

Average Opacity 0  
 Minimum Reading 0  
 Maximum Reading 0  
 No. of Readings >5% 0

**QA/QC DATA**

**E**

**This Page Intentionally Left Blank**



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 SDA Inlet

**USEPA Method 29 (Mercury)  
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 18	Mar 18	Mar 18
Start Time (approx.)	06:41	09:19	12:12
Stop Time (approx.)	08:52	11:30	14:22
Total Duration of Test Run (min.)	131	131	130
Net Sampling Time (min.)	120	120	120

**Sampling System Calibration Summary**

D <sub>n</sub>	Nozzle ID No:	275-1	275-1	275-1
	Nozzle Diameter (in):	0.275	0.275	0.275
C <sub>p</sub>	Probe ID No:	67-10-5	67-10-5	67-10-5
	Pitot Coefficient:	0.8200	0.8200	0.8200
Y <sub>d</sub>	Meter Box ID. No:	61-8	61-8	61-8
	Meter Box Yd - Field Sheet	1.0079	1.0079	1.0079
	Meter Box Yd - Database	1.0079	1.0079	1.0079
	Meter Box ΔH@ - Field Sheet	1.7934	1.7934	1.7934
	Meter Box ΔH@ - Database	1.7934	1.7934	1.7934

**QA/QC**

**Final Leak Check**

(a) 4% of Sampling Rate (cfm)	0.0232	0.0230	0.0231
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0010	0.0010	0.0020

**Sample Volume**

V <sub>mstd</sub>	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	69.410	69.313	69.732

**Alternative Method 5 Post-Test Calibration (EPA ALT-009)**

√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.0196	1.0084	1.0120
Y <sub>qb</sub>	Alternative Meter Calibration Factor	0.9740	0.9663	0.9646
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	-3.4%	-4.1%	-4.3%

**Average  
-3.9%**

**Mean Isokinetic Sampling Rate Variation**

%I	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
	Actual Variation (%)	103.96	106.45	106.08

**Point-by-Point Isokinetic Variation**

	Number of points <90%	1	0	0
	Number of points >110%	2	2	0
	Number of points <80%	0	0	0
	Number of points >120%	1	0	0

041506 115435  
 LCN @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 18	Mar 18	Mar 18
Start Time (approx.)	06:41	09:19	12:12
Stop Time (approx.)	08:52	11:30	14:22
Total Duration of Test Run (min.)	131	131	130
Net Sampling Time (min.)	125	125	125

**Sampling System Calibration Summary**

	Nozzle ID No:	268-1	268-1	268-1
D <sub>n</sub>	Nozzle Diameter (in):	0.268	0.268	0.268
	Probe ID No:	67-8-4	67-8-4	67-8-4
C <sub>p</sub>	Pitot Coefficient:	0.8120	0.8120	0.8120
	Meter Box ID. No:	61-7	61-7	61-7
Y <sub>d</sub>	Meter Box Yd - Field Sheet	0.9886	0.9886	0.9886
	Meter Box Yd - Database	0.9886	0.9886	0.9886
	Meter Box ΔH@ - Field Sheet	1.7796	1.7796	1.7796
	Meter Box ΔH@ - Database	1.7796	1.7796	1.7796

**QA/QC**

**Final Leak Check**

(a) 4% of Sampling Rate (cfm)	0.0224	0.0223	0.0222
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0030	0.0030	0.0040

**Sample Volume**

V <sub>mstd</sub>	Minimum Volume Required (dscf)	30.00	30.00	30.00
	Actual Sample Volume (dscf)	68.757	67.601	67.882

**Alternative Method 5 Post-Test Calibration (EPA ALT-009)**

√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.0120	0.9987	1.0015
Y <sub>qa</sub>	Alternative Meter Calibration Factor	1.0014	0.9984	1.0002
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	1.3%	1.0%	1.2%

**Average  
1.1%**

**Mean Isokinetic Sampling Rate Variation**

	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	100.00	100.02	101.07

**Point-by-Point Isokinetic Variation**

	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

041509 115543  
LOO@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

**USEPA Method 13B (Total Fluorides)  
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 18	Mar 18	Mar 18
Start Time (approx.)	06:38	08:06	09:47
Stop Time (approx.)	07:50	09:21	11:00
Total Duration of Test Run (min.)	72	75	73
Net Sampling Time (min.)	63	63	63

**Sampling System Calibration Summary**

	Nozzle ID No:	272-1	272-1	272-1
$D_n$	Nozzle Diameter (in):	0.272	0.272	0.272
	Probe ID No:	67-8-7	67-8-7	67-8-7
$C_p$	Pitot Coefficient:	0.8250	0.8250	0.8250
	Meter Box ID. No:	66-6	66-6	66-6
$Y_d$	Meter Box Yd - Field Sheet	0.9916	0.9916	0.9916
	Meter Box Yd - Database	0.9916	0.9916	0.9916
	Meter Box $\Delta H@$ - Field Sheet	1.8053	1.8053	1.8053
	Meter Box $\Delta H@$ - Database	1.8053	1.8053	1.8053

**QA/QC**

	<u>Final Leak Check</u>			
	(a) 4% of Sampling Rate (cfm)	0.0242	0.0245	0.0246
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0010	0.0030	0.0010
	<u>Sample Volume</u>			
	Minimum Volume Required (dscf)	30.00	30.00	30.00
$V_{mstd}$	Actual Sample Volume (dscf)	37.647	37.756	37.691
	<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>			
$\sqrt{\Delta H}_{avg}$	Average of Square Root of $\Delta H$ (in. W.C.)	1.1062	1.1192	1.1313
$Y_{qa}$	Alternative Meter Calibration Factor	1.0001	1.0045	1.0152
	Variation from full-test $Y_d$ (average $\leq \pm 5\%$ )	0.9%	1.3%	2.4%
				<b>Average 1.5%</b>
	<u>Mean Isokinetic Sampling Rate Variation</u>			
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	99.92	99.58	99.39
	<u>Point-by-Point Isokinetic Variation</u>			
	Number of points <90%	2	1	2
	Number of points >110%	1	0	0
	Number of points <80%	1	0	0
	Number of points >120%	1	0	0

041509 115254  
 M I N @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 1 FF Outlet

### USEPA Method 23 (PCDD/F) QA/QC Results

Run No.	1	2	3
Date (2009)	Mar 16	Mar 17	Mar 17
Start Time (approx.)	11:07	06:08	10:54
Stop Time (approx.)	15:32	10:27	15:18
Total Duration of Test Run (min.)	265	259	264
Net Sampling Time (min.)	250	250	250

#### Sampling System Calibration Summary

	Nozzle ID No:	266-1	266-1	266-1
D <sub>n</sub>	Nozzle Diameter (in):	0.266	0.266	0.266
	Probe ID No:	67-8-17	67-8-17	67-8-17
C <sub>p</sub>	Pitot Coefficient:	0.8330	0.8330	0.8330
	Meter Box ID. No:	66-6	66-6	66-6
Y <sub>d</sub>	Meter Box Yd - Field Sheet	0.9916	0.9916	0.9916
	Meter Box Yd - Database	0.9916	0.9916	0.9916
	Meter Box ΔH@ - Field Sheet	1.8053	1.8053	1.8053
	Meter Box ΔH@ - Database	1.8053	1.8053	1.8053

#### QA/QC

<u>Final Leak Check</u>				
	(a) 4% of Sampling Rate (cfm)	0.0235	0.0235	0.0231
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0030	0.0020	0.0080
<u>Sample Volume</u>				
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V <sub>mstd</sub>	Actual Sample Volume (dscf)	142.320	144.128	138.822
<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>				
√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.0563	1.0657	1.0403
Y <sub>qa</sub>	Alternative Meter Calibration Factor	0.9984	0.9995	1.0032
	Variation from full-test Y <sub>q</sub> (average ≤ ±5%)	0.7%	0.8%	1.2%
				<b>Average 0.9%</b>
<u>Mean Isokinetic Sampling Rate Variation</u>				
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	99.66	99.11	98.36
<u>Point-by-Point Isokinetic Variation</u>				
	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

041509 115712  
 PNO@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 SDA Inlet

**USEPA Method 29 (Mercury)  
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 16	Mar 16	Mar 16
Start Time (approx.)	06:58	09:58	12:45
Stop Time (approx.)	09:20	12:09	14:59
Total Duration of Test Run (min.)	142	131	134
Net Sampling Time (min.)	120	120	120

**Sampling System Calibration Summary**

	Nozzle ID No:	275-1	275-1	275-1
D <sub>n</sub>	Nozzle Diameter (in):	0.275	0.275	0.275
	Probe ID No:	67-10-5	67-10-5	67-10-5
C <sub>p</sub>	Pitot Coefficient:	0.8200	0.8200	0.8200
	Meter Box ID. No:	61-8	61-8	61-8
Y <sub>d</sub>	Meter Box Yd - Field Sheet	1.0079	1.0079	1.0079
	Meter Box Yd - Database	1.0079	1.0079	1.0079
	Meter Box ΔH@ - Field Sheet	1.7934	1.7934	1.7934
	Meter Box ΔH@ - Database	1.7934	1.7934	1.7934

**QA/QC**

	<b><u>Final Leak Check</u></b>			
	(a) 4% of Sampling Rate (cfm)	0.0246	0.0250	0.0250
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0010	0.0010	0.0010
	<b><u>Sample Volume</u></b>			
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V <sub>mstd</sub>	Actual Sample Volume (dscf)	72.688	72.636	73.317
	<b><u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u></b>			
√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.0983	1.0973	1.0953
Y <sub>qa</sub>	Alternative Meter Calibration Factor	0.9923	0.9844	0.9774
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	-1.5%	-2.3%	-3.0%
				<b>Average -2.3%</b>
	<b><u>Mean Isokinetic Sampling Rate Variation</u></b>			
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	102.08	102.95	104.43
	<b><u>Point-by-Point Isokinetic Variation</u></b>			
	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

041509 122455  
 P.Q.K@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 16	Mar 16	Mar 16
Start Time (approx.)	06:56	09:58	12:45
Stop Time (approx.)	09:20	12:09	14:59
Total Duration of Test Run (min.)	144	131	134
Net Sampling Time (min.)	125	125	125

**Sampling System Calibration Summary**

	Nozzle ID No:	268-1	268-1	268-1
D <sub>n</sub>	Nozzle Diameter (in):	0.268	0.268	0.268
	Probe ID No:	67-8-4	67-8-4	67-8-4
C <sub>p</sub>	Pitot Coefficient:	0.8120	0.8120	0.8120
	Meter Box ID. No:	66-11	66-11	66-11
Y <sub>d</sub>	Meter Box Yd - Field Sheet	0.9897	0.9897	0.9897
	Meter Box Yd - Database	0.9897	0.9897	0.9897
	Meter Box ΔH@ - Field Sheet	1.8958	1.8958	1.8958
	Meter Box ΔH@ - Database	1.8958	1.8958	1.8958

**QA/QC**

<b><u>Final Leak Check</u></b>				
	(a) 4% of Sampling Rate (cfm)	0.0246	0.0242	0.0247
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0030	0.0030	0.0020
<b><u>Sample Volume</u></b>				
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V <sub>mstd</sub>	Actual Sample Volume (dscf)	74.275	73.052	74.632
<b><u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u></b>				
√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.1224	1.1135	1.1264
Y <sub>qa</sub>	Alternative Meter Calibration Factor	0.9897	0.9977	0.9874
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	0.0%	0.8%	-0.2%
				<b>Average 0.2%</b>
<b><u>Mean Isokinetic Sampling Rate Variation</u></b>				
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	100.75	98.71	100.49
<b><u>Point-by-Point Isokinetic Variation</u></b>				
	Number of points <90%	0	2	0
	Number of points >110%	1	1	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

041508 122719  
 S O P @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 2 FF Outlet

**USEPA Method 13B (Total Fluorides)  
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 17	Mar 17	Mar 17
Start Time (approx.)	11:43	13:15	14:40
Stop Time (approx.)	12:55	14:27	15:49
Total Duration of Test Run (min.)	72	72	69
Net Sampling Time (min.)	63	63	63

**Sampling System Calibration Summary**

	Nozzle ID No:	272-1	272-1	272-1
D <sub>n</sub>	Nozzle Diameter (in):	0.272	0.272	0.272
	Probe ID No:	67-8-7	67-8-7	67-8-7
C <sub>p</sub>	Pitot Coefficient:	0.8250	0.8250	0.8250
	Meter Box ID. No:	66-7	66-7	66-7
Y <sub>d</sub>	Meter Box Yd - Field Sheet	1.0028	1.0028	1.0028
	Meter Box Yd - Database	1.0028	1.0028	1.0028
	Meter Box ΔH@ - Field Sheet	1.7673	1.7673	1.7673
	Meter Box ΔH@ - Database	1.7673	1.7673	1.7673

**QA/QC**

	<b><u>Final Leak Check</u></b>			
	(a) 4% of Sampling Rate (cfm)	0.0270	0.0265	0.0264
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0020	0.0020	0.0020
	<b><u>Sample Volume</u></b>			
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V <sub>mstd</sub>	Actual Sample Volume (dscf)	41.113	40.378	40.451
	<b><u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u></b>			
√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.1956	1.1659	1.1583
Y <sub>qa</sub>	Alternative Meter Calibration Factor	0.9968	0.9886	0.9838
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	-0.6%	-1.4%	-1.9%
	<b><u>Mean Isokinetic Sampling Rate Variation</u></b>			
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	100.55	102.44	101.62
	<b><u>Point-by-Point Isokinetic Variation</u></b>			
	Number of points <90%	1	0	1
	Number of points >110%	1	0	1
	Number of points <80%	0	0	0
	Number of points >120%	1	0	0

042709 081319  
 NML@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 SDA Inlet

### USEPA Method 29 (Mercury) QA/QC Results

Run No.	1	2	3
Date (2009)	Mar 17	Mar 17	Mar 17
Start Time (approx.)	06:33	09:15	11:56
Stop Time (approx.)	08:42	11:24	14:07
Total Duration of Test Run (min.)	129	129	131
Net Sampling Time (min.)	120	120	120

#### Sampling System Calibration Summary

	Nozzle ID No:	275-1	275-1	275-1
D <sub>n</sub>	Nozzle Diameter (in):	0.275	0.275	0.275
	Probe ID No:	67-10-5	67-10-5	67-10-5
C <sub>p</sub>	Pitot Coefficient:	0.8200	0.8200	0.8200
	Meter Box ID. No:	66-16	66-16	66-16
Y <sub>d</sub>	Meter Box Yd - Field Sheet	0.9992	0.9992	0.9992
	Meter Box Yd - Database	0.9992	0.9992	0.9992
	Meter Box ΔH@ - Field Sheet	1.7371	1.7371	1.7371
	Meter Box ΔH@ - Database	1.7371	1.7371	1.7371

#### QA/QC

##### Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0255	0.0253	0.0253
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0010	0.0010	0.0010

##### Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V <sub>mstd</sub>	Actual Sample Volume (dscf)	74.140	71.872	72.153

##### Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.1419	1.1192	1.1209
Y <sub>qa</sub>	Alternative Meter Calibration Factor	1.0180	1.0166	1.0166
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	1.9%	1.7%	1.7%

**Average**  
**1.8%**

##### Mean Isokinetic Sampling Rate Variation

	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	98.34	96.86	98.33

##### Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0
	Number of points >110%	0	1	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

041509 123608  
 M J N @



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
 QA/QC Results**

Run No.	1	2	3
Date (2009)	Mar 17	Mar 17	Mar 17
Start Time (approx.)	06:33	09:15	11:56
Stop Time (approx.)	08:42	11:24	14:07
Total Duration of Test Run (min.)	129	129	131
Net Sampling Time (min.)	125	125	125

**Sampling System Calibration Summary**

	Nozzle ID No:	268-1	268-1	268-1
D <sub>n</sub>	Nozzle Diameter (in):	0.268	0.268	0.268
	Probe ID No:	67-8-4	67-8-4	67-8-4
C <sub>p</sub>	Pitot Coefficient:	0.8120	0.8120	0.8120
	Meter Box ID. No:	66-22	66-22	66-22
Y <sub>d</sub>	Meter Box Yd - Field Sheet	0.9937	0.9937	0.9937
	Meter Box Yd - Database	0.9937	0.9937	0.9937
	Meter Box ΔH@ - Field Sheet	1.7498	1.7498	1.7498
	Meter Box ΔH@ - Database	1.7498	1.7498	1.7498

**QA/QC**

<u>Final Leak Check</u>				
	(a) 4% of Sampling Rate (cfm)	0.0259	0.0258	0.0252
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0020	0.0020	0.0030
<u>Sample Volume</u>				
	Minimum Volume Required (dscf)	30.00	30.00	30.00
V <sub>mstd</sub>	Actual Sample Volume (dscf)	79.347	77.161	75.173
<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>				
√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.1290	1.1142	1.0919
Y <sub>qa</sub>	Alternative Meter Calibration Factor	0.9800	0.9825	0.9871
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	-1.4%	-1.1%	-0.7%
				<b>Average -1.1%</b>
<u>Mean Isokinetic Sampling Rate Variation</u>				
	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	101.59	100.80	101.11
<u>Point-by-Point Isokinetic Variation</u>				
	Number of points <90%	2	0	1
	Number of points >110%	2	0	1
	Number of points <80%	0	0	0
	Number of points >120%	2	0	0

041508 123808  
 MPO@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 10735  
 Unit 3 FF Outlet

### USEPA Method 13B (Total Fluorides) QA/QC Results

Run No.	1	2	3
Date (2009)	Mar 16	Mar 16	Mar 16
Start Time (approx.)	07:20	09:30	11:20
Stop Time (approx.)	00:00	10:47	12:41
Total Duration of Test Run (min.)	1000	77	81
Net Sampling Time (min.)	63	63	63

#### Sampling System Calibration Summary

	Nozzle ID No:	272-1	272-1	272-1
D <sub>n</sub>	Nozzle Diameter (in):	0.272	0.272	0.272
	Probe ID No:	67-8-7	67-8-7	67-8-7
C <sub>p</sub>	Pitot Coefficient:	0.8250	0.8250	0.8250
	Meter Box ID. No:	66-22	66-22	66-22
Y <sub>d</sub>	Meter Box Yd - Field Sheet	0.9937	0.9937	0.9937
	Meter Box Yd - Database	0.9937	0.9937	0.9937
	Meter Box ΔH@ - Field Sheet	1.7498	1.7498	1.7498
	Meter Box ΔH@ - Database	1.7498	1.7498	1.7498

#### QA/QC

##### Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0273	0.0275	0.0276
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0010	0.0070	0.0010

##### Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00
V <sub>mstd</sub>	Actual Sample Volume (dscf)	41.775	41.580	41.687

##### Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.1947	1.1930	1.1970
Y <sub>qa</sub>	Alternative Meter Calibration Factor	0.9832	0.9833	0.9818
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	-1.1%	-1.0%	-1.2%

**Average  
-1.1%**

##### Mean Isokinetic Sampling Rate Variation

	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	101.92	99.39	99.82

##### Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	1
	Number of points >110%	0	0	3
	Number of points <80%	0	0	1
	Number of points >120%	0	0	0

041509 123716  
 KKN@

# Nozzle Calibration Sheet


Client: Wheelabrator WS Broward	Project Number: 0735
Calibrated by:	Unit: -3
Date: 3/10-18/2009	Runs: 1-3

	Nozzle Identification	D <sub>1</sub> (inches)	D <sub>2</sub> (inches)	D <sub>3</sub> (inches)	ΔD (inches)	D <sub>ave</sub> (inches)
5/29	0.268-1	0.269	0.267	0.268	0.002	0.268
135	0.272-1	0.272	0.272	0.272	0.000	0.272
23	0.266-1	0.265	0.266	0.266	0.001	0.266
29.12	0.275-1	0.275	0.275	0.275	0.000	0.275

D<sub>1</sub>, D<sub>2</sub>, D<sub>3</sub> = three nozzle diameter measurements

ΔD = maximum difference between any two diameters  
ΔD = 0.004 inches\*

D<sub>ave</sub> = average of D<sub>1</sub>, D<sub>2</sub>, D<sub>3</sub>



\* (40 CFR 60, Appendix A, Method 5, Section 5.1)

# Meter Box Full Test Calibration

Meter Box No: 61-6

Date of Calibration: 7/23/2008

Meter Box  $Y_d$ : 0.9875

Calibration Conducted by: OLEG

Meter Box  $\Delta H@$ : 1.6981

Barometric Pressure: 29.34

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	$\Delta H$	$\Delta P$	$Y_{ds}$	Initial	Final	$V_{ds}$ Net	Initial	Final	$V_d$ Net	$T_{is}$ In	$T_{os}$ Out	$T_{ds}$ Avg.	$T_i$ In	$T_o$ Out	$T_d$ Avg.	$\Theta$	$Y_d$	$\Delta H@$
0.390	0.50	-1.30	1.0000	0.000	5.000	5.000	106.300	111.448	5.148	77.5	77.5	77.50	92.0	90.0	91.00	12.35	0.9912	1.7422
0.390	0.50	-1.30	1.0000	0.000	5.000	5.000	111.448	116.601	5.153	77.5	77.5	77.50	92.0	90.0	91.00	12.34	0.9902	1.7393
0.977	3.00	-1.80	1.0000	0.000	10.000	10.000	142.791	153.152	10.361	77.5	77.5	77.50	98.0	91.0	94.50	9.86	0.9838	1.6627
0.971	3.00	-1.90	1.0000	0.000	10.000	10.000	153.152	163.500	10.348	77.5	77.5	77.50	97.0	91.0	94.00	9.92	0.9839	1.6630
0.688	1.50	-1.50	1.0000	0.000	10.000	10.000	166.689	177.024	10.335	77.5	77.5	77.50	95.0	90.0	92.50	14.00	0.9871	1.6791
0.688	1.50	-1.50	1.0000	0.000	10.000	10.000	177.024	187.323	10.299	77.5	77.5	77.50	94.0	89.0	91.50	14.00	0.9888	1.6821
Averages																0.98750	1.69807	

Nomenclature	Equations
<p><math>P_b</math> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p><math>\Delta H</math> Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p><math>\Delta P</math> Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p><math>V_d</math> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>V_{ds}</math> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>T_d</math> Average Meter Box Temperature (°F)</p> <p><math>T_o</math> Outlet Meter Box Temperature (°F)</p> <p><math>T_{ds}</math> Average Standard Meter Temperature (°F)</p> <p><math>Y_d</math> Meter Correction Factor (unitless), <math>Y_1 \leq Y_{avg} \pm 0.02</math></p> <p><math>Y_{ds}</math> Standard Meter Correction Factor (unitless)</p> <p><math>\Delta H@</math> Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O) <math>\Delta H@ \leq \Delta H@_{avg} \pm 0.2</math></p> <p><math>\Theta</math> Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
5.8	5.0
10.6	10.0
15.8	15.0
20.4	20.0
25.6	25.0

# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 61-6

Office: \_\_\_\_\_

Calibrated by: OLEG

Client: \_\_\_\_\_

Date: 7/23/08

Job No: \_\_\_\_\_

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1	2	3	4	5	6	7
	Stack	Probe	Filter	Imp Out	Aux	DGM In	DGM Out
50	50	48	52				
100	100	98	102				
150	150	148	152				
200	201	198	202				
250	251	248	252				
300	300	298	302				
350	350	348	352				
400	400	398	401				
450	450	449	452				
500	501	500	501				
550	550	549	551				
600	600	599	601				

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>10/7/2007</u>
Calibration Report No: <u>R044701</u>	

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735      Meter No. 61-6      Orifice A-2  
 Location warehouse      Meter Yd 0.9875      Orifice K' 0.4506  
 Test Date 03/25/09      Meter ΔH@ 1.6981      Orifice Cal. Date 01/21/09  
 Operator r. vicere      Full Test Cal. Date 07/23/08

### Leak Checks

Negative Pressure

No movement of manometer in one-minute  Pass

Positive Pressure

No movement of manometer in one-minute  Pass

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 28.94 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dscf)	Meter Temperature		Ambient Temp. - T <sub>amb</sub> (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>n</sub> (dscf)	Avg Meter Temp. for Run - T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation ΔY
			Inlet (°F)	Outlet (°F)								
	0.0	838.10	71	68								
1	5.0	841.08	72	69	75	1.00	20	5.0	2.98	70.0	0.9796	0.1%
2	10.0	844.06	72	69	76	1.00	20	5.0	2.98	70.5	0.9796	0.1%
3	15.0	847.05	73	70	76	1.00	20	5.0	2.99	71.0	0.9772	-0.2%
<b>Average Y<sub>i</sub></b>											<b>0.9788</b>	
<b>Cal. Error</b>											<b>-0.9%</b>	

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

# Meter Box Full Test Calibration

Meter Box No: 61-7

Date of Calibration: 11/17/2008

Meter Box  $Y_d$ : 0.9886

Calibration Conducted by: OLEG LAVROV

Meter Box  $\Delta H@$ : 1.7796

Barometric Pressure: 29.42

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	$\Delta H$	$\Delta P$	$Y_{ds}$	Initial	Final	$V_{ds}$ Net	Initial	Final	$V_d$ Net	$T_{is}$ In	$T_{os}$ Out	$T_{ds}$ Avg.	$T_i$ In	$T_o$ Out	$T_d$ Avg.	$\Theta$	$Y_d$	$\Delta H@$
0.952	3.00	-1.80	1.0000	0.000	10.000	10.000	508.848	519.093	10.245	68.0	68.0	68.00	81.0	76.0	78.50	10.32	0.9836	1.8019
0.951	3.00	-1.80	1.0000	0.000	10.000	10.000	519.093	529.355	10.262	68.0	68.0	68.00	84.0	77.0	80.50	10.34	0.9857	1.8055
0.395	0.50	-1.20	1.0000	0.000	5.000	5.000	534.052	539.168	5.116	68.0	68.0	68.00	79.0	77.0	78.00	12.43	0.9916	1.7395
0.396	0.50	-1.20	1.0000	0.000	5.000	5.000	539.168	544.282	5.114	68.0	68.0	68.00	79.0	77.0	78.00	12.42	0.9920	1.7367
0.673	1.50	-1.60	1.0000	0.000	10.000	10.000	548.819	559.068	10.249	68.0	68.0	68.00	82.0	77.0	79.50	14.60	0.9893	1.7999
0.674	1.50	-1.60	1.0000	0.000	10.000	10.000	559.068	569.323	10.255	68.0	68.0	68.00	82.0	78.0	80.00	14.59	0.9896	1.7941
Averages																	0.98863	1.77958

E-17

Nomenclature	Equations
<p><math>P_b</math> Barometric Pressure (in. Hg)</p> <p><math>Q</math> Flow Rate (cfm)</p> <p><math>\Delta H</math> Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p><math>\Delta P</math> Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p><math>V_d</math> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>V_{ds}</math> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>T_d</math> Average Meter Box Temperature (°F)</p> <p><math>T_o</math> Outlet Meter Box Temperature (°F)</p> <p><math>T_{ds}</math> Average Standard Meter Temperature (°F)</p> <p><math>Y_d</math> Meter Correction Factor (unitless), <math>Y_1 \leq Y_{avg} \pm 0.02</math></p> <p><math>Y_{ds}</math> Standard Meter Correction Factor (unitless)</p> <p><math>\Delta H@</math> Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O) <math>\Delta H@_i \leq \Delta H@_{avg} \pm 0.2</math></p> <p><math>\Theta</math> Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
5.3	5.0
10.3	10.0
15.0	15.0
19.7	20.0
24.8	25.0

# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 61-7 Office: \_\_\_\_\_  
 Calibrated by: OLEG LAVROV Client: \_\_\_\_\_  
 Date: 11/17/08 Job No: \_\_\_\_\_  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	50	48	49				
100	100	98	99				
150	150	148	149				
200	200	198	199				
250	250	248	248				
300	300	298	299				
350	350	348	349				
400	400	398	399				
450	450	448	449				
500	500	498	499				
550	550	548	549				
600	600	598	599				

*Tolerance = ±2°F difference from reference setting.*

### Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	



## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735      Meter No. 61-7      Orifice B-3  
 Location warehouse      Meter Yd 0.9886      Orifice K' 0.4534  
 Test Date 03/25/09      Meter ΔH@ 1.7796      Orifice Cal. Date 02/13/09  
 Operator r. vicere      Full Test Cal. Date 11/17/08

### Leak Checks

Negative Pressure  Pass  
*No movement of manometer in one-minute*  
 Positive Pressure  Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 28.94 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. - T <sub>amb</sub> (°F)	Orifice ΔH (In. W.C.)	Vacuum (In. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (dcf)	Avg Meter Temp. for Run T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	747.20	73	70								
1	5.0	750.09	73	70	73	1.00	19	5.0	2.89	71.5	1.0212	-0.3%
2	10.0	752.97	74	71	74	1.00	19	5.0	2.88	72.0	1.0247	0.1%
3	15.0	755.85	75	72	74	1.00	19	5.0	2.88	73.0	1.0266	0.2%

Average Y <sub>i</sub>	1.0242
Cal. Error	3.6%

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

# Meter Box Full Test Calibration

Meter Box No: 61-8

Date of Calibration: 10/10/2008

Meter Box  $Y_d$ : 1.0079

Calibration Conducted by: OLEG LAVROV

Meter Box  $\Delta H@$ : 1.7934

Barometric Pressure: 29.41

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	$\Delta H$	$\Delta P$	$Y_{ds}$	Initial	Final	$V_{ds}$ Net	Initial	Final	$V_d$ Net	$T_{is}$ In	$T_{os}$ Out	$T_{ds}$ Avg.	$T_i$ In	$T_o$ Out	$T_d$ Avg.	$\Theta$	$Y_d$	$\Delta H@$
0.962	3.00	-1.70	1.0000	0.000	10.000	10.000	178.888	188.822	9.934	70.0	70.0	70.00	78.0	73.0	75.50	10.18	1.0052	1.7772
0.957	3.00	-1.70	1.0000	0.000	10.000	10.000	188.822	198.772	9.950	70.0	70.0	70.00	81.0	74.0	77.50	10.23	1.0074	1.7913
0.381	0.50	-1.00	1.0000	0.000	5.000	5.000	216.571	221.528	4.957	70.5	70.5	70.50	79.0	76.0	77.50	12.82	1.0182	1.8720
0.382	0.50	-1.00	1.0000	0.000	5.000	5.000	221.528	226.500	4.972	70.5	70.5	70.50	80.0	77.0	78.50	12.81	1.0170	1.8856
0.686	1.50	-1.30	1.0000	0.000	10.000	10.000	231.519	241.649	10.130	70.5	70.5	70.50	84.0	79.0	81.50	14.26	1.0006	1.7275
0.685	1.50	-1.30	1.0000	0.000	10.000	10.000	241.849	251.820	10.171	70.5	70.5	70.50	86.0	80.0	83.00	14.27	0.9993	1.7267
Averages																1.00794	1.79338	

E - 20

Nomenclature	Equations
<p><math>P_b</math> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p><math>\Delta H</math> Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p><math>\Delta P</math> Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p><math>V_d</math> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>V_{ds}</math> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>T_d</math> Average Meter Box Temperature (°F)</p> <p><math>T_o</math> Outlet Meter Box Temperature (°F)</p> <p><math>T_{ds}</math> Average Standard Meter Temperature (°F)</p> <p><math>Y_d</math> Meter Correction Factor (unitless), <math>Y_i \leq Y_{avg} \pm 0.02</math></p> <p><math>Y_{ds}</math> Standard Meter Correction Factor (unitless)</p> <p><math>\Delta H@</math> Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)  <math>\Delta H@_i \leq \Delta H@_{avg} \pm 0.2</math></p> <p><math>\Theta</math> Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Standard (in. Hg)	Gauge (in. Hg)
5.2	5.0
9.7	10.0
14.3	15.0
19.7	20.0
24.1	25.0

# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 61-8

Office: \_\_\_\_\_

Calibrated by: OLEG LAVROV

Client: \_\_\_\_\_

Date: 10/10/08

Job No: \_\_\_\_\_

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	50	50				
100	99	100	100				
150	149	150	150				
200	199	200	200				
250	249	250	250				
300	299	300	300				
350	349	350	350				
400	399	400	400				
450	449	450	450				
500	499	500	500				
550	549	550	551				
600	599	600	601				

*Tolerance = ±2°F difference from reference setting.*

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735      Meter No. 61-8      Orifice A-4  
 Location warehouse      Meter Yd 1.0079      Orifice K' 0.4959  
 Test Date 03/25/09      Meter ΔH@ 1.7934      Orifice Cal. Date 01/21/09  
 Operator r. vicere      Full Test Cal. Date 10/10/08

### Leak Checks

Negative Pressure  Pass  
 No movement of manometer in one-minute  
 Positive Pressure  Pass  
 No movement of manometer in one-minute

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 28.94 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. T <sub>amb</sub> (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - G (minutes)	Net Meter Volume for Run - V <sub>m</sub> (dcf)	Avg Meter Temp. for Run T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY
			Inlet (°F)	Outlet (°F)								
	0.0	255.80	73	70								
1	5.0	259.11	74	70	75	1.30	18	5.0	3.31	71.8	0.9731	-0.1%
2	10.0	262.41	74	71	75	1.30	18	5.0	3.30	72.3	0.9769	0.3%
3	15.0	265.73	75	71	75	1.30	18	5.0	3.32	72.8	0.9719	-0.2%

Average Y <sub>i</sub>	0.9740
Cal. Error	-3.4%

### Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec. : } \text{Cal. Error} \leq \pm 5\%$$

E - 22

# Meter Box Full Test Calibration

Meter Box No: 66-6

Date of Calibration: 2/23/2009

Meter Box  $Y_d$ : 0.9916

Calibration Conducted by: M. Vaquero

Meter Box  $\Delta H@$ : 1.8053

Barometric Pressure: 29.88

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	$\Delta H$	$\Delta P$	$Y_{ds}$	Initial	Final	$V_{ds}$ Net	Initial	Final	$V_d$ Net	$T_{is}$ In	$T_{os}$ Out	$T_{ds}$ Avg.	$T_i$ In	$T_o$ Out	$T_d$ Avg.	$\Theta$	$Y_d$	$\Delta H@$
0.979	3.00	-1.90	1.0000	0.000	10.000	10.000	562.625	572.791	10.166	65.0	65.0	65.00	75.0	73.0	74.00	10.25	0.9886	1.7401
0.979	3.00	-1.90	1.0000	0.000	10.000	10.000	572.791	582.945	10.154	65.0	65.0	65.00	75.0	73.0	74.00	10.26	0.9897	1.7435
0.384	0.50	-1.20	1.0000	0.000	5.000	5.000	625.330	630.420	5.090	65.0	65.0	65.00	73.0	72.0	72.50	13.07	0.9922	1.8897
0.384	0.50	-1.20	1.0000	0.000	5.000	5.000	630.420	635.515	5.095	65.0	65.0	65.00	73.0	72.0	72.50	13.07	0.9912	1.8897
0.684	1.50	-1.50	1.0000	0.000	10.000	10.000	639.532	649.665	10.133	65.0	65.0	65.00	74.0	72.0	73.00	14.68	0.9945	1.7880
0.685	1.50	-1.50	1.0000	0.000	10.000	10.000	649.665	659.807	10.142	65.0	65.0	65.00	74.0	72.0	73.00	14.65	0.9937	1.7807
Averages																0.99165	1.80528	

E - 23

Nomenclature	Equations
<p><math>P_b</math> Barometric Pressure (in. Hg)</p> <p><math>Q</math> Flow Rate (cfm)</p> <p><math>\Delta H</math> Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p><math>\Delta P</math> Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p><math>V_d</math> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>V_{ds}</math> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>T_d</math> Average Meter Box Temperature (°F)</p> <p><math>T_o</math> Outlet Meter Box Temperature (°F)</p> <p><math>T_{ds}</math> Average Standard Meter Temperature (°F)</p> <p><math>Y_d</math> Meter Correction Factor (unitless), <math>Y_i \leq Y_{avg} \pm 0.02</math></p> <p><math>Y_{ds}</math> Standard Meter Correction Factor (unitless)</p> <p><math>\Delta H@</math> Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p><math>\Delta H@_i \leq \Delta H@_{avg} \pm 0.2</math></p> <p><math>\Theta</math> Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
5.0	5.0
10.2	10.0
15.2	15.0
20.0	20.0
24.4	24.5

# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-6 Office: \_\_\_\_\_  
 Calibrated by: M. Vaquero Client: \_\_\_\_\_  
 Date: 2/23/09 Job No: \_\_\_\_\_  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	48	48	49				
100	98	98	99				
150	148	148	149				
200	198	199	199				
250	248	249	249				
300	298	298	299				
350	348	349	349				
400	398	399	399				
450	448	449	449				
500	498	499	499				
550	548	549	549				
600	598	599	599				

*Tolerance = ±2°F difference from reference setting.*

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>10/13/2009</u>
Calibration Report No: <u>R044701</u>	

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735      Meter No. 66-6      Orifice A-4  
 Location warehouse      Meter Yd 0.9916      Orifice K' 0.4959  
 Test Date 03/24/09      Meter ΔH@ 1.8053      Orifice Cal. Date 01/21/09  
 Operator r. vicere      Full Test Cal. Date 02/23/09

**Leak Checks**

Negative Pressure  Pass  
*No movement of manometer in one-minute*

Positive Pressure  Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 28.95 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (scf)	Meter Temperature		Ambient Temp - T <sub>amb</sub> (°F)	Orifice ΔH (In. W.C.)	Vacuum (In. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (scf)	Avg Meter Temp for Run T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	697.90	72	71								
1	5.0	701.17	72	69	77	1.30	17	5.0	3.27	71.0	0.9817	0.7%
2	10.0	704.48	72	69	79	1.30	17	5.0	3.31	70.5	0.9672	-0.8%
3	15.0	707.76	73	70	80	1.30	17	5.0	3.28	71.0	0.9760	0.1%

**Average Y<sub>i</sub>**      0.9750  
**Cal. Error**      -1.7%

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec. : } \text{Cal. Error} \leq \pm 5\%$$

E - 25

# Meter Box Full Test Calibration

Meter Box No: 66-7

Date of Calibration: 2/20/2009

Meter Box  $Y_d$ : 1.0028

Calibration Conducted by: Martin Vaquero

Meter Box  $\Delta H@$ : 1.7673

Barometric Pressure: 29.36

Standard Meter Gas Volume (ft <sup>3</sup> )				Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results				
Q	$\Delta H$	$\Delta P$	$Y_{ds}$	Initial	Final	$V_{ds}$ Net	Initial	Final	$V_d$ Net	$T_{is}$ In	$T_{os}$ Out	$T_{ds}$ Avg.	$T_i$ In	$T_o$ Out	$T_d$ Avg.	$\Theta$	$Y_d$	$\Delta H@$
0.960	3.00	-1.80	1.0000	0.000	10.000	10.000	930.751	940.869	10.118	65.5	65.5	65.50	80.0	73.0	76.50	10.27	0.9970	1.7812
0.961	3.00	-1.80	1.0000	0.000	10.000	10.000	940.869	950.970	10.101	65.5	65.5	65.50	80.0	73.0	76.50	10.26	0.9987	1.7777
0.394	0.50	-1.00	1.0000	0.000	5.000	5.000	954.620	959.686	5.066	65.5	65.5	65.50	77.0	74.0	75.50	12.51	1.0020	1.7587
0.394	0.50	-1.00	1.0000	0.000	5.000	5.000	959.686	964.737	5.051	65.5	65.5	65.50	76.0	74.0	75.00	12.51	1.0040	1.7587
0.681	1.50	-1.40	1.0000	0.000	10.000	10.000	980.882	990.970	10.088	65.5	65.5	65.50	80.0	75.0	77.50	14.47	1.0066	1.7614
0.680	1.50	-1.40	1.0000	0.000	10.000	10.000	990.970	1001.037	10.067	65.5	65.5	65.50	80.0	75.0	77.50	14.49	1.0087	1.7663
Averages																1.00282	1.76732	

E - 26

Nomenclature	Equations
<p><math>P_b</math> Barometric Pressure (in. Hg)</p> <p><math>Q</math> Flow Rate (cfm)</p> <p><math>\Delta H</math> Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p><math>\Delta P</math> Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p><math>V_d</math> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>V_{ds}</math> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>T_d</math> Average Meter Box Temperature (°F)</p> <p><math>T_o</math> Outlet Meter Box Temperature (°F)</p> <p><math>T_{ds}</math> Average Standard Meter Temperature (°F)</p> <p><math>Y_d</math> Meter Correction Factor (unitless), <math>Y_i \leq Y_{avg} \pm 0.02</math></p> <p><math>Y_{ds}</math> Standard Meter Correction Factor (unitless)</p> <p><math>\Delta H@</math> Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p><math>\Delta H@_i \leq \Delta H@_{avg} \pm 0.2</math></p> <p><math>\Theta</math> Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
5.0	5.0
10.2	10.0
15.2	15.0
19.8	20.0
25.2	25.0



# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-7 Office: \_\_\_\_\_  
 Calibrated by: Martin Vaquero Client: \_\_\_\_\_  
 Date: 2/20/09 Job No: \_\_\_\_\_  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	51	51	51				
100	100	100	101				
150	151	151	151				
200	201	201	201				
250	252	250	251				
300	302	301	301				
350	352	351	351				
400	401	400	401				
450	450	450	451				
500	500	500	501				
550	550	550	551				
600	601	600	601				

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735      Meter No. 66-7      Orifice B-5  
 Location warehouse      Meter Yd 1.0028      Orifice K' 0.5612  
 Test Date 03/25/09      Meter ΔH@ 1.7673      Orifice Cal. Date 02/13/09  
 Operator r. vicere      Full Test Cal. Date 02/20/09

### Leak Checks

Negative Pressure

No movement of manometer in one-minute  Pass

Positive Pressure

No movement of manometer in one-minute  Pass

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 28.94 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. T <sub>amb</sub> (°F)	Orifice ΔH (In. W.C.)	Vacuum (In. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (dcf)	Avg Meter Temp. for Run T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	632.90	73	70								
1	5.0	636.47	73	70	71	1.50	18	5.0	3.57	71.5	1.0238	-0.2%
2	10.0	640.02	74	70	72	1.50	18	5.0	3.55	71.8	1.0291	0.3%
3	15.0	643.59	74	71	72	1.50	18	5.0	3.57	72.3	1.0243	-0.1%
<b>Average Y<sub>i</sub></b>											1.0257	
<b>Cal. Error</b>											2.3%	

### Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times \left(P_b + \frac{\Delta H}{13.6}\right) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

# Meter Box Full Test Calibration

Meter Box No: 66-11

Date of Calibration: 10/29/2008

Meter Box  $Y_d$ : 0.9897

Calibration Conducted by: OLEG LAVROV

Meter Box  $\Delta H@$ : 1.8958

Barometric Pressure: 29.38

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	$\Delta H$	$\Delta P$	$Y_{ds}$	Initial	Final	$V_{ds}$ Net	Initial	Final	$V_d$ Net	$T_{is}$ In	$T_{os}$ Out	$T_{ds}$ Avg.	$T_i$ In	$T_o$ Out	$T_d$ Avg.	$\Theta$	$Y_d$	$\Delta H@$
0.938	3.00	-1.90	1.0000	0.000	10.000	10.000	17.805	27.997	10.192	69.0	69.0	69.00	83.0	75.0	79.00	10.44	0.9875	1.8570
0.938	3.00	-1.90	1.0000	0.000	10.000	10.000	27.997	38.210	10.213	69.0	69.0	69.00	84.0	76.0	80.00	10.44	0.9873	1.8536
0.371	0.50	-1.30	1.0000	0.000	5.000	5.000	42.333	47.433	5.100	69.0	69.0	69.00	80.0	77.0	78.50	13.22	0.9935	1.9777
0.371	0.50	-1.30	1.0000	0.000	5.000	5.000	47.433	52.542	5.109	69.0	69.0	69.00	80.0	77.0	78.50	13.21	0.9918	1.9747
0.660	1.50	-1.50	1.0000	0.000	10.000	10.000	67.288	77.585	10.297	69.0	69.0	69.00	85.0	80.0	82.50	14.84	0.9885	1.8587
0.661	1.50	-1.50	1.0000	0.000	10.000	10.000	77.585	87.887	10.302	69.0	69.0	69.00	86.0	81.0	83.50	14.83	0.9898	1.8528
Averages																0.98974	1.89577	

E - 29

Nomenclature	Equations
<p><math>P_b</math> Barometric Pressure (in. Hg)</p> <p><math>Q</math> Flow Rate (cfm)</p> <p><math>\Delta H</math> Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p><math>\Delta P</math> Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p><math>V_d</math> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>V_{ds}</math> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>T_d</math> Average Meter Box Temperature (°F)</p> <p><math>T_o</math> Outlet Meter Box Temperature (°F)</p> <p><math>T_{ds}</math> Average Standard Meter Temperature (°F)</p> <p><math>Y_d</math> Meter Correction Factor (unitless), <math>Y_i \leq Y_{avg} \pm 0.02</math></p> <p><math>Y_{ds}</math> Standard Meter Correction Factor (unitless)</p> <p><math>\Delta H@</math> Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O) <math>\Delta H@_i \leq \Delta H@_{avg} \pm 0.2</math></p> <p><math>\Theta</math> Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
4.5	5.0
9.7	10.0
14.9	15.0
20.3	20.0
25.3	25.0

# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-11 Office: \_\_\_\_\_  
 Calibrated by: OLEG LAVROV Client: \_\_\_\_\_  
 Date: 10/29/08 Job No: \_\_\_\_\_  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1	2	3	4	5	6	7
	Stack	Probe	Filter	Imp Out	Aux	DGM In	DGM Out
50	49	50	50				
100	99	100	100				
150	149	150	150				
200	199	200	200				
250	249	250	250				
300	299	300	300				
350	349	350	350				
400	399	400	399				
450	449	450	449				
500	499	499	499				
550	549	549	549				
600	599	600	599				

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10715      Meter No. 66-11      Orifice A-2  
 Location warehouse      Meter Yd 0.9897      Orifice K' 0.4506  
 Test Date 03/26/09      Meter ΔH@ 1.8958      Orifice Cal. Date 01/21/09  
 Operator r. vicere      Full Test Cal. Date 10/29/08

### Leak Checks

Negative Pressure  Pass  
*No movement of manometer in one-minute*  
 Positive Pressure  Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 29.07 in. Hg

Run	Elapsed Time (minutes)	Water Volume (cc)	Meter Temperature		Ambient Temp. T <sub>amb</sub> (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (ccf)	Avg Meter Temp. for Run T <sub>m,2</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	587.30	72	69								
1	5.0	590.28	73	70	75	1.10	20	5.0	2.98	71.0	0.9812	0.0%
2	10.0	593.26	73	70	76	1.10	20	5.0	2.98	71.5	0.9812	0.0%
3	15.0	596.24	74	71	77	1.10	20	5.0	2.98	72.0	0.9812	0.0%

Average Y <sub>i</sub>	0.9812
Cal. Error	-0.9%

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \Delta H / 13.6) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E - 31

# Meter Box Full Test Calibration

Meter Box No: 66-16

Date of Calibration: 9/13/2008

Meter Box  $Y_d$ : 0.9992

Calibration Conducted by: OLEG

Meter Box  $\Delta H@$ : 1.7371

Barometric Pressure: 29.17

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	$\Delta H$	$\Delta P$	$Y_{ds}$	Initial	Final	$V_{ds}$ Net	Initial	Final	$V_d$ Net	$T_{is}$ In	$T_{os}$ Out	$T_{ds}$ Avg.	$T_i$ In	$T_o$ Out	$T_d$ Avg.	$\Theta$	$Y_d$	$\Delta H@$
0.961	3.00	-1.90	1.0000	0.000	10.000	10.000	171.536	181.553	10.017	75.5	75.5	75.50	83.0	78.0	80.50	10.00	0.9953	1.7487
0.958	3.00	-1.90	1.0000	0.000	10.000	10.000	181.553	191.593	10.040	75.5	75.5	75.50	85.0	79.0	82.00	10.03	0.9957	1.7559
0.391	0.50	-1.30	1.0000	0.000	5.000	5.000	197.931	202.959	5.028	75.5	75.5	75.50	82.0	80.0	81.00	12.29	1.0001	1.7543
0.390	0.50	-1.30	1.0000	0.000	5.000	5.000	202.959	207.985	5.026	75.5	75.5	75.50	82.0	80.0	81.00	12.31	1.0005	1.7601
0.687	1.50	-1.50	1.0000	0.000	10.000	10.000	210.719	220.760	10.041	75.5	75.5	75.50	85.0	81.0	83.00	13.99	1.0023	1.7018
0.687	1.50	-1.50	1.0000	0.000	10.000	10.000	220.760	230.810	10.050	75.5	75.5	75.50	85.0	81.0	83.00	13.99	1.0014	1.7018
Averages																0.99920	1.73709	

E-32

Nomenclature	Equations
<p><math>P_b</math> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p><math>\Delta H</math> Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p><math>\Delta P</math> Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p><math>V_d</math> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>V_{ds}</math> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>T_d</math> Average Meter Box Temperature (°F)</p> <p><math>T_o</math> Outlet Meter Box Temperature (°F)</p> <p><math>T_{ds}</math> Average Standard Meter Temperature (°F)</p> <p><math>Y_d</math> Meter Correction Factor (unitless), <math>Y_1 \leq Y_{avg} \pm 0.02</math></p> <p><math>Y_{ds}</math> Standard Meter Correction Factor (unitless)</p> <p><math>\Delta H@</math> Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p><math>\Delta H@ \leq \Delta H@_{avg} \pm 0.2</math></p> <p><math>\Theta</math> Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Standard (in. Hg)	Gauge (in. Hg)
5.3	5.0
9.9	10.0
15.3	15.0
20.3	20.0
24.8	25.0

# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-16 Office: \_\_\_\_\_  
 Calibrated by: OLEG Client: \_\_\_\_\_  
 Date: 9/13/08 Job No: \_\_\_\_\_  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	49	51				
100	99	100	101				
150	149	150	150				
200	199	200	200				
250	249	250	250				
300	299	300	300				
350	349	350	350				
400	399	400	400				
450	449	450	450				
500	499	500	500				
550	549	550	550				
600	599	600	600				

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

### Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>10/7/2007</u>
Calibration Report No: <u>R044701</u>	

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735      Meter No. 66-16      Orifice B-3  
 Location warehouse      Meter Yd 0.9992      Orifice K' 0.4534  
 Test Date 03/24/09      Meter ΔH@ 1.7371      Orifice Cal. Date 02/13/09  
 Operator r. vicere      Full Test Cal. Date 09/13/08

**Leak Checks**

Negative Pressure  Pass  
*No movement of manometer in one-minute*

Positive Pressure  Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 28.95 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (ccf)	Meter Temperature		Ambient Temp. (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (ccf)	Avg. Meter Temp. for Run T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	748.10	71	68								
1	5.0	750.92	72	68	79	1.00	21	5.0	2.82	69.8	1.0372	0.4%
2	10.0	753.76	73	69	80	1.00	21	5.0	2.84	70.5	1.0304	-0.3%
3	15.0	756.60	74	69	80	1.00	21	5.0	2.84	71.3	1.0319	-0.1%

Average Y<sub>i</sub>      1.0332  
 Cal. Error      3.4%

### Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}}{\bar{Y}} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y} - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

E - 34





# Meter Box Full Test Calibration

Meter Box No: 66-22

Date of Calibration: 11/13/2008

Meter Box  $Y_d$ : 0.9937

Calibration Conducted by: Martin Vaquero

Meter Box  $\Delta H@$ : 1.7498

Barometric Pressure: 29.01

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	$\Delta H$	$\Delta P$	$Y_{ds}$	Initial	Final	$V_{ds}$ Net	Initial	Final	$V_d$ Net	$T_{is}$ In	$T_{os}$ Out	$T_{ds}$ Avg.	$T_i$ In	$T_o$ Out	$T_d$ Avg.	$\Theta$	$Y_d$	$\Delta H@$
0.966	3.00	-1.90	1.0000	0.000	10.000	10.000	937.916	948.134	10.218	69.5	69.5	69.50	87.0	79.0	83.00	10.00	0.9912	1.7160
0.966	3.00	-1.90	1.0000	0.000	11.000	11.000	948.134	959.364	11.230	69.5	69.5	69.50	87.0	80.0	83.50	11.00	0.9930	1.7128
0.385	0.50	-1.10	1.0000	0.000	5.000	5.000	962.944	968.050	5.106	69.5	69.5	69.50	80.0	79.0	79.50	12.55	0.9937	1.8018
0.385	0.50	-1.10	1.0000	0.000	5.000	5.000	968.050	973.153	5.103	69.5	69.5	69.50	80.0	79.0	79.50	12.55	0.9943	1.8018
0.679	1.50	-1.40	1.0000	0.000	10.000	10.000	974.427	984.641	10.214	69.5	69.5	69.50	85.0	79.0	82.00	14.23	0.9948	1.7373
0.680	1.50	-1.40	1.0000	0.000	10.000	10.000	984.641	994.859	10.218	69.5	69.5	69.50	85.0	80.0	82.50	14.21	0.9954	1.7293
Averages																0.99374	1.74982	

E - 35

Nomenclature	Equations
<p><math>P_b</math> Barometric Pressure (in. Hg)</p> <p><math>Q</math> Flow Rate (cfm)</p> <p><math>\Delta H</math> Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p><math>\Delta P</math> Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p><math>V_d</math> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>V_{ds}</math> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p><math>T_d</math> Average Meter Box Temperature (°F)</p> <p><math>T_o</math> Outlet Meter Box Temperature (°F)</p> <p><math>T_{ds}</math> Average Standard Meter Temperature (°F)</p> <p><math>Y_d</math> Meter Correction Factor (unitless), <math>Y_i \leq Y_{avg} \pm 0.02</math></p> <p><math>Y_{ds}</math> Standard Meter Correction Factor (unitless)</p> <p><math>\Delta H@</math> Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p><math>\Delta H@_i \leq \Delta H@_{avg} \pm 0.2</math></p> <p><math>\Theta</math> Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
5.0	5.0
10.1	10.0
14.7	15.0
19.3	20.0
24.0	25.0

# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-22

Office: \_\_\_\_\_

Calibrated by: Martin Vaquero

Client: \_\_\_\_\_

Date: 11/13/08

Job No: \_\_\_\_\_

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6 DGM In	7 DGM Out
50	49	49	49				
100	99	99	99				
150	149	149	149				
200	199	199	199				
250	249	249	249				
300	299	299	299				
350	349	349	349				
400	399	399	399				
450	449	449	449				
500	499	499	499				
550	549	549	549				
600	599	599	599				

*Tolerance = ±2°F difference from reference setting.*

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Exp. Date: <u>10/13/2009</u>
Calibration Report No: <u>R044791</u>	

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 10735      Meter No. 66-22      Orifice A-2  
 Location warehouse      Meter Yd 0.9937      Orifice K' 0.4506  
 Test Date 03/24/09      Meter ΔH@ 1.7498      Orifice Cal. Date 01/21/09  
 Operator r. vicere      Full Test Cal. Date 11/13/08

### Leak Checks

Negative Pressure  Pass  
*No movement of manometer in one-minute*  
 Positive Pressure  Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 28.95 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (ccf)	Meter Temperature		Ambient Temp. T <sub>amb</sub> (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>n</sub> (ccf)	Avg Meter Temp. for Run T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	324.90	72	68								
1	5.0	327.89	74	68	75	1.10	21	5.0	2.99	70.5	0.9770	-0.6%
2	10.0	330.86	75	69	78	1.10	21	5.0	2.97	71.5	0.9827	0.0%
3	15.0	333.81	77	70	81	1.10	21	5.0	2.95	72.8	0.9889	0.6%

Average Y <sub>i</sub>	0.9829
Cal. Error	-1.1%

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}}{Y_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y} - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

## Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-4

Project Number: 10735

**Thermocouple Calibration**

Reference Type: Thermocouple Reference I.D. No.: 15-078-39 Pyrometer I.D. No.: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	66	68	-2	0.38%	%Difference ≤ 1.5
2	200°F-250°F	250	255	-5	0.70%	

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications?                      → YES

**Pitot Tube Calibration (Wind Tunnel Method @ 60 ft/sec)**

Reference Pitot I.D. No.: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>P(S)</sub> *	Abs. Deviation from Avg. C <sub>P(A)</sub> **
1	0.546	0.836	0.801	0.008
2	0.553	0.826	0.810	0.001
3	0.546	0.806	0.815	0.007
Side 'A' Average Probe C <sub>P(A)</sub> =			0.8085	0.0053

Specification  
Avg. C<sub>p</sub> Deviations ≤ 0.01

Pitot Side 'B':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>P(S)</sub> *	Abs. Deviation from Avg. C <sub>P(B)</sub> **
1	0.550	0.823	0.810	0.006
2	0.550	0.810	0.816	0.000
3	0.553	0.803	0.822	0.006
Side 'B' Average Probe C <sub>P(B)</sub> =			0.8157	0.0039

Specification  
Avg. C<sub>p</sub> Deviations ≤ 0.01

'A' Average C <sub>p</sub>	—	'B' Average C <sub>p</sub>	=	Difference	Specification
0.809		0.816		-0.007	Difference  ≤ 0.01

Does assembly meet specifications?                     

YES

→ If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

**All specifications are from EPA-600/9-76-005, section 3.1**

Probe Cp = 0.812

Calibrated by: W. Berry

Date: 01/06/2009

## Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-4

Project Number: \_\_\_\_\_

**Thermocouple Calibration**

Reference Type: Thermometer Reference I.D. No: \_\_\_\_\_ Pyrometer I.D. No: \_\_\_\_\_ Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient					
2	200°F-250°F					

\* Based on Absolute Temperature (Rankine)

%Difference ≤ 1.5

**Geometric Pitot Calibration**

Is pitot assembly in good repair?  Yes  No If no, explain:

### "S" Pitot

Dimensions	Dimensions	Specifications	Within Spec?
$\alpha_1 = 2$	$\alpha_2 = 1$	$\leq 10^\circ$	YES
$\beta_1 = 0$	$\beta_2 = 0$	$\leq 5^\circ$	YES
$\gamma = 1$	$\theta = 2$	None	N/A
$A = 0.713$		None	N/A
$Dt = 0.244$		$0.1875" \leq Dt \leq 0.375"$	YES

Calculations	Specifications	Within Spec?
$A/2 = Pa = Pb = 0.357$ inches	None	N/A
$Pa/Dt = Pb/Dt = 1.461$ inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma = 0.012$ inches	$\leq 0.125"$	YES
$w = A \sin \theta = 0.025$ inches	$\leq 0.03125"$	YES

Pitot Cp= **0.84** according to 40 CFR 60 section 10.1

### Standard Pitot

Measurement	Specification	Calculation	Within Spec?
Tube O.D.	None		
Static Hole I.D.	within 10% of (0.1*O.D.)		
Tip to Static	$\geq 6^*O.D.$		
Static to Bend	$\geq 8^*O.D.$		

Pitot Cp=

Calibrated by: Danial Luckhard

Date: 1/6/2009

# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-7  
 Project Number: 10735

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	72.0	79.0	-7	1.32%	%Difference ≤ 1.5
2	200°F-250°F	213.0	213.0	0	0.00%	

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel Reference Pitot Cp: 0.99

Pitot Side 'A':				Abs. Deviation from Avg. C <sub>p(A)</sub> **	Specification Avg. C <sub>p</sub> Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *		
1	0.563	0.822	0.820	0.009	
2	0.568	0.800	0.834	0.006	
3	0.571	0.811	0.830	0.002	
Side 'A' Average Probe C <sub>p(A)</sub> =			0.8281	0.0057	

Pitot Side 'B':				Abs. Deviation from Avg. C <sub>p(B)</sub> **	Specification Avg. C <sub>p</sub> Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *		
1	0.573	0.822	0.827	0.005	
2	0.574	0.832	0.822	0.001	
3	0.570	0.839	0.816	0.006	
Side 'B' Average Probe C <sub>p(B)</sub> =			0.8216	0.0040	

'A' Average C <sub>p</sub> 0.828	-	'B' Average C <sub>p</sub> 0.822	=	Difference 0.006	Specification  Difference  ≤ 0.01
-------------------------------------	---	-------------------------------------	---	---------------------	--------------------------------------

Does assembly meet specifications?

YES

If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

All specifications are from EPA-600/9-76-005, section 3.1

Probe Cp= 0.825 Calibrated by: W. Berry Date: 03/05/2009



# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-7

Project Number: 10735

**Thermocouple Calibration**

Reference Type: Thermometer Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient	72.0	79.0	-7.0	1.32%	YES
2	200°F-250°F	213.0	213.0	0.0	0.00%	YES

\* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5

YES

**Geometric Pitot Calibration**

Is pitot assembly in good repair?  Yes  No If no, explain:

### "S" Pitot

Dimensions	Dimensions	Specifications	Within Spec?
$\alpha 1 = 2$	$\alpha 2 = 1$	$\leq 10^\circ$	YES
$\beta 1 = 2$	$\beta 2 = 1$	$\leq 5^\circ$	YES
$\gamma = 2$	$\theta = 1$	None	N/A
$A = 0.716$		None	N/A
$Dt = 0.250$		$0.1875" \leq Dt \leq 0.375"$	YES

Calculations	Specifications	Within Spec?
$A/2 = P_a = P_b = 0.358$ inches	None	N/A
$P_a/Dt = P_b/Dt = 1.432$ inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma = 0.025$ inches	$\leq 0.125"$	YES
$w = A \sin \theta = 0.012$ inches	$\leq 0.03125"$	YES

Pitot Cp= **0.84** according to 40 CFR 60 section 10.1

### Standard Pitot

Measurement	Specification	Calculation	Within Spec?
Tube O.D.	None		
Static Hole I.D.	within 10% of (0.1*O.D.)		
Tip to Static	$\geq 6 \times O.D.$		
Static to Bend	$\geq 8 \times O.D.$		

Pitot Cp=

Calibrated by: N. Hitchins

Date: 3/4/2009

# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-17

Project Number: 10735

Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	73.0	74.0	-1	0.19%	
2	200°F-250°F	221.0	219.0	2	0.29%	%Difference ≤ 1.5

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

Pitot Tube Calibration (Windsunne Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A' :

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(A)</sub> **
1	0.566	0.801	0.832	0.006
2	0.570	0.794	0.839	0.001
3	0.566	0.781	0.843	0.005
Side 'A' Average Probe C <sub>p(A)</sub> =			0.8381	0.0039

**Specification**  
Avg. C<sub>p</sub> Deviations ≤ 0.01

Pitot Side 'B' :

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(B)</sub> **
1	0.573	0.815	0.830	0.001
2	0.565	0.808	0.828	0.000
3	0.566	0.809	0.828	0.001
Side 'B' Average Probe C <sub>p(B)</sub> =			0.8288	0.0007

**Specification**  
Avg. C<sub>p</sub> Deviations ≤ 0.01

'A' Average C <sub>p</sub> 0.838	—	'B' Average C <sub>p</sub> 0.829	=	Difference 0.009	
-------------------------------------	---	-------------------------------------	---	---------------------	--

**Specification**  
|Difference| ≤ 0.01

Does assembly meet specifications?

YES

If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{p(S)} = C_{p(STD)} \sqrt{\frac{\Delta p_{(STD)}}{\Delta p_{(S)}}}$$

$$** Deviation = |C_{p(S)} - \bar{C}_{p(A \text{ or } B)}|$$

All specifications are from EPA-600/9-76-005, section 3.1

Probe Cp= 0.833

Calibrated by: W. Berry

Date: 03/05/2009





## Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-17  
 Project Number: 10735

**Thermocouple Calibration**

Reference Type: Thermometer Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient	73.0	74.0	-1.0	0.19%	YES
2	200°F-250°F	221.0	219.0	2.0	0.29%	YES

\* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5

YES

**Geometric Pitot Calibration**

Is pitot assembly in good repair?  Yes  No If no, explain:

### "S" Pitot

Dimensions	Dimensions	Specifications	Within Spec?
$\alpha 1 = 1$	$\alpha 2 = 1$	$\leq 10^\circ$	YES
$\beta 1 = 1$	$\beta 2 = 1$	$\leq 5^\circ$	YES
$\gamma = 0$	$\theta = 1$	None	N/A
$A = 0.714$		None	N/A
$Dt = 0.250$		$0.1875" \leq Dt \leq 0.375"$	YES

Calculations	Specifications	Within Spec?
$A/2 = Pa = Pb = 0.357$ inches	None	N/A
$Pa/Dt = Pb/Dt = 1.428$ inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma = 0.000$ inches	$\leq 0.125"$	YES
$w = A \sin \theta = 0.012$ inches	$\leq 0.03125"$	YES

Pitot Cp= **0.84 according to 40 CFR 60 section 10.1**

### Standard Pitot

Measurement	Specification	Calculation	Within Spec?
Tube O.D.	None		
Static Hole I.D.	within 10% of (0.1*O.D.)		
Tip to Static	$\geq 6 \times O.D.$		
Static to Bend	$\geq 8 \times O.D.$		

Pitot Cp=

Calibrated by: N. Hitchins

Date: 3/4/2009

# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-1  
Project Number: \_\_\_\_\_

**Thermocouple Calibration**

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	68.0	71.0	-3	0.57%	%Difference ≤ 1.5
2	200°F-250°F	232.0	224.0	8	1.16%	

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

**Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)**

Reference Pitot I.D. No: Wind Tunnel Reference Pitot Cp: 0.99

Pitot Side 'A':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(A)</sub> **	Specification
1	0.571	0.826	0.823	0.003	Avg. C <sub>p</sub> Deviations ≤ 0.01
2	0.572	0.816	0.829	0.002	
3	0.570	0.816	0.828	0.001	
Side 'A' Average Probe C <sub>p(A)</sub> =			0.8265	0.0021	

Pitot Side 'B':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(B)</sub> **	Specification
1	0.564	0.830	0.816	0.003	Avg. C <sub>p</sub> Deviations ≤ 0.01
2	0.571	0.829	0.822	0.002	
3	0.568	0.827	0.821	0.001	
Side 'B' Average Probe C <sub>p(B)</sub> =			0.8193	0.0023	

'A' Average C <sub>p</sub>	—	'B' Average C <sub>p</sub>	=	Difference	Specification
0.827		0.819		0.008	Difference  ≤ 0.01

Does assembly meet specifications? YES → If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

**All specifications are from EPA 600/9-76-005, section 3.1.**

Probe Cp= 0.823 Calibrated by: W. Berry Date: 03/04/2009



## Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-1  
 Project Number: 10735

**Thermocouple Calibration**

Reference Type: Thermometer Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient	68.0	71.0	-3.0	0.57%	YES
2	200°F-250°F	232.0	224.0	8.0	1.16%	YES

\* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5

YES

**Geometric Pitot Calibration**

Is pitot assembly in good repair?  Yes  No If no, explain:

### "S" Pitot

Dimensions	Dimensions	Specifications	Within Spec?
$\alpha 1 = 1$	$\alpha 2 = 1$	$\leq 10^\circ$	YES
$\beta 1 = 2$	$\beta 2 = 1$	$\leq 5^\circ$	YES
$\gamma = 1$	$\theta = 1$	None	N/A
$A = 0.714$		None	N/A
$Dt = 0.250$		$0.1875" \leq Dt \leq 0.375"$	YES

Calculations	Specifications	Within Spec?
$A/2 = Pa = Pb = 0.357$ inches	None	N/A
$Pa/Dt = Pb/Dt = 1.428$ inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma = 0.012$ inches	$\leq 0.125"$	YES
$w = A \sin \theta = 0.012$ inches	$\leq 0.03125"$	YES

Pitot Cp= 0.84 according to 40 CFR 60 section 10.1

### Standard Pitot

Measurement	Specification	Calculation	Within Spec?
Tube O.D.	None		
Static Hole I.D.	within 10% of (0.1*O.D.)		
Tip to Static	$\geq 6 \times O.D.$		
Static to Bend	$\geq 8 \times O.D.$		

Pitot Cp=

Calibrated by: N. Hitchins

Date: 3/4/2009

# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-4

Project Number: 10735

**Thermocouple Calibration**

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	69.0	71.0	-2	0.38%	%Difference ≤ 1.5
2	200°F-250°F	223.0	217.0	6	0.88%	

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

**Pitot Probe Calibration (Wind Tunnel Method @ 50 ft/sec)**

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A' :

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>P(S)</sub> *	Abs. Deviation from Avg. C <sub>P(A)</sub> **
1	0.561	0.822	0.818	0.002
2	0.568	0.822	0.823	0.003
3	0.564	0.822	0.820	0.001
Side 'A' Average Probe C <sub>P(A)</sub> =			0.8204	0.0020

**Specification**  
Avg. C<sub>p</sub> Deviations ≤ 0.01

Pitot Side 'B' :

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>P(S)</sub> *	Abs. Deviation from Avg. C <sub>P(B)</sub> **
1	0.568	0.815	0.826	0.001
2	0.563	0.816	0.823	0.002
3	0.574	0.825	0.826	0.001
Side 'B' Average Probe C <sub>P(B)</sub> =			0.8249	0.0015

**Specification**  
Avg. C<sub>p</sub> Deviations ≤ 0.01

'A' Average C <sub>p</sub> 0.820	-	'B' Average C <sub>p</sub> 0.825	=	Difference -0.005	
-------------------------------------	---	-------------------------------------	---	----------------------	--

**Specification**  
|Difference| ≤ 0.01

Does assembly meet specifications?

YES

If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta p_{(STD)}}{\Delta p_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

**All specifications are from EPA 600/9-76-005, section 3.1**

Probe Cp= 0.823

Calibrated by: W. Berry

Date: 03/04/2009



## Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-4  
 Project Number: 10735

**Thermocouple Calibration**

Reference Type: Thermometer Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient	69.0	71.0	-2.0	0.38%	YES
2	200°F-250°F	223.0	217.0	6.0	0.88%	YES

\* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5

**YES**

**Geometric Pitot Calibration**

Is pitot assembly in good repair?  Yes  No If no, explain: \_\_\_\_\_

### "S" Pitot

Dimensions		Dimensions		Specifications	Within Spec?
$\alpha 1 =$	2	$\alpha 2 =$	1	$\leq 10^\circ$	YES
$\beta 1 =$	0	$\beta 2 =$	2	$\leq 5^\circ$	YES
$\gamma =$	2	$\theta =$	1	None	N/A
A =	0.724			None	N/A
Dt =	0.250			$0.1875" \leq Dt \leq 0.375"$	YES

Calculations		Specifications	Within Spec?
$A/2 = P_a = P_b =$	0.362 inches	None	N/A
$P_a/Dt = P_b/Dt =$	1.448 inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma =$	0.025 inches	$\leq 0.125"$	YES
$w = A \sin \theta =$	0.013 inches	$\leq 0.03125"$	YES

Pitot Cp= **0.84 according to 40 CFR 60 section 10.1**

### Standard Pitot

	Measurement	Specification	Calculation	Within Spec?
Tube O.D.		None		
Static Hole I.D.		within 10% of (0.1*O.D.)		
Tip to Static		$\geq 6 \times O.D.$		
Static to Bend		$\geq 8 \times O.D.$		

Pitot Cp=

Calibrated by: N. Hitchins

Date: 3/4/2009

# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-10-5  
 Project Number: 10735

## Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	69.0	75.0	-6	1.13%	%Difference ≤ 1.5
2	200°F-250°F	207.0	216.0	-9	1.35%	

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

## Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel Reference Pitot Cp: 0.99

Pitot Side 'A' :				Abs. Deviation from Avg. C <sub>p(A)</sub> **	Specification Avg. C <sub>p</sub> Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *		
1	0.565	0.830	0.817	0.002	
2	0.565	0.820	0.822	0.003	
3	0.559	0.819	0.818	0.001	
Side 'A' Average Probe C <sub>p(A)</sub> =			0.8190	0.0019	

Pitot Side 'B' :				Abs. Deviation from Avg. C <sub>p(B)</sub> **	Specification Avg. C <sub>p</sub> Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *		
1	0.567	0.828	0.819	0.001	
2	0.566	0.822	0.821	0.001	
3	0.559	0.814	0.821	0.000	
Side 'B' Average Probe C <sub>p(B)</sub> =			0.8205	0.0009	

'A' Average C <sub>p</sub> 0.819	-	'B' Average C <sub>p</sub> 0.820	=	Difference -0.001	Specification  Difference  ≤ 0.01
-------------------------------------	---	-------------------------------------	---	----------------------	--------------------------------------

Does assembly meet specifications?

YES

If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

## All specifications are from EPA-600/9-76-005, section 3.

Probe Cp= 0.820

Calibrated by: W. Berry

Date: 03/05/2009



## Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-10-5  
 Project Number: 10735

### Thermocouple Calibration

Reference Type: Thermometer Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Within spec?
1	Ambient	69.0	75.0	-6.0	1.13%	YES
2	200°F-250°F	207.0	216.0	-9.0	1.35%	YES

\* Based on Absolute Temperature (Rankine) %Difference ≤ 1.5  
 YES

### Geometric Pitot Calibration

Is pitot assembly in good repair?  Yes  No If no, explain: \_\_\_\_\_

### "S" Pitot

Dimensions	Dimensions	Specifications	Within Spec?
$\alpha 1 = 0$	$\alpha 2 = 0$	$\leq 10^\circ$	YES
$\beta 1 = 1$	$\beta 2 = 1$	$\leq 5^\circ$	YES
$\gamma = 1$	$\theta = 0$	None	N/A
A = 0.726		None	N/A
Dt = 0.250		$0.1875" \leq Dt \leq 0.375"$	YES

Calculations	Specifications	Within Spec?
$A/2 = P_a = P_b = 0.363$ inches	None	N/A
$P_a/Dt = P_b/Dt = 1.452$ inches	$1.05 < P/Dt < 1.5$	YES
$z = A \sin \gamma = 0.013$ inches	$\leq 0.125"$	YES
$w = A \sin \theta = 0.000$ inches	$\leq 0.03125"$	YES

Pitot Cp= **0.84** according to 40 CFR 60 section 10.1

### Standard Pitot

	Measurement	Specification	Calculation	Within Spec?
Tube O.D.		None		
Static Hole I.D.		within 10% of (0.1*O.D.)		
Tip to Static		$>= 6 * O.D.$		
Static to Bend		$>= 8 * O.D.$		

Pitot Cp=

Calibrated by: N. Hitchins

Date: 3/4/2009



Air Liquide America  
Specialty Gases LLC



# RATA CLASS

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

## CERTIFICATE OF ACCURACY: EPA Protocol Gas

### Assay Laboratory

P.O. No.: 57134-71-65000  
AIR LIQUIDE AMERICA SPECIALTY GASES LLC Project No.: 05-72060-003  
1290 COMBERMERE STREET  
TROY, MI 48083

### Customer

CLEAN AIR ENGINEERING  
DON ALLEN  
500 W. WOOD STREET  
PALATINE IL 60067

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM045493 Certification Date: 13Jan2009 Exp. Date: 13Jan2012  
Cylinder Pressure\*\*\*: 2000 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	14.0 %	+/- 1%	Direct NIST and NMI
OXYGEN	6.05 %	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2000	01Jul2009	K026898	5.008 %	CARBON DIOXIDE
NTRM 2350	01Dec2011	K016398	23.20 %	OXYGEN

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
PIR/2000/609015	13Jan2009	NDIR
CAI/110P/V03018	22Dec2008	PARAMAGNETIC

### ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)


First Triad Analysis

Second Triad Analysis

Calibration Curve

#### CARBON DIOXIDE


Date: 13Jan2009	Response Unit: MV
Z1 = 0.00000	R1 = 39.30000 T1 = 83.10000
R2 = 39.40000	Z2 = 0.00000 T2 = 83.10000
Z3 = 0.00000	T3 = 83.10000 R3 = 39.40000
Avg. Concentration:	14.00 %



Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>
r = 0.999998
Constants: A = -0.0052472
B = 0.108852633 C = 0.0002522
D = 5.78883E-08 E = 0

#### OXYGEN

Date: 13Jan2008	Response Unit: %
Z1 = 0.00000	R1 = 23.20000 T1 = 6.05000
R2 = 23.20000	Z2 = 0.00000 T2 = 6.05000
Z3 = 0.00000	T3 = 6.05000 R3 = 23.20000
Avg. Concentration:	6.053 %



Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>
r = 0.999999
Constants: A = -0.00568057
B = 0.999821643 C = 0
D = 0 E = 0

APPROVED BY:

JEFF PROTEAU



**RATA CLASS**



**Scott Specialty Gases**

*Dual-Analyzed Calibration Standard*

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

**CERTIFICATE OF ACCURACY: EPA Protocol Gas**

Assay Laboratory

SCOTT SPECIALTY GASES  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: 55647-71-65000  
Project No.: 05-53475-001

Customer

CLEAN AIR ENGINEERING  
DON ALLEN  
500 W. WOOD STREET  
PALATINE IL 60067

**ANALYTICAL INFORMATION**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: AAL9828 Certification Date: 05Apr2007 Exp. Date: 04Apr2010  
Cylinder Pressure\*\*\*: 1900 PSIG

<u>COMPONENT</u>	<u>CERTIFIED CONCENTRATION (Moles)</u>	<u>ANALYTICAL ACCURACY**</u>	<u>TRACEABILITY</u>
CARBON DIOXIDE	6.054 %	+/- 1%	Direct NIST and NMI
OXYGEN	14.02 %	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

<u>TYPE/SRM NO.</u>	<u>EXPIRATION DATE</u>	<u>CYLINDER NUMBER</u>	<u>CONCENTRATION</u>	<u>COMPONENT</u>
NTRM 2300	01Nov2010	1D002807	23.04 %	CARBON DIOXIDE
NTRM 2350	01May2009	K026542	23.48 %	OXYGEN

**INSTRUMENTATION**

<u>INSTRUMENT/MODEL/SERIAL#</u>	<u>DATE LAST CALIBRATED</u>	<u>ANALYTICAL PRINCIPLE</u>
VARIAN/3400/10693	04Apr2007	THERMAL CONDUCTIVITY
CALIFORNIA /110P/S02041	05Apr2007	PARAMAGNETIC

**ANALYZER READINGS**

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

**CARBON DIOXIDE**


Date: 04Apr2007 Response Unit: AREA  
Z1 = 0.00000 R1 = 1185892. T1 = 305456.0  
R2 = 1166031. Z2 = 0.00000 T2 = 305856.0  
Z3 = 0.00000 T3 = 305949.0 R3 = 1166669.  
Avg. Concentration: 6.054 %



Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 0.999996  
Constants: A = 0.010560  
B = 0.000020 C = 0  
D = 0 E = 0

**OXYGEN**

Date: 05Apr2007 Response Unit: %  
Z1 = 0.00000 R1 = 23.48000 T1 = 14.03000  
R2 = 23.48000 Z2 = 0.00000 T2 = 14.03000  
Z3 = 0.00000 T3 = 14.02000 R3 = 23.49000  
Avg. Concentration: 14.02 %



Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 0.999999  
Constants: A = -0.002923  
B = 0.999759 C = 0  
D = 0 E = 0

APPROVED BY: \_\_\_\_\_



Scott Specialty Gases  
Air Liquide America Specialty Gases LLC

Shipped 1290 COMBERMERE STREET  
From: TROY MI 48083  
Phone: 248-589-2950 Fax: 248-589-2134  
**C E R T I F I C A T E   O F   A N A L Y S I S**

WAREHOUSE/STOCK  
WAREHOUSE/STOCK/  
CHICAGO WAREHOUSE  
868 SIVERT  
WOOD DALE

IL 60191

PROJECT #: 05-69004-002  
PO#: GENERAL STOCK  
ITEM #: 0501813 AL  
DATE: 15Sep2008

CYLINDER #: ALM061790  
FILL PRESSURE: 02000 PSIG

PURE MATERIAL: NITROGEN

CAS# 7727-37-9

GRADE: ZERO GAS

PURITY: 99.998%

IMPURITY  
THC

MAXIMUM  
CONCENTRATIONS  
0.5 PPM

ANALYST:

