



**Wheelabrator South Broward Inc.**

A Waste Management Company

4400 South State Road 7  
Ft. Lauderdale, FL 33314

RECEIVED

MAY 13 2013

DIVISION OF AIR  
RESOURCE MANAGEMENT

May 8, 2013

UPS# 1Z2AW7390197438931

Mr. Joe Lurix  
Air Program Administrator  
Florida Department of Environmental Protection  
Southeast District  
400 North Congress Ave., Suite 200  
West Palm Beach, FL 33401

Re: Wheelabrator South Broward  
2013 Annual Compliance Stack Test and RATA Reports

Dear Mr. Lurix:

Please find enclosed a copy of the final compliance stack test report and the continuous emissions monitoring system certification RATA report for testing conducted on March 25-27 of this year by Clean Air Engineering, Inc.

I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this submittal. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements and information in this document are true, accurate and complete.

If there are any questions, please contact this office at (954) 581-6606.

Sincerely,

Scott McIlvaine  
Plant Manager

cc: USEPA, Region IV, Pesticides and Toxics Management Division, Air & EPCRA Enforcement  
Branch, Air Enforcement Section (with) UPS#1Z2AW7390196354363

FDEP, Tallahassee, Bureau of Air Regulation, New Source Review Section,  
(with) UPS#1Z2AW7390196615143

Broward County Department of Planning and Environmental Protection, Air Quality Division  
(with) UPS#1Z2AW7390195194958

Nicole Turnbull (with)  
Ram Tewari – BCWRS (without)  
Tim Porter (without)  
Rob French – MPI (with)





Wheelabrator South Broward, Inc.  
4400 South State Road 7  
Ft. Lauderdale, FL 33314

**RECEIVED**

**MAY 13 2013**

**DIVISION OF AIR  
RESOURCE MANAGEMENT**

---

**REPORT ON COMPLIANCE TESTING**

Performed for:  
**WHEELABRATOR SOUTH BROWARD, INC.  
ASH HANDLING SYSTEM, LIME SILO VENT,  
UNITS 1, 2 AND 3 SDA INLETS, FF OUTLETS AND STACKS  
FT. LAUDERDALE, FL  
VOLUME III OF III**

Client Reference No: Service Agreement  
CleanAir Project No: 12218-3  
Revision 0: May 8, 2013

---

**QA/QC DATA**

F

*I herby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: ML

Date: 5/6/13



**This Page Intentionally Left Blank**



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 5/29 and Method 29 (Particulate/Metals and Mercury)  
 QA/QC Results**

Run No.	1	2	3	4
Date (2013)	Mar 25	Mar 26	Mar 26	Mar 26
Start Time (approx.)	12:26	07:51	10:25	12:59
Stop Time (approx.)	14:40	10:03	12:36	15:11
Total Duration of Test Run (min.)	134	132	131	132
Net Sampling Time (min.)	125	125	125	125

**Sampling System Calibration Summary**

	Nozzle ID No:	0.276-1	0.2725-1	0.2725-1	0.2725-1
D <sub>n</sub>	Nozzle Diameter (in):	0.276	0.273	0.273	0.273
	Probe ID No:	67-8-21	67-8-21	67-8-21	67-8-21
C <sub>p</sub>	Pitot Coefficient:	0.8130	0.8130	0.8130	0.813
	Meter Box ID. No:	85-2	85-2	85-2	85-2
Y <sub>d</sub>	Meter Box Yd - Field Sheet	1.0039	1.0039	1.0039	1.0039
	Meter Box Yd - Database	1.0039	1.0039	1.0039	1.0039
	Meter Box ΔH@ - Field Sheet	1.7413	1.7413	1.7413	1.7413
	Meter Box ΔH@ - Database	1.7413	1.7413	1.7413	1.7413

**QA/QC**

Final Leak Check

	(a) 4% of Sampling Rate (cfm)	0.0256	0.0215	0.0214	0.0228
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0030	0.0010	0.0050	0.0010

Sample Volume

	Minimum Volume Required (dscf)	30.00	30.00	30.00	30.00
V <sub>mstd</sub>	Actual Sample Volume (dscf)	76.916	67.795	66.117	70.456

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.1080	0.9415	0.9270	0.9868
Y <sub>qa</sub>	Alternative Meter Calibration Factor	0.9862	0.9749	0.9749	0.9728
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	-1.8%	-2.9%	-2.9%	-3.1%
					<b>Average -2.7%</b>

Mean Isokinetic Sampling Rate Variation

	Minimum Allowable (%)	90	90	90	90
	Maximum Allowable (%)	110	110	110	110
%I	Actual Variation (%)	105.74	100.82	103.20	103.70

Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0	0
	Number of points >110%	3	0	0	0
	Number of points <80%	0	0	0	0
	Number of points >120%	0	0	0	0

042213 151210  
 NIKN

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 SDA Inlet

### USEPA Method 26A (HCI) QA/QC Results

Run No.	1	2	3
Date (2013)	Mar 25	Mar 25	Mar 25
Start Time (approx.)	08:00	09:23	10:54
Stop Time (approx.)	09:00	10:34	11:54
Total Duration of Test Run (min.)	60	71	60
Net Sampling Time (min.)	60	60	60

#### Sampling System Calibration Summary

Probe ID No:	66-4-7	66-4-7	66-4-7
Meter Box ID. No:	61-11	61-11	61-11
$Y_d$ Meter Box $Y_d$ - Field Sheet	1.0050	1.0050	1.0050
Meter Box $Y_d$ - Database	1.0050	1.0050	1.0050
Meter Box $\Delta H@$ - Field Sheet	1.6964	1.6964	1.6964
Meter Box $\Delta H@$ - Database	1.6964	1.6964	1.6964

#### QA/QC

##### Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0238	0.0245	0.0245
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0000	0.0030	0.0030

##### Sample Volume

$V_{mstd}$ Minimum Volume Required (dscf)	30.00	30.00	30.00
Actual Sample Volume (dscf)	34.011	34.796	34.703

##### Alternative Method 5 Post-Test Calibration (EPA ALT-009)

$\sqrt{\Delta H}_{avg}$ Average of Square Root of $\Delta H$ (in. W.C.)	1.0954	1.0954	1.0954
$Y_{qa}$ Alternative Meter Calibration Factor	1.0684	1.0412	1.0418
Variation from full-test $Y_d$ (average $\leq \pm 5\%$ )	6.3%	3.6%	3.7%
			<b>Average 4.5%</b>

042213 151237  
 QKN@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 26A (HCI)  
 QA/QC Results**

Run No.	1	2	3
Date (2013)	Mar 25	Mar 25	Mar 25
Start Time (approx.)	08:00	09:23	10:54
Stop Time (approx.)	09:00	10:34	11:54
Total Duration of Test Run (min.)	60	71	60
Net Sampling Time (min.)	60	60	60

**Sampling System Calibration Summary**

Probe ID No:	67-4-3	67-4-3	67-4-3
Meter Box ID. No:	66-14	66-14	66-14
$Y_d$ Meter Box $Y_d$ - Field Sheet	0.9879	0.9879	0.9879
Meter Box $Y_d$ - Database	0.9879	0.9879	0.9879
Meter Box $\Delta H@$ - Field Sheet	1.8015	1.8015	1.8015
Meter Box $\Delta H@$ - Database	1.8015	1.8015	1.8015

**QA/QC**

**Final Leak Check**

(a) 4% of Sampling Rate (cfm)	0.0273	0.0275	0.0277
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0010	0.0030	0.0010

**Sample Volume**

$V_{mstd}$ Minimum Volume Required (dscf)	30.00	30.00	30.00
Actual Sample Volume (dscf)	39.448	39.521	39.530

**Alternative Method 5 Post-Test Calibration (EPA ALT-009)**

$\sqrt{\Delta H}_{avg}$ Average of Square Root of $\Delta H$ (in. W.C.)	1.2247	1.2247	1.2247
$Y_{qa}$ Alternative Meter Calibration Factor	0.9993	0.9923	0.9888
Variation from full-test $Y_d$ (average $\leq \pm 5\%$ )	1.2%	0.4%	0.1%
			<b>Average</b>
			<b>0.6%</b>

042213 151237  
 NQJ@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 5/29 and Method 29 (Particulate/Metals and Mercury)  
 QA/QC Results**

Run No.	1	2	3	4
Date (2013)	Mar 25	Mar 25	Mar 25	Mar 27
Start Time (approx.)	07:59	10:32	13:04	12:07
Stop Time (approx.)	10:11	12:45	15:17	14:22
Total Duration of Test Run (min.)	132	133	133	135
Net Sampling Time (min.)	125	125	125	125

**Sampling System Calibration Summary**

$D_n$	Nozzle ID No:	0.2725-1	0.2725-1	0.2725-1	0.2725-2
	Nozzle Diameter (in):	0.273	0.273	0.273	0.273
$C_p$	Probe ID No:	67-8-17	67-8-17	67-8-17	67-8-16
	Pitot Coefficient:	0.8240	0.8240	0.8240	0.825
$Y_d$	Meter Box ID. No:	66-11	66-11	66-11	66-22
	Meter Box Yd - Field Sheet	0.9906	0.9906	0.9906	0.9972
	Meter Box Yd - Database	0.9906	0.9906	0.9906	0.9972
	Meter Box $\Delta H@$ - Field Sheet	1.8274	1.8274	1.8274	1.8840
	Meter Box $\Delta H@$ - Database	1.8274	1.8274	1.8274	1.8840

**QA/QC**

**Final Leak Check**

(a) 4% of Sampling Rate (cfm)	0.0227	0.0224	0.0222	0.0223
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0020	0.0020	0.0030	0.0030

**Sample Volume**

$V_{mstd}$	Minimum Volume Required (dscf)	30.00	30.00	30.00	30.00
	Actual Sample Volume (dscf)	68.028	66.494	66.386	69.965

**Alternative Method 5 Post-Test Calibration (EPA ALT-009)**

$\sqrt{\Delta H}_{avg}$	Average of Square Root of $\Delta H$ (in. W.C.)	1.0146	1.0038	0.9957	1.0284
$Y_{qa}$	Alternative Meter Calibration Factor	0.9914	0.9982	0.9940	0.9868
	Variation from full-test $Y_d$ (average $\leq \pm 5\%$ )	0.1%	0.8%	0.3%	-1.0%
					<b>Average 0.0%</b>

**Mean Isokinetic Sampling Rate Variation**

	Minimum Allowable (%)	90	90	90	90
	Maximum Allowable (%)	110	110	110	110
%I	Actual Variation (%)	101.05	98.87	99.05	100.56

**Point-by-Point Isokinetic Variation**

	Number of points <90%	0	0	0	0
	Number of points >110%	0	0	0	0
	Number of points <80%	0	0	0	0
	Number of points >120%	0	0	0	0

042213 151254  
 R N N O

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 23 (PCDD/F)  
 QA/QC Results**

Run No.	2	3	4
Date (2013)	Mar 26	Mar 26	Mar 27
Start Time (approx.)	08:03	13:09	07:21
Stop Time (approx.)	12:49	17:25	11:39
Total Duration of Test Run (min.)	286	256	258
Net Sampling Time (min.)	250	250	250

**Sampling System Calibration Summary**

	Nozzle ID No:	2722-1	2722-1	2722-1
D <sub>n</sub>	Nozzle Diameter (in):	0.272	0.272	0.272
	Probe ID No:	67-8-16	67-8-16	67-8-16
C <sub>p</sub>	Pitot Coefficient:	0.8250	0.8250	0.8250
	Meter Box ID. No:	66-22	66-22	66-22
Y <sub>d</sub>	Meter Box Yd - Field Sheet	0.9972	0.9972	0.9972
	Meter Box Yd - Database	0.9972	0.9972	0.9972
	Meter Box ΔH@ - Field Sheet	1.8840	1.8840	1.8840
	Meter Box ΔH@ - Database	1.8840	1.8840	1.8840

**QA/QC**

Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0217	0.0224	0.0224
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0030	0.0000	0.0030

Sample Volume

Minimum Volume Required (dscf)	NA	NA	NA
--------------------------------	----	----	----

Alternative Method 5 Post-Test Calibration (EPA ALT-009)

√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	1.0019	1.0204	1.0328	
Y <sub>qa</sub>	Alternative Meter Calibration Factor	0.9873	0.9848	0.9808	<b>Average</b>
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	-1.0%	-1.2%	-1.6%	<b>-1.3%</b>

Mean Isokinetic Sampling Rate Variation

	Minimum Allowable (%)	90	90	90
	Maximum Allowable (%)	110	110	110
%I	Actual Variation (%)	100.90	99.73	101.43

Point-by-Point Isokinetic Variation

	Number of points <90%	0	0	0
	Number of points >110%	0	0	0
	Number of points <80%	0	0	0
	Number of points >120%	0	0	0

042213 151311  
 PJJ@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 2 SDA Inlet

## USEPA Method 26A (HCI) QA/QC Results

Run No.	1	2
Date (2013)	Mar 27	Mar 27
Start Time (approx.)	07:47	09:08
Stop Time (approx.)	08:47	10:08
Total Duration of Test Run (min.)	60	60
Net Sampling Time (min.)	60	60

### Sampling System Calibration Summary

	Probe ID No:	66-4-7	66-4-7
	Meter Box ID. No:	61-11	61-11
$Y_d$	Meter Box $Y_d$ - Field Sheet	1.0050	1.0050
	Meter Box $Y_d$ - Database	1.0050	1.0050
	Meter Box $\Delta H@$ - Field Sheet	1.6964	1.6964
	Meter Box $\Delta H@$ - Database	1.6964	1.6964

### QA/QC

	<u>Final Leak Check</u>		
	(a) 4% of Sampling Rate (cfm)	0.0239	0.0241
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0030	0.0030
	<u>Sample Volume</u>		
	Minimum Volume Required (dscf)	30.00	30.00
$V_{mstd}$	Actual Sample Volume (dscf)	36.313	35.676
	<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>		
$\sqrt{\Delta H_{avg}}$	Average of Square Root of $\Delta H$ (in. W.C.)	1.0954	1.0954
$Y_{qa}$	Alternative Meter Calibration Factor	1.0316	1.0367
	Variation from full-test $Y_d$ (average $\leq \pm 5\%$ )	2.6%	3.2%
			<b>Average 2.9%</b>

\*Run 3 impinger broke mid run which compromised the sample.

042213 151356  
 NK@@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

### USEPA Method 26A (HCI) QA/QC Results

Run No.	1	2	3
Date (2013)	Mar 27	Mar 27	Mar 27
Start Time (approx.)	07:47	09:08	10:27
Stop Time (approx.)	08:47	10:08	11:27
Total Duration of Test Run (min.)	60	60	60
Net Sampling Time (min.)	60	60	60

#### Sampling System Calibration Summary

Probe ID No:	67-4-3	67-4-3	67-4-3
Meter Box ID. No:	66-11	66-11	66-11
$Y_d$ Meter Box $Y_d$ - Field Sheet	0.9906	0.9906	0.9906
Meter Box $Y_d$ - Database	0.9906	0.9906	0.9906
Meter Box $\Delta H@$ - Field Sheet	1.8274	1.8274	1.8274
Meter Box $\Delta H@$ - Database	1.8274	1.8274	1.8274

#### QA/QC

##### Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0268	0.0272	0.0271
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0020	0.0020	0.0010

##### Sample Volume

$V_{mstd}$ Minimum Volume Required (dscf)	30.00	30.00	30.00
Actual Sample Volume (dscf)	41.046	40.896	40.501

##### Alternative Method 5 Post-Test Calibration (EPA ALT-009)

$\sqrt{\Delta H}_{avg}$ Average of Square Root of $\Delta H$ (in. W.C.)	1.2247	1.2247	1.2247
$Y_{qa}$ Alternative Meter Calibration Factor	0.9803	0.9762	0.9839
Variation from full-test $Y_d$ (average $\leq \pm 5\%$ )	-1.0%	-1.5%	-0.7%
			<b>Average</b>
			<b>-1.1%</b>

042213 151405  
 NNQ@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 3 FF Outlet

**USEPA Method 5/29 and Method 29 (Particulate/Metals and Mercury)  
 QA/QC Results**

Run No.	1	2	3	4
Date (2013)	Mar 26	Mar 27	Mar 27	Mar 27
Start Time (approx.)	12:11	07:28	09:59	12:29
Stop Time (approx.)	14:24	09:41	12:11	14:41
Total Duration of Test Run (min.)	133	133	132	132
Net Sampling Time (min.)	125	125	125	125

**Sampling System Calibration Summary**

D <sub>n</sub>	Nozzle ID No:	0.2725-2	0.2725-2	0.2725-2	0.2725-1
	Nozzle Diameter (in):	0.273	0.273	0.273	0.273
C <sub>p</sub>	Probe ID No:	67-8-17	67-8-17	67-8-17	67-8-17
	Pitot Coefficient:	0.8240	0.8240	0.8240	0.824
Y <sub>d</sub>	Meter Box ID. No:	66-6	66-6	66-6	66-6
	Meter Box Yd - Field Sheet	0.9854	0.9854	0.9854	0.9854
	Meter Box Yd - Database	0.9854	0.9854	0.9854	0.9854
	Meter Box ΔH@ - Field Sheet	1.8280	1.8280	1.8280	1.8280
	Meter Box ΔH@ - Database	1.8280	1.8280	1.8280	1.8280

**QA/QC**

<u>Final Leak Check</u>					
	(a) 4% of Sampling Rate (cfm)	0.0218	0.0218	0.0228	0.0241
	(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200	0.0200
	Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200	0.0200
	Actual Final Leak Rate (cfm)	0.0020	0.0030	0.0020	0.0030
<u>Sample Volume</u>					
	Minimum Volume Required (dscf)	30.00	30.00	30.00	30.00
V <sub>mstd</sub>	Actual Sample Volume (dscf)	65.654	68.916	69.345	73.413
<u>Alternative Method 5 Post-Test Calibration (EPA ALT-009)</u>					
√ΔH <sub>avg</sub>	Average of Square Root of ΔH (in. W.C.)	0.9793	0.9813	1.0060	1.0599
Y <sub>qa</sub>	Alternative Meter Calibration Factor	0.9924	0.9681	0.9702	0.9659
	Variation from full-test Y <sub>d</sub> (average ≤ ±5%)	0.7%	-1.8%	-1.5%	-2.0%
<u>Mean Isokinetic Sampling Rate Variation</u>					
	Minimum Allowable (%)	90	90	90	90
	Maximum Allowable (%)	110	110	110	110
%I	Actual Variation (%)	99.10	101.00	98.52	100.88
<u>Point-by-Point Isokinetic Variation</u>					
	Number of points <90%	2	0	0	0
	Number of points >110%	1	0	0	0
	Number of points <80%	2	0	0	0
	Number of points >120%	1	0	0	0

042213 151450  
 NNMN



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 3 SDA Inlet

### USEPA Method 26A (HCI) QA/QC Results

Run No.	1	2	3
Date (2013)	Mar 26	Mar 26	Mar 26
Start Time (approx.)	08:00	09:21	10:46
Stop Time (approx.)	09:00	10:21	11:46
Total Duration of Test Run (min.)	60	60	60
Net Sampling Time (min.)	60	60	60

#### Sampling System Calibration Summary

Probe ID No:	66-4-7	66-4-7	66-4-7
Meter Box ID. No:	61-11	61-11	61-11
$Y_d$ Meter Box $Y_d$ - Field Sheet	1.0050	1.0050	1.0050
Meter Box $Y_d$ - Database	1.0050	1.0050	1.0050
Meter Box $\Delta H@$ - Field Sheet	1.6964	1.6964	1.6964
Meter Box $\Delta H@$ - Database	1.6964	1.6964	1.6964

#### QA/QC

##### Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0236	0.0248	0.0241
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0030	0.0030	0.0030

##### Sample Volume

$V_{mstd}$ Minimum Volume Required (dscf)	30.00	30.00	30.00
Actual Sample Volume (dscf)	35.380	36.205	35.211

##### Alternative Method 5 Post-Test Calibration (EPA ALT-009)

$\sqrt{\Delta H}_{avg}$ Average of Square Root of $\Delta H$ (in. W.C.)	1.0954	1.0954	1.0954
$Y_{qa}$ Alternative Meter Calibration Factor	1.0548	1.0180	1.0448
Variation from full-test $Y_d$ (average $\pm 5\%$ )	5.0%	1.3%	4.0%
			<b>Average</b> 3.4%

042213 151505  
 KGO@

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 3 FF Outlet

### USEPA Method 26A (HCl) QA/QC Results

Run No.	1	2	3
Date (2013)	Mar 26	Mar 26	Mar 26
Start Time (approx.)	08:00	09:21	10:46
Stop Time (approx.)	09:00	10:21	11:46
Total Duration of Test Run (min.)	60	60	60
Net Sampling Time (min.)	60	60	60

#### Sampling System Calibration Summary

Probe ID No:	67-4-3	67-4-3	67-4-3
Meter Box ID. No:	66-18	66-18	66-18
$Y_d$ Meter Box $Y_d$ - Field Sheet	1.0008	1.0008	1.0008
Meter Box $Y_d$ - Database	1.0008	1.0008	1.0008
Meter Box $\Delta H@$ - Field Sheet	1.9165	1.9165	1.9165
Meter Box $\Delta H@$ - Database	1.9165	1.9165	1.9165

#### QA/QC

##### Final Leak Check

(a) 4% of Sampling Rate (cfm)	0.0258	0.0259	0.0260
(b) Allowable Rate from Method (cfm)	0.0200	0.0200	0.0200
Allowable Limit - minimum of a and b (cfm)	0.0200	0.0200	0.0200
Actual Final Leak Rate (cfm)	0.0010	0.0020	0.0020

##### Sample Volume

$V_{mstd}$ Minimum Volume Required (dscf)	30.00	30.00	30.00
Actual Sample Volume (dscf)	38.835	38.653	38.295

##### Alternative Method 5 Post-Test Calibration (EPA ALT-009)

$\sqrt{\Delta H_{avg}}$ Average of Square Root of $\Delta H$ (in. W.C.)	1.2247	1.2247	1.2247	
$Y_{qa}$ Alternative Meter Calibration Factor	1.0111	1.0116	1.0137	<b>Average</b>
Variation from full-test $Y_d$ (average $\leq \pm 5\%$ )	1.0%	1.1%	1.3%	<b>1.1%</b>

042213 151516  
 JN1@

# Nozzle Calibration Sheet

Client	Wheelabrator	Project Number	12218
Calibrated by	S. Brown	Unit	1-3
Date	3/ / 2013	Runs	1-


Caliper ID 12156068

Nozzle Identification	D <sub>1</sub> (inches)	D <sub>2</sub> (inches)	D <sub>3</sub> (inches)	ΔD (inches)	D <sub>ave</sub> (inches)
0.2725-1	0.2725	0.2725	0.2725	0.0000	0.2725
0.2720-1	0.2720	0.2725	0.2720	0.0005	0.2720
0.2765-1	0.2760	0.2765	0.2770	0.0010	0.2760
0.2725-2	0.2730	0.2720	0.2725	0.0010	0.2725

D<sub>1</sub>, D<sub>2</sub>, D<sub>3</sub> = three nozzle diameter measurements

ΔD = maximum difference between any two diameters  
ΔD = 0.004 inches

D<sub>ave</sub> = average of D<sub>1</sub>, D<sub>2</sub>, D<sub>3</sub>



\* (40 CFR 60, Appendix A, Method 5, Section 5.1)

**CERTIFICATE OF INSPECTION / 検査成績書**

発行No./Issue No. : 4097558680

Product name/品名	Digimatic Caliper/デジマチックキヤリパ
Model No./符号	CD-4"CSX
Code No./コードNo.	500-185-20
Serial No./製造No.	12156088
Measuring range/測定範囲	0-100mm / 0-4inch
Minimum indication/最小表示量	0.01mm / 0.0005inch
Standard Temperature/標準温度	20°C
QC Manager	M.Sato <i>M. Sato</i>

(1) Inspection result/検査結果

Measuring length 測定長	Permissible values 許容値	errors/器差	
		External/外側	Internal/内側
$\phi 4$ 0 50 Unit : mm 100 単位 : mm 150 200	0.01	---	-0.02
	-0.03		
	$\pm 0.02$		
	※		
	※		
$\phi 0.18$ 0 2 Unit : inch 4 単位 : inch 6 8	0.0005	---	-0.0010
	-0.0015		
	$\pm 0.0010$		
	---		
	---		

Inspection standard : Mitutoyo standard  
 Based on : JISB7507:1993, DIN862:1988  
 Traceable to : NMIJ/AIST by JCSS No.0030, NIST via 821/276375-08,  
 PTB via 4937 PTB 06

**Mitutoyo Corporation**

(2) Judgment/判定 : Passed/合格

※DIN 862,1988 : 0.03

この検査成績書には安心してご利用いただけますよう出荷時の検査データを記録していますが、校正証明書取得用にはご利用できません。

UC048-00180(1)

# Caliper Calibration Sheet

Calibrated by	<i>D. Leishman</i>		
Calibration Date	5-14-12	Expiration Date	5-14-13

Caliper ID	12156068
------------	----------

Standard Caliper ID	101460021
---------------------	-----------


Inside Jaw Check		
Standard Caliper Setting (in)	Caliper Reading (in)	Deviation ( $\Delta D$ )
0.150	0.1505	0.0005
0.300	0.300	0.000
0.500	0.500	0.000

Outside Jaw Check		
Standard Caliper Setting (in)	Caliper Reading (in)	Deviation ( $\Delta D$ )
0.150	0.1505	0.0005
0.300	0.300	0.000
0.500	0.500	0.000

$\Delta D$  = maximum deviation between standard and caliper being calibrated  
 $\Delta D \leq 0.001$  inch for every reading




# Clean Air Engineering - Meter Box Full Test Calibration

**Client:** Source **Reviewed By:** M. Vaquero **Calibration Signature:**   
**ID No:** 61-11 **Calibrated By:** Jeff Ivens **Meter Box Yd:** 1.0050  
**Dept No:** Source **Date of Calibration:** 07/10/12 **Meter Box ΔH@:** 1.6964  
**Meter Box Serial No:** n/a **Due Date of Calibration:** 07/11/13 **Barometer Serial No:** W12637  
**Manufacturer Part No:** 0028 **Meter Box Vacuum:** 1.0 in. H<sub>2</sub>O **Barometric Pressure:** 29.34 in. Hg

Standard Meter Gas Volume (ft <sup>3</sup> )				Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results				
Q	ΔH	ΔP	Y <sub>ds</sub>	Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	T <sub>is</sub> In	T <sub>os</sub> Out	T <sub>ds</sub> Avg.	T <sub>i</sub> In	T <sub>o</sub> Out	T <sub>d</sub> Avg.	Θ	Y <sub>d</sub>	ΔH@
0.396	0.50	-1.20	1.0000	0.000	5.000	5.000	748.300	753.335	5.035	80.0	80.0	80.00	92.0	87.0	89.50	12.10	1.0062	1.6972
0.395	0.50	-1.20	1.0000	0.000	5.000	5.000	753.335	758.379	5.044	80.0	80.0	80.00	92.0	87.0	89.50	12.12	1.0044	1.7028
0.688	1.50	-1.50	1.0000	0.000	10.000	10.000	786.700	776.806	10.108	80.0	80.0	80.00	98.0	89.0	93.50	13.94	1.0067	1.6833
0.689	1.50	-1.50	1.0000	0.000	10.000	10.000	776.806	786.934	10.128	80.0	80.0	80.00	99.0	89.0	94.00	13.91	1.0054	1.6781
0.988	3.00	-1.80	1.0000	0.000	10.000	10.000	720.100	730.169	10.069	80.0	80.0	80.00	98.0	86.0	92.00	9.90	1.0031	1.7073
0.985	3.00	-1.80	1.0000	0.000	10.000	10.000	730.169	740.262	10.093	80.0	80.0	80.00	100.0	88.0	94.00	9.93	1.0043	1.7114
Averages																1.00502	1.69635	

Nomenclature	Equations
<p>P<sub>b</sub> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure Differential (in. H<sub>2</sub>O)</p> <p>ΔP Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p>V<sub>d</sub> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p>V<sub>ds</sub> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p>T<sub>d</sub> Average Meter Box Temperature (°F)</p> <p>T<sub>o</sub> Outlet Meter Box Temperature (°F)</p> <p>T<sub>ds</sub> Average Standard Meter Temperature (°F)</p> <p>Y<sub>d</sub> Meter Correction Factor (unitless), Y<sub>d</sub> ≤ Y<sub>avg</sub> ± 0.02</p> <p>Y<sub>ds</sub> Standard Meter Correction Factor (unitless)</p> <p>ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p>ΔH@ ≤ ΔH<sub>avg</sub> ± 0.2</p> <p>Θ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_d + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(Y_{ds})}{(T_{ds} + 460)(\Theta)}$

Average YD vs. Average CFM



Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
5.2	5.0
10.1	10.0
14.6	15.0
19.6	20.0
24.6	25.0

## Calibration Reference Information (Standard Meter)

**Reference Used:** Wet Test Meter **Serial No:** 11AH6  
**Calibrated By:** Martin Vaquero **Date Calibrated:** 10/26/2011  
**Percent Error:** 0.230% **Calibration Due Date:** 10/26/2012

## Meter Box Pre-Calibration Inspection

**Positive Leak Check:** Pass **Electrical Check:** Pass  
**Negative Leak Check:** Pass **Pyrometer Check:** Pass  
**Vacuum Gauge Check:** Pass **YD Tolerance:** Pass



# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 61-11 Office: n/a  
 Calibrated by: Jeff Ivens Client: Source  
 Date: 7/10/12 Job No: n/a  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6	7
50	51	52	52	51	51		
100	101	102	102	101	101		
150	151	152	152	151	151		
200	201	202	202	201	201		
250	251	252	252	251	251		
300	301	302	302	301	301		
350	351	352	352	351	351		
400	401	402	402	401	401		
450	451	452	452	451	451		
500	501	502	502	501	501		
550	551	552	551	551	551		
600	601	602	601	601	601		

*Tolerance = ±2°F difference from reference setting.*

### Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-279500</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>8/18/2011</u>
Calibration Report No: <u>1000150187</u>	Calibration Due Date: <u>8/18/2012</u>






# Clean Air Engineering - Meter Box Full Test Calibration

Client: Source Reviewed By: R. REDEL Calibration Signature: [Signature]  
 ID No: 66-6 Calibrated By: J. Ivens Meter Box Yd: 0.9854  
 Dept No: 66 Date of Calibration: 01/21/13 Meter Box ΔH@: 1.8280  
 Meter Box Serial No: 66-6 Due Date of Calibration: 01/09/13 Barometer Serial No: W12637  
 Manufacturer Part No: 0028 Meter Box Vacuum: 1.0 in. H<sub>2</sub>O Barometric Pressure: 29.36 in. Hg

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y <sub>ds</sub>	Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	T <sub>is</sub> In	T <sub>os</sub> Out	T <sub>ds</sub> Avg.	T <sub>i</sub> In	T <sub>o</sub> Out	T <sub>a</sub> Avg.	Θ	Y <sub>d</sub>	ΔH@
0.381	0.50	-1.20	1.0000	0.000	5.000	5.000	978.500	983.658	5.158	64.0	64.0	64.00	78.0	77.0	77.50	12.97	0.9901	1.8691
0.380	0.50	-1.20	1.0000	0.000	5.000	5.000	983.658	988.815	5.157	64.0	64.0	64.00	77.0	76.0	76.50	12.99	0.9885	1.8784
0.672	1.50	-1.50	1.0000	0.000	10.000	10.000	10.462	20.850	10.388	64.5	64.5	64.50	85.0	77.0	81.00	14.70	0.9855	1.8042
0.672	1.50	-1.50	1.0000	0.000	10.000	10.000	20.850	31.260	10.410	64.5	64.5	64.50	86.0	78.0	82.00	14.70	0.9852	1.8008
0.951	3.00	-1.80	1.0000	0.000	10.000	10.000	952.676	963.085	10.409	64.0	64.0	64.00	87.0	77.0	82.00	10.39	0.9819	1.7992
0.947	3.00	-1.80	1.0000	0.000	10.000	10.000	963.085	973.490	10.405	64.0	64.0	64.00	86.0	77.0	81.50	10.44	0.9813	1.8165
Averages																	0.98541	1.82803

Nomenclature	Equations
P <sub>b</sub> Barometric Pressure (in. Hg) Q Flow Rate (cfm) ΔH Orifice Pressure differential (in. H <sub>2</sub> O) ΔP Inlet Pressure Differential (in. H <sub>2</sub> O) V <sub>d</sub> Gas Meter Volume - Dry (ft <sup>3</sup> ) V <sub>ds</sub> Standard Meter Volume - Dry (ft <sup>3</sup> ) T <sub>d</sub> Average Meter Box Temperature (°F) T <sub>o</sub> Outlet Meter Box Temperature (°F) T <sub>ds</sub> Average Standard Meter Temperature (°F) Y <sub>d</sub> Meter Correction Factor (unitless), Y <sub>1</sub> sY <sub>avg</sub> ± 0.02 Y <sub>ds</sub> Standard Meter Correction Factor (unitless) ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H <sub>2</sub> O) ΔH@ <sub>1.5</sub> ΔH@ <sub>avg</sub> ± 0.2 Θ Duration of Run (minutes)	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$



Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
4.9	5.0
10.1	10.0
15.1	15.0
20.1	20.0
24.7	25.0

Calibration Reference Information (Standard Meter)	
Reference used: <u>Wet Test Meter</u>	Serial No: <u>11AG9</u>
Calibrated By: <u>Martin Vaguero</u>	Date Calibrated: <u>7/22/2012</u>
Percent Error: <u>0.245%</u>	Calibration Due Date: <u>7/23/2013</u>

Meter Box Pre-Calibration Inspection			
Positive Leak Check:	Pass	Electrical Check:	Pass
Negative Leak Check:	Pass	Pyrometer Check:	Pass
Vacuum Gauge Check:	Pass	YD Tolerance:	Pass



# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-6

Office: n/a

Calibrated by: J. Ivens

Client: n/a

Date: 1/21/13

Job No: n/a

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6	7
50	49	50	50	50	50		
100	99	100	100	100	100		
150	149	150	150	150	150		
200	199	200	200	200	200		
250	249	250	250	250	250		
300	299	300	300	300	300		
350	349	350	350	350	350		
400	399	400	400	400	400		
450	449	450	450	450	450		
500	499	500	500	500	500		
550	549	550	550	550	550		
600	599	600	600	600	600		

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

### Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-279500</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>8/20/2012</u>
Calibration Report No: <u>1000164078</u>	Calibration Due Date: <u>8/21/2013</u>

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 12218      Meter No. 66-6      Orifice C-5  
 Location warehouse      Meter Yd 0.9854      Orifice K' 0.5583  
 Test Date 04/04/13      Meter ΔH@ 1.8280      Orifice Cal. Date 11/21/12  
 Operator P. Bihun      Full Test Cal. Date 01/21/13

### Leak Checks

Negative Pressure  Pass  
*No movement of manometer in one-minute*  
 Positive Pressure  Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 29.44 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. - T <sub>amb</sub> (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (dcf)	Avg Meter Temp. for Run - T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	672.30	66	65								
	5.0	676.05	67	65	69	1.70	20	5.0	3.75	65.8	0.9605	0.0%
	10.0	679.80	68	66	72	1.70	20	5.0	3.75	66.5	0.9592	-0.1%
	15.0	683.55	70	67	74	1.70	20	5.0	3.75	67.8	0.9610	0.1%
											<b>Average Y<sub>i</sub></b>	0.9602
											<b>Cal. Error</b>	-2.6%

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec. : } \text{Cal. Error} \leq \pm 5\%$$

F-21


# Clean Air Engineering - Meter Box Full Test Calibration

Client: Source Reviewed By: M. Vaquero Calibration Signature: [Signature]  
 ID No: 66-11 Calibrated By: Jeff Ivens Meter Box Yd: 0.9906  
 Dept No: Source Date of Calibration: 07/11/12 Meter Box ΔH@: 1.8274  
 Meter Box Serial No: n/a Due Date of Calibration: 07/12/13 Barometer Serial No: W12637  
 Manufacturer Part No: 0028 Meter Box Vacuum: 1.0 in. H<sub>2</sub>O Barometric Pressure: 29.34 in. Hg

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y <sub>ds</sub>	Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	T <sub>is</sub> In	T <sub>os</sub> Out	T <sub>ds</sub> Avg.	T <sub>i</sub> In	T <sub>o</sub> Out	T <sub>d</sub> Avg.	Θ	Y <sub>d</sub>	ΔH@
0.377	0.50	-1.20	1.0000	0.000	5.000	5.000	984.600	989.693	5.093	78.5	78.5	78.50	88.0	85.0	86.50	12.73	0.9921	1.8750
0.377	0.50	-1.20	1.0000	0.000	5.000	5.000	989.693	994.781	5.088	78.5	78.5	78.50	87.0	85.0	86.00	12.75	0.9922	1.8809
0.664	1.50	-1.50	1.0000	0.000	10.000	10.000	19.911	30.137	10.226	79.0	79.0	79.00	93.0	86.0	89.50	14.47	0.9895	1.8170
0.663	1.50	-1.50	1.0000	0.000	10.000	10.000	30.137	40.373	10.236	79.0	79.0	79.00	93.0	86.0	89.50	14.48	0.9885	1.8195
0.950	3.00	-1.80	1.0000	0.000	10.000	10.000	957.401	967.589	10.188	78.5	78.5	78.50	95.0	85.0	90.00	10.12	0.9905	1.7774
0.945	3.00	-1.80	1.0000	0.000	10.000	10.000	967.589	977.782	10.193	78.5	78.5	78.50	96.0	85.0	90.50	10.17	0.9910	1.7950
Averages																	0.99062	1.82744

Nomenclature	Equations
P <sub>b</sub> Barometric Pressure (in. Hg) Q Flow Rate (cfm) ΔH Orifice Pressure differential (in. H <sub>2</sub> O) ΔP Inlet Pressure Differential (in. H <sub>2</sub> O) V <sub>d</sub> Gas Meter Volume - Dry (ft <sup>3</sup> ) V <sub>ds</sub> Standard Meter Volume - Dry (ft <sup>3</sup> ) T <sub>d</sub> Average Meter Box Temperature (°F) T <sub>o</sub> Outlet Meter Box Temperature (°F) T <sub>ds</sub> Average Standard Meter Temperature (°F) Y <sub>d</sub> Meter Correction Factor (unitless), Y <sub>1</sub> ≤ Y <sub>avg</sub> ± 0.02 Y <sub>ds</sub> Standard Meter Correction Factor (unitless) ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H <sub>2</sub> O) ΔH@ ≤ ΔH <sub>avg</sub> ± 0.2 Θ Duration of Run (minutes)	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_o + 460)(\Theta)}$

Average YD vs. Average CFM



Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
4.7	5.0
9.8	10.0
14.9	15.0
20.3	20.0
25.6	25.0

Calibration Reference Information (Standard Meter)	
Reference Used: <u>Wet Test Meter</u>	Serial No: <u>11AH6</u>
Calibrated By: <u>Martin Vaquero</u>	Date Calibrated: <u>10/28/2011</u>
Percent Error: <u>0.230%</u>	Calibration Due Date: <u>10/26/2012</u>

Meter Box Pre-Calibration Inspection			
Positive Leak Check:	Pass	Electrical Check:	Pass
Negative Leak Check:	Pass	Pyrometer Check:	Pass
Vacuum Gauge Check:	Pass	YD Tolerance:	Pass



# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-11 Office: n/a  
 Calibrated by: Jeff Ivens Client: Source  
 Date: 7/11/12 Job No: n/a  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6	7
50	49	50	50	49	49		
100	99	100	100	99	99		
150	149	150	150	149	149		
200	199	200	200	199	199		
250	249	250	250	249	249		
300	299	300	300	299	299		
350	349	350	350	349	349		
400	399	400	400	399	399		
450	449	450	450	449	449		
500	499	500	500	499	499		
550	549	550	550	549	549		
600	599	600	600	599	599		

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-279500</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>8/18/2011</u>
Calibration Report No: <u>1000150187</u>	Calibration Due Date: <u>8/18/2012</u>

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 12218                      Meter No. 66-11                      Orifice C-3  
 Location warehouse                      Meter Yd 0.9906                      Orifice K' 0.4406  
 Test Date 04/03/13                      Meter ΔH@ 1.8274                      Orifice Cal. Date 11/21/12  
 Operator P. Bihun                      Full Test Cal. Date 07/11/12

### Leak Checks

Negative Pressure  Pass  
*No movement of manometer in one-minute*  
 Positive Pressure  Pass  
*No movement of manometer in one-minute*

Barom. Press. (P<sub>b</sub>) 29.65 in. Hg

Important: All leak checks must pass in order for calibration to be valid.

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. - T <sub>amb</sub> (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (dcf)	Avg Meter Temp. for Run - T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	179.00	68	67								
	5.0	181.91	69	67	70	1.10	21	5.0	2.91	67.8	0.9811	0.1%
	10.0	184.82	69	68	70	1.10	21	5.0	2.91	68.3	0.9821	0.2%
	15.0	187.74	70	68	72	1.10	21	5.0	2.92	68.8	0.9778	-0.3%
<b>Average Y<sub>i</sub></b>											0.9803	
<b>Cal. Error</b>											-1.0%	

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$Cal. Error = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec. : } Cal. Error \leq \pm 5\%$$

F - 24


# Clean Air Engineering - Meter Box Full Test Calibration

Client: Source Reviewed By: M. Vaquero Calibration Signature: [Signature]  
 ID No: 66-14 Calibrated By: Jeff Ivens Meter Box Yd: 0.9879  
 Dept No: Source Date of Calibration: 09/12/12 Meter Box ΔH@: 1.8015  
 Meter Box Serial No: n/a Due Date of Calibration: 09/13/13 Barometer Serial No: W12637  
 Manufacturer Part No: 0028 Meter Box Vacuum: 1.0 in. H<sub>2</sub>O Barometric Pressure: 29.36 in. Hg

Q	ΔH	ΔP	Y <sub>ds</sub>	Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
				Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	T <sub>is</sub> In	T <sub>os</sub> Out	T <sub>ds</sub> Avg.	T <sub>i</sub> In	T <sub>o</sub> Out	T <sub>d</sub> Avg.		θ	Y <sub>d</sub>
0.384	0.50	-1.20	1.0000	0.000	5.000	5.000	31.900	37.035	5.135	79.0	79.0	79.00	90.0	88.0	89.00	12.51	0.9876	1.8029
0.384	0.50	-1.20	1.0000	0.000	5.000	5.000	37.035	42.171	5.136	79.0	79.0	79.00	90.0	87.0	88.50	12.51	0.9865	1.8062
0.670	1.50	-1.50	1.0000	0.000	10.000	10.000	51.301	61.594	10.293	79.0	79.0	79.00	96.0	89.0	92.50	14.35	0.9884	1.7780
0.670	1.50	-1.50	1.0000	0.000	10.000	10.000	61.594	71.883	10.289	79.0	79.0	79.00	97.0	89.0	93.00	14.35	0.9897	1.7780
0.938	3.00	-1.80	1.0000	0.000	10.000	10.000	0.003	10.233	10.230	79.0	79.0	79.00	97.0	88.0	91.50	10.24	0.9883	1.8186
0.935	3.00	-1.80	1.0000	0.000	10.000	10.000	10.233	20.462	10.249	79.0	79.0	79.00	97.0	87.0	92.00	10.28	0.9873	1.8295
Averages																0.98795	1.80153	

Nomenclature	Equations
<p>P<sub>b</sub> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p>ΔP Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p>V<sub>d</sub> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p>V<sub>ds</sub> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p>T<sub>a</sub> Average Meter Box Temperature (°F)</p> <p>T<sub>o</sub> Outlet Meter Box Temperature (°F)</p> <p>T<sub>ds</sub> Average Standard Meter Temperature (°F)</p> <p>Y<sub>d</sub> Meter Correction Factor (unitless), Y<sub>d</sub> ≤ Y<sub>avg</sub> ± 0.02</p> <p>Y<sub>ds</sub> Standard Meter Correction Factor (unitless)</p> <p>ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p>ΔH@ ≤ ΔH@<sub>avg</sub> ± 0.2</p> <p>θ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_a + 460)} \left[ \frac{(T_{ds} + 460)\theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(Y_{ds} + 460)(\theta)}$

Average YD vs. Average CFM



12.47

Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
5.0	5.0
10.5	10.0
15.6	15.0
20.6	20.0
25.5	25.0

## Calibration Reference Information (Standard Meter)

Reference Used: Wei Test Meter Serial No: 11AH6  
 Calibrated By: Martin Vaquero Date Calibrated: 10/20/2011  
 Percent Error: 0.230% Calibration Due Date: 10/28/2012

## Meter Box Pre-Calibration Inspection

Positive Leak Check: Pass Electrical Check: Pass  
 Negative Leak Check: Pass Pyrometer Check: Pass  
 Vacuum Gauge Check: Pass YD Tolerance: Pass



# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-14 Office: n/a  
 Calibrated by: Jeff Ivens Client: Source  
 Date: 9/12/12 Job No: n/a  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6	7
50	50	51	48	49	49		
100	99	101	98	99	99		
150	149	151	149	149	149		
200	199	201	200	199	199		
250	249	251	249	249	249		
300	299	301	299	299	299		
350	349	351	349	349	349		
400	399	401	399	398	399		
450	449	451	449	449	449		
500	499	501	499	499	499		
550	549	551	549	549	549		
600	599	601	599	598	599		

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-279500</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>8/20/2012</u>
Calibration Report No: <u>1000164078</u>	Calibration Due Date: <u>8/20/2013</u>



## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 12218      Meter No. 66-14      Orifice C-5  
 Location wh      Meter Yd 0.9879      Orifice K' 0.5583  
 Test Date 04/02/13      Meter ΔH@ 1.8015      Orifice Cal. Date 11.21/12  
 Operator p bihun      Full Test Cal. Date 09/12/12

### Leak Checks

Negative Pressure  Pass  
*No movement of manometer in one-minute*  
 Positive Pressure  Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 29.50 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. - T <sub>amb</sub> (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (dcf)	Avg Meter Temp. for Run - T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	533.20	64	63								
	5.0	536.88	67	63	67	1.60	20	5.0	3.68	64.3	0.9781	0.3%
	10.0	540.57	66	63	71	1.60	20	5.0	3.69	64.8	0.9727	-0.3%
	15.0	544.24	67	64	74	1.60	20	5.0	3.67	65.0	0.9757	0.0%
											Average Y <sub>i</sub>	0.9755
											Cal. Error	-1.3%

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec. : } \text{Cal. Error} \leq \pm 5\%$$

F - 27

Client: SOURCE 86

Reviewed By: R.Redel

Calibration Signature: \_\_\_\_\_

ID No: 66-18

Calibrated By: O.Lavrov

Meter Box Yd: 1.0008

Job No: n/a

Date of Calibration: 10/31/12

Meter Box ΔH@: 1.9165

Meter Box Serial No: 4U-5139-63M

Due Date of Calibration: 11/01/13

Barometer Serial No: W12637

Manufacturer Part No: 0028

Meter Box Vacuum: 1.0 in. H<sub>2</sub>O


Barometric Pressure: 29.00 In. Hg

				Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
Q	ΔH	ΔP	Y <sub>ds</sub>	Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	T <sub>is</sub> In	T <sub>os</sub> Out	T <sub>ds</sub> Avg.	T <sub>i</sub> In	T <sub>o</sub> Out	T <sub>d</sub> Avg.	Θ	Y <sub>d</sub>	ΔH@
0.374	0.50	-1.00	1.0000	0.000	6.000	6.000	62.141	68.233	6.092	71.5	71.5	71.50	84.0	81.0	82.50	15.45	1.0015	1.9043
0.374	0.50	-1.00	1.0000	0.000	5.000	5.000	68.233	73.298	5.065	71.5	71.5	71.50	83.0	80.0	81.50	12.87	1.0019	1.9063
0.651	1.50	-1.30	1.0000	0.000	10.000	10.000	77.743	87.888	10.145	71.5	71.5	71.50	86.0	83.0	84.50	14.78	1.0027	1.8752
0.651	1.50	-1.30	1.0000	0.000	10.000	10.000	87.888	98.028	10.140	71.5	71.5	71.50	86.0	83.0	84.50	14.78	1.0032	1.8752
0.900	3.00	-1.70	1.0000	0.000	10.000	10.000	38.244	48.400	10.156	71.5	71.5	71.50	89.0	80.0	84.50	10.69	0.9988	1.9728
0.901	3.00	-1.70	1.0000	0.000	10.000	10.000	48.400	58.556	10.156	71.5	71.5	71.50	90.0	81.0	85.50	10.68	0.9986	1.9655
Averages																	1.00077	1.91653

F - 28

Nomenclature	Equations
<p>P<sub>b</sub> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p>ΔP Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p>V<sub>d</sub> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p>V<sub>ds</sub> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p>T<sub>d</sub> Average Meter Box Temperature (°F)</p> <p>T<sub>o</sub> Outlet Meter Box Temperature (°F)</p> <p>T<sub>ds</sub> Average Standard Meter Temperature (°F)</p> <p>Y<sub>d</sub> Meter Correction Factor (unitless), Y<sub>i</sub> ≤ Y<sub>avg</sub> ± 0.02</p> <p>Y<sub>ds</sub> Standard Meter Correction Factor (unitless)</p> <p>ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p>ΔH@ ≤ ΔH@<sub>avg</sub> ± 0.2</p> <p>Θ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Average YD vs Average CFM



Vacuum Gauge

Standard (in. Hg)	Gauge (in. Hg)
4.6	5.0
9.7	10.0
15.1	15.0
20.1	20.0
25.1	25.0

Calibration Reference Information (Standard Meter)	
Reference Used: Wet Test Meter	Serial No: 11AG9
Calibrated By: Martin Vaquero	Date Calibrated: 7/22/2012
Percent Error: 0.249%	Calibration Due Date: 7/22/2013

Meter Box Pre-Calibration Inspection			
Positive Leak Check:	Pass	Electrical Check:	Pass
Negative Leak Check:	Pass	Pyrometer Check:	Pass
Vacuum Gauge Check:	Pass	YD Tolerance:	Pass
± 2% of 1.0000			

# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-18

Office: Express

Calibrated by: O.Lavrov

Client: SOURCE 66

Date: 10/31/12

Job No: n/a

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)							
	1	2	3	4	5			
	Stack	Probe	Filter	Imp Out	Aux			
50	51	48	50	51	51			
100	101	98	100	101	101			
150	151	148	150	151	151			
200	201	198	200	201	201			
250	251	248	250	251	251			
300	300	298	300	300	300			
350	350	348	350	350	350			
400	400	398	400	400	400			
450	450	448	450	450	450			
500	500	498	500	500	500			
550	550	548	550	550	550			
600	600	598	600	600	600			

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-225950</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>10/18/2012</u>
Calibration Report No: <u>1000164938</u>	Calibration Due Date: <u>10/18/2013</u>

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 12218                      Meter No. 66-18                      Orifice C-5  
 Location warehouse                      Meter Yd 1.0008                      Orifice K' 0.5583  
 Test Date 04/03/13                      Meter ΔH@ 1.9165                      Orifice Cal. Date 11/21/12  
 Operator P. Bihun                      Full Test Cal. Date 10/31/12

**Leak Checks**  
 Negative Pressure                       Pass  
*No movement of manometer in one-minute*  
 Positive Pressure                       Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 29.65 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. - T <sub>amb</sub> (°F)	Orifice ΔH (In. W.C.)	Vacuum (In. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (dcf)	Avg Meter Temp. for Run T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	365.50	69	67								
	5.0	369.15	70	67	72	1.80	20	5.0	3.65	68.3	0.9885	0.1%
	10.0	372.79	70	68	74	1.80	20	5.0	3.64	68.8	0.9903	0.3%
	15.0	376.45	71	68	77	1.80	20	5.0	3.65	69.3	0.9844	-0.3%
											<b>Average Y<sub>i</sub></b>	0.9878
											<b>Cal. Error</b>	-1.3%

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}}{\bar{Y}} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$Cal. Error = \frac{\bar{Y} - Y_d}{Y_d} \times 100 \quad \text{Spec.: } Cal. Error \leq \pm 5\%$$

Client: SOURCE 66

Reviewed By: R.Redel

Calibration Signature: 

ID No: 66-22

Calibrated By: O.Lavrov

Meter Box Yd: 0.9972

Job No: N/A

Date of Calibration: 10/12/12

Meter Box ΔH@: 1.8340

Meter Box Serial No: 28-080307-1

Due Date of Calibration: 10/13/13

Barometer Serial No: W12637

Manufacturer Part No: 0028


Meter Box Vacuum: 1.0 in. H<sub>2</sub>O

Barometric Pressure: 29.61 in. Hg

Standard Meter Gas Volume (ft <sup>3</sup> )				Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results				
Q	ΔH	ΔP	Y <sub>ds</sub>	Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	T <sub>is</sub> In	T <sub>os</sub> Out	T <sub>ds</sub> Avg.	T <sub>i</sub> In	T <sub>o</sub> Out	T <sub>d</sub> Avg.	Θ	Y <sub>d</sub>	ΔH@
0.380	0.50	-1.10	1.0000	0.000	5.000	5.000	958.243	963.397	5.154	72.5	72.5	72.50	91.0	88.0	89.50	12.91	0.9971	1.8582
0.379	0.50	-1.10	1.0000	0.000	5.000	5.000	963.397	968.558	5.161	72.5	72.5	72.50	91.0	88.0	89.50	12.93	0.9958	1.8640
0.658	1.50	-1.30	1.0000	0.000	10.000	10.000	2.358	12.646	10.287	72.5	72.5	72.50	95.0	88.0	91.50	14.96	0.9998	1.8714
0.657	1.50	-1.30	1.0000	0.000	10.000	10.000	12.646	22.940	10.294	72.5	72.5	72.50	95.0	88.0	91.50	14.94	0.9991	1.8664
0.913	3.00	-1.80	1.0000	0.000	10.000	10.000	932.821	943.182	10.341	72.0	72.0	72.00	99.0	90.0	94.50	10.75	0.9980	1.9220
0.913	3.00	-1.80	1.0000	0.000	10.000	10.000	943.182	953.512	10.350	72.0	72.0	72.00	99.0	90.0	94.50	10.75	0.9951	1.9220
Averages																	0.99716	1.88399

F - 31

Nomenclature	Equations
<p>P<sub>b</sub> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure differential (in. H<sub>2</sub>O)</p> <p>ΔP Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p>V<sub>d</sub> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p>V<sub>ds</sub> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p>T<sub>d</sub> Average Meter Box Temperature (°F)</p> <p>T<sub>o</sub> Outlet Meter Box Temperature (°F)</p> <p>T<sub>ds</sub> Average Standard Meter Temperature (°F)</p> <p>Y<sub>d</sub> Meter Correction Factor (unitless), Y<sub>i</sub> ≤ Y<sub>avg</sub> ± 0.02</p> <p>Y<sub>ds</sub> Standard Meter Correction Factor (unitless)</p> <p>ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p>ΔH@ ≤ ΔH@<sub>avg</sub> ± 0.2</p> <p>Θ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \left[ \frac{T_d + 460}{T_{ds} + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right] \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b(T_o + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds} \times P_b)}{(T_{ds} + 460)(\Theta)}$



Vacuum Gauge	
Standard (in. Hg)	Gauge (in. Hg)
5.5	5.0
9.9	10.0
15.1	15.0
20.2	20.0
25.1	25.0

Calibration Reference Information (Standard Meter)	
Reference Used: <u>Wet Test Meter</u>	Serial No: <u>11AG9</u>
Calibrated By: <u>Martin Vaguero</u>	Date Calibrated: <u>7/22/2012</u>
Percent Error: <u>0.245%</u>	Calibration Due Date: <u>7/23/2013</u>

Meter Box Pre-Calibration Inspection			
Positive Leak Check: <u>Pass</u>	Electrical Check: <u>Pass</u>	Negative Leak Check: <u>Pass</u>	Pyrometer Check: <u>Pass</u>
Vacuum Gauge Check: <u>Pass</u>	YD Tolerance: <u>± 2% of 1.0000</u>		

# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 66-22

Office: Express

Calibrated by: O.Lavrov

Client: SOURCE 66

Date: 10/12/12

Job No: n/a

Temperature Scale Used: Fahrenheit

Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)					
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	
50	50	49	48	50	50	
100	100	99	98	100	100	
150	150	149	148	150	150	
200	200	199	198	200	200	
250	250	249	248	250	250	
300	300	299	298	300	300	
350	350	349	348	350	350	
400	400	399	399	400	400	
450	450	449	449	450	450	
500	500	499	498	500	500	
550	550	549	549	550	550	
600	600	599	598	600	600	

Tolerance =  $\pm 2^{\circ}\text{F}$  difference from reference setting.

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-279500</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>8/20/2012</u>
Calibration Report No: <u>1000164078</u>	Calibration Due Date: <u>8/20/2013</u>

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 12218                      Meter No. 66-22                      Orifice C-5  
 Location warehouse                      Meter Yd 0.9972                      Orifice K' 0.5583  
 Test Date 04/03/13                      Meter ΔH@ 1.8840                      Orifice Cal. Date 11/21/12  
 Operator P. Bihun                      Full Test Cal. Date 10/12/12

### Leak Checks

Negative Pressure  Pass  
*No movement of manometer in one-minute*  
 Positive Pressure  Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 29.65 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. - T <sub>amb</sub> (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (dcf)	Avg Meter Temp. for Run - T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	904.00	67	65								
	5.0	907.65	68	66	72	1.70	20	5.0	3.65	66.5	0.9855	0.4%
	10.0	911.32	69	67	74	1.70	20	5.0	3.67	67.5	0.9802	-0.2%
	15.0	914.99	70	67	76	1.70	20	5.0	3.67	68.3	0.9797	-0.2%
											<b>Average Y<sub>i</sub></b>	0.9818
											<b>Cal. Error</b>	-1.5%

### Calculations and Specifications

$$Y_i = \frac{K \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec. : } \Delta Y_i \leq \pm 2\%$$

$$Cal. Error = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec. : } Cal. Error \leq \pm 5\%$$

F-33


# Clean Air Engineering - Meter Box Full Test Calibration

Client: Source Reviewed By: R. Redel Calibration Signature: [Signature]  
 ID No: 85-2 Calibrated By: Jeff Ivens Meter Box Yd: 1.0039  
 Dept No: Source 66 Date of Calibration: 12/21/12 Meter Box ΔH@: 1.7413  
 Meter Box Serial No: n/a Due Date of Calibration: 12/22/13 Barometer Serial No: W12637  
 Manufacturer Part No: 0028 Meter Box Vacuum: 1.0 in. H<sub>2</sub>O Barometric Pressure: 29.05 in. Hg

Q	ΔH	ΔP	Y <sub>ds</sub>	Standard Meter Gas Volume (ft <sup>3</sup> )			Meter Box Gas Volume (ft <sup>3</sup> )			Std. Meter Temperature (°F)			Meter Box Temperature (°F)			Time (min.)	Calibration Results	
				Initial	Final	V <sub>ds</sub> Net	Initial	Final	V <sub>d</sub> Net	T <sub>is</sub> In	T <sub>os</sub> Out	T <sub>ds</sub> Avg.	T <sub>i</sub> In	T <sub>o</sub> Out	T <sub>d</sub> Avg.		Θ	Y <sub>d</sub>
0.392	0.50	-1.20	1.0000	0.000	5.000	5.000	96.200	101.271	5.071	66.0	66.0	66.00	83.0	79.0	81.00	12.44	1.0098	1.7446
0.389	0.50	-1.20	1.0000	0.000	5.000	5.000	106.319	111.396	5.077	66.0	66.0	66.00	83.0	80.0	81.50	12.52	1.0095	1.7638
0.682	1.50	-1.50	1.0000	0.000	10.000	10.000	127.792	138.085	10.293	66.5	66.5	66.50	91.0	82.0	86.50	14.27	1.0008	1.7155
0.852	1.50	-1.50	1.0000	0.000	10.000	10.000	148.410	158.693	10.283	66.5	66.5	66.50	91.0	83.0	87.00	14.27	1.0027	1.7123
0.857	3.00	-1.80	1.0000	0.000	10.000	10.000	67.805	77.808	10.203	65.5	65.5	65.50	89.0	77.0	83.00	10.19	1.0005	1.7591
0.858	3.00	-1.80	1.0000	0.000	10.000	10.000	77.808	88.043	10.235	65.5	65.5	65.50	91.0	78.0	84.50	10.18	1.0002	1.7524
Averages																	1.00391	1.74128

Nomenclature	Equations
<p>P<sub>b</sub> Barometric Pressure (in. Hg)</p> <p>Q Flow Rate (cfm)</p> <p>ΔH Orifice Pressure Differential (in. H<sub>2</sub>O)</p> <p>ΔP Inlet Pressure Differential (in. H<sub>2</sub>O)</p> <p>V<sub>ds</sub> Gas Meter Volume - Dry (ft<sup>3</sup>)</p> <p>V<sub>ds</sub> Standard Meter Volume - Dry (ft<sup>3</sup>)</p> <p>T<sub>a</sub> Average Meter Box Temperature (°F)</p> <p>T<sub>o</sub> Outlet Meter Box Temperature (°F)</p> <p>T<sub>ds</sub> Average Standard Meter Temperature (°F)</p> <p>Y<sub>d</sub> Meter Correction Factor (unitless), Y<sub>d</sub> ≤ Y<sub>avg</sub> ± 0.02</p> <p>Y<sub>ds</sub> Standard Meter Correction Factor (unitless)</p> <p>ΔH@ Orifice Pressure Differential giving 0.75 cfm of air at 68°F and 29.92 in. Hg (in. H<sub>2</sub>O)</p> <p>ΔH@ ≤ ΔH@<sub>avg</sub> ± 0.2</p> <p>Θ Duration of Run (minutes)</p>	$Y_d = (Y_{ds}) \left[ \frac{V_{ds}}{V_d} \right] \left[ \frac{T_d + 460}{T_a + 460} \right] \left[ \frac{P_b + \Delta P / 13.6}{P_b + \Delta H / 13.6} \right]$ $\Delta H@ = \frac{(0.0319)(\Delta H)}{P_b (T_a + 460)} \left[ \frac{(T_{ds} + 460)\Theta}{(V_{ds})(Y_{ds})} \right]^2$ $Q = \frac{17.64(V_{ds})(P_b)}{(T_{ds} + 460)(\Theta)}$

Average YD vs. Average CFM



Vacuum Gauge	
Standard (in.Hg)	Gauge (in.Hg)
5.3	5.0
10.2	10.0
15.4	15.0
20.4	20.0
25.4	25.0

Calibration Reference Information (Standard Meter)	
Reference Used: <u>Wet Test Meter</u>	Serial No: <u>11AG9</u>
Calibrated By: <u>Martin Vaquero</u>	Date Calibrated: <u>7/22/2012</u>
Percent Error: <u>0.245%</u>	Calibration Due Date: <u>7/23/2013</u>

Meter Box Pre-Calibration Inspection			
Positive Leak Check:	Pass	Electrical Check:	Pass
Negative Leak Check:	Pass	Pyrometer Check:	Pass
Vacuum Gauge Check:	Pass	YD Tolerance:	Pass



F - 34



# Meter Box - Pyrometer Calibration Sheet

Meter Box No: 85-2 Office: n/a  
 Calibrated by: Jeff Ivens Client: Source  
 Date: 12/21/12 Job No: n/a  
 Temperature Scale Used: Fahrenheit Type of Calibration: Full-Test

Calibration Reference Settings (°F)	Pyrometer Reading for each Channel (°F)						
	1 Stack	2 Probe	3 Filter	4 Imp Out	5 Aux	6	7
50	51	51	51	51	50		
100	101	101	101	101	101		
150	151	152	150	151	151		
200	201	202	201	201	201		
250	252	252	250	251	251		
300	301	302	300	301	301		
350	351	352	350	351	351		
400	401	402	400	401	401		
450	452	451	450	451	451		
500	501	501	500	501	501		
550	552	552	549	551	551		
600	601	602	600	600	601		

Tolerance = ±2°F difference from reference setting.

## Calibration Reference Information

Reference Used: <u>Omega CL23A</u>	Serial No: <u>T-279500</u>
Calibrated By: <u>JH Metrology</u>	Date Calibrated: <u>10/18/2012</u>
Calibration Report No: <u>1000164938</u>	Calibration Due Date: <u>10/18/2013</u>

## Meter Box Critical Orifice Post-Test Calibration Data

Project No. 12218      Meter No. 85-2      Orifice C-5  
 Location warehouse      Meter Yd 1.0039      Orifice K' 0.5583  
 Test Date 04/03/13      Meter ΔH@ 1.7413      Orifice Cal. Date 11/21/12  
 Operator P. Bihun      Full Test Cal. Date 12/21/12

### Leak Checks

Negative Pressure  Pass  
*No movement of manometer in one-minute*  
 Positive Pressure  Pass  
*No movement of manometer in one-minute*

Important: All leak checks must pass in order for calibration to be valid.

Barom. Press. (P<sub>b</sub>) 29.65 in. Hg

Run	Elapsed Time (minutes)	Meter Volume (dcf)	Meter Temperature		Ambient Temp. - T <sub>amb</sub> (°F)	Orifice ΔH (in. W.C.)	Vacuum (in. Hg)	Net Run Time - θ (minutes)	Net Meter Volume for Run - V <sub>m</sub> (dcf)	Avg Meter Temp. for Run T <sub>m</sub> (°F)	DGM Calibration Factor - Y <sub>i</sub>	Percent Variation - ΔY <sub>i</sub>
			Inlet (°F)	Outlet (°F)								
	0.0	824.10	71	70								
	5.0	827.84	72	69	73	1.60	21	5.0	3.74	70.5	0.9684	0.0%
	10.0	831.57	73	70	74	1.60	20	5.0	3.73	71.0	0.9710	0.3%
	15.0	835.32	74	70	76	1.60	20	5.0	3.75	71.8	0.9654	-0.3%
											<b>Average Y<sub>i</sub></b>	0.9683
											<b>Cal. Error</b>	-3.5%

### Calculations and Specifications

$$Y_i = \frac{K' \times P_b \times (T_m + 460) \times \theta}{17.64 \times V_m \times (P_b + \frac{\Delta H}{13.6}) \times \sqrt{T_{amb} + 460}}$$

$$\Delta Y_i = \frac{Y_i - \bar{Y}_i}{\bar{Y}_i} \times 100 \quad \text{Spec.: } \Delta Y_i \leq \pm 2\%$$

$$\text{Cal. Error} = \frac{\bar{Y}_i - Y_d}{Y_d} \times 100 \quad \text{Spec.: } \text{Cal. Error} \leq \pm 5\%$$

# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-4-3

Project Number: \_\_\_\_\_

## Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	73	74	-1	0.19%	
2	200°F-250°F	236	239	-3	0.43%	%Difference ≤ 1.5

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

## Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

**Pitot Side 'A':**

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(A)</sub> **
1	0.549	0.749	0.848	0.003
2	0.544	0.749	0.844	0.002
3	0.545	0.749	0.845	0.001
Side 'A' Average Probe C <sub>p(A)</sub> =			0.8456	0.0017

**Specification**  
Avg. C<sub>p</sub> Deviations ≤ 0.01

**Pitot Side 'B':**

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(B)</sub> **
1	0.535	0.747	0.838	0.001
2	0.541	0.755	0.839	0.000
3	0.540	0.753	0.839	0.000
Side 'B' Average Probe C <sub>p(B)</sub> =			0.8382	0.0005

**Specification**  
Avg. C<sub>p</sub> Deviations ≤ 0.01

<b>'A' Average C<sub>p</sub></b> 0.846	—	<b>'B' Average C<sub>p</sub></b> 0.838	=	<b>Difference</b> 0.008
---	---	---	---	----------------------------

**Specification**  
|Difference| ≤ 0.01

Does assembly meet specifications?

YES

If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

(All specifications are from EPA 600/9-76-003 section 3.1)

Probe Cp= 0.842

Calibrated by: D. Luckhard

Date: 10/09/2012



# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-16

Project Number: \_\_\_\_\_

**Thermocouple Calibration**

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	75	75	0	0.00%	%Difference ≤ 1.5
2	200°F-250°F	298	295	3	0.40%	

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications?  YES

**Pitot Tube Calibration (Wind Tunnel Method @ 48 ft/sec)**

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>P(S)</sub> *	Abs. Deviation from Avg. C <sub>P(A)</sub> **
1	0.533	0.780	0.819	0.007
2	0.544	0.771	0.832	0.006
3	0.541	0.775	0.827	0.001
Side 'A' Average Probe C <sub>P(A)</sub> =			0.8256	0.0047

Specification  
Avg. C<sub>p</sub> Deviations ≤ 0.01

Pitot Side 'B':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>P(S)</sub> *	Abs. Deviation from Avg. C <sub>P(B)</sub> **
1	0.543	0.774	0.830	0.005
2	0.539	0.786	0.820	0.005
3	0.542	0.782	0.824	0.000
Side 'B' Average Probe C <sub>P(B)</sub> =			0.8246	0.0033

Specification  
Avg. C<sub>p</sub> Deviations ≤ 0.01

'A' Average C <sub>p</sub>	—	'B' Average C <sub>p</sub>	=	Difference	Specification
0.826		0.825		0.001	Difference  ≤ 0.01

Does assembly meet specifications?

YES

If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$*C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta P_{(STD)}}{\Delta P_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

**All specifications are from EPA-600/9-76-005, Section 3.1**

Probe Cp= 0.825

Calibrated by: G. Pavlovics

Date: 10/25/2012

# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot I.D. Number: 67-8-17  
 Project Number: \_\_\_\_\_

## Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	72	72	0	0.00%	%Difference ≤ 1.5
2	200°F-250°F	242	245	-3	0.43%	

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

## Pitot Tube Calibration (Wind Tunnel Method @ 49 ft/sec)

Reference Pitot I.D. No: Wind Tunnel Reference Pitot Cp: 0.99

Pitot Side 'A':				Abs. Deviation from Avg. C <sub>p(A)</sub> **	Specification Avg. C <sub>p</sub> Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *		
1	0.544	0.778	0.828	0.001	
2	0.544	0.780	0.827	0.000	
3	0.541	0.778	0.826	0.001	
Side 'A' Average Probe C <sub>p(A)</sub> =			0.8270	0.0007	

Pitot Side 'B':				Abs. Deviation from Avg. C <sub>p(B)</sub> **	Specification Avg. C <sub>p</sub> Deviations ≤ 0.01
Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *		
1	0.546	0.796	0.820	0.002	
2	0.549	0.797	0.822	0.000	
3	0.547	0.792	0.823	0.001	
Side 'B' Average Probe C <sub>p(B)</sub> =			0.8214	0.0011	

'A' Average C <sub>p</sub> 0.827	-	'B' Average C <sub>p</sub> 0.821	=	Difference 0.006	Specification  Difference  ≤ 0.01
-------------------------------------	---	-------------------------------------	---	---------------------	--------------------------------------

Does assembly meet specifications? YES → If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' C<sub>p</sub> values. If "No", Pitot must be replaced.

$$* C_{P(S)} = C_{P(STD)} \sqrt{\frac{\Delta p_{(STD)}}{\Delta p_{(S)}}}$$

$$** Deviation = |C_{P(S)} - \overline{C_{P(A \text{ or } B)}}|$$

All specifications are from EPA-600/9-76-005, section 3.1

Probe Cp= 0.824 Calibrated by: B ARNOLD Date: 04/20/2012



# Sample Probe Calibration

Probe Type: M5 with S-Type Pitot

I.D. Number: 67-8-21

Project Number: \_\_\_\_\_

## Thermocouple Calibration

Reference Type: Thermocouple Reference I.D. No: 15-078-39 Pyrometer I.D. No: 80512890 Units: °F

Point No.	Target Temp.	Reference Temp.	Indicated Temp.	Temp. Difference	% Difference*	Specification
1	Ambient	77	76	1	0.19%	%Difference ≤ 1.5
2	200°F-250°F	286	286	0	0.00%	

\* Based on Absolute Temperature (Rankine)

Does thermocouple assembly meet specifications? → YES

## Pitot Tube Calibration (Wind Tunnel Method @ 50 ft/sec)

Reference Pitot I.D. No: Wind Tunnel

Reference Pitot Cp: 0.99

Pitot Side 'A':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(A)</sub> **
1	0.537	0.801	0.811	0.002
2	0.537	0.799	0.811	0.001
3	0.544	0.800	0.816	0.003
Side 'A' Average Probe C <sub>p(A)</sub> =			0.8128	0.0022

Specification  
Avg. C<sub>p</sub> Deviations ≤ 0.01

Pitot Side 'B':

Trial No.	Reference ΔP	Probe ΔP	Probe C <sub>p(S)</sub> *	Abs. Deviation from Avg. C <sub>p(B)</sub> **
1	0.542	0.808	0.811	0.003
2	0.538	0.808	0.808	0.006
3	0.540	0.785	0.822	0.008
Side 'B' Average Probe C <sub>p(B)</sub> =			0.8133	0.0055

Specification  
Avg. C<sub>p</sub> Deviations ≤ 0.01

'A' Average C <sub>p</sub> 0.813	-	'B' Average C <sub>p</sub> 0.813	=	Difference 0.000
-------------------------------------	---	-------------------------------------	---	---------------------

Specification  
|Difference| ≤ 0.01

Does assembly meet specifications? → YES

If "Yes", C<sub>p</sub> = Average of Side 'A' and 'B' Cp values. If "No", Pitot must be replaced.

$$* C_{p(S)} = C_{p(STD)} \sqrt{\frac{\Delta p_{(STD)}}{\Delta p_{(S)}}}$$

$$** Deviation = |C_{p(S)} - \bar{C}_{p(A \text{ or } B)}|$$

## All specifications are from EPA 600/9-76-005 section 9.1

Probe Cp= 0.813

Calibrated by: G. Pavlovivs

Date: 10/25/2012



# Certificate of Calibration

2033001737

Page 1 of 2



## Customer Information

### On Site Calibration

CleanAir Engineering, Inc.  
500 W. Wood Street  
Palatine, IL 60067

PO #: 04380-64-65800

Reference #: 1232582dd

Account #: 09352MT

SO #: 32582

## Instrument Identification

Instrument Id: **8028301135**

Location:

Noun: Scale, 4100/0.1 Gram Digital

Model: AV4101C

Mfr: Ohaus

Serial #: 8028301135

Accuracy:  $\pm 0.1$  Gram repeatability,  $\pm 0.3$  Linearity

## Certification Information

Reason For Service: Calibration with Data

Technician: Eric Uphouse

Type Of Calibration: Normal

Cal Date: 16 AUG 12

As Found Condition: In Tolerance

Cal Due: 16 AUG 13

As Left Condition: Left As Found

Temperature: 21.0 °C

Procedure: 33K6-4-41-1 : Scales

Humidity: 35.0 %

In Tolerance     Out of Tolerance

## Calibration Data

Range	Nominal	As Found	As Left	Min	Max
Plate Repeatability					
Center	5.0	5.0	✓ As Found	4.9	5.1
Left Rear	5.0	5.0	✓ As Found	4.9	5.1
Right Rear	5.0	5.0	✓ As Found	4.9	5.1

*No sampling plan or other procedure was used for this calibration. Measurements and information on this certificate are valid at time of calibration only and any number of factors may cause calibration to drift out of tolerance prior to calibration due date.*

*This instrument has been calibrated using standards with accuracies traceable to the National Institute of Standards and Technology, derived from natural physical constants, from ratio measurements, or compared to consensus standards.*

*The expanded uncertainty of the measurement process has not exceeded 25% of the tolerance allowed for the individual characteristics measured, unless otherwise stated. The uncertainties are based on a 95% confidence level, K=2.*

*J.H. Metrology Co., Inc's Calibration Control System complies with applicable requirements of ANSI Z540-1-1994, ISO 9001, and ISO/IEC 17025-2005.*

*The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without the written approval of J.H. Metrology Co., Inc.*

Approved by: Eric Uphouse  
Vice President

Printed: 8/23/2012 13:08:38

Date: Aug 19, 2012

JH Metrology Co, Inc. • 1801 Hicks Road, Unit E • Rolling Meadows, Illinois 60008 • Phone: (847) 991-0290 • Fax: (847) 991-0348





# Certificate of Calibration

2033001737

Page 2 of 2



In Tolerance     Out of Tolerance

## Calibration Data

Range	Nominal	As Found		As Left	Min	Max
Plate Repeatability						
Left Front	5.0	5.0	✓	As Found	4.9	5.1
Right Front	5.0	5.0	✓	As Found	4.9	5.1
Center	5.0	5.0	✓	As Found	4.9	5.1
Linearity						
4100 Grams	100.0	100.0	✓	As Found	99.7	100.3
	2000.0	2000.0	✓	As Found	1999.7	2000.3
	4000.0	4000.0	✓	As Found	3999.7	4000.3

End of Datasheet

## Calibration Standards

<u>NIST Traceable #</u>	<u>Instrument ID#</u>	<u>Description</u>	<u>Model</u>	<u>Calibration Date</u>	<u>Date Due</u>
1000150842	00941	Metric Weight Set, 12 Piece, Class 2	Unknown	03 NOV 2010	30 NOV 2012
1000152014	01088	Weight Set, 1mg - 200g, Class 1	Unknown	01 DEC 2010	31 DEC 2012


*No sampling plan or other procedure was used for this calibration. Measurements and information on this certificate are valid at time of calibration only and any number of factors may cause calibration to drift out of tolerance prior to calibration due date.*

*This instrument has been calibrated using standards with accuracies traceable to the National Institute of Standards and Technology, derived from natural physical constants, from ratio measurements, or compared to consensus standards.*

*The expanded uncertainty of the measurement process has not exceeded 25% of the tolerance allowed for the individual characteristics measured, unless otherwise stated. The uncertainties are based on a 95% confidence level, K=2.*

*J.H. Metrology Co., Inc's Calibration Control System complies with applicable requirements of ANSI Z540-1-1994, ISO 9001, and ISO/IEC 17025-2005.*

*The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without the written approval of J.H. Metrology Co., Inc.*

  
 Approved by: \_\_\_\_\_  
 Vice President

Printed: 8/23/2012 13:08:38

Date: Aug 19, 2012

JH Metrology Co, Inc. • 1801 Hicks Road, Unit E • Rolling Meadows, Illinois 60008 • Phone: (847) 991-0290 • Fax: (847) 991-0348



# Certificate of Calibration

2033001736

Page 1 of 2



## Customer Information

### On Site Calibration

CleanAir Engineering, Inc.  
500 W. Wood Street  
Palatine, IL 60067

PO #: 04380-64-65800  
Reference #: 1232582dd  
Account #: 09352MT  
SO #: 32582

## Instrument Identification

Instrument Id: **8028301068**

Location:

Noun: Scale, 4100/0.1 Gram Digital

Model: AV4101C

Mfr: Ohaus

Serial #: 8028301068

Accuracy:  $\pm 0.1$  Gram repeatability,  $\pm 0.3$  Linearity

## Certification Information

Reason For Service: Calibration with Data

Technician: Eric Uphouse

Type Of Calibration: Normal

Cal Date: 16 AUG 12

As Found Condition: In Tolerance

Cal Due: 16 AUG 13

As Left Condition: Left As Found

Temperature: 21.0 °C

Procedure: 33K6-4-41-1 : Scales

Humidity: 35.0 %

In Tolerance     Out of Tolerance

## Calibration Data

Range	Nominal	As Found	As Left	Min	Max
Plate Repeatability					
Center	5.0	5.0	✓	As Found	4.9    5.1
Left Rear	5.0	5.0	✓	As Found	4.9    5.1
Right Rear	5.0	5.0	✓	As Found	4.9    5.1

*No sampling plan or other procedure was used for this calibration. Measurements and information on this certificate are valid at time of calibration only and any number of factors may cause calibration to drift out of tolerance prior to calibration due date.*

*This instrument has been calibrated using standards with accuracies traceable to the National Institute of Standards and Technology, derived from natural physical constants, from ratio measurements, or compared to consensus standards.*

*The expanded uncertainty of the measurement process has not exceeded 25% of the tolerance allowed for the individual characteristics measured, unless otherwise stated. The uncertainties are based on a 95% confidence level, K=2.*

*J.H. Metrology Co., Inc's Calibration Control System complies with applicable requirements of ANSI Z540-1-1994, ISO 9001, and ISO/IEC 17025-2005.*

*The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without the written approval of J.H. Metrology Co., Inc.*

*Eric Uphouse*  
Approved by: \_\_\_\_\_  
Vice President

Printed: 8/23/2012 13:08:36

Date: Aug 19, 2012

JH Metrology Co, Inc. • 1801 Hicks Road, Unit E • Rolling Meadows, Illinois 60008 • Phone: (847) 991-0290 • Fax: (847) 991-0348



# Certificate of Calibration

2033001736

Page 2 of 2



✓ In Tolerance    ✗ Out of Tolerance

## Calibration Data

Range	Nominal	As Found	As Left	Min	Max
Plate Repeatability					
Left Front	5.0	5.0	✓	As Found	4.9    5.1
Right Front	5.0	5.0	✓	As Found	4.9    5.1
Center	5.0	5.0	✓	As Found	4.9    5.1
Linearity					
4100 Grams	100.0	100.0	✓	As Found	99.7    100.3
	2000.0	1999.9	✓	As Found	1999.7    2000.3
	4000.0	3999.8	✓	As Found	3999.7    4000.3

End of Datasheet

## Calibration Standards

NIST Traceable #	Instrument ID#	Description	Model	Calibration Date	Date Due
1000150842	00941	Metric Weight Set, 12 Piece, Class 2	Unknown	03 NOV 2010	30 NOV 2012
1000152014	01088	Weight Set, 1mg - 200g, Class 1	Unknown	01 DEC 2010	31 DEC 2012

*No sampling plan or other procedure was used for this calibration. Measurements and information on this certificate are valid at time of calibration only and any number of factors may cause calibration to drift out of tolerance prior to calibration due date.*

*This instrument has been calibrated using standards with accuracies traceable to the National Institute of Standards and Technology, derived from natural physical constants, from ratio measurements, or compared to consensus standards.*

*The expanded uncertainty of the measurement process has not exceeded 25% of the tolerance allowed for the individual characteristics measured, unless otherwise stated. The uncertainties are based on a 95% confidence level, K=2.*

*J.H. Metrology Co., Inc's Calibration Control System complies with applicable requirements of ANSI Z540-1-1994, ISO 9001, and ISO/IEC 17025-2005.*


*The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without the written approval of J.H. Metrology Co., Inc.*

Approved by: \_\_\_\_\_  
 Vice President

Printed: 8/23/2012 13:08:36

Date: Aug 19, 2012

JH Metrology Co, Inc. • 1801 Hicks Road, Unit E • Rolling Meadows, Illinois 60008 • Phone: (847) 991-0290 • Fax: (847) 991-0348



Air Liquide America  
Specialty Gases LLC



# RATA CLASS

## Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

### CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory - PGVP Vendor ID: A22012

P.O. No.: 60126-71-65000  
Document #: 48472837-001

Customer  
CLEAN AIR ENGINEERING

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
1290 COMBERMERE STREET  
TROY, MI 48083

500 WEST WOOD STREET  
PALATINE IL 60067  
US

#### ANALYTICAL INFORMATION Gas Type : OC2

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: CC196768 Certification Date: 27Nov2012 Exp. Date: 28Nov2020  
Cylinder Pressure\*\*\*: 2000 PSIG Batch No: TRO0070277

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
OXYGEN	9.52 %	+/- 1%	Direct NIST and VSL
CARBON DIOXIDE	9.53 %	+/- 1%	Direct NIST and VSL
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

#### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2380 23	04Jan2018	KO24582	23.20 %	OXYGEN
NTRM 2300	17Aug2018	1D002807	23.04 %	CARBON DIOXIDE

#### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL #	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
CAI/110P/V03018	26Nov2012	PARAMAGNETIC
PIR/2000/609015	12Nov2012	NDIR

#### ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

##### First Triad Analysis

**OXYGEN**

Date: 27Nov2012 Response Unit: %

Z1 = 0.00000	R1 = 23.20000	T1 = 9.53000
R2 = 23.20000	Z2 = 0.00000	T2 = 9.53000
Z3 = 0.00000	T3 = 9.53000	R3 = 23.20000

Avg. Concentration: 9.520 %

##### Second Triad Analysis

##### Calibration Curve

Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 0.999989  
Constants: A = -0.01175669  
B = 1.000226328 C = 0  
D = 0 E = 0

##### CARBON DIOXIDE

Date: 27Nov2012 Response Unit: MV

Z1 = 0.00000	R1 = 97.90000	T1 = 57.50000
R2 = 97.90000	Z2 = 0.00000	T2 = 57.50000
Z3 = 0.00000	T3 = 57.50000	R3 = 97.90000

Avg. Concentration: 9.527 %

Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 0.999987  
Constants: A = -0.00468369  
B = 0.134173465 C = -7.139E-05  
D = 1.21594-05 E = 0

Special Notes: DELIVERY DOC# S 48472875

APPROVED BY: \_\_\_\_\_

JEFF CROTEAU



AIR LIQUIDE

Air Liquide America  
Specialty Gases LLC



RATA CLASS

Dual-Analyzed Calibration Standard

1 290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

**CERTIFICATE OF ACCURACY: EPA Protocol Gas**

Assay Laboratory - PGVP Vendor ID: A22011

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: 59343-71-65000  
Document # : 44063920-002

Customer  
CLEAN AIR

DON ALLEN  
500 WEST WOOD STREET  
PALATINE IL 60067  
US

**ANALYTICAL INFORMATION Gas Type : OC2**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM040668  
Cylinder Pressure\*\*\*: 2000 PSIG

Certification Date: 28Nov2011

Exp. Date: 27Nov2014  
Batch No: TRO00470B7

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
CARBON DIOXIDE	17.9 %	+/- 1%	Direct NIST and VSL
OXYGEN	18.1 %	+/- 1%	Direct NIST and VSL
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2300	17Aug2018	K026052	23.04 %	CARBON DIOXIDE
NTRM 2350	01Dec2011	K016398	23.20 %	OXYGEN

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
PIR/2000/609015	10Nov2011	NDIR
CAI/110PA/03018	17Nov2011	PARAMAGNETIC

**ANALYZER READINGS**

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

**First Triad Analysis**

**Second Triad Analysis**

**Calibration Curve**

**CARBON DIOXIDE**

Date:	Response Unit:
29Nov2011	MV
Z1=0.00000	R1=98.20000 T1=86.20000
R2=98.20000	Z2=0.00000 T2=86.20000
Z3=0.00000	T3=86.20000 R3=98.20000
Avg. Concentration:	17.90 %

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.999986	
Constants:	A = -0.00224432
B = 0.138734928	C = -0.0004576
D = 1.39269E-05	E = 0

**OXYGEN**

Date:	Response Unit:
29Nov2011	%
Z1=0.00000	R1=23.20000 T1=18.15000
R2=23.20000	Z2=0.00000 T2=18.15000
Z3=0.00000	T3=18.15000 R3=23.20000
Avg. Concentration:	18.14 %

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.999999	
Constants:	A = -0.00577277
B = 0.999884783	C = 0
D = 0	E = 0

Special Notes:


DELIVER ON DOC # 44063869

APPROVED BY:

JEFF CROTEAU



## Servomex 1420C Oxygen Analyzer



### The 1420C Includes:

- Analyzer
- Power cord
- Signal cable
- Manual
- Calibration sheet
- Instrument Rental Shipping Container

### Specifications:

- Weight: 12 lbs.
- Dimensions: 9" x 5" x 7" (single unit)
- Range: 0-25 & 100% O<sub>2</sub>.
- Accuracy: +/- 0.1%
- Linearity: +/- 0.1% O<sub>2</sub>
- Repeatability: +/- 0.1% O<sub>2</sub>
- Response time (T<sub>90</sub>): 2.5 seconds at 200 ml/min;  
2.0 seconds at 250 ml/min
- Zero Drift: <+/- .002% O<sub>2</sub>/hour
- Span Drift: <+/- .002% O<sub>2</sub>/hour
- Warm up time: typically 1 hour
- Electrical output: 0-1V non-isolated (min load 1K)  
or 4-20mA isolated (max load 600?).
- Display: 3.5 digit green LED display
- Display resolution: 0.1%
- AC Supply: 88-264VAC, 47-63 Hz
- Power required: 45 VA
- Operating ambient temperature: 32oF to 113oF  
(0oC to 45oC) as standard. 32oF to 104oF (0oC to  
40oC) when fitted in bench top case.
- Storage temperature: -4oF to 158oF (-20oC to  
70oC).
- Relative humidity: 0-90% non-condensing.

### Rental/Application Notes:


- Effect of ambient temperature: <+/- 0.03% O<sub>2</sub>/C  
zero; <+/- 0.10% O<sub>2</sub>/C span
- Effect of barometric pressure: The analyzer mea-  
sures the partial pressure of oxygen in the sample  
gas. Therefore, any change in sample pressure at the  
measuring cell will have an effect, which is propor-  
tional to the change in absolute pressure from time  
of calibration. An analyzer for oxygen purity (with  
pressure compensation) reduces error by a factor of  
approximately 5.
- Inlet pressure: 1-10 psig (7-70 kPag)
- Vent pressure: 11.6 to 15.9 psia (80-110 kPag)
- Flow rate: 1-6 lpm
- The Servomex 1420C/1415C can be plumbed  
together in a 19" rack mount (Model 1440C). The  
combined weight is 44 lbs. These units are compat-  
ible with the older 1400B series.
- When renting, equipment must be returned in its  
original packaging.

## CleanAir.

CleanAir Instrument Rental  
500 W. Wood Street  
Palatine, IL 60067-4975  
800-553-5511  
www.cleanair.com



### Servomex 1415C CO2 Analyzer



#### The 1415C Includes:

- Analyzer
- Power cord
- Signal cable
- Manual
- Calibration sheet
- Instrument Rental Shipping Container

#### Specifications:

- Weight: 12 lbs.
- Dimensions: 9" x 5" x 7" (single unit)
- Range: 0-20 & 25% CO<sub>2</sub>
- Accuracy: 1% of selected range
- Linearity: 1% of selected range
- Repeatability: 1% of selected range
- Response time (T90): <10 seconds
- Zero Drift: 2% of full scale/week
- Span Drift: 1% of reading/day
- Warm up time: typically 1 hour
- Electrical output: 0-1V non-isolated (min load 1K) or 4-20mA isolated (max load 600?).
- Display: 3.5 digit green LED display reading.
- Display resolution: 0.1%
- AC Supply: 88-264VAC, 47-63 Hz
- Power required: 45 VA
- Operating ambient temperature: 32°F to 113°F (0°C to 45°C) as standard. 32°F to 104°F (0°C to 40°C) when fitted in bench top case.
- Storage temperature: -4°F to 158°F (-20°C to 70°C)
- Relative humidity: 0-90% non-condensing.

#### Rental/Application Notes:

- Effect of ambient temperature: 1% of full scale per 10°C change.
- Effect of barometric pressure: 0.15% of reading per mbar within specified range.
- Inlet pressure: 1-10 psig (7-70 kPag)
- Vent pressure: 11.6 to 15.9 psia (80-110 kPag)
- Flow rate: 1-6 lpm
- The Servomex 1420C/1415C can be plumbed together in a 19" rack mount (Model 1440C). The combined weight is 44 lbs. These units are compatible with the older 1400B series.
- Equipment must be returned in its original packaging.

**This Page Intentionally Left Blank**



WHEELABRATOR SOUTH BROWARD, INC.  
FT. LAUDERDALE, FL

Client Reference No: Service Agreement  
CleanAir Project No: 12218-3

**FIELD DATA**

**G**

*I hereby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials:   *AK*  

Date:   *3/6/13*  



**This Page Intentionally Left Blank**

TEST LOCATION: FF OUT LET

*particulate  
METALS*

TESTING

METHOD: S-29

PAGE 1 OF 2

UNIT: 1


RUN: 1

FIELD DATA SHEET

Client: <u>WHEELABRATOR</u>	Project No: <u>2218</u>
Plant: <u>SOUTH BROWARD</u>	Date: <u>3/25/13</u>
Meter Operator: <u>SHAWN JOINT</u>	
Probe Operator: <u>WAYNE BERRY</u>	

Meter Box: <u>85-2</u>	Sample Box No: <u>M3</u>
Meter Yr: <u>1.0039</u>	Meter ΔH: <u>1.7413</u>
K-Factor: <u>2.74</u>	Pitot Co: <u>0.813</u>

Leak Rate Before: <u>0.003</u> (in) (Lpm) @ <u>15</u> (in. Hg)	
Leak Rate After: <u>0.003</u> (in) (Lpm) @ <u>15</u> (in. Hg)	
Pitot Leak Check: Before: <input checked="" type="checkbox"/> After: Good: <input checked="" type="checkbox"/> Bad: <input type="checkbox"/>	



Amb. Temp (°F): <u>76</u>	Bar. Press: <u>29.70</u> (in. Hg) (mbar)
Probe I.D. No: <u>67-8-21</u>	
Liner Material: <u>GLASS</u>	

Filter No: <u>254-40</u>	
Thimble No: <u>NA</u>	
Nozzle Diameter: <u>0.276</u>	Nozzle I.D: <u>0.276-1</u>

Start Time: <u>12:26</u>	Stop Time: <u>1:40</u>
--------------------------	------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (L)	Stack Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb Filter		Notes
													<input type="checkbox"/> Dust Tag	<input type="checkbox"/> Tag	
1	5	0.24	0.66	533.300	307	250	250	52	85	84	2	8.4	NA		
2	10	0.22	0.60	537.78	307	252	250	52	86	85	2	8.3			
3	15	0.33	0.90	540.47	308	251	252	53	88	84	3	8.5			
4	20	0.35	0.96	543.31	308	250	251	53	88	84	3	8.6			
5	25	0.54	1.50	546.90	308	252	250	53	89	85	3	8.4			ΔU = .32
2-1	30	0.56	1.50	550.64	321	251	252	54	91	86	4	8.6			
2	35	0.40	1.10	553.78	300	252	254	51	92	86	4	8.8			
3	40	0.37	1.00	556.70	309	251	252	50	92	87	3	8.8			
4	45	0.47	1.30	560.03	312	252	251	49	92	87	4	8.6			
5	50	0.58	1.60	563.67	310	252	252	51	93	87	4	8.5			ΔV = .22
3-1	55	0.53	1.50	567.38	311	251	252	51	93	87	4	8.8			
2	60	0.40	1.10	570.45	311	254	253	52	93	87	4	8.6			
Total		7.6565	13.7207		3229				1082	1029					
Average		0.6696	1.2447		311.3600				89.121						

Sum of square roots.

Circle correct bracketed units on data sheet.

87.7400



TEST LOCATION: FF Inlet  
 UNIT: 1 RUN: 1

METALS TESTING  
**FIELD DATA SHEET**

METHOD: 5-29 PAGE 2 OF 2

Client: WHEELABRATOR Project No: 1218  
 Plant: S. BROWNS Date: 3-25-13  
 Meter Operator: ES  
 Probe Operator: ES

Meter Box: \_\_\_\_\_ Sample Box No: \_\_\_\_\_  
 Meter Yd: \_\_\_\_\_ Meter ΔH<sub>0</sub>: \_\_\_\_\_  
 K Factor: \_\_\_\_\_ Pitot Cp: \_\_\_\_\_  
 Leak Rate Before: (cfm) [Lpm] @ (in. Hg)  
 Leak Rate After: (cfm) [Lpm] @ (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad

Cross Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (In) [Out]	First point all the way

of page [In] [Out]

Amb Temp: (°F) \_\_\_\_\_ Bar Press: \_\_\_\_\_ [in. Hg] [mbar]  
 Probe I.D. No: \_\_\_\_\_  
 Liner Material: \_\_\_\_\_

Filter No: \_\_\_\_\_  
 Thimble No: \_\_\_\_\_  
 Nozzle Diameter: \_\_\_\_\_ Nozzle I.D.: \_\_\_\_\_

Start Time: \_\_\_\_\_ Stop Time: \_\_\_\_\_

G-4

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub>		Stack Temp T <sub>s</sub> (°F)	Probe T <sub>1</sub> (°F)	Filter T <sub>1</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (% dv)	<input type="checkbox"/> Amb Filter <input type="checkbox"/> Dioxn Trap	Notes
				Int. Vol. (ft <sup>3</sup> )	[L]										
				570.45			250	250							
P3-3	65	0.42	1.20	573.65		311	252	254	53	94	88	4	8.3		
4	70	0.50	1.40	577.68		311	252	255	56	94	88	4	8.0		
5	75	0.52	1.40	580.53		310	251	252	56	94	88	4	7.8		ΔV = -.30
P4-1	80	0.44	1.20	583.96		309	253	253	58	93	88	4	7.9		
2	85	0.40	1.10	587.24		309	255	254	58	92	88	4	8.0		
3	90	0.52	1.40	590.51		312	253	255	59	92	88	4	8.2		
4	95	0.56	1.50	594.06		312	252	254	59	93	88	4	8.5		
5	100	0.58	1.60	598.03		310	254	252	60	94	88	4	8.4		ΔV = .19
P5-1	105	0.41	1.10	600.88		311	253	254	60	93	89	4	8.2		
2	110	0.42	1.20	604.07		310	254	252	60	93	89	4	8.4		
3	115	0.44	1.20	607.28		312	255	254	60	92	88	4	8.4		
4	120	0.55	1.50	610.79		312	256	255	61	93	88	4	8.6		
5	125	0.58	1.60	614.42		316	252	254	62	93	88	4	8.5		
	Total	9.0910	17.4000			4055				1210	1146				
	Average														

Sum of square roots.

Circle correct bracketed units on data sheet.




QA/QC Date: 3-25-13

TEST LOCATION: FF outlet Parkville/Meigs TESTING METHOD: 5729 PAGE 1 OF 2  
 UNIT: 1 RUN: 2 FIELD DATA SHEET

Client: Whitaker Project No: 12218  
 Plant: S. Brewer Date: 3/26/13  
 Meter Operator: P. Bilney  
 Probe Operator: P. Bilney

Meter Box: 85-2 Sample Box No: M1  
 Meter No: 10039 Meter Alt: 17413  
 K Factor: 2.33 Pitot Co: 0.813  
 Leak Rate Before: 0.002 (Lpm) @ 15 (in. Hg)  
 Leak Rate After: 0.001 (Lpm) @ 10 (in. Hg)  
 Pitot Leak Check Before:  After:  Good  Bad



Amb. Temp (°F): 60 Bar. Press: 29.92 (in. Hg) (mbar)  
 Probe I.D. No: 67-8-21  
 Liner Material: Glass

Filter No: PS4 EHS-38  
 Thimble No: N/A  
 Nozzle Diameter: 0.2725 Nozzle I.D.: 7725-1

Start Time: 7:57 Stop Time: 10:03

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume (L)	Stack Temp Ts (°F)	Probe Temp (°F)		Cond Temp Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb Filter <input type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
						210	250							
5-1	5	0.36	0.84	614.900	302	250	249	54	62	61	2.5	8.1		
2	10	0.38	0.89	620.17	302	247	247	57	63	61	2.5	8.6		
3	15	0.40	0.93	622.90	302	245	248	50	64	62	3.0	7.7		
4	20	0.43	1.0	625.74	303	246	248	50	66	62	3.0	8.1		
5	25	0.42	0.98	628.545	302	248	248	52	67	62	3.0	7.8		628.630
4-1	30	0.38	0.89	631.30	302	247	252	55	66	63	3.0	9.5		(-0.05)
2	35	0.40	0.93	634.05	303	246	249	55	67	63	3.0	9.7		
3	40	0.40	0.93	636.80	303	248	249	57	68	63	3.0	8.7		
4	45	0.49	1.1	639.81	303	248	250	58	68	64	3.5	8.4		
5	50	0.53	1.2	642.955	302	248	248	59	69	64	3.5	8.3		643.028
3-1	55	0.37	0.86	645.66	302	247	249	60	68	65	3.0	8.2		(-0.07)
2	60	0.35	0.82	648.21	302	248	249	62	68	65	3.0	8.1		
Total				67.210										
Average				0.8956	301.9200				66.0600					

Sum of square roots:  
 $\sqrt{53.4118} = 7.31$   
 $\sqrt{0.6147} = 0.784$   
 11.37

Circle correct bracketed units on data sheet.

3/28

QA/QC: PB  
 Date: 3/26/13



TEST LOCATION: PE Outlet  
 UNIT: 1 RUN: 2

Parham Lake / Mill Lake TESTING  
**FIELD DATA SHEET**

METHOD: 5/29 PAGE 2 OF 2

Client: Whitaker Project No: 12218  
 Plant: 51 Brown Date: 3/26/13  
 Meter Operator: P. Bishop  
 Probe Operator: P. Bishop

Meter Box: \_\_\_\_\_ Sample Box No: \_\_\_\_\_  
 Meter Ya: \_\_\_\_\_ Meter ΔH: \_\_\_\_\_  
 K Factor: \_\_\_\_\_ Pitot Co: \_\_\_\_\_  
 Leak Rate Before: [cfm] [Lpm] @ [in. Hg]  
 Leak Rate After: [cfm] [Lpm] @ [in. Hg]  
 Pitot Leak Check Before:  After: Good  Bad

Cross-Section of Test Location

↑  
 [N] [UP]

Duct Dimensions (in.): \_\_\_\_\_

Static Pres (in. H <sub>2</sub> O)	Port Len (in)	Gas Flow (In) [Out]	First-point all the way
_____	_____	_____	_____

Page \_\_\_\_\_ of \_\_\_\_\_ [In] [Out]

Amb Temp (°F)	Bar Press. (in. Hg) [mbar]
_____	_____
Probe ID No	_____
Liner Material	_____
Filter No	_____
Thimble No	_____
Nozzle Diameter	Nozzle ID
_____	_____
Start Time	Stop Time
_____	_____

G-8

Traverse Point Number	Min/pt Elapsed Time	Velocity Head (in. H <sub>2</sub> O)	Orifice Setting Δh (in. H <sub>2</sub> O)	Gas Sample Volume		Stack Temp (°F)	Probe Temp (°F)	Filter Temp (°F)	Cond Temp (°F)	DGM Inlet (°F)	DGM Outlet (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% O <sub>2</sub> )	Amb Filter <input type="checkbox"/> Dioxin trap <input type="checkbox"/>	Notes
				Init. Vol.	(ft <sup>3</sup> ) [L]										
3	65	0.31	0.86	650.89	304	249	210	63	68	65	3.0	8.1			
4	70	0.43	1.0	653.77	303	249	248	63	68	64	3.5	7.9			
5	75	0.46	1.1	656.810	302	250	248	63	68	65	3.5	8.2			
2-1	80	0.40	0.93	659.623	301	248	255	64	68	65	3.5	9.1		656.87K -0.065	
2	85	0.37	0.82	662.23	302	249	210	65	69	65	3.0	8.6			
3	90	0.30	0.70	664.63	301	250	200	65	69	65	3.0	8.2			
4	95	0.38	0.89	667.30	303	250	250	65	69	65	3.5	8.7			
5	100	0.52	1.3	670.590	304	250	249	62	71	66	4.0	8.3		K=240	
1-1	105	0.23	0.55	672.79	298	248	253	61	70	66	2.5	9.1		672.675 -0.088	
2	110	0.23	0.55	674.90	298	250	257	62	70	67	2.5	8.0			
3	115	0.29	0.70	677.29	302	250	246	63	69	67	3.0	8.0			
4	120	0.26	0.62	679.54	301	251	247	63	69	67	3.0	8.0			
5	125	0.42	1.0	682.415	301	250	249	63	70	67	3.5	8.2			
Total															
Average															

Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC PB  
 Date 3/26/13



TEST LOCATION: PP Outlet  
 UNIT: \_\_\_\_\_ RUN: 3

Particulate/Metals TESTING  
**FIELD DATA SHEET**

METHOD: 5729 PAGE 2 OF 2

Client: <u>Whelabrator</u>	Project No.: <u>17218</u>
Plant: <u>Brownwood</u>	Date: <u>3/26/13</u>
Meter Operator: <u>P. Bihun</u>	Probe Operator: <u>P. Bihun</u>
Meter Box	Sample Box No.
Meter Yd.	Meter ΔH <sub>o</sub>
K Factor	Pitot Coefficient
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Cross Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.):

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (In) [Out]	First point all the way of page [In] [Out]
------------------------------------	-----------------	---------------------	--

Amb Temp (CF)	Bar. Press. (in. Hg) [mbar]
Probe ID No.	
Liner Material	
Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.
Start Time:	Stop Time:

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub>		Stack Temp (°F)	Probe T <sub>p</sub> (°F)		Filter T <sub>f</sub> (°F)	Cond. Temp. (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (% O <sub>2</sub> )	Amb Filter <input type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
				Inlet Vol.	Q (L)		Set Points	Set Points								
3	65	0.33	0.81	719.33	302	270	250	64	78	74	2.5	7.3	N/A			
4	70	0.41	1.0	722.19	302	246	249	64	78	74	3.0	7.9				
5	75	0.45	1.1	725.25	304	247	249	64	78	74	3.0	7.3				
2-1	80	0.38	0.93	728.07	302	245	253	65	77	75	3.0	7.3		725, 300		
2	85	0.30	0.74	730.53	302	247	249	65	79	75	3.0	7.2		725, 300		
3	90	0.28	0.69	732.92	302	245	249	64	79	76	3.0	7.7				
4	95	0.31	0.76	735.43	302	245	249	60	80	76	3.0	6.9				
5	100	0.44	1.1	738.470	302	249	252	58	80	77	3.5	8.6		738, 545		
1-1	105	0.22	0.54	740.65	299	247	257	55	80	77	2.5	8.9		738, 545		
2	110	0.20	0.49	742.63	295	245	245	57	79	78	2.5	7.5				
3	115	0.29	0.71	745.05	289	249	250	59	79	78	3.0	8.2				
4	120	0.25	0.61	747.27	301	249	280	60	80	78	2.5	7.6				
5	125	0.35	0.86	749.925	300	250	257	60	80	78	3.0	8.1				
Total																
Average																

\*Sum of square roots.

Circle correct bracketed units on data sheet.



G-8



# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 1 FF Outlet	
Plant <u>South Broward</u>	Job No. 12218	Method	5/29

Balance Calibration Check			
Balance ID	<u>TL07-4</u>	Reference Weight Mass	<u>500.0g</u>
Reference Weight ID	<u>60150 8028501135</u>	Reference Weight Reading	<u>499.3g</u>
Check must be performed at least Once per Method per Job <u>8028501068</u>		Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.	

Run No. <u>1</u>	1	Filter Type Quartz	Sample Box No. <u>M3</u>
Date <u>3.25.13</u>		Lot No. <u>e54-40</u>	pH NA
Analyst <u>HN</u>		Filter No. <u>e45-40</u>	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	<u>787.8</u>	<u>465.4</u>	<u>322.4</u>	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>674.0</u>	<u>545.3</u>	<u>128.7</u>	QA/QC SB Date <u>3/26</u>
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>575.2</u>	<u>550.7</u>	<u>24.5</u>	
Impinger 4	Empty	<u>429.5</u>	<u>424.5</u>	<u>5.0</u>	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>645.7</u>	<u>643.7</u>	<u>2.0</u>	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>545.9</u>	<u>546.3</u>	<u>-0.4</u>	<u>482.2</u>
Impinger 7	≈ 250 g Silica Gel	<u>747.3</u>	<u>729.4</u>	<u>17.9</u>	<u>500.1</u>

Run No. <u>2</u>	2	Filter Type Quartz	Sample Box No. <u>M1</u>
Date <u>3.26.13</u>		Lot No.	pH NA
Analyst <u>HN</u>		Filter No. <u>e54-38</u>	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	<u>664.4</u>	<u>443.3</u>	<u>221.1</u>	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>646.9</u>	<u>530.6</u>	<u>116.3</u>	QA/QC SB Date <u>3/26</u>
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>572.1</u>	<u>538.5</u>	<u>33.6</u>	
Impinger 4	Empty	<u>451.0</u>	<u>443.9</u>	<u>7.1</u>	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>545.4</u>	<u>541.0</u>	<u>4.4</u>	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>530.3</u>	<u>529.7</u>	<u>0.6</u>	<u>383.1</u>
Impinger 7	≈ 250 g Silica Gel	<u>850.4</u>	<u>837.9</u>	<u>12.5</u>	<u>395.6</u>

Run No. <u>3</u>	3	Filter Type Quartz	Sample Box No. <u>M3</u>
Date <u>3.26.13</u>		Lot No.	pH NA
Analyst <u>HN/DL</u>		Filter No. <u>e54-37</u>	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	<u>729.8</u>	<u>464.4</u>	<u>265.4</u>	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>648.3</u>	<u>545.1</u>	<u>103.2</u>	QA/QC SB Date <u>3/26</u>
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>572.8</u>	<u>550.3</u>	<u>22.5</u>	
Impinger 4	Empty	<u>427.9</u>	<u>424.2</u>	<u>3.7</u>	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>646.6</u>	<u>644.6</u>	<u>2.0</u>	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>543.8</u>	<u>543.8</u>	<u>0</u>	<u>396.6</u>
Impinger 7	≈ 250 g Silica Gel	<u>760.2</u>	<u>746.9</u>	<u>13.3</u>	<u>410.1</u>

QA/QC SB  
Date 3/26



TEST LOCATION: FF Outlet  
 UNIT: 1 RUN: 4


Metals TESTING  
 FIELD DATA SHEET

METHOD: 29 PAGE 1 OF 2

Client: Wheelabrator Project No.: 12215  
 Plant: S. Broward Date: 7/26/13  
 Meter Operator: P. Bihun  
 Probe Operator: P. Bihun

Meter Box: FF-2 Sample Box No.: M1  
 Meter Yr: 1,0039 Meter ΔH: 1,7413  
 K Factor: 2.45 Pilot C: 0.813

Leak Rate Before: 002 (CFM) [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 001 (CFM) [Lpm] @ 10 (in. Hg)  
 Pilot Leak Check Before:  After:  Good  Bad



Amb. Temp. (°F): 66 Bar. Press: 29.90 (in. Hg) [mbar]  
 Probe I.D. No.: 678-21  
 Liner Material: Glass

Filter No.: N/A  
 Thimble No.: N/A  
 Nozzle Diameter: 0.2725 Nozzle I.D.: 2725-1

Start Time: 12:59 Stop Time: 15:11

Traverse Point Number	Min/pt Elapsed Time	Velocity Head (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume		Static Temp. Ts (°F)	Filter T <sub>c</sub> (°F)		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (% dv)	Ambifilter <input type="checkbox"/> Oxid Trap <input type="checkbox"/>	Notes
				Initial Vol. (L)	V <sub>m</sub> (L)		Set Points	Set Points							
5-1	5	0.32	0.78	750.46	752.97	302	210	212	65	76	76	2.5	8.8		
2	10	0.34	0.83	755.59	755.59	304	245	247	53	77	77	2.5	8.9		
3	15	0.42	1.0	758.49	758.49	300	246	248	50	79	77	2.5	8.6		
4	20	0.48	1.2	761.71	761.71	302	248	248	49	82	78	3.0	8.3		
5	25	0.46	1.1	764.730	764.730	304	247	249	49	83	79	3.0	8.4		764.730 (-0.06)
4-1	30	0.38	0.93	767.15	767.15	304	246	250	53	82	79	2.5	8.9		
2	35	0.35	0.86	770.22	770.22	304	247	251	53	82	79	2.5	8.8		
3	40	0.42	1.0	773.09	773.09	304	248	250	54	81	79	3.0	9.3		
4	45	0.51	1.4	776.51	776.51	308	248	248	51	80	78	3.5	9.2		
5	50	0.52	1.3	779.87	779.87	311	249	250	55	79	77	3.5	8.7		779.87 (-0.065)
3-1	55	0.32	0.78	782.46	782.46	300	247	249	58	78	76	3.0	9.0		
2	60	0.35	0.86	785.14	785.14	304	248	249	62	78	76	3.0	8.9		
Total				24.740	71.380					307					
Average				0.989	0.989	305.04	247	249	58	77.74					

Sum of square roots.  
0.62835  
12.04

Circle correct bracketed units on data sheet.

3647

1888

QA/QC FB  
 Date 7/26/13

TEST LOCATION:

FF Outlet

Metals

TESTING

METHOD: 29

PAGE 2

OF 2

2

UNIT: 1

RUN: 4

FIELD DATA SHEET

Client: <u>Whelan</u>	Project No. <u>12215</u>
Plant: <u>S. Broward</u>	Date: <u>7/26/13</u>
Meter Operator: <u>P. Bihun</u>	
Probe Operator: <u>P. Bihun</u>	

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (In) (Out)	First point all the way (In) (Out)
------------------------------------	-----------------	---------------------	------------------------------------

Amb. Temp. (°F)	Bar. Press. (in. Hg) [mbar]
Probe I.D. No.	
Liner Material	

Meter Box	Sample Box No.
Meter Yd.	Meter ΔH <sub>0</sub>
K Factor	Pitot C <sub>p</sub>
Leak Rate Before (cfm) [Lpm] @ (in. Hg)	
Leak Rate After (cfm) [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time	Stop Time
------------	-----------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub>		Stack Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Cond. Temp T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (%dV)	Amb Filter <input type="checkbox"/>	Dioxin Trap <input type="checkbox"/>	Notes
				Init. Vol.	(7) [L]		Set Points	Set Points								
3	65	0.40	0.98	788.00	301	249	251	63	78	75	3.0	9.1				
4	70	0.57	1.3	796.35	307	249	248	63	78	74	3.5	9.4				
5	75	0.56	1.4	794.825	308	249	249	63	78	75	3.5	9.0				794.900
2-1	80	0.45	1.1	797.90	307	248	250	64	78	74	3.0	9.2				(-0.075)
2	85	0.38	0.93	800.67	308	249	250	65	80	74	3.0	9.4				
3	90	0.33	0.81	803.26	308	250	250	65	80	75	3.0	9.7				
4	95	0.43	1.1	806.32	308	250	250	60	80	75	3.5	9.0				
5	100	0.56	1.4	809.765	308	250	254	58	81	75	3.5	8.7				809.820
1-1	105	0.21	0.52	811.88	303	249	253	61	78	75	2.5	9.7				(-0.055)
2	110	0.22	0.54	814.00	304	250	250	62	79	75	2.5	8.8				
3	115	0.32	0.78	816.52	305	251	249	63	79	75	3.0	8.6				
4	120	0.30	0.74	818.98	306	250	249	64	79	75	3.0	8.7				
5	125	0.44	1.1	822.050	306	250	251	64	79	75	3.5	8.0				
Total																
Average																

Sum of square roots.

Circle correct bracketed units on data sheet.



# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 1 FF Outlet	
Plant South Broward	Job No. 12218	Method	29

8028301048 Balance Calibration Check			
Balance ID	FL07-4	8028301135	Reference Weight Mass 500.0g
Reference Weight ID	60150		Reference Weight Reading 499.3g

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No. 4	4	Filter Type Quartz	Sample Box No. M1
Date 3-26-13		Lot No.	pH NA
Analyst HJ/DL		Filter No. 254-35	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	733.4	441.8	291.6	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	631.8	532.2	99.6	QA/QC 58 Date 3/28
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	553.3	537.0	16.3	
Impinger 4	Empty	445.3	443.3	2.0	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	559.7	558.3	1.4	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	539.6	536.7	2.9	413.8
Impinger 7	≈ 250 g Silica Gel	762.1	743.8	18.3	432.1

Run No. 5	5	Filter Type Quartz	Sample Box No.
Date		Lot No.	pH NA
Analyst		Filter No.	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty				
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>				QA/QC Date
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>				
Impinger 4	Empty				
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>				Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>				
Impinger 7	≈ 250 g Silica Gel				

Run No. 6	6	Filter Type Quartz	Sample Box No.
Date		Lot No.	pH NA
Analyst		Filter No.	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty				
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>				QA/QC Date
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>				
Impinger 4	Empty				
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>				Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>				
Impinger 7	≈ 250 g Silica Gel				

QA/QC 58  
Date 4/19




TEST LOCATION: INLET  
 UNIT: 1 RUN: 1

HCL TESTING  
 FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client: WHEELABRAX Project No.: 1217  
 Plant: S. BOWARDS Date: 3-25-13  
 Meter Operator: SS  
 Probe Operator: SS

Meter Box: 6K11 Sample Box No.: B-6  
 Meter No.: 10050 Meter Alt.: 1.5964  
 K Factor: NA Pitot Co.: 0.834  
 Leak Rate Before: 0.003 [cfm] [Lpm] @ 5 (in. Hg)  
 Leak Rate After: 0.00 [cfm] [Lpm] @ 5 (in. Hg)  
 Pilot Leak Check Before:  After: Good  Bad



Amb. Temp: 68 (°F) Bar. Press: 29.70 (in. Hg) [mbar]  
 Probe I.D. No.: 66-47  
 Liner Material: GLASS

Filter No.: NA  
 Thimble No.: NA  
 Nozzle Diameter: NA Nozzle I.D.: NA

Start Time: 8:00 Stop Time: 9:00

Traverse Point Number	Min/pl Elapsed Time	Velocity Head (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (L)	Stack Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Filter T <sub>f</sub> (°F)	Cond. Temp. (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (% O <sub>2</sub> )	Amb. Filter	Dioxin Trap	Notes
						Set Points	Set Points									
1-1	5	NA	1.20	579.200	498	355	355	52	88	88	2	8.2				
	10			582.24	500	352	355	52	89	88	2	8.3				
	15			585.25	501	355	356	54	94	90	2	8.4				
	20			589.21	503	354	355	54	97	90	2	8.5				
	25			591.16	501	355	354	55	95	91	4	8.2				
	30			594.09	502	356	355	52	94	92	5	8.0				
	35			597.01	501	356	356	52	98	93	6	8.1				
	40			599.00	501	355	355	54	100	93	7	8.2				
	45			602.85	501	354	354	54	102	93	9	8.4				
	50			605.71	505	356	355	55	102	93	10	8.6				
	55			608.79	508	354	352	56	102	93	11	8.8				
	60			611.71	508	355	353	57	102	93	12	8.8				
				614.99												
	Total			35.690	609					163	1097					
	Average			1.2000	602.467					94.1667						

\*Sum of square roots.

Circle correct bracketed units on data sheet



QA/QC SS  
 Date 3-25-13


TEST LOCATION: INLET

HCL TESTING

METHOD: 26A PAGE 1 OF 1

UNIT: 1 RUN: 2

FIELD DATA SHEET



Amb Temp (°F)	<u>70</u>	Bar. Press:	<u>29.78</u>	(in. Hg) [mbar]
Probe I.D. No.	<u>66-4-7</u>			
Liner Material	<u>GASS</u>			

Filter No.	<u>NA</u>		
Thimble No.	<u>NA</u>		
Nozzle Diameter	<u>NA</u>	Nozzle ID	<u>NA</u>

Client	<u>WHEELABRATOR</u>	Project No.	<u>12018</u>
Plant	<u>S. BLOWARDS</u>	Date	<u>3-25-13</u>
Meter Operator	<u>ST</u>		
Probe Operator	<u>ST</u>		

Meter Box	<u>Q-11</u>	Sample Box No.	<u>B-14</u>
Meter Rtg.	<u>1.0050</u>	Meter ΔH <sub>2</sub>	<u>1.6964</u>
K Factor	<u>NA</u>	Pitot C <sub>p</sub>	<u>0.834</u>
Leak Rate Before	<u>0.003 (cm) [Lpm]</u>	@	<u>18 (in. Hg)</u>
Leak Rate After	<u>0.003 (cm) [Lpm]</u>	@	<u>16 (in. Hg)</u>
Pitot Leak Check Before:	<input checked="" type="checkbox"/> Good	After:	<input checked="" type="checkbox"/> Good <input type="checkbox"/> Bad

Start Time: 9:23 Stop Time: 10:34

G-14

Traverse Point Number	Min/pt Elapsed Time	Velocity Head (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume Init. Vol. [L]	Stack Temp: Ts (°F)	Probe Temp (°F)		Cond. Temp: Tc (°F)	DGM Inlet Tm in (°F)	DGM Outlet Tm out (°F)	Rump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb Filter <input type="checkbox"/> Dioxin Trace <input type="checkbox"/>	Notes	
						Set Points	Set Points								
H-1	5	NA	1.20	615.300	489	355	355	52	97	96	3	7.0			
	9			618.53	488	352	354	52	96	95	4	7.1		PART STOP 11 MIN DELAY	
	12			619.84	488	354	355	45	98	95	5	7.0			
	18			618.01	496	353	355	48	99	96	6	7.0			
	25			630.90	489	354	355	44	100	96	6	7.2			
	32			633.89	491	355	356	49	100	96	7	7.4			
	38			636.89	488	355	356	53	101	97	9	7.0			
	45			640.00	490	354	355	54	100	96	10	7.0			
	52			642.97	490	355	354	56	99	96	11	7.0			
	58			645.95	496	353	353	58	99	96	12	7.6			
	65			648.92	491	355	354	58	98	95	13	7.5			
	70			652.02	494	353	353	60	99	95	14	7.6			
	Total			756.700	5887				1186	1149					
	Average			(1.2000)	(490.5800)				(97.2917)						

Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC 84  
Date 3-25-13





# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 1 SDA Inlet	
Plant South Broward	Job No. 12218	Method Modified 26A	

Balance Calibration Check			
Balance ID	802801135	Reference Weight Mass	500.0g
Reference Weight ID	60150	Reference Weight Reading	499.3g

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No.	1	Filter Type Quartz	Sample Box No.	B6
Date	3-25-13	Lot No.	pH	NA
Analyst	HN	Filter No. NA	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	469.8	444.8	25.0	QA/QC SB Date 3/25
Impinger 2	100 mL 0.1N H2SO4	643.5	547.2	96.3	
Impinger 3	100 mL 0.1N H2SO4	565.2	536.2	29.0	
Impinger 4	Empty	489.2	483.2	6.0	Total Weight (gm) 156.3 171.3
Impinger 5	Silica Gel	697.5	682.5	15.0	
Impinger 6					
Impinger 7					

Run No.	2	Filter Type Quartz	Sample Box No.	B14
Date	3-25-13	Lot No.	pH	NA
Analyst	HN	Filter No. NA	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	496.8	444.2	52.6	QA/QC SB Date 3/25
Impinger 2	100 mL 0.1N H2SO4	646.6	542.2	104.4	
Impinger 3	100 mL 0.1N H2SO4	587	562.3	24.7	
Impinger 4	Empty	426.5	421.0	5.5	Total Weight (gm) 187.2 199.0
Impinger 5	Silica Gel	706.5	694.7	11.8	
Impinger 6					
Impinger 7					

Run No.	3	Filter Type Quartz	Sample Box No.	B6
Date	3-25-13	Lot No.	pH	NA
Analyst	HN	Filter No. NA	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4 HN	492.4	471.8	437.9	QA/QC SB Date 3/25
Impinger 2	100 mL 0.1N H2SO4 12.15	707.7	651.1	540.2	
Impinger 3	100 mL 0.1N H2SO4 3-25-13	592.9	561.8	534.0	
Impinger 4	Empty	485.2	483.2	483.2	Total Weight (gm) 176.7 187.4
Impinger 5	Silica Gel	735.5	707.7	697.0	
Impinger 6					
Impinger 7					

QA/QC SB  
Date 3/25






TEST LOCATION: FF OUTLOT  
 UNIT: 1 RUN: 1

HCL TESTING  
 FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client: WHELAN LABORATORY Project No. 12218  
 Plant: SOUTH BAYWAY Date: 3/25/13  
 Meter Operator: WALTER BERRY  
 Probe Operator:                     



Amb. Temp. (°F) 75 Bar. Press. 29.70 (in. Hg) [mbar]  
 Probe I.D. No. 67-4-3  
 Liner Material GLASS

Meter Box 66-14 Sample Box No. B-01  
 Meter Yr. 0.9879 Meter ΔH<sub>0</sub> 1.8015  
 K-Factor                      Pitot Co.                     

Duct Dimensions (in.) 96 x 96  
 Static Pres. (in. H<sub>2</sub>O) -10.0 Port Len. (in.) 10 Gas Flow                      First point all the way                       
 of page                      (In) [Out] (In) [Out]

Filter No.                       
 Trimble No.                       
 Nozzle Diameter                      Nozzle I.D.                     

Leak Rate Before 0.004 (lpm) @ 5 (in. Hg)  
 Leak Rate After 0.001 (lpm) @ 10 (in. Hg)  
 Pitot Leak Check Before  After  Bad

Start Time 0800 Stop Time 0900

Traverse Point Number	Min/pt. Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH <sub>0</sub> (in. H <sub>2</sub> O)	Gas Sample Volume		Stack Temp Ts (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond Temp (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (% O <sub>2</sub> )	Amb. Filter	Bioxin Trap	Notes
				Init. Vol.	[m <sup>3</sup> ] [L]											
3-1	5	MA	1.5	406.400		298	291	303	63	75	73	5	8.7			
	10		1.5	409.59		299	293	302	62	75	73	5	9.0			
	15		1.5	412.97		299	295	298	61	78	74	5.5	8.7			
	20		1.5	416.35		299	297	306	62	80	75	6	8.3			
	25		1.5	419.77		303	297	302	63	81	75	6	9.0			
	30		1.5	423.22		301	297	302	63	81	75	6	9.0			
	35		1.5	426.63		303	298	305	64	83	76	6	8.8			
	40		1.5	430.07		303	299	308	64	83	76	6	8.8			
	45		1.5	433.55		302	298	299	64	84	77	6	9.0			
	50		1.5	436.98		304	298	303	64	85	77	6	8.2			
	55		1.5	440.45		304	294	307	64	85	77	6	9.1			
	10		1.5	443.86		304	300	306	65	86	78	6	9.7			
			1.5	447.310		305	299	299	63	86	78	6	9.7			
	Total			40.9100		3625.0				981.0	909.0					
	Average		(1.5)			(302.83)				(78.7500)						

Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC W/B  
 Date 3/25/13


TEST LOCATION: FF OUTPUT  
 UNIT: 1 RUN: 2

HCL TESTING  
**FIELD DATA SHEET**

METHOD: 26A PAGE 1 OF 1

Client: WATERBURY Project No.: 12248  
 Plant: SOUTH B ROWLAND Date: 2/25/13  
 Meter Operator: WAYNE BERRY  
 Probe Operator:                     

Meter Box: 66-14 Sample Box No.: 824  
 Meter Yr: 0.9879 Meter ΔH: 1.0015  
 K Factor:                      Pitot Cp:                       
 Leak Rate Before: 0.003 [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 0.003 [Lpm] @ 10 (in. Hg)  
 Pitot Leak Check Before:  After:  Bad



Amb. Temp. (°F): 74 Bar. Press: 29.70 (in. Hg) [mbar]  
 Probe I.D. No.: 67-4-3  
 Liner Material: GLASS

Filter No.:                       
 Thimble No.:                       
 Nozzle Diameter:                      Nozzle I.D.:                     

Start Time: 0923 Stop Time: 1034

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub>		Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet	DGM Outlet	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (% dv)	Amb Filter <input type="checkbox"/>	Dioxin Trap <input type="checkbox"/>	Notes
				Init. Vol. (ft <sup>3</sup> ) [L]	Set Points					T <sub>m in</sub> (°F)	T <sub>m out</sub> (°F)					
3-1	5	N/A	1.5	447.730	300	300	300	300	59	78	77	5.5	10.9			PAUSE 0928
	10		1.5	454.59	302	292	296	54	79	78	5.5	8.8				0939 RESTART
	15		1.5	457.95	303	298	302	53	81	77	5.5	7.3				
	20		1.5	461.35	302	299	295	53	83	77	6	7.5				
	25		1.5	464.79	301	301	307	56	85	78	6	7.4				
	30		1.5	468.23	303	301	308	60	85	78	6	7.3				
	35		1.5	471.63	304	301	304	64	86	78	6	7.7				
	40		1.5	475.08	303	300	296	64	86	79	6	7.7				
	45		1.5	478.53	304	299	301	64	87	79	6	8.2				
	50		1.5	482.00	302	300	306	64	87	79	6	8.2				
	55		1.5	485.47	304	300	296	65	87	80	6	8.2				
	60		1.5	488.910	304	300	305	61	87	80	6	8.0				
	Total			41,180.0	3638.0				1910.940.0							
	Average		1.5		303.1667				81.2917							

\* Sum of square roots.

Circle correct bracketed units on data sheet.




TEST LOCATION: FF OUTLOT  
 UNIT: 1 RUN: 3

HCL TESTING  
**FIELD DATA SHEET**

METHOD: 26A PAGE 1 OF 1

Client: WHEELABRATOR Project No: 12218  
 Plant: SOUTH BROWARD Date: 3/25/13  
 Meter Operator: WAYNE BENNY  
 Probe Operator: —



Amb. Temp (°F): 74 Bar Press: 29.70 (in. Hg) [mbar]  
 Probe I.D. No.: 67-4-3  
 Liner Material: GLASS

Meter Box: 66-14 Sample Box No: 201  
 Meter Y: 0.9879 Meter ΔH: 1.8015  
 K Factor: — Pitot Co: —  
 Leak Rate Before: 0.007 [Lpm] [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 0.001 [Lpm] [Lpm] @ 10 (in. Hg)  
 Pitot Leak Check Before:  After: Good

Filter No: —  
 Thimble No: —  
 Nozzle Diameter: — Nozzle I.D.: —

Start Time: 1054 Stop Time: 1154

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (ft <sup>3</sup> ) [L]		Stack Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F) Set Points	Filter T <sub>f</sub> (°F)	Cond. Temp T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (%dv)	Amb. Filter	Dioxin Trap	Notes
				Init. Vol.	(ft <sup>3</sup> ) [L]											
3-1	5	N/A	1.5	489.570		308	293	307	63	83	80	6	7.8			
	10		1.5	496.75		308	295	305	63	85	81	5.5	8.0			
	15		1.5	500.16		311	297	296	52	87	81	5.5	7.4			
	20		1.5	503.59		303	298	295	54	89	82	5.5	8.4			
	25		1.5	507.01		307	299	307	58	89	83	5.5	8.6			
	30		1.5	510.47		305	299	300	63	90	83	5.5	9.0			
	35		1.5	513.94		304	299	297	63	91	84	5.5	8.2			
	40		1.5	517.38		305	298	304	60	90	84	5.5	9.1			
	45		1.5	520.82		306	301	307	56	90	84	5.5	8.7			
	50		1.5	524.25		303	300	304	54	91	84	5.5	8.1			
	55		1.5	527.71		304	300	299	53	92	85	5.5	8.5			
	60		1.5	531.130		305	300	301	54	94	86	5.5	8.6			
	Total			41.5600		3669.0				1071.09970						
	Average		1.5			305.7500				86.1667						

Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC WJ3  
 Date 3/25/13

G-19

# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 1 FF Outlet	
Plant South Broward	Job No. 12218	Method	Modified M26A

Balance Calibration Check			
Balance ID	TL07-4 802301068	Reference Weight Mass	500.0g
Reference Weight ID	60150	Reference Weight Reading	499.3g

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No.	1	Filter Type Teflon Mat	Sample Box No.	B1
Date	3/25/13	Lot No.	pH	
Analyst	DL	Filter No. NA	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	485.7	458.9	26.8	QA/QC SB Date 3/25
Impinger 2	100 mL 0.1N H2SO4	678.3	548.8	129.5	
Impinger 3	100 mL 0.1N H2SO4	592.0	530.9	61.1	
Impinger 4	Empty	486.1	468.3	17.8	
Impinger 5	Silica Gel	724.4	704.9	19.5	Total Weight (gm)
Impinger 6					23.5
Impinger 7					254.7

Run No.	2	Filter Type Teflon Mat	Sample Box No.	B24
Date	3.25.13	Lot No.	pH	
Analyst	HJ	Filter No. NA	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	480.1	450.8	37.3	QA/QC SB Date 3/25
Impinger 2	100 mL 0.1N H2SO4	722.9	566.8	156.1	
Impinger 3	100 mL 0.1N H2SO4	599.0	543.2	55.8	
Impinger 4	Empty	454.6	442.1	12.5	
Impinger 5	Silica Gel	724.2	706.5	17.7	Total Weight (gm)
Impinger 6					261.7
Impinger 7					279.4

Run No.	3	Filter Type Teflon Mat	Sample Box No.	B1
Date		Lot No.	pH	
Analyst		Filter No. NA	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	492.4	457.9	34.5	QA/QC Date
Impinger 2	100 mL 0.1N H2SO4	703.7	547.5	156.5	
Impinger 3	100 mL 0.1N H2SO4	592.9	539.4	53.5	
Impinger 4	Empty	468.9	468.6	0.3	
Impinger 5	Silica Gel	735.5	724.4	11.1	Total Weight (gm)
Impinger 6					244.5
Impinger 7					255.6


QA/QC SB  
Date 3/25



TEST LOCATION: FF Outlet Reinforced Metals TESTING METHOD: 5729 PAGE 1 OF 2  
 UNIT: 2 RUN: 1 FIELD DATA SHEET

Client: Whitcomb Project No: 12218  
 Plant: S. Broward Date: 3/25/13  
 Meter Operator: P. Bihun  
 Probe Operator: P. Bihun

Meter Box: PA 10 22 Sample Box No: M9  
 Meter Y: 100009972 Meter ΔH: 1.820  
 K Factor: 0.0228215 Pitot C: 0.1824  
 Leak Rate Before: 0.007 [Lpm] @ 75 (in. Hg)  
 Leak Rate After: 0.002 [Lpm] @ 10 (in. Hg)  
 Pitot Leak Check Before:  After:  Good  Bad



Amb. Temp (°F): 75 Bar. Press: 29.70 (in. Hg) (mbar)  
 Probe I.D. No: 67-8-47  
 Liner Material: Glass

Filter No: c45-1  
 Trimble No: N/A  
 Nozzle Diameter: 0.2725 Nozzle I.D.: 2725-1

Start Time: 7:59 Stop Time: 10:41

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume		Stack Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond Temp T <sub>c</sub> (°F)	DGM Inlet T <sub>in</sub> (°F)	DGM Outlet T <sub>out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb. Filter <input type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes	
				Init. Vol. (L)	m <sup>3</sup> (L)											
1	5	0.33	0.88	842.00		298	250	252	65	77	76	4.0	7.6	N/A	66-4	
2	10	0.31	0.82	847.11		299	253	253	65	79	76	3.5	7.2		Yd = 0.990	
3	15	0.32	0.85	849.62		298	251	256	63	80	77	3.5	7.9		ΔH = 1.8274	
4	20	0.33	0.88	852.19		298	250	250	62	82	77	4.0	7.9			
5	25	0.35	0.93	854.87		298	250	248	63	84	78	4.0	7.8		574.910	
6	30	0.32	0.85	857.50		298	248	247	65	83	79	4.0	8.1		-0.075	
7	35	0.33	0.88	860.08		299	249	249	65	81	78	4.0	8.3			
8	40	0.37	0.98	862.82		299	250	252	65	81	78	4.0	8.5			
9	45	0.42	1.1	865.71		300	250	254	62	82	78	4.5	9.0			
10	50	0.38	1.0	868.54		300	250	250	60	84	78	4.5	8.2		868.625	
11	55	0.27	0.72	870.97		303	249	247	61	82	78	3.5	9.2		-0.085	
12	60	0.40	1.1	873.90		300	249	248	61	83	79	4.5	9.5			
Total																
Average																

Sum of square roots: 10.99  
 Circle correct bracketed units on data sheet: 70.850  
70.845  
38 4/17  
3590  
81.8600  
110



QA/QC: YH  
 Date: 3/25/13

G-21

TEST LOCATION: FF Outlet  
 UNIT: 2 RUN: 1

Substrate / Metals TESTING  
**FIELD DATA SHEET**

METHOD: 5129 PAGE 2 OF 2

Client: Whe. Lab. Lab Project No.: 12218  
 Plan: S. Brewer Date: 3/25/13  
 Meter Operator: P. Bihun  
 Probe Operator: P. Bihun

Meter Box: \_\_\_\_\_ Sample Box No.: \_\_\_\_\_  
 Meter Yr: \_\_\_\_\_ Meter ΔH: \_\_\_\_\_  
 K Factor: \_\_\_\_\_ P/O C: \_\_\_\_\_  
 Leak Rate Before: [cfm] [Lpm] @ \_\_\_\_\_ (in. Hg)  
 Leak Rate After: [cfm] [Lpm] @ \_\_\_\_\_ (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad

Cross-Section of Test Location

↑  
 [N] [UP]

Duct Dimensions (in.): \_\_\_\_\_

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (in) [Out]	First point all the way
_____	_____	_____	_____

of page \_\_\_\_\_ [In] [Out]

Amb Temp (°F) \_\_\_\_\_ Bar. Press. \_\_\_\_\_ [in. Hg] [mbar]  
 Probe ID No. \_\_\_\_\_  
 Liner Material \_\_\_\_\_

Filter No. \_\_\_\_\_  
 Thimble No. \_\_\_\_\_  
 Nozzle Diameter \_\_\_\_\_ Nozzle ID \_\_\_\_\_

Start Time: \_\_\_\_\_ Stop Time: \_\_\_\_\_

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (L)	Stack Temp Ts (°F)	Probe T <sub>p</sub> (°F)		Filter T <sub>f</sub> (°F)	Cond. Temp T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (%dv)	Amb Filter <input type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
						Set Point	Set Point								
3	65	0.44	1.2	877.01	297	251	251	59	85	87	5.0	8.3	NA		
4	70	0.52	1.4	880.38	302	251	252	58	87	80	5.5	8.9			
5	75	0.50	1.3	883.600	300	250	247	59	88	80	5.0	9.3		883.600	
1	80	0.45	1.2	886.76	300	249	246	62	86	81	5.0	9.0		(-0.09)	
2	85	0.43	1.1	889.74	300	250	255	63	87	81	5.0	8.9			
3	90	0.48	1.3	892.98	298	251	254	63	87	81	5.5	10.1			
4	95	0.46	1.2	896.12	299	250	256	63	88	81	5.0	9.2		896.12	
5	100	0.48	1.3	899.325	299	250	246	64	88	82	5.5	7.4		(-0.085)	
1	105	0.36	0.95	902.12	296	249	255	65	86	81	4.5	7.7			
2	110	0.36	0.95	904.80	298	250	248	64	86	82	4.5	7.8			
3	115	0.37	0.95	907.55	298	250	252	62	87	82	4.5	7.8			
4	120	0.36	0.95	910.23	298	251	250	63	87	82	4.5	8.2			
5	125	0.40	1.1	913.180	299	250	250	63	87	82	5.0	8.3			
Total															
Average															

Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC PB  
 Date 3/25/13

G-22

TEST LOCATION: FF Outlet

Particulate / Metals TESTING

FIELD DATA SHEET

METHOD: 5725

PAGE 1 OF 2

UNIT: 2

RUN: 2

Client <u>Wheabrator</u>	Project No. <u>12218</u>
Plant <u>S. Broward</u>	Date <u>3/25/13</u>
Meter Operator <u>P. Bihun</u>	
Probe Operator <u>P. Bihun</u>	

Cross-Section of Test Location

Duct Dimensions: (in.) 96 x 96

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (in) [Out]	First point all the way (in) [Out]
<u>-11.6</u>	<u>10.0</u>		

Amb. Temp. (°F) <u>77</u>	Bar. Press. <u>29.70</u> (in. Hg) (mbar)
Probe I.D. No. <u>67-8-17</u>	
Liner Material: <u>Glass</u>	

Meter Box <u>U6-11</u>	Sample Box No. <u>M1</u>
Meter Vol. <u>0.9906</u>	Meter ΔH <sub>0</sub> <u>1.8274</u>
K Factor <u>2.65</u>	Pitot Co. <u>0.824</u>
Leak Rate Before <u>0.0030</u> (cm) [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.0020</u> (cm) [Lpm] @ <u>10</u> (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: <input checked="" type="checkbox"/> Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Filter No. <u>045-10</u>	
Thimble No. <u>N/A</u>	
Nozzle Diameter <u>0.2725</u>	Nozzle I.D. <u>2725-1</u>

Start Time: <u>10:32</u>	Stop Time: <u>12:45</u>
--------------------------	-------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub>		Stack Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb Filter <input type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
				Init. Vol.	(ft <sup>3</sup> ) (L)										
3-1	5	0.30	0.80	913.46		300	250	250	65	82	81	4.0	8.1		
2	10	0.34	0.90	918.62		306	256	254	65	87	82	4.0	8.5		
3	15	0.38	1.0	924.36		305	253	284	64	87	83	4.5	8.5		
4	20	0.46	1.2	929.44		298	250	253	63	88	83	5.0	8.4		
5	25	0.46	1.2	927.52		300	250	252	63	90	84	5.0	8.5		927.65
2-1	30	0.42	1.1	930.52		299	249	249	65	89	85	4.5	8.8		(-0.29)
2	35	0.40	1.1	933.46		301	250	255	65	91	85	4.5	8.1		
3	40	0.42	1.1	936.38		298	251	249	62	92	86	4.5	8.3		
4	45	0.41	1.1	939.29		300	250	253	56	92	86	4.5	8.6		
5	50	0.48	1.3	942.570		299	250	250	55	91	86	5.0	8.6		942.57
1-1	55	0.30	0.80	941.06		295	249	255	57	88	85	4.0	9.2		(-0.08)
2	60	0.38	1.0	947.84		300	250	252	57	86	84	4.5	7.8		
Total				25300	69850										
Average				0.6661	1.0120	299.120				86.5400					

Sum of square roots: 1216

Circle correct bracketed units on data sheet: 3601

2071



G-23



TEST LOCATION: FF Outlet  
 UNIT: 2 RUN: 2

Parkville/Whaley TESTING  
 FIELD DATA SHEET

METHOD: 5129 PAGE 2 OF 2

Client: Whaley Project No: 12218  
 Plant: S. Whaley Date: 3/25/13  
 Meter Operator: P. Behm  
 Probe Operator: P. Behm

Cross-Section of Test Location

↑  
 [N] [UP]

Duct Dimensions (in):

Static Pres (in. H <sub>2</sub> O)	Port Len (in.)	Gas Flow (In) [Out]	First point all the way of page [In] [Out]
------------------------------------	----------------	---------------------	--

Amb. Temp (°F) Bar. Press. (in. Hg) [mbar]  
 Probe ID No.  
 Liner Material

Meter Box Sample Box No.  
 Meter V<sub>0</sub> Meter ΔH<sub>0</sub>  
 K Factor Pitot C<sub>p</sub>  
 Leak Rate Before [cfm] [Lpm] @ (in. Hg)  
 Leak Rate After [cfm] [Lpm] @ (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad

Filter No.  
 Thimble No.  
 Nozzle Diameter Nozzle I.D.

Start Time: Stop Time:

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>s</sub> (L)	Stack Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp (°F)	DGM Inlet T <sub>in</sub> (°F)	DGM Outlet T <sub>out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% O <sub>2</sub> )	Amb Filter <input type="checkbox"/>	Dioxin Trap <input type="checkbox"/>	Notes
						Set Points									
3	65	0.39	1.0	950.61	298	250	251	56	89	84	4.5	7.3			
4	70	0.40	1.1	953.55	300	257	249	56	90	84	5.0	7.8			
5	75	0.45	1.2	956.630	296	250	253	57	91	85	5.0	7.4			956.75
5-1	80	0.30	0.80	959.23	296	249	253	59	87	85	4.0	9.0			0.125
2	85	0.32	0.85	961.77	298	249	252	63	89	85	4.0	8.4			
3	90	0.38	1.0	964.57	300	257	252	63	89	85	4.5	8.2			
4	95	0.33	0.88	967.15	299	251	252	60	91	86	4.5	7.8			
5	100	0.38	1.0	969.940	299	250	247	58	91	86	4.5	8.6			970.030
4-1	105	0.41	1.1	972.92	300	248	250	60	90	86	5.0	8.8			0.09
2	110	0.35	0.93	975.60	297	249	252	61	88	86	4.5	8.6			
3	115	0.35	0.93	978.30	298	251	251	62	86	85	4.5	8.0			
4	120	0.35	0.93	980.93	298	250	251	63	85	84	4.5	9.1			
5	125	0.37	0.98	983.705	298	250	251	63	85	84	4.5	8.9			
Total															
Average															

Sum of square roots.

Circle correct bracketed units on data sheet.



G-24




TEST LOCATION: FF Outlet  
 UNIT: 2 RUN: 3

Perth/lat/Modals TESTING  
**FIELD DATA SHEET**

METHOD: 5129 PAGE 1 OF 2

Client	<u>Wheelabrator</u>	Project No.	<u>12218</u>
Plant	<u>4. Broward</u>	Date	<u>3/25/13</u>
Meter Operator	<u>P. Bihun</u>		
Probe Operator	<u>P. Bihun</u>		



Amb. Temp (°F)	<u>78</u>	Bar. Press (in. Hg) (mbar)	<u>29.70</u>
Probe ID No.	<u>67-5-17</u>		
Liner Material	<u>Glass</u>		

Meter Box	<u>4-11</u>	Sample Box No.	<u>M9</u>
Meter Yr	<u>0.9906</u>	Meter ΔH <sub>0</sub>	<u>1.8224</u>
K Factor	<u>2.65</u>	Pilot C <sub>0</sub>	<u>0.824</u>
Leak Rate Before (cm <sup>3</sup> /Lpm)	<u>0.063</u>	@ (in. Hg)	<u>15</u>
Leak Rate After (cm <sup>3</sup> /Lpm)		@ (in. Hg)	
Pilot Leak Check Before	<input checked="" type="checkbox"/>	After Good	<input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Filter No.	<u>054-39</u>		
Thimble No.	<u>N/A</u>		
Nozzle Diameter	<u>0.2725</u>	Nozzle I.D.	<u>2725-1</u>

Start Time	<u>13:04</u>	Stop Time	<u>15:17</u>
------------	--------------	-----------	--------------

Reverse Point Number	Min/pt Elapsed Time	Velocity Head (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (L)		Stack Temp T <sub>s</sub> (°F)	Probe Temp (°F)		Cond. Temp T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb Filter <input type="checkbox"/> Bloxin Trap <input type="checkbox"/>	Notes
				Init. Vol.	(L)		Set Points	Set Points							
5-1	5	0.30	0.80	984.15		298	250	253	66	80	80	4.0	9.3		
2	10	0.33	0.88	989.30		299	257	254	63	83	80	4.0	9.0		
7	15	0.32	0.88	991.80		299	254	253	61	84	81	4.0	8.3		
4	20	0.35	0.93	994.47		299	251	251	61	84	82	4.0	8.1		
1	25	0.35	0.93	997.140		305	249	248	62	88	83	4.0	8.5		997.245
4-1	30	0.37	0.98	1000.00		312	250	247	64	89	84	4.5	8.5		(-0.10)
2	35	0.37	0.98	1002.76		307	249	253	64	89	85	4.5	8.5		
3	40	0.35	0.93	1005.42		299	251	248	62	90	88	4.5	8.2		
4	45	0.38	1.0	1008.20		303	250	250	62	89	88	4.5	7.9		
5	50	0.35	0.93	1010.890		300	250	253	61	89	85	4.5	8.3		1010.990
3-1	55	0.38	1.0	1013.77		298	249	248	62	86	85	4.5	8.5		(-0.10)
2	60	0.35	0.93	1016.44		302	249	253	63	88	85	4.5	8.4		
	Total			594.118											
	Average			69.435		300	249	253	62	89	85	4.5	8.4		

Sum of square roots: 0.6118  
 Single correct bracketed units on data sheet: 2043



QA/QC RB  
 Date 3/25/13

TEST LOCATION: FF Outlet

UNIT: 2

RUN: 3

# TESTING FIELD DATA SHEET

METHOD: 5729 PAGE 1 OF 2

Client	<u>Whelanator</u>	Project No.	<u>12218</u>
Plant	<u>S. Broward</u>	Date	<u>3/25/13</u>
Meter Operator	<u>P. Bihun</u>		
Probe Operator	<u>P. Bihun</u>		

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres	Port/Inlet	Gas Flow	First point
(in. H <sub>2</sub> O)	(in.)	[In] [Out]	all the way
of page			[In] [Out]

Amb. Temp. (°F)	Bar. Press.	[in. Hg] [mbar]
Probe I.D. No.		
Liner Material		

Meter Box	Sample Box No.				
Meter Y <sub>ct</sub>	Meter ΔH <sub>@</sub>				
K Factor	Pitot C <sub>p</sub>				
Leak Rate Before	[cfm] [Lpm]	@	(in. Hg)		
Leak Rate After	[cfm] [Lpm]	@	(in. Hg)		
Pitot Leak Check Before	<input type="checkbox"/>	After Good	<input type="checkbox"/>	Bad	<input type="checkbox"/>

Filter No.		
Thimble No.		
Nozzle Diameter		Nozzle I.D.

Start Time	Stop Time
------------	-----------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume Inlet Vol (ft <sup>3</sup> )	Stack Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Cond. Temp T <sub>c</sub> (°F)	DGM Inlet T <sub>m</sub> (°F)	DGM Outlet T <sub>m</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% O <sub>2</sub> )	Amb Filter <input type="checkbox"/>	Dioxin Trap <input type="checkbox"/>	Notes
						Set Points	Set Points								
3	65	0.37	0.98	1019.19	289	257	257	62	89	81	4.5	8.7			
4	70	0.42	1.1	1022.16	303	200	254	63	89	85	5.0	8.8			
1	75	0.42	1.1	1025.140	301	250	257	63	92	85	5.0	9.1			1025.215
2-1	80	0.38	1.0	1027.99	304	249	249	65	88	85	4.5	9.1			-0.075
2	85	0.46	1.2	1031.11	299	249	252	65	88	85	5.0	8.2			
3	90	0.40	1.1	1034.03	299	250	250	62	84	83	5.0	8.3			
4	95	0.46	1.2	1037.11	297	250	252	63	81	81	5.0	8.7			
1	100	0.43	1.1	1040.100	300	250	247	62	83	81	5.0	8.6			1040.175
1-1	105	0.34	0.90	1042.82	301	249	255	63	81	80	4.5	8.9			-0.075
2	110	0.36	0.95	1045.50	297	250	254	64	81	80	4.5	8.4			
3	115	0.36	0.95	1048.21	298	200	255	60	80	79	4.5	9.1			
4	120	0.32	0.85	1050.76	298	250	253	61	81	79	4.5	9.2			
5	125	0.47	1.3	1053.945	299	251	253	61	81	79	5.5	8.8			
Total															
Average															

Sum of square roots.

Circle correct bracketed units on data sheet.



G-26

# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 2 FF Outlet	
Plant <u>South Broward</u>	Job No. 12218	Method	5/29

Balance Calibration Check			
Balance ID	<u>TL 07-4 8028301068</u>	Reference Weight Mass	<u>500.0g</u>
Reference Weight ID	<u>60150</u>	Reference Weight Reading	<u>499.3g</u>

Check must be performed at least Once per Method per Job      Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No. <u>1</u>	1	Filter Type Quartz	Sample Box No. <u>M9</u>
Date <u>3-25-13</u>		Lot No.	pH NA
Analyst <u>DL</u>		Filter No. <u>e45-11</u>	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	<u>703.8</u>	<u>456.6</u>	<u>247.2</u>	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>682.6</u>	<u>558.2</u>	<u>124.4</u>	QA/QC <u>SB</u> Date <u>3/25</u>
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>586.1</u>	<u>554.6</u>	<u>31.5</u>	
Impinger 4	Empty	<u>445.5</u>	<u>437.6</u>	<u>7.9</u>	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>549.7</u>	<u>545.2</u>	<u>4.5</u>	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>538.2</u>	<u>537.5</u>	<u>1.7</u>	
Impinger 7	≈ 250 g Silica Gel	<u>735.3</u>	<u>715.8</u>	<u>19.5</u>	<u>436.7</u>

Run No. <u>2</u>	2	Filter Type Quartz	Sample Box No. <u>M1</u>
Date <u>3-25-13</u>		Lot No.	pH NA
Analyst <u>DL</u>		Filter No. <u>e45-10</u>	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	<u>688.1</u>	<u>444.3</u>	<u>243.8</u>	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>639.9</u>	<u>531.7</u>	<u>108.2</u>	QA/QC Date
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>566.9</u>	<u>538.8</u>	<u>28.1</u>	
Impinger 4	Empty	<u>451.3</u>	<u>444.7</u>	<u>6.6</u>	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>547.9</u>	<u>542.6</u>	<u>5.3</u>	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>540.7</u>	<u>538.5</u>	<u>2.2</u>	
Impinger 7	≈ 250 g Silica Gel	<u>837.9</u>	<u>824.5</u>	<u>13.4</u>	<u>407.6</u>

Run No.	3	Filter Type Quartz	Sample Box No. <u>M9</u>
Date <u>3/25/13</u>		Lot No.	pH NA
Analyst <u>DL</u>		Filter No. <u>e54-39</u>	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	<u>716.5</u>	<u>456.5</u>	<u>260.0</u>	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>652.5</u>	<u>556.6</u>	<u>95.9</u>	QA/QC <u>SB</u> Date <u>3/25</u>
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	<u>564.0</u>	<u>544.8</u>	<u>19.2</u>	
Impinger 4	Empty	<u>441.6</u>	<u>436.9</u>	<u>4.7</u>	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>548.7</u>	<u>546.0</u>	<u>2.7</u>	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	<u>540.8</u>	<u>540.6</u>	<u>0.2</u>	
Impinger 7	≈ 250 g Silica Gel	<u>749.5</u>	<u>735.3</u>	<u>14.2</u>	<u>396.9</u>

QA/QC SB  
Date 3/25




TEST LOCATION: FF OUTLOT METALS TESTING  
 UNIT: 2 RUN: 4  
**FIELD DATA SHEET**

METHOD: 5/29 PAGE 1 OF 2

Client: WHEELABRATOR Project No.: 12218  
 Plant: SOUTH BROWARD Date: 3/27/13  
 Meter Operator: SHAWN JOINT  
 Probe Operator: WAYNO BERRY

Meter Box: 66-22 Sample Box No.: M-1  
 Meter Yr: 0.9972 Meter ΔH: 1.8840  
 K Factor: 2.40 Pitot Cp: 0.825  
 Leak Rate Before: 0.03 [cfm] [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 0.003 [cfm] [Lpm] @ 16 (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad



Amb. Temp. (°F) Bar. Press. 30.10 (in. Hg) (mbar)  
 Probe I.D. No. 67-8-16  
 Liner Material: KLASS

Filter No. NA  
 Thimble No. NA  
 Nozzle Diameter: 0.2725 Nozzle I.D.: 0.2725-2

Start Time: 12:07 Stop Time: 14:22

Traverse Point Number	Min/pl Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (ft <sup>3</sup> ) [L]	Stack Temp (°F)	Probe T <sub>p</sub> (°F) Set Points	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet (°F)	DGM Outlet (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (% dv)	Amb. Filter		Notes
													<input type="checkbox"/>	<input type="checkbox"/>	
1-1	5	0.42	1.20	832.300	297	250	250	54	63	62	5	9.6	NA		
2	10	0.38	1.10	838.09	296	251	252	54	65	62	5	9.6			*K=2.77
3	15	0.39	1.10	840.85	295	252	254	53	65	62	5	9.6			
4	20	0.43	1.20	843.74	300	254	252	54	66	62	5	9.7			
5	25	0.45	1.20	846.69	299	252	251	56	68	63	5	9.3			ΔV=-.19
2-1	30	0.44	1.20	849.90	297	251	252	58	69	65	5	9.4			
2	35	0.45	1.20	852.92	297	250	252	59	70	65	5	9.5			
3	40	0.38	1.10	855.74	303	251	250	60	71	64	5	9.6			
4	45	0.45	1.20	858.74	300	252	251	62	71	65	5	9.4			
5	50	0.50	1.40	861.89	297	250	250	58	71	65	5	9.3			ΔV=-.11
3-1	55	0.36	0.90	864.72	299	251	250	41	72	66	5	9.0			
2	60	0.33	0.91	867.31	300	250	252	41	73	67	5	8.7			
Total		7.7185	13.9100	69.790	3580				824	793					
Average		0.6179	1.0629		299.9600				68	600					

Sum of square roots.

Circle correct bracketed units on data sheet.

SB 69.520  
4/23/13

QA/QC SA  
Date 4/23/13



TEST LOCATION: FF OUTLET  
 UNIT: 2 RUN: 4

METALS TESTING  
 FIELD DATA SHEET

METHOD: 5-29 PAGE 2 OF 2

Client: WHEELABRATOR Project No: 12217  
 Plant: S. Blowers Date: 3-27-13  
 Meter Operator: SS  
 Probe Operator: WB

Meter Box: \_\_\_\_\_ Sample Box No.: \_\_\_\_\_  
 Meter No.: \_\_\_\_\_ Meter ΔH@: \_\_\_\_\_  
 K Factor: \_\_\_\_\_ Pitot Cp: \_\_\_\_\_  
 Leak Rate Before: [cfm] [Lpm] @ (in. Hg)  
 Leak Rate After: [cfm] [Lpm] @ (in. Hg)  
 Pitot Leak Check Before:  After:  Good  Bad

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.): \_\_\_\_\_

Static Pres (in. H <sub>2</sub> O)	Pitot Len (in.)	Gas Flow (In) (Out)	First point all the way of page (In) (Out)
------------------------------------	-----------------	---------------------	--

Amb Temp (°F) \_\_\_\_\_ Bar. Press. (in. Hg) [mbar] \_\_\_\_\_  
 Probe I.D. No. \_\_\_\_\_  
 Liner Material \_\_\_\_\_

Filter No. \_\_\_\_\_  
 Thimble No. \_\_\_\_\_  
 Nozzle Diameter \_\_\_\_\_ Nozzle I.D. \_\_\_\_\_

Start Time: \_\_\_\_\_ Stop Time: \_\_\_\_\_

Traverse Point Number	Min/pt Elapsed time	Velocity Head (in. H <sub>2</sub> O)	Orifice Setting (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (L)	Stack Temp. Ts (°F)	Probe Temp (°F)		Cond. Temp. Tc (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>min</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb Filter		Notes
						Set	Points						<input type="checkbox"/>	<input type="checkbox"/>	
3-3	65	0.37	1.00	870.14	301	251	252	42	76	69	5	8.2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
4	70	0.40	1.10	873.00	300	252	252	43	76	70	5	8.4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5	75	0.41	1.10	875.74	300	250	251	43	76	70	5	8.5	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	ΔU = .08
4-1	80	0.36	1.00	878.74	299	252	251	43	74	70	5	9.0	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2	85	0.33	0.91	871.30	301	251	250	44	74	70	5	9.1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
3	90	0.35	0.97	883.99	295	253	254	46	74	70	5	9.4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
4	95	0.35	0.97	886.73	301	252	250	50	74	70	5	9.6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5	100	0.36	1.00	889.42	300	252	251	50	76	71	5	9.5	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	ΔU = .13
5-1	105	0.32	0.89	892.10	300	251	250	52	75	70	5	9.6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2	110	0.28	0.78	894.52	300	252	252	53	74	70	5	9.8	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
3	115	0.30	0.83	896.99	299	251	252	54	75	70	5	9.6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
4	120	0.42	1.20	900.10	299	252	251	55	75	70	5	9.3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5	125	0.36	1.00	902.90	299	252	252	55	75	70	5	9.2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Total		7.293	12.750		3894				974	90.000			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Average													<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC SS  
 Date 3-27-13

# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 2 FF Outlet	
Plant South Broward	Job No. 12218	Method	29

Balance Calibration Check			
Balance ID	TLO7-4 8028301068	Reference Weight Mass	500.0g
Reference Weight ID	60150	Reference Weight Reading	499.3g
Check must be performed at least Once per Method per Job		Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.	

Run No.	4	Filter Type Quartz	Sample Box No.	M1
Date	3/27/11	Lot No.	pH	NA
Analyst	DL	Filter No.	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	682g	443.1	239.7	
Impinger 2	100 ml 5%HNO <sub>3</sub> /10%H <sub>2</sub> O <sub>2</sub>	631.2	530.0	101.2	QA/QC SB Date 3/27
Impinger 3	100 ml 5%HNO <sub>3</sub> /10%H <sub>2</sub> O <sub>2</sub>	551.6	530.1	21.5	
Impinger 4	Empty	446.9	443.9	3.0	
Impinger 5	100 ml 4%KMnO <sub>4</sub> /10%H <sub>2</sub> SO <sub>4</sub>	542.8	541.3	1.5	Total Weight (gm)
Impinger 6	100 ml 4%KMnO <sub>4</sub> /10%H <sub>2</sub> SO <sub>4</sub>	534.9	536.2	-1.3	
Impinger 7	≈ 250 g Silica Gel	774.4	762.0	12.4	378.0

Run No.	5	Filter Type Quartz	Sample Box No.	
Date		Lot No.	pH	NA
Analyst		Filter No.	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty				
Impinger 2	100 ml 5%HNO <sub>3</sub> /10%H <sub>2</sub> O <sub>2</sub>				QA/QC Date
Impinger 3	100 ml 5%HNO <sub>3</sub> /10%H <sub>2</sub> O <sub>2</sub>				
Impinger 4	Empty				
Impinger 5	100 ml 4%KMnO <sub>4</sub> /10%H <sub>2</sub> SO <sub>4</sub>				Total Weight (gm)
Impinger 6	100 ml 4%KMnO <sub>4</sub> /10%H <sub>2</sub> SO <sub>4</sub>				
Impinger 7	≈ 250 g Silica Gel				

Run No.	6	Filter Type Quartz	Sample Box No.	
Date		Lot No.	pH	NA
Analyst		Filter No.	Rinse	NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty				
Impinger 2	100 ml 5%HNO <sub>3</sub> /10%H <sub>2</sub> O <sub>2</sub>				QA/QC Date
Impinger 3	100 ml 5%HNO <sub>3</sub> /10%H <sub>2</sub> O <sub>2</sub>				
Impinger 4	Empty				
Impinger 5	100 ml 4%KMnO <sub>4</sub> /10%H <sub>2</sub> SO <sub>4</sub>				Total Weight (gm)
Impinger 6	100 ml 4%KMnO <sub>4</sub> /10%H <sub>2</sub> SO <sub>4</sub>				
Impinger 7	≈ 250 g Silica Gel				

QA/QC SB  
Date 3/27




TEST LOCATION: FF outlet

DIOXIN TESTING  
FIELD DATA SHEET

METHOD: 23 PAGE 1 OF 2

UNIT: 2 RUN: 2

Client	<u>Wheelabrator</u>	Project No.	<u>12218</u>
Plant	<u>S. Broward</u>	Date	<u>3-26-13</u>
Meter Operator	<u>A. Obuchowski</u>		
Probe Operator			



Amb. Temp. (°F)	<u>65</u>	Bar. Press.	<u>29.90</u> [in. Hg] [mbar]
Probe I.D. No.	<u>67-8-16</u>		
Liner Material	<u>g/ass</u>		

Meter Box	<u>66-22</u>	Sample Box No.	<u>D3</u>
Meter Y <sub>d</sub>	<u>0.9972</u>	Meter ΔH <sub>0</sub>	<u>1.8840</u>
K Factor	<u>2.687275</u>	Pitot C <sub>p</sub>	<u>0.825</u>
Leak Rate Before	<u>0.005 [cfm]</u> [Lpm]	@	<u>15</u> (in. Hg)
Leak Rate After	<u>0.003 [cfm]</u> [Lpm]	@	<u>12</u> (in. Hg)
Pitot Leak Check Before	<input checked="" type="checkbox"/>	After: Good	<input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Filter No.	<u>-</u>		
Thimble No.	<u>-</u>		
Nozzle Diameter	<u>0.2722</u>	Nozzle I.D.	<u>2722-1</u>

Duct Dimensions (in.)	<u>96 x 96</u>		
Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
<u>-10.4</u>	<u>10</u>	<u>[In]</u>	<u>[Out]</u>

Start Time:	<u>0803</u>	Stop Time:	<u>1249</u>
-------------	-------------	------------	-------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (L)	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (%.dv)	<input checked="" type="checkbox"/> Amb Filter	<input checked="" type="checkbox"/> Dioxin-Trap	Notes	
						Set Points										
				<u>412.515</u>		<u>250</u>	<u>250</u>									
<u>1-1</u>	<u>10</u>	<u>0.35</u>	<u>0.94</u>	<u>417.65</u>	<u>292</u>	<u>251</u>	<u>249</u>	<u>47</u>	<u>59</u>	<u>58</u>	<u>5</u>	<u>7.9</u>	<u>46</u>		<u>IGS 0806 pause</u>	
<u>-2</u>	<u>20</u>	<u>0.38</u>	<u>1.0</u>	<u>423.02</u>	<u>292</u>	<u>252</u>	<u>251</u>	<u>46</u>	<u>60</u>	<u>58</u>	<u>8</u>	<u>8.5</u>	<u>45</u>			
<u>-3</u>	<u>30</u>	<u>0.43</u>	<u>1.2</u>	<u>428.83</u>	<u>297</u>	<u>250</u>	<u>250</u>	<u>49</u>	<u>61</u>	<u>59</u>	<u>9</u>	<u>8.2</u>	<u>50</u>			
<u>-4</u>	<u>40</u>	<u>0.37</u>	<u>0.99</u>	<u>434.28</u>	<u>301</u>	<u>250</u>	<u>250</u>	<u>52</u>	<u>62</u>	<u>59</u>	<u>8</u>	<u>8.1</u>	<u>52</u>			
<u>-5</u>	<u>50</u>	<u>0.47</u>	<u>1.3</u>	<u>440.42</u>	<u>295</u>	<u>250</u>	<u>249</u>	<u>56</u>	<u>62</u>	<u>59</u>	<u>10</u>	<u>7.8</u>	<u>55</u>		<u>440.42</u>	
<u>2-1</u>	<u>60</u>	<u>0.34</u>	<u>0.91</u>	<u>446.00</u>	<u>294</u>	<u>250</u>	<u>250</u>	<u>60</u>	<u>62</u>	<u>59</u>	<u>8</u>	<u>9.0</u>	<u>60</u>		<u>(0.35)</u>	
<u>-2</u>	<u>70</u>	<u>0.38</u>	<u>1.0</u>	<u>451.48</u>	<u>295</u>	<u>251</u>	<u>250</u>	<u>64</u>	<u>62</u>	<u>60</u>	<u>9</u>	<u>8.5</u>	<u>63</u>			
<u>-3</u>	<u>86</u>	<u>0.40</u>	<u>1.1</u>	<u>457.17</u>	<u>294</u>	<u>250</u>	<u>248</u>	<u>66</u>	<u>64</u>	<u>61</u>	<u>9</u>	<u>8.6</u>	<u>65</u>			
<u>-4</u>	<u>96</u>	<u>0.43</u>	<u>1.2</u>	<u>463.10</u>	<u>299</u>	<u>250</u>	<u>249</u>	<u>52</u>	<u>64</u>	<u>61</u>	<u>9</u>	<u>9.6</u>	<u>48</u>			
<u>-5</u>	<u>100</u>	<u>0.51</u>	<u>1.4</u>	<u>469.49</u>	<u>297</u>	<u>250</u>	<u>250</u>	<u>50</u>	<u>65</u>	<u>62</u>	<u>10</u>	<u>9.0</u>	<u>47</u>		<u>469.60</u>	
<u>3-1</u>	<u>110</u>	<u>0.34</u>	<u>0.94</u>	<u>474.92</u>	<u>291</u>	<u>250</u>	<u>249</u>	<u>47</u>	<u>65</u>	<u>61</u>	<u>8</u>	<u>9.5</u>	<u>46</u>		<u>(-0.11)</u>	
<u>-2</u>	<u>120</u>	<u>0.34</u>	<u>0.94</u>	<u>480.24</u>	<u>293</u>	<u>250</u>	<u>250</u>	<u>48</u>	<u>68</u>	<u>66</u>	<u>8</u>	<u>8.7</u>	<u>47</u>			
<u>-3</u>	<u>130</u>	<u>0.33</u>	<u>0.91</u>	<u>485.47</u>	<u>294</u>	<u>250</u>	<u>249</u>	<u>55</u>	<u>69</u>	<u>68</u>	<u>8</u>	<u>7.7</u>	<u>56</u>			
	<u>Total</u>	<u>15.1377</u>	<u>25.22</u>	<u>135.705</u>	<u>7393</u>				<u>1656</u>	<u>1578</u>						
	<u>Average</u>	<u>0.6055</u>	<u>1.0088</u>	<u>695.72</u>					<u>64.68</u>	<u>64.66</u>						

Sum of square roots.

Circle correct bracketed units on data sheet.

13.83

3874

623 (64.66)



QA/QC  
Date 3-26-13

TEST LOCATION: FF outlet  
 UNIT: 2 RUN: 2

DIOXIN TESTING  
**FIELD DATA SHEET**

METHOD: 23 PAGE 2 OF 2

Client <u>Wheelabrator</u>	Project No. <u>1221E</u>
Plant <u>S. Broward</u>	Date <u>3-26-13</u>
Meter Operator <u>A. Obuchowski</u>	
Probe Operator <u>11</u>	

Meter Box	Sample Box No.
Meter Y <sub>d</sub>	Meter ΔH <sub>@</sub>
K Factor	Pitot C <sub>p</sub>
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/>	After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
------------------------------------	-----------------	-----------------------------	------------------------------------

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. [ft <sup>3</sup> ] [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> Filter T <sub>f</sub> (°F)		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>min</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (%dv)	<input checked="" type="checkbox"/> Amb Filter <input checked="" type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
						Set Points	Set Points							
				<u>490.82</u>		<u>250</u>	<u>250</u>							
3-4	<u>140</u>	<u>0.35</u>	<u>0.96</u>	<del>465.47</del>	<u>296</u>	<u>250</u>	<u>250</u>	<u>64</u>	<u>70</u>	<u>67</u>	<u>8</u>	<u>8.7</u>	<u>63</u>	<u>200 cfm</u>
-5	<u>150</u>	<u>0.39</u>	<u>1.1</u>	<del>490.82</del> <u>496.18</u>	<u>296</u>	<u>250</u>	<u>250</u>	<u>62</u>	<u>70</u>	<u>66</u>	<u>9</u>	<u>9.0</u>	<u>65</u>	<u>496.36</u>
4-1	<u>160</u>	<u>0.37</u>	<u>1.0</u>	<u>501.77</u>	<u>299</u>	<u>249</u>	<u>249</u>	<u>54</u>	<u>67</u>	<u>65</u>	<u>8</u>	<u>9.3</u>	<u>56</u>	<u>(-0.18)</u>
-2	<u>170</u>	<u>0.33</u>	<u>0.91</u>	<u>506.97</u>	<u>298</u>	<u>250</u>	<u>251</u>	<u>49</u>	<u>67</u>	<u>65</u>	<u>8</u>	<u>9.2</u>	<u>55</u>	
-3	<u>180</u>	<u>0.33</u>	<u>0.91</u>	<u>512.20</u>	<u>295</u>	<u>251</u>	<u>251</u>	<u>49</u>	<u>69</u>	<u>64</u>	<u>8</u>	<u>8.1</u>	<u>59</u>	
-4	<u>190</u>	<u>0.35</u>	<u>0.96</u>	<u>517.54</u>	<u>296</u>	<u>249</u>	<u>250</u>	<u>52</u>	<u>69</u>	<u>64</u>	<u>8</u>	<u>9.2</u>	<u>63</u>	
-5	<u>200</u>	<u>0.44</u>	<u>1.2</u>	<u>523.44</u>	<u>295</u>	<u>249</u>	<u>250</u>	<u>56</u>	<u>68</u>	<u>64</u>	<u>10</u>	<u>8.8</u>	<u>54</u>	<u>523.62</u>
5-1	<u>210</u>	<u>0.28</u>	<u>0.77</u>	<u>528.40</u>	<u>292</u>	<u>249</u>	<u>246</u>	<u>59</u>	<u>70</u>	<u>65</u>	<u>7</u>	<u>9.2</u>	<u>59</u>	<u>(-0.18)</u>
-2	<u>220</u>	<u>0.33</u>	<u>0.91</u>	<u>533.60</u>	<u>296</u>	<u>251</u>	<u>250</u>	<u>61</u>	<u>71</u>	<u>66</u>	<u>8</u>	<u>9.6</u>	<u>61</u>	
-3	<u>230</u>	<u>0.33</u>	<u>0.91</u>	<u>538.84</u>	<u>299</u>	<u>250</u>	<u>249</u>	<u>64</u>	<u>70</u>	<u>65</u>	<u>8</u>	<u>9.8</u>	<u>64</u>	
-4	<u>240</u>	<u>0.33</u>	<u>0.91</u>	<u>544.02</u>	<u>305</u>	<u>250</u>	<u>248</u>	<u>63</u>	<u>72</u>	<u>66</u>	<u>8</u>	<u>8.7</u>	<u>57</u>	
-5	<u>250</u>	<u>0.31</u>	<u>0.85</u>	<u>549.04</u>	<u>292</u>	<u>250</u>	<u>253</u>	<u>64</u>	<u>70</u>	<u>66</u>	<u>8</u>	<u>8.7</u>	<u>54</u>	✓
Total														
Average														

\* Sum of square roots.

Circle correct bracketed units on data sheet.



G-32



TEST LOCATION: FF outlet

Dioxin TESTING

METHOD: 23 PAGE 1 OF 2

UNIT: 2 RUN: 3

**FIELD DATA SHEET**

Cross-Section of Test Location



Client	wheelabrator	Project No.	12218
Plant	S. Broward	Date	3-26-13
Meter Operator	A. Duchaux		
Probe Operator	"		

Amb. Temp. (°F)	65	Bar. Press.	29.90	(in. Hg) (mbar)
Probe I.D. No.	67-E-16			
Liner Material	glass			

Meter Box	66-22	Sample Box No.	
Meter Y <sub>d</sub>	0.9972	Meter ΔH <sub>0</sub>	1.8840
K Factor	2.70-2.77	Pitot C <sub>p</sub>	0.825
Leak Rate Before	0.04 (cfm) [Lpm]	@	15 (in. Hg)
Leak Rate After	0.00 (cfm) [Lpm]	@	12 (in. Hg)
Pitot Leak Check Before	<input checked="" type="checkbox"/>	After: Good	<input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Duct Dimensions (in.)	96 x 96		
Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (in.) [Out]	First point all the way of page (in.) [Out]
-11.0	10		

Filter No.	-		
Thimble No.	-		
Nozzle Diameter	0.2722	Nozzle I.D.	2722-1

Start Time:	1309	Stop Time:	17:25
-------------	------	------------	-------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>min</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (% dv)	<input type="checkbox"/> Amb Filter <input checked="" type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
						Set Points	Set Points							
				549.725		250	250							
5-1	10	0.29	0.78	554.56	297	250	250	61	72	68	5	8.6	56	200 cfm
-2	20	0.29	0.78	559.32	296	255	254	50	76	71	5	8.5	44	
-3	30	0.32	0.89	564.51	297	250	250	47	77	72	7	8.7	47	
-4	40	0.34	0.94	569.81	301	249	252	47	74	71	7	9.5	49	
-5	50	0.36	1.0	575.70	291	250	251	52	73	70	8	9.7	57	575.50
4-1	60	0.32	0.89	580.64	292	249	249	59	72	70	7	9.5	59	(-0.20)
-2	70	0.32	0.89	585.85	293	250	253	63	72	69	7	9.4	62	
-3	80	0.30	0.83	590.84	300	251	250	64	76	70	7	9.7	59	
-4	90	0.31	0.86	595.93	295	250	252	66	78	72	7	9.5	65	
-5	100	0.31	0.86	601.10	293	250	251	54	79	74	7	9.4	46	601.28
3-1	110	0.35	0.97	606.61	298	250	250	50	80	74	8	9.8	46	(-0.18)
-2	120	0.35	0.97	612.03	295	250	251	49	78	74	8	9.9	49	
-3	130	0.35	0.97	617.47	296	250	250	54	78	73	8	8.9	53	
Total		15.3252	26.27	139.9550	7456				1024	1802				
Average		0.6130	1.0508	298.24					74.52					

Sum of square roots.

Circle correct bracketed units on data sheet.

11.63

3844

985

928



G-33

TEST LOCATION: FF outlet DIOXIN TESTING METHOD: 23 PAGE 2 OF 2  
 UNIT: 2 RUN: 3

**FIELD DATA SHEET**

Client: <u>wheelabrator</u>	Project No. <u>1221E</u>
Plant: <u>S. Broward</u>	Date: <u>3-26-13</u>
Meter Operator: <u>A. Obuchowski</u>	
Probe Operator: <u>"</u>	

Meter Box	Sample Box No.
Meter $Y_d$	Meter $\Delta H_{@}$
K Factor	Pitot $C_p$
Leak Rate Before [cfm] [Lpm] @ (in. Hg)	
Leak Rate After [cfm] [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/>	After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
------------------------------------	-----------------	-----------------------------	------------------------------------

Amb. Temp. (°F)	Bar. Press. (in. Hg) [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head $\Delta P$ (in. H <sub>2</sub> O)	Orifice Setting $\Delta H$ (in. H <sub>2</sub> O)	Gas Sample Volume $V_m$ Init. Vol. <u>(ft<sup>3</sup>)</u> [L]	Stack Temp. $T_s$ (°F)	Probe $T_p$ (°F)	Filter $T_f$ (°F)	Cond. Temp. $T_c$ (°F)	DGM Inlet $T_{min}$ (°F)	DGM Outlet $T_{out}$ (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (%dv)	<input type="checkbox"/> Amb Filter <input checked="" type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
						Set Points 250 250								
3-4	140	0.42	1.2	623.47	297	250	251	58	76	73	9	9.5	53	200 u/min
3-5	150	0.42	1.2	629.48	296	250	254	63	75	72	9	9.9	55	629.61
2-1	160	0.43	1.2	635.62	296	250	250	61	76	72	9	9.9	53	(-0.17)
-2	170	0.41	1.1	641.33	299	250	251	55	77	72	8	9.9	49	
-3	180	0.43	1.2	647.27	299	251	249	52	79	72	9	9.8	50	
-4	190	0.44	1.2	653.25	297	250	251	55	77	71	9	10.0	53	
-5	200	0.51	1.4	659.76	299	250	250	60	79	72	10	9.9	58	659.90
1-1	210	0.35	0.97	665.38	312	250	250	62	79	74	8	10.0	59	(-0.14)
-2	220	0.35	0.97	670.86	305	250	253	64	81	74	8	9.9	52	
-3	230	0.42	1.2	676.87	302	250	250	59	80	74	9	10.0	49	
-4	240	0.50	1.4	683.37	304	250	247	61	80	74	10	10.1	56	
-5	250	0.59	1.6	690.33	306	250	250	65	80	74	12	10.4	63	↓
Total	*													
Average														

\* Sum of square roots.

Circle correct bracketed units on data sheet.



G-34

TEST LOCATION: FF outlet  
 UNIT: 2 RUN: 4

DIOXIN TESTING  
**FIELD DATA SHEET**

METHOD: 23 PAGE 1 OF 2

Client <u>Wheelabrator</u>	Project No. <u>1221E</u>
Plant <u>S. Broward</u>	Date <u>3-27-13</u>
Meter Operator <u>A. Chuchawski</u>	
Probe Operator <u>"</u>	

Meter Box <u>66-22</u>	Sample Box No. <u>D3</u>
Meter Yd <u>0.0072</u>	Meter ΔH <sub>@</sub> <u>1.8840</u>
K Factor <u>2.74</u>	Pitot Cp <u>0.825</u>
Leak Rate Before <u>0.005</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Leak Rate After <u>0.003</u> [cfm] [Lpm] @ <u>15</u> (in. Hg)	
Pitot Leak Check Before: <input checked="" type="checkbox"/> After: Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>	

Cross-Section of Test Location

Duct Dimensions (in.) 96 x 96

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (in.) [Out] of page	First point all the way (in.) [Out]
<u>-11.2</u>	<u>10</u>		<u>6</u>

Amb. Temp. (°F) <u>55</u>	Bar. Press. <u>30.10</u> (in. Hg) [mbar]
Probe I.D. No. <u>67-E-16</u>	
Liner Material <u>g/SS</u>	

Filter No. <u>-</u>	
Thimble No. <u>-</u>	
Nozzle Diameter <u>0.2722</u>	Nozzle I.D. <u>2722-1</u>

Start Time: <u>721</u>	Stop Time: <u>1139</u>
------------------------	------------------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (L)	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (% dv)	<input type="checkbox"/> Amb Filter <input checked="" type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
						Set Points								
2-1	10	0.34	0.93	690.910	295	260	250	43	49	47	5	9.2	39	200 cfm
-2	20	0.36	0.99	701.37	298	252	252	38	51	48	7	9.0	40	
-3	30	0.44	1.2	707.13	299	250	252	37	54	49	8	8.8	45	
-4	40	0.40	1.1	712.70	299	250	253	40	58	52	8	9.0	53	
-5	50	0.45	1.2	718.55	304	249	249	43	59	54	8	8.7	57	718.73
1-1	66	0.33	0.90	723.86	296	249	251	47	58	57	7	9.9	49	(-0.18)
-2	70	0.38	1.0	729.25	292	250	250	48	57	57	8	8.1	47	
-3	80	0.30	0.82	734.24	300	250	250	50	59	58	7	8.8	53	
-4	90	0.38	1.0	739.70	288	249	250	51	61	60	8	8.9	51	
-5	100	0.42	1.2	745.62	290	250	249	53	60	61	9	8.8	54	745.91
5-1	110	0.22	0.60	750.15	291	249	250	54	61	62	6	9.9	57	(-0.29)
-2	120	0.28	0.77	755.03	293	250	250	56	62	63	7	8.8	58	
-3	130	0.33	0.90	760.27	292	250	252	49	62	63	8	8.3	49	
Total		15.945	26.920	139.920	293				1548	1519				
Average		0.6238	1.0768	295.720					61.340					

Sum of square roots.

Circle correct bracketed units on data sheet.

12.61

3877

751 731



G-35

TEST LOCATION: FF outlet  
 UNIT: 2 RUN: 4

Dioxin TESTING  
**FIELD DATA SHEET**

METHOD: 22 PAGE 2 OF 2

Client	Wheelabrator	Project No.	1221 E
Plant	S. Broward	Date	3-27-13
Meter Operator	A. Obuchowski		
Probe Operator	"		

Meter Box	Sample Box No.
Meter Y <sub>d</sub>	Meter ΔH <sub>@</sub>
K Factor	Pitot C <sub>p</sub>
Leak Rate Before	[cfm] [Lpm] @ (in. Hg)
Leak Rate After	[cfm] [Lpm] @ (in. Hg)
Pitot Leak Check Before:	<input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow [In] [Out] of page	First point all the way [In] [Out]
------------------------------------	-----------------	-----------------------------	------------------------------------

Amb. Temp. (°F)	Bar. Press. [in. Hg] [mbar]
Probe I.D. No.	
Liner Material	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. [ft <sup>3</sup> ] [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator, approx (%.dv)	Amb Filter		Notes
						Set Points	Set Points							<input type="checkbox"/>	<input checked="" type="checkbox"/>	
5-4	140	0.35	0.96	765.64	291	250	250	250	46	63	64	8	8.5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	165 200 u/min
-5	150	0.39	1.1	771.36	292	250	249	250	47	63	64	8	8.5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	771.50
4-1	160	0.35	0.96	776.82	289	250	251	250	51	64	64	8	9.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	-0.14
-2	170	0.36	0.99	782.30	291	250	250	250	56	67	66	8	9.5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
-7	180	0.39	1.1	788.06	293	250	249	250	61	67	67	9	10.5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
-4	190	0.48	1.3	794.31	294	250	250	250	58	68	68	10	10.9	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
-5	200	0.51	1.4	800.73	295	249	252	250	52	70	70	10	9.9	<input type="checkbox"/>	<input checked="" type="checkbox"/>	800.90
3-1	210	0.42	1.2	806.85	300	250	248	250	55	67	68	9	10.5	<input type="checkbox"/>	<input checked="" type="checkbox"/>	-0.17
-2	220	0.43	1.2	812.72	302	250	251	250	58	67	66	9	9.8	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
-3	230	0.44	1.2	818.70	300	250	248	250	62	66	64	9	10.6	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
-4	240	0.55	1.5	825.14	304	250	250	250	61	67	64	11	10.4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
-5	250	0.52	1.4	831.610	305	250	250	250	61	68	63	11	9.9	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Total															*	
Average																

Sum of square roots.

Circle correct bracketed units on data sheet.



# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 2 FF Outlet	
Plant South Broward	Job No. 12218	Method 23	

Balance Calibration Check			
Balance ID	TL07-4 8028901135	Reference Weight Mass	500.0g
Reference Weight ID	60150	Reference Weight Reading	499.3g

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No. 1	Filter Type Rinsed Glass Fiber	Sample Box No. D4
Date 3-25-13	Lot No.	pH NA
Analyst HN	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	636.0	632.8	730.2	
Impinger 2	100 ml HPLC Water	541.3	538.1	3.2	QA/QC 5B Date 3/26
Impinger 3	100 ml HPLC Water	560.9	560.1	0.8	
Impinger 4	Empty	420.5	420.3	0.2	
Impinger 5	Trap # T1640-003	355.9	335.0	20.9	Total Weight (gm)
Impinger 6	Silica Gel	780.5	728.7	51.8	755.3
Impinger 7					807.1

Run No. 2	Filter Type Rinsed Glass Fiber	Sample Box No. D3
Date 3/26/13	Lot No.	pH NA
Analyst DL	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	1332.7	642.0	690.7	
Impinger 2	100 ml HPLC Water	508.9	510.1	-1.2	QA/QC 5B Date 3/26
Impinger 3	100 ml HPLC Water	517.3	517.6	-0.3	
Impinger 4	Empty	420.0	420.9	5.1	
Impinger 5	Trap # T1640-009	379.8	358.4	21.4	Total Weight (gm)
Impinger 6	Silica Gel	793.7	741	52.7	715.7
Impinger 7					768.4

Run No. 3	Filter Type Rinsed Glass Fiber	Sample Box No. D4
Date 3/26/13	Lot No.	pH NA
Analyst PL	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	1283.7	633.5	650.2	
Impinger 2	100 ml HPLC Water	545.6	548.2	-2.6	QA/QC 5B Date 3/27
Impinger 3	100 ml HPLC Water	553.3	553.5	-0.2	
Impinger 4	Empty	420.1	420.1	0.0	
Impinger 5	Trap # T1640-001	425.2	404.8	20.4	Total Weight (gm)
Impinger 6	Silica Gel	755.9	705.1	50.8	662.8
Impinger 7					718.6

QA/QC 5B  
Date 3/27



# Impinger Weight Sheet

Client Wheelabrator	Unit Name / Location Unit 2 FF Outlet
Plant South Broward	Job No. 12218 Method 23

Balance Calibration Check			
Balance ID	8028101135	Reference Weight Mass	500g
Reference Weight ID	60150	Reference Weight Reading	499.9

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No. 4	4	Filter Type Rinsed Glass Fiber	Sample Box No.
Date: 3-27-13	Lot No.		pH NA
Analyst: HN	Filter No. NA		Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	1334.0	640.7	693.3	
Impinger 2	100 ml HPLC Water	523.7	523.2	0.5	QA/QC SB Date 4/18/13
Impinger 3	100 ml HPLC Water	531.0	529.7	1.3	
Impinger 4	Empty	430.2	430.2	0.0	
Impinger 5	Trap # 1640-002	343.1	321.4	21.7	Total Weight (gm)
Impinger 6	Silica Gel	791.8	734.2	57.6	716.8
Impinger 7					774.4

Run No.	5	Filter Type Rinsed Glass Fiber	Sample Box No.
Date	Lot No.		pH NA
Analyst	Filter No. NA		Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty				
Impinger 2	100 ml HPLC Water				QA/QC Date
Impinger 3	100 ml HPLC Water				
Impinger 4	Empty				
Impinger 5	Trap #				Total Weight (gm)
Impinger 6	Silica Gel				
Impinger 7					

Run No.	6	Filter Type Rinsed Glass Fiber	Sample Box No.
Date	Lot No.		pH NA
Analyst	Filter No. NA		Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty				
Impinger 2	100 ml HPLC Water				QA/QC Date
Impinger 3	100 ml HPLC Water				
Impinger 4	Empty				
Impinger 5	Trap #				Total Weight (gm)
Impinger 6	Silica Gel				
Impinger 7					

QA/QC SB  
Date 4/18/13





TEST LOCATION: INLET  
 UNIT: 2 RUN: 2

HCL TESTING  
**FIELD DATA SHEET**

METHOD: 26A PAGE 1 OF 1

Client: WHEELABRATOR Project No: 1208  
 Plant: S. BROWARD Date: 3-27-13  
 Meter Operator: SS  
 Probe Operator: SS



Amb. Temp. (°F): 62 Bar. Press.: 30.10 [in. Hg] [mbar]  
 Probe I.D. No.: 66-4-7  
 Liner Material: GLASS

Filter No.: NA  
 Thimble No.: NA  
 Nozzle Diameter: NA Nozzle I.D.: NA

Meter Box: 61-11 Sample Box No: B14  
 Meter Yd: 1.0050 Meter ΔH: 1.6164  
 K Factor: NA Pitot Cp: 0.834

Duct Dimensions (in.):  
 Static Pres (in. H<sub>2</sub>O): -1.4 Port Len. (in.): 14  
 Gas Flow: [In] [Out] First point all the way  
 of page: (1) [Out]

Start Time: 9:08 Stop Time: 10:08

Traverse Point Number	Min/pt Elapsed Time	Velocity Head (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (L)	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>in</sub> (°F)	DGM Outlet T <sub>out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (ppm)	Amb Filter <input type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
						Set Points								
1-1	5	NA	20	838.00	496	355	355	45	80	78	4	7.7	NA	
	10			841.01	495	352	355	45	81	79	5	7.8		
	15			844.02	495	354	354	46	82	79	6	7.9		
	20			847.03	497	355	355	46	83	80	7	7.9		
	25			850.04	497	354	354	46	83	80	8	7.9		
	30			853.05	496	354	355	47	83	80	8	7.8		
	35			856.02	495	354	354	48	85	80	9	8.0		
	40			859.02	494	355	355	50	85	81	10	8.2		
	45			862.17	495	354	356	51	86	81	11	7.9		
	50			865.16	497	355	356	52	87	82	11	8.3		
	55			869.18	499	356	355	53	87	82	12	7.8		
	60			871.19	497	354	354	54	88	83	13	8.2		
				874.15										
	Total			36,150	5953				1010	965				
	Average			1,000	496.083				82.2917					

Sum of square roots.

Circle correct bracketed units on data sheet.



G-40



TEST LOCATION: INLET

HCL TESTING

METHOD: 26A


PAGE 1 OF 1

UNIT: 2

RUN: 3

### FIELD DATA SHEET

Client	<u>WHEELABRATOR</u>	Project No.	<u>12011</u>
Plant	<u>S. BROWARDS</u>	Date	<u>3-27-13</u>
Meter Operator	<u>SS</u>		
Probe Operator	<u>SS</u>		



Amb. Temp. (°F)	<u>64</u>	Bar. Press.	<u>30.10</u>	(in. Hg) [mbar]
Probe I.D. No.	<u>66-4-7</u>			
Liner Material	<u>GLASS</u>			

Meter Box	<u>61-11</u>	Sample Box No.	<u>B</u>
Meter Yd	<u>1.0050</u>	Meter ΔH	<u>1.504</u>
K Factor	<u>NA</u>	Pitot Cp	<u>0.934</u>
Leak Rate Before	<u>0.0036</u> [Lpm]	@	<u>15</u> (in. Hg)
Leak Rate After	[Lpm]	@	(in. Hg)
Pitot Leak Check Before	<input checked="" type="checkbox"/>	After: Good	<input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Filter No.	<u>NA</u>		
Thimble No.	<u>NA</u>		
Nozzle Diameter	<u>NA</u>	Nozzle I.D.	<u>NA</u>

Start Time	<u>10:27</u>	Stop Time	
------------	--------------	-----------	--

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> Init. Vol. (L)	Stack Temp. Ts (°F)	Probe Temp. (°F)		Cond. Temp. (°F)	DGM Inlet T <sub>in</sub> (°F)	DGM Outlet T <sub>out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (% O <sub>2</sub> )	Amb Filter	Dioxin Trap	Notes
						Set Points	Set Points								
1-1	5	NA	1.20	874.500	511	354	355	49	89	86	3	8.2			NA
	10			877.55	510	355	354	49	89	86	4	8.1			
	15			883.42	511	356	355	50	90	87	5	7.7			
	20			886.34	511	356	355	50	92	87	7	7.5			
	25			889.26	510	354	354	50	93	87	8	7.3			
	30			892.18	514	355	352	50	92	88	9	7.2			
	35			895.03	512	356	354	50	92	88	10	7.5			
	40			897.88	511	356	355	50	98	88	15	7.8			
	45	4.0 ←		899.06	511	355	356	49	103	89	20	8.7			
	50														
	55														
	60														
	Total														
	Average														

\* Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC SA  
Date 3-27-13

G-41

# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 2 SDA Inlet	
Plant South Broward	Job No. 12218	Method Modified 26A	

Balance Calibration Check			
Balance ID	FL 07-4 8028301068	Reference Weight Mass	500.0g
Reference Weight ID	60150	Reference Weight Reading	499.3g

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No. <u>1</u>	1 Filter Type Quartz	Sample Box No. <u>B6</u>
Date <u>3-27-13</u>	Lot No.	pH NA
Analyst <u>DL</u>	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	475.5	455.0	20.5	QA/QC <u>SB</u> Date <u>3/27</u>
Impinger 2	100 mL 0.1N H2SO4	644.2	544.2	100.0	
Impinger 3	100 mL 0.1N H2SO4	561.7	535.7	26.0	Total Weight (gm) <u>151.9</u> <u>165.5</u>
Impinger 4	Empty	487.7	482.3	5.4	
Impinger 5	Silica Gel	740.3	726.7	13.6	
Impinger 6					
Impinger 7					

Run No. <u>2</u>	2 Filter Type Quartz	Sample Box No. <u>B14</u>
Date <u>3-27-13</u>	Lot No.	pH NA
Analyst <u>DL</u>	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	502.0	464.3	38.7	QA/QC <u>SB</u> Date <u>3/27</u>
Impinger 2	100 mL 0.1N H2SO4	631.2	545.9	85.3	
Impinger 3	100 mL 0.1N H2SO4	582.8	567.6	15.2	Total Weight (gm) <u>140.6</u> <u>148.4</u>
Impinger 4	Empty	423.7	422.3	1.4	
Impinger 5	Silica Gel	739.0	731.2	7.8	
Impinger 6					
Impinger 7					

Run No. <u>3</u>	3 Filter Type Quartz	Sample Box No. <u>B6</u>
Date <u>3-27-13</u>	Lot No.	pH NA
Analyst <u>DL</u>	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	X	456.6		QA/QC Date
Impinger 2	100 mL 0.1N H2SO4		552.0		
Impinger 3	100 mL 0.1N H2SO4		532.8		
Impinger 4	Empty		482.8		
Impinger 5	Silica Gel		740.3		
Impinger 6					Total Weight (gm)
Impinger 7					

QA/QC SB  
Date 3/27



TEST LOCATION: PF OUTLOT  
 UNIT: 2 RUN: 1


ACL TESTING  
**FIELD DATA SHEET**

METHOD: 26A PAGE 1 OF 1

Client: WHEELABRATOR Project No: 12218  
 Plant: SOUTH BARABO Date: 3/27/13  
 Meter Operator: WAYNE BERRY  
 Probe Operator: \_\_\_\_\_

Meter Box: 66-11 Sample Box No: 8-1  
 Meter Yd: 0.9906 Meter Alt: 1.8274  
 K Factor: \_\_\_\_\_ Pitot Cp: \_\_\_\_\_

Leak Rate Before: 0.002 [cfm] [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 0.002 [cfm] [Lpm] @ 10 (in. Hg)  
 Pitot Leak Check Before:  After:  Bad:



Amb. Temp. (°F): 50 Bar. Press: 30.10 (in. Hg) [mbar]  
 Probe ID No: 67-4-3  
 Liner Material: GLASS

Filter No.: \_\_\_\_\_  
 Thimble No.: \_\_\_\_\_  
 Nozzle Diameter: \_\_\_\_\_ Nozzle I.D.: \_\_\_\_\_

Start Time: 0747 Stop Time: 0847

Traverse Point Number	Min/pt Elapsed Time	Velocity Head (in. H <sub>2</sub> O)	Orifice Setting (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (in. H <sub>2</sub> O)	Stack Temp. T <sub>s</sub> (°F)	Probe Temp. (°F)	Filter Temp. (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb. Filter		Notes
													<input type="checkbox"/>	<input type="checkbox"/>	
3-1	5	MA	1.5	057.80	294	283	302	43	51	50	5.5	9.0			
	10		1.5	061.10	292	289	301	40	54	57	5.5	8.1			
	15		1.5	064.42	296	291	300	40	56	53	5.5	8.0			
	20		1.5	067.74	302	292	300	43	58	54	6	8.1			
	25		1.5	071.10	296	292	301	46	59	56	6	9.1			
	30		1.5	074.47	298	284	299	51	58	58	6	8.8			
	35		1.5	077.85	299	280	300	54	59	59	6	8.5			
	40		1.5	081.24	293	280	299	58	59	60	6	8.1			
	45		1.5	084.58	295	283	300	59	61	61	6.5	8.1			
	50		1.5	088.06	300	279	301	61	60	62	6.5	8.3			
	55		1.5	091.34	298	280	300	62	62	63	6.5	7.8			
	60		1.5	094.745	290	283	300	63	62	64	6.5	8.0			
	Total			40.2700	3553.0				689.00	691.0					
	Average		<u>1.5</u>		<u>296.0833</u>				<u>57.5000</u>	<u>58.17</u>					

Sum of square roots:

Circle correct bracketed units on data sheet


52.916



TEST LOCATION: FF OUT LOT HCL TESTING METHOD: 26A PAGE 1 OF 1  
 UNIT: 2 RUN: 2 FIELD DATA SHEET

Client: WHEELABRATOR Project No. 12218  
 Plant: SOUTH BURNING Date: 3/27/13  
 Meter Operator: WAYNE BERRY  
 Probe Operator: \_\_\_\_\_

Meter Box: 66-11 Sample Box No.: B-24  
 Meter No.: 0,9906 Meter ΔH: 1.8274  
 K Factor: \_\_\_\_\_ Pitot Co.: \_\_\_\_\_  
 Leak Rate Before: 0.004 [cfm] [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 0.002 [cfm] [Lpm] @ 10 (in. Hg)  
 Pitot Leak Check Before:  After:  Good



Amb. Temp: (°F) 50 Bar. Press.: 30.10 (in. Hg) [mbar]  
 Probe I.D. No.: 67-4-3  
 Liner Material: GLASS

Filter No.: \_\_\_\_\_  
 Thimble No.: \_\_\_\_\_  
 Nozzle Diameter: \_\_\_\_\_ Nozzle I.D.: \_\_\_\_\_

Start Time: 0908 Stop Time: 1008

Traverse Point Number	Min/pl. Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>n</sub> (L)	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb Filter <input type="checkbox"/>	Dioxin Trap <input type="checkbox"/>	Notes
						300	300									
3-1	5	N/A	1.5	095.380	294	277	307	54	61	67	6	9.2				
	10		1.5	102.11	294	275	303	52	62	68	6.5	9.2				
	15		1.5	105.48	293	276	301	51	63	68	7	8.9				
	20		1.5	108.88	294	269	301	53	62	67	7	8.7				
	25		1.5	112.27	294	274	301	53	64	67	7	8.9				
	30		1.5	115.67	296	271	300	53	65	68	7	8.4				
	35		1.5	119.09	292	277	301	55	65	68	7	8.8				
	40		1.5	122.50	295	278	301	58	64	68	7	8.4				
	45		1.5	125.91	293	272	298	61	65	68	7	7.9				
	50		1.5	129.31	295	272	300	63	65	68	7	8.2				
	55		1.5	132.80	292	275	302	64	67	69	7	8.9				
	60		1.5	136.135	297	281	301	64	68	69	7	7.7				
	Total			40.7550	3529.0				771.9	815.0						
	Average				294.0833				66.0833							

\* Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC WB  
 Date 3/27/13

G-44

TEST LOCATION: FF OUTLET  
 UNIT: 2 RUN: 3


HCL TESTING  
**FIELD DATA SHEET**

METHOD: 26A PAGE 1 OF 1

Client: WHEELABRATOR Project No: 12218  
 Plant: SOUTH BROWNS Date: 3/27/13  
 Meter Operator: SHAWN JOINT  
 Probe Operator: WAYNE BONAT

Meter Box: 66-11 Sample Box No: B-01  
 Meter Yd: 0.9906 Meter ΔH: 1.8274  
 K Factor: 1 Pitot Co: 1

Leak Rate Before: 0.002 [cfm] [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 0.001 [cfm] [Lpm] @ 10 (in. Hg)  
 Pitot Leak Check Before: OK After: Good  Bad



Amb. Temp. (°F): 53 Bar. Press: 30.10 (in. Hg) [mbar]  
 Probe I.D. No: 67-4-3  
 Liner Material: GLASS

Filter No.: —  
 Thimble No.: —  
 Nozzle Diameter: — Nozzle I.D.: —

Start Time: 1027 Stop Time: 1127

Traverse Point Number	Min/pl. Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume Int. Vol. (ft <sup>3</sup> ) [L]	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)		Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb. Filter	Dioxin Trap	Notes
						300	300									
2-1	5	N/A	1.5	136.570	299	284	305	49	69	72	5.5	8.7				
	10		1.5	143.38	295	292	304	45	72	73	5.5	9.0				
	15		1.5	146.78	296	287	301	44	72	74	5.5	9.1				
	20		1.5	150.15	296	286	299	45	72	74	5.5	9.4				
	25		1.5	153.54	298	279	301	49	70	72	5.5	9.5				
	30		1.5	156.94	298	281	300	53	70	72	5.5	9.2				
	35		1.5	160.35	298	286	301	56	72	73	5.5	9.3				
	40		1.5	163.74	296	287	301	55	70	72	6	9.7				
	45		1.5	167.12	298	279	301	57	65	68	6	9.7				
	50		1.5	170.48	295	281	300	57	65	66	6	8.8				
55		1.5	173.83	297	290	301	58	66	65	6	9.8					
60		1.5	177.210	298	283	300	54	65	64	6	9.7					
Total				40.6400	3564.0					828.0	845.0					
Average				(1.5)	(297.00)					(69.7083)						

\*Sum of square roots.

Circle correct bracketed units on data sheet.



# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 2 FF Outlet	
Plant South Broward	Job No. 12218	Method Modified M26A	

Balance Calibration Check			
Balance ID	8028101135	Reference Weight Mass	500g
Reference Weight ID	60150	Reference Weight Reading	499.9

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No. 1	Filter Type Teflon Mat	Sample Box No. 131
Date 3-27-13	Lot No.	pH
Analyst HW	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	493.5	458.5	35.0	QA/QC 5B Date 3/27
Impinger 2	100 mL 0.1N H2SO4	654.8	548.0	106.8	
Impinger 3	100 mL 0.1N H2SO4	590.5	539.7	50.8	
Impinger 4	Empty	481.5	468.3	13.2	
Impinger 5	Silica Gel	702.8	687.9	14.9	Total Weight (gm)
Impinger 6					205.8
Impinger 7					220.7

Run No. 2	Filter Type Teflon Mat	Sample Box No. 324
Date 3-27-13	Lot No.	pH
Analyst HW	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	481.2	437.5	43.7	QA/QC 5B Date 3/27
Impinger 2	100 mL 0.1N H2SO4	660.0	547.6	112.4	
Impinger 3	100 mL 0.1N H2SO4	573.0	527.9	45.9	
Impinger 4	Empty	450.2	440.8	9.4	
Impinger 5	Silica Gel	730.1	716.8	13.3	Total Weight (gm)
Impinger 6					211.4
Impinger 7					224.7

Run No. 3	Filter Type Teflon Mat	Sample Box No. 31
Date 3-27-13	Lot No.	pH
Analyst HW	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	494.4	452.0	42.4	QA/QC 5B Date 3/27
Impinger 2	100 mL 0.1N H2SO4	661.3	545.8	115.5	
Impinger 3	100 mL 0.1N H2SO4	595.6	550.0	45.6	
Impinger 4	Empty	476.9	468.0	8.9	
Impinger 5	Silica Gel	717.9	702.4	15.5	Total Weight (gm)
Impinger 6					212.4
Impinger 7					227.9

QA/QC 5B  
Date 3/27  
G - 46





TEST LOCATION: FF OUTLET  
 UNIT: 3 RUN: 1

METALS TESTING  
**FIELD DATA SHEET**

METHOD: S-29 PAGE 2 OF 2

Client: <u>WHEELABRATOR</u>	Project No: <u>12217</u>
Plant: <u>S. BLOWERS</u>	Date: <u>3-26-13</u>
Meter Operator: <u>SJ</u>	
Probe Operator: <u>WLB</u>	

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.)

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (In) [Out]	First point all the way (In) [Out]

of page

Amb. Temp (°F)	<u>76</u>	Bar. Press.	<u>29.70</u>	(in. Hg) [mbar]
Probe ID No	<u>67-877</u>			
Liner Material	<u>GAS</u>			

Meter Box	Sample Box No.
Meter Yr	Meter ΔH
K-Factor	Pitot C
Leak Rate Before (cfm) [Lpm] @ (in. Hg)	
Leak Rate After (cfm) [Lpm] @ (in. Hg)	
Pitot Leak Check Before	After: Good <input type="checkbox"/> Bad <input type="checkbox"/>

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.
Start Time	Stop Time

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>s</sub> (ft <sup>3</sup> ) [L]	Stack Temp. Ts (°F)	Probe	Filter	Cond. Temp. Tc (°F)	DGM Inlet (°F)	DGM Outlet (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb. Filter <input type="checkbox"/> Dioxin Trap <input type="checkbox"/>	Notes
						(°F)	(°F)							
3-3	65	0.36	1.00	417.810	294	250	250	45	87	78	4	9.4	NA	
4	70	0.32	0.90	423.19	294	254	253	46	88	78	4	9.3		
5	75	0.29	0.81	425.65	293	252	252	46	87	79	4	9.5		ΔV = -.11
4-1	80	0.33	0.92	428.47	294	251	252	48	86	79	4	9.3		
2	85	0.32	0.90	431.11	294	250	250	50	86	79	4	9.4		
3	90	0.36	1.00	433.87	295	251	250	51	86	79	4	9.2		
4	95	0.39	1.10	436.86	295	252	251	51	88	79	4	9.0		
5	100	0.36	1.00	439.73	295	252	250	51	88	79	4	9.1		ΔV = -.14
5-1	105	0.30	0.84	444.87	294	250	251	53	85	79	4	9.5		
2	110	0.32	0.90	447.50	294	250	252	56	85	78	4	9.0		
3	115	0.43	1.20	450.72	295	251	250	56	88	79	4	9.2		
4	120	0.38	1.10	452.15	295	252	252	56	88	79	4	9.3		
5	125	0.36	1.00	453.57	295	250	252	56	87	79	4	9.1		
Total		7.6544	12.6700		3927				1132	1024				
Average														

\* Sum of square roots.

Circle correct bracketed units on data sheet.



G-48



TEST LOCATION: FF Outlet

UNIT: 3

RUN: 2

# TESTING FIELD DATA SHEET

METHOD: 5729 PAGE 1 OF 2

Client	<u>Whitcomb</u>	Project No.	<u>12218</u>
Plant	<u>S. Broward</u>	Date	<u>3/27/13</u>
Meter Operator	<u>P. Bikus</u>		
Probe Operator	<u>P. Bikus</u>		

Meter Box	<u>16-6</u>	Sample Box No.	<u>M3</u>
Meter Yd.	<u>6.954</u>	Meter ΔH	<u>1.8280</u>
K Factor	<u>2.64</u>	Pitot Co.	<u>0.824</u>
Leak Rate Before	<u>0.03</u> [pm] [Lpm]	@	<u>1.5</u> (in. Hg)
Leak Rate After	<u>0.03</u> [pm] [Lpm]	@	<u>1.0</u> (in. Hg)
Pitot Leak Check Before	<input checked="" type="checkbox"/>	After: Good	<input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

Duct Dimensions (in.) 96x96

Static Pres (in. H <sub>2</sub> O)	Port Len (in.)	Gas Flow (in) [Out]	First point all the way
<u>-9.8</u>	<u>10.0</u>		<input checked="" type="checkbox"/> [Out]

Amb Temp (°F)	<u>50</u>	Bar Press	<u>30.18</u> (in. Hg) [mbar]
Probe I.D. No.	<u>67-8-17</u>		
Liner Material	<u>Glass</u>		

Filter No.	<u>854-34</u>		
Thimble No.	<u>N/A</u>		
Nozzle Diameter	<u>0.1725</u>	Nozzle I.D.	<u>7725-1</u>

Start Time	<u>7:28</u>	Stop Time	<u>9:41</u>
------------	-------------	-----------	-------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub>		Stack Temp T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond Temp T <sub>c</sub> (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>max</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb Filter	Dioxin/Lead	Notes
				Init. Vol.	(ft <sup>3</sup> /L)											
5-1	5	0.38	0.99	454.160		328	212	210	50	53	52	4.0	8.6			
2	10	0.36	0.94	459.61		326	217	213	48	56	52	4.0	8.3			
3	15	0.35	0.91	462.21		328	218	216	44	59	53	4.0	7.9			
4	20	0.43	1.1	465.15		329	251	249	44	60	53	4.5	8.2			
5	25	0.44	1.1	468.05		330	250	257	48	62	54	4.5	8.5			
4-1	30	0.41	1.0	471.11		329	248	247	46	61	55	4.5	8.6			4.6 LIT (-0.02)
2	35	0.38	0.99	473.87		326	249	257	47	64	56	4.5	7.7			
3	40	0.36	0.94	476.52		327	243	248	49	65	56	4.0	8.3			
4	45	0.38	0.99	479.34		328	244	253	50	64	57	4.5	8.2			
5	50	0.33	0.86	481.92		327	248	249	51	65	57	4.0	8.6			4.6 LIT (-0.06)
3-1	55	0.26	0.68	484.26		324	249	252	52	62	58	3.5	8.0			
2	60	0.37	0.96	486.97		328	250	254	52	63	58	4.5	8.3			
Total																
Average		<u>0.6092</u>	<u>0.9700</u>	<u>481.255</u>		<u>326.160</u>			<u>50.8018</u>							

Sum of square roots.

11.56

Circle correct bracketed units on data sheet.

7932

1395



G-49

TEST LOCATION:

FR Outlet

Partinville Mills TESTING FIELD DATA SHEET

METHOD: 5/29

PAGE 2 OF 2

UNIT: 3

RUN: 2

Client: Whirlgator Project No: 12214 Plant: S. Broadway Date: 3/22/13 Meter Operator: P. Bikus Probe Operator: P. Bikus

Meter Box Sample Box No. Meter Yr Meter Alt K-Factor Pitot C Leak Rate Before [cfm] [Lpm] @ (in. Hg) Leak Rate After [cfm] [Lpm] @ (in. Hg) Pitot Leak Check Before: [ ] After: Good [ ] Bad [ ]

Cross-Section of Test Location [N] [UP] Duct Dimensions (in.) Static Pres (in. Hg) Port Len. (in.) Gas Flow [In] [Out] First point all the way of page [In] [Out] Start Time Stop Time

Amb Temp (°F) Bar. Press. [in. Hg] [mbar] Probe I.D. No. Liner Material

Filter No. Thimble No. Nozzle Diameter Nozzle I.D.

Start Time Stop Time

Table with columns: Traverse Point Number, Min/Elapsed, Velocity Head, Orifice Setting, Gas Sample Volume, Stack Temp, Probe Temp, Filter Temp, Cond Temp, DGM Inlet, DGM Outlet, Pump Vacuum, Oxygen Indicator, Notes. Includes handwritten data and circled values like -0.09 and -0.025.

Sum of square roots.

Circle correct bracketed units on data sheet.




TEST LOCATION: FF Outlet  
 UNIT: 3 RUN: 3

Parkin Lake/ Metals TESTING  
 FIELD DATA SHEET

METHOD: 5129 PAGE 1 OF 2

Client: Whisper Laboratory Project No.: 12218  
 Plant: S. Broward Date: 3/27/13  
 Meter Operator: P. Bibian  
 Probe Operator: P. Bibian

Meter Box: 46-4 Sample Box No.: M9  
 Meter Yd: 0.9574 Meter AH: 1.5250  
 K Factor: 2.60 Pto. Co.: 0.824  
 Leak Rate Before: 0.026 (Cfm) [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 0.026 (Cfm) [Lpm] @ 10 (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad



Amb Temp (°F): 62 Bar. Press: 30.10 (in. Hg) [mbar]  
 Probe I.D. No.: 67-5-17  
 Liner Material: Glass

Filter No.: 254-33  
 Shim No.: N/A  
 Nozzle Diameter: 0.2725 Nozzle I.D.: 7725-1

Start Time: 9:59 Stop Time: 12:11

Traverse Point Number	Min/pulse Elapsed Time	Velocity Head (in. H <sub>2</sub> O)	Orifice Setting (in. H <sub>2</sub> O)	Gas Sample Volume (L)	Stack Temp (°F)	Probe Temp (°F)		Cond. Temp (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dy)	Amb Filter	Dioxin Trap	Notes
						Set Points	Set Points								
5-1	5	0.33	0.86	525.74	330	245	247	65	66	66	4.5	8.5			
2	10	0.33	0.86	528.34	332	260	254	54	71	67	4.0	8.6			
3	15	0.35	0.91	530.98	331	256	255	53	75	68	4.0	8.7			
4	20	0.36	0.94	533.73	332	257	252	53	77	70	4.0	9.1			
5	25	0.32	0.83	536.260	330	249	251	53	78	71	4.0	9.1			536.335
4-1	30	0.41	1.1	539.23	331	249	248	54	77	73	4.5	9.1			-0.075
2	35	0.48	1.3	542.57	333	250	254	53	80	74	5.5	8.9			
3	40	0.34	0.88	545.14	334	251	252	55	83	76	4.0	8.3			
4	45	0.38	0.91	547.81	337	250	247	57	82	77	4.0	8.7			550.542
5	50	0.35	0.91	550.485	326	250	249	58	81	77	4.0	9.3			-0.055
3-1	55	0.47	1.2	553.64	329	248	250	58	80	78	5.0	9.5			
2	60	0.47	1.2	556.73	333	250	250	58	83	78	5.0	8.4			
Total:									387						
Average:															

Sum of square roots: 11.9

Circle correct bracketed units on data sheet: 3978

1808



QA/QC: PJB  
 Date: 3/27/13

G-51

TEST LOCATION: FF outlet  
 UNIT: 3 RUN: 3

Particulate/Metals TESTING  
**FIELD DATA SHEET**

METHOD: 5129 PAGE 2 OF 2

Client: <u>Wheatlaker</u>	Project No.: <u>12214</u>
Plant: <u>S. Brewer</u>	Date: <u>3/27/13</u>
Meter Operator: <u>P. Bihan</u>	
Probe Operator: <u>P. Bihan</u>	

Cross-Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in.):

Static Pres (in. H <sub>2</sub> O)	Port Len (in.)	Gas Flow (In) (Out)	First point all the way (In) (Out)

of page.

Amb. Temp (°F)	Bar. Press. (in. Hg) [mbar]
Probe ID No.	
Liner Material	

Meter Box	Sample Box No.
Meter Yr	Meter ΔH <sub>0</sub>
K Factor	Pitot C <sub>p</sub>
Leak Rate Before (cfm) [Lpm] @ (in. Hg)	
Leak Rate After (cfm) [Lpm] @ (in. Hg)	
Pitot Leak Check Before: <input type="checkbox"/> After: Good <input type="checkbox"/> Bad <input type="checkbox"/>	

Filter No.	
Thimble No.	
Nozzle Diameter	Nozzle I.D.

Start Time:	Stop Time:
-------------	------------

Traverse Point Number	Mjn/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume Init. Vol. (ft <sup>3</sup> ) [L]	Stack Temp Ts (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb. Filter Dioxin Trap	Notes
						Set Points								
3	65	0.44	1.1	579.85	332	243	251	58	84	79	4.5	8.6		
4	70	0.40	1.0	562.68	332	248	253	59	81	79	4.5	9.2		
5	75	0.38	0.99	570.45	331	250	253	59	81	79	4.5	9.1		565.530
27	80	0.46	1.2	568.65	332	249	248	59	80	79	5.0	9.0		(-0.045)
2	85	0.48	1.3	571.88	331	250	249	59	82	79	5.5	9.3		
3	90	0.50	1.3	575.12	333	251	251	59	82	79	5.5	8.7		
4	95	0.38	0.99	577.95	333	251	252	59	84	79	4.5	9.1		
5	100	0.37	0.96	580.69	335	250	248	60	82	79	4.5	8.8		570.740
1-1	105	0.34	0.88	583.37	314	250	246	60	82	79	4.5	9.3		(-0.045)
2	110	0.28	0.73	585.73	317	250	251	61	81	79	4.0	9.3		
3	115	0.42	1.1	588.28	326	250	254	61	81	79	5.0	8.9		
4	120	0.40	1.0	591.66	327	250	253	62	82	78	4.5	8.6		
5	125	0.40	1.0	594.44	327	251	251	62	82	78	4.5	8.4		
Total											1024			
Average														

Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC CB  
 Date 3/27/13

G-52

# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 3 FF Outlet	
Plant South Broward	Job No. 12218	Method	5/29

Balance Calibration Check			
Balance ID	TL07-4 802 8301068	Reference Weight Mass	500.0g
Reference Weight ID	60150	Reference Weight Reading	499.3g

Check must be performed at least Once per Method per Job

Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No. 1	1	Filter Type Quartz	Sample Box No. M9
Date 3-26-13		Lot No.	pH NA
Analyst HN		Filter No. e54-36	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	684.4	457.4	227.0	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	645.4	556.0	89.4	QA/QC SB Date 3/26
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	565.7	545.1	20.6	
Impinger 4	Empty	440.1	437.0	3.1	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	549.5	547.7	1.8	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	541.2	541.5	-0.3	341.6
Impinger 7	≈ 250 g Silica Gel	760.4	749.5	10.9	352.5

Run No. 2	2	Filter Type Quartz	Sample Box No. M3
Date 3-27-13		Lot No.	pH NA
Analyst HN / DL		Filter No. e54-34	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	649.8	465.1	184.7	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	655.2	545.4	109.8	QA/QC SB Date 3/27
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	582.5	550.1	32.4	
Impinger 4	Empty	431.5	424.5	7.0	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	646.5	643.6	2.9	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	544.5	544.4	0.1	SB 336.6 336.9
Impinger 7	≈ 250 g Silica Gel	774.8	760.0	14.8	4/19 351.4 351.7

Run No. 3	3	Filter Type Quartz	Sample Box No. M9
Date 3-27-13		Lot No.	pH NA
Analyst HN		Filter No. e54-33	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	626.4	457.2	169.2	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	661.7	556.5	105.2	QA/QC SB Date 3/27
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	575.5	545.6	29.9	
Impinger 4	Empty	444.6	436.9	7.7	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	550.3	546.7	3.6	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	538.8	538.8	0.0	SB 345.6 345.6
Impinger 7	≈ 250 g Silica Gel	766.5	750.4	16.1	4/19 361.7 361.7

QA/QC SB  
Date 3/27



TEST LOCATION: FF Outlet

UNIT: 3

RUN: 4

# Metals TESTING FIELD DATA SHEET

METHOD: 79

PAGE 1 OF 2

Client	<u>Wheabrator</u>	Project No.	<u>12218</u>
Plant	<u>S. Broward</u>	Date	<u>3/12/13</u>
Meter Operator	<u>P. Bihun</u>		
Probe Operator	<u>P. Bihun</u>		

Meter Box	<u>66-6</u>	Sample Box No.	<u>M3</u>
Meter Id.	<u>0.9854</u>	Meter ΔH.	<u>1.8280</u>
K Factor	<u>270</u>	Pitot C.	<u>0.824</u>
Leak Rate Before	<u>0.004</u> (Lpm)	@	<u>11</u> (in. Hg)
Leak Rate After	<u>0.003</u> (Lpm)	@	<u>12</u> (in. Hg)
Pitot Leak Check Before	<input checked="" type="checkbox"/>	After	Good <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Cross-Section of Test Location

Duct Dimensions (in.) 96x96

Static Pres (in. H <sub>2</sub> O)	Port Len (in.)	Gas Flow (in. Out)	First point all the way
<u>-10.7</u>	<u>10.0</u>	<u>2</u> top page	<input checked="" type="checkbox"/> [Out]

Amb. Temp. (°F)	<u>68</u>	Bar. Press.	<u>30.10</u> (in. Hg) (mbar)
Probe I.D. No.	<u>67-8-17</u>		
Liner Material	<u>Glass</u>		

Filter No.	<u>N/A</u>		
Thimble No.	<u>N/A</u>		
Nozzle Diameter	<u>0.2725</u>	Nozzle I.D.	<u>2725-1</u>

Start Time	<u>12:29</u>	Stop Time	<u>14:41</u>
------------	--------------	-----------	--------------

Traverse Point Number	Min/pt Elapsed Time	Velocity Head AP (in. H <sub>2</sub> O)	Orifice Setting AH (in. H <sub>2</sub> O)	Gas Sample Volume Init Vol. (in. L)	Stack Temp Ts (°F)	Probe T (°F)	Filter T (°F)	Cond. Temp (°F)	DGM Inlet T (°F)	DGM Outlet T (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb. Filter	Dioxin Trap	Notes	
						Set Points										
5-1	5	0.33	0.89	594.720	328	248	256	62	74	76	4.0	9.1				
2	10	0.33	0.89	600.01	327	257	255	59	76	76	4.0	9.2				
3	15	0.34	0.92	602.72	328	256	257	56	79	75	4.0	8.7				
4	20	0.35	0.95	605.46	327	250	252	55	80	75	4.0	9.4				
5	25	0.34	0.92	608.140	326	250	249	55	80	75	4.0	9.5			<u>608.210</u> <u>-0.07</u>	
4-1	30	0.37	1.0	610.89	326	249	248	56	79	75	4.0	8.9				
2	35	0.35	0.95	613.73	327	250	254	56	80	75	4.0	9.0				
3	40	0.35	0.95	616.46	327	251	253	56	81	75	4.0	9.1				
4	45	0.36	0.97	619.22	326	251	251	56	81	76	4.0	9.1				
5	50	0.36	0.97	621.970	325	250	252	57	82	76	4.0	9.4			<u>622.015</u> <u>-0.045</u>	
3-1	55	0.37	1.0	624.84	325	249	252	58	80	76	4.0	9.4				
2	60	0.45	1.2	627.96	326	249	254	60	80	76	5.0	9.6				
Total				<u>75.305</u>												
Average				<u>10.6446</u>	<u>1.132</u>	<u>324.040</u>			<u>58.1806</u>							

Sum of square roots.

11.41

Circle correct bracketed units on data sheet.

3918

QA/QC PB  
Date 3/12/13





TEST LOCATION: PF Outlet  
 UNIT: 3 RUN: 4

Metals TESTING  
**FIELD DATA SHEET**

METHOD: 29 PAGE 2 OF 2

Client: Wheelabrator Project No.: 12218  
 Plant: S. Broward Date: 3/22/13  
 Meter Operator: P. Bihun  
 Probe Operator: P. Bihun

Cross Section of Test Location

↑  
[N] [UP]

Duct Dimensions (in):

Static Pres (in. H <sub>2</sub> O)	Port Len. (in.)	Gas Flow (In) [Out]	First point all the way [In] [Out]
------------------------------------	-----------------	---------------------	------------------------------------

Amb. Temp. (°F) Bar Press. (in. Hg) [mbar]  
 Probe ID No.  
 Liner Material

Meter Box Sample Box No.  
 Meter Yd Meter ΔH  
 K Factor Pitot C<sub>p</sub>  
 Leak Rate Before (cfm) [Lpm] @ (in. Hg)  
 Leak Rate After (cfm) [Lpm] @ (in. Hg)  
 Pitot Leak Check Before:  After:  Good  Bad

Filter No.  
 Thimble No.  
 Nozzle Diameter Nozzle ID

Start Time: Stop Time:

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume		Stack Temp. (°F)	Probe Temp. (°F)		Cond. Temp. (°F)	DGM Inlet T <sub>min</sub> (°F)	DGM Outlet T <sub>min</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb. Filter Dioxin Trap	Notes
				Init. Vol	(ft <sup>3</sup> ) [L]		Set Points	Set Points							
7	65	0.50	1.4	631.31	324	250	253	62	82	76	5.5	9.3	N/A		
4	70	0.43	1.2	634.52	325	250	254	62	82	75	5.0	9.6			
5	75	0.39	1.1	637.57	323	249	250	64	82	71	4.5	9.0			
2-1	80	0.57	1.5	641.10	323	248	257	65	79	75	5.5	9.2		637.57 -0.035	
2	85	0.52	1.4	644.48	324	250	253	60	82	71	5.5	8.8			
3	90	0.46	1.2	647.61	324	252	250	53	83	76	5.0	9.1			
4	95	0.42	1.1	650.58	325	250	248	52	83	76	4.5	9.4		653.87 -0.045	
5	100	0.47	1.3	653.85	324	250	252	51	83	76	5.5	9.3			
1-1	105	0.38	1.0	656.73	301	251	251	53	80	76	4.5	9.6			
2	110	0.45	1.2	659.90	325	250	253	54	81	76	5.0	9.0			
3	115	0.60	1.6	663.56	320	250	256	54	82	76	6.0	9.1			
4	120	0.48	1.3	666.83	322	251	248	54	84	76	5.5	9.5			
5	125	0.50	1.4	670.22	321	250	249	54	84	76	5.5	8.6			
Total															
Average															

\* Sum of square roots. Circle correct bracketed units on data sheet.



G-55

# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 3 FF Outlet	
Plant South Broward	Job No. 12218	Method	29

Balance Calibration Check			
Balance ID	TL07-4 802301068	Reference Weight Mass	500.0g
Reference Weight ID	60150	Reference Weight Reading	499.3g

Check must be performed at least Once per Method per Job Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No.	4	Filter Type Quartz	Sample Box No.
Date	3/27/13	Lot No.	pH NA
Analyst	DL	Filter No.	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty	707.2	465.7	241.5	
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	644.4	559.9	84.5	QA/QC 5B Date 4/19/13
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	566.4	551.6	14.8	
Impinger 4	Empty	437.9	434.9	3.0	
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	653.9	654.4	-0.5	Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	536.5	537.8	-1.3	342.0
Impinger 7	≈ 250 g Silica Gel	722.6	708.4	14.2	356.2

Run No.	5	Filter Type Quartz	Sample Box No.
Date		Lot No.	pH NA
Analyst		Filter No.	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty				
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>				QA/QC Date
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>				
Impinger 4	Empty				
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>				Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>				
Impinger 7	≈ 250 g Silica Gel				

Run No.	6	Filter Type Quartz	Sample Box No.
Date		Lot No.	pH NA
Analyst		Filter No.	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	Empty				
Impinger 2	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>				QA/QC Date
Impinger 3	100 ml 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>				
Impinger 4	Empty				
Impinger 5	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>				Total Weight (gm)
Impinger 6	100 ml 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>				
Impinger 7	≈ 250 g Silica Gel				

QA/QC 5B  
Date 4/19/13






TEST LOCATION: INLET HCL TESTING METHOD: 26A PAGE 1 OF 1  
 UNIT: 3 RUN: 1 FIELD DATA SHEET

Client WHEELABRATOR Project No. 12218  
 Plant S. BROWARDS Date 3-26-13  
 Meter Operator SJ  
 Probe Operator SJ

Meter Box 61-11 Sample Box No. B-14  
 Meter 1.0050 Meter  $\Delta H$  1.8164  
 K Factor NA Pitot C. 0.934

Leak Rate Before 0.03 [cfm] [Lpm] @ 15 (in. Hg)  
 Leak Rate After 0.03 [cfm] [Lpm] @ 18 (in. Hg)  
 Pitot Leak Check Before:  After: Good  Bad



Amb Temp (°F) 64 Bar. Press. 29.90 (in. Hg) [mbar]  
 Probe I.D. No. 66-4-7  
 Liner Material GLASS

Filter No. NA  
 Thimble No. NA  
 Nozzle Diameter NA Nozzle I.D. NA

Start Time: 9:00 Stop Time: 9:00

Traverse Point Number	Min/pt 5 Elapsed Time	Velocity Head $\Delta P$ (in. H <sub>2</sub> O)	Orifice Setting $\Delta H$ (in. H <sub>2</sub> O)	Gas Sample Volume $V_m$		Stack Temp $T_s$ (°F)	Probe Temp (°F)		Cond. Temp. $T_c$ (°F)	DGM Inlet $T_{in}$ (°F)	DGM Outlet $T_{out}$ (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (%dv)	Notes
				Init. Vol.	[ft <sup>3</sup> ] [L]		355	355						
P1-1	5	NA	1.20	692.200		480	355	355	47	70	70	4	8.8	NA
	10			695.25		481	352	356	47	72	70	4	8.7	
	15			691.30		480	354	355	49	74	70	5	8.6	
	20			701.25		481	355	354	52	74	70	6	8.5	
	25			704.11		482	354	352	54	75	70	8	8.8	
	30			701.02		484	355	355	59	75	70	10	9.0	
	35			709.92		484	354	358	60	75	71	11	8.6	
	40			712.71		482	355	355	54	75	71	12	8.8	
	45			715.66		481	354	356	54	75	71	13	8.7	
	50			708.60		481	355	356	55	75	71	14	8.5	
	55			721.54		484	354	355	56	76	72	15	8.6	
	60			704.88		484	355	354	56	77	72	15	8.7	
				727.64		484	356	354						
	Total			75.440		5.893				843	848			
	Average			1.2000		481.9167				72.5417				

\*Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC 8/1  
 Date 3-26-13



TEST LOCATION: Inlet

HCL

TESTING

METHOD: J6A


PAGE 1 OF 1

UNIT: 3

RUN: 3

### FIELD DATA SHEET

Client	WHEELABRATOR	Project No.	12218
Plant	S. Blowers	Date	3-26-13
Meter Operator	SJ		
Probe Operator	SJ		



Amb. Temp. (°F)	75	Bar. Press.	29.90	(in. Hg) [mbar]
Probe I.D. No.	66-4-7			
Liner Material	GLASS			

Meter Box	GF11	Sample Box No.	
Meter Yr	1.0090	Meter ΔH <sub>0</sub>	16964
K Factor	NA	Pitot C <sub>p</sub>	0.734
Leak Rate Before	0.03 (Lpm)	@	5 (in. Hg)
Leak Rate After	0.00 (Lpm)	@	6 (in. Hg)
Pitot Leak Check Before	<input checked="" type="checkbox"/>	After: Good	<input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Filter No.	NA		
Thimble No.	NA		
Nozzle Diameter	NA	Nozzle I.D.	NA

Start Time	10:46	Stop Time	11:46
------------	-------	-----------	-------

Traverse Point Number	Min/Sec Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>m</sub> (L)	Stack Temp (°F)	Filter T <sub>p</sub> (°F)		Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m in</sub> (°F)	DGM Outlet T <sub>m out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (% dV)	Amb. Filter <input type="checkbox"/>	Dioxin Trap <input type="checkbox"/>	Notes
						Set Points	Set Points								
11-1	5	NA	h <sub>2</sub> o	765.500	478	355	355	48	89	85	4	8.8			NA
	10			768.58	478	356	352	48	89	85	5	8.7			
	15			771.66	480	354	355	48	89	85	5	8.6			
	20			774.75	480	356	356	49	88	84	6	9.0			
	25			777.72	480	355	355	50	88	84	7	8.9			
	30			780.69	479	354	355	52	87	84	8	8.8			
	35			783.66	479	355	354	54	87	84	9	8.7			
	40			786.64	479	356	355	54	87	84	10	8.6			
	45			789.63	478	355	356	55	87	84	11	8.5			
	50			792.62	478	356	355	56	87	84	12	8.4			
	55			795.61	478	356	356	58	87	84	13	8.5			
	60			798.60	480	355	355	59	87	84	14	8.6			
				801.66	480	355	355	59	87	84	14	8.6			
	Total			36.160	5947				652	1011					
	Average			1.2000	478.9167				85.9583						

Sum of square roots.

Circle correct bracketed units on data sheet.



QA/QC SA  
Date 3-26-13

# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 3 SDA Inlet	
Plant South Broward	Job No. 12218	Method Modified 26A	

Balance Calibration Check			
Balance ID	TL07-4 8028301135	Reference Weight Mass	500.0g
Reference Weight ID	60150	Reference Weight Reading	499.3g
Check must be performed at least Once per Method per Job		Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.	

Run No. 1	Filter Type Quartz	Sample Box No. B14
Date 3-26-13	Lot No.	pH NA
Analyst HN	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	471.1	454.0	17.1	QA/QC 59 Date 3/26
Impinger 2	100 mL 0.1N H2SO4	600.7	529.5	71.2	
Impinger 3	100 mL 0.1N H2SO4	565.2	540.5	24.7	
Impinger 4	Empty	429.9	422.0	7.9	
Impinger 5	Silica Gel	718.8	706.1	12.7	Total Weight (gm)
Impinger 6					120.9
Impinger 7					133.6

Run No. 2	Filter Type Quartz	Sample Box No. B6
Date 3-26-13	Lot No.	pH NA
Analyst HN	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	498.0	457.1	41.7	QA/QC 58 Date 3/26
Impinger 2	100 mL 0.1N H2SO4	630.4	552.8	77.6	
Impinger 3	100 mL 0.1N H2SO4	548.9	535.2	13.7	
Impinger 4	Empty	485.0	482.7	2.3	
Impinger 5	Silica Gel	717.2	707.6	9.6	Total Weight (gm)
Impinger 6					135.3
Impinger 7					144.9

Run No. 3	Filter Type Quartz	Sample Box No. B14
Date 3-26-13	Lot No.	pH NA
Analyst DL	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	524.6	461.2	63.4	QA/QC 5A Date 3/26
Impinger 2	100 mL 0.1N H2SO4	601.7	545.8	55.9	
Impinger 3	100 mL 0.1N H2SO4	570.3	560.2	10.1	
Impinger 4	Empty	423.3	421.2	2.1	
Impinger 5	Silica Gel	731.3	720.1	11.2	Total Weight (gm)
Impinger 6					131.5
Impinger 7					142.7

QA/QC 5b  
Date 3/26



TEST LOCATION: FF OUTLET HCL TESTING METHOD: 26A PAGE 1 OF 1  
 UNIT: 3 RUN: 1 FIELD DATA SHEET

Client: WHEELABRATOR Project No: 12218  
 Plant: SOUTH BROADWAY Date: 3/26/13  
 Meter Operator: WAYNE BONEY  
 Probe Operator:                     

Meter Box: 6-18 Sample Box No: 8-24  
 Meter Yr: 1.0008 Meter Wt: 1.9165  
 K Factor:                      Pitot Cp:                       
 Leak Rate Before: 0.003 [cfm] [Lpm] @ 15 (in. Hg)  
 Leak Rate After: 0.001 [cfm] [Lpm] @ 16 (in. Hg)  
 Pitot Leak Check Before:  After:

Cross-Section of Test Location

Duct Dimensions (in.): 96 x 96

Static Pres. (in. H<sub>2</sub>O): -9.9 Port Len. (in.): 10 Gas Flow (in) [Out] of page:                      First point all the way (in) [Out]:                     

Amb Temp (°F): 55 Bar Press: 29.90 (in. Hg) [mbar]  
 Probe I.D. No: 67-4-3  
 Liner Material: GLASS

Filter No:                       
 Humble No:                       
 Nozzle Diameter:                      Nozzle I.D.:                     

Start Time: 0800 Stop Time: 0900

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume V <sub>s</sub> Init. Vol. (L)	Stack Temp. T <sub>s</sub> (°F)	Probe Temp. (°F)	Filter Temp. (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>in</sub> (°F)	DGM Outlet T <sub>out</sub> (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (% dv)	Amb Filter <input type="checkbox"/>	Notes
31	5	N/A	1.5	246.660	296	281	305	59	64	63	6	9.5		
	10		1.5	252.06	296	283	304	57	66	64	6	9.5		
	15		1.5	256.24	295	282	298	57	70	63	6	9.4		
	20		1.5	259.43	296	281	300	57	72	63	6	8.9		
	25		1.5	262.65	295	281	300	56	73	63	6	9.4		
	30		1.5	265.88	296	283	301	61	74	64	6	8.7		
	35		1.5	269.13	294	282	300	62	73	64	6	9.2		
	40		1.5	272.40	297	282	300	63	74	64	6	9.5		
	45		1.5	275.62	290	279	299	63	74	65	6	9.4		
	50		1.5	278.85	293	277	300	63	73	65	6	9.6		
	55		1.5	282.19	294	272	300	62	74	65	6	9.6		
	60		1.5	285.36	293	276	300	60	75	66	6.5	9.5		
	Total			38,700.0	3535.0				862.0	769.0				
	Average		(1.5)		(294.583)				(67.953)					

Sum of square roots.

Circle correct bracketed units on data sheet.



TEST LOCATION: FF OUTLET  
 UNIT: 3 RUN: 2

HCL TESTING  
 FIELD DATA SHEET

METHOD: 26A PAGE 1 OF 1

Client <u>WHEELABRATOR</u>	Project No. <u>12218</u>
Plant <u>SOUTH BROWNS</u>	Date <u>3/26/13</u>
Meter Operator <u>WAYNE BENNY</u>	
Probe Operator <u>—</u>	

Meter Box <u>16-18</u>	Sample Box No. <u>—</u>
Meter Yr <u>1.0008</u>	Meter ΔH @ <u>1.9165</u>
K-Factor <u>—</u>	Pitot Cp <u>—</u>

Leak Rate Before <u>0.004</u> [Lpm] @ <u>15</u> (in. Hg)
Leak Rate After <u>0.002</u> [Lpm] @ <u>10</u> (in. Hg)
Pitot Leak Check Before <input type="checkbox"/> After <input checked="" type="checkbox"/> Bad <input type="checkbox"/>

Cross Section of Test Location

Duct Dimensions (in.) 96x96

Static Pres (in. H <sub>2</sub> O) <u>-10.1</u>	Port Len (in.) <u>10</u>	Gas Flow (In [Out] of page) <u>In [Out]</u>	First point all the way <u>In [Out]</u>
---	--------------------------	---	---

Amb Temp (°F) <u>55</u>	Bar. Press <u>29.90</u> (in. Hg) [mbar]
Probe I.D. No. <u>67-4-3</u>	
Liner Material <u>GLASS</u>	

Filter No. <u>—</u>	
Thimble No. <u>—</u>	
Nozzle Diameter <u>—</u>	Nozzle I.D. <u>—</u>

Start Time <u>0921</u>	Stop Time <u>1021</u>
------------------------	-----------------------

Inverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume Init. Vol. (L)	Stack Temp. Ts (°F)	Probe T. (°F)	Filter T. (°F)	Cond. Temp. Tc (°F)	DGM Inlet T. (°F)	DGM Outlet T. (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx. (% dV)	Amb Filter <input type="checkbox"/>	Dioxin Trap <input type="checkbox"/>	Notes
						Set Points									
3-1	5	N/A	1.5	285.740	298	296	300	55	69	66	5.5	9.6			
	10		1.5	292.15	300	299	304	53	71	66	5.5	9.6			
	15		1.5	295.37	296	300	301	51	74	66	6	9.8			
	20		1.5	298.58	299	299	299	52	75	67	6	9.2			
	25		1.5	301.80	296	298	300	58	75	67	6	9.5			
	30		1.5	305.09	298	295	300	59	76	68	6.5	9.0			
	35		1.5	308.35	295	295	301	62	77	68	6.5	9.2			
	40		1.5	311.59	296	300	300	64	77	68	6.5	8.0			
	45		1.5	314.82	297	299	299	64	77	69	6.5	9.4			
	50		1.5	318.04	293	300	301	61	78	69	8.5	9.1			
	55		1.5	321.29	295	299	300	61	79	70	6.5	8.9			
	60		1.5	324.535	295	299	300	61	80	70	7.0	9.9			
	Total			38.7950	3558.0				908.0	814.0					
	Average		<u>1.5</u>		<u>296.500</u>				<u>71.7500</u>						

Sum of square roots.


Circle correct bracketed units on data sheet.



TEST LOCATION: PP OUTLET ACL TESTING  
 UNIT: 3 RUN: 3  
**Cross-Section of Test Location**  
**FIELD DATA SHEET**

METHOD: 26A PAGE 1 OF 1

Client: WFOCLAB Project No: 12718  
 Plant: SOUTH BROWNS Date: 3/26/13  
 Meter Operator: WAYNE BERRY  
 Probe Operator: —



Amb. Temp. (°F) 56 Bar. Press. 29.90 (in. Hg) [mbar]  
 Probe ID No: 67-4-3  
 Liner Material: GLASS

Meter Box: 66-18 Sample Box No: B-24  
 Meter Yr: 1.0008 Meter ΔH: 1.9165  
 K Factor: — Pitot Co: —

Duct Dimensions (in.): 96 x 96

Filter No: —  
 Thimble No: —  
 Nozzle Diameter: — Nozzle ID: —

Leak Rate Before: 0.005 [cfm] [Lpm] @ 10 (in. Hg)  
 Leak Rate After: 0.002 [cfm] [Lpm] @ 10 (in. Hg)  
 Pilot Leak Check Before:  After:  Good / Lead

Static Pres. H (in. H<sub>2</sub>O): -9.1  
 Port Len. (in.): 10  
 Gas Flow: 10 [Out]  
 First point all the way of page: 10 [Out]

Start Time: 1046 Stop Time: 1146

Traverse Point Number	Min/pt Elapsed Time	Velocity Head ΔP (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Gas Sample Volume Int. Vol. (L)	Stack Temp. Ts (°F)	Probe Temp. (°F)		Cond. Temp. (°F)	DGM Inlet Tm in (°F)	DGM Outlet Tm out (°F)	Pump Vacuum (in. Hg)	Oxygen Indicator approx (%dv)	Amb Filter	Dioxin Trap	Notes
						Set	Points								
3-1	5	N/A	1.5	328.48	300	297	304	55	76	72	6	9.8			
	10		1.5	331.72	292	298	301	53	78	73	6	9.8			
	15		1.5	334.92	293	302	300	51	81	73	6	9.2			
	20		1.5	338.16	294	300	301	51	83	74	6	9.0			
	25		1.5	341.39	292	298	300	53	83	74	6.5	8.4			
	30		1.5	344.64	292	299	301	58	83	75	6.5	9.8			
	35		1.5	347.91	292	299	301	57	84	76	6.5	9.2			
	40		1.5	351.17	293	299	301	61	84	76	6.5	9.5			
	45		1.5	354.42	292	302	300	62	85	77	6.5	9.7			
	50		1.5	357.78	294	300	299	63	87	78	6.5	9.7			
	55		1.5	360.95	297	300	300	63	88	79	6.5	8.5			
	60		1.5	364.210	290	298	300	63	87	80	6.5	9.7			
	Total			38.9900	352.0				999.0	907.0					
	Average			(1.5)	(293.4167)				(79.4167)						

\* Sum of Square roots.

Circle correct bracketed units on data sheet.



QA/QC WB  
 Date 3/26/13

G-63



# Impinger Weight Sheet

Client Wheelabrator		Unit Name / Location Unit 3 FF Outlet	
Plant South Broward	Job No. 12218	Method Modified M26A	

Balance Calibration Check			
Balance ID	TL 07-4 8028301068	Reference Weight Mass	500.0g
Reference Weight ID	60150	Reference Weight Reading	499.3g

Check must be performed at least Once per Method per Job      Reference Weight Mass must agree with Reference Weight Reading to within ±0.5 g.

Run No. 1	1 Filter Type Teflon Mat	Sample Box No. B24
Date 3-26-13	Lot No.	pH
Analyst DL	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	484.1	449.5	34.6	QA/QC JB Date 3/26
Impinger 2	100 mL 0.1N H2SO4	666.4	565.7	100.7	
Impinger 3	100 mL 0.1N H2SO4	584.7	542.7	42.0	
Impinger 4	Empty	451.1	441.7	9.4	
Impinger 5	Silica Gel	737.0	724.1	12.9	Total Weight (gm)
Impinger 6					186.7
Impinger 7					199.6

Run No. 2	2 Filter Type Teflon Mat	Sample Box No. B1
Date 3-26-13	Lot No.	pH
Analyst DL	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	478.1	446.5	31.6	QA/QC JB Date 3/26
Impinger 2	100 mL 0.1N H2SO4	639.0	534.6	104.4	
Impinger 3	100 mL 0.1N H2SO4	566.8	519.8	47.0	
Impinger 4	Empty	481.0	466.3	14.7	
Impinger 5	Silica Gel	689.5	671.1	17.4	Total Weight (gm)
Impinger 6					197.7
Impinger 7					215.1

Run No. 3	3 Filter Type Teflon Mat	Sample Box No. B24
Date 3-26-13	Lot No.	pH
Analyst HN	Filter No. NA	Rinse NA

	Contents	Gross Weight (gm)	Tare Weight (gm)	Net Weight Gain (gm)	
Impinger 1	50 mL 0.1N H2SO4	474.5	440.8	33.7	QA/QC JB Date 3/26
Impinger 2	100 mL 0.1N H2SO4	662.8	557.1	105.7	
Impinger 3	100 mL 0.1N H2SO4	576.8	529.0	37.8	
Impinger 4	Empty	451.1	441.4	9.7	
Impinger 5	Silica Gel	717.1	701.4	15.7	Total Weight (gm)
Impinger 6					186.9
Impinger 7					202.6

QA/QC JB  
Date 3/26






# EPA METHOD 22 Fugitive or Smoke Emission Inspection Outdoor Location

Job No.	12218	Date	3/27/17
Client	wheelabrator	Observer	P. Luckhard
Plant	South Broward	Affiliation	Clean Air Engineering

Industry	Municipal	Process Unit	Ash unloading
----------	-----------	--------------	---------------

Precipitation	0	Wind Direction	N
Sky Conditions	clear	Wind Speed	0-5 MPH

Sketch process unit: Indicate observer position relative to source and sun. Indicate potential emission points and/or actual emission points.



## OBSERVATIONS

Comments	Clock Time	Observation Period Duration (min : sec)	Accumulated Emission Duration (min : sec)
Doors 1, 2 and 4 closed at start 3 closed at 8:01, 2 opened at 8:08	Start 7:55	20:00	00:12.74
	Stop 8:15	<del>00:12.74</del> <sup>PL</sup> <sub>3/27/17</sub>	
all doors closed at start Door 3 opened at 8:23 and closed at 8:26 and opened at 8:32	Start 8:20	20:00	00:00
	Stop 8:40		
all doors closed for full 20 minutes	Start 8:45	20:00	00:00
	Stop 9:05		
	Start		
	Stop		
	Start		
	Stop		
	Start		
	Stop		


Note: Rest breaks must be taken every 15 to 20 minutes for 5 to 10 minutes.



# EPA METHOD 22 Fugitive or Smoke Emission Inspection Outdoor Location

Job No.	12218	Date	3/27/13
Client	Wheelabrator	Observer	D. Luckhard
Plant	South Browns	Affiliation	Clean Air Engineering
Industry	municipal	Process Unit	Ash conveyor/Daghouse enclosure
Precipitation	0	Wind Direction	N
Sky Conditions	clear	Wind Speed	0-5 MPH

Sketch process unit: Indicate observer position relative to source and sun. Indicate potential emission points and/or actual emission points.



## OBSERVATIONS

Comments	Clock Time	Observation Period Duration (min : sec)	Accumulated Emission Duration (min : sec)
all doors closed	Start 10:20	20:00	00:00
	Stop 10:40		
door 2 opened at 11:03	Start 10:45	20:00	00:00
all doors closed	Stop 11:05		
	Start 11:10	20:00	00:00
Stop 11:30			
	Start		
	Stop		
	Start		
	Stop		
	Start		
	Stop		

Note: Rest breaks must be taken every 15 to 20 minutes for 5 to 10 minutes.


# EPA METHOD 22 Fugitive or Smoke Emission Inspection Outdoor Location

Job No.	12218	Date	3/27/13
Client	wheelabrator	Observer	D. Luckhard
Plant	Browards-South	Affiliation	Clean Air Engineering

Industry	Municipal	Process Unit	Bay house Enclosure
----------	-----------	--------------	---------------------

Precipitation	0	Wind Direction	N
Sky Conditions	clear	Wind Speed	0-5 MPH

Sketch process unit: Indicate observer position relative to source and sun. Indicate potential emission points and/or actual emission points.



## OBSERVATIONS

Comments	Clock Time	Observation Period Duration (min : sec)	Accumulated Emission Duration (min : sec)
all doors closed	Start 12:30	20:00	60:00
	Stop 12:50		
	Start 12:55	20:00	00:00
	Stop 13:15		
	Start 13:20	20:00	00:00
	Stop 13:40		
	Start		
	Stop		
	Start		
	Stop		
	Start		
	Stop		

Note: Rest breaks must be taken every 15 to 20 minutes for 5 to 10 minutes.

# Visible Emissions Observation Form

CLIENT/OWNER		PROJECT NUMBER		OBSERVATION DATE				START TIME		END TIME			
Wheelabrator		12218		3/26/13				8:55		10:40			
PLANT		UNIT	RUN	SEC	15	30	45	60	SEC	15	30	45	60
South Broward Co		Lime Silo	1	0	0	0	0	0	30	0	0	0	0
PROCESS EQUIPMENT		OPERATING MODE		1	0	0	0	0	31	0	0	0	0
Lime Silo		continuous		2	0	0	0	0	32	0	0	0	0
CONTROL EQUIPMENT		OPERATING MODE		3	0	0	0	0	33	0	0	0	0
Dishouse		continuous		4	0	0	0	0	34	0	0	0	0
DESCRIBE EMISSION POINT				5	0	0	0	0	35	0	0	0	0
vent exit				6	0	0	0	0	36	0	0	0	0
				7	0	0	0	0	37	0	0	0	0
				8	0	0	0	0	38	0	0	10	0
HEIGHT ABOVE GROUND LEVEL		DISTANCE FROM OBSERVER		9	0	0	0	0	39	0	0	0	0
75 ft.		300 ft.		10	0	0	0	0	40	0	0	0	0
HEIGHT RELATIVE TO OBSERVER		DIRECTION FROM OBSERVER		11	0	0	0	0	41	0	0	0	0
70 ft.		W		12	0	0	0	0	42	0	0	0	0
DESCRIBE EMISSIONS				13	0	0	0	0	43	0	0	0	0
no plume				14	0	0	0	0	44	0	0	0	0
				15	0	0	0	0	45	0	0	0	0
				16	0	0	0	0	46	0	0	0	0
EMISSION COLOR		PLUME TYPE: CONTINUOUS <input checked="" type="checkbox"/>		17	0	0	0	0	47	0	0	0	0
NA		FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		18	0	0	0	0	48	0	0	0	0
WATER DROPLETS PRESENT		IF WATER DROPLET PLUME		19	0	0	0	0	49	0	0	0	0
YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		ATTACHED <input checked="" type="checkbox"/> DETACHED <input type="checkbox"/>		20	0	0	0	0	50	0	0	0	0
POINT IN PLUME AT WHICH EMISSIONS WERE DETERMINED				21	0	0	0	0	51	0	0	0	0
overcast sky / no plume				22	0	0	0	0	52	0	0	0	0
DESCRIBE BACKGROUND				23	0	0	0	0	53	0	0	0	0
overcast sky / Blue sky				24	0	0	0	0	54	0	0	0	0
1st 40 min rest of + 10 min				25	0	0	0	0	55	0	0	0	0
WIND SPEED		WIND DIRECTION		26	0	0	0	0	56	0	0	0	0
5-10 MPH		N		27	0	0	0	0	57	0	0	0	0
AMBIENT TEMPERATURE		RELATIVE HUMIDITY		28	0	0	0	0	58	0	0	0	0
55°F				29	0	0	0	0	59	0	0	0	0
LAYOUT SKETCH OF SOURCE				RANGE OF OPACITY READINGS									
				INDICATE NORTH									
				MINIMUM		MAXIMUM							
				0		0							
OBSERVER'S NAME (PRINT)				OBSERVER'S SIGNATURE									
Daniel Luckhard													
OBSERVER'S SIGNATURE				DATE									
				3/26/13									
CERTIFIED BY				DATE									
Aeromet				3/2013									
COMMENTS													

FD0029-2718 Rev. August 2008  
Copyright © 2004 Clean Air Engineering, Inc.

QA/QC SB  
Date 3/26



2/2

## Visible Emissions Observation Form

CLIENT/OWNER <i>Wheelabrator</i>		PROJECT NUMBER <i>12219</i>		OBSERVATION DATE <i>3/26/13</i>				START TIME <i>8:55</i>		END TIME <i>10:46</i>			
PLANT <i>South grounds</i>		UNIT <i>Line 5.1.</i>	RUN <i>1</i>	SEC MN	15	30	45	60	SEC MN	15	30	45	60
PROCESS EQUIPMENT		OPERATING MODE		1	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	31	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
CONTROL EQUIPMENT		OPERATING MODE		2	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	32	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
DESCRIBE EMISSION POINT		OPERATING MODE		3	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	33	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
HEIGHT ABOVE GROUND LEVEL		DISTANCE FROM OBSERVER		4	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	34	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
HEIGHT RELATIVE TO OBSERVER		DIRECTION FROM OBSERVER		5	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	35	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
DESCRIBE EMISSIONS		OPERATING MODE		6	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	36	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
EMISSION COLOR		PLUME TYPE: CONTINUOUS <input type="checkbox"/>		7	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	37	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
WATER DROPLETS PRESENT		IF WATER DROPLET PLUME		8	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	38	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
YES <input type="checkbox"/> NO <input type="checkbox"/>		ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>		9	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	39	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
POINT IN PLUME AT WHICH EMISSIONS WERE DETERMINED		OPERATING MODE		10	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	40	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
DESCRIBE BACKGROUND		OPERATING MODE		11	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	41	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
WIND SPEED		WIND DIRECTION		12	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	42	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
AMBIENT TEMPERATURE		RELATIVE HUMIDITY		13	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	43	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
LAYOUT SKETCH OF SOURCE		RANGE OF OPACITY READINGS		14	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	44	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
<p style="font-size: small;">INDICATE NORTH</p> <p style="font-size: small;">Stack with Plume <input type="checkbox"/></p> <p style="font-size: small;">Sun <input checked="" type="checkbox"/></p> <p style="font-size: small;">Wind <input checked="" type="checkbox"/></p>		MINIMUM		15	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	45	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
		MAXIMUM		16	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	46	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
OBSERVER'S NAME (PRINT)		OBSERVER'S SIGNATURE		17	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	47	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
OBSERVER'S SIGNATURE		DATE		18	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	48	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
DATE		CERTIFIED BY		19	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	49	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
DATE		DATE		20	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	50	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
COMMENTS		DATE		21	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	51	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>
		DATE		22	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	52				
		DATE		23	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	53				
		DATE		24	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	54				
		DATE		25	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	55				
		DATE		26	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	56				
		DATE		27	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	57				
		DATE		28	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	58				
		DATE		29	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	59				

**This Page Intentionally Left Blank**

**FIELD DATA PRINTOUTS**

H

*I herby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: MA

Date: 5/6/13



**This Page Intentionally Left Blank**



### Field Data Printout

Location: Unit 1 FF Outlet  
 Test Run: 1  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: S. Joint 473  
 Probe Operator: W. Berry 456  
 Test Date: 3/25/13  
 Start Time: 12:26  
 Stop Time: 14:40  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 16 "Hg

Test Method:  
 Analyte:

USEPA Method 5/29  
 Particulate/Metals

Bar. Press. (in. Hg): 29.70  
 Static P: -8.4  
 O<sub>2</sub> (dry volume %): 8.25  
 CO<sub>2</sub> (dry volume %): 10.93  
 N<sub>2</sub>+CO (dry volume %): 80.82

Nozzle ID No: 0.276-1  
 Nozzle Diameter (D<sub>n</sub>): 0.276  
 Probe ID No: 67-8-21  
 Pitot C<sub>p</sub>: 0.813  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 482.2  
 H<sub>2</sub>O (silica, g): 17.9  
 Actual Moisture (%): 23.43

Meter Box ID. No: 85-2  
 Meter ΔH@: 1.74130  
 Meter Y<sub>a</sub>: 1.00390

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>e</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
1-01	5.0	0.24	0.66	533.300	307	85	84	0.49	2.30	104.1
1-02	10.0	0.22	0.60	537.780	307	86	85	0.47	2.18	102.8
1-03	15.0	0.33	0.90	540.470	305	88	84	0.57	2.69	103.5
1-04	20.0	0.35	0.96	543.310	308	88	84	0.59	2.84	106.3
1-05	25.0	0.54	1.50	546.800	308	89	85	0.73	3.49	105.1
LEAK CHECK	25.0			547.120						
2-01	30.0	0.56	1.50	550.640	321	91	86	0.75	3.52	104.7
2-02	35.0	0.40	1.10	553.780	320	92	86	0.63	3.14	110.2*
2-03	40.0	0.37	1.00	556.700	309	92	87	0.61	2.92	105.7
2-04	45.0	0.47	1.30	560.030	312	92	87	0.69	3.33	107.2
2-05	50.0	0.58	1.60	563.670	310	93	87	0.76	3.64	105.4
LEAK CHECK	50.0			563.890						
3-01	55.0	0.53	1.50	567.380	311	93	87	0.73	3.49	105.7
3-02	60.0	0.40	1.10	570.450	311	93	87	0.63	3.07	106.9
3-03	65.0	0.42	1.20	573.650	311	94	88	0.65	3.20	108.6
3-04	70.0	0.50	1.40	577.080	311	94	88	0.71	3.43	106.7
3-05	75.0	0.52	1.40	580.530	310	94	88	0.72	3.45	105.2
LEAK CHECK	75.0			580.830						
4-01	80.0	0.44	1.20	583.960	309	93	88	0.66	3.13	103.7
4-02	85.0	0.40	1.10	587.240	309	92	88	0.63	3.28	114.1*
4-03	90.0	0.52	1.40	590.510	312	92	88	0.72	3.27	100.0
4-04	95.0	0.56	1.50	594.060	312	93	88	0.75	3.55	104.6
4-05	100.0	0.58	1.60	598.030	310	94	88	0.76	3.97	114.7*
LEAK CHECK	100.0			598.220						
5-01	105.0	0.41	1.10	600.880	311	93	89	0.64	2.66	91.3
5-02	110.0	0.42	1.20	604.070	310	93	89	0.65	3.19	108.2
5-03	115.0	0.44	1.20	607.280	312	92	88	0.66	3.21	106.7
5-04	120.0	0.55	1.50	610.780	322	93	88	0.74	3.50	104.7
5-05	125.0	0.58	1.60	614.420	316	93	88	0.76	3.64	105.7
Final	125.0		1.24480	80.09000	311.36000	89.34000		0.66858	80.09000	

25 points sampled

Sq.Rt.ΔP	0.6686	1.2448	80.0900	311.3600	89.3400
QC-Check: Field Averages	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

D42313 083525  
N

### Field Data Printout

Location: Unit 1 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: P. Bihun 505  
 Probe Operator: P. Bihun 505  
 Test Date: 3/26/13  
 Start Time: 07:51  
 Stop Time: 10:03  
 Leak Rate Before: 0.002 cfm @ 15" Hg  
 Leak Rate After: 0.001 cfm @ 10" Hg

**Test Method:**  
**Analyte:**

**USEPA Method 5/29**  
**Particulate/Metals**

Bar. Press. (in. Hg): 29.90  
 Static P: -7.8  
 O<sub>2</sub> (dry volume %): 8.32  
 CO<sub>2</sub> (dry volume %): 10.73  
 N<sub>2</sub>+CO (dry volume %): 80.95

Nozzle ID No: 0.2725-1  
 Nozzle Diameter (D<sub>n</sub>): 0.273  
 Probe ID No: 67-8-21  
 Pitot C<sub>p</sub>: 0.813  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 383.1  
 H<sub>2</sub>O (silica, g): 12.5  
 Actual Moisture (%): 21.54

Meter Box ID. No: 85-2  
 Meter ΔH@: 1.74130  
 Meter Y<sub>d</sub>: 1.00390

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			614.900						
5-01	5.0	0.36	0.84	617.490	302	62	61	0.60	2.59	100.4
5-02	10.0	0.38	0.89	620.170	302	63	61	0.62	2.68	101.0
5-03	15.0	0.40	0.93	622.900	302	64	62	0.63	2.73	100.1
5-04	20.0	0.43	1.00	625.740	303	66	62	0.66	2.84	100.3
5-05	25.0	0.42	0.98	628.545	302	67	62	0.65	2.80	100.1
LEAK CHECK	25.0			628.630						
4-01	30.0	0.38	0.89	631.300	302	66	63	0.62	2.67	100.2
4-02	35.0	0.40	0.93	634.050	303	67	63	0.63	2.75	100.5
4-03	40.0	0.40	0.93	636.800	303	68	63	0.63	2.75	100.4
4-04	45.0	0.49	1.10	639.810	303	68	64	0.70	3.01	99.3
4-05	50.0	0.53	1.20	642.955	302	69	64	0.73	3.15	99.6
LEAK CHECK	50.0			643.028						
3-01	55.0	0.37	0.86	645.660	302	68	65	0.61	2.63	99.7
3-02	60.0	0.35	0.82	648.210	302	68	65	0.59	2.55	99.3
3-03	65.0	0.37	0.86	650.890	304	68	65	0.61	2.68	101.6
3-04	70.0	0.43	1.00	653.770	303	68	64	0.66	2.88	101.4
3-05	75.0	0.46	1.10	656.810	302	68	65	0.68	3.04	103.3
LEAK CHECK	75.0			656.875						
2-01	80.0	0.40	0.93	659.630	301	68	65	0.63	2.76	100.3
2-02	85.0	0.35	0.82	662.230	302	69	65	0.59	2.60	101.1
2-03	90.0	0.30	0.70	664.630	301	69	65	0.55	2.40	100.7
2-04	95.0	0.38	0.89	667.300	303	69	65	0.62	2.67	99.8
2-05	100.0	0.52	1.30	670.590	304	71	66	0.72	3.29	105.0
LEAK CHECK	100.0			670.675						
1-01	105.0	0.23	0.55	672.790	298	70	66	0.48	2.12	101.0
1-02	110.0	0.23	0.55	674.900	298	70	67	0.48	2.11	100.6
1-03	115.0	0.29	0.70	677.290	302	69	67	0.54	2.39	101.9
1-04	120.0	0.26	0.62	679.540	301	69	67	0.51	2.25	101.2
1-05	125.0	0.42	1.00	682.415	301	70	67	0.65	2.88	101.8
Final	125.0		0.89560	67.20700	301.92000	66.06000		0.61477	67.20700	

25 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	0.6147	0.8956	67.2100	301.9200	66.0600
	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

042313 083525  
N

**Field Data Printout**

**Test Method:**

**USEPA Method 5/29**

**Analyte:**

**Particulate/Metals**

Location: Unit 1 FF Outlet  
 Test Run: 3  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000

Bar. Press. (in. Hg): 29.90  
 Static P: -7.5  
 O<sub>2</sub> (dry volume %): 7.73  
 CO<sub>2</sub> (dry volume %): 11.13  
 N<sub>2</sub>+CO (dry volume %): 81.14

Nozzle ID No: 0.2725-1  
 Nozzle Diameter (D<sub>n</sub>): 0.273  
 Probe ID No: 67-8-21  
 Pitot C<sub>p</sub>: 0.813  
 Pitot Leak Check:  Pass  Fail

Meter Operator: P. Bihun 505  
 Probe Operator: P. Bihun 505

Test Date: 3/26/13  
 Start Time: 10:25  
 Stop Time: 12:36  
 Leak Rate Before: 0.002 cfm @ 15 "Hg  
 Leak Rate After: 0.005 cfm @ 10 "Hg

H<sub>2</sub>O (condensate, ml or gm): 396.8  
 H<sub>2</sub>O (silica, g): 13.3  
 Actual Moisture (%): 22.59

Meter Box ID. No: 85-2  
 Meter ΔH@: 1.74130  
 Meter Y<sub>d</sub>: 1.00390

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter T <sub>m-in</sub> T <sub>m-out</sub> (°F) (°F)		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
	0.0			682.925						
5-01	5.0	0.39	0.96	685.760	302	71	69	0.62	2.84	105.1
5-02	10.0	0.36	0.88	688.430	302	72	70	0.60	2.67	102.8
5-03	15.0	0.41	1.00	691.290	302	74	70	0.64	2.86	103.0
5-04	20.0	0.42	1.00	694.140	302	74	70	0.65	2.85	101.4
5-05	25.0	0.43	1.10	697.180	302	76	71	0.66	3.04	106.7
LEAK CHECK	25.0			697.270						
4-01	30.0	0.36	0.88	699.940	303	75	72	0.60	2.67	102.4
4-02	35.0	0.34	0.83	702.560	303	75	72	0.58	2.62	103.4
4-03	40.0	0.36	0.88	705.260	302	76	72	0.60	2.70	103.4
4-04	45.0	0.42	1.00	708.140	302	76	73	0.65	2.88	102.0
4-05	50.0	0.45	1.10	711.180	301	77	73	0.67	3.04	103.9
LEAK CHECK	50.0			711.250						
3-01	55.0	0.39	0.96	714.050	303	76	73	0.62	2.80	103.0
3-02	60.0	0.32	0.78	716.580	303	76	73	0.57	2.53	102.7
3-03	65.0	0.33	0.81	719.330	302	78	74	0.57	2.75	109.5
3-04	70.0	0.41	1.00	722.190	302	78	74	0.64	2.86	102.3
3-05	75.0	0.45	1.10	725.255	304	78	74	0.67	3.06	104.8
LEAK CHECK	75.0			725.300						
2-01	80.0	0.38	0.93	728.070	302	77	75	0.62	2.77	102.9
2-02	85.0	0.30	0.74	730.530	302	79	75	0.55	2.46	102.6
2-03	90.0	0.28	0.69	732.920	302	79	76	0.53	2.39	103.0
2-04	95.0	0.31	0.76	735.430	302	80	76	0.56	2.51	102.8
2-05	100.0	0.44	1.10	738.470	302	80	77	0.66	3.04	104.5
LEAK CHECK	100.0			738.545						
1-01	105.0	0.22	0.54	740.850	299	80	77	0.47	2.11	101.9
1-02	110.0	0.20	0.49	742.630	295	79	78	0.45	1.98	100.3
1-03	115.0	0.29	0.71	745.050	299	79	78	0.54	2.42	102.1
1-04	120.0	0.25	0.61	747.270	301	80	78	0.50	2.22	100.9
1-05	125.0	0.35	0.86	749.925	300	80	78	0.59	2.65	102.0
Final	125.0		0.86840	66.72000	301.56000	75.46000		0.59225	66.72000	

25 points sampled  
 QC-Check: Field Averages  
 Sq.Rt.AP: 0.5922 0.8684 66.7200 301.5600 75.4600

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 083525  
 K

### Field Data Printout

Location: Unit 1 FF Outlet  
 Test Run: 4  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: P. Bihun 505  
 Probe Operator: P. Bihun 505  
 Test Date: 3/26/13  
 Start Time: 12:59  
 Stop Time: 15:11  
 Leak Rate Before: 0.002 cfm @ 15 "Hg  
 Leak Rate After: 0.001 cfm @ 10 "Hg

**Test Method:**  
**Analyte:**

**USEPA Method 29**  
**Mercury**

Bar. Press. (in. Hg): 29.90  
 Static P: -8.3  
 O<sub>2</sub> (dry volume %): 8.61  
 CO<sub>2</sub> (dry volume %): 10.59  
 N<sub>2</sub>+CO (dry volume %): 80.80

Nozzle ID No: 0.2725-1  
 Nozzle Diameter (D<sub>n</sub>): 0.273  
 Probe ID No: 67-8-21  
 Pitot C<sub>p</sub>: 0.813  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 413.8  
 H<sub>2</sub>O (silica, g): 18.3  
 Actual Moisture (%): 22.40

Meter Box ID. No: 85-2  
 Meter ΔH@: 1.74130  
 Meter Y<sub>d</sub>: 1.00390

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			750.415						
5-01	5.0	0.32	0.78	752.970	302	76	76	0.57	2.56	103.2
5-02	10.0	0.34	0.83	755.590	304	77	77	0.58	2.62	102.6
5-03	15.0	0.42	1.00	758.490	300	79	77	0.65	2.90	101.7
5-04	20.0	0.48	1.20	761.710	302	82	78	0.69	3.22	105.5
5-05	25.0	0.46	1.10	764.730	304	83	79	0.68	3.02	101.0
LEAK CHECK	25.0			764.790						
4-01	30.0	0.38	0.93	767.550	304	82	79	0.62	2.76	101.6
4-02	35.0	0.35	0.86	770.220	304	82	79	0.59	2.67	102.4
4-03	40.0	0.42	1.00	773.090	304	81	79	0.65	2.87	100.6
4-04	45.0	0.55	1.40	776.550	308	80	78	0.74	3.46	106.5
4-05	50.0	0.52	1.30	779.875	311	79	77	0.72	3.33	105.7
LEAK CHECK	50.0			779.940						
3-01	55.0	0.32	0.78	782.460	300	78	76	0.57	2.52	101.4
3-02	60.0	0.35	0.86	785.140	304	78	76	0.59	2.68	103.4
3-03	65.0	0.40	0.98	788.000	301	78	75	0.63	2.86	103.2
3-04	70.0	0.51	1.30	791.365	307	78	74	0.71	3.37	108.1
3-05	75.0	0.56	1.40	794.825	308	78	75	0.75	3.46	106.1
LEAK CHECK	75.0			794.900						
2-01	80.0	0.45	1.10	797.900	307	78	74	0.67	3.00	102.6
2-02	85.0	0.38	0.93	800.670	308	80	74	0.62	2.77	102.9
2-03	90.0	0.33	0.81	803.260	308	80	75	0.57	2.59	103.1
2-04	95.0	0.43	1.10	806.320	308	80	75	0.66	3.06	106.8
2-05	100.0	0.56	1.40	809.765	308	81	75	0.75	3.44	105.3
LEAK CHECK	100.0			809.820						
1-01	105.0	0.21	0.52	811.880	303	78	75	0.46	2.06	102.6
1-02	110.0	0.22	0.54	814.000	304	79	75	0.47	2.12	103.1
1-03	115.0	0.32	0.78	816.500	305	79	75	0.57	2.50	100.9
1-04	120.0	0.30	0.74	818.980	306	79	75	0.55	2.48	103.5
1-05	125.0	0.44	1.10	822.050	306	79	75	0.66	3.07	105.9
Final	125.0		0.98960	71.38000	305.04000	77.74000		0.62835	71.38000	

25 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	0.6284	0.9896	71.3800	305.0400	77.7400
----------	--------	--------	---------	----------	---------

Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK

042313 083555  
N

USEPA Method 3 Laboratory Data

Location: Unit 1 FF Outlet  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Method: EPA Method 3  
 Fuel Type: Municipal Waste  
 F<sub>o</sub> for Fuel: 1.03 to 1.3

Test Method: USEPA Method 5/29 and 29  
 Analyte: Particulate Metals and Mercury

Analyst: S. Brown  
 Analyst Emp No: 433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.93000		8.25000	80.82000	30.07880	1.15737	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.73000		8.32000	80.95000	30.04960	1.17241	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		11.13000		7.73000	81.14000	30.09000	1.18329	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
4	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.59000		8.61000	80.80000	30.03880	1.16053	<input checked="" type="checkbox"/> Fo value within expected range.

042313 083555  
 NIKN

**USEPA Method 4 Laboratory Data**

Location: Unit 1 FF Outlet  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218

**Test Method:** USEPA Method 29  
**Analyte:** Mercury

Analyst: H. Nguyen  
 Analyst Emp No: 429

Test Run: **1**

Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1 Empty	787.8	465.4	322.4	
Impinger 2 5%HNO3/10%H2O2	674.0	545.3	128.7	
Impinger 3 5%HNO3/10%H2O2	575.2	550.7	24.5	
Impinger 4 Empty	429.5	424.5	5.0	
Impinger 5 4%KMnO4/10%H2SO4	645.7	643.7	2.0	
Impinger 6 4%KMnO4/10%H2SO4	545.9	546.3	-0.4	482.2 Liquid (gm)
Impinger 7 Silica Gel	747.3	729.4	17.9	0.0 less rinse (gm)
Impinger 8				482.2 Net Liquid (gm)
				+ 17.9 Silica Gel (gm)
				500.1 Total Vlc (gm)

Rinse: \_\_\_\_\_ (ml or gm)

482.2	Field Data Check	<input checked="" type="checkbox"/> QA/QC OK
17.9		<input checked="" type="checkbox"/> QA/QC OK
500.1		<input checked="" type="checkbox"/> QA/QC OK

Test Run: **2**

Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1 Empty	664.4	443.3	221.1	
Impinger 2 5%HNO3/10%H2O2	646.9	530.6	116.3	
Impinger 3 5%HNO3/10%H2O2	572.1	538.5	33.6	
Impinger 4 Empty	451.0	443.9	7.1	
Impinger 5 4%KMnO4/10%H2SO4	545.4	541.0	4.4	
Impinger 6 4%KMnO4/10%H2SO4	530.3	529.7	0.6	383.1 Liquid (gm)
Impinger 7 Silica Gel	850.4	837.9	12.5	0.0 less rinse (gm)
Impinger 8				383.1 Net Liquid (gm)
				+ 12.5 Silica Gel (gm)
				395.6 Total Vlc (gm)

Rinse: \_\_\_\_\_ (ml or gm)

383.1	Field Data Check	<input checked="" type="checkbox"/> QA/QC OK
12.5		<input checked="" type="checkbox"/> QA/QC OK
395.6		<input checked="" type="checkbox"/> QA/QC OK

Test Run: **3**

Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1 Empty	729.8	464.4	265.4	
Impinger 2 5%HNO3/10%H2O2	648.3	545.1	103.2	
Impinger 3 5%HNO3/10%H2O2	572.8	550.3	22.5	
Impinger 4 Empty	427.9	424.2	3.7	
Impinger 5 4%KMnO4/10%H2SO4	646.6	644.6	2.0	
Impinger 6 4%KMnO4/10%H2SO4	543.8	543.8	0.0	396.8 Liquid (gm)
Impinger 7 Silica Gel	760.2	746.9	13.3	0.0 less rinse (gm)
Impinger 8				396.8 Net Liquid (gm)
				+ 13.3 Silica Gel (gm)
				410.1 Total Vlc (gm)

Rinse: \_\_\_\_\_ (ml or gm)

396.8	Field Data Check	<input checked="" type="checkbox"/> QA/QC OK
13.3		<input checked="" type="checkbox"/> QA/QC OK
410.1		<input checked="" type="checkbox"/> QA/QC OK

Test Run: **4**

Contents	Gross (gm)	Tare (gm)	Net (gm)	
Impinger 1 Empty	733.4	441.8	291.6	
Impinger 2 5%HNO3/10%H2O2	631.8	532.2	99.6	
Impinger 3 5%HNO3/10%H2O2	553.3	537.0	16.3	
Impinger 4 Empty	445.3	443.3	2.0	
Impinger 5 4%KMnO4/10%H2SO4	559.7	558.3	1.4	
Impinger 6 4%KMnO4/10%H2SO4	539.6	536.7	2.9	413.8 Liquid (gm)
Impinger 7 Silica Gel	762.1	743.8	18.3	0.0 less rinse (gm)
Impinger 8				413.8 Net Liquid (gm)
				+ 18.3 Silica Gel (gm)
				432.1 Total Vlc (gm)

Rinse: \_\_\_\_\_ (ml or gm)

413.8	Field Data Check	<input checked="" type="checkbox"/> QA/QC OK
18.3		<input checked="" type="checkbox"/> QA/QC OK
432.1		<input checked="" type="checkbox"/> QA/QC OK

042313 083555  
 N I K N

### Field Data Printout

**Test Method:**

**USEPA Method 26A**

**Analyte:**

**HCl**

Location: Unit 1 SDA Inlet  
 Test Run: 1  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 60.13205

Bar. Press. (in. Hg): 29.70  
 Static P: -1.7  
 O<sub>2</sub> (dry volume %): 7.88  
 CO<sub>2</sub> (dry volume %): 11.15  
 N<sub>2</sub>+CO (dry volume %): 80.98

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 66-4-7  
 Pitot C<sub>p</sub>: 0.834  
 Pitot Leak Check:  Pass  Fail

Meter Operator: S. Joint 473  
 Probe Operator: S. Joint 473  
 Test Date: 3/25/13  
 Start Time: 08:00  
 Stop Time: 09:00  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.000 cfm @ 15 "Hg

H<sub>2</sub>O (condensate, ml or gm): 156.3  
 H<sub>2</sub>O (silica, g): 15.0  
 Actual Moisture (%): 19.16

Meter Box ID. No: 61-11  
 Meter ΔH@: 1.69640  
 Meter Y<sub>d</sub>: 1.00500

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			579.200						
1-01	5.0		1.20	582.240	498	88	88		3.04	
1-01	10.0		1.20	585.250	500	89	88		3.01	
1-01	15.0		1.20	588.210	501	94	90		2.96	
1-01	20.0		1.20	591.160	503	97	90		2.95	
1-01	25.0		1.20	594.090	501	95	91		2.93	
1-01	30.0		1.20	597.010	502	94	92		2.92	
1-01	35.0		1.20	599.000	501	98	93		1.99	
1-01	40.0		1.20	602.850	501	100	93		3.85	
1-01	45.0		1.20	605.790	501	102	93		2.94	
1-01	50.0		1.20	608.790	505	102	93		3.00	
1-01	55.0		1.20	611.790	508	102	93		3.00	
1-01	60.0		1.20	614.890	508	102	93		3.10	
Final	60.0		1.20000	35.69000	502.41667	94.16667			35.69000	

1 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	1.2000	35.6900	502.4167	94.1667
----------	--------	---------	----------	---------

Avg. OK    Avg. OK    Avg. OK    Avg. OK    Avg. OK

042313 083721  
Q

### Field Data Printout

Location: Unit 1 SDA Inlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 60.13205  
 Meter Operator: S. Joint 473  
 Probe Operator: S. Joint 473

**Test Method:**  
**Analyte:**

**USEPA Method 26A**  
**HCl**

Bar. Press. (in. Hg): 29.70  
 Static P: -1.6  
 O<sub>2</sub> (dry volume %): 7.68  
 CO<sub>2</sub> (dry volume %): 11.25  
 N<sub>2</sub>+CO (dry volume %): 81.07

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 66-4-7  
 Pitot C<sub>pi</sub>: 0.834  
 Pitot Leak Check:  Pass  Fail

Test Date: 3/25/13  
 Start Time: 09:23  
 Stop Time: 10:34  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 16 "Hg

H<sub>2</sub>O (condensate, ml or gm): 187.2  
 H<sub>2</sub>O (silica, g): 11.8  
 Actual Moisture (%): 21.21

Meter Box ID. No: 61-11  
 Meter ΔH@: 1.69640  
 Meter Y<sub>cf</sub>: 1.00500

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
1-01	5.0		1.20	615.300	488	97	96		3.23	
1-01	10.0		1.20	621.670	498	96	95		3.14	
1-01	15.0		1.20	624.840	488	98	95		3.17	
1-01	20.0		1.20	628.010	490	99	96		3.17	
1-01	25.0		1.20	630.900	489	100	96		2.89	
1-01	30.0		1.20	633.890	491	100	96		2.99	
1-01	35.0		1.20	636.890	488	101	97		3.00	
1-01	40.0		1.20	640.000	490	100	96		3.11	
1-01	45.0		1.20	642.970	490	99	96		2.97	
1-01	50.0		1.20	645.950	490	99	96		2.98	
1-01	55.0		1.20	648.920	491	98	95		2.97	
1-01	60.0		1.20	652.020	494	99	95		3.10	
Final	60.0		1.20000	36.72000	490.58333	97.29167			36.72000	

1 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	1.2000	36.7200	490.5833	97.2917
----------	--------	---------	----------	---------

Avg. OK    Avg. OK    Avg. OK    Avg. OK    Avg. OK

042313 083721  
 K



### Field Data Printout

**Test Method:**

**USEPA Method 26A**

**Analyte:**

**HCl**

Location: Unit 1 SDA Inlet

Test Run: 3

Client: Wheelabrator South Broward, Inc.

Project No: 12218

Source Area (ft<sup>2</sup>): 60.13205

Meter Operator: S. Joint 473

Probe Operator: S. Joint 473

Test Date: 3/25/13

Start Time: 10:54

Stop Time: 11:54

Leak Rate Before: 0.003

Leak Rate After: 0.003

cfm @ 15 "Hg

cfm @ 16 "Hg

Bar. Press. (in. Hg): 29.70

Static P: -1.5

O<sub>2</sub> (dry volume %): 8.07

CO<sub>2</sub> (dry volume %): 11.04

N<sub>2</sub>+CO (dry volume %): 80.89

H<sub>2</sub>O (condensate, ml or gm): 176.7

H<sub>2</sub>O (silica, g): 10.7

Actual Moisture (%): 20.26

Nozzle ID No: N/A

Nozzle Diameter (D<sub>n</sub>): N/A

Probe ID No: 66-4-7

Pitot C<sub>p</sub>: 0.834

Pitot Leak Check:  Pass  Fail

Meter Box ID. No: 61-11

Meter ΔH@: 1.69640

Meter Y<sub>g</sub>: 1.00500

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			652.500						
1-01	5.0		1.20	655.630	488	98	96		3.13	
1-01	10.0		1.20	658.710	489	98	96		3.08	
1-01	15.0		1.20	661.750	489	103	97		3.04	
1-01	20.0		1.20	664.860	488	104	98		3.11	
1-01	25.0		1.20	667.880	491	103	98		3.02	
1-01	30.0		1.20	670.900	494	102	98		3.02	
1-01	35.0		1.20	673.970	495	103	98		3.07	
1-01	40.0		1.20	677.030	497	103	98		3.06	
1-01	45.0		1.20	680.100	497	103	98		3.07	
1-01	50.0		1.20	683.260	497	103	99		3.16	
1-01	55.0		1.20	686.280	497	103	99		3.02	
1-01	60.0		1.20	689.300	497	103	99		3.02	
Final	60.0		1.20000	36.80000	493.25000	100.00000			36.80000	

1 points sampled

Sq.Rt.ΔP

QC-Check: Field Averages

1.2000	36.8000	493.2500	100.0000
--------	---------	----------	----------

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 083721  
N

### USEPA Method 3 Laboratory Data

Location: Unit 1 SDA Inlet

Client: Wheelabrator South Broward, Inc.

Project No: 12218

Method: EPA Method 3

Fuel Type: Municipal Waste

F<sub>o</sub> for Fuel: 1.03 to 1.3

Test Method:

Analyte:

USEPA Method 26A

HCl

Analyst: S. Brown

Analyst Emp No: 433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		11.14500		7.87500	80.98000	30.09820	1.16869	<input checked="" type="checkbox"/> Fo value within expected range.
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		11.25000		7.68000	81.07000	30.10720	1.17511	<input checked="" type="checkbox"/> Fo value within expected range.
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		11.04000		8.07000	80.89000	30.08920	1.16214	<input checked="" type="checkbox"/> Fo value within expected range.
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

The Run 1 IGS bag did not have enough volume to analyze. An average of Runs 2 and 3 are used for the Run 1 O<sub>2</sub>/CO<sub>2</sub>

**USEPA Method 4 Laboratory Data**

Location: Unit 1 SDA Inlet

Client: Wheelabrator South Broward, Inc.

Project No: 12218

Test Run:

Test Method:

**USEPA Method 26A**

Analyte:

**HCl**

Analyst: H. Nguyen

Analyst Emp No: 429

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	469.8	444.8	25.0
Impinger 2	100 ml 0.1N H2SO4	643.5	547.2	96.3
Impinger 3	100 ml 0.1N H2SO4	565.2	536.2	29.0
Impinger 4	Empty	489.2	483.2	6.0
Impinger 5	Silica Gel	697.5	682.5	15.0
Impinger 6				
Impinger 7				
Impinger 8				

156.3 Liquid (gm)

*Field Data Check*

0.0 less rinse (gm)

156.3 Net Liquid (gm)

QA/QC OK

+ 15.0 Silica Gel (gm)

QA/QC OK

171.3 Total Vlc (gm)

QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	496.8	444.2	52.6
Impinger 2	100 ml 0.1N H2SO4	646.6	542.2	104.4
Impinger 3	100 ml 0.1N H2SO4	587.0	562.3	24.7
Impinger 4	Empty	426.5	421.0	5.5
Impinger 5	Silica Gel	706.5	694.7	11.8
Impinger 6				
Impinger 7				
Impinger 8				

187.2 Liquid (gm)

*Field Data Check*

0.0 less rinse (gm)

187.2 Net Liquid (gm)

QA/QC OK

+ 11.8 Silica Gel (gm)

QA/QC OK

199.0 Total Vlc (gm)

QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	471.8	437.9	33.9
Impinger 2	100 ml 0.1N H2SO4	651.1	540.2	110.9
Impinger 3	100 ml 0.1N H2SO4	561.8	534.0	27.8
Impinger 4	Empty	487.3	483.2	4.1
Impinger 5	Silica Gel	707.7	697.0	10.7
Impinger 6				
Impinger 7				
Impinger 8				

176.7 Liquid (gm)

*Field Data Check*

0.0 less rinse (gm)

176.7 Net Liquid (gm)

QA/QC OK

+ 10.7 Silica Gel (gm)

QA/QC OK

187.4 Total Vlc (gm)

QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1				
Impinger 2				
Impinger 3				
Impinger 4				
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

Liquid (gm)

*Field Data Check*

less rinse (gm)

Net Liquid (gm)

QA/QC OK

Silica Gel (gm)

QA/QC OK

Total Vlc (gm)

QA/QC OK

Rinse:  (ml or gm)

### Field Data Printout

Location: Unit 1 FF Outlet  
 Test Run: 1  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: W. Berry 456  
 Probe Operator:   
 Test Date: 3/25/13  
 Start Time: 08:00  
 Stop Time: 09:00  
 Leak Rate Before: 0.004 cfm @ 15 "Hg  
 Leak Rate After: 0.001 cfm @ 10 "Hg

**Test Method:**  
**Analyte:**

**USEPA Method 26A**  
**HCl**

Bar. Press. (in. Hg): 29.70  
 Static P: -10.0  
 O<sub>2</sub> (dry volume %): 9.21  
 CO<sub>2</sub> (dry volume %): 9.86  
 N<sub>2</sub>+CO (dry volume %): 80.93

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 67-4-3  
 Pitot C<sub>p</sub>: N/A  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 235.2  
 H<sub>2</sub>O (silica, g): 19.5  
 Actual Moisture (%): 23.30

Meter Box ID. No: 66-14  
 Meter ΔH@: 1.80150  
 Meter Y<sub>d</sub>: 0.98790

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
3-01	5.0		1.50	406.400	298	75	73		3.19	
3-01	10.0		1.50	409.590	299	75	73		3.38	
3-01	15.0		1.50	412.970	299	78	74		3.38	
3-01	20.0		1.50	416.350	303	80	75		2.92	
3-01	25.0		1.50	419.270	301	81	75		3.95	
3-01	30.0		1.50	423.220	303	83	76		3.41	
3-01	35.0		1.50	426.630	303	83	76		3.44	
3-01	40.0		1.50	430.070	302	84	77		3.48	
3-01	45.0		1.50	433.550	304	85	77		3.43	
3-01	50.0		1.50	436.980	304	85	77		3.47	
3-01	55.0		1.50	440.450	304	86	78		3.41	
3-01	60.0		1.50	443.860	305	86	78		3.45	
3-01	60.0		1.50	447.310						
Final	60.0		1.50000	40.91000	302.08333	78.75000			40.91000	

3 points sampled  
 QC-Check: Field Averages

	Sq.Rt. ΔP	1.5000	40.9100	302.0833	78.7500
--	-----------	--------	---------	----------	---------

Avg. OK   
  Avg. OK   
  Avg. OK   
  Avg. OK   
  Avg. OK

042313 083759  
 N

### Field Data Printout

**Test Method:**

**USEPA Method 26A**

**Analyte:**

**HCl**

Location: Unit 1 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000

Bar. Press. (in. Hg): 29.70  
 Static P: -8.3  
 O<sub>2</sub> (dry volume %): 7.76  
 CO<sub>2</sub> (dry volume %): 11.25  
 N<sub>2</sub>+CO (dry volume %): 80.99

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 67-4-3  
 Pitot C<sub>p</sub>: N/A  
 Pitot Leak Check:  Pass  Fail

Meter Operator: W. Berry 456  
 Probe Operator:

Test Date: 3/25/13  
 Start Time: 09:23  
 Stop Time: 10:34  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 10 "Hg

H<sub>2</sub>O (condensate, ml or gm): 261.7  
 H<sub>2</sub>O (silica, g): 17.7  
 Actual Moisture (%): 24.96

Meter Box ID. No: 66-14  
 Meter ΔH@: 1.80150  
 Meter Y<sub>d</sub>: 0.98790

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			447.730						
3-01	5.0		1.50	451.230	306	78	77		3.50	
3-01	10.0		1.50	454.590	302	79	78		3.36	
3-01	15.0		1.50	457.950	303	81	77		3.36	
3-01	20.0		1.50	461.350	302	83	77		3.40	
3-01	25.0		1.50	464.790	301	85	78		3.44	
3-01	30.0		1.50	468.230	303	85	78		3.44	
3-01	35.0		1.50	471.630	304	86	78		3.40	
3-01	40.0		1.50	475.080	303	86	79		3.45	
3-01	45.0		1.50	478.530	304	87	79		3.45	
3-01	50.0		1.50	482.000	302	87	79		3.47	
3-01	55.0		1.50	485.470	304	87	80		3.47	
3-01	60.0		1.50	488.910	304	87	80		3.44	
Final	60.0		1.50000	41.18000	303.16667	81.29167			41.18000	

3 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	1.5000	41.1800	303.1667	81.2917
----------	--------	---------	----------	---------

Avg. OK    Avg. OK    Avg. OK    Avg. OK    Avg. OK

042313 083758  
 Q

### Field Data Printout

Location: Unit 1 FF Outlet  
 Test Run: 3  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: W. Berry 456  
 Probe Operator:   
 Test Date: 3/25/13  
 Start Time: 10:54  
 Stop Time: 11:54  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.001 cfm @ 10 "Hg

Test Method:  
 Analyte:

USEPA Method 26A  
 HCl

Bar. Press. (in. Hg): 29.70  
 Static P: -8.4  
 O<sub>2</sub> (dry volume %): 8.53  
 CO<sub>2</sub> (dry volume %): 10.64  
 N<sub>2</sub>+CO (dry volume %): 80.83

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 67-4-3  
 Pitot C<sub>p</sub>: N/A  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 244.5  
 H<sub>2</sub>O (silica, g): 11.1  
 Actual Moisture (%): 23.33

Meter Box ID. No: 66-14  
 Meter ΔH@: 1.80150  
 Meter Y<sub>d</sub>: 0.98790

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			489.570						
3-01	5.0		1.50	493.350	308	83	80		3.78	
3-01	10.0		1.50	496.750	308	85	81		3.40	
3-01	15.0		1.50	500.160	311	87	81		3.41	
3-01	20.0		1.50	503.590	303	89	82		3.43	
3-01	25.0		1.50	507.010	307	89	83		3.42	
3-01	30.0		1.50	510.470	305	90	83		3.46	
3-01	35.0		1.50	513.940	304	91	84		3.47	
3-01	40.0		1.50	517.380	305	90	84		3.44	
3-01	45.0		1.50	520.820	306	90	84		3.44	
3-01	50.0		1.50	524.250	303	91	84		3.43	
3-01	55.0		1.50	527.710	304	92	85		3.46	
3-01	60.0		1.50	531.130	305	94	86		3.42	
Final	60.0		1.50000	41.56000	305.75000	86.16667			41.56000	

3 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	<span style="border: 1px solid black; padding: 2px;">1.5000</span>	<span style="border: 1px solid black; padding: 2px;">41.5600</span>	<span style="border: 1px solid black; padding: 2px;">305.7500</span>	<span style="border: 1px solid black; padding: 2px;">86.1667</span>
	<input type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

042313 063759

### USEPA Method 3 Laboratory Data

Location: Unit 1 FF Outlet  
 Client: Wheelabrator South Broward, Inc.

Test Method:  
 Analyte:

USEPA Method 26A  
 HCl

Project No: 12218  
 Method: EPA Method 3  
 Fuel Type: Municipal Waste  
 F<sub>o</sub> for Fuel: 1.03 to 1.3

Analyst:	S. Brown
Analyst Emp No:	433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.86000		9.21000	80.93000	29.94600	1.18560	<input checked="" type="checkbox"/> Fo value within expected range.
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		11.25000		7.76000	80.99000	30.11040	1.16800	<input checked="" type="checkbox"/> Fo value within expected range.
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.64000		8.53000	80.83000	30.04360	1.16259	<input checked="" type="checkbox"/> Fo value within expected range.
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

042313 083759  
 NQJ@

### USEPA Method 4 Laboratory Data

Location: Unit 1 FF Outlet

Client: Wheelabrator South Broward, Inc.

Project No: 12218

Test Run: 1

Test Method:

USEPA Method 26A

Analyte:

HCl

Analyst: D. Luckhard

Analyst Emp No: 568

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	485.7	458.9	26.8
Impinger 2	100 ml 0.1N H2SO4	678.3	548.8	129.5
Impinger 3	100 ml 0.1N H2SO4	592.0	530.9	61.1
Impinger 4	Empty	486.1	468.3	17.8
Impinger 5	Silica Gel	724.4	704.9	19.5
Impinger 6				
Impinger 7				
Impinger 8				

Rinse:            (ml or gm)

Test Run: 2

	Field Data Check	
235.2 Liquid (gm)		
0.0 less rinse (gm)		
235.2 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">235.2</span>
+ 19.5 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">19.5</span>
254.7 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">254.7</span>

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	488.1	450.8	37.3
Impinger 2	100 ml 0.1N H2SO4	722.9	566.8	156.1
Impinger 3	100 ml 0.1N H2SO4	599.0	543.2	55.8
Impinger 4	Empty	454.6	442.1	12.5
Impinger 5	Silica Gel	724.2	706.5	17.7
Impinger 6				
Impinger 7				
Impinger 8				

Rinse:            (ml or gm)

Test Run: 3

	Field Data Check	
261.7 Liquid (gm)		
0.0 less rinse (gm)		
261.7 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">261.7</span>
+ 17.7 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">17.7</span>
279.4 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">279.4</span>

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	492.4	457.9	34.5
Impinger 2	100 ml 0.1N H2SO4	703.7	547.5	156.2
Impinger 3	100 ml 0.1N H2SO4	592.9	539.4	53.5
Impinger 4	Empty	468.9	468.6	0.3
Impinger 5	Silica Gel	735.5	724.4	11.1
Impinger 6				
Impinger 7				
Impinger 8				

Rinse:            (ml or gm)

Test Run:           

	Field Data Check	
244.5 Liquid (gm)		
0.0 less rinse (gm)		
244.5 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">244.5</span>
+ 11.1 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">11.1</span>
255.6 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">255.6</span>

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1				
Impinger 2				
Impinger 3				
Impinger 4				
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

Rinse:            (ml or gm)

	Field Data Check	
Liquid (gm)		
less rinse (gm)		
Net Liquid (gm)	<input type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">          </span>
Silica Gel (gm)	<input type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">          </span>
Total Vlc (gm)	<input type="checkbox"/> QA/QC OK	<span style="border: 1px solid black; padding: 2px;">          </span>

042313 083750  
NQJ@



### Field Data Printout

**Test Method:**  
**Analyte:**

**USEPA Method 5/29**  
**Particulate/Metals**

Location: Unit 2 FF Outlet  
Test Run: 1  
Client: Wheelabrator South Broward, Inc.  
Project No: 12218  
Source Area (ft<sup>2</sup>): 64.00000

Bar. Press. (in. Hg): 29.70  
Static P: -12.2  
O<sub>2</sub> (dry volume %): 8.56  
CO<sub>2</sub> (dry volume %): 10.35  
N<sub>2</sub>+CO (dry volume %): 81.09

Nozzle ID No: 0.2725-1  
Nozzle Diameter (D<sub>n</sub>): 0.273  
Probe ID No: 67-8-17  
Pitot C<sub>p</sub>: 0.824  
Pitot Leak Check:  Pass  Fail

Meter Operator: P. Bihun 505  
Probe Operator: P. Bihun 505

Test Date: 3/25/13

Start Time: 07:59

Stop Time: 10:11

Leak Rate Before: 0.007 cfm @ 15 "Hg

Leak Rate After: 0.002 cfm @ 10 "Hg

H<sub>2</sub>O (condensate, ml or gm): 417.2

H<sub>2</sub>O (silica, g): 19.5

Actual Moisture (%): 23.20

Meter Box ID. No: 66-11

Meter ΔH@: 1.82740

Meter Y<sub>d</sub>: 0.99060

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>a</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter T <sub>m-in</sub> T <sub>m-out</sub> (°F) (°F)		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
	0.0			842.000						
1-01	5.0	0.33	0.88	844.620	298	77	76	0.57	2.62	102.1
1-02	10.0	0.31	0.82	847.110	299	79	76	0.56	2.49	99.9
1-03	15.0	0.32	0.85	849.620	298	80	77	0.57	2.51	98.9
1-04	20.0	0.33	0.88	852.190	298	82	77	0.57	2.57	99.6
1-05	25.0	0.35	0.93	854.875	298	84	78	0.59	2.68	100.7
LEAK CHECK	25.0			854.950						
2-01	30.0	0.32	0.85	857.500	298	83	79	0.57	2.55	100.0
2-02	35.0	0.33	0.88	860.080	299	81	78	0.57	2.58	100.0
2-03	40.0	0.37	0.98	862.820	299	81	78	0.61	2.74	100.3
2-04	45.0	0.42	1.10	865.750	300	82	78	0.65	2.93	100.7
2-05	50.0	0.38	1.00	868.540	300	84	78	0.62	2.79	100.6
LEAK CHECK	50.0			868.625						
3-01	55.0	0.27	0.72	870.970	303	82	78	0.52	2.35	100.6
3-02	60.0	0.40	1.10	873.900	300	83	79	0.63	2.93	103.0
3-03	65.0	0.44	1.20	877.010	297	85	79	0.66	3.11	103.9
3-04	70.0	0.52	1.40	880.380	302	87	80	0.72	3.37	103.6
3-05	75.0	0.50	1.30	883.600	300	88	80	0.71	3.22	100.7
LEAK CHECK	75.0			883.690						
4-01	80.0	0.45	1.20	886.760	300	86	81	0.67	3.07	101.3
4-02	85.0	0.43	1.10	889.740	300	87	81	0.66	2.98	100.5
4-03	90.0	0.48	1.30	892.980	298	87	81	0.69	3.24	103.3
4-04	95.0	0.46	1.20	896.120	299	88	81	0.68	3.14	102.2
4-05	100.0	0.48	1.30	899.325	299	88	82	0.69	3.21	102.1
LEAK CHECK	100.0			899.410						
5-01	105.0	0.36	0.95	902.120	296	86	81	0.60	2.71	99.7
5-02	110.0	0.36	0.95	904.800	298	86	82	0.60	2.68	98.6
5-03	115.0	0.37	0.98	907.550	298	87	82	0.61	2.75	99.7
5-04	120.0	0.36	0.95	910.230	298	87	82	0.60	2.68	98.5
5-05	125.0	0.40	1.10	913.180	299	87	82	0.63	2.95	103.0
Final	125.0		1.03680	70.84500	298.96000	81.86000		0.62203	70.84500	

25 points sampled

Sq.Rt.ΔP

QC-Check: Field Averages

0.6220	1.0368	70.8450	298.9600	81.8600
--------	--------	---------	----------	---------

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 083934

N

### Field Data Printout

Location: Unit 2 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: P. Bihun 505  
 Probe Operator: P. Bihun 505  
 Test Date: 3/25/13  
 Start Time: 10:32  
 Stop Time: 12:45  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.002 cfm @ 10 "Hg

**Test Method:**  
**Analyte:**

**USEPA Method 5/29**  
**Particulate/Metals**

Bar. Press. (in. Hg): 29.70  
 Static P: -11.6  
 O<sub>2</sub> (dry volume %): 8.36  
 CO<sub>2</sub> (dry volume %): 10.73  
 N<sub>2</sub>+CO (dry volume %): 80.91

Nozzle ID No: 0.2725-1  
 Nozzle Diameter (D<sub>n</sub>): 0.273  
 Probe ID No: 67-8-17  
 Pitot C<sub>p</sub>: 0.824  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 394.2  
 H<sub>2</sub>O (silica, g): 13.4  
 Actual Moisture (%): 22.39

Meter Box ID. No: 66-11  
 Meter ΔH@: 1.82740  
 Meter Y<sub>d</sub>: 0.99060

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			913.465						
3-01	5.0	0.30	0.80	916.020	300	82	81	0.55	2.55	102.6
3-02	10.0	0.34	0.90	918.620	306	85	82	0.58	2.60	98.2
3-03	15.0	0.38	1.00	921.360	305	87	83	0.62	2.74	97.5
3-04	20.0	0.46	1.20	924.440	298	88	83	0.68	3.08	99.2
3-05	25.0	0.46	1.20	927.525	300	90	84	0.68	3.08	99.2
LEAK CHECK	25.0			927.615						
2-01	30.0	0.42	1.10	930.520	299	89	85	0.65	2.90	97.7
2-02	35.0	0.40	1.10	933.460	301	91	85	0.63	2.94	101.2
2-03	40.0	0.42	1.10	936.380	298	92	86	0.65	2.92	97.7
2-04	45.0	0.41	1.10	939.290	300	92	86	0.64	2.91	98.7
2-05	50.0	0.48	1.30	942.510	299	91	86	0.69	3.22	101.0
LEAK CHECK	50.0			942.595						
1-01	55.0	0.30	0.80	945.060	295	88	85	0.55	2.46	97.8
1-02	60.0	0.38	1.00	947.840	300	86	84	0.62	2.78	98.6
1-03	65.0	0.39	1.00	950.610	298	89	84	0.62	2.77	96.6
1-04	70.0	0.40	1.10	953.550	300	90	84	0.63	2.94	101.3
1-05	75.0	0.45	1.20	956.630	296	91	85	0.67	3.08	99.7
LEAK CHECK	75.0			956.755						
5-01	80.0	0.30	0.80	959.230	296	87	85	0.55	2.48	98.4
5-02	85.0	0.32	0.85	961.770	298	89	85	0.57	2.54	97.7
5-03	90.0	0.38	1.00	964.580	300	89	85	0.62	2.81	99.3
5-04	95.0	0.33	0.88	967.150	299	91	86	0.57	2.57	97.1
5-05	100.0	0.38	1.00	969.940	299	91	86	0.62	2.79	98.3
LEAK CHECK	100.0			970.030						
4-01	105.0	0.41	1.10	972.920	300	90	86	0.64	2.89	98.2
4-02	110.0	0.35	0.93	975.600	297	88	86	0.59	2.68	98.5
4-03	115.0	0.35	0.93	978.300	298	86	85	0.59	2.70	99.6
4-04	120.0	0.35	0.93	980.930	298	85	84	0.59	2.63	97.2
4-05	125.0	0.37	0.98	983.705	298	85	84	0.61	2.78	99.7
Final	125.0		1.01200	69.85000	299.12000	86.54000		0.61606	69.85000	

25 points sampled  
 QC-Check: Field Averages  
 Sq.RLΔP: 0.6161 1.0120 69.8500 299.1200 86.5400  
 Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK

042313 083934  
N

### Field Data Printout

Location: Unit 2 FF Outlet  
 Test Run: 3  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000

Meter Operator: P. Bihun 505  
 Probe Operator: P. Bihun 505

Test Date: 3/25/13  
 Start Time: 13:04  
 Stop Time: 15:17  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 15 "Hg

Test Method:  
 Analyte:

USEPA Method 5/29  
 Particulate/Metals

Bar. Press. (in. Hg): 29.70  
 Static P: -11.7  
 O<sub>2</sub> (dry volume %): 8.58  
 CO<sub>2</sub> (dry volume %): 10.66  
 N<sub>2</sub>+CO (dry volume %): 80.76

Nozzle ID No: 0.2725-1  
 Nozzle Diameter (D<sub>n</sub>): 0.273  
 Probe ID No: 67-8-17  
 Pitot C<sub>p</sub>: 0.824  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 382.7  
 H<sub>2</sub>O (silica, g): 14.2  
 Actual Moisture (%): 21.96

Meter Box ID. No: 66-11  
 Meter ΔH@: 1.82740  
 Meter Y<sub>d</sub>: 0.99060

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			984.155						
5-01	5.0	0.30	0.80	986.720	298	80	80	0.55	2.57	102.7
5-02	10.0	0.33	0.88	989.300	299	83	80	0.57	2.58	98.3
5-03	15.0	0.32	0.85	991.800	299	84	81	0.57	2.50	96.6
5-04	20.0	0.35	0.93	994.470	299	88	82	0.59	2.67	98.2
5-05	25.0	0.35	0.93	997.140	305	88	83	0.59	2.67	98.5
LEAK CHECK	25.0			997.245						
4-01	30.0	0.37	0.98	1000.000	312	89	84	0.61	2.76	99.1
4-02	35.0	0.37	0.98	1002.760	307	89	85	0.61	2.76	98.9
4-03	40.0	0.35	0.93	1005.420	299	90	85	0.59	2.66	97.4
4-04	45.0	0.38	1.00	1008.200	303	89	85	0.62	2.78	98.0
4-05	50.0	0.35	0.93	1010.890	300	89	85	0.59	2.69	98.6
LEAK CHECK	50.0			1010.990						
3-01	55.0	0.38	1.00	1013.770	298	86	85	0.62	2.78	98.0
3-02	60.0	0.35	0.93	1016.440	302	88	85	0.59	2.67	98.1
3-03	65.0	0.37	0.98	1019.190	299	89	85	0.61	2.75	98.0
3-04	70.0	0.42	1.10	1022.160	303	89	85	0.65	2.97	99.6
3-05	75.0	0.42	1.10	1025.140	301	92	85	0.65	2.98	99.6
LEAK CHECK	75.0			1025.215						
2-01	80.0	0.38	1.00	1027.990	304	88	85	0.62	2.78	98.0
2-02	85.0	0.46	1.20	1031.110	299	88	85	0.68	3.12	99.9
2-03	90.0	0.40	1.10	1034.030	299	84	83	0.63	2.92	100.8
2-04	95.0	0.46	1.20	1037.110	297	81	81	0.68	3.08	99.5
2-05	100.0	0.43	1.10	1040.100	300	83	81	0.66	2.99	99.9
LEAK CHECK	100.0			1040.175						
1-01	105.0	0.34	0.90	1042.820	301	81	80	0.58	2.64	99.6
1-02	110.0	0.36	0.95	1045.500	297	81	80	0.60	2.68	97.9
1-03	115.0	0.36	0.95	1048.210	298	80	79	0.60	2.71	99.2
1-04	120.0	0.32	0.85	1050.760	298	81	79	0.57	2.55	98.9
1-05	125.0	0.47	1.30	1053.945	299	81	79	0.69	3.18	102.1
Final	125.0		0.99480	69.43500	300.64000	84.16000		0.61181	69.43500	

25 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	0.6118	0.9948	69.4350	300.6400	84.1600
----------	--------	--------	---------	----------	---------

Avg. OK    Avg. OK    Avg. OK    Avg. OK    Avg. OK

042313 083934  
 L

**Field Data Printout**

**Test Method:**  
**Analyte:**

**USEPA Method 29**  
**Mercury**

Location: Unit 2 FF Outlet  
 Test Run: 4  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: S. Joint 473  
 Probe Operator: W. Berry 456  
 Test Date: 3/27/13  
 Start Time: 12:07  
 Stop Time: 14:22  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 16 "Hg

Bar. Press. (in. Hg): 30.10  
 Static P: -12.1  
 O<sub>2</sub> (dry volume %): 9.39  
 CO<sub>2</sub> (dry volume %): 10.02  
 N<sub>2</sub>+CO (dry volume %): 80.59

Nozzle ID No: 0.2725-2  
 Nozzle Diameter (D<sub>n</sub>): 0.273  
 Probe ID No: 67-8-16  
 Pitot C<sub>p</sub>: 0.825  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 365.6  
 H<sub>2</sub>O (silica, g): 12.4  
 Actual Moisture (%): 20.27

Meter Box ID No: 66-22  
 Meter ΔH@: 1.88400  
 Meter Y<sub>d</sub>: 0.99720

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			832.300						
1-01	5.0	0.42	1.20	835.330	297	63	62	0.65	3.03	105.4
1-02	10.0	0.38	1.10	838.090	296	65	62	0.62	2.76	100.6
1-03	15.0	0.39	1.10	840.850	295	65	62	0.62	2.76	99.3
1-04	20.0	0.43	1.20	843.740	300	66	62	0.66	2.89	99.2
1-05	25.0	0.45	1.20	846.640	299	68	63	0.67	2.90	97.0
LEAK CHECK	25.0			846.830						
2-01	30.0	0.44	1.20	849.900	297	69	65	0.66	3.07	103.4
2-02	35.0	0.45	1.20	852.920	297	70	65	0.67	3.02	100.5
2-03	40.0	0.38	1.10	855.740	303	71	64	0.62	2.82	102.5
2-04	45.0	0.45	1.20	858.740	300	71	65	0.67	3.00	99.9
2-05	50.0	0.50	1.40	861.890	297	71	65	0.71	3.15	99.4
LEAK CHECK	50.0			862.000						
3-01	55.0	0.36	1.00	864.720	299	72	66	0.60	2.72	101.0
3-02	60.0	0.33	0.91	867.310	300	73	67	0.57	2.59	100.3
3-03	65.0	0.37	1.00	870.140	301	76	69	0.61	2.83	103.1
3-04	70.0	0.40	1.10	873.000	300	76	70	0.63	2.86	100.1
3-05	75.0	0.41	1.10	875.740	300	76	70	0.64	2.74	94.7
LEAK CHECK	75.0			876.020						
4-01	80.0	0.36	1.00	878.740	299	74	70	0.60	2.72	100.4
4-02	85.0	0.33	0.91	881.300	301	74	70	0.57	2.56	98.8
4-03	90.0	0.35	0.97	883.990	295	74	70	0.59	2.69	100.5
4-04	95.0	0.35	0.97	886.730	301	74	70	0.59	2.74	102.7
4-05	100.0	0.36	1.00	889.420	300	76	71	0.60	2.69	99.1
LEAK CHECK	100.0			889.550						
5-01	105.0	0.32	0.89	892.100	300	75	70	0.57	2.55	99.8
5-02	110.0	0.28	0.78	894.520	300	74	70	0.53	2.42	101.3
5-03	115.0	0.30	0.83	896.990	299	75	70	0.55	2.47	99.8
5-04	120.0	0.42	1.20	900.100	299	75	70	0.65	3.11	106.3
5-05	125.0	0.36	1.00	902.800	299	75	70	0.60	2.70	99.8
Final	125.0		1.06240	69.79000	298.96000	69.52000		0.61792	69.79000	

25 points sampled  
 QC-Check: Field Averages  
 Sq.Rt.ΔP: 0.6179 1.0624 69.7900 298.9600 69.5200  
 Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 084001  
P

**USEPA Method 3 Laboratory Data**

Location: Unit 2 FF Outlet  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Method: EPA Method 3  
 Fuel Type: Municipal Waste  
 F<sub>o</sub> for Fuel: 1.03 to 1.3

Test Method: USEAP Methods 5/29 and 29  
 Analyte: Particulate/Metals and Mercury

Analyst: S. Brown  
 Analyst Emp No: 433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.35000		8.56000	81.09000	29.99840	1.19227	<input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.73000		8.36000	80.91000	30.05120	1.16869	<input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.66000		8.58000	80.76000	30.04880	1.15572	<input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.
4	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.02000		9.39000	80.59000	29.97880	1.14870	<input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.

042313 084001  
 RNNP

**USEPA Method 4 Laboratory Data**

Location: Unit 2 FF Outlet

Client: Wheelabrator South Broward, Inc.

Project No: 12218

Test Run: 1

Test Method: USEAP Methods 5/29 and 29

Analyte: Particulate/Metals and Mercury

Analyst: D. Luckhard

Analyst Emp No: 568

Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1 Empty	703.8	456.6	247.2		
Impinger 2 5%HNO3/10%H2O2	682.6	558.2	124.4		
Impinger 3 5%HNO3/10%H2O2	586.1	554.6	31.5		
Impinger 4 Empty	445.5	437.6	7.9		
Impinger 5 4%KMnO4/10%H2SO4	549.7	545.2	4.5		
Impinger 6 4%KMnO4/10%H2SO4	539.2	537.5	1.7	417.2 Liquid (gm)	<i>Field Data Check</i>
Impinger 7 Silica Gel	735.3	715.8	19.5	0.0 less rinse (gm)	
Impinger 8				417.2 Net Liquid (gm)	
				+ 19.5 Silica Gel (gm)	<span style="border: 1px solid black; padding: 2px;">19.5</span> <input checked="" type="checkbox"/> QA/QC OK
				436.7 Total Vlc (gm)	<span style="border: 1px solid black; padding: 2px;">436.7</span> <input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)		

Test Run: 2

Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1 Empty	688.1	444.3	243.8		
Impinger 2 5%HNO3/10%H2O2	639.9	531.7	108.2		
Impinger 3 5%HNO3/10%H2O2	566.9	538.8	28.1		
Impinger 4 Empty	451.3	444.7	6.6		
Impinger 5 4%KMnO4/10%H2SO4	547.9	542.6	5.3		
Impinger 6 4%KMnO4/10%H2SO4	540.7	538.5	2.2	394.2 Liquid (gm)	<i>Field Data Check</i>
Impinger 7 Silica Gel	837.9	824.5	13.4	0.0 less rinse (gm)	
Impinger 8				394.2 Net Liquid (gm)	
				+ 13.4 Silica Gel (gm)	<span style="border: 1px solid black; padding: 2px;">13.4</span> <input checked="" type="checkbox"/> QA/QC OK
				407.6 Total Vlc (gm)	<span style="border: 1px solid black; padding: 2px;">407.6</span> <input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)		

Test Run: 3

Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1 Empty	716.5	456.5	260.0		
Impinger 2 5%HNO3/10%H2O2	652.5	556.6	95.9		
Impinger 3 5%HNO3/10%H2O2	564.0	544.8	19.2		
Impinger 4 Empty	441.6	436.9	4.7		
Impinger 5 4%KMnO4/10%H2SO4	548.7	546.0	2.7		
Impinger 6 4%KMnO4/10%H2SO4	540.8	540.6	0.2	382.7 Liquid (gm)	<i>Field Data Check</i>
Impinger 7 Silica Gel	749.5	735.3	14.2	0.0 less rinse (gm)	
Impinger 8				382.7 Net Liquid (gm)	
				+ 14.2 Silica Gel (gm)	<span style="border: 1px solid black; padding: 2px;">14.2</span> <input checked="" type="checkbox"/> QA/QC OK
				396.9 Total Vlc (gm)	<span style="border: 1px solid black; padding: 2px;">396.9</span> <input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)		

Test Run: 4

Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1 Empty	682.8	443.1	239.7		
Impinger 2 5%HNO3/10%H2O2	631.2	530.0	101.2		
Impinger 3 5%HNO3/10%H2O2	551.6	530.1	21.5		
Impinger 4 Empty	446.9	443.9	3.0		
Impinger 5 4%KMnO4/10%H2SO4	542.8	541.3	1.5		
Impinger 6 4%KMnO4/10%H2SO4	534.9	536.2	-1.3	365.6 Liquid (gm)	<i>Field Data Check</i>
Impinger 7 Silica Gel	774.4	762.0	12.4	0.0 less rinse (gm)	
Impinger 8				365.6 Net Liquid (gm)	
				+ 12.4 Silica Gel (gm)	<span style="border: 1px solid black; padding: 2px;">12.4</span> <input checked="" type="checkbox"/> QA/QC OK
				378.0 Total Vlc (gm)	<span style="border: 1px solid black; padding: 2px;">378.0</span> <input checked="" type="checkbox"/> QA/QC OK
	Rinse:		(ml or gm)		

042313 084001  
R N N P

### Field Data Printout

**Test Method:**

**USEPA Method 23**

**Analyte:**

**PCDD/F**

Location: Unit 2 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: A. Obuchowski 567  
 Probe Operator: A. Obuchowski 567

Bar. Press. (in. Hg): 29.90  
 Static P: -10.4  
 O<sub>2</sub> (dry volume %): 8.63  
 CO<sub>2</sub> (dry volume %): 10.34  
 N<sub>2</sub>+CO (dry volume %): 81.03

Nozzle ID No: 2722-1  
 Nozzle Diameter (D<sub>n</sub>): 0.272  
 Probe ID No: 67-8-16  
 Pitot C<sub>p</sub>: 0.825  
 Pitot Leak Check:  Pass  Fail

Test Date: 3/26/13  
 Start Time: 08:03  
 Stop Time: 12:49  
 Leak Rate Before: 0.005 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 12 "Hg

H<sub>2</sub>O (condensate, ml or gm): 715.7  
 H<sub>2</sub>O (silica, g): 52.7  
 Actual Moisture (%): 20.96

Meter Box ID. No: 66-22  
 Meter ΔH@: 1.88400  
 Meter Y<sub>d</sub>: 0.99720

Traverse Point	Run Time 10.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			412.515						
1-01	10.0	0.35	0.94	417.650	292	59	58	0.59	5.13	98.6
1-02	20.0	0.38	1.00	423.020	292	60	58	0.62	5.37	98.9
1-03	30.0	0.43	1.20	428.830	297	61	59	0.66	5.81	100.8
1-04	40.0	0.37	0.99	434.280	301	62	59	0.61	5.45	102.0
1-05	50.0	0.47	1.30	440.420	295	62	59	0.69	6.14	101.6
LEAK CHECK	50.0			440.770						
2-01	60.0	0.34	0.91	446.000	294	62	59	0.58	5.23	101.6
2-02	70.0	0.38	1.00	451.480	295	62	60	0.62	5.48	100.7
2-03	80.0	0.40	1.10	457.170	294	64	61	0.63	5.69	101.6
2-04	90.0	0.43	1.20	463.100	299	64	61	0.66	5.93	102.5
2-05	100.0	0.51	1.40	469.490	297	65	62	0.71	6.39	101.1
LEAK CHECK	100.0			469.600						
3-01	110.0	0.34	0.94	474.920	291	65	64	0.58	5.32	102.4
3-02	120.0	0.34	0.94	480.240	293	68	66	0.58	5.32	102.0
3-03	130.0	0.33	0.91	485.470	294	69	68	0.57	5.23	101.6
3-04	140.0	0.35	0.96	490.820	296	70	67	0.59	5.35	101.1
3-05	150.0	0.39	1.10	496.180	296	70	66	0.62	5.36	96.0
LEAK CHECK	150.0			496.360						
4-01	160.0	0.37	1.00	501.770	299	67	65	0.61	5.41	100.1
4-02	170.0	0.33	0.91	506.970	298	67	65	0.57	5.20	101.8
4-03	180.0	0.33	0.91	512.200	295	69	64	0.57	5.23	102.0
4-04	190.0	0.35	0.96	517.540	296	69	64	0.59	5.34	101.2
4-05	200.0	0.44	1.20	523.440	295	68	64	0.66	5.90	99.9
LEAK CHECK	200.0			523.620						
5-01	210.0	0.28	0.77	528.400	292	70	65	0.53	4.78	100.8
5-02	220.0	0.33	0.91	533.600	296	71	66	0.57	5.20	101.1
5-03	230.0	0.33	0.91	538.840	299	70	65	0.57	5.24	102.3
5-04	240.0	0.33	0.91	544.020	305	72	66	0.57	5.18	101.3
5-05	250.0	0.31	0.85	549.040	292	70	66	0.56	5.02	100.6
Final	250.0		1.00880	135.70500	295.72000	64.66000		0.60551	135.70500	

25 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	0.6055	1.0088	135.7050	295.7200	64.6600
	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

4.3% 2RSD

042513 084310  
 P

### Field Data Printout

Location: Unit 2 FF Outlet  
 Test Run: 3  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: A. Obuchowski 567  
 Probe Operator: A. Obuchowski 567  
 Test Date: 3/26/13  
 Start Time: 13:09  
 Stop Time: 17:25  
 Leak Rate Before: 0.004 cfm @ 15 "Hg  
 Leak Rate After: 0.000 cfm @ 12 "Hg

**Test Method:**  
**Analyte:**

**USEPA Method 23**  
**PCDD/F**

Bar. Press. (in. Hg): 29.90  
 Static P: -11.0  
 O<sub>2</sub> (dry volume %): 9.48  
 CO<sub>2</sub> (dry volume %): 9.80  
 N<sub>2</sub>+CO (dry volume %): 80.72

Nozzle ID No: 2722-1  
 Nozzle Diameter (D<sub>n</sub>): 0.272  
 Probe ID No: 67-8-16  
 Pitot C<sub>p</sub>: 0.825  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 667.8  
 H<sub>2</sub>O (silica, g): 50.8  
 Actual Moisture (%): 19.67

Meter Box ID. No: 66-22  
 Meter ΔH@: 1.88400  
 Meter Y<sub>d</sub>: 0.99720

Traverse Point	Run Time 10.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			549.725						
5-01	10.0	0.29	0.78	554.580	297	72	68	0.54	4.86	99.2
5-02	20.0	0.29	0.78	559.320	296	76	71	0.54	4.74	96.1
5-03	30.0	0.32	0.89	564.510	297	77	72	0.57	5.19	100.1
5-04	40.0	0.34	0.94	569.810	301	74	71	0.58	5.30	99.8
5-05	50.0	0.36	1.00	575.300	291	73	70	0.60	5.49	100.0
LEAK CHECK	50.0			575.500						
4-01	60.0	0.32	0.89	580.640	292	72	70	0.57	5.14	99.4
4-02	70.0	0.32	0.89	585.850	293	72	69	0.57	5.21	101.0
4-03	80.0	0.30	0.83	590.840	300	76	70	0.55	4.99	99.8
4-04	90.0	0.31	0.86	595.930	295	78	72	0.56	5.09	99.5
4-05	100.0	0.31	0.86	601.100	293	79	74	0.56	5.17	100.6
LEAK CHECK	100.0			601.280						
3-01	110.0	0.35	0.97	606.610	298	80	74	0.59	5.33	97.9
3-02	120.0	0.35	0.97	612.030	295	78	74	0.59	5.42	99.5
3-03	130.0	0.35	0.97	617.470	296	78	73	0.59	5.44	100.1
3-04	140.0	0.42	1.20	623.470	297	76	73	0.65	6.00	101.1
3-05	150.0	0.42	1.20	629.480	296	75	72	0.65	6.01	101.4
LEAK CHECK	150.0			629.610						
2-01	160.0	0.43	1.20	635.620	296	76	72	0.66	6.01	100.1
2-02	170.0	0.41	1.10	641.330	299	77	72	0.64	5.71	97.5
2-03	180.0	0.43	1.20	647.270	299	79	72	0.66	5.94	98.8
2-04	190.0	0.44	1.20	653.250	297	77	71	0.66	5.98	98.5
2-05	200.0	0.51	1.40	659.760	299	79	72	0.71	6.51	99.5
LEAK CHECK	200.0			659.900						
1-01	210.0	0.35	0.97	665.380	312	79	74	0.59	5.48	101.7
1-02	220.0	0.35	0.97	670.860	305	81	74	0.59	5.48	101.0
1-03	230.0	0.42	1.20	676.870	302	80	74	0.65	6.01	101.1
1-04	240.0	0.50	1.40	683.370	304	80	74	0.71	6.50	100.4
1-05	250.0	0.59	1.60	690.330	306	80	74	0.77	6.96	99.1
Final	250.0		1.05080	139.95500	298.24000	74.52000		0.61301	139.95500	

25 points sampled      Sq.Rt.ΔP  
**QC-Check: Field Averages**      **0.6130   1.0508   139.9550   298.2400   74.5200**      6.0% 2RSD  
 Avg. OK    Avg. OK    Avg. OK    Avg. OK    Avg. OK

042313 084310



### Field Data Printout

Location: Unit 2 FF Outlet  
 Test Run: 4  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: A. Obuchowski 567  
 Probe Operator: A. Obuchowski 567  
 Test Date: 3/27/13  
 Start Time: 07:21  
 Stop Time: 11:39  
 Leak Rate Before: 0.005 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 15 "Hg

**Test Method:**  
**Analyte:**

**USEPA Method 23**  
**PCDD/F**

Bar. Press. (in. Hg): 30.10  
 Static P: -11.2  
 O<sub>2</sub> (dry volume %): 9.12  
 CO<sub>2</sub> (dry volume %): 10.13  
 N<sub>2</sub>+CO (dry volume %): 80.75

Nozzle ID No: 2722-1  
 Nozzle Diameter (D<sub>n</sub>): 0.272  
 Probe ID No: 67-8-16  
 Pitot C<sub>p</sub>: 0.825  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 716.8  
 H<sub>2</sub>O (silica, g): 57.6  
 Actual Moisture (%): 20.37

Meter Box ID. No: 66-22  
 Meter ΔH@: 1.88400  
 Meter Y<sub>d</sub>: 0.99720

Traverse Point	Run Time 10.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			690.914						
2-01	10.0	0.34	0.93	696.090	295	49	47	0.58	5.18	102.9
2-02	20.0	0.36	0.99	701.370	298	51	48	0.60	5.28	101.9
2-03	30.0	0.44	1.20	707.130	299	54	49	0.66	5.76	100.3
2-04	40.0	0.40	1.10	712.700	299	58	52	0.63	5.57	101.0
2-05	50.0	0.45	1.20	718.550	304	59	54	0.67	5.85	100.1
LEAK CHECK	50.0			718.730						
1-01	60.0	0.33	0.90	723.860	296	58	57	0.57	5.13	101.7
1-02	70.0	0.38	1.00	729.250	292	57	57	0.62	5.39	99.4
1-03	80.0	0.30	0.82	734.240	300	59	58	0.55	4.99	103.8
1-04	90.0	0.38	1.00	739.760	288	61	60	0.62	5.52	100.9
1-05	100.0	0.42	1.20	745.620	290	60	61	0.65	5.86	102.0
LEAK CHECK	100.0			745.910						
5-01	110.0	0.22	0.60	750.150	291	61	62	0.47	4.24	101.7
5-02	120.0	0.28	0.77	755.030	293	62	63	0.53	4.88	103.8
5-03	130.0	0.33	0.90	760.270	292	62	63	0.57	5.24	102.6
5-04	140.0	0.35	0.96	765.640	291	63	64	0.59	5.37	101.8
5-05	150.0	0.39	1.10	771.360	292	63	64	0.62	5.72	102.9
LEAK CHECK	150.0			771.500						
4-01	160.0	0.35	0.96	776.820	289	64	64	0.59	5.32	100.7
4-02	170.0	0.36	0.99	782.300	291	67	66	0.60	5.48	101.9
4-03	180.0	0.39	1.10	788.060	293	67	67	0.62	5.76	103.0
4-04	190.0	0.48	1.30	794.310	294	68	68	0.69	6.25	100.6
4-05	200.0	0.51	1.40	800.730	295	70	70	0.71	6.42	100.0
LEAK CHECK	200.0			800.900						
3-01	210.0	0.42	1.20	806.850	300	67	68	0.65	5.95	102.9
3-02	220.0	0.43	1.20	812.720	302	67	66	0.66	5.87	100.7
3-03	230.0	0.44	1.20	818.700	300	66	64	0.66	5.98	101.5
3-04	240.0	0.55	1.50	825.140	304	67	64	0.74	6.44	98.0
3-05	250.0	0.52	1.40	831.610	305	68	63	0.72	6.47	101.3
Final	250.0		1.07680	139.91600	295.72000	61.34000		0.62378	139.91600	
25 points sampled		Sq. Rt. ΔP								
QC-Check: Field Averages		0.6238	1.0768	139.9200	295.7200	61.3400				
		<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK				

042313 984310

### USEPA Method 3 Laboratory Data

Location: Unit 2 FF Outlet  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Method: EPA Method 3  
 Fuel Type: Municipal Waste  
 F<sub>o</sub> for Fuel: 1.03 to 1.3

Test Method:  
 Analyte:

USEPA Method 23  
 PCDD/F

Analyst: S. Brown  
 Analyst Emp No: 433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		<span style="border: 1px solid black; padding: 2px;">10.34000</span>		<span style="border: 1px solid black; padding: 2px;">8.63000</span>	81.03000	29.99960	1.18665	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		<span style="border: 1px solid black; padding: 2px;">9.80000</span>		<span style="border: 1px solid black; padding: 2px;">9.48000</span>	80.72000	29.94720	1.16531	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
4	1							
	2							
	3							
Avg.								
CEM or Other Avg:		<span style="border: 1px solid black; padding: 2px;">10.13000</span>		<span style="border: 1px solid black; padding: 2px;">9.12000</span>	80.75000	29.98560	1.16288	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:		<span style="border: 1px solid black; padding: 2px;"></span>		<span style="border: 1px solid black; padding: 2px;"></span>				<input type="checkbox"/> Fo value within expected range.

042313 084310  
 P.J.J.®

**USEPA Method 4 Laboratory Data**

Location: Unit 2 FF Outlet  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218

**Test Method:** USEPA Method 23  
**Analyte:** PCDD/F

**Analyst:** D. Luckhard  
**Analyst Emp No:** 568

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	1332.7	642.0	690.7		
Impinger 2	HPLC Water	508.9	510.1	-1.2		
Impinger 3	HPLC Water	517.3	517.6	-0.3		
Impinger 4	Empty	426.0	420.9	5.1		
Impinger 5	XAD Trap	379.8	358.4	21.4		
Impinger 6	Silica Gel	793.7	741.0	52.7	715.7 Liquid (gm)	<i>Field Data Check</i>
Impinger 7					0.0 less rinse (gm)	
Impinger 8					715.7 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 52.7 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					768.4 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK

Rinse:            (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	1283.7	633.5	650.2		
Impinger 2	HPLC Water	545.6	548.2	-2.6		
Impinger 3	HPLC Water	553.3	553.5	-0.2		
Impinger 4	Empty	420.1	420.1	0.0		
Impinger 5	XAD Trap	425.2	404.8	20.4		
Impinger 6	Silica Gel	755.9	705.1	50.8	667.8 Liquid (gm)	<i>Field Data Check</i>
Impinger 7					0.0 less rinse (gm)	
Impinger 8					667.8 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 50.8 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					718.6 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK

Rinse:            (ml or gm)

Test Run: 4

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	1334.0	640.7	693.3		
Impinger 2	HPLC Water	523.7	523.2	0.5		
Impinger 3	HPLC Water	531.0	529.7	1.3		
Impinger 4	Empty	430.2	430.2	0.0		
Impinger 5	XAD Trap	343.1	321.4	21.7		
Impinger 6	Silica Gel	791.8	734.2	57.6	716.8 Liquid (gm)	<i>Field Data Check</i>
Impinger 7					0.0 less rinse (gm)	
Impinger 8					716.8 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 57.6 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					774.4 Total Vlc (gm)	<input checked="" type="checkbox"/> QA/QC OK

Rinse:            (ml or gm)

Test Run:           

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty					
Impinger 2	HPLC Water					
Impinger 3	HPLC Water					
Impinger 4	Empty					
Impinger 5	XAD Trap					
Impinger 6	Silica Gel				Liquid (gm)	<i>Field Data Check</i>
Impinger 7					less rinse (gm)	
Impinger 8					Net Liquid (gm)	<input type="checkbox"/> QA/QC OK
					Silica Gel (gm)	<input type="checkbox"/> QA/QC OK
					Total Vlc (gm)	<input type="checkbox"/> QA/QC OK

Rinse:            (ml or gm)

042313 084310  
 PJJ

**Field Data Printout**

**Test Method:**  
**Analyte:**

**USEPA Method 26A**  
**HCl**

Location: Unit 2 SDA Inlet  
 Test Run: 1  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 60.13205  
 Meter Operator: S. Joint 473  
 Probe Operator: S. Joint 473  
 Test Date: 3/27/13  
 Start Time: 07:47  
 Stop Time: 08:47  
 Leak Rate Before: 0.003 cfm @ 15 \*Hg  
 Leak Rate After: 0.003 cfm @ 10 \*Hg

Bar. Press. (in. Hg): 30.10  
 Static P: -1.5  
 O<sub>2</sub> (dry volume %): 8.23  
 CO<sub>2</sub> (dry volume %): 11.04  
 N<sub>2</sub>+CO (dry volume %): 80.73

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 66-4-7  
 Pitot C<sub>p</sub>: 0.834  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 151.9  
 H<sub>2</sub>O (silica, g): 13.6  
 Actual Moisture (%): 17.66

Meter Box ID No: 61-11  
 Meter ΔH@: 1.69640  
 Meter Y<sub>d</sub>: 1.00500

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			801.920						
1-01	5.0		1.20	804.990	494	70	69		3.07	
1-01	10.0		1.20	808.050	494	70	69		3.06	
1-01	15.0		1.20	811.020	494	69	68		2.97	
1-01	20.0		1.20	813.990	492	69	67		2.97	
1-01	25.0		1.20	816.970	492	69	67		2.98	
1-01	30.0		1.20	819.980	492	69	66		3.01	
1-01	35.0		1.20	823.000	490	70	66		3.02	
1-01	40.0		1.20	825.990	489	71	65		2.99	
1-01	45.0		1.20	828.950	489	72	65		2.96	
1-01	50.0		1.20	831.320	489	72	65		2.37	
1-01	55.0		1.20	834.800	490	72	66		3.48	
1-01	60.0		1.20	837.780	491	72	66		2.98	
Final	60.0		1.20000	35.86000	491.33333	68.50000			35.86000	

1 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	1.2000	35.8600	491.3333	68.5000
----------	--------	---------	----------	---------

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 084408  
 N

**Field Data Printout**

**Test Method:**  
**Analyte:**

**USEPA Method 26A**  
**HCl**

Location: Unit 2 SDA Inlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 60.13205

Bar. Press. (in. Hg): 30.10  
 Static P: -1.4  
 O<sub>2</sub> (dry volume %): 8.38  
 CO<sub>2</sub> (dry volume %): 10.98  
 N<sub>2</sub>+CO (dry volume %): 80.64

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 66-4-7  
 Pitot Cp: 0.834  
 Pitot Leak Check:  Pass  Fail

Meter Operator: S. Joint 473  
 Probe Operator: S. Joint 473

Test Date: 3/27/13  
 Start Time: 09:08  
 Stop Time: 10:08  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 15 "Hg

H<sub>2</sub>O (condensate, ml or gm): 140.6  
 H<sub>2</sub>O (silica, g): 7.8  
 Actual Moisture (%): 16.37

Meter Box ID. No: 61-11  
 Meter ΔH@: 1.69640  
 Meter Y<sub>g</sub>: 1.00500

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			838.000						
1-01	5.0		1.20	841.010	496	80	78		3.01	
1-01	10.0		1.20	844.020	495	81	79		3.01	
1-01	15.0		1.20	847.030	495	82	79		3.01	
1-01	20.0		1.20	850.040	497	83	80		3.01	
1-01	25.0		1.20	853.050	497	83	80		3.01	
1-01	30.0		1.20	856.220	496	83	80		3.17	
1-01	35.0		1.20	859.220	495	85	80		3.00	
1-01	40.0		1.20	862.170	494	85	81		2.95	
1-01	45.0		1.20	865.160	495	86	81		2.99	
1-01	50.0		1.20	868.180	497	87	82		3.02	
1-01	55.0		1.20	871.190	499	87	82		3.01	
1-01	60.0		1.20	874.150	497	88	83		2.96	
Final	60.0		1.20000	36.15000	496.08333	82.29167			36.15000	

1 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	1.2000	36.1500	496.0833	82.2917
----------	--------	---------	----------	---------

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 084408  
 K

**Field Data Printout**

**Test Method:**  
**Analyte:**

**USEPA Method 26A**  
**HCl**

Location: Unit 2 SDA Inlet  
 Test Run: 3  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 60.13205  
 Meter Operator: S. Joint 473  
 Probe Operator: S. Joint 473  
 Test Date: 3/27/13  
 Start Time: 10:27  
 Stop Time:  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 15 "Hg

Bar. Press. (in. Hg): 30.10  
 Static P: -1.4  
 O<sub>2</sub> (dry volume %): 9.32  
 CO<sub>2</sub> (dry volume %): 9.94  
 N<sub>2</sub>+CO (dry volume %): 80.74

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 66-4-7  
 Pitot C<sub>p</sub>: 0.834  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm):  
 H<sub>2</sub>O (silica, g):  
 #VALUE! #VALUE!

Meter Box ID. No: 61-11  
 Meter ΔH@: 1.69640  
 Meter Y<sub>d</sub>: 1.00500

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			874.500						
1-01	5.0		1.20	877.550	511	89	86		3.05	
1-01	10.0		1.20	880.500	510	89	86		2.95	
1-01	15.0		1.20	883.420	511	90	87		2.92	
1-01	20.0		1.20	886.340	511	92	87		2.92	
1-01	25.0		1.20	889.260	510	93	87		2.92	
1-01	30.0		1.20	892.180	514	92	88		2.92	
1-01	35.0		1.20	895.030	512	92	88		2.85	
1-01	40.0		1.20	897.880	511	98	88		2.85	
1-01	42.0		1.20	899.000	511	103	88		1.12	
<b>Final</b>	<b>42.0</b>		<b>1.20000</b>	<b>24.50000</b>	<b>511.23810</b>	<b>89.78571</b>			<b>24.50000</b>	

1 points sampled  
 QC-Check: Field Averages

Sq. Rt. ΔP	Voided Run	
1.2000	24.5000	511.2381 89.7857

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 084406  
 ©

USEPA Method 3 Laboratory Data

Test Method:  
Analyte:

USEPA Method 26A  
HCI

Location: Unit 2 SDA Inlet

Client: Wheelabrator South Broward, Inc.

Project No: 12218

Method: EPA Method 3

Fuel Type: Municipal Waste

F<sub>o</sub> for Fuel: 1.03 to 1.3

Analyst: S. Brown

Analyst Emp No: 433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		11.04000		8.23000	80.73000	30.09560	1.14764	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.98000		8.38000	80.64000	30.09200	1.14026	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.94000		9.32000	80.74000	29.96320	1.16499	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

042313 084408  
NK@@

**USEPA Method 4 Laboratory Data**

Location: Unit 2 SDA Inlet  
 Client: Wheelabrator South Broward, Inc.

**Test Method: USEPA Method 26A**  
**Analyte: HCl**

Project No: 12218

Analyst: D. Luckhard  
 Analyst Emp No: 568

Test Run: 1

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	475.5	455.0	20.5
Impinger 2	100 ml 0.1N H2SO4	644.2	544.2	100.0
Impinger 3	100 ml 0.1N H2SO4	561.7	535.7	26.0
Impinger 4	Empty	487.7	482.3	5.4
Impinger 5	Silica Gel	740.3	726.7	13.6
Impinger 6				
Impinger 7				
Impinger 8				

Field Data Check	
151.9 Liquid (gm)	
0.0 less rinse (gm)	
151.9 Net Liquid (gm)	151.9
+ 13.6 Silica Gel (gm)	13.6
165.5 Total Vlc (gm)	165.5

Rinse:          (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	503.0	464.3	38.7
Impinger 2	100 ml 0.1N H2SO4	631.2	545.9	85.3
Impinger 3	100 ml 0.1N H2SO4	582.8	567.6	15.2
Impinger 4	Empty	423.7	422.3	1.4
Impinger 5	Silica Gel	739.0	731.2	7.8
Impinger 6				
Impinger 7				
Impinger 8				

Field Data Check	
140.6 Liquid (gm)	
0.0 less rinse (gm)	
140.6 Net Liquid (gm)	140.6
+ 7.8 Silica Gel (gm)	7.8
148.4 Total Vlc (gm)	148.4

Rinse:          (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4		456.6	
Impinger 2	100 ml 0.1N H2SO4		552.0	
Impinger 3	100 ml 0.1N H2SO4		532.8	
Impinger 4	Empty		482.8	
Impinger 5	Silica Gel		740.3	
Impinger 6				
Impinger 7				
Impinger 8				

Field Data Check	
Liquid (gm)	
less rinse (gm)	
Net Liquid (gm)	
Silica Gel (gm)	
Total Vlc (gm)	

Rinse:          (ml or gm)

Test Run:         

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1				
Impinger 2				
Impinger 3				
Impinger 4				
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

Field Data Check	
Liquid (gm)	
less rinse (gm)	
Net Liquid (gm)	
Silica Gel (gm)	
Total Vlc (gm)	

Rinse:          (ml or gm)

Test Run:         

042313 064408  
 NK



### Field Data Printout

**Test Method:**

**USEPA Method 26A**

**Analyte:**

**HCl**

Location: Unit 2 FF Outlet  
 Test Run: 1  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: W. Berry 456  
 Probe Operator:

Bar. Press. (in. Hg): 30.10  
 Static P: -11.2  
 O<sub>2</sub> (dry volume %): 8.77  
 CO<sub>2</sub> (dry volume %): 10.51  
 N<sub>2</sub>+CO (dry volume %): 80.72

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 67-4-3  
 Pitot C<sub>p</sub>: N/A  
 Pitot Leak Check:  Pass  Fail

Test Date: 3/27/13  
 Start Time: 07:47  
 Stop Time: 08:47  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.002 cfm @ 10 "Hg

H<sub>2</sub>O (condensate, ml or gm): 205.8  
 H<sub>2</sub>O (silica, g): 14.9  
 Actual Moisture (%): 20.19

Meter Box ID. No: 66-11  
 Meter ΔH@: 1.82740  
 Meter Y<sub>d</sub>: 0.99060

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dof)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			54.475						
3-01	5.0		1.50	57.800	294	51	50		3.33	
3-01	10.0		1.50	61.100	292	54	51		3.30	
3-01	15.0		1.50	64.420	296	56	53		3.32	
3-01	20.0		1.50	67.740	302	58	54		3.32	
3-01	25.0		1.50	71.100	296	59	56		3.36	
3-01	30.0		1.50	74.470	298	58	58		3.37	
3-01	35.0		1.50	77.850	299	59	59		3.38	
3-01	40.0		1.50	81.240	293	59	60		3.39	
3-01	45.0		1.50	84.580	295	61	61		3.34	
3-01	50.0		1.50	88.060	300	60	62		3.48	
3-01	55.0		1.50	91.340	298	62	63		3.28	
3-01	60.0		1.50	94.745	290	62	64		3.41	
Final	60.0		1.50000	40.27000	296.08333	57.91667			40.27000	

3 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	1.5000	40.2700	296.0833	57.9166
----------	--------	---------	----------	---------

Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK  
  Avg. OK

042313 084432  
N

### Field Data Printout

Location: Unit 2 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: W. Berry 456  
 Probe Operator:  
 Test Date: 3/27/13  
 Start Time: 09:08  
 Stop Time: 10:08  
 Leak Rate Before: 0.004 cfm @ 15 "Hg  
 Leak Rate After: 0.002 cfm @ 10 "Hg

**Test Method:**  
**Analyte:**

**USEPA Method 26A**  
**HCl**

Bar. Press. (in. Hg): 30.10  
 Static P: -11.1  
 O<sub>2</sub> (dry volume %): 8.87  
 CO<sub>2</sub> (dry volume %): 10.49  
 N<sub>2</sub>+CO (dry volume %): 80.64

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 67-4-3  
 Pitot C<sub>p</sub>: N/A  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 211.4  
 H<sub>2</sub>O (silica, g): 13.3  
 Actual Moisture (%): 20.54

Meter Box ID. No: 66-11  
 Meter ΔH@: 1.82740  
 Meter Y<sub>d</sub>: 0.99060

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			95.380						
3-01	5.0		1.50	98.740	294	61	67		3.36	
3-01	10.0		1.50	102.110	294	62	68		3.37	
3-01	15.0		1.50	105.480	293	63	68		3.37	
3-01	20.0		1.50	108.880	294	62	67		3.40	
3-01	25.0		1.50	112.270	294	64	67		3.39	
3-01	30.0		1.50	115.670	296	65	68		3.40	
3-01	35.0		1.50	119.090	292	65	68		3.42	
3-01	40.0		1.50	122.500	295	64	68		3.41	
3-01	45.0		1.50	125.910	293	65	68		3.41	
3-01	50.0		1.50	129.310	295	65	68		3.40	
3-01	55.0		1.50	132.800	292	67	69		3.49	
3-01	60.0		1.50	136.135	297	68	69		3.33	
Final	60.0		1.50000	40.75500	294.08333	66.08333			40.75500	

3 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP				
	1.5000	40.7550	294.0833	66.0833

Avg. OK   
 Avg. OK   
 Avg. OK   
 Avg. OK   
 Avg. OK

042313 084432  
N

**Field Data Printout**

**Test Method:**  
**Analyte:**

**USEPA Method 26A**  
**HCl**

Location: Unit 2 FF Outlet  
 Test Run: 3  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000

Meter Operator: S. Joint 473  
 Probe Operator: W. Berry 456

Test Date: 3/27/13  
 Start Time: 10:27  
 Stop Time: 11:27  
 Leak Rate Before: 0.002 cfm @ 15 "Hg  
 Leak Rate After: 0.001 cfm @ 10 "Hg

Bar. Press. (in. Hg): 30.10  
 Static P: -12.1  
 O<sub>2</sub> (dry volume %): 9.70  
 CO<sub>2</sub> (dry volume %): 9.67  
 N<sub>2</sub>+CO (dry volume %): 80.63

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 67-4-3  
 Pitot C<sub>p</sub>: N/A  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 212.4  
 H<sub>2</sub>O (silica, g): 15.5  
 Actual Moisture (%): 20.94

Meter Box ID. No: 66-11  
 Meter ΔH@: 1.82740  
 Meter Y<sub>d</sub>: 0.99060

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
2-01	0.0		1.50	136.570	299	69	72		3.42	
2-01	5.0		1.50	143.380	295	72	73		3.39	
2-01	10.0		1.50	146.780	296	72	74		3.40	
2-01	15.0		1.50	150.150	296	72	74		3.37	
2-01	20.0		1.50	153.540	298	70	72		3.39	
2-01	25.0		1.50	156.940	298	70	72		3.40	
2-01	30.0		1.50	160.350	298	72	73		3.41	
2-01	35.0		1.50	163.740	296	70	72		3.39	
2-01	40.0		1.50	167.120	298	65	68		3.38	
2-01	45.0		1.50	170.480	295	65	66		3.36	
2-01	50.0		1.50	173.830	297	66	65		3.35	
2-01	55.0		1.50	177.210	298	65	64		3.38	
2-01	60.0		1.50							
Final	60.0		1.50000	40.64000	297.00000	69.70833			40.64000	

2 points sampled

Sq.Rt.ΔP	1.5000	40.6400	297.0000	69.7083
----------	--------	---------	----------	---------

QC-Check: Field Averages

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 084432  
Q

USEPA Method 3 Laboratory Data

Test Method:  
Analyte:

USEPA Method 26A  
HCl

Location: Unit 2 FF Outlet  
Client: Wheelabrator South Broward, Inc.  
Project No: 12218  
Method: EPA Method 3  
Fuel Type: Municipal Waste  
F<sub>o</sub> for Fuel: 1.03 to 1.3

Analyst: S. Brown  
Analyst Emp No: 433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.51000		8.77000	80.72000	30.03240	1.15414	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.49000		8.87000	80.64000	30.03320	1.14681	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.67000		9.70000	80.63000	29.93520	1.15822	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis:
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

042313 084432  
NNQ@

**USEPA Method 4 Laboratory Data**

Location: Unit 2 FF Outlet  
 Client: Wheelabrator South Broward, Inc.

Test Method: **USEPA Method 26A**  
 Analyte: **HCl**

Project No: 12218

Analyst: H. Nguyen

Analyst Emp No: 429

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	493.5	458.5	35.0
Impinger 2	100 ml 0.1N H2SO4	654.8	548.0	106.8
Impinger 3	100 ml 0.1N H2SO4	590.5	539.7	50.8
Impinger 4	Empty	481.5	468.3	13.2
Impinger 5	Silica Gel	702.8	687.9	14.9
Impinger 6				
Impinger 7				
Impinger 8				

205.8 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
205.8 Net Liquid (gm)	<input type="text" value="205.8"/>
+ 14.9 Silica Gel (gm)	<input type="text" value="14.9"/>
220.7 Total Vlc (gm)	<input type="text" value="220.7"/>

- QA/QC OK
- QA/QC OK
- QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	481.2	437.5	43.7
Impinger 2	100 ml 0.1N H2SO4	660.0	547.6	112.4
Impinger 3	100 ml 0.1N H2SO4	573.8	527.9	45.9
Impinger 4	Empty	450.2	440.8	9.4
Impinger 5	Silica Gel	730.1	716.8	13.3
Impinger 6				
Impinger 7				
Impinger 8				

211.4 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
211.4 Net Liquid (gm)	<input type="text" value="211.4"/>
+ 13.3 Silica Gel (gm)	<input type="text" value="13.3"/>
224.7 Total Vlc (gm)	<input type="text" value="224.7"/>

- QA/QC OK
- QA/QC OK
- QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	494.4	452.0	42.4
Impinger 2	100 ml 0.1N H2SO4	661.3	545.8	115.5
Impinger 3	100 ml 0.1N H2SO4	595.6	550.0	45.6
Impinger 4	Empty	476.9	468.0	8.9
Impinger 5	Silica Gel	717.9	702.4	15.5
Impinger 6				
Impinger 7				
Impinger 8				

212.4 Liquid (gm)	<i>Field Data Check</i>
0.0 less rinse (gm)	
212.4 Net Liquid (gm)	<input type="text" value="212.4"/>
+ 15.5 Silica Gel (gm)	<input type="text" value="15.5"/>
227.9 Total Vlc (gm)	<input type="text" value="227.9"/>

- QA/QC OK
- QA/QC OK
- QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1				
Impinger 2				
Impinger 3				
Impinger 4				
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

Liquid (gm)	<i>Field Data Check</i>
less rinse (gm)	
Net Liquid (gm)	<input type="text"/>
Silica Gel (gm)	<input type="text"/>
Total Vlc (gm)	<input type="text"/>

- QA/QC OK
- QA/QC OK
- QA/QC OK

Rinse:  (ml or gm)

042313 084432  
 NN Q 8

**Field Data Printout**

**Test Method:**  
**Analyte:**

**USEPA Method 5/29**  
**Particulate/Metals**

Location: Unit 3 FF Outlet

Test Run: 1

Client: Wheelabrator South Broward, Inc.

Project No: 12218

Source Area (ft<sup>2</sup>): 64.00000

Meter Operator:	S. Joint	473
Probe Operator:	W. Berry	456

Test Date: 3/26/13

Start Time: 12:11

Stop Time: 14:24

Leak Rate Before:	0.002	cfm	@ 15 "Hg
Leak Rate After:	0.002	cfm	@ 12 "Hg

Bar. Press. (in. Hg):	29.90
Static P:	-9.8

O<sub>2</sub> (dry volume %): 9.80  
CO<sub>2</sub> (dry volume %): 9.42  
N<sub>2</sub>+CO (dry volume %): 80.78

Nozzle ID No:	0.2725-2
Nozzle Diameter (D <sub>n</sub> ):	0.273
Probe ID No:	67-8-17
Pitot C <sub>p</sub> :	0.824
Pitot Leak Check:	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail

H<sub>2</sub>O (condensate, ml or gm): 341.6  
H<sub>2</sub>O (silica, g): 10.9  
Actual Moisture (%): 20.17

Meter Box ID. No:	66-6
Meter ΔH@:	1.82800
Meter Y <sub>d</sub> :	0.98540

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
1-01	5.0	0.32	0.87	384.820	292	74	71	0.57	2.63	100.5
1-02	10.0	0.22	0.60	389.670	290	77	71	0.47	2.22	101.8
1-03	15.0	0.25	0.70	391.880	293	78	72	0.50	2.21	95.1
1-04	20.0	0.31	0.87	394.480	293	80	73	0.56	2.60	100.2
1-05	25.0	0.33	0.92	397.240	292	81	73	0.57	2.76	103.0
LEAK CHECK	25.0			397.430						
2-01	30.0	0.44	1.20	400.430	294	81	73	0.66	3.00	97.1
2-02	35.0	0.47	1.30	403.600	294	82	73	0.69	3.17	99.2
2-03	40.0	0.40	1.10	406.500	294	84	74	0.63	2.90	98.1
2-04	45.0	0.33	0.92	409.200	294	84	74	0.57	2.70	100.5
2-05	50.0	0.35	0.98	411.960	296	84	75	0.59	2.76	99.8
LEAK CHECK	50.0			412.180						
3-01	55.0	0.32	0.90	414.850	295	85	77	0.57	2.67	100.6
3-02	60.0	0.38	1.10	417.810	295	86	77	0.62	2.96	102.3
3-03	65.0	0.36	1.00	420.520	294	88	78	0.60	2.71	95.9
3-04	70.0	0.32	0.90	423.190	294	88	78	0.57	2.67	100.2
3-05	75.0	0.29	0.81	425.650	293	88	79	0.54	2.46	96.8
LEAK CHECK	75.0			425.760						
4-01	80.0	0.34	0.92	428.470	294	86	79	0.58	2.71	99.3
4-02	85.0	0.32	0.90	431.110	294	86	79	0.57	2.64	99.1
4-03	90.0	0.36	1.00	433.870	295	86	79	0.60	2.76	97.8
4-04	95.0	0.39	1.10	436.860	295	88	79	0.62	2.99	101.6
4-05	100.0	0.36	1.00	439.730	295	88	79	0.60	2.87	101.5
LEAK CHECK	100.0			439.870						
5-01	105.0	0.30	0.84	444.870	294	85	79	0.55	5.00	194.0*
5-02	110.0	0.32	0.90	447.500	294	85	78	0.57	2.63	98.9
5-03	115.0	0.43	1.20	450.720	295	88	79	0.66	3.22	104.2
5-04	120.0	0.38	1.10	452.150	295	88	79	0.62	1.43	49.2*
5-05	125.0	0.36	1.00	453.570	295	88	79	0.60	1.42	50.2*
Final	125.0		0.96520	68.09000	293.96000	80.30000		0.58621	68.09000	

25 points sampled  
QC-Check: Field Averages

Sq.Rt.ΔP	0.5860	0.9652	68.0900	293.9600	80.3000
	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

042319 084654  
N

### Field Data Printout

**Test Method:**

**USEPA Method 5/29**

**Analyte:**

**Particulate/Metals**

Location: Unit 3 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000

Bar. Press. (in. Hg): 30.18  
 Static P: -9.8  
 O<sub>2</sub> (dry volume %): 9.23  
 CO<sub>2</sub> (dry volume %): 10.07  
 N<sub>2</sub>+CO (dry volume %): 80.70

Nozzle ID No: 0.2725-2  
 Nozzle Diameter (D<sub>n</sub>): 0.273  
 Probe ID No: 67-8-17  
 Pitot C<sub>p</sub>: 0.824  
 Pitot Leak Check:  Pass  Fail

Meter Operator: P. Bihun 505  
 Probe Operator: P. Bihun 505

H<sub>2</sub>O (condensate, ml or gm): 336.9  
 H<sub>2</sub>O (silica, g): 14.8  
 Actual Moisture (%): 19.37

Meter Box ID No: 66-6  
 Meter ΔH@: 1.82800  
 Meter Y<sub>d</sub>: 0.98540

Test Date: 3/27/13  
 Start Time: 07:28  
 Stop Time: 09:41  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 10 "Hg

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			454.160						
5-01	5.0	0.38	0.99	456.940	328	53	52	0.62	2.78	103.4
5-02	10.0	0.36	0.94	459.610	326	56	52	0.60	2.67	101.6
5-03	15.0	0.35	0.91	462.210	328	59	53	0.59	2.60	100.1
5-04	20.0	0.43	1.10	465.150	329	60	53	0.66	2.94	102.1
5-05	25.0	0.44	1.10	468.085	330	62	54	0.66	2.94	100.5
LEAK CHECK	25.0			468.155						
4-01	30.0	0.41	1.10	471.110	329	61	55	0.64	2.96	104.8
4-02	35.0	0.38	0.99	473.870	326	64	56	0.62	2.76	101.1
4-03	40.0	0.36	0.94	476.560	327	65	56	0.60	2.69	101.1
4-04	45.0	0.38	0.99	479.360	328	64	57	0.62	2.80	102.6
4-05	50.0	0.33	0.86	481.925	327	65	57	0.57	2.57	100.6
LEAK CHECK	50.0			481.985						
3-01	55.0	0.26	0.68	484.260	326	62	58	0.51	2.27	100.6
3-02	60.0	0.37	0.96	486.970	328	63	58	0.61	2.71	100.6
3-03	65.0	0.40	1.00	489.760	329	65	58	0.63	2.79	99.5
3-04	70.0	0.35	0.91	492.420	330	65	59	0.59	2.66	101.3
3-05	75.0	0.34	0.88	495.000	324	66	59	0.58	2.58	99.2
LEAK CHECK	75.0			495.090						
2-01	80.0	0.55	1.40	498.410	330	64	59	0.74	3.32	101.1
2-02	85.0	0.41	1.10	501.350	332	67	60	0.64	2.94	103.4
2-03	90.0	0.44	1.10	504.190	325	67	60	0.66	2.84	96.0
2-04	95.0	0.38	0.99	506.970	321	67	60	0.62	2.78	100.8
2-05	100.0	0.35	0.91	509.630	324	67	61	0.59	2.66	100.6
LEAK CHECK	100.0			509.705						
1-01	105.0	0.22	0.57	511.750	309	64	61	0.47	2.05	96.8
1-02	110.0	0.28	0.73	514.120	309	65	61	0.53	2.37	99.4
1-03	115.0	0.35	0.91	516.760	329	67	62	0.59	2.64	100.0
1-04	120.0	0.38	0.99	519.560	332	68	62	0.62	2.80	101.9
1-05	125.0	0.45	1.20	522.710	328	69	62	0.67	3.15	105.1
Final	125.0		0.97000	68.25500	326.16000	60.80000		0.60922	68.25500	

25 points sampled      Sq.Rt.ΔP  
**QC-Check: Field Averages**      **0.6092**   **0.9700**   **68.2550**   **326.1600**   **60.8000**  
 Avg. OK    Avg. OK    Avg. OK    Avg. OK    Avg. OK

042313 084834  
 N

### Field Data Printout

Location: Unit 3 FF Outlet  
 Test Run: 3  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: P. Bihun 505  
 Probe Operator: P. Bihun 505  
 Test Date: 3/27/13  
 Start Time: 09:59  
 Stop Time: 12:11  
 Leak Rate Before: 0.002 cfm @ 15 "Hg  
 Leak Rate After: 0.002 cfm @ 10 "Hg

**Test Method:**  
**Analyte:**

**USEPA Method 5/29**  
**Particulate/Metals**

Bar. Press. (in. Hg): 30.10  
 Static P: -10.7  
 O<sub>2</sub> (dry volume %): 9.70  
 CO<sub>2</sub> (dry volume %): 9.60  
 N<sub>2</sub>+CO (dry volume %): 80.70

Nozzle ID No: 0.2725-2  
 Nozzle Diameter (D<sub>n</sub>): 0.273  
 Probe ID No: 67-8-17  
 Pitot C<sub>p</sub>: 0.824  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 315.6  
 H<sub>2</sub>O (silica, g): 16.1  
 Actual Moisture (%): 18.37

Meter Box ID No: 66-6  
 Meter ΔH@: 1.82800  
 Meter Y<sub>d</sub>: 0.98540

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			523.105						
5-01	5.0	0.33	0.86	525.740	330	66	66	0.57	2.63	101.4
5-02	10.0	0.33	0.86	528.340	332	71	67	0.57	2.60	99.7
5-03	15.0	0.35	0.91	530.980	331	75	68	0.59	2.64	97.7
5-04	20.0	0.36	0.94	533.730	332	77	70	0.60	2.75	100.1
5-05	25.0	0.32	0.83	536.260	330	78	71	0.57	2.53	97.3
LEAK CHECK	25.0			536.335						
4-01	30.0	0.41	1.10	539.230	331	77	73	0.64	2.89	98.4
4-02	35.0	0.48	1.30	542.510	333	80	74	0.69	3.28	102.9
4-03	40.0	0.34	0.88	545.140	334	83	76	0.58	2.63	97.5
4-04	45.0	0.35	0.91	547.810	337	82	77	0.59	2.67	97.8
4-05	50.0	0.35	0.91	550.485	326	81	77	0.59	2.68	97.4
LEAK CHECK	50.0			550.540						
3-01	55.0	0.47	1.20	553.640	329	80	78	0.69	3.10	97.6
3-02	60.0	0.47	1.20	556.730	333	83	78	0.69	3.09	97.3
3-03	65.0	0.44	1.10	559.850	332	84	79	0.66	3.12	101.2
3-04	70.0	0.40	1.00	562.680	332	81	79	0.63	2.83	96.6
3-05	75.0	0.38	0.99	565.485	331	81	79	0.62	2.81	98.1
LEAK CHECK	75.0			565.530						
2-01	80.0	0.46	1.20	568.650	332	80	79	0.68	3.12	99.4
2-02	85.0	0.48	1.30	571.880	331	82	79	0.69	3.23	100.5
2-03	90.0	0.50	1.30	575.120	333	82	79	0.71	3.24	98.9
2-04	95.0	0.38	0.99	577.950	333	84	79	0.62	2.83	98.8
2-05	100.0	0.37	0.96	580.695	335	82	79	0.61	2.75	97.5
LEAK CHECK	100.0			580.740						
1-01	105.0	0.34	0.88	583.370	314	82	79	0.58	2.63	96.1
1-02	110.0	0.28	0.73	585.730	317	81	79	0.53	2.36	95.3
1-03	115.0	0.42	1.10	588.780	326	81	79	0.65	3.05	101.2
1-04	120.0	0.40	1.00	591.610	327	82	78	0.63	2.83	96.2
1-05	125.0	0.40	1.00	594.445	327	82	78	0.63	2.84	96.4
Final	125.0		1.01800	71.12000	329.92000	77.94000		0.62468	71.12000	

25 points sampled  
 QC-Check: Field Averages  
 Sq.Rt.ΔP: 0.6247 1.0180 71.1200 329.9200 77.9400  
 Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

D42313 084634  
M



**Field Data Printout**

**Test Method:**

**USEPA Method 29**

**Analyte:**

**Mercury**

Location: Unit 3 FF Outlet

Test Run: 4

Client: Wheelabrator South Broward, Inc.

Project No: 12218

Source Area (ft<sup>2</sup>): 64.00000

Meter Operator:	P. Bihun	505
Probe Operator:	P. Bihun	505

Test Date: 3/27/13

Start Time: 12:29

Stop Time: 14:41

Leak Rate Before:	0.004	cfm	@ 15 "Hg
Leak Rate After:	0.003	cfm	@ 10 "Hg

Bar. Press. (in. Hg): 30.10

Static P: -10.7

O<sub>2</sub> (dry volume %): 10.02

CO<sub>2</sub> (dry volume %): 9.37

N<sub>2</sub>+CO (dry volume %): 80.61

Nozzle ID No: 0.2725-1

Nozzle Diameter (D<sub>n</sub>): 0.273

Probe ID No: 67-8-17

Pilot C<sub>p</sub>: 0.824

Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 342.0

H<sub>2</sub>O (silica, g): 14.2

Actual Moisture (%): 18.59

Meter Box ID. No: 66-6

Meter ΔH@: 1.82800

Meter Y<sub>d</sub>: 0.98540

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			594.720						
5-01	5.0	0.33	0.89	597.370	328	74	76	0.57	2.65	100.4
5-02	10.0	0.33	0.89	600.010	327	76	76	0.57	2.64	99.7
5-03	15.0	0.34	0.92	602.720	328	79	75	0.58	2.71	100.8
5-04	20.0	0.35	0.95	605.460	327	80	75	0.59	2.74	100.3
5-05	25.0	0.34	0.92	608.140	326	80	75	0.58	2.68	99.4
LEAK CHECK	25.0			608.210						
4-01	30.0	0.37	1.00	610.990	326	79	75	0.61	2.78	99.0
4-02	35.0	0.35	0.95	613.730	327	80	75	0.59	2.74	100.3
4-03	40.0	0.35	0.95	616.460	327	81	75	0.59	2.73	99.8
4-04	45.0	0.36	0.97	619.220	326	81	76	0.60	2.76	99.3
4-05	50.0	0.36	0.97	621.970	325	82	76	0.60	2.75	98.8
LEAK CHECK	50.0			622.015						
3-01	55.0	0.37	1.00	624.840	325	80	76	0.61	2.83	100.3
3-02	60.0	0.45	1.20	627.980	326	80	76	0.67	3.12	100.6
3-03	65.0	0.50	1.40	631.350	326	82	76	0.71	3.39	103.5
3-04	70.0	0.43	1.20	634.520	325	82	75	0.66	3.17	104.4
3-05	75.0	0.39	1.10	637.515	323	82	75	0.62	3.00	103.4
LEAK CHECK	75.0			637.550						
2-01	80.0	0.57	1.50	641.100	323	79	75	0.75	3.55	101.8
2-02	85.0	0.52	1.40	644.480	324	82	75	0.72	3.38	101.2
2-03	90.0	0.46	1.20	647.610	324	83	76	0.68	3.13	99.4
2-04	95.0	0.42	1.10	650.580	325	83	76	0.65	2.97	98.7
2-05	100.0	0.47	1.30	653.850	324	83	76	0.69	3.27	102.8
LEAK CHECK	100.0			653.895						
1-01	105.0	0.38	1.00	656.730	301	80	76	0.62	2.84	97.8
1-02	110.0	0.45	1.20	659.900	325	81	76	0.67	3.17	102.0
1-03	115.0	0.60	1.60	663.560	320	82	76	0.77	3.66	101.7
1-04	120.0	0.48	1.30	666.830	322	84	76	0.69	3.27	101.5
1-05	125.0	0.50	1.40	670.220	321	84	76	0.71	3.39	103.0
Final	125.0		1.13240	75.30500	324.04000	78.18000		0.64458	75.30500	

25 points sampled

Sq. Rt. ΔP

QC-Check: Field Averages

0.6446	1.1324	75.3050	324.0400	78.1800
--------	--------	---------	----------	---------

Avg. OK    Avg. OK    Avg. OK    Avg. OK    Avg. OK

042313 084858  
N

### USEPA Method 3 Laboratory Data

Location: Unit 3 FF Outlet  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Method: EPA Method 3  
 Fuel Type: Municipal Waste  
 F<sub>o</sub> for Fuel: 1.03 to 1.3

Test Method: USEPA Method 5/29 and 29  
 Analyte: Particulate/Metals and Mercury

Analyst: S. Brown  
 Analyst Emp No: 433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.42000	9.80000	80.78000	29.89920	1.17834	<input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.	

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.07000	9.23000	80.70000	29.98040	1.15889	<input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.	

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.60000	9.70000	80.70000	29.92400	1.16667	<input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.	

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
4	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.37000	10.02000	80.61000	29.90000	1.16115	<input checked="" type="checkbox"/> F <sub>o</sub> value within expected range.	

042313 064856  
 N N M N

**USEPA Method 4 Laboratory Data**

Location: Unit 3 FF Outlet

Client: Wheelabrator South Broward, Inc.

Project No: 12218

Test Run: 1

Test Method: USEPA Method 5/29 and 29

Analyte: Particulate/Metals and Mercury

Analyst: H. Nguyen

Analyst Emp No: 429

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	684.4	457.4	227.0		
Impinger 2	5%HNO3/10%H2O2	645.4	556.0	89.4		
Impinger 3	5%HNO3/10%H2O2	565.7	545.1	20.6		
Impinger 4	Empty	440.1	437.0	3.1		
Impinger 5	4%KMnO4/10%H2SO4	549.5	547.7	1.8		
Impinger 6	4%KMnO4/10%H2SO4	541.2	541.5	-0.3	341.6 Liquid (gm)	Field Data Check
Impinger 7	Silica Gel	760.4	749.5	10.9	0.0 less rinse (gm)	
Impinger 8					341.6 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 10.9 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					<b>352.5 Total Vlc (gm)</b>	<input checked="" type="checkbox"/> QA/QC OK

Rinse:            (ml or gm)

Test Run: 2

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	649.8	465.1	184.7		
Impinger 2	5%HNO3/10%H2O2	655.2	545.4	109.8		
Impinger 3	5%HNO3/10%H2O2	582.5	550.1	32.4		
Impinger 4	Empty	431.5	424.5	7.0		
Impinger 5	4%KMnO4/10%H2SO4	646.5	643.6	2.9		
Impinger 6	4%KMnO4/10%H2SO4	544.5	544.4	0.1	336.9 Liquid (gm)	Field Data Check
Impinger 7	Silica Gel	774.8	760.0	14.8	0.0 less rinse (gm)	
Impinger 8					336.9 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 14.8 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					<b>351.7 Total Vlc (gm)</b>	<input checked="" type="checkbox"/> QA/QC OK

Rinse:            (ml or gm)

Test Run: 3

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	626.4	457.2	169.2		
Impinger 2	5%HNO3/10%H2O2	661.7	556.5	105.2		
Impinger 3	5%HNO3/10%H2O2	575.5	545.6	29.9		
Impinger 4	Empty	444.6	436.9	7.7		
Impinger 5	4%KMnO4/10%H2SO4	550.3	546.7	3.6		
Impinger 6	4%KMnO4/10%H2SO4	538.8	538.8	0.0	315.6 Liquid (gm)	Field Data Check
Impinger 7	Silica Gel	766.5	750.4	16.1	0.0 less rinse (gm)	
Impinger 8					315.6 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 16.1 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					<b>331.7 Total Vlc (gm)</b>	<input checked="" type="checkbox"/> QA/QC OK

Rinse:            (ml or gm)

Test Run: 4

	Contents	Gross (gm)	Tare (gm)	Net (gm)		
Impinger 1	Empty	707.2	465.7	241.5		
Impinger 2	5%HNO3/10%H2O2	644.4	559.9	84.5		
Impinger 3	5%HNO3/10%H2O2	566.4	551.6	14.8		
Impinger 4	Empty	437.9	434.9	3.0		
Impinger 5	4%KMnO4/10%H2SO4	653.9	654.4	-0.5		
Impinger 6	4%KMnO4/10%H2SO4	536.5	537.8	-1.3	342.0 Liquid (gm)	Field Data Check
Impinger 7	Silica Gel	722.6	708.4	14.2	0.0 less rinse (gm)	
Impinger 8					342.0 Net Liquid (gm)	<input checked="" type="checkbox"/> QA/QC OK
					+ 14.2 Silica Gel (gm)	<input checked="" type="checkbox"/> QA/QC OK
					<b>356.2 Total Vlc (gm)</b>	<input checked="" type="checkbox"/> QA/QC OK

Rinse:            (ml or gm)

042313 084556  
N N N N

### Field Data Printout

Location: Unit 3 SDA Inlet  
 Test Run: 1  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 60.13205  
 Meter Operator: S. Joint 473  
 Probe Operator: S. Joint 473  
 Test Date: 3/26/13  
 Start Time: 08:00  
 Stop Time: 09:00  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 18 "Hg

Test Method:  
 Analyte:

USEPA Method 26A  
 HCl

Bar. Press. (in. Hg): 29.90  
 Static P: -1.1  
 O<sub>2</sub> (dry volume %): 9.84  
 CO<sub>2</sub> (dry volume %): 9.38  
 N<sub>2</sub>+CO (dry volume %): 80.78

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 66-4-7  
 Pitot C<sub>p</sub>: 0.834  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 120.9  
 H<sub>2</sub>O (silica, g): 12.7  
 Actual Moisture (%): 15.09

Meter Box ID. No: 61-11  
 Meter ΔH@: 1.69640  
 Meter Y<sub>d</sub>: 1.00500

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			692.200						
1-01	5.0		1.20	695.250	480	70	70		3.05	
1-01	10.0		1.20	698.300	481	72	70		3.05	
1-01	15.0		1.20	701.250	480	74	70		2.95	
1-01	20.0		1.20	704.110	482	74	70		2.86	
1-01	25.0		1.20	707.020	482	75	70		2.91	
1-01	30.0		1.20	709.920	484	75	70		2.90	
1-01	35.0		1.20	712.790	482	75	71		2.87	
1-01	40.0		1.20	715.660	482	75	71		2.87	
1-01	45.0		1.20	718.600	481	75	71		2.94	
1-01	50.0		1.20	721.540	481	75	71		2.94	
1-01	55.0		1.20	724.580	484	76	72		3.04	
1-01	60.0		1.20	727.640	484	77	72		3.06	
<b>Final</b>	60.0		1.20000	35.44000	481.91667	72.54167			35.44000	

1 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP				
	1.2000	35.4400	481.9167	72.5417
<input type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

042313 084715  
K

### Field Data Printout

**Test Method:**

**USEPA Method 26A**

**Analyte:**

**HCl**

Location: Unit 3 SDA Inlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 60.13205

Bar. Press. (in. Hg): 29.90  
 Static P: -1.0  
 O<sub>2</sub> (dry volume %): 10.15  
 CO<sub>2</sub> (dry volume %): 9.03  
 N<sub>2</sub>+CO (dry volume %): 80.82

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 66-4-7  
 Pitot C<sub>p</sub>: 0.834  
 Pitot Leak Check:  Pass  Fail

Meter Operator: S. Joint 473  
 Probe Operator: S. Joint 473

Test Date: 3/26/13  
 Start Time: 09:21  
 Stop Time: 10:21  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 16 "Hg

H<sub>2</sub>O (condensate, ml or gm): 135.3  
 H<sub>2</sub>O (silica, g): 9.6  
 Actual Moisture (%): 15.85

Meter Box ID. No: 61-11  
 Meter ΔH@: 1.69640  
 Meter Y<sub>g</sub>: 1.00500

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			728.000						
1-01	5.0		1.20	731.140	493	83	79		3.14	
1-01	10.0		1.20	734.310	493	84	79		3.17	
1-01	15.0		1.20	737.470	490	85	80		3.16	
1-01	20.0		1.20	740.580	489	88	82		3.11	
1-01	25.0		1.20	743.645	488	89	85		3.06	
1-01	30.0		1.20	746.710	488	89	86		3.07	
1-01	35.0		1.20	749.770	488	89	86		3.06	
1-01	40.0		1.20	752.860	483	90	88		3.09	
1-01	45.0		1.20	755.960	483	91	89		3.10	
1-01	50.0		1.20	759.060	483	91	89		3.10	
1-01	55.0		1.20	762.080	481	92	89		3.02	
1-01	60.0		1.20	765.240	481	92	89		3.16	
Final	60.0		1.20000	37.24000	486.66667	86.83333			37.24000	

1 points sampled  
 QC-Check: Field Averages

Sq.Rt. ΔP	1.2000	37.2400	486.6667	86.8333
-----------	--------	---------	----------	---------

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 084715  
 0

Location: Unit 3 SDA Inlet  
 Test Run: 3  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 60.13205  
 Meter Operator: [ ] 473  
 Probe Operator: [ ] 473  
 Test Date: 3/26/13  
 Start Time: 10:46  
 Stop Time: 11:46  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.003 cfm @ 16 "Hg

**Test Method:**  
**Analyte:**

Bar. Press. (in. Hg): 29.90  
 Static P: -1.1  
 O<sub>2</sub> (dry volume %): 9.07  
 CO<sub>2</sub> (dry volume %): 10.29  
 N<sub>2</sub>+CO (dry volume %): 80.64

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 66-4-7  
 Pitot C<sub>p</sub>: 0.834  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 131.5  
 H<sub>2</sub>O (silica, g): 11.2  
 Actual Moisture (%): 16.02

Meter Box ID. No: 61-11  
 Meter ΔH@: 1.69640  
 Meter Y<sub>d</sub>: 1.00500

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			765.500						
1-01	5.0		1.20	768.580	478	89	85		3.08	
1-01	10.0		1.20	771.660	478	89	85		3.08	
1-01	15.0		1.20	774.750	480	89	85		3.09	
1-01	20.0		1.20	777.720	480	88	84		2.97	
1-01	25.0		1.20	780.690	480	88	84		2.97	
1-01	30.0		1.20	783.660	479	87	84		2.97	
1-01	35.0		1.20	786.640	479	87	84		2.98	
1-01	40.0		1.20	789.630	479	87	84		2.99	
1-01	45.0		1.20	792.620	478	87	84		2.99	
1-01	50.0		1.20	795.610	478	87	84		2.99	
1-01	55.0		1.20	798.600	478	87	84		2.99	
1-01	60.0		1.20	801.660	480	87	84		3.06	
Final	60.0		1.20000	36.16000	478.91667	85.95833			36.16000	

Sq.Rt.ΔP

QC-Check: Field Averages

	1.2000	36.1600	478.9167	
--	--------	---------	----------	--

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 084715  
 0

### USEPA Method 3 Laboratory Data

Location: Unit 3 SDA Inlet  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Method: EPA Method 3  
 Fuel Type: Municipal Waste  
 F<sub>o</sub> for Fuel: 1.03 to 1.3

Test Method: USEPA Method 26A  
 Analyte: HCl

Analyst:	S. Brown
Analyst Emp No:	433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.38000		9.84000	80.78000	29.89440	1.17910	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.03000		10.15000	80.82000	29.85080	1.19048	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		10.29000		9.07000	80.64000	30.00920	1.14966	<input checked="" type="checkbox"/> Fo value within expected range.

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
	1							
	2							
	3							
Avg.								
CEM or Other Avg:								<input type="checkbox"/> Fo value within expected range.

042313 084715  
KGO

### USEPA Method 4 Laboratory Data

Location: Unit 3 SDA Inlet  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218

Test Method: **USEPA Method 26A**  
 Analyte: **HCl**

Analyst: **H. Nguyen**

Analyst Emp No: **429**

Test Run: **1**

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	471.1	454.0	17.1
Impinger 2	100 ml 0.1N H2SO4	600.7	529.5	71.2
Impinger 3	100 ml 0.1N H2SO4	565.2	540.5	24.7
Impinger 4	Empty	429.9	422.0	7.9
Impinger 5	Silica Gel	718.8	706.1	12.7
Impinger 6				
Impinger 7				
Impinger 8				

120.9 Liquid (gm)		
0.0 less rinse (gm)		
120.9 Net Liquid (gm)	<b>120.9</b>	<input checked="" type="checkbox"/> QA/QC OK
+ 12.7 Silica Gel (gm)	<b>12.7</b>	<input checked="" type="checkbox"/> QA/QC OK
133.6 Total Vlc (gm)	<b>133.6</b>	<input checked="" type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

Test Run: **2**

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	498.8	457.1	41.7
Impinger 2	100 ml 0.1N H2SO4	630.4	552.8	77.6
Impinger 3	100 ml 0.1N H2SO4	548.9	535.2	13.7
Impinger 4	Empty	485.0	482.7	2.3
Impinger 5	Silica Gel	717.2	707.6	9.6
Impinger 6				
Impinger 7				
Impinger 8				

135.3 Liquid (gm)		
0.0 less rinse (gm)		
135.3 Net Liquid (gm)	<b>135.3</b>	<input checked="" type="checkbox"/> QA/QC OK
+ 9.6 Silica Gel (gm)	<b>9.6</b>	<input checked="" type="checkbox"/> QA/QC OK
144.9 Total Vlc (gm)	<b>144.9</b>	<input checked="" type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

Test Run: **3**

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	524.6	461.2	63.4
Impinger 2	100 ml 0.1N H2SO4	601.7	545.8	55.9
Impinger 3	100 ml 0.1N H2SO4	570.3	560.2	10.1
Impinger 4	Empty	423.3	421.2	2.1
Impinger 5	Silica Gel	731.3	720.1	11.2
Impinger 6				
Impinger 7				
Impinger 8				

131.5 Liquid (gm)		
0.0 less rinse (gm)		
131.5 Net Liquid (gm)	<b>131.5</b>	<input checked="" type="checkbox"/> QA/QC OK
+ 11.2 Silica Gel (gm)	<b>11.2</b>	<input checked="" type="checkbox"/> QA/QC OK
142.7 Total Vlc (gm)	<b>142.7</b>	<input checked="" type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1				
Impinger 2				
Impinger 3				
Impinger 4				
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

Liquid (gm)		
less rinse (gm)		
Net Liquid (gm)		<input type="checkbox"/> QA/QC OK
Silica Gel (gm)		<input type="checkbox"/> QA/QC OK
Total Vlc (gm)		<input type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

042313 084715  
KGO



**Field Data Printout**

**Test Method:**

**USEPA Method 26A**

**Analyte:**

**HCl**

Location: Unit 3 FF Outlet  
 Test Run: 1  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: W. Berry 456  
 Probe Operator:

Bar. Press. (in. Hg): 29.90  
 Static P: -9.9  
 O<sub>2</sub> (dry volume %): 9.86  
 CO<sub>2</sub> (dry volume %): 9.47  
 N<sub>2</sub>+CO (dry volume %): 80.67

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 67-4-3  
 Pitot C<sub>p</sub>: N/A  
 Pitot Leak Check:  Pass  Fail

Test Date: 3/26/13  
 Start Time: 08:00  
 Stop Time: 09:00  
 Leak Rate Before: 0.003 cfm @ 15 "Hg  
 Leak Rate After: 0.001 cfm @ 10 "Hg

H<sub>2</sub>O (condensate, ml or gm): 186.7  
 H<sub>2</sub>O (silica, g): 12.9  
 Actual Moisture (%): 19.48

Meter Box ID. No: 66-18  
 Meter ΔH@: 1.91650  
 Meter Y<sub>d</sub>: 1.00080

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			246.660						
3-01	5.0		1.50	249.980	296	64	63		3.32	
3-01	10.0		1.50	253.060	296	66	64		3.08	
3-01	15.0		1.50	256.240	295	70	63		3.18	
3-01	20.0		1.50	259.430	296	72	63		3.19	
3-01	25.0		1.50	262.650	295	73	63		3.22	
3-01	30.0		1.50	265.880	296	74	64		3.23	
3-01	35.0		1.50	269.130	294	73	64		3.25	
3-01	40.0		1.50	272.400	297	74	64		3.27	
3-01	45.0		1.50	275.620	290	74	65		3.22	
3-01	50.0		1.50	278.850	293	73	65		3.23	
3-01	55.0		1.50	282.190	294	74	65		3.34	
3-01	60.0		1.50	285.360	293	75	66		3.17	
Final	60.0		1.50000	38.70000	294.58333	67.95833			38.70000	

3 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	1.5000	38.7000	294.5833	67.9583
----------	--------	---------	----------	---------

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042313 084740  
 J

**Field Data Printout**

Location: Unit 3 FF Outlet  
 Test Run: 2  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000  
 Meter Operator: W. Berry 456  
 Probe Operator:  
 Test Date: 3/26/13  
 Start Time: 09:21  
 Stop Time: 10:21  
 Leak Rate Before: 0.004 cfm @ 15 "Hg  
 Leak Rate After: 0.002 cfm @ 10 "Hg

Test Method:  
 Analyte:

USEPA Method 26A  
 HCl

Bar. Press. (in. Hg): 29.90  
 Static P: -10.1  
 O<sub>2</sub> (dry volume %): 9.56  
 CO<sub>2</sub> (dry volume %): 9.76  
 N<sub>2</sub>+CO (dry volume %): 80.68

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 67-4-3  
 Pitot C<sub>p</sub>: N/A  
 Pitot Leak Check:  Pass  Fail

H<sub>2</sub>O (condensate, ml or gm): 197.7  
 H<sub>2</sub>O (silica, g): 17.4  
 Actual Moisture (%): 20.75

Meter Box ID No: 66-18  
 Meter ΔH@: 1.91650  
 Meter Y<sub>c</sub>: 1.00080

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			285.740						
3-01	5.0		1.50	288.920	298	69	66		3.18	
3-01	10.0		1.50	292.150	300	71	66		3.23	
3-01	15.0		1.50	295.370	296	74	66		3.22	
3-01	20.0		1.50	298.580	299	75	67		3.21	
3-01	25.0		1.50	301.800	296	75	67		3.22	
3-01	30.0		1.50	305.090	298	76	68		3.29	
3-01	35.0		1.50	308.350	295	77	68		3.26	
3-01	40.0		1.50	311.590	296	77	68		3.24	
3-01	45.0		1.50	314.820	297	77	69		3.23	
3-01	50.0		1.50	318.040	293	78	69		3.22	
3-01	55.0		1.50	321.290	295	79	70		3.25	
3-01	60.0		1.50	324.535	295	80	70		3.25	
Final	60.0		1.50000	38.79500	296.50000	71.75000			38.79500	

3 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	1.5000	38.7950	296.5000	71.7500
<input type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK	<input checked="" type="checkbox"/> Avg. OK

042913 084740  
 N

**Field Data Printout**

**Test Method:**

**USEPA Method 26A**

**Analyte:**

**HCl**

Location: Unit 3 FF Outlet  
 Test Run: 3  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Source Area (ft<sup>2</sup>): 64.00000

Bar. Press. (in. Hg): 29.90  
 Static P: -9.1  
 O<sub>2</sub> (dry volume %): 9.58  
 CO<sub>2</sub> (dry volume %): 9.81  
 N<sub>2</sub>+CO (dry volume %): 80.61

Nozzle ID No: N/A  
 Nozzle Diameter (D<sub>n</sub>): N/A  
 Probe ID No: 67-4-3  
 Pitot C<sub>p</sub>: N/A  
 Pitot Leak Check:  Pass  Fail

Meter Operator: W. Berry 456  
 Probe Operator:

Test Date: 3/26/13  
 Start Time: 10:46  
 Stop Time: 11:46  
 Leak Rate Before: 0.005 cfm @ 15 "Hg  
 Leak Rate After: 0.002 cfm @ 10 "Hg

H<sub>2</sub>O (condensate, ml or gm): 186.9  
 H<sub>2</sub>O (silica, g): 15.7  
 Actual Moisture (%): 19.93

Meter Box ID. No: 66-18  
 Meter ΔH@: 1.91650  
 Meter Y<sub>g</sub>: 1.00080

Traverse Point	Run Time 5.0 min/read	Pitot ΔP <sub>s</sub> (in. H <sub>2</sub> O)	Sample ΔH (in. H <sub>2</sub> O)	Metered (dcf)	Stack T <sub>s</sub> (°F)	Dry Gas Meter		√ΔP <sub>s</sub> (calculated) (√in. H <sub>2</sub> O)	Volume (calculated) (ft <sup>3</sup> )	Isokinetics (calculated) (%)
						T <sub>m-in</sub> (°F)	T <sub>m-out</sub> (°F)			
	0.0			325.220						
2-01	5.0		1.50	328.480	300	76	72		3.26	
2-01	10.0		1.50	331.720	292	78	73		3.24	
2-01	15.0		1.50	334.920	293	81	73		3.20	
2-01	20.0		1.50	338.160	294	83	74		3.24	
2-01	25.0		1.50	341.390	292	83	74		3.23	
2-01	30.0		1.50	344.640	292	83	75		3.25	
2-01	35.0		1.50	347.910	292	84	76		3.27	
2-01	40.0		1.50	351.170	293	84	76		3.26	
2-01	45.0		1.50	354.420	292	85	77		3.25	
2-01	50.0		1.50	357.780	294	87	78		3.36	
2-01	55.0		1.50	360.950	297	88	79		3.17	
2-01	60.0		1.50	364.210	290	87	80		3.26	
Final	60.0		1.50000	38.99000	293.41667	79.41667			38.99000	

2 points sampled  
 QC-Check: Field Averages

Sq.Rt.ΔP	1.5000	38.9900	293.4167	79.4167
----------	--------	---------	----------	---------

Avg. OK  Avg. OK  Avg. OK  Avg. OK  Avg. OK

042813 084740

USEPA Method 3 Laboratory Data

Location: Unit 3 FF Outlet  
 Client: Wheelabrator South Broward, Inc.  
 Project No: 12218  
 Method: EPA Method 3  
 Fuel Type: Municipal Waste  
 F<sub>o</sub> for Fuel: 1.03 to 1.3

Test Method: USEPA Method 26A  
 Analyte: HCl

Analyst: S. Brown  
 Analyst Emp No: 433

Run Number	Trial	Percent CO <sub>2</sub>	Percent O <sub>2</sub> +CO <sub>2</sub>	Percent O <sub>2</sub>	Percent N <sub>2</sub>	Dry Mol. Weight	F <sub>o</sub>	Method of Analysis: CEM
1	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.47000	9.86000	80.67000	29.90960	1.16579	<input checked="" type="checkbox"/>	Fo value within expected range.
2	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.76000	9.56000	80.68000	29.94400	1.16189	<input checked="" type="checkbox"/>	Fo value within expected range.
3	1							
	2							
	3							
Avg.								
CEM or Other Avg:		9.81000	9.58000	80.61000	29.95280	1.15392	<input checked="" type="checkbox"/>	Fo value within expected range.
	1							
	2							
	3							
Avg.								
CEM or Other Avg:							<input type="checkbox"/>	Fo value within expected range.

042313 084740  
 JN1

**USEPA Method 4 Laboratory Data**

Location: Unit 3 FF Outlet  
 Client: Wheelabrator South Broward, Inc.

**Test Method:** USEPA Method 26A  
**Analyte:** HCl

Project No: 12218

Analyst: D. Luckhard

Test Run:

Analyst Emp No: 568

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	484.1	449.5	34.6
Impinger 2	100 ml 0.1N H2SO4	666.4	565.7	100.7
Impinger 3	100 ml 0.1N H2SO4	584.7	542.7	42.0
Impinger 4	Empty	451.1	441.7	9.4
Impinger 5	Silica Gel	737.0	724.1	12.9
Impinger 6				
Impinger 7				
Impinger 8				

186.7 Liquid (gm)  
 0.0 less rinse (gm)  
 186.7 Net Liquid (gm)  
 + 12.9 Silica Gel (gm)  
 199.6 Total Vic (gm)

*Field Data Check*

186.7	<input checked="" type="checkbox"/> QA/QC OK
12.9	<input checked="" type="checkbox"/> QA/QC OK
199.6	<input checked="" type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	478.1	446.5	31.6
Impinger 2	100 ml 0.1N H2SO4	639.0	534.6	104.4
Impinger 3	100 ml 0.1N H2SO4	566.8	519.8	47.0
Impinger 4	Empty	481.0	466.3	14.7
Impinger 5	Silica Gel	688.5	671.1	17.4
Impinger 6				
Impinger 7				
Impinger 8				

197.7 Liquid (gm)  
 0.0 less rinse (gm)  
 197.7 Net Liquid (gm)  
 + 17.4 Silica Gel (gm)  
 215.1 Total Vic (gm)

*Field Data Check*

197.7	<input checked="" type="checkbox"/> QA/QC OK
17.4	<input checked="" type="checkbox"/> QA/QC OK
215.1	<input checked="" type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1	50 ml 0.1N H2SO4	474.5	440.8	33.7
Impinger 2	100 ml 0.1N H2SO4	662.8	557.1	105.7
Impinger 3	100 ml 0.1N H2SO4	576.8	539.0	37.8
Impinger 4	Empty	451.1	441.4	9.7
Impinger 5	Silica Gel	717.1	701.4	15.7
Impinger 6				
Impinger 7				
Impinger 8				

186.9 Liquid (gm)  
 0.0 less rinse (gm)  
 186.9 Net Liquid (gm)  
 + 15.7 Silica Gel (gm)  
 202.6 Total Vic (gm)

*Field Data Check*

186.9	<input checked="" type="checkbox"/> QA/QC OK
15.7	<input checked="" type="checkbox"/> QA/QC OK
202.6	<input checked="" type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

Test Run:

	Contents	Gross (gm)	Tare (gm)	Net (gm)
Impinger 1				
Impinger 2				
Impinger 3				
Impinger 4				
Impinger 5				
Impinger 6				
Impinger 7				
Impinger 8				

Liquid (gm)  
 less rinse (gm)  
 Net Liquid (gm)  
 Silica Gel (gm)  
 Total Vic (gm)

*Field Data Check*

	<input type="checkbox"/> QA/QC OK
	<input type="checkbox"/> QA/QC OK
	<input type="checkbox"/> QA/QC OK

Rinse:  (ml or gm)

042313 08470  
 J N I @

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 25, 2013  
 Start Time 12:29  
 Stop time 13:03

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
<b>Calibration Checks</b>			
C <sub>oi</sub> Initial zero	0.048	0.030	
C <sub>ui</sub> Initial upscale	18.128	17.988	
C <sub>of</sub> Final zero	0.057	0.045	
C <sub>uf</sub> Final upscale	18.085	17.905	
C <sub>ma</sub> Actual gas value	18.100	17.900	
<b>U1 R1 M26A INLET</b>			
C <sub>Avg</sub> Average conc.	10.901	8.201	Bad Bag
C <sub>Gas</sub> Bias adjusted	10.88	8.16	
<b>U1 R2 M26A INLET</b>			
C <sub>Avg</sub> Average conc.	7.708	11.297	
C <sub>Gas</sub> Bias adjusted	7.68	11.25	
<b>U1 R3 M26A INLET</b>			
C <sub>Avg</sub> Average conc.	8.101	11.079	
C <sub>Gas</sub> Bias adjusted	8.07	11.04	
<b>U1 R1 M26A OUTLET</b>			
C <sub>Avg</sub> Average conc.	9.242	9.900	
C <sub>Gas</sub> Bias adjusted	9.21	9.86	
<b>U1 R2 M26A OUTLET</b>			
C <sub>Avg</sub> Average conc.	7.798	11.297	
C <sub>Gas</sub> Bias adjusted	7.76	11.25	
<b>U1 R3 M26A OUTLET</b>			
C <sub>Avg</sub> Average conc.	8.561	10.678	
C <sub>Gas</sub> Bias adjusted	8.53	10.64	
<b>U2 R1 5/29</b>			
C <sub>Avg</sub> Average conc.	8.586	10.396	
C <sub>Gas</sub> Bias adjusted	8.56	10.35	
<b>U2 R2 5/29</b>			
C <sub>Avg</sub> Average conc.	8.394	10.777	
C <sub>Gas</sub> Bias adjusted	8.36	10.73	

**Wheelabrator**  
**CleanAir Project No. 12218**  
**South Broward**  
**FF Outlet, SDA Inlet**

March 25, 2013  
 Start Time 12:29  
 Stop time 13:03

**IGS Bag Analysis**

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
040813:123405			
12:30:57	0.147	-0.010	
12:31:12	0.054	-0.054	
12:31:27	0.049	0.031	
12:30:57	0.147	-0.010	
12:31:12	0.054	-0.054	
12:31:27	0.049	0.031	
<b>12:31:42</b>	<b>0.048</b>	<b>0.030</b>	<b>ZERO</b>
12:31:57	0.045	0.025	
12:32:12	1.376	-0.063	
12:32:27	16.623	-0.071	
12:32:42	20.343	-0.069	
12:32:57	18.637	-0.069	
12:33:12	18.034	-0.070	
12:33:27	18.020	-0.069	
12:33:42	15.680	2.351	
12:33:57	-0.041	18.093	
12:34:12	-0.045	18.102	
12:34:27	4.800	17.969	
12:34:42	18.123	17.967	
12:34:57	18.126	17.979	
12:35:12	18.127	17.984	
<b>12:35:27</b>	<b>18.128</b>	<b>17.988</b>	<b>SPAN</b>
12:35:42	18.154	17.987	
12:35:57	19.501	8.031	
12:36:12	12.277	6.822	
12:36:27	9.628	9.380	
12:36:42	9.542	9.497	
12:36:57	9.542	9.501	
<b>12:37:12</b>	<b>9.542</b>	<b>9.499</b>	<b>LINEARITY</b>
12:37:27	9.542	9.494	
12:37:42	13.548	7.250	
12:37:57	20.156	0.859	
12:38:12	20.648	0.188	
12:38:27	16.815	2.451	
12:38:42	10.704	8.179	
12:38:57	10.493	8.525	
<b>12:39:12</b>	<b>10.901</b>	<b>8.201</b>	<b>U1 R1 M26A INLET</b>
12:39:27	10.923	8.090	
12:39:42	11.216	8.245	
12:39:57	18.475	2.719	
12:40:12	20.559	0.240	
12:40:27	20.634	0.158	

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 25, 2013  
 Start Time 12:29  
 Stop time 13:03

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
12:40:42	20.641	0.151	
12:40:57	20.644	0.147	
12:41:12	20.645	0.147	
12:41:27	20.647	0.146	
12:41:42	20.647	0.140	
12:41:57	14.659	4.076	
12:42:12	8.139	10.703	
12:42:27	7.717	11.263	
12:42:42	7.706	11.288	
<b>12:42:57</b>	<b>7.708</b>	<b>11.297</b>	<b>U1 R2 M26A INLET</b>
12:43:12	7.708	11.298	
12:43:27	15.521	6.039	
12:43:42	20.428	0.451	
12:43:57	19.328	0.657	
12:44:12	10.043	8.669	
12:44:27	8.163	10.988	
<b>12:44:42</b>	<b>8.101</b>	<b>11.079</b>	<b>U1 R3 M26A INLET</b>
12:44:57	8.103	11.089	
12:45:12	8.105	11.096	
12:45:27	8.103	11.105	
12:45:42	9.014	10.946	
12:45:57	18.267	3.090	
12:46:12	20.564	0.270	
12:46:27	20.076	0.270	
12:46:42	11.682	6.994	
12:46:57	9.332	9.779	
12:47:12	9.245	9.895	
<b>12:47:27</b>	<b>9.242</b>	<b>9.900</b>	<b>U1 R1 M26A OUTLET</b>
12:47:42	9.243	9.903	
12:47:57	10.565	9.513	
12:48:12	18.950	2.192	
12:48:27	20.574	0.227	
12:48:42	19.037	0.808	
12:48:57	9.572	9.083	
12:49:12	7.847	11.204	
12:49:27	7.795	11.286	
<b>12:49:42</b>	<b>7.798</b>	<b>11.297</b>	<b>U1 R2 M26A OUTLET</b>
12:49:57	7.800	11.299	
12:50:12	8.751	11.136	
12:50:27	18.227	3.132	
12:50:42	20.562	0.270	
12:50:57	19.908	0.353	
12:51:12	11.029	7.654	



**Wheelabrator**  
**CleanAir Project No. 12218**  
**South Broward**  
**FF Outlet, SDA Inlet**

March 25, 2013  
 Start Time 12:29  
 Stop time 13:03

**IGS Bag Analysis**

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
12:51:27	8.646	10.540	
12:51:42	8.561	10.666	
<b>12:51:57</b>	<b>8.561</b>	<b>10.678</b>	<b>U1 R3 M26A OUTLET</b>
12:52:12	8.559	10.682	
12:52:27	8.560	10.685	
12:52:42	8.561	10.684	
12:52:57	8.562	10.681	
12:53:12	8.558	10.681	
12:53:27	8.606	10.687	
12:53:42	16.533	5.134	
12:53:57	20.497	0.376	
12:54:12	20.657	0.175	
12:54:27	19.950	0.323	
12:54:42	11.015	7.518	
12:54:57	8.672	10.289	
<b>12:55:12</b>	<b>8.586</b>	<b>10.396</b>	<b>U2 R1 5/29</b>
12:55:27	8.584	10.402	
12:55:42	8.582	10.407	
12:55:57	8.580	10.409	
12:56:12	13.282	7.619	
12:56:27	20.127	0.787	
12:56:42	20.599	0.192	
12:56:57	20.194	0.215	
12:57:12	10.950	7.523	
12:57:27	8.450	10.670	
12:57:42	8.394	10.766	
<b>12:57:57</b>	<b>8.394</b>	<b>10.777</b>	<b>U2 R2 5/29</b>
12:58:12	8.393	10.782	
12:58:27	10.988	9.595	
12:58:42	19.712	1.422	
12:58:57	20.167	0.197	
12:59:12	5.770	0.098	
12:59:27	0.182	0.052	
<b>12:59:42</b>	<b>0.057</b>	<b>0.045</b>	<b>ZERO</b>
12:59:57	0.054	0.043	
13:00:12	0.051	0.042	
13:00:27	0.372	0.041	
13:00:42	14.730	0.108	
13:00:57	20.390	0.149	
13:01:12	20.640	0.147	
13:01:27	19.441	6.353	
13:01:42	18.173	16.778	
13:01:57	18.079	17.851	

Wheelabrator  
CleanAir Project No. 12218  
South Broward  
FF Outlet, SDA Inlet

March 25, 2013  
Start Time 12:29  
Stop time 13:03

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
13:02:12	18.085	17.905	SPAN
13:02:27	18.091	17.919	
13:02:42	18.097	17.924	
13:02:57	18.101	17.929	
13:03:12	18.485	16.635	

**Wheelabrator**  
**CleanAir Project No. 12218**  
**South Broward**  
**FF Outlet, SDA Inlet**

March 27, 2013  
 Start Time 15:12  
 Stop time 15:29

**IGS Bag Analysis**

	Channel 1 O2	Channel 2 CO2
	FF Outlet %dv	FF Outlet %dv
<b>Calibration Checks</b>		
C <sub>oi</sub> Initial zero	0.012	0.029
C <sub>ui</sub> Initial upscale	18.022	17.946
C <sub>of</sub> Final zero	0.040	0.076
C <sub>uf</sub> Final upscale	18.041	17.888
C <sub>ms</sub> Actual gas value	18.100	17.900
<b>U1 R1 5/29</b>		
C <sub>AVG</sub> Average conc.	8.234	10.960
C <sub>Gas</sub> Bias adjusted	<b>8.25</b>	<b>10.93</b>
<b>U2 R1 M23</b>		
C <sub>AVG</sub> Average conc.	8.443	10.687
C <sub>Gas</sub> Bias adjusted	<b>8.46</b>	<b>10.66</b>
<b>U2 R3 5/29</b>		
C <sub>AVG</sub> Average conc.	8.566	10.667
C <sub>Gas</sub> Bias adjusted	<b>8.58</b>	<b>10.64</b>

040813 123405

15:13:52	0.015	0.027
15:14:07	0.012	0.029
15:13:52	0.015	0.027
<b>15:14:07</b>	<b>0.012</b>	<b>0.029 ZERO</b>
15:14:22	2.570	0.031
15:14:37	16.476	5.672
15:14:52	17.924	16.370
15:15:07	17.946	17.516
15:15:22	18.011	17.715
15:15:37	18.027	17.928
<b>15:15:52</b>	<b>18.022</b>	<b>17.946 SPAN</b>
15:16:07	17.977	17.896
15:16:22	18.029	17.956
15:16:37	18.039	17.961
15:16:52	16.719	10.662
15:17:07	10.088	9.160
15:17:22	9.463	9.496
15:17:37	9.447	9.497
15:17:52	9.445	9.494
15:18:07	9.491	9.493
15:18:22	16.857	4.544

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 27, 2013  
 Start Time 15:12  
 Stop time 15:29

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
15:18:37	20.497	0.307	
15:18:52	20.643	0.128	
15:19:07	20.644	0.116	
15:19:22	20.646	0.108	
15:19:37	19.726	0.375	
15:19:52	10.637	8.094	
15:20:07	8.395	10.843	
15:20:22	8.309	10.982	
<b>15:20:37</b>	<b>8.234</b>	<b>10.960</b>	<b>U1 R1 5/29</b>
15:20:52	8.305	10.964	
15:21:07	8.296	10.998	
15:21:22	8.310	11.003	
15:21:37	13.223	7.271	
15:21:52	9.745	9.086	
15:22:08	8.475	10.645	
15:22:22	8.443	10.684	
<b>15:22:37</b>	<b>8.443</b>	<b>10.687</b>	<b>U2 R1 M23</b>
15:22:52	8.556	10.691	
15:23:07	16.971	4.615	
15:23:22	20.511	0.268	
15:23:37	20.641	0.128	
15:23:52	20.642	0.116	
15:24:07	20.642	0.110	
15:24:22	20.640	0.108	
15:24:37	20.330	0.128	
15:24:52	11.812	6.759	
15:25:07	8.697	10.465	
<b>15:25:22</b>	<b>8.566</b>	<b>10.667</b>	<b>U2 R3 5/29</b>
15:25:37	8.565	10.685	
15:25:52	8.565	10.690	
15:26:07	8.567	10.696	
15:26:22	12.401	8.557	
15:26:37	20.000	1.014	
15:26:52	19.733	4.440	
15:27:07	18.167	16.617	
<b>15:27:22</b>	<b>18.041</b>	<b>17.888</b>	<b>SPAN</b>
15:27:37	18.040	17.936	
15:27:52	18.038	17.947	
15:28:07	18.031	13.051	
15:28:22	4.995	1.665	
15:28:37	0.233	0.163	
<b>15:28:52</b>	<b>0.040</b>	<b>0.076</b>	<b>ZERO</b>
15:29:07	0.031	0.065	

Wheelabrator  
CleanAir Project No. 12218  
South Broward  
FF Outlet, SDA Inlet

March 27, 2013  
Start Time 15:12  
Stop time 15:29

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2
	FF Outlet %dv	FF Outlet %dv
15:29:22	6.221	0.068
15:29:37	19.262	0.109
15:29:52	19.970	0.137

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 26, 2013  
 Start Time 11:50  
 Stop time 12:14

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2
	FF Outlet %dv	FF Outlet %dv
<b>Calibration Checks</b>		
C <sub>oi</sub> Initial zero	0.037	0.008
C <sub>ui</sub> Initial upscale	18.116	17.918
C <sub>of</sub> Final zero	0.044	0.027
C <sub>uf</sub> Final upscale	18.097	17.890
C <sub>ms</sub> Actual gas value	18.100	17.900
<b>U1 R2 5/29</b>		
C <sub>Avg</sub> Average conc.	8.350	10.736
C <sub>Gas</sub> Bias adjusted	8.32	10.73
<b>U3 R1 M26A OUTLET</b>		
C <sub>Avg</sub> Average conc.	9.881	9.479
C <sub>Gas</sub> Bias adjusted	9.86	9.47
<b>U3 R2 M26A OUTLET</b>		
C <sub>Avg</sub> Average conc.	9.585	9.774
C <sub>Gas</sub> Bias adjusted	9.56	9.76
<b>U3 R3 M26A OUTLET</b>		
C <sub>Avg</sub> Average conc.	9.601	9.818
C <sub>Gas</sub> Bias adjusted	9.58	9.81
<b>U3 R1 M26A INLET</b>		
C <sub>Avg</sub> Average conc.	9.866	9.393
C <sub>Gas</sub> Bias adjusted	9.84	9.38
<b>U3 R2 M26A INLET</b>		
C <sub>Avg</sub> Average conc.	10.176	9.038
C <sub>Gas</sub> Bias adjusted	10.15	9.03
<b>U3 R3 M26A INLET</b>		
C <sub>Avg</sub> Average conc.	9.090	10.296
C <sub>Gas</sub> Bias adjusted	9.07	10.29

040813 123405

11:51:01	0.344	0.015
11:51:16	-0.238	0.011
11:51:01	0.344	0.015

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 26, 2013  
 Start Time 11:50  
 Stop time 12:14

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
11:51:16	-0.238	0.011	
11:51:31	-0.202	0.008	
11:51:46	0.008	0.009	
11:52:01	<b>0.037</b>	<b>0.008</b>	<b>ZERO</b>
11:52:16	0.037	0.009	
11:52:31	4.465	0.019	
11:52:46	18.213	8.320	
11:53:01	18.552	18.175	
11:53:16	18.279	18.553	
11:53:31	18.144	17.925	
11:53:46	18.113	17.922	
11:54:01	18.114	17.922	
11:54:16	18.114	17.924	
11:54:31	<b>18.116</b>	<b>17.918</b>	<b>SPAN</b>
11:54:46	18.474	16.914	
11:55:01	15.068	6.514	
11:55:16	9.683	9.320	
11:55:31	9.517	9.522	
11:55:46	9.517	9.526	
11:56:01	9.515	9.526	
11:56:16	<b>9.517</b>	<b>9.526</b>	<b>LINEARITY</b>
11:56:31	13.330	7.515	
11:56:46	20.342	0.662	
11:57:01	20.668	0.111	
11:57:16	20.661	0.120	
11:57:31	20.651	0.118	
11:57:46	20.607	0.101	
11:58:01	20.649	0.110	
11:58:16	16.849	2.320	
11:58:31	8.930	9.926	
11:58:46	8.396	10.680	
11:59:01	<b>8.350</b>	<b>10.736</b>	<b>U1 R2 5/29</b>
11:59:16	8.340	10.753	
11:59:31	11.258	9.398	
11:59:46	19.908	1.163	
12:00:01	20.642	0.138	
12:00:16	18.065	1.487	
12:00:31	10.498	8.599	
12:00:46	9.889	9.462	
12:01:01	<b>9.881</b>	<b>9.479</b>	<b>U3 R1 M26A OUTLET</b>
12:01:16	9.882	9.486	
12:01:31	12.750	8.067	
12:01:46	20.121	0.897	

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 26, 2013  
 Start Time 11:50  
 Stop time 12:14

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
12:02:01	20.408	0.247	
12:02:16	14.608	4.249	
12:02:31	9.735	9.506	
12:02:46	9.585	9.767	
<b>12:03:01</b>	<b>9.585</b>	<b>9.774</b>	<b>U3 R2 M26A OUTLET</b>
12:03:16	9.585	9.780	
12:03:31	13.491	7.584	
12:03:46	20.331	0.639	
12:04:01	20.665	0.128	
12:04:16	20.637	0.115	
12:04:31	13.281	5.384	
12:04:46	9.683	9.665	
<b>12:05:01</b>	<b>9.601</b>	<b>9.818</b>	<b>U3 R3 M26A OUTLET</b>
12:05:16	9.603	9.828	
12:05:31	12.898	8.102	
12:05:46	20.226	0.814	
12:06:01	19.800	0.369	
12:06:16	11.363	7.430	
12:06:31	9.891	9.353	
<b>12:06:46</b>	<b>9.866</b>	<b>9.393</b>	<b>U3 R1 M26A INLET</b>
12:07:01	9.866	9.402	
12:07:16	11.710	8.723	
12:07:31	19.811	1.305	
12:07:46	20.638	0.140	
12:08:01	14.773	4.088	
12:08:16	10.353	8.793	
12:08:31	10.195	9.015	
<b>12:08:46</b>	<b>10.176</b>	<b>9.038</b>	<b>U3 R2 M26A INLET</b>
12:09:01	10.166	9.051	
12:09:16	16.403	5.020	
12:09:31	20.503	0.291	
12:09:46	19.550	0.477	
12:10:01	10.555	8.268	
12:10:16	9.110	10.246	
<b>12:10:31</b>	<b>9.090</b>	<b>10.296</b>	<b>U3 R3 M26A INLET</b>
12:10:46	9.090	10.303	
12:11:01	16.449	5.294	
12:11:16	20.536	0.270	
12:11:31	18.586	10.847	
12:11:47	18.053	17.616	
12:12:01	18.088	17.873	
<b>12:12:16</b>	<b>18.097</b>	<b>17.890</b>	<b>SPAN</b>
12:12:31	18.714	15.458	



Wheelabrator  
CleanAir Project No. 12218  
South Broward  
FF Outlet, SDA Inlet

March 26, 2013  
Start Time 11:50  
Stop time 12:14

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2
	FF Outlet %dv	FF Outlet %dv
12:12:46	20.480	2.041
12:13:01	16.267	0.168
12:13:16	0.981	0.049
12:13:31	0.055	0.033
<b>12:13:46</b>	<b>0.044</b>	<b>0.027 ZERO</b>
12:14:01	2.167	0.025
12:14:16	18.247	0.091

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 26, 2013  
 Start Time 17:09  
 Stop time 17:41

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2
	FF Outlet %dv	FF Outlet %dv
<b>Calibration Checks</b>		
C <sub>oi</sub> Initial zero	-0.024	0.024
C <sub>ui</sub> Initial upscale	18.050	17.920
C <sub>of</sub> Final zero	-0.003	0.054
C <sub>uf</sub> Final upscale	18.027	17.863
C <sub>ma</sub> Actual gas value	18.100	17.900
<b>U1 R3 5/29</b>		
C <sub>Avg</sub> Average conc.	7.692	11.142
C <sub>Gas</sub> Bias adjusted	7.73	11.13
<b>U1 R4 M29</b>		
C <sub>Avg</sub> Average conc.	8.578	10.598
C <sub>Gas</sub> Bias adjusted	8.61	10.59
<b>U3 R1 5/29</b>		
C <sub>Avg</sub> Average conc.	9.756	9.433
C <sub>Gas</sub> Bias adjusted	9.80	9.42
<b>U2 R2 M23</b>		
C <sub>Avg</sub> Average conc.	8.591	10.349
C <sub>Gas</sub> Bias adjusted	8.63	10.34
<b>U2 R3 M23</b>		
C <sub>Avg</sub> Average conc.	9.436	9.815
C <sub>Gas</sub> Bias adjusted	9.48	9.80

040813 123405

17:10:33	0.441	0.028
17:10:48	0.033	0.024
17:10:33	0.441	0.028
17:10:48	0.033	0.024
17:11:03	-0.023	0.024
17:11:18	<b>-0.024</b>	<b>0.024 ZERO</b>
17:11:33	1.521	0.025
17:11:48	17.054	0.799
17:12:03	16.665	12.732
17:12:18	16.195	15.536
17:12:33	16.172	15.708
17:12:48	17.352	12.935

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 26, 2013  
 Start Time 17:09  
 Stop time 17:41

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
17:13:03	20.080	2.083	
17:13:18	20.512	0.194	
17:13:33	20.531	0.112	
17:13:48	20.532	0.104	
17:14:03	20.533	0.100	
17:14:18	20.537	0.097	
17:14:33	17.252	1.961	
17:14:48	10.134	8.509	
17:15:03	9.380	9.457	
17:15:18	9.364	9.496	
17:15:33	9.365	9.507	
17:15:48	9.380	9.513	
17:16:03	15.508	11.632	
17:16:18	17.850	17.386	
17:16:33	17.935	17.949	
17:16:48	17.987	17.944	
17:17:03	18.047	17.923	
17:17:18	18.050	17.920	SPAN
17:17:33	18.063	17.919	
17:17:48	16.550	10.046	
17:18:03	9.875	9.240	
17:18:18	9.445	9.563	
17:18:33	9.439	9.567	LINEARITY
17:18:48	9.642	9.569	
17:19:03	18.174	3.496	
17:19:18	20.662	0.194	
17:19:33	20.472	0.126	
17:19:48	10.892	7.245	
17:20:03	7.767	11.035	
17:20:18	7.693	11.134	
17:20:33	7.692	11.142	U1 R3 5/29
17:20:48	9.080	10.795	
17:21:03	18.881	2.369	
17:21:18	20.616	0.179	
17:21:33	17.487	1.877	
17:21:48	9.279	9.613	
17:22:03	8.588	10.577	
17:22:18	8.578	10.598	U1 R4 M29
17:22:33	10.443	9.913	
17:22:48	19.305	1.866	
17:23:03	20.195	0.151	
17:23:18	11.919	6.596	
17:23:33	9.814	9.341	

**Wheelabrator**  
**CleanAir Project No. 12218**  
**South Broward**  
**FF Outlet, SDA Inlet**

March 26, 2013  
 Start Time 17:09  
 Stop time 17:41

**IGS Bag Analysis**

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
17:23:48	9.758	9.432	
<b>17:24:03</b>	<b>9.756</b>	<b>9.433</b>	<b>U3 R1 5/29</b>
17:24:18	11.363	8.879	
17:24:33	19.479	1.653	
17:24:48	20.654	0.153	
17:25:03	15.705	3.216	
17:25:18	9.011	9.768	
17:25:33	8.601	10.330	
<b>17:25:48</b>	<b>8.591</b>	<b>10.349</b>	<b>U2 R2 M23</b>
17:26:03	10.043	9.919	
17:26:18	18.946	2.194	<-- Paused at 17:26:26
17:36:23	20.680	0.077	
17:36:38	18.316	1.304	
17:36:53	10.650	8.293	
17:37:08	9.480	9.724	
17:37:23	9.436	9.802	
<b>17:37:38</b>	<b>9.436</b>	<b>9.815</b>	<b>U2 R3 M23</b>
17:37:53	10.164	9.709	
17:38:08	18.327	2.955	
17:38:23	20.536	0.252	
17:38:38	18.792	10.772	
17:38:53	18.062	17.324	
17:39:08	18.022	17.827	
<b>17:39:23</b>	<b>18.027</b>	<b>17.863</b>	<b>SPAN</b>
17:39:38	18.139	17.799	
17:39:53	12.015	6.121	
17:40:08	0.912	0.492	
17:40:23	0.019	0.076	
<b>17:40:38</b>	<b>-0.003</b>	<b>0.054</b>	<b>ZERO</b>
17:40:53	1.188	0.047	
17:41:08	16.114	0.085	

**Wheelabrator**  
**CleanAir Project No. 12218**  
**South Broward**  
**FF Outlet, SDA Inlet**

March 27, 2013  
 Start Time 11:14  
 Stop time 12:17

**IGS Bag Analysis**

	Channel 1 O2	Channel 2 CO2
	FF Outlet %dv	FF Outlet %dv
<b>Calibration Checks</b>		
C <sub>Oi</sub> Initial zero	-0.012	0.000
C <sub>ui</sub> Initial upscale	18.138	17.939
C <sub>of</sub> Final zero	0.012	0.012
C <sub>uf</sub> Final upscale	18.126	17.915
C <sub>ma</sub> Actual gas value	18.100	17.900
<b>U2 R1 M26A OUTLET</b>		
C <sub>Avg</sub> Average conc.	8.789	10.533
C <sub>Gas</sub> Bias adjusted	8.77	10.51
<b>U2 R2 M26A OUTLET</b>		
C <sub>Avg</sub> Average conc.	8.883	10.513
C <sub>Gas</sub> Bias adjusted	8.87	10.49
<b>U2 R1 M26A INLET</b>		
C <sub>Avg</sub> Average conc.	8.240	11.057
C <sub>Gas</sub> Bias adjusted	8.23	11.04
<b>U2 R2 M26A INLET</b>		
C <sub>Avg</sub> Average conc.	8.396	10.999
C <sub>Gas</sub> Bias adjusted	8.38	10.98
<b>U3 R2 M5/29</b>		
C <sub>Avg</sub> Average conc.	9.243	10.087
C <sub>Gas</sub> Bias adjusted	9.23	10.07
<b>U2 R3 M26A OUTLET</b>		
C <sub>Avg</sub> Average conc.	9.718	9.683
C <sub>Gas</sub> Bias adjusted	9.70	9.67
<b>U2 R3 M26A INLET</b>		
C <sub>Avg</sub> Average conc.	9.339	9.953
C <sub>Gas</sub> Bias adjusted	9.32	9.94
<b>U2 R4 M23</b>		
C <sub>Avg</sub> Average conc.	9.134	10.152
C <sub>Gas</sub> Bias adjusted	9.12	10.13

**Wheelabrator**  
**CleanAir Project No. 12218**  
**South Broward**  
**FF Outlet, SDA Inlet**

March 27, 2013  
 Start Time 11:14  
 Stop time 12:17

**IGS Bag Analysis**

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
040813_123405			
11:15:15	1.253	0.008	
11:15:30	-0.043	0.012	
11:15:45	-0.006	0.004	
11:15:15	1.253	0.008	
11:15:30	-0.043	0.012	
11:15:45	-0.006	0.004	
11:16:00	-0.012	-0.001	
<b>11:16:15</b>	<b>-0.012</b>	<b>0.000</b>	<b>ZERO</b>
11:16:30	-0.013	0.000	
11:16:45	0.964	0.000	
11:17:00	15.944	0.492	
11:17:15	18.522	12.911	
11:17:30	18.245	17.691	
11:17:45	18.076	17.759	
11:18:00	18.196	18.006	
11:18:15	18.240	18.056	
11:18:30	18.242	17.969	
11:18:45	18.222	17.924	
11:19:00	18.159	17.927	
11:19:15	18.142	17.935	
<b>11:19:30</b>	<b>18.138</b>	<b>17.939</b>	<b>SPAN</b>
11:19:45	18.139	17.940	
11:20:00	18.138	17.946	
11:20:15	18.140	17.949	
11:20:30	18.141	17.951	
11:20:45	19.422	10.398	
11:21:00	13.395	6.155	
11:21:15	9.683	9.374	
11:21:30	9.504	9.583	
11:21:45	9.499	9.587	
11:22:00	9.499	9.587	
<b>11:22:15</b>	<b>9.499</b>	<b>9.588</b>	<b>LINEARITY</b>
11:22:30	9.499	9.586	
11:22:45	13.077	7.631	
11:23:00	20.146	0.922	
11:23:15	20.620	0.138	
11:23:30	13.094	5.641	
11:23:45	9.026	10.230	
<b>11:24:00</b>	<b>8.789</b>	<b>10.533</b>	<b>U2 R1 M26A OUTLET</b>
11:24:15	8.783	10.545	
11:24:30	8.780	10.544	
11:24:45	8.993	10.548	

Prepared by Clean Air Engineering Proprietary Software  
 SS CEM Version 08-2004a

Copyright © 2004 Clean Air Engineering Inc.

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 27, 2013  
 Start Time 11:14  
 Stop time 12:17

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
11:25:00	17.197	4.401	
11:25:15	16.988	2.425	
11:25:30	9.721	9.288	
11:25:45	8.890	10.396	
11:26:00	8.883	10.506	
11:26:15	8.883	10.509	
11:26:30	<b>8.883</b>	<b>10.513</b>	<b>U2 R2 M26A OUTLET</b>
11:26:45	8.883	10.513	
11:27:00	8.887	10.517	
11:27:15	15.720	5.836	
11:27:30	20.434	0.471	
11:27:45	20.026	0.287	
11:28:00	11.083	7.644	
11:28:15	8.369	10.889	
11:28:30	<b>8.240</b>	<b>11.057</b>	<b>U2 R1 M26A INLET</b>
11:28:45	8.234	11.070	
11:29:00	8.234	11.076	
11:29:15	8.235	11.079	
11:29:30	12.801	8.296	
11:29:45	20.015	1.001	
11:30:00	20.683	0.149	
11:30:15	19.909	0.333	
11:30:30	11.048	7.790	
11:30:45	8.520	10.822	
11:31:00	8.401	10.986	
11:31:15	<b>8.396</b>	<b>10.999</b>	<b>U2 R2 M26A INLET</b>
11:31:30	8.398	11.001	
11:31:45	8.398	11.000	
11:32:00	10.619	10.028	
11:32:15	19.207	1.949	
11:32:30	20.639	0.202	
11:32:45	20.676	0.134	
11:33:00	14.718	4.217	
11:33:15	9.598	9.599	
11:33:30	<b>9.243</b>	<b>10.087</b>	<b>U3 R2 M5/29</b>
11:33:45	9.231	10.113	
11:34:00	9.231	10.120	
11:34:15	9.231	10.124	
11:34:30	9.231	10.124	
11:34:45	9.234	10.126	
11:35:00	11.961	8.743	
11:35:15	19.635	1.429	
11:35:30	20.662	0.173	<-- Paused at 11:35:34

**Wheelabrator**  
**CleanAir Project No. 12218**  
**South Broward**  
**FF Outlet, SDA Inlet**

March 27, 2013  
 Start Time 11:14  
 Stop time 12:17

**IGS Bag Analysis**

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
12:05:40	20.678	0.096	
12:05:55	20.671	0.094	
12:06:10	14.784	4.171	
12:06:25	10.077	9.164	
12:06:40	9.728	9.652	
<b>12:06:55</b>	<b>9.718</b>	<b>9.683</b>	<b>U2 R3 M26A OUTLET</b>
12:07:10	9.719	9.689	
12:07:25	9.720	9.692	
12:07:40	10.394	9.584	
12:07:55	16.391	3.974	
12:08:10	10.837	8.224	
12:08:25	9.449	9.887	
<b>12:08:40</b>	<b>9.339</b>	<b>9.953</b>	<b>U2 R3 M26A INLET</b>
12:08:55	9.376	9.948	
12:09:10	9.371	9.951	
12:09:25	15.858	5.654	
12:09:40	20.518	0.321	
12:09:55	19.993	0.279	
12:10:10	11.269	7.483	
12:10:25	9.195	10.077	
12:10:40	9.138	10.173	
12:10:55	9.139	10.181	
<b>12:11:10</b>	<b>9.134</b>	<b>10.152</b>	<b>U2 R4 M23</b>
12:11:25	9.139	10.189	
12:11:40	11.260	9.247	
12:11:55	19.341	1.763	
12:12:10	20.644	0.191	
12:12:25	19.990	0.123	
12:12:40	4.933	0.053	
12:12:55	0.151	0.022	
12:13:10	0.020	0.018	
12:13:25	0.014	0.017	
<b>12:13:40</b>	<b>0.012</b>	<b>0.012</b>	<b>ZERO</b>
12:13:55	0.010	0.012	
12:14:10	0.010	0.011	
12:14:25	0.006	0.011	
12:14:40	8.264	0.055	
12:14:55	19.897	0.110	
12:15:10	20.519	0.361	
12:15:25	18.593	12.894	
12:15:40	18.130	17.569	
12:15:55	18.120	17.791	
12:16:10	18.124	17.899	



Wheelabrator  
CleanAir Project No. 12218  
South Broward  
FF Outlet, SDA Inlet

March 27, 2013  
Start Time 11:14  
Stop time 12:17

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
12:16:25	18.126	17.915	SPAN
12:16:40	18.126	17.922	
12:16:55	18.124	17.923	
12:17:10	19.387	11.003	
12:17:25	20.617	0.902	

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 27, 2013  
 Start Time 14:32  
 Stop time 14:48

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2
	FF Outlet %dv	FF Outlet %dv
<b>Calibration Checks</b>		
C <sub>oi</sub> Initial zero	0.031	0.005
C <sub>ui</sub> Initial upscale	18.081	17.889
C <sub>of</sub> Final zero	0.040	0.039
C <sub>uf</sub> Final upscale	18.086	17.859
C <sub>ma</sub> Actual gas value	18.100	17.900
<b>U3 R3 5/29</b>		
C <sub>Avg</sub> Average conc.	9.711	9.594
C <sub>Gas</sub> Bias adjusted	<b>9.70</b>	<b>9.60</b>
<b>U2 R4 M29</b>		
C <sub>Avg</sub> Average conc.	9.397	10.017
C <sub>Gas</sub> Bias adjusted	<b>9.39</b>	<b>10.02</b>
<b>U3 R4 M29</b>		
C <sub>Avg</sub> Average conc.	10.023	9.366
C <sub>Gas</sub> Bias adjusted	<b>10.02</b>	<b>9.37</b>

040813 123405

14:33:14	20.604	0.113	
14:33:14	20.604	0.113	
14:33:29	17.125	0.112	
14:33:44	1.727	0.027	
14:33:59	0.056	0.006	
14:34:14	0.035	0.005	
<b>14:34:29</b>	<b>0.031</b>	<b>0.005</b>	<b>ZERO</b>
14:34:44	0.031	0.004	
14:34:59	11.945	0.890	
14:35:14	18.051	14.229	
14:35:29	18.083	17.582	
14:35:44	18.080	17.885	
<b>14:35:59</b>	<b>18.081</b>	<b>17.889</b>	<b>SPAN</b>
14:36:14	18.116	17.888	
14:36:29	19.051	8.062	
14:36:44	11.711	7.468	
14:36:59	9.567	9.412	
14:37:14	9.482	9.510	
<b>14:37:29</b>	<b>9.481</b>	<b>9.512</b>	<b>LINEARITY</b>
14:37:44	10.464	9.301	
14:37:59	18.626	2.505	

Wheelabrator  
 CleanAir Project No. 12218  
 South Broward  
 FF Outlet, SDA Inlet

March 27, 2013  
 Start Time 14:32  
 Stop time 14:48

IGS Bag Analysis

	Channel 1 O2	Channel 2 CO2	
	FF Outlet %dv	FF Outlet %dv	
14:38:14	20.585	0.211	
14:38:29	18.946	0.901	
14:38:44	11.075	7.909	
14:38:59	9.756	9.514	
14:39:14	9.711	9.587	
<b>14:39:29</b>	<b>9.711</b>	<b>9.594</b>	<b>U3 R3 5/29</b>
14:39:44	10.630	9.397	
14:39:59	18.530	2.643	
14:40:14	20.558	0.225	
14:40:29	18.997	0.864	
14:40:44	10.716	7.960	
14:40:59	9.433	9.864	
14:41:14	9.396	10.007	
<b>14:41:29</b>	<b>9.397</b>	<b>10.017</b>	<b>U2 R4 M29</b>
14:41:44	9.399	10.024	
14:41:59	15.320	6.034	
14:42:14	20.297	0.578	
14:42:29	20.615	0.146	
14:42:44	20.616	0.129	
14:42:59	20.614	0.121	
14:43:14	20.612	0.116	
14:43:29	20.238	0.157	
14:43:44	12.733	6.181	
14:43:59	10.201	9.200	
14:44:14	10.091	9.409	
14:44:29	10.061	9.344	
<b>14:44:44</b>	<b>10.023</b>	<b>9.366</b>	<b>U3 R4 M29</b>
14:44:59	10.091	9.405	
14:45:14	12.540	8.179	
14:45:29	18.038	10.117	
14:45:44	18.058	17.157	
14:45:59	18.087	17.808	
14:46:14	18.086	17.837	
14:46:29	18.085	17.851	
<b>14:46:44</b>	<b>18.086</b>	<b>17.859</b>	<b>SPAN</b>
14:46:59	18.085	17.874	
14:47:14	18.328	13.540	
14:47:29	5.500	1.780	
14:47:44	0.255	0.146	
14:47:59	0.046	0.051	
<b>14:48:14</b>	<b>0.040</b>	<b>0.039</b>	<b>ZERO</b>

WHEELABRATOR SOUTH BROWARD, INC.

Clean Air Project No: 12218

Location: Ash Unloading Area

Date (2013): March 27

Start Time: 7:55

End Time: 9:05

**METHOD 22 FIELD DATA PRINTOUT**

Run	Clock Time (start)	Observation Period (minutes)	Accumulated Emission Duration (seconds)
1	7:55 8:15	20	13
2	8:20 8:40	20	0
3	8:45 9:05	20	0

Total (% of observation time) = 0.36

Total (minutes) = 0.22

WHEELABRATOR SOUTH BROWARD, INC.

Clean Air Project No: 12218

Location: Door to Baghouse / Ash Unloading

Date (2013): March 27

Start Time: 10:20

End Time: 11:30

**METHOD 22 FIELD DATA PRINTOUT**

Run	Clock Time (start)	Observation Period (minutes)	Accumulated Emission Duration (seconds)
1	10:20 10:40	20	0
2	10:45 11:05	20	0
3	11:10 11:30	20	0

Total (% of observation time) = 0.0

Total (minutes) = 0.0

WHEELABRATOR SOUTH BROWARD, INC.

Clean Air Project No: 12218

Location: Rolling Door/Door to Baghouse

Date (2013): March 27

Start Time: 12:30

End Time: 13:40

**METHOD 22 FIELD DATA PRINTOUT**

Run	Clock Time (start)	Observation Period (minutes)	Accumulated Emission Duration (seconds)
1	12:30 12:50	20	0
2	12:55 13:15	20	0
3	13:20 13:40	20	0

Total (% of observation time) = 0.0

Total (minutes) = 0.0

**LABORATORY DATA**

*I herby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: ML

Date: 5/6/13



**This Page Intentionally Left Blank**



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

### USEPA Method 5/202 (FPM/CPM) Gravimetric Laboratory Data Summary for FPM

Run No.  Draft Lab Data

Run No.	Blank	1	2	3
Date (2013)		Mar 25	Mar 26	Mar 26
Start Time (approx.)		12:26	07:51	10:25
Stop Time (approx.)		14:40	10:03	12:36

**Analytical Detection Limits**

MDL <sub>f</sub>	Minimum detection limit for filter (g)	0.00010
MDL <sub>s</sub>	Minimum detection limit for solvent rinse (g)	0.00010

**Filter(s)**

m <sub>f1</sub>	Filter No. 1 residue mass (g)	0.00220	0.00190	0.00190
m <sub>f2</sub>	Filter No. 2 residue mass (g)			
m <sub>f3</sub>	Filter No. 3 residue mass (g)			
m <sub>f4</sub>	Filter No. 4 residue mass (g)			
m <sub>filter</sub>	Total filter residue (g)	0.00220	0.00190	0.00190

**First Solvent Rinse**

Acetone

ρ <sub>1</sub>	Density (g/mL)	0.785		
V <sub>s1</sub>	Sample volume (mL)	150	78	94
V <sub>a1</sub>	Aliquot volume (mL)	144	150	94
r <sub>s1</sub>	Aliquot residue mass (g)	0.00040	0.00460	0.00260
r <sub>s1</sub>	Sample residue mass (g)		0.00460	0.00260
m <sub>b1</sub>	Allowable blank correction (g)		0.00042	0.00022
m <sub>1</sub>	Net residue mass (g)		0.00418	0.00238

**Second Solvent Rinse**

N/A

ρ <sub>2</sub>	Density (g/mL)			
V <sub>s2</sub>	Sample volume (mL)			
V <sub>a2</sub>	Aliquot volume (mL)			
r <sub>s2</sub>	Aliquot residue mass (g)			
r <sub>s2</sub>	Sample residue mass (g)			
m <sub>b2</sub>	Allowable blank correction (g)			
m <sub>2</sub>	Net residue mass (g)	0.00000	0.00000	0.00000

m <sub>s</sub>	Total Solvent Residue (g)	0.00418	0.00238	0.00164
m <sub>T</sub>	Total Gravimetric Result (g)	0.00638	0.00428	0.00354
m <sub>D</sub>	Total Gravimetric Detection Limit (g)	0.00020	0.00020	0.00020
m <sub>n</sub>	Total Filterable Particulate Matter (g)	0.00638	0.00428	0.00354
n <sub>MDL</sub>	Number of Non-Detectable Fractions	N/A	N/A	N/A
DLC	Detection Level Classification	ADL	ADL	ADL

Comments:

For analytical results below detection limits:

- Run samples are treated as the entire value of the MDL in calculations.
- Reagent blank samples are treated as zero in calculations.

Detection level classifications are defined as follows:

- ADL = Above Detection Level - all fractions are above detection limit
- DLL = Detection Level Limited - some fractions are below detection limit
- BDL = Below Detection Limit - all fractions are below detection limit

042313 084947

**USEPA Method 5/202 (FPM/CPM)  
 Gravimetric Laboratory Data Summary for FPM**

Run No.	<input type="checkbox"/> Draft Lab Data	Blank	1	2	3
Date (2013)			Mar 25	Mar 25	Mar 25
Start Time (approx.)			07:59	10:32	13:04
Stop Time (approx.)			10:11	12:45	15:17

**Analytical Detection Limits**

MDL <sub>f</sub>	Minimum detection limit for filter (g)	0.00010
MDL <sub>s</sub>	Minimum detection limit for solvent rinse (g)	0.00010

**Filter(s)**

m <sub>f1</sub>	Filter No. 1 residue mass (g)	0.00480	0.00440	0.00530
m <sub>f2</sub>	Filter No. 2 residue mass (g)			
m <sub>f3</sub>	Filter No. 3 residue mass (g)			
m <sub>f4</sub>	Filter No. 4 residue mass (g)			
m <sub>filter</sub>	Total filter residue (g)	0.00480	0.00440	0.00530

**First Solvent Rinse**

Acetone

ρ <sub>1</sub>	Density (g/mL)	0.785			
v <sub>s1</sub>	Sample volume (mL)		74	52	82
v <sub>a1</sub>	Aliquot volume (mL)	144	74	52	82
r <sub>a1</sub>	Aliquot residue mass (g)	0.00040	0.00700	0.00480	0.00400
r <sub>s1</sub>	Sample residue mass (g)		0.00700	0.00480	0.00400
m <sub>b1</sub>	Allowable blank correction (g)		0.00021	0.00014	0.00023
m <sub>1</sub>	Net residue mass (g)		0.00679	0.00466	0.00377

**Second Solvent Rinse**

N/A

ρ <sub>2</sub>	Density (g/mL)				
v <sub>s2</sub>	Sample volume (mL)				
v <sub>a2</sub>	Aliquot volume (mL)				
r <sub>a2</sub>	Aliquot residue mass (g)				
r <sub>s2</sub>	Sample residue mass (g)				
m <sub>b2</sub>	Allowable blank correction (g)				
m <sub>2</sub>	Net residue mass (g)		0.00000	0.00000	0.00000

m <sub>s</sub>	Total Solvent Residue (g)		0.00679	0.00466	0.00377
m <sub>T</sub>	Total Gravimetric Result (g)		0.01159	0.00906	0.00907
m <sub>D</sub>	Total Gravimetric Detection Limit (g)		0.00020	0.00020	0.00020
m <sub>n</sub>	Total Filterable Particulate Matter (g)		0.01159	0.00906	0.00907
n <sub>MDL</sub>	Number of Non-Detectable Fractions		N/A	N/A	N/A
DLC	Detection Level Classification		ADL	ADL	ADL

**Comments:**

For analytical results below detection limits:

Run samples are treated as the entire value of the MDL in calculations.

Reagent blank samples are treated as zero in calculations.

Detection level classifications are defined as follows:

ADL = Above Detection Level - all fractions are above detection limit

DLL = Detection Level Limited - some fractions are below detection limit

BDL = Below Detection Limit - all fractions are below detection limit

042313 085900

**USEPA Method 5/202 (FPM/CPM)  
 Gravimetric Laboratory Data Summary for FPM**

Run No.  Draft Lab Data

	Blank	1	2	3
Date (2013)		Mar 26	Mar 27	Mar 27
Start Time (approx.)		12:11	07:28	09:59
Stop Time (approx.)		14:24	09:41	12:11

**Analytical Detection Limits**

MDL <sub>f</sub>	Minimum detection limit for filter (g)	0.00010
MDL <sub>s</sub>	Minimum detection limit for solvent rinse (g)	0.00010

**Filter(s)**

m <sub>f1</sub>	Filter No. 1 residue mass (g)	0.00940	0.01080	0.00930
m <sub>f2</sub>	Filter No. 2 residue mass (g)			
m <sub>f3</sub>	Filter No. 3 residue mass (g)			
m <sub>f4</sub>	Filter No. 4 residue mass (g)			
m <sub>filter</sub>	Total filter residue (g)	0.00940	0.01080	0.00930

**First Solvent Rinse**

Acetone

ρ <sub>1</sub>	Density (g/mL)	0.785		
V <sub>s1</sub>	Sample volume (mL)		130	42
V <sub>a1</sub>	Aliquot volume (mL)	144	130	42
r <sub>a1</sub>	Aliquot residue mass (g)	0.00040	0.00650	0.00890
r <sub>s1</sub>	Sample residue mass (g)		0.00650	0.00890
m <sub>b1</sub>	Allowable blank correction (g)		0.00036	0.00012
m <sub>1</sub>	Net residue mass (g)		0.00614	0.00878

**Second Solvent Rinse**

N/A

ρ <sub>2</sub>	Density (g/mL)			
V <sub>s2</sub>	Sample volume (mL)			
V <sub>a2</sub>	Aliquot volume (mL)			
r <sub>a2</sub>	Aliquot residue mass (g)			
r <sub>s2</sub>	Sample residue mass (g)			
m <sub>b2</sub>	Allowable blank correction (g)			
m <sub>2</sub>	Net residue mass (g)		0.00000	0.00000

m <sub>s</sub>	Total Solvent Residue (g)	0.00614	0.00878	0.01299
m <sub>T</sub>	Total Gravimetric Result (g)	0.01554	0.01958	0.02229
m <sub>D</sub>	Total Gravimetric Detection Limit (g)	0.00020	0.00020	0.00020
m <sub>n</sub>	Total Filterable Particulate Matter (g)	0.01554	0.01958	0.02229
n <sub>MDL</sub>	Number of Non-Detectable Fractions	N/A	N/A	N/A
DLC	Detection Level Classification	ADL	ADL	ADL

**Comments:**

For analytical results below detection limits:

Run samples are treated as the entire value of the MDL in calculations.

Reagent blank samples are treated as zero in calculations.

Detection level classifications are defined as follows:

ADL = Above Detection Level - all fractions are above detection limit

DLL = Detection Level Limited - some fractions are below detection limit

BDL = Below Detection Limit - all fractions are below detection limit

042313 090120

Wheelabrator South Broward, Inc.  
Clean Air Project No: 12218  
Unit 1 FF Outlet

### USEPA Method 5/29 (Particulate/Metals) Cadmium (Cd) Laboratory Parameters

Run No.	1	2	3
Date (2013)	Mar 25	Mar 26	Mar 26
Start Time (approx.)	12:26	07:51	10:25
Stop Time (approx.)	14:40	10:03	12:36
<b>Combined Front and Back Analyses</b>			
$m_{F-DL}$ Front half detection limit ( $\mu\text{g}$ )	0.2000	0.2000	0.2000
$m_{FS}$ Matter collected in front half sample ( $\mu\text{g}$ )	0.2729	<0.2000	<0.2000
$m_{FB}$ Matter collected in front half blank ( $\mu\text{g}$ )	<0.2000	<0.2000	<0.2000
$m_{FB-allow}$ Allowable front half blank correction ( $\mu\text{g}$ )	0.0000	0.0000	0.0000
$m_n$ Total matter corrected for allowable blanks ( $\mu\text{g}$ )	0.2729	<0.2000	<0.2000

042313 084947  
M

Wheelabrator South Broward, Inc.  
Clean Air Project No: 12218  
Unit 1 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
Lead (Pb) Laboratory Parameters**

Run No.	1	2	3
Date (2013)	Mar 25	Mar 26	Mar 26
Start Time (approx.)	12:26	07:51	10:25
Stop Time (approx.)	14:40	10:03	12:36
<b>Combined Front and Back Analyses</b>			
$m_{F-DL}$ Front half detection limit ( $\mu\text{g}$ )	0.2000	0.2000	0.2000
$m_{FS}$ Matter collected in front half sample ( $\mu\text{g}$ )	0.8561	0.5509	0.5243
$m_{FB}$ Matter collected in front half blank ( $\mu\text{g}$ )	0.3264	0.3264	0.3264
$m_{FB-allow}$ Allowable front half blank correction ( $\mu\text{g}$ )	0.3264	0.3264	0.3264
$m_n$ Total matter corrected for allowable blanks ( $\mu\text{g}$ )	0.5297	0.2245	<0.2000

1-7

042313 084947  
M

Wheelabrator South Broward, Inc.  
Clean Air Project No: 12218  
Unit 2 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
Cadmium (Cd) Laboratory Parameters**

Run No.	1	2	3
Date (2013)	Mar 25	Mar 25	Mar 25
Start Time (approx.)	07:59	10:32	13:04
Stop Time (approx.)	10:11	12:45	15:17
<b>Combined Front and Back Analyses</b>			
$m_{F-DL}$ Front half detection limit ( $\mu\text{g}$ )	0.2000	0.2000	0.2000
$m_{FS}$ Matter collected in front half sample ( $\mu\text{g}$ )	2.0285	2.0936	1.7367
$m_{FB}$ Matter collected in front half blank ( $\mu\text{g}$ )	<0.2000	<0.2000	<0.2000
$m_{FB-allow}$ Allowable front half blank correction ( $\mu\text{g}$ )	0.0000	0.0000	0.0000
$m_n$ Total matter corrected for allowable blanks ( $\mu\text{g}$ )	2.0285	2.0936	1.7367

042313 085900  
L

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
 Lead (Pb) Laboratory Parameters**

Run No.	1	2	3
Date (2013)	Mar 25	Mar 25	Mar 25
Start Time (approx.)	07:59	10:32	13:04
Stop Time (approx.)	10:11	12:45	15:17
<b>Combined Front and Back Analyses</b>			
m <sub>F-DL</sub> Front half detection limit (µg)	0.2000	0.2000	0.2000
m <sub>FS</sub> Matter collected in front half sample (µg)	11.6146	16.3997	19.2155
m <sub>FB</sub> Matter collected in front half blank (µg)	0.3264	0.3264	0.3264
m <sub>FB-allow</sub> Allowable front half blank correction (µg)	0.3264	0.3264	0.3264
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	11.2882	16.0733	18.8891

6-1

042313 085900

L

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 3 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
 Cadmium (Cd) Laboratory Parameters**

Run No.	1	2	3
Date (2013)	Mar 26	Mar 27	Mar 27
Start Time (approx.)	12:11	07:28	09:59
Stop Time (approx.)	14:24	09:41	12:11
<b>Combined Front and Back Analyses</b>			
m <sub>F-DL</sub> Front half detection limit (µg)	0.2000	0.2000	0.2000
m <sub>FS</sub> Matter collected in front half sample (µg)	5.2617	3.6665	4.1661
m <sub>FB</sub> Matter collected in front half blank (µg)	<0.2000	<0.2000	<0.2000
m <sub>FB-allow</sub> Allowable front half blank correction (µg)	0.0000	0.0000	0.0000
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	5.2617	3.6665	4.1661

I - 10

042313 090120  
 J



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 3 FF Outlet

**USEPA Method 5/29 (Particulate/Metals)  
 Lead (Pb) Laboratory Parameters**

Run No.	1	2	3
Date (2013)	Mar 26	Mar 27	Mar 27
Start Time (approx.)	12:11	07:28	09:59
Stop Time (approx.)	14:24	09:41	12:11
<b>Combined Front and Back Analyses</b>			
m <sub>F-DL</sub> Front half detection limit (µg)	0.2000	0.2000	0.2000
m <sub>FS</sub> Matter collected in front half sample (µg)	40.0660	27.3831	32.2038
m <sub>FB</sub> Matter collected in front half blank (µg)	0.3264	0.3264	0.3264
m <sub>FB-allow</sub> Allowable front half blank correction (µg)	0.3264	0.3264	0.3264
m <sub>n</sub> Total matter corrected for allowable blanks (µg)	39.7396	27.0566	31.8773

L-11

042313 090120  
 J

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Laboratory Parameters**

**Detection Limits**

m <sub>1b-DL</sub>	Fraction 1B Detection Limit (µg)	0.1000
m <sub>2b-DL</sub>	Fraction 2B Detection Limit (µg)	0.2000
m <sub>3a-DL</sub>	Fraction 3A Detection Limit (µg)	0.2000
m <sub>3b-DL</sub>	Fraction 3B Detection Limit (µg)	0.5000
m <sub>3c-DL</sub>	Fraction 3C Detection Limit (µg)	0.4000

**Blank Analysis**

m <sub>1b-B</sub>	Fraction 1B Blank (µg)	<0.1000
m <sub>2b-B</sub>	Fraction 2B Blank (µg)	<0.2000
m <sub>3a-B</sub>	Fraction 3A Blank (µg)	<0.2000
m <sub>3b-B</sub>	Fraction 3B Blank (µg)	<0.5000
m <sub>3c-B</sub>	Fraction 3C Blank (µg)	<0.4000
m <sub>total-B</sub>	Total Blank Amount (µg)	<1.4000

**Run No.**

	1	2	3	4
Date (2013)	Mar 25	Mar 26	Mar 26	Mar 26
Start Time (approx.)	12:26	07:51	10:25	12:59
Stop Time (approx.)	14:40	10:03	12:36	15:11

**Sample Analysis**

m <sub>1b-S</sub>	Fraction 1B Sample (µg)	<0.1000	<0.1000	<0.1000	<0.1000
m <sub>2b-S</sub>	Fraction 2B Sample (µg)	<0.8000	<0.8000	<0.7000	<0.7000
m <sub>3a-S</sub>	Fraction 3A Sample (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>3b-S</sub>	Fraction 3B Sample (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>3c-S</sub>	Fraction 3C Sample (µg)	<0.4000	<0.4000	<0.4000	<0.4000
m <sub>total-S</sub>	Total Sample Amount (µg)	<0.8000	<0.8000	<0.7000	<0.7000

**Allowable Blank**

m <sub>T-B-allow</sub>	Total Allowable Blank (µg)	0.0000	0.0000	0.0000	0.0000
------------------------	----------------------------	--------	--------	--------	--------

**Sample Corrected for Blank**

m <sub>n</sub>	Total Sample Amount (µg)	<0.8000	<0.8000	<0.7000	<0.7000
----------------	--------------------------	---------	---------	---------	---------

**Sample Corrected for Blank - Prorated Fractions**

m <sub>n-1b</sub>	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	<0.1000
m <sub>n-2b</sub>	Fraction 2B (µg)	<0.8000	<0.8000	<0.7000	<0.7000
m <sub>n-3a</sub>	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>n-3b</sub>	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>n-3c</sub>	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	<0.4000

042313 085847  
 N

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Laboratory Parameters**

**Detection Limits**

m <sub>1b-DL</sub>	Fraction 1B Detection Limit (µg)	0.1000
m <sub>2b-DL</sub>	Fraction 2B Detection Limit (µg)	0.2000
m <sub>3a-DL</sub>	Fraction 3A Detection Limit (µg)	0.2000
m <sub>3b-DL</sub>	Fraction 3B Detection Limit (µg)	0.5000
m <sub>3c-DL</sub>	Fraction 3C Detection Limit (µg)	0.4000

**Blank Analysis**

m <sub>1b-B</sub>	Fraction 1B Blank (µg)	<0.1000
m <sub>2b-B</sub>	Fraction 2B Blank (µg)	<0.2000
m <sub>3a-B</sub>	Fraction 3A Blank (µg)	<0.2000
m <sub>3b-B</sub>	Fraction 3B Blank (µg)	<0.5000
m <sub>3c-B</sub>	Fraction 3C Blank (µg)	<0.4000
m <sub>total-B</sub>	Total Blank Amount (µg)	<1.4000

**Run No.**

	1	2	3	4
Date (2013)	Mar 25	Mar 25	Mar 25	Mar 27
Start Time (approx.)	07:59	10:32	13:04	12:07
Stop Time (approx.)	10:11	12:45	15:17	14:22

**Sample Analysis**

	1	2	3	4	
m <sub>1b-S</sub>	Fraction 1B Sample (µg)	<0.1000	<0.1000	<0.1000	<0.1000
m <sub>2b-S</sub>	Fraction 2B Sample (µg)	0.8805	1.0329	1.0367	1.1187
m <sub>3a-S</sub>	Fraction 3A Sample (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>3b-S</sub>	Fraction 3B Sample (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>3c-S</sub>	Fraction 3C Sample (µg)	<0.4000	<0.4000	<0.4000	<0.4000
m <sub>total-S</sub>	Total Sample Amount (µg)	0.8805	1.0329	1.0367	1.1187

**Allowable Blank**

m <sub>T-B-allow</sub>	Total Allowable Blank (µg)	0.0000	0.0000	0.0000	0.0000
------------------------	----------------------------	--------	--------	--------	--------

**Sample Corrected for Blank**

m <sub>n</sub>	Total Sample Amount (µg)	0.8805	1.0329	1.0367	1.1187
----------------	--------------------------	--------	--------	--------	--------

**Sample Corrected for Blank - Prorated Fractions**

	1	2	3	4	
m <sub>n-1b</sub>	Fraction 1B (µg)	<0.1000	<0.1000	<0.1000	<0.1000
m <sub>n-2b</sub>	Fraction 2B (µg)	0.8805	1.0329	1.0367	1.1187
m <sub>n-3a</sub>	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>n-3b</sub>	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>n-3c</sub>	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	<0.4000

042313 085928  
L

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 3 FF Outlet

**USEPA Method 29 (Mercury)  
 Mercury (Hg) Laboratory Parameters**

**Detection Limits**

m <sub>1b-DL</sub>	Fraction 1B Detection Limit (µg)	0.1000
m <sub>2b-DL</sub>	Fraction 2B Detection Limit (µg)	0.2000
m <sub>3a-DL</sub>	Fraction 3A Detection Limit (µg)	0.2000
m <sub>3b-DL</sub>	Fraction 3B Detection Limit (µg)	0.5000
m <sub>3c-DL</sub>	Fraction 3C Detection Limit (µg)	0.4000

**Blank Analysis**

m <sub>1b-B</sub>	Fraction 1B Blank (µg)	<0.1000
m <sub>2b-B</sub>	Fraction 2B Blank (µg)	<0.2000
m <sub>3a-B</sub>	Fraction 3A Blank (µg)	<0.2000
m <sub>3b-B</sub>	Fraction 3B Blank (µg)	<0.5000
m <sub>3c-B</sub>	Fraction 3C Blank (µg)	<0.4000
m <sub>total-B</sub>	Total Blank Amount (µg)	<1.4000

**Run No.**

	1	2	3	4
Date (2013)	Mar 26	Mar 27	Mar 27	Mar 27
Start Time (approx.)	12:11	07:28	09:59	12:29
Stop Time (approx.)	14:24	09:41	12:11	14:41

**Sample Analysis**

m <sub>1b-S</sub>	Fraction 1B Sample (µg)	<0.1000	0.1468	<0.1000	0.1548
m <sub>2b-S</sub>	Fraction 2B Sample (µg)	1.3447	3.1709	3.2687	2.4133
m <sub>3a-S</sub>	Fraction 3A Sample (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>3b-S</sub>	Fraction 3B Sample (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>3c-S</sub>	Fraction 3C Sample (µg)	<0.4000	<0.4000	<0.4000	<0.4000
m <sub>total-S</sub>	Total Sample Amount (µg)	1.3447	3.3176	3.2687	2.5681

**Allowable Blank**

m <sub>T-B-allow</sub>	Total Allowable Blank (µg)	0.0000	0.0000	0.0000	0.0000
------------------------	----------------------------	--------	--------	--------	--------

**Sample Corrected for Blank**

m <sub>n</sub>	Total Sample Amount (µg)	1.3447	3.3176	3.2687	2.5681
----------------	--------------------------	--------	--------	--------	--------

**Sample Corrected for Blank - Prorated Fractions**

m <sub>n-1b</sub>	Fraction 1B (µg)	<0.1000	0.1468	<0.1000	0.1548
m <sub>n-2b</sub>	Fraction 2B (µg)	1.3447	3.1709	3.2687	2.4133
m <sub>n-3a</sub>	Fraction 3A (µg)	<0.2000	<0.2000	<0.2000	<0.2000
m <sub>n-3b</sub>	Fraction 3B (µg)	<0.5000	<0.5000	<0.5000	<0.5000
m <sub>n-3c</sub>	Fraction 3C (µg)	<0.4000	<0.4000	<0.4000	<0.4000

042313 090148  
 K

**Clean Air Engineering, Inc.**  
500 West Wood Street  
Palatine, IL 60067

Project Number: 12218

Particulate Matter, Cadmium, Lead,  
& Mercury

EPA Methods 29 & 5 Analyses


Analytical Report  
20241



Element One, Inc.  
6319-D Carolina Beach Rd., Wilmington, NC 28412  
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com

The following data for Analytical Report 20241  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Review by:



Daphne Woodman, Chemist  
April 15, 2013

Report Reviewed and Finalized By:



Ken Smith, Laboratory Director  
April 15, 2013

**elementOne**

20241 CAE M29-5 Report Packet  
Page 2 of 46

# SUMMARY OF RESULTS

**elementOne**

20241 CAE M29-5 Report Packet  
Page 3 of 46

## Summary of Analysis

### Summary of Method 29 Mercury Analysis

Run Number		Average Total	Front Half	H <sub>2</sub> O <sub>2</sub>	Empty	KMnO <sub>4</sub>	HCl
		Catch, µg	µg	/HNO <sub>3</sub>	Impinger	µg	µg
U1 FF Outlet R1	#1	< 0.8	< 0.1	< 0.8	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.8	< 0.2	< 0.5	< 0.4
U1 FF Outlet R2	#1	< 0.8	< 0.1	< 0.8	< 0.2	< 0.6	< 0.4
	#2		< 0.1	< 0.8	< 0.2	< 0.6	< 0.4
U1 FF Outlet R3	#1	< 0.7	< 0.1	< 0.7	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.7	< 0.2	< 0.5	< 0.4
U1 FF Outlet R4	#1	< 0.7	< 0.1	< 0.7	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.7	< 0.2	< 0.5	< 0.4
U2 FF Outlet R1	#1	0.881	< 0.1	0.872	< 0.2	< 0.5	< 0.4
	#2		< 0.1	0.889	< 0.2	< 0.5	< 0.4
U2 FF Outlet R2	#1	1.03	< 0.1	1.04	< 0.2	< 0.5	< 0.4
	#2		< 0.1	1.02	< 0.2	< 0.5	< 0.4
U2 FF Outlet R3	#1	1.04	< 0.1	1.03	< 0.2	< 0.5	< 0.4
	#2		< 0.1	1.04	< 0.2	< 0.5	< 0.4
U2 FF Outlet R4	#1	1.12	< 0.1	1.13	< 0.2	< 0.5	< 0.4
	#2		< 0.1	1.11	< 0.2	< 0.5	< 0.4
U3 FF Outlet R1	#1	1.34	< 0.1	1.35	< 0.2	< 0.5	< 0.4
	#2		< 0.1	1.33	< 0.2	< 0.5	< 0.4
U3 FF Outlet R2	#1	3.32	0.148	3.17	< 0.2	< 0.6	< 0.4
	#2		0.146	3.17	< 0.2	< 0.6	< 0.4
U3 FF Outlet R3	#1	3.27	< 0.1	3.28	< 0.2	< 0.5	< 0.4
	#2		< 0.1	3.26	< 0.2	< 0.5	< 0.4
U3 FF Outlet R4	#1	2.57	0.157	2.43	< 0.2	< 0.5	< 0.4
	#2		0.153	2.40	< 0.2	< 0.5	< 0.4
Field Blank	#1	< 0.5	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
Reagent Blank	#1	< 0.5	< 0.1	< 0.2	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.2	< 0.2	< 0.5	< 0.4



## Summary of Analysis

### Unit 1 - Summary of Method 5 Particulate Analysis

Fraction	U1-FF-Outlet-R1 e20241-1 Catch, mg	U1-FF-Outlet-R2 e20241-2 Catch, mg	U1-FF-Outlet-R3 e20241-3 Catch, mg
Filter	2.2	1.9	1.9
Rinse	4.6	2.6	1.9
Total PM	6.8	4.5	3.8

### Unit 1 - Summary of Method 29 Metals Analysis

Element	U1-FF-Outlet-R1 e20241-1 Total µg	U1-FF-Outlet-R2 e20241-2 Total µg	U1-FF-Outlet-R2 e20241-2 dup Total µg	U1-FF-Outlet-R3 e20241-3 Total µg
Cadmium	0.273	< 0.2	< 0.2	< 0.2
Lead	0.856	0.562	0.540	0.524

## Summary of Analysis

### Unit 2 - Summary of Method 5 Particulate Analysis

Fraction	U2-FF-Outlet-R1	U2-FF-Outlet-R2	U2-FF-Outlet-R3
	e20241-5 Catch, mg	e20241-6 Catch, mg	e20241-7 Catch, mg
Filter	4.8	4.4	5.3
Rinse	7.0	4.8	4.0
Total PM	11.8	9.2	9.3

### Unit 2 - Summary of Method 29 Metals Analysis

Element	U2-FF-Outlet-R1	U2-FF-Outlet-R2	U2-FF-Outlet-R2	U2-FF-Outlet-R3
	e20241-5 Total µg	e20241-6 Total µg	e20241-6 dup Total µg	e20241-7 Total µg
Cadmium	2.03	2.11	2.08	1.74
Lead	11.6	16.4	16.4	19.2

## Summary of Analysis

### Unit 3 - Summary of Method 5 Particulate Analysis

Fraction	U3-FF-Outlet-R1 e20241-9 Catch, mg	U3-FF-Outlet-R2 e20241-10 Catch, mg	U3-FF-Outlet-R3 e20241-11 Catch, mg
Filter	9.4	10.8	9.3
Rinse	6.5	8.9	13.4
Total PM	15.9	19.7	22.7

### Unit 3 - Summary of Method 29 Metals Analysis

Element	U3-FF-Outlet-R1 e20241-9 Total µg	U3-FF-Outlet-R2 e20241-10 Total µg	U3-FF-Outlet-R2 e20241-10 dup Total µg	U3-FF-Outlet-R3 e20241-11 Total µg
Cadmium	5.26	3.69	3.65	4.17
Lead	40.1	27.5	27.3	32.2

## Summary of Analysis

### Blanks - Summary of Method 5 Particulate Analysis

<u>Fraction</u>	<u>Reagent Blank e20241-14 Catch, mg</u>
Filter	-----
Rinse	0.4
Total PM	0.4

### Blanks - Summary of Method 29 Metals Analysis

<u>Element</u>	<u>Field Blank e20241-13 Total µg</u>	<u>Reagent Blank e20241-14 Total µg</u>
Cadmium	< 0.2	< 0.2
Lead	0.461	0.326

**elementOne**

20241 CAE M29-5 Report Packet  
Page 8 of 46

# ANALYTICAL NARRATIVE

**elementOne**

20241 CAE M29-5 Report Packet  
Page 9 of 46

## Element One Analytical Narrative

Client:	Clean Air, IL	Element One #:	20241
Client ID:	12218 South Broward	Analyst:	LAL & DBW
Method:	Methods 29 & 5	Dates Received:	04/02/13
Analytes:	PM, Cd, Pb & Hg	Dates Analyzed:	04/08-15/13

### Summary of Analysis

The Method 5 particulate samples were analyzed in accordance with EPA Method 5 guidelines. Particulate samples were weighed to a constant weight of  $\pm 0.5\text{mg}$  and reported to the nearest 0.1mg. The Method 29 samples were digested, prepared, and analyzed according to Method 29 protocol. Samples were analyzed for mercury on a PerkinElmer FIMS-100 CVAA mercury analyzer. The samples were analyzed for metals on a PerkinElmer ELAN 6100 ICP-MS.

### Detection Limits

The FIMS-100 CVAA instrument reporting limit for mercury was 0.004  $\mu\text{g}$  per aliquot analyzed. The ICP-MS instrument reporting limit was 1.0 $\mu\text{g/L}$  for the metals.

### Analysis QA/QC

Duplicate analyses relative percent difference (RPD), spike sample recovery and second source calibration verification data are summarized in the Quality Control Section. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank values or spike recovery values. The Method 5 blank correction factor has not been implemented. The ICP analysis of the Field Blank and Reagent Blank samples revealed detectable concentrations of lead.

# QUALITY CONTROL SUMMARY

**elementOne**

20241 CAE M29-5 Report Packet  
Page 11 of 46

## Summary of Quality Control Data

### Mercury Duplicate Analysis RPD

(Method 29 QC limits: < 10% for RPD)

Run Number	Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U1 FF Outlet R1	NA	NA	NA	NA	NA
U1 FF Outlet R2	NA	NA	NA	NA	NA
U1 FF Outlet R3	NA	NA	NA	NA	NA
U1 FF Outlet R4	NA	NA	NA	NA	NA
U2 FF Outlet R1	NA	1.9%	NA	NA	NA
U2 FF Outlet R2	NA	1.8%	NA	NA	NA
U2 FF Outlet R3	NA	0.6%	NA	NA	NA
U2 FF Outlet R4	NA	2.0%	NA	NA	NA
U3 FF Outlet R1	NA	1.5%	NA	NA	NA
U3 FF Outlet R2	1.0%	0.2%	NA	NA	NA
U3 FF Outlet R3	NA	0.6%	NA	NA	NA
U3 FF Outlet R4	2.3%	1.3%	NA	NA	NA
Field Blank	NA	NA	NA	NA	NA
Reagent Blank	NA	NA	NA	NA	NA

### Mercury Spike Recoveries

(Method 29 QC limits: ± 25% for Spike Recoveries)

Run Number		Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U1 FF Outlet R3	#1	88%	98%	93%	86%	102%
	#2	87%	97%	92%	86%	102%
U2 FF Outlet R3	#1	99%	93%	95%	85%	101%
	#2	100%	94%	95%	85%	100%
U3 FF Outlet R3	#1	103%	81%	96%	89%	103%
	#2	104%	80%	95%	88%	102%

**elementOne**

20241 CAE M29-5 Report Packet  
Page 12 of 46



## Summary of Quality Control Data

### Metals Duplicate Analysis RPD

(Method 29 QC limits: < 20% for RPD)

Element	U1-FF-Outlet-R2 RPD	U2-FF-Outlet-R2 RPD	U3-FF-Outlet-R2 RPD
Cadmium	NA	1.1%	1.1%
Lead	4.1%	0.6%	0.9%

### Metals Analysis Spike Recoveries

(Method 29 QC limits: ± 25% for Spike Recoveries)

Element	U1-FF-Outlet-R3 Recovery	U2-FF-Outlet-R3 Recovery	U3-FF-Outlet-R3 Recovery
Cadmium	95%	113%	102%
Lead	95%	114%	106%

### Second Source Calibration Check Recoveries

(QC limits: ±10% for Second Source Continuing Check Standard\*)

Element	1 ppb	50 ppb	100 ppb*	250 ppb
Cadmium	105%	99%	99%	100%
Lead	97%	92%	99%	101%

**elementOne**


20241 CAE M29-5 Report Packet  
Page 13 of 46

# SAMPLE CUSTODY

**elementOne**

20241 CAE M29-5 Report Packet  
Page 14 of 46

20241


CLIENT <u>Wheelabrator</u>		PROJECT <u>12218SB</u>		DEPT. <u>66</u>		66-12218SB-9	
PLANT <u>South Broward</u>		PROJECT MANAGER <u>S. Brown</u>		 <p>Clean Air 500 West Wood Street Palatka, FL 32909 800-627-0035 (phone) 847-951-3385 (fax)</p>		FORWARDING LAB Element One, Inc. 6619-4 Carolina Beach Road Wilmington, NC 28412 910-766-0128 (phone) 910-792-6853 (fax)	
ANALYTICAL METHOD <u>USEPA M-5/29</u>	CONTAINER NUMBER <u>1</u>	SAMPLE FRACTION <u>QUARTZ FILTER</u> <u>PETRI DISH</u>				ANALYSIS REQUESTED <input checked="" type="checkbox"/> Crystalline <input checked="" type="checkbox"/> Metals <input checked="" type="checkbox"/> Mercury <input checked="" type="checkbox"/> Arsenic	
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	NUMBER OF CONTAINERS	CONTAINER SEALED?	LIQUID LEVEL MARKED?
	3/25	Unit 1 FF Outlet	1	Quartz Filter No. e54-40	1	X	X X X
	3/25	Unit 1 FF Outlet	2	Quartz Filter No. e54-38	1	X	X X X
	3/26	Unit 1 FF Outlet	3	Quartz Filter No. e54-37	1	X	X X X
	3/25	Unit 1 FF Outlet	4	Quartz Filter	1		X
	3/27	FF Outlet	Field Blank	Quartz Filter	1		X X
	3/25	Unit 2 FF Outlet	1	Quartz Filter No. e54-11	1	X	X X X
	3/25	Unit 2 FF Outlet	2	Quartz Filter No. e54-10	1	X	X X X
	3/25	Unit 2 FF Outlet	3	Quartz Filter No. e54-39	1	X	X X X
	3/27	Unit 2 FF Outlet	4	Quartz Filter	1		X
	3/26	Unit 3 FF Outlet	1	Quartz Filter No. e54-38	1	X	X X X
	3/27	Unit 3 FF Outlet	2	Quartz Filter No. e54-34	1	X	X X X
	3/27	Unit 3 FF Outlet	3	Quartz Filter No. e54-33	1	X	X X X
	3/27	Unit 3 FF Outlet	4	Quartz Filter	1		X
Metals include: Cadmium (Cd) Lead (Pb)							
Relinquished By: (signature) <u>S. Brown</u>		Date / Time 4/9/2013 11:00		Relinquished By: (signature)		Date / Time	
Received By: (signature) <u>Leaderton</u>		Date / Time 4/2/13 10:40a		Received By: (signature)		Date / Time	
This form completed by:						Signature <u>S. Brown</u>	
						Date 4/1/2013	

Samples received in good condition in Escherbach and REC level 2 containers. No empty containers received - FLB


2024

CLIENT: <u>Whistleblower</u>		PROJECT: <u>12218SS</u>		FORWARDING LAB					
PLANT: <u>South Broward</u>		DEPT.: <u>00</u>		Element One, Inc.					
PROJECT MANAGER: <u>S. Brown</u>		CONTAINER NUMBER: <u>2</u>		6310-D Carolina Beach Road					
ANALYTICAL METHOD: <u>USEPA M-57B</u>		SAMPLE FRACTION: <u>FRONT HALF ACETONE RINSE</u>		Wilmington, NC 28412					
		<u>250 mL CLEAR GLASS</u>		910-750-0138 (phone)					
				910-750-6663 (fax)					
LAB ID NUMBER		DATE	TEST LOCATION	RUN NUMBER	NUMBER OF CONTAINERS	CONTAINER SEALED?	ANALYSIS REQUESTED	ADDITIONAL INFORMATION	
		[2013]					<input type="checkbox"/> Grounding <input type="checkbox"/> Metals <input type="checkbox"/> Mercury <input type="checkbox"/> Active	Nitrogen include Cadmium (Cd) Lead (Pb)	
	325		Unit 1 FF Outlet	1	1				X X X X
	326		Unit 1 FF Outlet	2	1				X X X X
	326		Unit 1 FF Outlet	3	1				X X X X
	325		Unit 2 FF Outlet	1	1				X X X X
	326		Unit 2 FF Outlet	2	1				X X X X
	326		Unit 2 FF Outlet	3	1				X X X X
	326		Unit 3 FF Outlet	1	1				X X X X
	327		Unit 3 FF Outlet	2	1				X X X X
	327		Unit 3 FF Outlet	3	1				X X X X
	327		Field Blank	NA	1				X X X X
Relinquished By: (signature)		Date / Time	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)		Date / Time		This form completed by:
S. Brown		4/13/2013 11:50			S. Brown		4/13/2013		S. Brown
Received By: (signature)		Date / Time	Received By: (signature)	Date / Time	Relinquished By: (signature)		Date / Time	Signature	
<u>S. Brown</u>		4/13/2013						Date	


20241

CLIENT <u>Wheelerbraun</u>		PROJECT <u>12218SB</u>		66-12218SB-1			
PLANT <u>South Broward</u>		DEPT. <u>68</u>					
PROJECT MANAGER <u>S. Brown</u>		 600 West Wood Street Palatka, FL 32909 800-827-4033 (phone) 847-891-3365 (fax)					
ANALYTICAL METHOD <u>USEPA M-520</u>	CONTAINER NUMBER <u>3</u>	SAMPLE FRACTION <u>FRONT HALF HNO<sub>3</sub> RINSE 250 mL HDLP</u>		ANALYSIS REQUESTED <input checked="" type="checkbox"/> Gravimetric <input checked="" type="checkbox"/> Metals <input checked="" type="checkbox"/> Mercury <input checked="" type="checkbox"/> Arsenic			
LAB ID NUMBER		DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	FORWARDING LAB Element One, Inc. 6319-D Carolina Beach Road Wilmington, NC 28412 910-793-0128 (phone) 910-793-1253 (fax)  ADDITIONAL INFORMATION	
		3/25	Unit 1 FF Outlet	1	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP	Metals include: Cadmium (Cd) Lead (Pb)	
		3/26	Unit 1 FF Outlet	2	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/26	Unit 1 FF Outlet	3	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/26	Unit 1 FF Outlet	4	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
			FF Outlet	Hold Blank	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/25	Unit 2 FF Outlet	1	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/25	Unit 2 FF Outlet	2	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/25	Unit 2 FF Outlet	3	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/27	Unit 2 FF Outlet	4	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/25	Unit 3 FF Outlet	1	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/27	Unit 3 FF Outlet	2	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/27	Unit 3 FF Outlet	3	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
		3/27	Unit 3 FF Outlet	4	Front Half HNO <sub>3</sub> Rinse, 250 mL HDLP		
Front and Back combined analysis.							
Retinquished By: (signature) <u>S. Brown</u>	Date / Time <u>4/1/2013 11:00</u>	Retinquished By: (signature)	Date / Time	Retinquished By: (signature)	Date / Time		This form completed by: <u>S. Brown</u>
Received By: (signature) <u>Log Berton</u>	Date / Time <u>4/2/13 10:42</u>	Received By: (signature)	Date / Time	Retinquished By: (signature)	Date / Time		Signature <u>[Signature]</u> Date <u>4/1/2013</u>


2024/

CLIENT <u>Wheelabrator</u>		PROJECT <u>12218SB</u>		66-12218SB-12		
PLANT <u>South Broward</u>		DEPT. <u>68</u>				
PROJECT MANAGER <u>S. Brown</u>						
ANALYTICAL METHOD <b>USEPA M-529</b>	CONTAINER NUMBER <b>4</b>	SAMPLE FRACTION <b>IMPINGERS 1-3 CATCH AND RINSE 1000 mL HDLP</b>		ANALYSIS REQUESTED <input checked="" type="checkbox"/> Gravimetric <input checked="" type="checkbox"/> Metals <input checked="" type="checkbox"/> Mercury <input checked="" type="checkbox"/> Arsenic		
		500 West Wood Street Palm Beach, FL 33467 800-627-0033 (phone) 847-991-3385 (fax)		FORWARDING LAB Element Ore, Inc. 6318-D Carolina Beech Road Wilmington, NC 28412 910-790-0128 (phone) 910-792-6853 (fax)		
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ADDITIONAL INFORMATION	
	3/25	Unit 1 FF Outlet	1	Impingers 1-3 Catch and Rinse, 1000 mL HDLP	Metals include: Cadmium (Cd) Lead (Pb)	
	3/26	Unit 1 FF Outlet	2	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/26	Unit 1 FF Outlet	3	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/26	Unit 1 FF Outlet	4	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
		FF Outlet	Field Blank	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/25	Unit 2 FF Outlet	1	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/25	Unit 2 FF Outlet	2	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/25	Unit 2 FF Outlet	3	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/27	Unit 2 FF Outlet	4	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/25	Unit 3 FF Outlet	1	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/27	Unit 3 FF Outlet	2	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/27	Unit 3 FF Outlet	3	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
	3/27	Unit 3 FF Outlet	4	Impingers 1-3 Catch and Rinse, 1000 mL HDLP		
						Front and Back combined analysis.
Relinquished By: (signature) <u>S. Brown</u>		Date / Time 4/1/2013 11:00	Relinquished By: (signature)			Date / Time
Received By: (signature) <u>Lisa Branton</u>		Date / Time 4/2/13 10:42	Received By: (signature)			Date / Time
				This form completed by: <u>S. Brown</u> Signature Date 4/1/2013		

2024/


CLIENT Wheolabrator		PROJECT 12218SB		66-12218SB-13	
PLANT South Broward		DEPT. 66			
PROJECT MANAGER S. Brown		 505 West Wood Street Palatka, FL 32909 800-627-0533 (phone) 847-991-3385 (fax)		ANALYSIS REQUESTED Gravimetric Acids Mercury Arsenic	
ANALYTICAL METHOD USEPA M-5/29	CONTAINER NUMBER 5A	SAMPLE FRACTION IMPINGER 4 CATCH AND RINSE 250 mL HDLP		FORWARDING LAB Element One, Inc. 6319-D Carolina Beach Road Wilmington, NC 28412 910-793-0128 (phone) 910-792-6553 (fax)	
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ADDITIONAL INFORMATION
	3/25	Unit 1 FF Outlet	1	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/26	Unit 1 FF Outlet	2	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/26	Unit 1 FF Outlet	3	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/26	Unit 1 FF Outlet	4	Impinger 4 Catch and Rinse, 250 mL HDLP	X
		FF Outlet	Field Blank	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/26	Unit 2 FF Outlet	1	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/26	Unit 2 FF Outlet	2	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/27	Unit 2 FF Outlet	3	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/27	Unit 2 FF Outlet	4	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/26	Unit 3 FF Outlet	1	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/27	Unit 3 FF Outlet	2	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/27	Unit 3 FF Outlet	3	Impinger 4 Catch and Rinse, 250 mL HDLP	X
	3/27	Unit 3 FF Outlet	4	Impinger 4 Catch and Rinse, 250 mL HDLP	X
Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time
S. Brown	4/15/2013 11:50				
Received By: (signature)	Date / Time	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time
<i>S. Brown</i>	4/2/13 1042				
				This form completed by: S. Brown Signature: <i>S. Brown</i> Date: 4/1/2013	

20241


CLIENT Wheelabrator		PROJECT 122185B		66-122185B-14			
PLANT South Broward		DEPT. 66					
PROJECT MANAGER S. Brown		 500 West Wood Street Panama, IL 60067 800-627-0033 (phone) 817-351-3355 (fax)		ANALYSIS REQUESTED Gaseous Metals Mercury Acetone			
ANALYTICAL METHOD USEPA M-5/29	CONTAINER NUMBER 5B	SAMPLE FRACTION IMPINGERS 5-6 CATCH AND RINSE 650 mL AMBER GLASS		FORWARDING LAB Element One, Inc. 6319-D Carolina Beach Road Wilmington, NC 28412 910-793-0128 (phone) 910-792-6853 (fax)			
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ADDITIONAL INFORMATION		
	3/25	Unit 1 FF Outlet	1	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/25	Unit 1 FF Outlet	2	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/25	Unit 1 FF Outlet	3	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/28	Unit 1 FF Outlet	4	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
		FF Outlet	Field blank	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/25	Unit 2 FF Outlet	1	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/25	Unit 2 FF Outlet	2	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/25	Unit 2 FF Outlet	3	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/27	Unit 2 FF Outlet	4	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/20	Unit 3 FF Outlet	1	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/27	Unit 3 FF Outlet	2	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/27	Unit 3 FF Outlet	3	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
	3/27	Unit 3 FF Outlet	4	Impingers 5-6 Catch and Rinse, 650 mL Amber Glass	X		
Relinquished By: (signature) S. Brown		Date / Time 4/1/2013 11:03	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by: S. Brown
Received By: (signature) <i>S. Brown</i>		Date / Time 4/2/13 1042	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Signature <i>S. Brown</i> Date 4/1/2013



20241

CLIENT <u>Wheelabrator</u>		PROJECT <u>122185B</u>		68-122185B-15	
PLANT <u>South Broward</u>		DEPT. <u>86</u>			
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palatka, FL 32909 880-627-6033 (phone) 847-991-3585 (fax)			
ANALYTICAL METHOD <b>USEPA M-529</b>	CONTAINER NUMBER <b>5C</b>	SAMPLE FRACTION <b>IMPINGERS 5-6 8N HCL RINSE 250 mL AMBER GLASS</b>		NUMBER OF CONTAINERS CONTAINER SEALED? LIQUID LEVEL MARKED?	ANALYSIS REQUESTED Gray/Inertic Metals Mercury Arsenic
FORWARDING LAB Element One, Inc. 6315-D Carolina Beach Road Wilmington, NC 28412 810-753-0123 (phone) 810-797-6852 (fax)					
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ADDITIONAL INFORMATION
	3/25	Unit 1 FF Outlet	1	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/26	Unit 1 FF Outlet	2	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/26	Unit 1 FF Outlet	3	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/26	Unit 1 FF Outlet	4	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
		FF Outlet	Field Blank	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/25	Unit 2 FF Outlet	1	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/25	Unit 2 FF Outlet	2	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/25	Unit 2 FF Outlet	3	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/27	Unit 2 FF Outlet	4	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/26	Unit 3 FF Outlet	1	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/27	Unit 3 FF Outlet	2	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/27	Unit 3 FF Outlet	3	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
	3/27	Unit 3 FF Outlet	4	Impingers 5-6 8N HCl Rinse, 250 mL Amber Glass	X
Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time
S. Brown	4/1/2013 11:40				
Received By: (signature)	Date / Time	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time
<i>S. Brown</i>	4/2/13 10:42				
				This form completed by:	
				S. Brown	
				Signature	Date
				<i>S. Brown</i>	4/1/2013

2024/

CLIENT <u>Whombrator</u>		PROJECT <u>12218SB</u>		76-12218SB-16							
PLANT <u>South Broward</u>		DEPT <u>66</u>									
PROJECT MANAGER <u>S. Brown</u>		 503 West Wood Street Palatka, FL 32909 888-467-0933 (phone) 847-9911-3245 (fax)		ANALYSIS REQUESTED Gravimetric    Metals    Mercury    Archive							
ANALYTICAL METHOD <u>USEPA M-6/29</u>	CONTAINER NUMBER <u>SEE BELOW (IF APPLICABLE)</u>					SAMPLE FRACTION <u>REAGENT BLANKS</u>	FORWARDING LAB Element One, Inc. 6018-D Carolina Beach Road Wilmington, NC 28412 910-793-0128 (phone) 910-792-5853 (fax)				
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	NUMBER OF CONTAINERS	CONTAINER BEADED?	LIQUID LEVEL MARKED?	ADDITIONAL INFORMATION			
	3/28	Reagent Blank	AE	Acetone (200 mL), Container 7: 250 mL Clear Glass	1			X	X	X	Metals include: Cadmium (Cd) Lead (Pb)
	3/28	Reagent Blank	AE	0.1N HNO <sub>3</sub> (300 mL), Container 8A: 1000 mL HDPE	1				X	X	
	3/28	Reagent Blank	AE	DI Water (100 mL), Container 8B: 250 mL HDPE	1				X	X	
	3/28	Reagent Blank	AE	5% HNO <sub>3</sub> / 10% H <sub>2</sub> O <sub>2</sub> (200 mL), Container 9: 250 mL HDPE	1				X	X	
	3/28	Reagent Blank	AE	4% KMnO <sub>4</sub> / 10% H <sub>2</sub> SO <sub>4</sub> (100 mL), Container 10: 250 mL Amber Glass	1					X	
	3/28	Reagent Blank	AE	DI Water (200 mL) / 4N HCl (25 mL), Container 11: 250 mL Amber Glass	1					X	
	3/28	Reagent Blank	AE	Quartz Filters (3), Container 12: 250 mL HDPE	1				X	X	
Relinquished By: (signature) S. Brown		Date / Time 4/1/2013 11:00	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by: S. Brown		Signature	Date 4/1/2013	
Received By: (signature) <i>Leon Burton</i>		Date / Time 4/2/13 1042	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time			Signature	Date	

# ANALYTICAL DATA

**elementOne**

20241 CAE M29-5 Report Packet  
Page 23 of 46

## Analytical Calculations

### Metals-

$$\text{Element Results } (\mu\text{g}) = \text{ICP Results } (\mu\text{g/L}) * \text{Dilution} * \text{Final Volume (L)}$$

### Where-

ICP Results= Raw sample concentration (ppb)--*ICP-Data Sheet*

Dilution=  $\frac{\text{Diluted Volume}}{\text{Aliquot}}$ --*ICP-MS Run Sheet*

Final Volume= FH=Final Volume (FV)--*Sample Submission*  
BH= $\frac{\text{Received Volume (BV)} * \text{Final Volume (FV)}}{\text{Aliquot (Used)}}$ --*Sample Submission*  
Combined Results= FH+BH

### Mercury-

$$\text{Mercury Results } (\mu\text{g}) = \frac{\text{CVAA Results } (\mu\text{g}) * \text{Final Volume (ml)}}{\text{Aliquot (ml)}}$$

### Where-

CVAA Results= Raw sample reading ( $\mu\text{g}$ )--*Hg-Data Sheet*

Aliquot= Sample Aliquot (Alq.)--*Hg-Data Sheet*

Final Volume=Final Volume (FV)\*--*Sample Submission*  
\* With the exception of the BH fraction where-  
=Received Volume (BV)--*Sample Submission*

### elementOne

## Analytical Calculations

### Spike Recovery-

$$\text{Spike (\%)} = \frac{(\text{Spiked Result } (\mu\text{g/L}) - \text{Sample Result } (\mu\text{g/L}))}{\text{Spike Amount } (\mu\text{g/L})} \times 100$$

### Where-

Spike Result = Raw sample concentration (ppb)--*ICP-Data Sheet*

Sample Result = Raw sample concentration (ppb)--*ICP-Data Sheet*

Spike Amount--*ICP-MS Spike Table*

### Duplicate Analysis RPD-

$$\text{RPD (\%)} = \frac{(\text{Duplicate Result } (\mu\text{g/L}) - \text{Sample Result } (\mu\text{g/L}))}{\text{Average } (\mu\text{g/L})} \times 100$$

### Where-

Sample Result =Raw sample concentration (ppb)--*ICP-Data Sheet*

Duplicate Results=Raw sample concentration (ppb)--*ICP-Data Sheet*

$$\text{Average} = \frac{(\text{Duplicate} + \text{Sample Results})}{2}$$

**FH / BH Combined**

Analysis Due Date 04.10.13  
QA/QC/Report Due Date 04.12.13

Client Clean Air IL  
Project No 12218/SB

Date Rec 04.02.13  
Time Rec 1042

HNO<sub>3</sub> Lot: 1112110 HF Lot: 5112070 HCl Lot: 51412070  
Volume Marked (Y/N) Volume Loss Y (N)? Ref. Method: 29 / 5

**Sample Identification**

1	U1 FF Outlet R1	5	U2 FF Outlet R1	9	U3 FF Outlet R1
2	U1 FF Outlet R2	6	U2 FF Outlet R2	10	U3 FF Outlet R2
	U1 FF Outlet R2 Duplicate		U2 FF Outlet R2 Duplicate		U3 FF Outlet R2 Duplicate
3	U1 FF Outlet R3	7	U2 FF Outlet R3	11	U3 FF Outlet R3
	U1 FF Outlet R3 Spike		U2 FF Outlet R3 Spike		U3 FF Outlet R3 Spike
4	U1 FF Outlet R4	8	U2 FF Outlet R4	12	U3 FF Outlet R4
				13	Field Blank
				14	Reagent Blank

**Analyses Requested**

Samples 1-14 Hg  
Samples 1-3, 5-7, 9-11, 13-14 Cd, Pb  
Samples 1-3, 5-7, 9-11, 14 PM

Runs / FB	Fil / Acc (FH)		HNO <sub>3</sub> (FH)		5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub> (BH)		HNO <sub>3</sub> (A)		KMnO <sub>4</sub> (B)		HCl (C)		
	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	pH <2.0	Y/N	
1	45-40	150	125	180	780	390	50	108	200	430	500	220	400
2.D	54-38	78	115		690	345		122		470	600	230	
3.S	54-37	94	135		690	345	↓	106		410	500	200	
4			120		720	360		106		430		210	
5	45-11	74	90		720	360	50	112		370		220	
6.D	45-10	52	110		690	345		110		430		230	
7.S	54-39	82	100		680	340	↓	108		436		230	
8			255		670	335		106		430		210	
9	54-36	130	170		690	320	50	106		370	↓	240	
10.D	54-34	42	120		630	315		110		385	315	600	210
11.S	54-33	146	145		575	277	↓	104		480	500	220	
12			135		670	335		102		420		215	
13			75	↓	300	150	50	104	↓	390	↓	220	↓

**M-29 Reagent Blank**

Lab ID	Fraction	BV, ml	FV, ml	Comments
14	C7 FH Acetone	144		
	C8A FH 0.1N HNO <sub>3</sub>	310	100	Used 100 ml
	C8A A 0.1N HNO <sub>3</sub>	310		
	C8B B DI H <sub>2</sub> O	100	100/33	Used 33 ml
	C9 BH 5% HNO <sub>3</sub> /10% H <sub>2</sub> O <sub>2</sub>	200	50	Used 100 ml
	C10 B 4% KMnO <sub>4</sub> /10% H <sub>2</sub> SO <sub>4</sub>	100	100/33	Used 100 ml
	C11 C 8N HCl DI H <sub>2</sub> O	220		
	C12 FH Filter			

Lab Communications (Continued on Sample Submission Page 2) CRB + Spiked w/ 100 mL Std. A @ 25 ppm  
M29: Received C1, C2, C3, C4; C8A, C8B, C8C; RB C12, C7, C8A, C8B, C9, C10, C11—04.02.13 LLB (FH + BH)

SS Page 1 of 2  
4/3/2013 1:48:01 PM  
SS by YAB  
Labeled By/Date ALC 4.2.13

FH Prep By/Date JWL 4.10.13 A Prep By/Date JWL 4.5.13  
BH Prep By/Date JWL 4.5.13 B Prep By/Date JWL 4.5.13  
BH/FH Prep By/Date JWL 4.10.13 C Prep By/Date JWL 4.9.13  
PM Prep By/Date ALC 4.4.13 ID Verification By/Date JWL HUS 4.4.13

elementOne

Method 5 Particulate

Lab # 20241

Client Clean Air

Page 1 of 2

Balance checks Date: 04.08.13 2 g = 2.0000  
 Date: 04.08.13 2 g = 1.9999  
 Date:

Acetone Concentration  
 1.53E-05 mg/mg

Filters											
Sample ID #	Filter ID	Tin ID	A		B		B		B		Catch Description and Loading
			Filter Tare, g	Date - 04.08.13 Inlets - LAL		Date - 04.09.13 Inlets - LAL		Date Inlets			
				Time	Fiber Weight, g	Time	Fiber Weight, g	Time	Fiber Weight, g		
20241-1	e45-40	T-64	0.3581	10:15	0.3603	11:00	0.3607				
20241-2	e54-38	T-42	0.3568	10:15	0.3587	11:00	0.3589				
20241-3	e54-37	T-87	0.3513	10:15	0.3532	11:00	0.3532				
20241-5	e45-11	T-86	0.3439	10:15	0.3487	11:00	0.3487				
20241-6	e45-10	T-85	0.3361	10:15	0.3405	11:00	0.3405				
20241-7	e54-39	T-82	0.3513	10:15	0.3566	11:00	0.3569				
Client Blk											
E1 Blank											

Acetone Rinses											
Sample ID #	Sample Volume, ml	Bag ID	C		D		D		D		Catch Description and Loading
			Bag Tare, g	Date - 04.08.13 Inlets - LAL		Date - 04.09.13 Inlets - LAL		Date Inlets			
				Time	Bag & Sample Weight, g	Time	Bag & Sample Weight, g	Time	Bag & Sample Weight, g		
20241-1	150	838	10.1349	10:15	10.1395	11:00	10.1395				
20241-2	78	875	10.3043	10:15	10.3070	11:00	10.3069				
20241-3	94	X58	10.4188	10:15	10.4188	11:00	10.4187				
20241-5	74	896	10.3258	10:15	10.3328	11:00	10.3331				
20241-6	52	X68	10.3162	10:15	10.3210	11:00	10.3210				
20241-7	82	554	10.2519	10:15	10.2581	11:00	10.2559				
Client Ace Blk											
E1 Acetone Blank											
	144	X86	10.2008	10:15	10.2012	11:00	10.2012				
	100	885	10.5758	10:15	10.5760	11:00	10.5769				

Total Catches									
Sample ID #	Filter ID	Filter Tare, g	Final Filter + Catch, g	Filter Catch, mg	Acetone Bag ID	Bag Tare, g	Final Bag - Ace Catch, g	Acetone Catch, mg	Total Catch, mg
20241-1	e45-40	0.3581	0.3603	2.2	838	10.1349	10.1395	4.6	6.8
20241-2	e54-38	0.3568	0.3587	1.9	875	10.3043	10.3069	2.8	4.5
20241-3	e54-37	0.3513	0.3532	1.9	X58	10.4188	10.4187	1.9	3.0
20241-5	e45-11	0.3439	0.3487	4.8	896	10.3258	10.3328	7.0	11.8
20241-6	e45-10	0.3361	0.3405	4.4	X58	10.3162	10.3210	4.8	9.2
20241-7	e54-39	0.3513	0.3566	5.3	554	10.2519	10.2559	4.0	9.3
Client Blk									
E1 Blank									
					885	10.2008	10.2012	0.4	0.4
					885	10.5758	10.5759	0.1	0.1

Element One, Inc. Form 123 - Revision 2.01.24.12

*Smiley*

elementOne

elementOne

Method 5 Particulate

Lab # 20241

Client

Page 2 of 2

Balance checks Date: 04.08.13 2 g = 2.0000  
 Date: 04.08.13 2 g = 1.9999  
 Date:

Acetone Concentration  
 1.53E-05 mg/mg

Filters										
Sample ID #	Filter ID	Tin ID	A	B		B		B		Catch Description and Loading
			Filter Tare, g	Date - 04.08.13 Inits - LAL		Date - 04.08.13 Inits - LAL		Date Inits		
				Time	Filter Weight, g	Time	Filter Weight, g	Time	Filter Weight, g	
20241-9	e54-36	T-81	0.3515	10:15	0.3609	11:00	0.3613			
20241-10	e54-34	T-25	0.3548	10:15	0.3656	11:00	0.3659			
20241-11	e54-33	T-04	0.3521	10:15	0.3614	11:00	0.3618			
Client Blk-14										
E1 Blank										

Acetone Rinses										
Sample ID #	Sample Volume, ml	Bag ID	C	D		D		D		Catch Description and Loading
			Bag Tare, g	Date - 04.08.13 Inits - LAL		Date - 04.08.13 Inits - LAL		Date Inits		
				Time	Bag & Sample Weight, g	Time	Bag & Sample Weight, g	Time	Bag & Sample Weight, g	
20241-9	130	661	10.5023	10:15	10.5090	11:00	10.5088			
20241-10	42	X16	10.3343	10:15	10.3434	11:00	10.3432			
20241-11	148	558	10.1793	10:15	10.1927	11:00	10.1929			
Client Ace Bk	144	X86	10.2008	10:15	10.2012	11:00	10.2012			
E1 Acetone Blank	100	685	10.5758	10:15	10.5760	11:00	10.5759			

Total Catches										
Sample ID #	Filter ID	Filter Tare, g	Final Filter + Catch, g	Filter Catch, mg	Acetone Bag ID	Bag Tare, g	Final Bag + Ace Catch, g	Acetone Catch, mg	Total Catch, mg	
20241-9	e54-36	0.3515	0.3609	9.4	661	10.5023	10.5088	6.5	15.9	
20241-10	e54-34	0.3548	0.3656	10.8	X16	10.3343	10.3432	8.9	19.7	
20241-11	e54-33	0.3521	0.3614	9.3	558	10.1793	10.1927	13.4	22.7	
Client Blk-14					X86	10.2008	10.2012	0.4	0.4	
E1 Blank					685	10.5758	10.5759	0.1	0.1	

Element One, Inc. Form 123 - Revision 2.01.24.12



elementOne

Method 29 Microwave Worksheet

Lab ID # e 20241

Client: Clean Air

Date Digested: 4.10.13 Initials: JWC Worksheet Prepared by: JWC

Auto Sample Loc.	Sample Lab ID	Sample Weight (g)	# of filters digested	Spike	Prep Volume (ml)	Weight In Micro / Weight Out Micro	Units
	20241						
1	-LRB						
2	-LRB+			100 ul Std. A			
3	-1		1				
4	-2						
5	-3						
6	-4						
7	-5						
8	-6						
9	-7						
10	-8						
11	-9						
12	-10						
13	-11						
14	-12						
15	-13						
16	-14						
<p>LRB+ spiked w/ 100 ul of Std. A @ 25 ppm          - Filter #4: Some spilled during transfer to hot plate          - 14 contained 3 filters, digested middle filter - AOS</p>							

Element One, Inc. Form 104 - Revision 1.0

HF lot #: 5112070

HNO<sub>3</sub> Lot #: 1112110

2ml

1ml

elementOne

20241 CAE M29-5 Report Packet

Page 29 of 46

## Sample/Batch Report

*Daphne*  
4115113

User Name: icp  
 Computer Name: ICP-MS  
 Sample File: C:\elandata\_icp\Sample\10.sam  
 Report Date/Time: Monday, April 15, 2013 09:29:52

AVS Loc.	Batch ID	Sample ID	Description	Sample Type	Init. Quant.	Prep. Vol.	Aliquot Vol.	Diluted Vol.	Solids Ratio
	5	QC Std 2		Sample					
303		20241-1		Sample					
304		20241-2		Sample					
305	d	20241-2		Duplicate of 3					
308		20241-3		Sample					
307	s	20241-3		Spike - 1 of 5					
308		20241-5		Sample					
309		20241-6		Sample					
310	d	20241-6		Duplicate of 8					
311		20241-7		Sample					
312	s	20241-7		Spike - 1 of 10					
313		20241-8		Sample					
314		20241-10		Sample					
315	d	20241-10		Duplicate of 13					
316		20241-11		Sample					
317	s	20241-11		Spike - 1 of 15					
318		20241-13		Sample					
319		20241-14		Sample					
1		QC Std 1		Sample					
3		QC Std 4		Sample					
5		QC Std 2		Sample					
403		20244-4		Sample					
404		20244-5		Sample					
405	d	20244-5		Duplicate of 23					
406		20244-8		Sample					
407	s	20244-6		Spike - 1 of 25					
408		20244-10		Sample					
409		20244-11		Sample					
410	d	20244-11		Duplicate of 28					
411		20244-12		Sample					
412	s	20244-12		Spike - 1 of 30					
413		20244-16		Sample					
414		20244-17		Sample					
415	d	20244-17		Duplicate of 33					
416		20244-18		Sample					
417	s	20244-18		Spike - 1 of 35					
418		20244-19		Sample					
419		20244-20		Sample					
420		20244-5		Sample					
421	d	20244-5		Duplicate of 38					
320	x5	20241-7		Sample					
321	x5s	20241-7		Spike - 1 of 41					
322		20241-13		Sample					
323		20241-14		Sample					

## Dataset Report

User Name: icp  
 Computer Name: ICP-MS  
 Dataset File Path: C:\elandata\_icp\DataSet\041213-4\  
 Report Date/Time: Monday, April 15, 2013 09:29:42

*Steph L*  
 4/15/13

Autosampler Position: 4

### The Dataset

Time	Sample ID	Batch ID	Read Type	Description	Init. Quant	Prep. Vol.	Aliquot. Vol.	Diluted Vol.
15:03:37 Fri 12-Apr-13	Blank		Blank					
15:05:08 Fri 12-Apr-13	Standard 1		Standard #1					
15:06:35 Fri 12-Apr-13	Standard 2		Standard #2					
15:08:04 Fri 12-Apr-13	Standard 3		Standard #3					
15:09:33 Fri 12-Apr-13	QC Std 1		QC Std #1					
15:11:03 Fri 12-Apr-13	QC Std 2		QC Std #2					
15:12:31 Fri 12-Apr-13	QC Std 3		QC Std #3					
15:14:02 Fri 12-Apr-13	QC Std 4		QC Std #4					
15:15:32 Fri 12-Apr-13	QC Std 5		QC Std #5					
15:17:01 Fri 12-Apr-13	QC Std 6		QC Std #6					
15:18:30 Fri 12-Apr-13	QC Std 7		QC Std #7					
15:19:59 Fri 12-Apr-13	QC Std 8		QC Std #8					
15:21:28 Fri 12-Apr-13	QC Std 10		QC Std #10					
15:22:58 Fri 12-Apr-13	QC Std 2		Sample					
15:24:28 Fri 12-Apr-13	20241-1		Sample					
15:25:57 Fri 12-Apr-13	20241-2		Sample					
15:27:25 Fri 12-Apr-13	20241-2	d	Duplicate of 16					
15:28:55 Fri 12-Apr-13	20241-3		Sample					
15:30:24 Fri 12-Apr-13	20241-3	s	Spike - 1 of 18					
15:31:53 Fri 12-Apr-13	20241-5		Sample					
15:33:22 Fri 12-Apr-13	20241-6		Sample					
15:34:51 Fri 12-Apr-13	20241-6	d	Duplicate of 21					
15:36:20 Fri 12-Apr-13	20241-7		Sample					
15:37:49 Fri 12-Apr-13	20241-7	s	Spike - 1 of 23					
15:39:19 Fri 12-Apr-13	QC Std 1		QC Std #1					
15:40:48 Fri 12-Apr-13	QC Std 4		QC Std #4					
15:42:18 Fri 12-Apr-13	20241-9		Sample					
15:43:47 Fri 12-Apr-13	20241-10		Sample					
15:45:16 Fri 12-Apr-13	20241-10	d	Duplicate of 28					
15:46:45 Fri 12-Apr-13	20241-11		Sample					
15:48:14 Fri 12-Apr-13	20241-11	s	Spike - 1 of 30					
15:49:43 Fri 12-Apr-13	20241-13		Sample					
15:51:12 Fri 12-Apr-13	20241-14		Sample					
15:52:43 Fri 12-Apr-13	QC Std 1		Sample					
15:54:12 Fri 12-Apr-13	QC Std 4		Sample - empty tube					
15:55:42 Fri 12-Apr-13	Blank		Blank					
15:57:32 Fri 12-Apr-13	Standard 1		Standard #1					
15:59:23 Fri 12-Apr-13	Standard 2		Standard #2					
16:01:14 Fri 12-Apr-13	Standard 3		Standard #3					
16:03:05 Fri 12-Apr-13	QC Std 1		QC Std #1					
16:04:56 Fri 12-Apr-13	QC Std 2		QC Std #2					
16:06:46 Fri 12-Apr-13	QC Std 3		QC Std #3					
16:08:38 Fri 12-Apr-13	QC Std 4		QC Std #4					

16:10:30 Fri 12-Apr-13	QC Std 5		QC Std #5
16:12:21 Fri 12-Apr-13	QC Std 6		QC Std #6
16:14:11 Fri 12-Apr-13	QC Std 7		QC Std #7
16:16:02 Fri 12-Apr-13	QC Std 8		QC Std #8
16:17:54 Fri 12-Apr-13	QC Std 9		QC Std #9
16:19:45 Fri 12-Apr-13	QC Std 10		QC Std #10
16:21:36 Fri 12-Apr-13	QC Std 2		Sample
16:23:30 Fri 12-Apr-13	QC Std 1		QC Std #1
16:25:21 Fri 12-Apr-13	QC Std 4		QC Std #4
16:27:14 Fri 12-Apr-13	20244-4		Sample
16:29:04 Fri 12-Apr-13	20244-5		Sample
16:30:55 Fri 12-Apr-13	20244-5	d	Duplicate of 54
16:32:46 Fri 12-Apr-13	20244-6		Sample
16:34:36 Fri 12-Apr-13	20244-6	s	Spike - 1 of 56
16:36:27 Fri 12-Apr-13	20244-10		Sample
16:38:18 Fri 12-Apr-13	20244-11		Sample
16:40:08 Fri 12-Apr-13	20244-11	d	Duplicate of 59
16:41:59 Fri 12-Apr-13	20244-12		Sample
16:43:50 Fri 12-Apr-13	20244-12	s	Spike - 1 of 61
16:45:43 Fri 12-Apr-13	QC Std 1		QC Std #1
16:47:33 Fri 12-Apr-13	QC Std 4		QC Std #4
16:49:23 Fri 12-Apr-13	20244-16		Sample
16:51:17 Fri 12-Apr-13	20244-17		Sample
16:53:08 Fri 12-Apr-13	20244-17	d	Duplicate of 66
16:54:58 Fri 12-Apr-13	20244-18		Sample
16:56:49 Fri 12-Apr-13	20244-18	s	Spike - 1 of 68
16:58:40 Fri 12-Apr-13	20244-19		Sample
17:00:30 Fri 12-Apr-13	20244-20		Sample
17:02:24 Fri 12-Apr-13	QC Std 1		QC Std #1
17:04:15 Fri 12-Apr-13	QC Std 4		QC Std #4
09:02:25 Mon 15-Apr-13	20244-5		Sample
09:04:16 Mon 15-Apr-13	20244-5	d	Duplicate of 74
09:06:09 Mon 15-Apr-13	QC Std 1		QC Std #1
09:08:00 Mon 15-Apr-13	QC Std 4		QC Std #4
09:14:52 Mon 15-Apr-13	20241-7	x5	Sample
09:16:21 Mon 15-Apr-13	20241-7	x5a	Spike - 1 of 78
09:17:50 Mon 15-Apr-13	20241-13		Sample
09:19:19 Mon 15-Apr-13	20241-14		Sample
09:20:51 Mon 15-Apr-13	QC Std 1		QC Std #1
09:22:20 Mon 15-Apr-13	QC Std 4		QC Std #4





ICP-MS QC Values Table

Element or Test	ICP Element Mass	Element symbol	Lowest Reported Value (ug)	Upper Reported Value (ug)	Reporting Unit	QC #1	QC #2	QC #3	QC #4	QC #5	QC #6 A	QC #7 AB	QC #8 .25	QC #9 LRB	QC #10 LRB+	QC #11 LRB+
Lithium	Lithium	Li	1	500	mg/L	0	1	250	100	50				0	50	100
Beryllium		Be	1	500	mg/L	0	1	250	100	50			0.25	0	50	100
Boron	Boron	B	5	500	mg/L	0	1	250	100	50				0	50	100
Sodium		Na	20	5600	mg/L	0	21	2500	1100	250				0	50	100
Magnesium	Magnesium	Mg	20	5600	mg/L	0	21	2500	1100	250				0	50	100
Aluminum		Al	1	500	mg/L	0	1	250	100	50				0	50	100
Phosphorus		P	20	5000	mg/L	0	20	2500	1000	250				0	200	
Potassium		K	20	5600	mg/L	0	20	2000	1000	200				0	500	
Calcium		Ca	50	5600	mg/L	0	21	2500	1100	250				0	500	
Titanium		Ti	1	500	mg/L	0	1	250	100	50			0.25	0	50	100
Vanadium		V	1	500	mg/L	0	1	250	100	50	0	20	0.25	0	50	100
Chromium	Chromium	Cr	1	500	mg/L	0	1	250	100	50		10	0.25	0	50	100
Iron		Fe	20	5600	mg/L	0	21	2500	1100	250	0	0		0		
Manganese		Mn	1	500	mg/L	0	1	250	100	50	0	10	0.25	0	50	100
Cobalt		Co	1	500	mg/L	0	1	250	100	50	0	20	0.25	0	50	100
Nickel		Ni	1	500	mg/L	0	1	250	100	50	0	20	0.25	0	50	100
Copper		Cu	1	500	mg/L	0	1	250	100	50	0	10	0.25	0	50	100
Zinc	Zinc	Zn	1	500	mg/L	0	1	250	100	50	0	10	0.25	0	50	100
Germanium		Ge	1	500	mg/L	0	1	250	100	50	0	10	0.25	0	50	100
Arsenic		As	1	500	mg/L	0	1	250	100	50	0	10	0.25	0	50	100
Selenium	Selenium	Se	1	500	mg/L	0	1	250	100	50	0	10	0.25	0	50	100
Strontium		Sr	1	500	mg/L	0	1	250	100	50	0			0	50	100
Molybdenum		Mo	1	500	mg/L	0	1	250	100	50			0.25	0	50	100
Rhodium		Rh	1	500	mg/L	0	1	250	100	50			0.25	0	50	100
Silver	Silver	Ag	1	500	mg/L	0	1	250	100	50	0	10		0	50	100
Cadmium	Cadmium	Cd	1	500	mg/L	0	1	250	100	50	0	5	0.25	0	50	100
Tin		Sn	1	500	mg/L	0	1	250	100	50	0			0	50	100
Antimony		Sb	1	500	mg/L	0	1	250	100	50	0		0.25	0	50	100
Tellurium		Te	1	500	mg/L	0	1	250	100	50	0		0.25	0	50	100
Cesium		Cs	1	500	mg/L	0	1	250	100	50	0			0	50	100
Barium		Ba	1	500	mg/L	0	1	250	100	50	0			0	50	100
Lanthanum		La	1	500	mg/L	0	1	250	100	50	0			0	50	100
Tantalum		Ta	1	500	mg/L	0	1	250	100	50	0			0	50	100
Platinum		Pt	1	500	mg/L	0	1	250	100	50	0			0	50	100
Gold		Au	1	500	mg/L	0	1	250	100	50	0			0	50	100
Thallium		Tl	1	500	mg/L	0	1	250	100	50	0			0	50	100
Lead		Pb	1	500	mg/L	0	1	250	100	50	0		0.25	0	50	100
Bismuth		Bi	1	500	mg/L	0	1	250	100	50	0			0	50	100
Thorium		Th	1	500	mg/L	0	1	250	100	50	0			0	50	100
Uranium		U	1	500	mg/L	0	1	250	100	50	0			0	50	100
Krypton		Kr	1	500	mg/L	0	1	250	100	50	0			0	50	100

elementOne

elementOne **MERCURY BATCH DIGESTION - RUN WORKSHEET**

Block 3 92.67  
 Date Prepared/Digested: 4-8-13 Prep By: LAL/MLL SIF File #: 040713-1  
 Block #1 Temperature: 93.20 Start Time: 8:30 Machine ID: # 3  
 Block #2 Temperature: 94.22 Stop Time: 10:45 Batch Analyst: JAL/LAL

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: <del>040813-1</del>
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: 040813-1 by: LAL
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml	40	40	Lot #: 040813-2
6	0.20ug	0.50ml	40	40	Standard #3 (QC #3): Lot #: 040813-3
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by: LAL

Submitted for Review By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Initial Review By: LAL Date: 4.8.13 Time: 3:52  
 Final QC Review By: JCS Date: 4/10/13 Time: 1332

Comments: 20244-9BHT @ 2ml & 1ml

A/S	LAB #	Client	WV/FV	Ali Used	ml used	Sample Vol, ml	Spike ug
9	20212-1C				4	400	
10	-2C						
11	-3C						
12	-4C						
13	-5C						
14	-6C						
15	-6CD						
16	-7C						
17	-7C+						
18	-8C						
19	-9C						

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
**Spike for Hg,** Use calibration working 0.4ug/ml standard at the rate of 0.20ml per 40ml sample.  
**Digestion chemicals to be added in order at the following rate per 40ml volumes.**  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 8.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 52151 HNO<sub>3</sub> Lot # 1112110 HCl Lot #: 4112070  
 Persulfate Lot # 032513-8 KMnO<sub>4</sub> Lot # 012813-6 Hydrox Lot#: 032513-6  
 Clear samples after digestion with 3.2ml of Hydroxylamine solution.

59-102



elementOne

MERCURY BATCH DIGESTION - RUN WORKSHEET

SIF File #: 040813-1

A/S	LAB #	Client	W/V/V	Ali Used	ml used	Sample Vol, ml	Spike µg
20	20242 - 9CD				4	400	
21	-10C				↓	↓	
22	-10C+				↓	↓	
23	-11C				↓	↓	
24	-12C				↓	↓	
25	-12CD				↓	↓	
26	-13C				↓	↓	
27	-13C+				↓	↓	
28	-14C				↓	↓	
29	20241 - 1A				4	200	
30	-2A				↓	↓	
31	-2AD				↓	↓	
32	-3A				↓	↓	
33	-3A+				↓	↓	
34	-4A				↓	↓	
35	-5A				↓	↓	
36	-6A				↓	↓	
37	-6AD				↓	↓	
38	-7A				↓	↓	
39	-7A+				↓	↓	
40	-8A				↓	↓	
41	-9A				↓	↓	
42	-10A				↓	↓	
43	-10AD				↓	↓	
44	-11A				↓	↓	
45	-11A+				↓	↓	
46	-12A				↓	↓	
47	-13A				↓	↓	
48	-14A				↓	↓	
49	20241 - 18H				4	730	
50	-28H				↓	740	
51	-28HD				↓	↓	
52	-38H				↓	690	
53	-38H+				↓	↓	
54	-48H				↓	720	

elementOne

MERCURY BATCH DIGESTION - RUN WORKSHEET

SIF File #: 040813-1

A/S	LAB #	Client	WV/V	Ali Used	ml used	Sample Vol, ml	Spike µg
55	20241-5 BH				4	720	
56	-6 BH					690	
57	-6 BHD					↓	
58	-7 BH					480	
59	-7 BH +					↓	
60	-8 BH					670	
61	-9 BH					640	
62	-10 BH					630	
63	-10 BHD					↓	
64	-11 BH					575	
65	-11 BH +					↓	
66	-12 BH					670	
67	-13 BH					300	
68	-14 BH				↓	200	
69	20244-1 BH				2	620	
70	-2 BH					620	
71	-2 BHD					↓	
72	-3 BH					590	
73	-3 BH +				↓	↓	
74	-4 BH				4	750	
75	-5 BH					790	
76	-5 BHD					↓	
77	-6 BH					720	
78	-6 BH +				↓	↓	
79	-7 BH				2	600	
80	-8 BH					650	
81	-8 BHD					↓	
82	-9 BH					640	
83	-9 BH +				↓	↓	
84	-10 BH				4	700	
85	-11 BH					760	
86	-11 BHD					↓	
87	-12 BH					700	
88	-12 BH +				↓	↓	
89	-13 BH				2	570	

elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

Date Prepared/Digested: 4-8-13 Prep By: LAL SIF File #: 040913-1  
 Block #1 Temperature: 93.92 Start Time: 5:55 Machine ID: #1  
 Block #2 Temperature: 94.82 Stop Time: 8:10 Batch Analyst: JWL/LAL

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: 4205419
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: 040813-1 by: LAL
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2): Lot #: 040813-2
5	0.16 ug	0.40ml	40	40	Standard #3 (QC #3): Lot #: 040813-3
6	0.20ug	0.50ml	40	40	
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by:

Submitted for Review By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Initial Review By: LAL Date: 4-9-13 Time: 11:20  
 Final QC Review By: US Date: 4/10/13 Time: 1345

Comments: \_\_\_\_\_

A/S	LAB #	Client	Wt/FV	All Used	ml used	Sample Vol, ml	Spike ug
9	20241-16				4	500	
10	- 2 B					600	
11	- 2 B D					↓	
12	- 3 B					500	
13	- 3 B f						
14	- 4 B						
15	- 5 B						
16	- 6 B						
17	- 6 B D						
18	- 7 B						
19	- 7 B f						

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
**Spike for Hg.** Use calibration working 0.4ug/ml standard at the rate of 0.20ml per 40ml sample.  
**Digestion chemicals to be added in order at the following rate per 40ml volumes.**  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 52151 HNO<sub>3</sub> Lot # 1112110 HCl Lot #: 4/12070  
 Persulfate Lot # 032513-8 KMnO<sub>4</sub> Lot # 012713-6 Hydrox Lot #: 032513-6  
 Clear samples after digestion with 3.2ml of Hydroxylamine solution.

elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

SIF File #: 040913-1

A/S	LAB #	Client	W/FV	Ali Used	ml used	Sample Vol, ml	Spike µg
20	20241-8B				4	500	
21	-9B					↓	
22	-10B					600	
23	-10BD					↓	
24	-11B					500	
25	-11B+					↓	
26	-12B					↓	
27	-13B					↓	
28	-14B					↓	
29	20244-1B					500	
30	-2B					↓	
31	-2BD					↓	
32	-3B					↓	
33	-3B+					↓	
34	-4B					↓	
35	-5B					↓	
36	-5BD					↓	
37	-6B					↓	
38	-6B+					↓	
39	-7B					↓	
40	-8B					↓	
41	-8BD					↓	
42	-9B					↓	
43	-9B+					↓	
44	-10B					600	
45	-11B					500	
46	-11BD					↓	
47	-12B					↓	
48	-12B+					↓	
49	-13B					↓	
50	-14B					↓	
51	-14BD					↓	
52	-15B					↓	
53	-15B+					↓	
54	-16B					↓	

elementOne MERCURY BATCH DIGESTION - RUN WORKSHEET

Date Prepared/Digested: 4-10-13 Prep By: JWL SIF File #: 041113-1  
 Block #1 Temperature: 92.59 Start Time: 5:55 Machine ID: #1  
 Block #2 Temperature: Stop Time: 8:10 Batch Analyst: JWL/LAL

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: 4205419
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: 040113-1 by: LAL
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml	40	40	Lot #: 040113-2
6	0.20ug	0.50ml	40	40	Standard #3 (QC #3): Lot #: 040113-3
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by: JWL

Submitted for Review By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Initial Review By: JWL Date: 4-11-13 Time: 2:00  
 Final QC Review By: DBL Date: 4/12/13 Time: 12:32  
 Comments: 20285-2C should be # not Dup  
20277-3+

A/S	LAB #	Client	W/FV	Ali Used	ml used	Sample Vol, ml	Spike ug
9	20285-3B				.5	1000	
10	-3BD				↓	↓	
11	-4B				↓	↓	
12	-4B+				↓	↓	
13	20244-14FA				.025	100	
14	-14FHD				↓	↓	
15	20277/7911/1BLK				20	1	
16	-BLK+				↓	↓	
17	20277-1				↓	↓	
18	-2				↓	↓	
19	-2D				↓	↓	

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
**Spike for Hg,** Use calibration working 0.4ug/ml standard at the rate of 0.20ml per 40ml sample.  
**Digestion chemicals to be added in order at the following rate per 40ml volumes.**  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 52151 HNO<sub>3</sub> Lot # 111211b HCl Lot # 4112030  
 Persulfate Lot # 040813-2 KMnO<sub>4</sub> Lot # 012913-6 Hydrox Lot# 032513-6  
 Clear samples after digestion with 3.2ml of Hydroxylamine solution.

elementOne

MERCURY BATCH DIGESTION - RUN WORKSHEET

SIF File #: 04113-1

A/S	LAB #	Client	W/V/V	Ali Used	ml used	Sample Vol, ml	Spike ug
20	20277-3				20	1	
21	-3+						
22	-4						
23	20279						
24	20280						
25	-Dup						
26	20281						
27	-SpK				✓	✓	
28	20241-1C				4	400	
29	-2C						
30	-2CD						
31	-3C						
32	-3C+						
33	-4C						
34	-5C						
35	-6C						
36	-6CD						
37	-7C						
38	-7C+						
39	-8C						
40	-9C						
41	-10C						
42	-10CD						
43	-11C						
44	-11C+						
45	-12C						
46	-13C						
47	-14C						
48	20244-1C						
49	-2C						
50	-2CD						
51	-3C						
52	-3C+						
53	-4C						
54	-5C				✓	✓	

elementOne **MERCURY BATCH DIGESTION - RUN WORKSHEET**

Date Prepared/Digested: 4.10.13 Prep By: JWL SIF File #: 091213-1  
 Block #1 Temperature: 91.76 Start Time: 5:55 Machine ID: #3  
 Block #2 Temperature: 91.38 Stop Time: 8:10 Batch Analyst: JWL/LAL

A/S	Curve & QC's	0.4ug/ml working std	BV, ml	FV, ml	Standard Lot Numbers
1	Lab BLK (3/ batch)	0	40	40	Standard #1 (for working std) Lot #: 4205419
2	0.004 ug	0.01ml	40	40	Working Standard
3	0.04 ug	0.10ml	40	40	Lot #: 040813-1 by: LAL
4	0.08 ug	0.20ml	40	40	Standard #2 (QC #2):
5	0.16 ug	0.40ml	40	40	Lot #: 040813-2
6	0.20ug	0.50ml	40	40	Standard #3 (QC #3): Lot #: 040813-3
7	QC #2= 0.08ug	0.2ml #2 std	40	40	
8	QC #3= 0.08ug	0.2ml #3 std	40	40	Curve prepared by: JWL

Submitted for Review By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Initial Review By: JWL Date: 4-12-13 Time: 12:00  
 Final QC Review By: JWL Date: 4/15/13 Time: 8:56  
 Comments: PLS 20273 -3+, -12+ 20282 -5pk ac m @ 12K  
2020

A/S	LAB #	Client	Wt/FV	Ali Used	ml used	Sample Vol, ml	Spike ug
9	20277-3				10	1	
10	-3+				↓	↓	
11	-3				5	↓	
12	-3+				↓	↓	
13	20241-LRBFH				4	100	
14	-LRBFH+				1.6	↓	
15	-1FH				4	↓	
16	-2FH				↓	↓	
17	-2FHD				↓	↓	
18	-3FH				↓	↓	
19	-3FH+				↓	↓	

**NOTES:** Lab blanks and spikes must be prepared with each batch digestion  
**Spike for Hg,** Use calibration working 0.4ug/ml standard at the rate of 0.20ml per 40ml sample.  
**Digestion chemicals to be added in order at the following rate per 40ml volumes.**  
 H<sub>2</sub>SO<sub>4</sub> @ 2.0ml..... HNO<sub>3</sub> @ 1.0ml..... Persulfate @ 3.0ml..... KMnO<sub>4</sub> @ 6.0ml  
 H<sub>2</sub>SO<sub>4</sub> Lot # 52151 HNO<sub>3</sub> Lot # 41112110 HCl Lot #: 4112020  
 Persulfate Lot # 040813-7 KMnO<sub>4</sub> Lot # 032513-6 Hydrox Lot #: 032513-6  
 Clear samples after digestion with 3.2ml of Hydroxylamine solution.

elementOne

MERCURY BATCH DIGESTION - RUN WORKSHEET

SIF File #: \_\_\_\_\_

A/S	LAB #	Client	WUFV	Ali Used	ml used	Sample Vol. ml	Spike µg
20	20241-4FH				4	100	
21	-5FH						
22	-6FH						
23	-6FH(D)						
24	-7FH						
25	-7FH+						
26	-8FH						
27	-9FH						
28	-10FH						
29	-10FH(D)						
30	-11FH						
31	-11FH+						
32	-12FH						
33	-13FH						
34	-14FH						
35	20283-1				0.5105	1	
36	-2				0.4036		
37	-2D				0.4168		
38	-3				0.4487		
39	-3+				0.4482		
40	-4				0.4100		
41	-5				0.4117		
42	-6				0.5267		
43	-7				0.4081		
44	-8				0.4028		
45	-9				0.5272		
46	-10				0.5105		
47	-11				0.5187		
48	-11D				0.5117		
49	-12				0.5354		
50	-12+				0.5317		
51	20282				0.5304		
52	-Dup				0.5469		
53	-Spk				0.5173	✓	
54	17349-3 BC				11	10	



PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: Blank

Sample Da: Friday, April 12, 2013 15:03:37

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	64272.7		ppb
	Sc	45	346801		ppb
>	Rh	103	696269.7		ppb
	Cd	111	17.5		ppb
	Cd	114	27.9		ppb
>	Ho	165	1397078.3		ppb
	Pb	208	2649.2		ppb
	Kr	83	127.9		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 1

Sample Da: Friday, April 12, 2013 15:05:06

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	71247.7		ppb
	Sc	45	349742.4		ppb
>	Rh	103	670954.8		ppb
	Cd	111	3398.1	1.01959	ppb
	Cd	114	8020.8	0.91674	ppb
>	Ho	165	1363890.9		ppb
	Pb	208	55656.1	0.91621	ppb
	Kr	83	-89.9		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 2

Sample Da: Friday, April 12, 2013 15:06:35

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	76471.8		ppb
	Sc	45	353203.8		ppb
>	Rh	103	671967.2		ppb
	Cd	111	327645.6	98.70146	ppb
	Cd	114	776459.5	88.94925	ppb
>	Ho	165	1380306		ppb
	Pb	208	5643913.8	96.27389	ppb
	Kr	83	-23139.2		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: Standard 3

Sample Da: Friday, April 12, 2013 15:08:04

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	70350.2		ppb
	Sc	45	330949.3		ppb
>	Rh	103	601968		ppb
	Cd	111	1488259.4	500.2597	ppb
	Cd	114	3928822.5	502.2103	ppb
>	Ho	165	1281327.7		ppb
	Pb	208	27250849	500.7454	ppb
	Kr	83	-106086.4		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da: Friday, April 12, 2013 15:09:33

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	77964.5		ppb
	Sc	45	352180.5		ppb
>	Rh	103	660694.5		ppb
	Cd	111	122.2	0.03223	ppb
	Cd	114	279.6	0.02965	ppb
>	Ho	165	1346589.6		ppb
	Pb	208	8590.3	0.10658	ppb
	Kr	83	134.2		mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 2

Sample Da: Friday, April 12, 2013 15:11:03

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	66048.2			ppb
T	Sc	45	297735.9			ppb
V	Rh	103	573012.2			ppb
I	Cd	111	2949.1	1.04696		ppb
T	Cd	114	7121.9	0.96601		ppb
V	Ho	165	1181590.8			ppb
T	Pb	208	50618.7	0.972		ppb
	Kr	83	-45.8			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 3

Sample Da: Friday, April 12, 2013 15:12:31

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	67719.1			ppb
T	Sc	45	298664.3			ppb
V	Rh	103	559837.7			ppb
I	Cd	111	692940	250.3646		ppb
T	Cd	114	1642868.6	225.814		ppb
V	Ho	165	1209691.3			ppb
T	Pb	208	13010794	253.3208		ppb
	Kr	83	-48966.7			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Da: Friday, April 12, 2013 15:14:02

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	75298.2			ppb
T	Sc	45	333993.8			ppb
V	Rh	103	615222.8			ppb
I	Cd	111	302402.6	99.43371		ppb
T	Cd	114	716227.4	89.56205		ppb
V	Ho	165	1251126.7			ppb
T	Pb	208	5264589.3	99.05111		ppb
	Kr	83	-21333.8			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 5

Sample Da: Friday, April 12, 2013 15:15:32

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	74970.8			ppb
T	Sc	45	327643.6			ppb
V	Rh	103	609229.9			ppb
I	Cd	111	149089.6	49.52048		ppb
T	Cd	114	350996.5	44.33229		ppb
V	Ho	165	1247578.2			ppb
T	Pb	208	2443173.5	46.06817		ppb
	Kr	83	135			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 6

Sample Da: Friday, April 12, 2013 15:17:01

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	95039.8			ppb
T	Sc	45	405588.3			ppb
V	Rh	103	691379.8			ppb
I	Cd	111	1334.1	0.38576		ppb
T	Cd	114	9291.9	1.03037		ppb
V	Ho	165	1597491.6			ppb
T	Pb	208	10594.1	0.11157		ppb
	Kr	83	123.2			mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 7

Sample Da: Friday, April 12, 2013 15:18:30

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas	Report Unit
	Li		6	100983.8		ppb
	Sc		45	405904.1		ppb
>	Rh		103	676865.1		ppb
	Cd		111	15366.7	4.58838	ppb
	Cd		114	44461.4	5.05174	ppb
>	Ho		165	1569887.9		ppb
	Pb		208	16477.9	0.20255	ppb
	Kr		83	132.2		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 9

Sample Da: Friday, April 12, 2013 15:19:59

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas	Report Unit
	Li		6	60830.3		ppb
	Sc		45	248405		ppb
>	Rh		103	481532.1		ppb
	Cd		111	146.8	1.44825	ppb
	Cd		114	285.2	1.4075	ppb
>	Ho		165	1021420		ppb
	Pb		208	34540.3	1.99453	ppb
	Kr		83	90.6		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 10

Sample Da: Friday, April 12, 2013 15:21:28

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas	Report Unit
	Li		6	81858.9		ppb
	Sc		45	323516.6		ppb
>	Rh		103	611256.7		ppb
	Cd		111	142151.3	47.06071	ppb
	Cd		114	338122.7	42.57172	ppb
>	Ho		165	1273167.3		ppb
	Pb		208	2423539.5	44.8065	ppb
	Kr		83	53.4		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-1

Sample Da: Friday, April 12, 2013 15:24:28

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas	Report Unit
	Li		6	64493		ppb
	Sc		45	260514.8		ppb
>	Rh		103	480480		ppb
	Cd		111	2168.6	1.36449	ppb
	Cd		114	2185.7	0.82693	ppb
>	Ho		165	1051423.1		ppb
	Pb		208	182138	4.28074	ppb
	Kr		83	-403.8		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-2

Sample Da: Friday, April 12, 2013 15:25:57

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas	Report Unit
	Li		6	78403.5		ppb
	Sc		45	308620.4		ppb
>	Rh		103	570981.5		ppb
	Cd		111	1899.5	0.67663	ppb
	Cd		114	1168.6	0.15692	ppb
>	Ho		165	1195766.8		ppb
	Pb		208	144239.7	2.8105	ppb
	Kr		83	-446		mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-2

Sample Da Friday, April 12, 2013 15:27:26

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	88853.4			ppb
T	Sc	45	337180.6			ppb
Y	Rh	103	620827.5			ppb
I	Cd	111	1906.4	0.61617		ppb
T	Cd	114	1130.5	0.13327		ppb
Y	Ho	165	1307295.8			ppb
T	Pb	208	152328	2.69882		ppb
	Kr	83	-499.6			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-3

Sample Da Friday, April 12, 2013 15:28:55

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	79420.4			ppb
T	Sc	45	309090.2			ppb
Y	Rh	103	554995.6			ppb
I	Cd	111	2423.7	0.87855		ppb
T	Cd	114	2051.9	0.28154		ppb
Y	Ho	165	1208765.5			ppb
T	Pb	208	136847.7	2.62137		ppb
	Kr	83	-354.9			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-3

Sample Da Friday, April 12, 2013 15:30:24

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	76716.7			ppb
T	Sc	45	297791.3			ppb
Y	Rh	103	528364.8			ppb
I	Cd	111	124758	47.71316		ppb
T	Cd	114	293481.8	42.73734		ppb
Y	Ho	165	1153551.5			ppb
T	Pb	208	2410568	49.94804		ppb
	Kr	83	-264.9			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-5

Sample Da Friday, April 12, 2013 15:31:53

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	93666.4			ppb
T	Sc	45	347485.6			ppb
Y	Rh	103	627886.9			ppb
I	Cd	111	31476.6	10.14266		ppb
T	Cd	114	71697.6	8.77932		ppb
Y	Ho	165	1328968.9			ppb
T	Pb	208	3280734.9	58.07316		ppb
	Kr	83	-1794			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-6

Sample Da Friday, April 12, 2013 15:33:22

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear	Report Unit
	Li	6	88732.9			ppb
T	Sc	45	332375.7			ppb
Y	Rh	103	596461.3			ppb
I	Cd	111	31045.9	10.52707		ppb
T	Cd	114	69196.7	8.92352		ppb
Y	Ho	165	1265701.4			ppb
T	Pb	208	4421895	82.22443		ppb
	Kr	83	-1553.8			mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-6

Sample Da Friday, April 12, 2013 15:34:51

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
	Li	6	89743.1		ppb
	Sc	45	333751		ppb
>	Rh	103	596190.1		ppb
	Cd	111	30682.5	10.40872	ppb
	Cd	114	69400	8.95469	ppb
>	Ho	165	1267753.8		ppb
	Pb	208	4404779.8	81.77269	ppb
	Kr	83	-1493.8		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-7

Sample Da Friday, April 12, 2013 15:36:20

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
	Li	6	88624.6		ppb
	Sc	45	326200.2		ppb
>	Rh	103	592730.2		ppb
	Cd	111	25452.8	8.68345	ppb
	Cd	114	58768.7	7.62559	ppb
>	Ho	165	1249391		ppb
	Pb	208	5369311.5	101.156	ppb
	Kr	83	-1233.1		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-7

Sample Da Friday, April 12, 2013 15:37:49

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
	Li	6	78331.5		ppb
	Sc	45	285234.5		ppb
>	Rh	103	518671.3		ppb
	Cd	111	167340.6	65.29101	ppb
	Cd	114	395463.7	58.67544	ppb
>	Ho	165	1100935.1		ppb
	Pb	208	8053259.1	172.1995	ppb
	Kr	83	-1231.8		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da Friday, April 12, 2013 15:39:19

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
	Li	6	91705.9		ppb
	Sc	45	326260.9		ppb
>	Rh	103	597838.1		ppb
	Cd	111	163.4	0.05035	ppb
	Cd	114	67.5	0.00559	ppb
>	Ho	165	1212255.6		ppb
	Pb	208	4428.4	0.04144	ppb
	Kr	83	84.7		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Da Friday, April 12, 2013 15:40:48

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Mear Report Unit
	Li	6	96442.7		ppb
	Sc	45	341027.4		ppb
>	Rh	103	598541.3		ppb
	Cd	111	298946.1	101.0642	ppb
	Cd	114	699870.1	89.98238	ppb
>	Ho	165	1234965.1		ppb
	Pb	208	5224330.4	99.56473	ppb
	Kr	83	-21111.9		mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-9

Sample Date: Friday, April 12, 2013 15:42:18

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc.	Meas Report	Unit
Li	6	86877.3			ppb
Sc	45	306421.1			ppb
Rh	103	560601.9			ppb
Cd	111	72876.2	26.30852		ppb
Cd	114	170327	23.38083		ppb
Ho	165	1219720.2			ppb
Pb	208	10379355	200.3301		ppb
Kr	83	-2966.2			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-10

Sample Date: Friday, April 12, 2013 15:43:47

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc.	Meas Report	Unit
Li	6	91593.5			ppb
Sc	45	322384.6			ppb
Rh	103	568603.1			ppb
Cd	111	51767.6	18.43251		ppb
Cd	114	119834.2	16.22837		ppb
Ho	165	1263032.9			ppb
Pb	208	7379035.2	137.5317		ppb
Kr	83	-2995.4			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-10

Sample Date: Friday, April 12, 2013 15:45:16

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc.	Meas Report	Unit
Li	6	99768.1			ppb
Sc	45	336171.6			ppb
Rh	103	590839.7			ppb
Cd	111	53250.3	18.23225		ppb
Cd	114	121865.5	15.86696		ppb
Ho	165	1307423.7			ppb
Pb	208	7572166.9	136.299		ppb
Kr	83	-3094			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-11

Sample Date: Friday, April 12, 2013 15:46:45

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc.	Meas Report	Unit
Li	6	102558.6			ppb
Sc	45	337436.6			ppb
Rh	103	607279.3			ppb
Cd	111	62479.3	20.83041		ppb
Cd	114	144616	18.33676		ppb
Ho	165	1326801.3			ppb
Pb	208	9070032.1	161.0188		ppb
Kr	83	-3368.1			mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-11

Sample Date: Friday, April 12, 2013 15:48:14

Sample Description:

Concentration Results

Analyte	Mass	Meas. Intens	Conc.	Meas Report	Unit
Li	6	107623.7			ppb
Sc	45	356222.4			ppb
Rh	103	630102			ppb
Cd	111	222987.8	71.60799		ppb
Cd	114	532696.9	65.03178		ppb
Ho	165	1420163.8			ppb
Pb	208	12879933	214.1032		ppb
Kr	83	-3479.6			mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da: Monday, April 15, 2013 09:06:09

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	72851.9		ppb
	Sc	45	269089.2		ppb
>	Rh	103	480436.6		ppb
	Cd	111	16.7	0.00196	ppb
	Cd	114	20.4	0.00018	ppb
>	Ho	165	1012628.7		ppb
	Pb	208	1174	-0.01728	ppb
	Kr	83	123.4		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Da: Monday, April 15, 2013 09:08:00

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	70031.9		ppb
	Sc	45	259529.2		ppb
>	Rh	103	456731.2		ppb
	Cd	111	225276.5	99.79515	ppb
	Cd	114	536333.5	90.35295	ppb
>	Ho	165	979071.4		ppb
	Pb	208	4137205.8	99.45447	ppb
	Kr	83	-15666.4		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-7

Sample Da: Monday, April 15, 2013 09:14:52

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	80565.7		ppb
	Sc	45	277205		ppb
>	Rh	103	491080.6		ppb
	Cd	111	4588	1.88522	ppb
	Cd	114	10189	1.59348	ppb
>	Ho	165	1059103.1		ppb
	Pb	208	866283.4	19.21548	ppb
	Kr	83	-108.5		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-7

Sample Da: Monday, April 15, 2013 09:16:21

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	74661		ppb
	Sc	45	250470		ppb
>	Rh	103	432255.1		ppb
	Cd	111	127917.5	59.88817	ppb
	Cd	114	305502.7	54.39773	ppb
>	Ho	165	943382.1		ppb
	Pb	208	3052182.2	76.13566	ppb
	Kr	83	-71		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-13

Sample Da: Monday, April 15, 2013 09:17:50

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	62048.2		ppb
	Sc	45	214695		ppb
>	Rh	103	362420.3		ppb
	Cd	111	1670.4	0.92746	ppb
	Cd	114	316.6	0.06402	ppb
>	Ho	165	839299.6		ppb
	Pb	208	83740.4	2.30463	ppb
	Kr	83	-780.5		mg/L

PerkinElmer ELAN 6100 ICP-MS

Method 6020 & 200.8 Metals Summary Report

Sample ID: 20241-14

Sample Da: Monday, April 15, 2013 09:19:19

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	82626.7		ppb
T-	Sc	45	271036.4		ppb
>	Rh	103	468518		ppb
	Cd	111	1017.8	0.43447	ppb
T-	Cd	114	384.8	0.05986	ppb
>	Ho	165	1074068		ppb
T-	Pb	208	76485.3	1.63214	ppb
	Kr	83	-670.1		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 1

Sample Da: Monday, April 15, 2013 09:20:51

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	82100.4		ppb
T-	Sc	45	257780.3		ppb
>	Rh	103	447486		ppb
	Cd	111	43.5	0.01458	ppb
T-	Cd	114	21.6	0.00063	ppb
>	Ho	165	966012.2		ppb
T-	Pb	208	770	-0.02588	ppb
	Kr	83	120.4		mg/L

Method 6020 & 200.8 Metals Summary Report

Sample ID: QC Std 4

Sample Da: Monday, April 15, 2013 09:22:20

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Li	6	80542.3		ppb
T-	Sc	45	246746.8		ppb
>	Rh	103	422437.4		ppb
	Cd	111	214309.9	102.6443	ppb
T-	Cd	114	507519.7	92.43889	ppb
>	Ho	165	945994.8		ppb
T-	Pb	208	3999072.3	99.4985	ppb
	Kr	83	-13847		mg/L



PerkinElmer FIMS-100 CVAA Mercury Analyzer

Sample_ID	Date	Time	Mean_Sig	Mean_Rd	Mean_Rt	Units	Alq.	Vol.	Sig 1	Reading-1	Result-1	Sig 2	Reading-2	Result-2
Calib Blank	4/8/2013	11:07:51	0.0001209			µg			0.0001209					
STD1=.004ug	4/8/2013	11:09:06	0.0013402			µg			0.0013402					
STD2=.04ug	4/8/2013	11:10:22	0.01249			µg			0.01249					
STD3=.08ug	4/8/2013	11:11:39	0.0277711			µg			0.0277711					
STD4=.16ug	4/8/2013	11:12:57	0.0512234			µg			0.0512234					
STD5=.2ug	4/8/2013	11:14:16	0.0656804			µg			0.0656804					
Reagent Blank	4/8/2013	11:16:04	9.694E-05	0.0002965	0.0002965	µg			0.0001239	0.0003789	0.0003789	6.999E-05	0.0002141	0.0002141
0.004ug = DL	4/8/2013	11:17:18	0.0012886	0.0039409	0.0039409	µg			0.0012886	0.0039409	0.0039409			
0.080ug = STD.2	4/8/2013	11:21:15	0.0260761	0.0797467	0.0797467	µg			0.0260761	0.0797467	0.0797467			
0.080ug = QC STD 3	4/8/2013	11:23:55	0.0245971	0.0752236	0.0752236	µg			0.0245971	0.0752236	0.0752236			
REAGENT BLANK	4/8/2013	11:25:12	0.0002341	0.0007159	0.0007159	µg			0.0002341	0.0007159	0.0007159			
0.004ug = DL	4/8/2013	12:06:22	0.0012483	0.0038175	0.0038175	µg	4	400	0.0012483	0.0038175	0.0038175			
0.080ug = STD.2	4/8/2013	12:07:39	0.0263363	0.0805427	0.0805427	µg	4	400	0.0263363	0.0805427	0.0805427			
REAGENT BLANK	4/8/2013	12:08:56	-0.0000183	-0.0000562	-0.0000562	µg	4	400	-0.0000183	-0.0000562	-0.0000562			
20241-1A	4/8/2013	12:10:44	-0.000085	-0.0002602	-0.0130119	µg	4	200	-0.0000682	-0.0002118	-0.010592	-0.0001009	-0.0003086	-0.0154318
20241-2A	4/8/2013	12:12:35	-0.0000888	-0.0002716	-0.0135808	µg	4	200	-0.0000848	-0.0002595	-0.0129776	-0.0000927	-0.0002836	-0.014184
20241-2A DUP	4/8/2013	12:14:27	-0.0000798	-0.0002441	-0.0122052	µg	4	200	-0.0000872	-0.0002668	-0.0133416	-0.0000723	-0.0002213	-0.0110689
20241-3A	4/8/2013	12:16:15	-0.0000168	-0.0000514	-0.0025714	µg	4	200	-0.0000236	-0.0000722	-0.0036126	-0.00001	-0.0000306	-0.0015303
20241-3A SPK	4/8/2013	12:17:59	0.0243188	0.0743726	0.3718631	µg	4	200	0.0244425	0.0747508	3.7375383	0.0241952	0.0739945	3.6997236
20241-4A	4/8/2013	12:19:44	-0.000096	-0.0002937	-0.0146896	µg	4	200	-0.0000992	-0.0002813	-0.0140698	-0.0001001	-0.0003061	-0.0153093
20241-5A	4/8/2013	12:21:30	-0.0000843	-0.0002578	-0.0128921	µg	4	200	-0.0000891	-0.0002727	-0.0138365	-0.0000794	-0.0002429	-0.0121477
20241-6A	4/8/2013	12:23:16	-0.0000403	-0.0001234	-0.0061748	µg	4	200	-0.0000471	-0.000144	-0.007204	-0.0000336	-0.0001029	-0.0051457
20241-6A DUP	4/8/2013	12:25:02	-0.0000407	-0.0001246	-0.0062332	µg	4	200	-0.0000511	-0.0001565	-0.0078283	-0.0000303	-0.0000927	-0.0046381
20241-7A	4/8/2013	12:26:49	-0.0000815	-0.0002493	-0.0124689	µg	4	200	-0.0000774	-0.0002367	-0.0118369	-0.0000856	-0.000262	-0.0131009
0.004ug = DL	4/8/2013	12:28:03	0.0012647	0.0038677	0.0038677	µg	4	200	0.0012647	0.0038677	0.0038677			
0.080ug = STD.2	4/8/2013	12:29:20	0.0262659	0.0803271	0.0803271	µg	4	200	0.0262659	0.0803271	0.0803271			
REAGENT BLANK	4/8/2013	12:30:37	-0.0000121	-0.0000037	-0.0000037	µg	4	200	-0.0000121	-0.0000037	-0.0000037			
20241-7A SPK	4/8/2013	12:32:24	0.0248505	0.0759985	3.7999252	µg	4	200	0.0249101	0.0761808	3.809041	0.0247908	0.0758162	3.7908094
20241-8A	4/8/2013	12:34:12	-0.0000102	-0.0000313	-0.0015688	µg	4	200	-1.565E-05	4.786E-05	0.0023933	-0.0000361	-0.0001106	-0.005531
20241-9A	4/8/2013	12:36:00	-0.0000694	-0.0002124	-0.010622	µg	4	200	-0.0000711	-0.0002174	-0.0108735	-0.0000678	-0.0002074	-0.0103704
20241-10A	4/8/2013	12:37:49	4.165E-05	0.0001274	0.0063702	µg	4	200	4.524E-05	0.0001384	0.006919	3.807E-05	0.0001164	0.0058214
20241-10A DUP	4/8/2013	12:39:39	9.379E-05	0.0002868	0.0143416	µg	4	200	8.527E-05	0.0002608	0.013039	0.0001023	0.0003129	0.0156443
20241-11A	4/8/2013	12:41:29	5.991E-05	0.0001832	0.009162	µg	4	200	7.623E-05	0.0002331	0.0116572	4.359E-05	0.0001333	0.0066669
20241-11A SPK	4/8/2013	12:43:37	0.0249801	0.076395	3.8197477	µg	4	200	0.0251064	0.0767813	3.8390671	0.0248537	0.0760086	3.8004284
20241-12A	4/8/2013	12:45:27	1.08E-06	3.33E-06	0.0001666	µg	4	200	1.176E-05	3.596E-05	0.0017985	-0.0000095	-0.0000293	-0.0014651
20241-13A	4/8/2013	12:47:19	-0.0000512	-0.0001567	-0.0078387	µg	4	200	-0.0000551	-0.0001687	-0.0084361	-0.0000473	-0.0001448	-0.0072412
20241-14A	4/8/2013	12:49:07	-0.0000078	-0.0000241	-0.0012061	µg	4	200	-0.000011	-0.0000338	-0.0018909	-0.0000047	-0.0000144	-0.0007212
0.004ug = DL	4/8/2013	12:50:20	0.0012759	0.0039019	0.0039019	µg	4	200	0.0012759	0.0039019	0.0039019			
0.080ug = STD.2	4/8/2013	12:51:37	0.0261615	0.0800079	0.0800079	µg	4	200	0.0261615	0.0800079	0.0800079			
REAGENT BLANK	4/8/2013	12:52:54	1.751E-05	5.357E-05	5.357E-05	µg	4	200	1.751E-05	5.357E-05	5.357E-05			
20241-1 BH	4/8/2013	12:54:39	0.0008928	0.0027305	0.0524538	µg	4	780	0.0009072	0.0027744	0.5410026	0.0008785	0.0026867	0.5239051
20241-2 BH	4/8/2013	12:56:23	0.000754	0.0023058	0.4380966	µg	4	760	0.0007689	0.0023453	0.4456154	0.000741	0.0022662	0.4305777
20241-2 BH DUP	4/8/2013	12:58:08	0.0007974	0.0024387	0.4633567	µg	4	760	0.0008141	0.0024897	0.4730145	0.0007808	0.0023877	0.4536719
20241-3 BH	4/8/2013	12:59:54	0.0006506	0.0019896	0.3432085	µg	4	690	0.0006439	0.0019691	0.3396682	0.0006573	0.0020101	0.3467487
20241-3 BH SPK	4/8/2013	13:01:40	0.0254627	0.0778709	13.432732	µg	4	690	0.0255547	0.0781522	13.481258	0.0253707	0.0775896	13.384206
20241-4 BH	4/8/2013	13:03:26	0.0009709	0.0029694	0.534483	µg	4	720	0.0009997	0.0030575	0.550341	0.0009421	0.0028812	0.518625
20241-5 BH	4/8/2013	13:05:13	0.0015995	0.0048918	0.8805202	µg	4	720	0.0015842	0.0048448	0.8720683	0.0016149	0.0049387	0.888972
20241-6 BH	4/8/2013	13:07:01	0.0019579	0.0059876	1.0328658	µg	4	690	0.001975	0.0060401	1.0419142	0.0019407	0.0059352	1.0238173
20241-6 BH DUP	4/8/2013	13:08:49	0.0018696	0.0057176	0.9862935	µg	4	690	0.0018702	0.0057194	0.9866002	0.001869	0.0057159	0.9859868
20241-7 BH	4/8/2013	13:10:38	0.0019941	0.0060985	1.0367421	µg	4	680	0.0019982	0.0060803	1.0336473	0.0020001	0.0061167	1.0398369
0.004ug = DL	4/8/2013	13:11:55	0.0013193	0.0040347	0.0040347	µg	4	680	0.0013193	0.0040347	0.0040347			
0.080ug = STD.2	4/8/2013	13:13:12	0.0244458	0.0747611	0.0747611	µg	4	680	0.0244458	0.0747611	0.0747611			
REAGENT BLANK	4/8/2013	13:14:29	4.194E-05	0.0001283	0.0001283	µg	4	680	4.194E-05	0.0001283	0.0001283			
Reagent Blank	4/8/2013	14:11:24	-0.0000322	-0.0000984	-0.0000984	µg	4	680	-0.0000304	-0.0000932	-0.0000932	-0.0000339	-0.0001037	-0.0001037
0.004ug = DL	4/8/2013	14:12:38	0.001271	0.003887	0.003887	µg	4	680	0.001271	0.003887	0.003887			
0.080ug = STD.2	4/8/2013	14:13:55	0.0242375	0.0741241	0.0741241	µg	4	680	0.0242375	0.0741241	0.0741241			
0.080ug = QC STD 3	4/8/2013	14:15:15	0.0239044	0.0731051	0.0731051	µg	4	680	0.0239044	0.0731051	0.0731051			
REAGENT BLANK	4/8/2013	14:16:32	6.002E-05	0.0001836	0.0001836	µg	4	680	6.002E-05	0.0001836	0.0001836			
20241-7 BH SPK	4/8/2013	14:18:20	0.0264859	0.0810001	13.770014	µg	4	680	0.0264214	0.0808029	13.736489	0.0265504	0.0811973	13.803539
20241-8 BH	4/8/2013	14:20:10	0.0021839	0.006679	1.1187249	µg	4	670	0.0022059	0.0067461	1.1299732	0.002162	0.0066118	1.1074766
20241-9 BH	4/8/2013	14:22:00	0.0027481	0.0084044	1.3447093	µg	4	640	0.0027686	0.0084669	1.354703	0.0027277	0.008342	1.3347155
20241-10BH	4/8/2013	14:23:51	0.006583	0.0201325	3.1708848	µg	4	630	0.0065894	0.0201519	3.1739219	0.0065767	0.0201131	3.1678076
20241-10 BH DUP	4/8/2013	14:25:40	0.0067586	0.0206695	3.2554432	µg	4	630	0.0068051	0.0208116	3.2778268	0.0067122	0.0205274	3.2330596
20241-11 BH	4/8/2013	14:27:24	0.0074352	0.0227385	3.2686621	µg	4	575	0.007459	0.0228115	3.2791496	0.0074113	0.0226656	3.2581745
20241-11 BH SPK	4/8/2013	14:29:08	0.0285454	0.0872986	12.549177	µg	4	575	0.0286114	0.0875002	12.578158	0.0284795	0.087097	12.520196
20241-12 BH	4/8/2013	14:30:53	0.0047111	0.0144077	2.4132831	µg	4	670	0.0047429	0.0145048	2.4295593	0.0046793	0.0143105	2.3970069
20241-13 BH	4/8/2013	14:32:39	-0.0000681	-0.0002082	-0.0156223	µg	4	300	-0.0000633	-0.0001936	-0.0145231	-0.0000729	-0.0002229	-0.0167216
20241-14 BH	4/8/2013	14:34:25	-0.000052	-0.0001592	-0.0079641	µg	4	200	-0.000054	-0.0001653	-0.0082654	-0.0000501	-0.0001532	-0.0076628
0.004ug = DL	4/8/2013	14:35:40	0.0013467	0.0041185	0.0041185	µg	4	200	0.0013467	0.0041185	0.0041185			
0.080ug = STD.2	4/8/2013	14:36:57	0.0248532	0.0760068	0.0760068	µg	4	200	0.0248532	0.0760068	0			

PerkinElmer FIMS-100 CVA Mercury Analyzer

Sample_ID	Date	Time	Mean_Sig	Mean_Rd	Mean_Rt	Units	Alq.	Vol.	Sig 1	Reading-1	Result-1	Sig 2	Reading-2	Result-2
STD5=2ug	4/9/2013	9:13:46	0.0540149			µg			0.0540149					
Reagent Blank	4/9/2013	9:15:33	1.625E-05	6.231E-05	6.231E-05	µg			4.523E-05	0.0001734	0.0001734	-0.0000127	-0.0000487	-0.0000487
0.004ug = DL	4/9/2013	9:16:45	0.0009972	0.0038229	0.0038229	µg			0.0009972	0.0038229	0.0038229			
0.080ug = STD.2	4/9/2013	9:18:01	0.0188958	0.0724402	0.0724402	µg			0.0188958	0.0724402	0.0724402			
REAGENT BLANK	4/9/2013	9:19:17	7.563E-05	0.00029	0.00029	µg			7.563E-05	0.00029	0.00029			
0.080ug = STD.2	4/9/2013	9:20:33	0.0189375	0.0725999	0.0725999	µg			0.0189375	0.0725999	0.0725999			
0.080ug = QC STD 3	4/9/2013	9:21:52	0.0195857	0.0750852	0.0750852	µg			0.0195857	0.0750852	0.0750852			
REAGENT BLANK	4/9/2013	9:28:07	0.0001149	0.0004405	0.0004405	µg			0.0001149	0.0004405	0.0004405			
20241-1B	4/9/2013	9:29:52	0.0001315	0.0005042	0.0630213	µg	4	500	0.0001198	0.0004592	0.0574019	0.0001432	0.0005491	0.0686408
20241-2B	4/9/2013	9:31:37	0.0002082	0.0007981	0.1197124	µg	4	600	0.0002248	0.0008618	0.1292724	0.0001916	0.0007343	0.1101524
20241-2B DUP	4/9/2013	9:33:21	0.0001155	0.0004426	0.0663916	µg	4	600	0.0001094	0.0004195	0.0629253	0.0001215	0.0004657	0.0898579
20241-3B	4/9/2013	9:35:07	0.0002177	0.0008347	0.1043401	µg	4	500	0.0002336	0.0008957	0.1119616	0.0002018	0.0007737	0.0967185
20241-3B SPK	4/9/2013	9:36:56	0.0179877	0.0689587	8.6198411	µg	4	500	0.0179925	0.0689771	8.6221436	0.0179829	0.0689403	8.6175387
20241-4B	4/9/2013	9:38:44	0.0001425	0.0005463	0.0682839	µg	4	500	0.000146	0.0005596	0.0699455	0.000139	0.000533	0.0666222
20241-5B	4/9/2013	9:40:34	0.0001791	0.0006865	0.0858098	µg	4	500	0.0001906	0.0007306	0.0913283	0.0001675	0.0006423	0.0802913
20241-6B	4/9/2013	9:42:23	0.0002391	0.0009167	0.1145917	µg	4	500	0.0002322	0.0008904	0.1112959	0.000246	0.0009431	0.1178874
20241-6B DUP	4/9/2013	9:44:10	0.0001877	0.0007194	0.0899242	µg	4	500	0.0001909	0.0007318	0.0914746	0.0001844	0.000707	0.0883737
20241-7B	4/9/2013	9:45:53	0.0001332	0.0005108	0.0638455	µg	4	500	0.0001189	0.0004558	0.0589744	0.0001476	0.0005657	0.0707166
0.004ug = DL	4/9/2013	9:47:06	0.010926	0.0041886	0.0041886	µg	4	500	0.0010926	0.0041886	0.0041886			
0.080ug = STD.2	4/9/2013	9:49:42	0.0193775	0.0742869	0.0742869	µg	4	500	0.0193775	0.0742869	0.0742869			
REAGENT BLANK	4/9/2013	9:50:58	0.0001299	0.000498	0.000498	µg	4	500	0.0001299	0.000498	0.000498			
20241-7B SPK	4/9/2013	9:52:42	0.0176967	0.0678434	8.4804228	µg	4	500	0.0177378	0.0680009	8.5001161	0.0176557	0.0676858	8.4607295
20241-8B	4/9/2013	9:54:26	0.0001245	0.0004774	0.0596752	µg	4	500	0.0001504	0.0005766	0.0720784	9.864E-05	0.0003782	0.0472721
20241-9B	4/9/2013	9:56:10	0.000133	0.0005101	0.0637565	µg	4	500	9.863E-05	0.0003781	0.0472683	0.0001675	0.000642	0.0802446
20241-10B	4/9/2013	9:57:55	0.0001028	0.0003941	0.0591146	µg	4	600	0.0001271	0.0004873	0.0730933	7.849E-05	0.0003009	0.0451359
20241-10B DUP	4/9/2013	9:59:42	0.0001325	0.0005081	0.0762192	µg	4	600	0.0001217	0.0004667	0.0700059	0.0001433	0.0005496	0.0824326
20241-11B	4/9/2013	10:01:28	0.0001563	0.0005993	0.0749121	µg	4	500	0.0001404	0.0005381	0.0672623	0.0001723	0.0006605	0.0825199
20241-11B SPK	4/9/2013	10:03:14	0.0185045	0.0709401	8.8675066	µg	4	500	0.0185782	0.0712225	8.9028074	0.0184308	0.0706576	8.8322059
20241-12B	4/9/2013	10:05:02	0.0001352	0.0005183	0.0647917	µg	4	500	0.0001385	0.0005309	0.0663616	0.0001319	0.0005058	0.8632218
20241-13B	4/9/2013	10:06:54	0.0001136	0.0004354	0.0544288	µg	4	500	9.692E-05	0.0003716	0.046445	0.0001302	0.0004993	0.0624126
20241-14B	4/9/2013	10:08:42	0.0001475	0.0005654	0.0706755	µg	4	500	0.0001018	0.000089	0.0862496	0.000115	0.0004408	0.0551015
0.004ug = DL	4/9/2013	10:09:58	0.0010874	0.0041689	0.0041689	µg	4	500	0.0010874	0.0041689	0.0041689			
0.080ug = STD.2	4/9/2013	10:11:12	0.0197171	0.0755887	0.0755887	µg	4	500	0.0197171	0.0755887	0.0755887			
REAGENT BLANK	4/9/2013	10:12:29	0.00018	0.0006902	0.0006902	µg	4	500	0.00018	0.0006902	0.0006902			
Calib Blank	4/11/2013	10:11:50	6.084E-05			µg	20	1	6.084E-05					
STD1=.004ug	4/11/2013	10:13:04	0.0010562			µg	20	1	0.0010562					
STD2=.04ug	4/11/2013	10:14:19	0.0108164			µg	20	1	0.0108164					
STD3=.08ug	4/11/2013	10:15:35	0.0212494			µg	20	1	0.0212494					
STD4=.16ug	4/11/2013	10:16:51	0.0413365			µg	20	1	0.0413365					
STD5=.2ug	4/11/2013	10:18:09	0.0504828			µg	20	1	0.0504828					
Reagent Blank	4/11/2013	10:19:55	4.463E-05	0.0001743	0.0001743	µg	20	1	5.044E-05	0.000197	0.000197	3.882E-05	0.0001518	0.0001516
0.004ug = DL	4/11/2013	10:21:08	0.001039	0.0040571	0.0040571	µg	20	1	0.001039	0.0040571	0.0040571			
0.080ug = STD.2	4/11/2013	10:22:23	0.0189133	0.0738497	0.0738497	µg	20	1	0.0189133	0.0738497	0.0738497			
0.080ug = QC STD 3	4/11/2013	10:23:42	0.0202673	0.0791366	0.0791366	µg	20	1	0.0202673	0.0791366	0.0791366			
REAGENT BLANK	4/11/2013	10:24:58	1.22E-06	4.78E-06	4.78E-06	µg	20	1	1.22E-06	4.78E-06	4.78E-06			
0.004ug = DL	4/11/2013	11:07:39	0.0009745	0.003805	0.003805	µg	20	1	0.0009745	0.003805	0.003805			
0.080ug = STD.2	4/11/2013	11:08:55	0.0193454	0.0755373	0.0755373	µg	20	1	0.0193454	0.0755373	0.0755373			
REAGENT BLANK	4/11/2013	11:10:11	4.216E-05	0.0001646	0.0001646	µg	20	1	4.216E-05	0.0001646	0.0001646			
20241-1C	4/11/2013	11:13:45	0.0001573	0.0006143	0.0614323	µg	4	400	0.0001437	0.0005612	0.0561155	0.0001709	0.0006675	0.066749
20241-2C	4/11/2013	11:15:33	7.067E-05	0.000276	0.027596	µg	4	400	8.011E-05	0.0003128	0.0312834	8.123E-05	0.0002391	0.0239087
20241-2C DUP	4/11/2013	11:17:23	0.0001004	0.000392	0.0391992	µg	4	400	9.688E-05	0.0003783	0.0378308	0.0001039	0.0004057	0.0405675
20241-3C	4/11/2013	11:19:13	0.0001374	0.0005364	0.0536441	µg	4	400	0.0001331	0.0005198	0.0519777	0.0001417	0.0005531	0.0553106
20241-3C SPK	4/11/2013	11:20:59	0.0208667	0.0814771	8.1477085	µg	4	400	0.0208729	0.0815016	8.1501635	0.0208604	0.0814525	8.1452535
20241-4C	4/11/2013	11:22:41	0.0001127	0.0004401	0.0440073	µg	4	400	0.000108	0.0004217	0.0421654	0.0001174	0.0004585	0.0458492
20241-5C	4/11/2013	11:24:24	0.0001676	0.0006546	0.065459	µg	4	400	0.0001781	0.0006956	0.0695553	0.0001572	0.0006136	0.0613627
20241-6C	4/11/2013	11:26:07	0.0001614	0.0006301	0.0630068	µg	4	400	0.0001555	0.0006072	0.0607156	0.0001672	0.000653	0.0652979
20241-6C DUP	4/11/2013	11:27:51	0.0001247	0.0004869	0.0486907	µg	4	400	0.0001089	0.0004251	0.042508	0.0001405	0.0005487	0.0548733
0.004ug = DL	4/11/2013	11:31:30	0.0010572	0.0041279	0.0041279	µg	4	400	0.0010572	0.0041279	0.0041279			
0.080ug = STD.2	4/11/2013	11:32:46	0.0196667	0.0767916	0.0767916	µg	4	400	0.0196667	0.0767916	0.0767916			
REAGENT BLANK	4/11/2013	11:34:02	4.272E-05	0.0001668	0.0001668	µg	4	400	4.272E-05	0.0001668	0.0001668			
20241-7C	4/11/2013	11:35:46	8.448E-05	0.0003299	0.0329896	µg	4	400	0.0001019	0.0003977	0.0397709	6.712E-05	0.0002621	0.0262082
20241-7C SPK	4/11/2013	11:37:31	0.020594	0.0804124	8.0412389	µg	4	400	0.0207555	0.0810429	8.1042877	0.0204325	0.0797819	7.9781902
20241-8C	4/11/2013	11:39:17	0.0001415	0.0005525	0.055252	µg	4	400	0.0001346	0.0005255	0.0525491	0.0001484	0.0005795	0.0579549
20241-9C	4/11/2013	11:41:03	8.819E-05	0.0003444	0.0344384	µg	4	400	8.827E-05	0.0003447	0.0344675	8.812E-05	0.0003441	0.0344092
20241-10C	4/11/2013	11:42:49	0.0001461	0.0005704	0.0570386	µg	4	400						

PerkinElmer FIMS-100 CVAA Mercury Analyzer

Sample_ID	Date	Time	Mean_Sig	Mean_Rd	Mean_Rt	Units	Alq.	Vol.	Sig 1	Reading-1	Result-1	Sig 2	Reading-2	Result-2
REAGENT BLANK	4/11/2013	12:16:45	4.646E-05	0.0001814	0.0001814	µg	4	400	4.646E-05	0.0001814	0.0001814			
Calib Blank	4/12/2013	9:24:46	8.975E-05			µg	4	100	8.975E-05					
STD1=.004ug	4/12/2013	9:26:02	0.0011721			µg	4	100	0.0011721					
STD2=.04ug	4/12/2013	9:27:18	0.0124241			µg	4	100	0.0124241					
STD3=.08ug	4/12/2013	9:28:35	0.0248286			µg	4	100	0.0248286					
STD4=.16ug	4/12/2013	9:29:53	0.0477428			µg	4	100	0.0477428					
STD5=.2ug	4/12/2013	9:31:12	0.0595009			µg	4	100	0.0595009					
Reagent Blank	4/12/2013	9:32:59	1.069E-05	3.572E-05	3.572E-05	µg	4	100	5.3E-07	1.78E-06	1.78E-06	2.084E-05	6.965E-05	6.965E-05
0.004ug = DL	4/12/2013	9:34:14	0.0012083	0.0040376	0.0040376	µg	4	100	0.0012083	0.0040376	0.0040376			
0.080ug = STD.2	4/12/2013	9:35:30	0.0222097	0.0742138	0.0742138	µg	4	100	0.0222097	0.0742138	0.0742138			
0.080ug = QC STD 3	4/12/2013	9:36:50	0.0252921	0.0845138	0.0845138	µg	4	100	0.0252921	0.0845138	0.0845138			
REAGENT BLANK	4/12/2013	9:38:08	3.965E-05	0.0001325	0.0001325	µg	4	100	3.965E-05	0.0001325	0.0001325			
20241-LRB FH	4/12/2013	9:47:04	5.923E-05	0.0001979	0.0049482	µg	4	100	5.748E-05	0.0001921	0.0048022	6.097E-05	0.0002038	0.0050941
20241-LRB FH SPK	4/12/2013	9:48:54	0.0188535	0.0629993	3.9374545	µg	1.6	100	0.0187875	0.0627786	3.9236598	0.0189196	0.06322	3.9512491
20241-1FH	4/12/2013	9:50:44	2.669E-05	8.921E-05	0.0022303	µg	4	100	0.000018	6.016E-05	0.0015042	3.539E-05	0.0001183	0.0029565
20241-2FH	4/12/2013	9:52:36	5.874E-05	0.0001963	0.0049071	µg	4	100	6.708E-05	0.0002242	0.0056045	5.039E-05	0.0001684	0.0042096
20241-2FH DUP	4/12/2013	9:54:24	5.475E-05	0.000183	0.0045743	µg	4	100	5.129E-05	0.0001714	0.004285	5.822E-05	0.0001945	0.0048636
20241-3FH	4/12/2013	9:56:10	7.374E-05	0.0002464	0.0061608	µg	4	100	6.707E-05	0.0002241	0.005603	8.042E-05	0.0002687	0.0067187
0.004ug = DL	4/12/2013	9:57:24	0.0011993	0.0040073	0.0040073	µg	4	100	0.0011993	0.0040073	0.0040073			
0.080ug = STD.2	4/12/2013	9:58:42	0.0219722	0.0734202	0.0734202	µg	4	100	0.0219722	0.0734202	0.0734202			
REAGENT BLANK	4/12/2013	9:59:58	7.187E-05	0.0002402	0.0002402	µg	4	100	7.187E-05	0.0002402	0.0002402			
20241-3FH SPK	4/12/2013	10:01:44	0.0209537	0.070017	1.7504245	µg	4	100	0.0210101	0.0702053	1.7551322	0.0208973	0.0698287	1.7457168
20241-4FH	4/12/2013	10:03:31	0.0001419	0.0004742	0.011854	µg	4	100	0.0001136	0.0003797	0.0094926	0.0001702	0.0005686	0.0142154
20241-5FH	4/12/2013	10:05:17	0.0006079	0.0020311	0.0507785	µg	4	100	0.000607	0.0020284	0.050711	0.0006087	0.0020338	0.0508459
20241-6FH	4/12/2013	10:07:04	0.0004856	0.0016227	0.0405683	µg	4	100	0.0004864	0.0016254	0.0406348	0.0004848	0.0016201	0.0405017
20241-6FH DUP	4/12/2013	10:08:52	0.0005126	0.0017129	0.0428218	µg	4	100	0.0005186	0.0017331	0.0433263	0.0005066	0.0016927	0.0423173
20241-7FH	4/12/2013	10:10:39	0.0005599	0.0018711	0.0467764	µg	4	100	0.0005647	0.0018869	0.0471714	0.0005552	0.0018553	0.0463814
20241-7FH SPK	4/12/2013	10:12:28	0.0238217	0.0796003	1.9900063	µg	4	100	0.0237197	0.0792596	1.9814901	0.0239236	0.0799409	1.9885225
20241-8FH	4/12/2013	10:14:18	4.027E-05	0.0001346	0.0033648	µg	4	100	3.308E-05	0.0001106	0.0027639	4.747E-05	0.0001586	0.0039658
20241-9FH	4/12/2013	10:16:08	0.0009368	0.0031304	0.0782597	µg	4	100	0.0009342	0.0031216	0.0780409	0.0009394	0.0031391	0.0784785
20241-10FH	4/12/2013	10:17:58	0.0017569	0.0058706	0.146765	µg	4	100	0.0017658	0.0059004	0.1475099	0.001748	0.0058408	0.14602
0.004ug = DL	4/12/2013	10:19:14	0.0011893	0.0039741	0.0039741	µg	4	100	0.0011893	0.0039741	0.0039741			
0.080ug = STD.2	4/12/2013	10:20:31	0.0222264	0.0742698	0.0742698	µg	4	100	0.0222264	0.0742698	0.0742698			
REAGENT BLANK	4/12/2013	10:21:48	3.631E-05	0.0001213	0.0001213	µg	4	100	3.631E-05	0.0001213	0.0001213			
20241-10FH DUP	4/12/2013	10:23:36	0.0019526	0.0065247	0.1631171	µg	4	100	0.0019592	0.0065467	0.1636686	0.001946	0.0065026	0.1625656
20241-11FH	4/12/2013	10:25:27	0.0007779	0.0025995	0.0649874	µg	4	100	0.0007743	0.0025873	0.0646828	0.0007816	0.0026117	0.0652919
20241-11FH SPK	4/12/2013	10:27:19	0.0247788	0.0827978	2.0699444	µg	4	100	0.0246278	0.0822939	2.0573472	0.0249294	0.0833017	2.0825415
20241-12FH	4/12/2013	10:29:06	0.0018533	0.0061929	0.1548229	µg	4	100	0.0018744	0.0062632	0.1565795	0.0018323	0.0061227	0.1530663
20241-13FH	4/12/2013	10:30:50	3.906E-05	0.0001305	0.0032632	µg	4	100	3.872E-05	0.0001294	0.0032351	0.0000394	0.0001317	0.0032914
20241-14FH	4/12/2013	10:32:36	8.522E-05	0.0002848	0.0071193	µg	4	100	0.0001042	0.0003481	0.0087036	6.625E-05	0.0002214	0.005535
0.004ug = DL	4/12/2013	10:40:56	0.0012544	0.0041917	0.0041917	µg	0.4	1	0.0012544	0.0041917	0.0041917			
0.080ug = STD.2	4/12/2013	10:42:12	0.0223738	0.0747623	0.0747623	µg	0.4	1	0.0223738	0.0747623	0.0747623			
REAGENT BLANK	4/12/2013	10:43:29	5.783E-05	0.0001933	0.0001933	µg	0.4	1	5.783E-05	0.0001933	0.0001933			



18 April 2013

Scott Brown  
Clean Air Engineering  
500 West Wood Street  
Palatine, IL 60067

Ph.: 847-991-3300  
Email: [scott\\_brown@cleanair.com](mailto:scott_brown@cleanair.com)

Subject: Certificate of Results

Dear Scott;

Attached to this narrative are the analytical results you requested on samples submitted for the determination of polychlorinated dibenzo-*p*-dioxins and dibenzofurans. The insert below summarizes the relevant information pertaining to your project. In particular, QC annotations bring to your attention specific analytical observations and assessments made during the sample handling and data interpretation phases. Results reported relate only to the items tested.

Project Information Summary	When applicable, see QC Annotations for details
Client Project No.	12218SB
AP Project #	A5342
Analytical Protocol	Method 23
No. Samples Submitted	6
No. Samples Analyzed	4 (Reagent Blank & Run 1 Archived)
No. Laboratory Method Blanks	1
No. OPRs / Batch CS3	1
No. Outstanding Samples	0
Date Received	28-Mar-2013
Condition Received	good
Temperature upon Receipt (C)	4 (traps and filters), 12 (solvents)
Extraction within Holding Time	yes
Analysis within Holding Time	yes
Data meet QA/QC Requirements	yes
Exceptions	none
Analytical Difficulties	none

**ANALYTICAL PERSPECTIVES IS NOW PART OF SGS, THE WORLD'S LEADING INSPECTION, VERIFICATION, TESTING AND CERTIFICATION COMPANY.**



**QC Annotations:**

1. Please see Appendix A & B attached for data qualifier/attribute and lab identifier descriptions which may be contained in the project.
2. The Laboratory Method Blank and BCS3 were created at time of extraction. Method Blank does not contain CS/SS standard spikes.

**Analytical Perspectives Certification IDs:**

SOUTH CAROLINA	99054
ARKANSAS	88-0628
NEW JERSEY-NELAP SECONDARY	NC005
FLORIDA-NELAP PRIMARY	E87608
LOUISIANA	4024
NORTH CAROLINA	37783
WASHINGTON	C2027
NEW YORK	11988
VIRGINIA	460180
MINNESOTA	037-999-448
OREGON	pending
TEXAS	T104704484-10-1
PENNSYLVANIA-NELAP SECONDARY	68-01849

SGS Analytical Perspectives remains committed to serving you in the most effective manner. Should you have any questions or need additional information and technical support, please do not hesitate to contact us.

The management and staff of SGS Analytical Perspectives welcomes customer feedback, both positive and negative, as we continually improve our services. Please visit our web site at [www.ultratrace.com](http://www.ultratrace.com) and click on the 'Leave Your Feedback Here!' link on the Home Page. Thank you for choosing SGS Analytical Perspectives.

Sincerely,

Donna R McCall  
Project Scientist Associate



**APPENDIX A: DATA QUALIFIERS / DATA ATTRIBUTES**

<b>&gt;</b>	Indicates high recoveries. Shown with the numeric value at the top of the range. <sup>1</sup>
<b>B</b>	The analyte was found in the method blank, at a concentration that was at least 10% of the concentration in the sample.
<b>C</b>	Two or more congeners co-elute. In EDDs C denotes the lowest IUPAC congener in a co-elution group and additional co-eluters for the group are shown with the number of the lowest IUPAC co-eluter.
<b>E</b>	The reported concentration exceeds the calibration range (upper point of the calibration curve).
<b>EMPC</b>	Represents an Estimated Maximum Possible Concentration. EMPC's arise in cases where the signal/noise ratio is not sufficient for peak identification (the determined ion-abundance ratio is outside the allowed theoretical range), or where there is a co-eluting interference.
<b>ETH</b>	Indicates the presence of a diphenyl ether that appears to interfere with the quantitation of a furan. The reported concentration is the maximum.
<b>H/h</b>	If the standard recovery is below the method or SOP specified value "H" is assigned. If the obtained value is less than half the specified value "h" is assigned. <sup>1</sup>
<b>J</b>	Indicates that an analyte has a concentration below the reporting limit (lowest point of the calibration curve).
<b>ND</b>	Indicates a non-detect.
<b>NR</b>	Indicates a value that is not reportable.
<b>PR</b>	Due to interference, the associated congener is poorly resolved.
<b>QI</b>	Indicates the presence of a quantitative interference.
<b>SI</b>	Denotes "Single Ion Mode" and is utilized for PCBs where the secondary ion trace has a significantly elevated noise level due to background PFK. Responses for such peaks are calculated using an EMPC approach based solely on the primary ion area(s) and may be considered estimates. <sup>1</sup>
<b>U</b>	The analyte was not detected. The estimated detection limit (EDL) may be reported for this analyte.
<b>V</b>	The labeled standard recovery was found to be outside of the method control limits.
<b>X</b>	Indicates results reported from reinjection, refractionation, or repeat analyses.

**APPENDIX B: LAB ID IDENTIFIERS**

<b>AR</b>	Indicates use of the archived portion of the sample extract.
<b>CU</b>	Indicates a sample that required additional clean-up prior to MS injection/processing.
<b>D</b>	Indicates a dilution of the sample extract. The number that follows the "D" indicates the dilution factor.
<b>DE</b>	Indicates a dilution performed with the addition of ES (extraction standard) solution.
<b>DUP</b>	Designation for a duplicate sample.
<b>MS</b>	Designation for a matrix spike.
<b>MSD</b>	Designation for a matrix spike duplicate.
<b>RJ</b>	Indicates a reinjection of the sample extract.
<b>S</b>	Indicates a sample split. The number that follows the "S" indicates the split factor.

<sup>1</sup> Denotes data qualifiers/attributes whose use will be phased out over time

**A5342 - TEQ**  
Project ID: 12218SB

**Sample Summary**  
**Part 1**



**Method 23**

Analyte	Method Blank A5342 pg	Unit 2 FF Outlet - Field Blank pg	Unit 2 FF Outlet - Run 2 pg	Unit 2 FF Outlet - Run 3 pg	Unit 2 FF Outlet - Run 4 pg
2,3,7,8-TCDD	(1.47)	(2.21)	[11.1]	13.8	14.7
1,2,3,7,8-PeCDD	(1.51)	(2.09)	36.8	43.7	41.8
1,2,3,4,7,8-HxCDD	(1.18)	(2.21)	56.8	63.2	64
1,2,3,6,7,8-HxCDD	(1.19)	(2.18)	177	171	200
1,2,3,7,8,9-HxCDD	(1.29)	(2.46)	77.8	72.7	85.8
1,2,3,4,6,7,8-HpCDD	7.16	9.17	987	1060	1110
OCDD	[17.5]	19.4	786	845	847
2,3,7,8-TCDF	(1.01)	(1.54)	[11.4]	12.9	13.4
1,2,3,7,8-PeCDF	(0.942)	(1.86)	21	19.2	21
2,3,4,7,8-PeCDF	(0.85)	(1.76)	44.5	42.8	45.4
1,2,3,4,7,8-HxCDF	(1.14)	(1.29)	33.1	31.3	31.6
1,2,3,6,7,8-HxCDF	(1.08)	(1.26)	38.2	38.3	36.7
2,3,4,6,7,8-HxCDF	(1.13)	(1.29)	69	71.9	70.9
1,2,3,7,8,9-HxCDF	(1.56)	(1.95)	12.1	(3.33)	(3.71)
1,2,3,4,6,7,8-HpCDF	2.28	(1.15)	97.6	96.3	94.6
1,2,3,4,7,8,9-HpCDF	(1.76)	(1.93)	19.3	24	22.7
OCDF	8.03	14.8	43	40.5	38.5
ITEF TEQ (ND=0; EMPC=0)	<b>0.102</b>	<b>0.126</b>	<b>100</b>	<b>117</b>	<b>123</b>
ITEF TEQ (ND=0; EMPC=EMPC)	<b>0.12</b>	<b>0.126</b>	<b>112</b>	<b>117</b>	<b>123</b>
ITEF TEQ (ND=DL/2; EMPC=0)	<b>1.94</b>	<b>2.97</b>	<b>101</b>	<b>117</b>	<b>123</b>
ITEF TEQ (ND=DL/2; EMPC=EMPC)	<b>1.96</b>	<b>2.97</b>	<b>112</b>	<b>117</b>	<b>123</b>
ITEF TEQ (ND=DL; EMPC=EMPC)	<b>3.8</b>	<b>5.8</b>	<b>112</b>	<b>117</b>	<b>123</b>
Checkcode	475-588-HQH	270-937-HSF	027-340-YGQ	012-546-KXD	292-919-QVQ
Lab ID	MB1_10783_DF_TLX	A5342_10783_DF_001	A5342_10783_DF_003	A5342_10783_DF_004	A5342_10783_DF_005

1 - 73

( ) = DL  
[ ] = EMPC

# A5342 - WHO-2005-TEQ

Project ID: 12218SB

## Sample Summary Part 1



## Method 23

Analyte	Method Blank A5342	Unit 2 FF Outlet - Field Blank	Unit 2 FF Outlet - Run 2	Unit 2 FF Outlet - Run 3	Unit 2 FF Outlet - Run 4
	pg	pg	pg	pg	pg
2,3,7,8-TCDD	(1.47)	(2.21)	[11.1]	13.8	14.7
1,2,3,7,8-PeCDD	(1.51)	(2.09)	36.8	43.7	41.8
1,2,3,4,7,8-HxCDD	(1.18)	(2.21)	56.8	63.2	64
1,2,3,6,7,8-HxCDD	(1.19)	(2.18)	177	171	200
1,2,3,7,8,9-HxCDD	(1.29)	(2.46)	77.8	72.7	85.8
1,2,3,4,6,7,8-HpCDD	7.16	9.17	987	1060	1110
OCDD	[17.5]	19.4	786	845	847
2,3,7,8-TCDF	(1.01)	(1.54)	[11.4]	12.9	13.4
1,2,3,7,8-PeCDF	(0.942)	(1.86)	21	19.2	21
2,3,4,7,8-PeCDF	(0.85)	(1.76)	44.5	42.8	45.4
1,2,3,4,7,8-HxCDF	(1.14)	(1.29)	33.1	31.3	31.6
1,2,3,6,7,8-HxCDF	(1.08)	(1.26)	38.2	38.3	36.7
2,3,4,6,7,8-HxCDF	(1.13)	(1.29)	69	71.9	70.9
1,2,3,7,8,9-HxCDF	(1.56)	(1.95)	12.1	(3.33)	(3.71)
1,2,3,4,6,7,8-HpCDF	2.28	(1.15)	97.6	96.3	94.6
1,2,3,4,7,8,9-HpCDF	(1.76)	(1.93)	19.3	24	22.7
OCDF	8.03	14.8	43	40.5	38.5
WHO-2005 TEQ (ND=0; EMPC=0)	<b>0.0967</b>	<b>0.102</b>	<b>109</b>	<b>129</b>	<b>133</b>
WHO-2005 TEQ (ND=0; EMPC=EMPC)	<b>0.102</b>	<b>0.102</b>	<b>121</b>	<b>129</b>	<b>133</b>
WHO-2005 TEQ (ND=DL/2; EMPC=0)	<b>2.22</b>	<b>3.27</b>	<b>110</b>	<b>129</b>	<b>134</b>
WHO-2005 TEQ (ND=DL/2; EMPC=EMPC)	<b>2.22</b>	<b>3.27</b>	<b>121</b>	<b>129</b>	<b>134</b>
WHO-2005 TEQ (ND=DL; EMPC=EMPC)	<b>4.35</b>	<b>6.44</b>	<b>121</b>	<b>129</b>	<b>134</b>
Checkcode	475-588-HQH	270-937-HSF	027-340-YGQ	012-546-KXD	292-919-QVQ
Lab ID	MB1_10783_DF_TLX	A5342_10783_DF_001	A5342_10783_DF_003	A5342_10783_DF_004	A5342_10783_DF_005

1-74

() = DL  
[] = EMPC



**A5342 - Totals**  
Project ID: 12218SB

**Sample Summary**  
**Part 2**





**Method 23**

Analyte	Method Blank A5342	Unit 2 FF Outlet - Field Blank	Unit 2 FF Outlet - Run 2	Unit 2 FF Outlet - Run 3	Unit 2 FF Outlet - Run 4
	pg	pg	pg	pg	pg
<b>Totals</b>					
TCDDs	0	0	2570	2660	2990
PeCDDs	0	0	2740	2760	3020
HxCDDs	0	5.02	4310	4520	4880
HpCDDs	10.8	15.5	1930	2070	2170
OCDD	0	19.4	786	845	847
TCDFs	0	0	744	743	835
PeCDFs	0	0	685	660	703
HxCDFs	0	0	562	557	568
HpCDFs	6.52	4.78	228	260	248
OCDF	8.03	14.8	43	40.5	38.5
<b>Total PCDD/Fs (ND=0; EMPC=0)</b>	<b>25.4</b>	<b>59.4</b>	<b>14600</b>	<b>15100</b>	<b>16300</b>
<b>Total PCDD/Fs (ND=0; EMPC=EMPC)</b>	<b>42.9</b>	<b>64.3</b>	<b>14700</b>	<b>15100</b>	<b>16300</b>
<b>Total PCDD/Fs (2378-X ND=DL; EMPC=EMPC)</b>	<b>59</b>	<b>89.5</b>	<b>14700</b>	<b>15100</b>	<b>16300</b>
<b>Total 2378s (ND=0; EMPC=0)</b>	<b>17.5</b>	<b>43.4</b>	<b>2500</b>	<b>2640</b>	<b>2740</b>
<b>Total 2378s (ND=0.5; EMPC=0)</b>	<b>26.8</b>	<b>55.9</b>	<b>2500</b>	<b>2650</b>	<b>2740</b>
<b>Total 2378s (ND=1; EMPC=0)</b>	<b>36.1</b>	<b>68.5</b>	<b>2500</b>	<b>2650</b>	<b>2740</b>
<b>Total 2378s (ND=0; EMPC=1)</b>	<b>35</b>	<b>43.4</b>	<b>2520</b>	<b>2640</b>	<b>2740</b>
<b>Total 2378s (ND=0.5; EMPC=1)</b>	<b>43</b>	<b>55.9</b>	<b>2520</b>	<b>2650</b>	<b>2740</b>
<b>Total 2378s (ND=1; EMPC=1)</b>	<b>51.1</b>	<b>68.5</b>	<b>2520</b>	<b>2650</b>	<b>2740</b>
Checkcode	475-588-HQH	270-937-HSF	027-340-YGQ	012-546-KXD	292-919-QVQ
Lab ID	MB1_10783_DF_TLX	A5342_10783_DF_001	A5342_10783_DF_003	A5342_10783_DF_004	A5342_10783_DF_005

1 - 75

() = DL  
[] = EMPC

**A5342 - Others**  
**Project ID: 12218SB**

<b>Sample Summary</b>						<b>Method 23</b>
<b>Part 3</b>		<b>Method Blank A5342</b>	<b>Unit 2 FF Outlet - Field Blank</b>	<b>Unit 2 FF Outlet - Run 2</b>	<b>Unit 2 FF Outlet - Run 3</b>	<b>Unit 2 FF Outlet - Run 4</b>
<b>Analyte</b>		pg	pg	pg	pg	pg
<b>Other PCDD/Fs (ND=0, EMPC=0)</b>						
Other TCDD	0	0	2570	2650	2980	2980
Other PeCDD	0	0	2710	2720	2980	2980
Other HxCDD	0	5.02	4000	4210	4530	4530
Other HpCDD	3.69	6.28	939	1010	1060	1060
Other TCDF	0	0	744	730	822	822
Other PeCDF	0	0	619	598	636	636
Other HxCDF	0	0	409	415	429	429
Other HpCDF	4.24	4.78	111	139	131	131
<b>Other PCDD/Fs (ND=0, EMPC=EMPC)</b>						
Other TCDD	0	4.86	2590	2650	3000	3000
Other PeCDD	0	0	2730	2720	2990	2990
Other HxCDD	0	5.02	4020	4210	4530	4530
Other HpCDD	3.69	6.28	939	1010	1060	1060
Other TCDF	0	0	749	750	832	832
Other PeCDF	0	0	629	598	643	643
Other HxCDF	0	0	409	415	429	429
Other HpCDF	4.24	4.78	111	139	131	131
Checkcode	475-588-HQH	270-937-HSF	027-340-YGQ	012-546-KXD	292-919-QVQ	
Lab ID	MB1_10783_DF_TLX	A5342_10783_DF_001	A5342_10783_DF_003	A5342_10783_DF_004	A5342_10783_DF_005	

1 - 76

( ) = DL  
 [ ] = EMPC

**A5342 - DLs**  
**Project ID: 12218SB**

**Sample Summary**  
**Part 5 (DLs)**




**Method 23**

Analyte	Method Blank A5342	Unit 2 FF Outlet - Field Blank	Unit 2 FF Outlet - Run 2	Unit 2 FF Outlet - Run 3	Unit 2 FF Outlet - Run 4
	pg	pg	pg	pg	pg
2,3,7,8-TCDD	1.47	2.21	2.4	2.05	2.15
1,2,3,7,8-PeCDD	1.51	2.09	3.22	4.93	2.65
1,2,3,4,7,8-HxCDD	1.18	2.21	2.12	2.39	1.95
1,2,3,6,7,8-HxCDD	1.19	2.18	2.08	2.35	2.06
1,2,3,7,8,9-HxCDD	1.29	2.46	2.41	2.59	2.24
1,2,3,4,6,7,8-HpCDD	1.97	2.64	3.64	5.02	2.81
OCDD	2.53	4.4	3.4	4.06	4.41
2,3,7,8-TCDF	1.01	1.54	2.36	2.24	0.942
1,2,3,7,8-PeCDF	0.942	1.86	3.53	3.1	2.24
2,3,4,7,8-PeCDF	0.85	1.76	3.2	2.83	2.06
1,2,3,4,7,8-HxCDF	1.14	1.29	2.55	2.28	2.68
1,2,3,6,7,8-HxCDF	1.08	1.26	2.48	2.16	2.54
2,3,4,6,7,8-HxCDF	1.13	1.29	2.6	2.27	2.56
1,2,3,7,8,9-HxCDF	1.56	1.95	3.77	3.33	3.71
1,2,3,4,6,7,8-HpCDF	1.07	1.15	1.88	1.99	1.42
1,2,3,4,7,8,9-HpCDF	1.76	1.93	3.13	3.12	2.22
OCDF	3.46	4.73	5.02	5.61	3.06
Total TCDD	1.47	2.21	2.4	2.05	2.15
Total PeCDD	1.51	2.09	3.22	4.93	2.65
Total HxCDD	1.22	2.27	2.2	2.44	2.08
Total HpCDD	1.97	2.64	3.64	5.02	2.81
Total TCDF	1.01	1.54	2.36	2.24	0.942
Total PeCDF	0.895	1.81	3.36	2.96	2.15
Total HxCDF	1.21	1.42	2.8	2.47	2.83
Total HpCDF	1.37	1.5	2.43	2.49	1.78
Checkcode	475-588-HQH	270-937-HSF	027-340-YGQ	012-546-KXD	292-919-QVQ
Lab ID	MB1_10783_DF_TLX	A5342_10783_DF_001	A5342_10783_DF_003	A5342_10783_DF_004	A5342_10783_DF_005


ITEF-TEQ  
Project ID: 12218SB  
A5342

- ND=0; EMPC=0
- ND=0; EMPC=EMPC
- ND=DL/2; EMPC=0
- ND=DL/2; EMPC=EMPC
- ND=DL; EMPC=EMPC



WHO-2005-TEQ  
 Project ID: 12218SB  
 A5342


- ▧ ND=0; EMPC=0
- ▨ ND=0; EMPC=EMPC
- ▩ ND=DL/2; EMPC=0
- ND=DL/2; EMPC=EMPC
- ND=DL; EMPC=EMPC



# Totals

Project ID: 12218SB  
A5342

- Total PCDD/Fs (ND=0; EMPC=0)
- Total PCDD/Fs (ND=0; EMPC=EMPC)
- Total PCDD/Fs (2378-X ND=DL; EMPC=EMPC)




### Mean Recoveries of Extraction Standards (N=5)

Project ID: 12218SB

A5342

○ Mean

○ Std. Dev.




Method Specification Limits: Tetra-Hexa ES: 40-130%, Hepta-Octa ES: 25-130% (F = fail)

# Mean Recoveries of Sampling Standards (N=4)

Project ID: 12218SB

A5342

Mean Std. Dev.




Method Specification Limits: Tetra-Octa SS: 70-130% (F = fail)







**ANALYTICAL PERSPECTIVES**




**ANALYTICAL PERSPECTIVES**



**ANALYTICAL PERSPECTIVES**




**ANALYTICAL PERSPECTIVES**




1 - 84

ANALYTICAL PERSPECTIVES



Method E1 Air Unit 2 PP Outlet - Run 4 A5342\_10783\_DP\_005 (282-916) COPAL

ANALYTICAL PERSPECTIVES




Method E1 Air Unit 2 PP Outlet - Run 4 A5342\_10783\_DP\_005 (282-916) COPAL

# Sample ID: Method Blank A5342

# Method 23

Client Data		Sample Data		Laboratory Data			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	A5342	Date Received:	n/a
Project ID:	12218SB	Weight/Volume:	1	Lab Sample ID	MB1_10783_DF_TLX	Date Extracted:	01-Apr-2013
Date Collected:	n/a	Split:	2	QC Batch No:	10783	Date Analyzed:	05-Apr-2013
				Dilution:	-	Time Analyzed:	21:09:40
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	ND	1.47			ES 2378-TCDD	87.3	
12378-PeCDD	ND	1.51			ES 12378-PeCDD	92.1	
123478-HxCDD	ND	1.18			ES 123478-HxCDD	89.2	
123678-HxCDD	ND	1.19			ES 123678-HxCDD	89.1	
123789-HxCDD	ND	1.29			ES 123789-HxCDD	93.5	
1234678-HpCDD	7.16			J	ES 1234678-HpCDD	89.8	
OCDD	EMPC		17.5	J	ES OCDD	83.8	
2378-TCDF	ND	1.01			ES 2378-TCDF	92	
12378-PeCDF	ND	0.942			ES 12378-PeCDF	93.1	
23478-PeCDF	ND	0.85			ES 23478-PeCDF	94.1	
123478-HxCDF	ND	1.14			ES 123478-HxCDF	89.4	
123678-HxCDF	ND	1.08			ES 123678-HxCDF	90.6	
234678-HxCDF	ND	1.13			ES 234678-HxCDF	88.8	
123789-HxCDF	ND	1.56			ES 123789-HxCDF	90.1	
1234678-HpCDF	2.28			J	ES 1234678-HpCDF	87.6	
1234789-HpCDF	ND	1.76			ES 1234789-HpCDF	89.1	
OCDF	8.03			J	ES OCDF	83.4	
Totals					Standard	SS/AS/FS/TS Recoveries	
Total TCDD	ND	1.47	ND		SS 37C-2378-TCDD	n/a	
Total PeCDD	ND	1.51	ND		SS 12347-PeCDD	n/a	
Total HxCDD	ND	1.22	ND		SS 12346-PeCDF	n/a	
Total HpCDD	10.8		10.8		SS 123469-HxCDF	n/a	
					SS 1234689-HpCDF	n/a	
Total TCDF	ND	1.01	ND		AS 1368-TCDD	89.1	
Total PeCDF	ND	0.895	ND		AS 1368-TCDF	90.5	
Total HxCDF	ND	1.21	ND		FS 1278-TCDD	102	
Total HpCDF	6.52		6.52		FS 12478-PeCDD	97.9	
<b>Total PCDD/Fs</b>	<b>25.4</b>		<b>42.9</b>		FS 123468-HxCDD	102	
					FS 1234679-HpCDD	97.1	
					TS 1378-TCDD	n/a	
ITEF TEQs							
TEQ: ND=0	0.102		0.12				
TEQ: ND=DL/2	1.94	1.86	1.96				
TEQ: ND=DL	3.78	3.71	3.8				



**SGS**



ANALYTICAL PERSPECTIVES

2714 Exchange Drive  
Wilmington, NC 28405, USA  
www.us.sgs.com

Tel: +1 910 794-1613; Toll-Free 866 846-8290; Fax: +1 910 794-3919

1 - 88

# Sample ID: Unit 2 FF Outlet - Field Blank

# Method 23

Client Data		Sample Data		Laboratory Data			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	A5342	Date Received:	28-Mar-2013
Project ID:	12218SB	Weight/Volume:	1	Lab Sample ID:	A5342_10783_DF_001	Date Extracted:	01-Apr-2013
Date Collected:	26-Mar-2013	Split:	2	QC Batch No:	10783	Date Analyzed:	05-Apr-2013
				Dilution:	-	Time Analyzed:	22:02:57
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	ND	2.21			ES 2378-TCDD	82.1	
12378-PeCDD	ND	2.09			ES 12378-PeCDD	86.3	
123478-HxCDD	ND	2.21			ES 123478-HxCDD	83.9	
123678-HxCDD	ND	2.18			ES 123678-HxCDD	79.7	
123789-HxCDD	ND	2.46			ES 123789-HxCDD	83.4	
1234678-HpCDD	9.17			J B	ES 1234678-HpCDD	78.6	
OCDD	19.4			J B	ES OCDD	75.5	
2378-TCDF	ND	1.54			ES 2378-TCDF	89	
12378-PeCDF	ND	1.86			ES 12378-PeCDF	89.9	
23478-PeCDF	ND	1.76			ES 23478-PeCDF	90.7	
123478-HxCDF	ND	1.29			ES 123478-HxCDF	82.1	
123678-HxCDF	ND	1.26			ES 123678-HxCDF	83.1	
234678-HxCDF	ND	1.29			ES 234678-HxCDF	83	
123789-HxCDF	ND	1.95			ES 123789-HxCDF	76.7	
1234678-HpCDF	ND	1.15			ES 1234678-HpCDF	79.5	
1234789-HpCDF	ND	1.93			ES 1234789-HpCDF	79.2	
OCDF	14.8			J B	ES OCDF	74	
Totals					Standard	SS/AS/FS/TS Recoveries	
Total TCDD	ND		4.86		SS 37Cl-2378-TCDD	118	
Total PeCDD	ND	2.09	ND		SS 12347-PeCDD	121	
Total HxCDD	5.02		5.02		SS 12346-PeCDF	114	
Total HpCDD	15.5		15.5		SS 123469-HxCDF	118	
Total TCDF	ND	1.54	ND		SS 1234689-HpCDF	116	
Total PeCDF	ND	1.81	ND		AS 1368-TCDD	85.2	
Total HxCDF	ND	1.42	ND		AS 1368-TCDF	89.5	
Total HpCDF	4.78		4.78		FS 1278-TCDD	104	
<b>Total PCDD/Fs</b>	<b>59.4</b>		<b>64.3</b>		FS 12478-PeCDD	106	
<b>ITEF TEQs</b>					FS 123468-HxCDD	105	
TEQ: ND=0	0.126		0.126		FS 1234679-HpCDD	106	
TEQ: ND=DL/2	2.97	2.86	2.97		TS 1378-TCDD	n/a	
TEQ: ND=DL	5.8	5.71	5.8				



2714 Exchange Drive  
Wilmington, NC 28405, USA  
www.us.sgs.com

Tel: +1 910 794-1613; Toll-Free 866 846-8290; Fax: +1 910 794-3919

I - 87

# Sample ID: Unit 2 FF Outlet - Run 2

# Method 23

Client Data		Sample Data		Laboratory Data			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	A5342	Date Received:	28-Mar-2013
Project ID:	12218SB	Weight/Volume:	1	Lab Sample ID:	A5342_10783_DF_003	Date Extracted:	01-Apr-2013
Date Collected:	26-Mar-2013	Split:	2	QC Batch No:	10783	Date Analyzed:	05-Apr-2013
				Dilution:	-	Time Analyzed:	22:56:20
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	EMPC		11.1		ES 2378-TCDD	85.8	
12378-PeCDD	36.8			J	ES 12378-PeCDD	90	
123478-HxCDD	56.8				ES 123478-HxCDD	84.5	
123678-HxCDD	177				ES 123678-HxCDD	81.1	
123789-HxCDD	77.8				ES 123789-HxCDD	85.1	
1234678-HpCDD	987				ES 1234678-HpCDD	80.7	
OCDD	786				ES OCDD	78.2	
2378-TCDF	EMPC		11.4		ES 2378-TCDF	88.9	
12378-PeCDF	21			J	ES 12378-PeCDF	89.3	
23478-PeCDF	44.5			J	ES 23478-PeCDF	92.3	
123478-HxCDF	33.1			J	ES 123478-HxCDF	83.6	
123678-HxCDF	38.2			J	ES 123678-HxCDF	84.9	
234678-HxCDF	69				ES 234678-HxCDF	84.2	
123789-HxCDF	12.1			J	ES 123789-HxCDF	81.2	
1234678-HpCDF	97.6				ES 1234678-HpCDF	79.9	
1234789-HpCDF	19.3			J	ES 1234789-HpCDF	79.7	
OCDF	43			J B	ES OCDF	76.4	
Totals					Standard	SS/AS/FS/TS Recoveries	
Total TCDD	2570		2600		SS 37Cl-2378-TCDD	117	
Total PeCDD	2740		2770		SS 12347-PeCDD	117	
Total HxCDD	4310		4330		SS 12346-PeCDF	116	
Total HpCDD	1930		1930		SS 123469-HxCDF	118	
					SS 1234689-HpCDF	120	
Total TCDF	744		761		AS 1368-TCDD	87.3	
Total PeCDF	685		695		AS 1368-TCDF	88.7	
Total HxCDF	562		562		FS 1278-TCDD	104	
Total HpCDF	228		228		FS 12478-PeCDD	100	
<b>Total PCDD/Fs</b>	<b>14600</b>		<b>14700</b>		FS 123468-HxCDD	103	
					FS 1234679-HpCDD	102	
<b>ITEF TEQs</b>					TS 1378-TCDD	n/a	
TEQ: ND=0	100		112				
TEQ: ND=DL/2	101	3.96	112				
TEQ: ND=DL	103	7.91	112				



2714 Exchange Drive  
Wilmington, NC 28405, USA  
www.us.sgs.com

Tel: +1 910 794-1613; Toll-Free 866 846-8290; Fax: +1 910 794-3919

# Sample ID: Unit 2 FF Outlet - Run 3

# Method 23

Client Data		Sample Data		Laboratory Data			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	A5342	Date Received:	28-Mar-2013
Project ID:	12218SB	Weight/Volume:	1	Lab Sample ID	A5342_10783_DF_004	Date Extracted:	01-Apr-2013
Date Collected:	26-Mar-2013	Split:	2	QC Batch No:	10783	Date Analyzed:	05-Apr-2013
				Dilution:	-	Time Analyzed:	23:49:44
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	13.8				ES 2378-TCDD	78	
12378-PeCDD	43.7			J	ES 12378-PeCDD	80	
123478-HxCDD	63.2				ES 123478-HxCDD	72.1	
123678-HxCDD	171				ES 123678-HxCDD	73.7	
123789-HxCDD	72.7				ES 123789-HxCDD	74.8	
1234678-HpCDD	1060				ES 1234678-HpCDD	71.9	
OCDD	845				ES OCDD	68	
2378-TCDF	12.9				ES 2378-TCDF	78.6	
12378-PeCDF	19.2			J	ES 12378-PeCDF	79.3	
23478-PeCDF	42.8			J	ES 23478-PeCDF	79.8	
123478-HxCDF	31.3			J	ES 123478-HxCDF	73.3	
123678-HxCDF	38.3			J	ES 123678-HxCDF	73.7	
234678-HxCDF	71.9				ES 234678-HxCDF	73.2	
123789-HxCDF	ND	3.33			ES 123789-HxCDF	72.4	
1234678-HpCDF	96.3				ES 1234678-HpCDF	68.8	
1234789-HpCDF	24			J	ES 1234789-HpCDF	70.9	
OCDF	40.5			J B	ES OCDF	68	
Totals					Standard	SS/AS/FS/TS Recoveries	
Total TCDD	2660		2660		SS 37Cl-2378-TCDD	119	
Total PeCDD	2760		2760		SS 12347-PeCDD	117	
Total HxCDD	4520		4520		SS 12346-PeCDF	116	
Total HpCDD	2070		2070		SS 123469-HxCDF	119	
Total TCDF	743		762		SS 1234689-HpCDF	121	
Total PeCDF	660		660		AS 1368-TCDD	79.5	
Total HxCDF	557		557		AS 1368-TCDF	80.3	
Total HpCDF	260		260		FS 1278-TCDD	99.3	
<b>Total PCDD/Fs</b>	<b>15100</b>		<b>15100</b>		FS 12478-PeCDD	99.2	
<b>ITEF TEQs</b>					FS 123468-HxCDD	105	
TEQ: ND=0	117		117		FS 1234679-HpCDD	97.8	
TEQ: ND=DL/2	117	4.08	117		TS 1378-TCDD	n/a	
TEQ: ND=DL	117	8.16	117				





2714 Exchange Drive  
 Wilmington, NC 28405, USA  
 www.us.sgs.com

Tel: +1 910 794-1613; Toll-Free 866 846-8290; Fax: +1 910 794-3919

1 - 88

# Sample ID: Unit 2 FF Outlet - Run 4

# Method 23

Client Data		Sample Data		Laboratory Data			
Name:	Clean Air Engineering	Matrix:	Air	Lab Project ID:	A5342	Date Received:	28-Mar-2013
Project ID:	12218SB	Weight/Volume:	1	Lab Sample ID:	A5342_10783_DF_005	Date Extracted:	01-Apr-2013
Date Collected:	27-Mar-2013	Split:	2	QC Batch No:	10783	Date Analyzed:	06-Apr-2013
				Dilution:	-	Time Analyzed:	00:43:05
Analyte	Conc. (pg)	DL (pg)	EMPC (pg)	Qualifiers	Standard	ES Recoveries	Qualifiers
2378-TCDD	14.7				ES 2378-TCDD	92.6	
12378-PeCDD	41.8			J	ES 12378-PeCDD	97.7	
123478-HxCDD	64				ES 123478-HxCDD	95.2	
123678-HxCDD	200				ES 123678-HxCDD	90	
123789-HxCDD	85.8				ES 123789-HxCDD	95.1	
1234678-HpCDD	1110				ES 1234678-HpCDD	92.5	
OCDD	847				ES OCDD	88.5	
2378-TCDF	13.4				ES 2378-TCDF	97.8	
12378-PeCDF	21			J	ES 12378-PeCDF	99.5	
23478-PeCDF	45.4			J	ES 23478-PeCDF	102	
123478-HxCDF	31.6			J	ES 123478-HxCDF	92.9	
123678-HxCDF	36.7			J	ES 123678-HxCDF	93.2	
234678-HxCDF	70.9				ES 234678-HxCDF	94.9	
123789-HxCDF	ND	3.71			ES 123789-HxCDF	89.2	
1234678-HpCDF	94.6				ES 1234678-HpCDF	85.8	
1234789-HpCDF	22.7			J	ES 1234789-HpCDF	89.8	
OCDF	38.5			J B	ES OCDF	88.4	
Totals					Standard	SS/AS/FS/TS Recoveries	
Total TCDD	2990		3010		SS 37Cl-2378-TCDD	121	
Total PeCDD	3020		3030		SS 12347-PeCDD	118	
Total HxCDD	4880		4880		SS 12346-PeCDF	114	
Total HpCDD	2170		2170		SS 123469-HxCDF	122	
					SS 1234689-HpCDF	125	
Total TCDF	835		846		AS 1368-TCDD	95	
Total PeCDF	703		709		AS 1368-TCDF	99.2	
Total HxCDF	568		568		FS 1278-TCDD	100	
Total HpCDF	248		248		FS 12478-PeCDD	98.5	
					FS 123468-HxCDD	101	
<b>Total PCDD/Fs</b>	<b>16300</b>		<b>16300</b>		FS 1234679-HpCDD	98.5	
					TS 1378-TCDD	n/a	
<b>ITEF TEQs</b>					  2714 Exchange Drive Wilmington, NC 28405, USA www.us.sgs.com Tel: +1 910 794-1613; Toll-Free 866 846-8290; Fax: +1 910 794-3919		
TEQ: ND=0	123		123				
TEQ: ND=DL/2	123	3.28	123				
TEQ: ND=DL	123	6.56	123				



Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 SDA Inlet

### USEPA Method 26A (HCl) Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2013)		Mar 25	Mar 25	Mar 25
Start Time (approx.)		08:00	09:23	10:54
Stop Time (approx.)		09:00	10:34	11:54

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl<sup>-</sup>/liter) 0.0090

**HCl as Total Chloride**

B<sub>Cl</sub> Blank concentration (mg Cl<sup>-</sup>/liter) <0.0410

S <sub>Cl-1</sub>	Fraction 1 concentration (mg Cl <sup>-</sup> /liter)	1190.0000	986.6000	959.6000
S <sub>Cl-2</sub>	Fraction 2 concentration (mg Cl <sup>-</sup> /liter)			
v <sub>1</sub>	Fraction 1 sample volume (ml)	612.0	644.0	645.0
v <sub>2</sub>	Fraction 2 sample volume (ml)			
m <sub>HCl</sub>	HCl collected before blank subtraction (mg)	748.6718	653.1608	636.2724
m <sub>b</sub>	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m <sub>nb</sub>	HCl collected after blank subtraction (mg)	748.6718	653.1608	636.2724
m <sub>MDL</sub>	Minimum detectable HCl (mg)	0.0057	0.0060	0.0060
m <sub>n</sub>	Total HCl used in emission calculations (mg)	748.6718	653.1608	636.2724

042313 085712  
 @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 1 FF Outlet

### USEPA Method 26A (HCl) Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2013)		Mar 25	Mar 25	Mar 25
Start Time (approx.)		08:00	09:23	10:54
Stop Time (approx.)		09:00	10:34	11:54

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl<sup>-</sup>/liter) 0.0090

**HCl as Total Chloride**  
 B<sub>Cl</sub> Blank concentration (mg Cl<sup>-</sup>/liter) <0.0410

S <sub>Cl-1</sub>	Fraction 1 concentration (mg Cl <sup>-</sup> /liter)	1.1200	1.2400	3.8400
S <sub>Cl-2</sub>	Fraction 2 concentration (mg Cl <sup>-</sup> /liter)			
v <sub>1</sub>	Fraction 1 sample volume (ml)	773.0	695.0	745.0
v <sub>2</sub>	Fraction 2 sample volume (ml)			
m <sub>HCl</sub>	HCl collected before blank subtraction (mg)	0.8900	0.8859	2.9409
m <sub>b</sub>	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m <sub>nb</sub>	HCl collected after blank subtraction (mg)	0.8900	0.8859	2.9409
m <sub>MDL</sub>	Minimum detectable HCl (mg)	0.0072	0.0064	0.0069
m <sub>n</sub>	Total HCl used in emission calculations (mg)	0.8900	0.8859	2.9409

042313 085723  
 @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 2 SDA Inlet

### USEPA Method 26A (HCl) Chloride Laboratory Data Summary

Run No.	Blank	1	2
Date (2013)		Mar 27	Mar 27
Start Time (approx.)		07:47	09:08
Stop Time (approx.)		08:47	10:08

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl<sup>-</sup>/liter) 0.0090

**HCl as Total Chloride**

B<sub>Cl</sub> Blank concentration (mg Cl<sup>-</sup>/liter) <0.0410

S <sub>Cl-1</sub>	Fraction 1 concentration (mg Cl <sup>-</sup> /liter)	1185.0000	1045.0000	
S <sub>Cl-2</sub>	Fraction 2 concentration (mg Cl <sup>-</sup> /liter)			
v <sub>1</sub>	Fraction 1 sample volume (ml)	673.0	696.0	
v <sub>2</sub>	Fraction 2 sample volume (ml)			
m <sub>HCl</sub>	HCl collected before blank subtraction (mg)	819.8351	747.6850	
m <sub>b</sub>	Allowable blank subtraction (mg)	0.0000	0.0000	
m <sub>nb</sub>	HCl collected after blank subtraction (mg)	819.8351	747.6850	
m <sub>MDL</sub>	Minimum detectable HCl (mg)	0.0062	0.0064	
m <sub>n</sub>	Total HCl used in emission calculations (mg)	819.8351	747.6850	

042313 085959  
 @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 2 FF Outlet

### USEPA Method 26A (HCl) Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2013)		Mar 27	Mar 27	Mar 27
Start Time (approx.)		07:47	09:08	10:27
Stop Time (approx.)		08:47	10:08	11:27

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl<sup>-</sup>/liter)

**HCl as Total Chloride**

B<sub>Cl</sub> Blank concentration (mg Cl<sup>-</sup>/liter)

S <sub>Cl-1</sub> Fraction 1 concentration (mg Cl <sup>-</sup> /liter)	14.3900	14.5200	13.2800
S <sub>Cl-2</sub> Fraction 2 concentration (mg Cl <sup>-</sup> /liter)			
v <sub>1</sub> Fraction 1 sample volume (ml)	689.0	647.0	692.0
v <sub>2</sub> Fraction 2 sample volume (ml)			
m <sub>HCl</sub> HCl collected before blank subtraction (mg)	10.1923	9.6575	9.4471
m <sub>b</sub> Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m <sub>nb</sub> HCl collected after blank subtraction (mg)	10.1923	9.6575	9.4471
m <sub>MDL</sub> Minimum detectable HCl (mg)	0.0064	0.0060	0.0064
m <sub>n</sub> Total HCl used in emission calculations (mg)	10.1923	9.6575	9.4471

042313 090012  
 @

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 3 SDA Inlet

### USEPA Method 26A (HCl) Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2013)		Mar 26	Mar 26	Mar 26
Start Time (approx.)		08:00	09:21	10:46
Stop Time (approx.)		09:00	10:21	11:46

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl<sup>-</sup>/liter) 0.0090

**HCl as Total Chloride**  
 B<sub>Cl</sub> Blank concentration (mg Cl<sup>-</sup>/liter) <0.0410

S <sub>Cl-1</sub>	Fraction 1 concentration (mg Cl <sup>-</sup> /liter)	1024.0000	972.9000	941.0000
S <sub>Cl-2</sub>	Fraction 2 concentration (mg Cl <sup>-</sup> /liter)			
v <sub>1</sub>	Fraction 1 sample volume (ml)	600.0	643.0	646.0
v <sub>2</sub>	Fraction 2 sample volume (ml)			
m <sub>HCl</sub>	HCl collected before blank subtraction (mg)	631.6032	643.0908	624.9068
m <sub>b</sub>	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m <sub>nb</sub>	HCl collected after blank subtraction (mg)	631.6032	643.0908	624.9068
m <sub>MDL</sub>	Minimum detectable HCl (mg)	0.0056	0.0059	0.0060
m <sub>n</sub>	Total HCl used in emission calculations (mg)	631.6032	643.0908	624.9068

042313 090206  
 ©

Wheelabrator South Broward, Inc.  
 Clean Air Project No: 12218  
 Unit 3 FF Outlet

### USEPA Method 26A (HCl) Chloride Laboratory Data Summary

Run No.	Blank	1	2	3
Date (2013)		Mar 26	Mar 26	Mar 26
Start Time (approx.)		08:00	09:21	10:46
Stop Time (approx.)		09:00	10:21	11:46

DRAFT LAB DATA

MDL Min. detectable limit (mg Cl<sup>-</sup>/liter) 0.0090

**HCl as Total Chloride**

B<sub>Cl</sub> Blank concentration (mg Cl<sup>-</sup>/liter) <0.0410

S <sub>Cl-1</sub>	Fraction 1 concentration (mg Cl <sup>-</sup> /liter)	17.6600	17.5000	19.7000
S <sub>Cl-2</sub>	Fraction 2 concentration (mg Cl <sup>-</sup> /liter)			
v <sub>1</sub>	Fraction 1 sample volume (ml)	709.0	734.0	678.0
v <sub>2</sub>	Fraction 2 sample volume (ml)			
m <sub>HCl</sub>	HCl collected before blank subtraction (mg)	12.8715	13.2047	13.7306
m <sub>b</sub>	Allowable blank subtraction (mg)	0.0000	0.0000	0.0000
m <sub>nb</sub>	HCl collected after blank subtraction (mg)	12.8715	13.2047	13.7306
m <sub>MDL</sub>	Minimum detectable HCl (mg)	0.0066	0.0068	0.0063
m <sub>n</sub>	Total HCl used in emission calculations (mg)	12.8715	13.2047	13.7306

042313 084740  
 @



---

**LABORATORY ANALYSIS FOR ANIONS**  
**Laboratory Services Report No: 64-28960\_IC\_CL\_V0**

Performed for:  
**PALATINE SOURCE TESTING**  
500 West Wood St  
Palatine IL, 60067

Pertaining to a Field Sampling Project Performed for :  
**WHEELABRATOR SOUTH BROWARD**

Customer Reference No: 12218  
Laboratory Services Project No: 28960  
Revision 0: 4/12/13

---

To the best of our knowledge, the laboratory results presented in this report are accurate, complete, error free, legible and representative of the samples per the analysis described here-in.

Submitted by,

Digitally signed  
by Eric Ewing  
Date: 2013.04.12  
16:39:04 -05'00'

Reviewed by,

Digitally signed  
by Michael Tuegel  
Date: 2013.04.12  
16:50:31 -05'00'

---

Eric Ewing  
Title: Analyst – Laboratory Services  
Ph: 847-654-4519  
Email: eewing@cleanair.com

---

Michael Tuegel  
Title: Quality Leader – Laboratory Services  
Ph: 847-654-4557  
Email: mtuegel@cleanair.com

**REVISION HISTORY**

**LABORATORY ANALYSIS FOR ANIONS**  
**LABORATORY Services Report No: 64-28960\_IC\_CI\_V0**

**FINAL REPORT REVISION HISTORY**

Revision:	Date	Pages	Comments
0	4/12/13	All	Final version of original document.



**CONTENTS**

**1 CERTIFICATE OF ANALYSIS..... 1-1**

**2 ANALYTICAL CASE NARRATIVE..... 2-1**

INTRODUCTION..... 2-1

    Key Project Participants ..... 2-1

        Table 2-2: Pertinent Personnel..... 2-1

    Accreditation ..... 2-1

        Table 2-3: Specific Accreditations and Expiration Dates ..... 2-1

DISCUSSION OF ANALYTICAL RESULTS..... 2-2

    Table 2-4: Statistical Description of the Ion Chromatography Results. .... 2-2

**3 METHODOLOGY..... 3-1**

    Table 3-2: List of Analytical Methodology..... 3-1

    Analytical Procedures Common To All Methods ..... 3-2

        Sample Preparation ..... 3-2

        Sample Volumes ..... 3-2

        Sample Analysis..... 3-2

        Detection Limits..... 3-2

        Instrument Calibration ..... 3-3

        Quality Control Procedures ..... 3-3

        Standard and Reagent Traceability ..... 3-4

        Project Archival ..... 3-5

        Reporting Abbreviations ..... 3-5

**4 APPENDIX..... 4-1**

    SAMPLE CALCULATIONS..... I

    RAW DATA ..... II

    QUALITY ASSURANCE RECORDS ..... III

    CHAIN-OF-CUSTODY DOCUMENTATION..... IV

    DETECTION LIMIT DETERMINATION DATA ..... V

    EQUIPMENT CALIBRATION RECORDS ..... VI

    STANDARD PREPARATION RECORDS ..... VII

    BATCH LOG SHEETS..... VIII

    CHROMATOGRAMS..... IX

**CERTIFICATE OF ANALYSIS**

1-1

Laboratory Sample Identification Number	Sample Identification	Sample Volume (mL)	Chloride Sample Conc. (mg/L)
Reagent Blanks			
28959-001	DI H2O RB	300	<
28959-002	0.1N H2SO4 RB	340	<
U1 SDA Inlet			
28959-003	Imp C&R R1	612	1,190
28959-004	Imp C&R R2	644	986.6
28959-005	Imp C&R R3	645	959.6
U1 FF Outlet			
28959-006	Imp C&R R1	773	1.12
28959-007	Imp C&R R2	695	1.24
28959-008	Imp C&R R3	745	3.84
U2 SDA Inlet			
28959-009	Imp C&R R1	673	1,185
28959-010	Imp C&R R2	696	1,045
U2 FF Outlet			
28959-011	Imp C&R R1	689	14.39
28959-012	Imp C&R R2	647	14.52
28959-013	Imp C&R R3	692	13.28
U3 SDA Inlet			
28959-014	Imp C&R R1	600	1,024
28959-015	Imp C&R R2	643	972.9
28959-016	Imp C&R R3	646	941.0
U3 FF Outlet			
28959-017	Imp C&R R1	709	17.66
28959-018	Imp C&R R2	734	17.50
28959-019	Imp C&R R3	678	19.70

Method Detection Limit (mg/L): 0.009

Limit of Quantitation (mg/L): 0.041

*End of Section 1 – Certificate of Analysis*

**ANALYTICAL CASE NARRATIVE**

2-1

**INTRODUCTION**

Palatine Source Testing contracted Clean Air Engineering Laboratory Services (Laboratory Services) to determine the following:

- Chloride Content

All analyses were performed on samples received by the Laboratory Services at their facility in Palatine, IL. All analyses were performed in accordance with the applicable EPA Method requirements along with all NELAP quality requirements as outlined and described in Section 3 of this report.

This report shall in no way be reproduced except in full without the prior written approval of Clean Air Laboratory Services.

**Key Project Participants**

Samples were received at Clean Air Engineering Laboratory Services facility on 4/1/13. The following is a table of key personnel involved:

**Table 2-2:  
Pertinent Personnel**

Technician	Affiliation	Function
S. Brown	Palatine Source Testing	Custody Relinquished
E. Ewing	Laboratory Services	Sample Receipt
E. Ewing	Laboratory Services	Lead Analyst
S. Brown	Palatine Source Testing	Project Manager

**Accreditation**

Clean Air Laboratory Services is accredited through the following state agencies.

**Table 2-3:  
Specific Accreditations and Expiration Dates**

State	Certificate Number	Expiration Date
Texas	T104704431-12-3	8/31/2013
Louisiana	169249	6/30/2013
New Jersey	IL004	6/30/2013

Please visit the respective state websites to view our current accreditation status and a comprehensive list of our accredited services.

**ANALYTICAL CASE NARRATIVE**

2-2

**DISCUSSION OF ANALYTICAL RESULTS**

Table 2-4 shown below, presents the average amounts of chloride found for each sample fraction. Also shown are the standard deviations (SD) and percent relative standard deviations (RSD). These data are not corrected for plant conditions or sampling volumes.

**Table 2-4:  
 Statistical Description of the Ion Chromatography Results.**

Sample Fraction	Location	Average Concentration (mg/L)	Standard Deviation of Concentration (mg/L)	Relative Standard Deviation of Concentration (%)
Imp C&R	U1 SDA Inlet	1045	126	12.05%
Imp C&R	U1 FF Outlet	2.07	1.54	74.53%
Imp C&R	U2 SDA Inlet	1115	98.5	8.84%
Imp C&R	U2 FF Outlet	14.06	0.68	4.82%
Imp C&R	U3 SDA Inlet	979.2	41.8	4.27%
Imp C&R	U3 FF Outlet	18.29	1.22	6.70%

*End of Section 2 – Analytical Case Narrative*

**METHODOLOGY**

3-1

Laboratory Services followed procedures as detailed in U.S. EPA Method 26A and U.S. EPA Method 300.1. Table 3-2, below summarizes the methods and their respective sources.

**Table 3-2:  
List of Analytical Methodology**

---

Title 40 CFR Part 60 Appendix A

U.S. EPA Method 26A "Determination of Hydrogen Halide and Halogen Emissions From Stationary Sources Non-Isokinetic Method"

Methods for the Determination of Organic and Inorganic Compounds in Drinking Water, Volume 1  
(EPA/815-R-00-014)

U.S. EPA Method 300.1 "Determination of Inorganic Anions In Drinking Water By Ion Chromatography"

---

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and are located on the internet at <http://ecfr.gpoaccess.gov>.

Laboratory Services followed specific quality assurance and quality control (QA/QC) procedures as outlined in the individual methods and as prescribed in Laboratory Services' internal Quality Manual. Results of recorded QA/QC activities performed by Laboratory Services are summarized in Appendix III.

**METHODOLOGY**

3-2

**Analytical Procedures Common To All Methods**

**Sample Preparation**

- Samples were prepared according to the procedures listed in the EPA Method above. Each sample was analyzed at full strength and a dilution was prepared if necessary to achieve a concentration that was within calibration range limits.

**Sample Volumes**

- Samples 28960-001 and 28960-002 did not have a sample volume recorded at the time of sample receipt. The sample volume was measured using a serialized Class A graduated cylinder (S/N 0591). All other sample volumes were determined by field personnel.

**Sample Analysis**

- All analyses were carried out using a Dionex Model ICS-90 ion chromatograph. In ion chromatography, the sample is moved through a static phase (the column) by a mobile phase (the eluent solution). The different components of the mixture can swap from one phase to another, but the rate of this migration will depend on the affinity of each component for the stationary phase. Therefore, different affinities will make components need different times to go through the same length of stationary phase. This time is one of the two characteristic data given by chromatography, and is known as retention time. The other important data is the peak area. A specific analyte is identified by its characteristic retention time. The concentration is determined by instrument response as the peak area count.
- The stationary phase for this work consisted of a Dionex Model AS14A anion column. The mobile phase consisted of an 8.0mM/1.0mM sodium carbonate/bicarbonate eluent solution.
- The instrument response is determined by measuring the conductivity of the mobile phase. In ion chromatography, the mobile phase usually contains ions that create background conductivity, making it difficult to measure the conductivity due only to the analyte ions as they exit the column. This problem is greatly reduced by selectively removing the mobile phase ions after the analytical column and before the detector. This is done with an eluent suppressor, which consists of an ion-exchange membrane. For anion analysis, the mobile phase is Na<sub>2</sub>CO<sub>3</sub>/NaHCO<sub>3</sub>, and the eluent suppressor supplies H<sup>+</sup> to neutralize the anion and remove other ions opposite in charge of the specific analyte. For this analysis, background ionic suppression is removed using a 40 mN sulfuric acid regenerant.

**Detection Limits**

- The Method Detection Limit (MDL) was determined in accordance with procedures in 40 CFR 136, Appendix B. Documentation showing the determination of detection limits is included with this report. The Limit of Quantitation (LOQ) is set to be the concentration of the lowest calibration point for each analyte. Values between these limits were quantified, but should be

**METHODOLOGY**

3-3

used with discretion as they were below the LOQ. Values that were below the MDL were indicated by a "<" where appropriate.

**Instrument Calibration**

- Instrument calibration followed regulations found in U.S. EPA Method 300.1 and U.S. EPA Method 26A.
- Calibration standards were prepared from ACS grade, or better, dry salts as per section 7.3 of U.S. EPA Method 300.1.
- As per section 4.2.2 of U.S. EPA CTM-027, a series of 6 diluted standards were prepared from the original calibration standard and run through the column in duplicate from lowest to highest concentration.
- The average peak area for each calibration point is plotted against the expected solution concentration.
- In accordance with section 7.2.3 of U.S. EPA Method 9057, a least-squares regression with an R<sup>2</sup> value of 0.995 or greater must be produced from the resulting curve.
- In accordance with U.S. EPA Method 26, a full post-test calibration was performed. The pre-test and post-test calibration average peak area for any standard must agree within 5% of any observed area.
- All calibration standards were prepared in a deionized water matrix. This is a deviation from U.S. EPA Method 26A which states that calibration standards are to be prepared in the same matrix as the samples. Documentation showing the validity of this deviation is available upon request.

**Quality Control Procedures**

Clean Air adheres to QA/QC procedures that both meet and exceed EPA requirements.

- Before the first sample was analyzed and every twenty samples thereafter, a Quality Control (QC) sample was analyzed. The QC sample was created using ACS grade or better dry salts from a different manufacturer and or lot number than the salts used to create the calibration standards. The QC must show a regression concentration within 10 percent of the expected concentration.
- After the first ten samples were analyzed and every twenty samples thereafter (and before the post-test calibration) a laboratory blank and a Continuing Calibration Verification (CCV) were analyzed. The CCV was prepared from the same calibration standard as used to create the 8 standards that make up the calibration curve. The laboratory blank must show a regression concentration of zero, and the CCV must show a regression concentration within 10 percent of the expected concentration.
- A matrix spike analysis was performed on ten percent of the total number of samples. This sample was prepared with equal amounts of sample and a calibration standard whose concentration was known to be larger than that of the sample. The matrix spike is acceptable when the recovery is found to be 100 ± 10 percent

**METHODOLOGY**

3-4

- As a measure of precision, 20% of all matrix spikes were prepared and analyzed in duplicate. The average area count of two identical matrix spikes may not have a relative percent difference of more than 10 percent.
- Every sample was analyzed in duplicate and the mean area count used to determine the concentration. The duplicate area counts must not have a relative difference of more than five percent. In the event that the relative difference is more than five percent, the sample was reanalyzed in duplicate until a duplicate relative difference of less than five percent is obtained.
- Each point on the calibration curve should be within  $\pm 2$  percent of the calibration span of the curve used
- The observed concentration value of each point on the calibration curve should have a relative percent difference of 10 percent from its expected concentration.

**Standard and Reagent Traceability**

- Each calibration standard has been prepared in accordance with U.S. EPA Method 300.1 and U.S. EPA Method 26A and has been designated an original lot number. This number can be used to trace back to the original dry salts used in the preparation of these standards. These lot numbers are found in Table 3-3, below.

**Table 3-3:  
Standard Lot Numbers Used For Analysis**

Standard Type	Lot Number	Concentration of Analyte
Stock Standard	03201302-64-00000-01	1014.41 mg/L
QC Standard	03201302-64-00000-02	205.37 mg/L
Working Standard	03201302-64-00000-03	10.14 mg/L
Cal 01	03201302-64-00000-04	0.04 mg/L
Cal 02	03201302-64-00000-05	0.20 mg/L
Cal 03	03201302-64-00000-06	0.41 mg/L
Cal 04	03201302-64-00000-07	1.27 mg/L
Cal 05	03201302-64-00000-08	1.62 mg/L
Cal 06	03201302-64-00000-09	2.54 mg/L
CCV	03201302-64-00000-10	0.81 mg/L
QC	03201302-64-00000-11	1.03 mg/L

In suppressed ion chromatography, eluent is defined as the carrier that moves chemicals through the column and regenerant is defined as a reagent used to remove ions opposite in charge of the specific analyte while reducing the overall conductivity of the eluent. Table 3-4 displays the lot numbers of these reagents used for each day of analysis.



**METHODOLOGY**

3-5

**Table 3-4:  
Eluent and Regenerant Lot Numbers Used for Each Day of Analysis**

Analysis Date	Eluent Lot Number	Regenerant Lot Number
3/29/2013	1046-64-00000-01	1200-64-00000-01
4/1/2013	1046-64-00000-01	1200-64-00000-01
4/2/2013	1046-64-00000-01	1200-64-00000-01
4/3/2013	1046-64-00000-01	1200-64-00000-01
4/4/2013	1046-64-00000-02	1200-64-00000-01
4/5/2013	1046-64-00000-02	1200-64-00000-01

**Project Archival**

- A copy of this report and all associated supporting records will be archived and stored for at least 20 years.
- All samples are archived for a period of one year from the date of receipt in our facility.
- The archival facility is a controlled access storage facility that does not incorporate any environmental controls.
- Ion chromatography samples are archived in the following manner:
  - All samples are stored in the original sample container
  - Any digestates or reconstitutions are stored in an adequately sized container

**Reporting Abbreviations**

- 1 RB: Reagent Blank
- 2 Imp C&R: Impinger Catch and Rinse

*End of Section 3 – Methodology*

**APPENDIX**

4-1

SAMPLE CALCULATIONS.....	I
RAW DATA .....	II
QUALITY ASSURANCE RECORDS .....	III
CHAIN-OF-CUSTODY DOCUMENTATION.....	IV
DETECTION LIMIT DETERMINATION DATA .....	V
EQUIPMENT CALIBRATION RECORDS .....	VI
STANDARD PREPARATION RECORDS .....	VII
BATCH LOG SHEETS .....	VIII
CHROMATOGRAMS.....	IX

*CleanAir*

PALATINE SOURCE TESTING  
WHEELABRATOR SOUTH BROWARD

Customer Reference No: 12218  
Laboratory Services Project No: 28960

**SAMPLE CALCULATIONS**

i

**Sample Calculations**  
Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

Calibration Point No: Cal 02  
Sample No: 28959-003  
Sample Location: U1 SDA Inlet

1. Difference between duplicate injections for pre-test calibration (Pre Cal 1).

$$\Delta_{Injection} = |Area_{Trial\ 2} - Area_{Trial\ 1}|$$

Where:

$\Delta_{Injection}$  = Area count difference between duplicate injections

$Area_{Trial2}$  = Area count for injection Trial 2

$Area_{Trial1}$  = Area count for injection Trial 1

$$\Delta_{Injection} = 0.0009$$

$$Area_{Trial2} = 0.0422$$

$$Area_{Trial1} = 0.0413$$

2. Average area count value for duplicate injections for pre-test calibration (Pre Cal 1).

$$Avg_{PreInj} = \frac{(Area_{Trial1} + Area_{Trial2})}{2}$$

Where:

$Avg_{PreInj}$  = Average of duplicate injection area counts

$Area_{Trial2}$  = Area count for injection Trial 2

$Area_{Trial1}$  = Area count for injection Trial 1

2 = Constant (number of values)

$$Avg_{Inj} = 0.0418$$

$$Area_{Trial2} = 0.0422$$

$$Area_{Trial1} = 0.0413$$

### Sample Calculations

#### Ion Chromatography Analysis

Customer: Palatine Source Testing	Lab Project No: 28959	Analyst: Eric Ewing
Plant: Wheelabrator South Broward	Customer Reference No: 12218	Received: 4/1/13
Applicable Analytical Method: U.S. EPA Method 26A	Analyte: Chloride	

Calibration Point No: Cal 02

Sample No: 28959-003

Sample Location: U1 SDA Inlet

#### 3. Difference between individual injection and average area count for pre-test calibration.

$$\Delta_{PreMean\%} = \frac{|Area_{Trial2} - Avg_{PreInj}|}{Avg_{PreInj}} 100$$

Where:

$\Delta_{PreMean\%}$  = Difference between individual injection and average area count (%).

$Avg_{PreInj}$  = Average of duplicate injection area counts

$Area_{Trial2}$  = Area count for injection Trial 2

100 = Constant (conversion factor for percentage)

$$\Delta_{PreMean\%} = 1.0664$$

$$Avg_{PreInj} = 0.0418$$

$$Area_{Trial2} = 0.0422$$

Note: EPA Method 26 requires  $\Delta_{PreMean\%}$  to be less than 5%.

#### 4. Average of all area count values for a given calibration point.

$$\bar{X} = \frac{\sum_{i=1}^n x_i}{n}$$

Where:

$\bar{X}$  = Average of all area count values for a given calibration point.

$x_i$  = Individual area count values for each individual injection.

$i$  = Iteration value.

$n$  = Number of injections for the calibration point under question.

$$\bar{X} = 0.0425$$

$$x_1 = 0.0413$$

$$x_2 = 0.0422$$

$$n = 8$$

**Sample Calculations**  
Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

Calibration Point No: Cal 02  
Sample No: 28959-003  
Sample Location: U1 SDA Inlet

5. Average of all concentration values used for generating calibration curve.

$$\overline{Y}_{All} = \frac{\sum_{i=1}^n y_i}{n}$$

Where:

- $\overline{Y}_{All}$  = Average of all area concentration values.
- $y_i$  = Individual concentration values for each individual injection.
- $n$  = Number of injections.

$\overline{Y}_{All}$	=	0.8680
$y_1$	=	0.0000
$y_2$	=	0.0406
$n$	=	7

6. Average of all area count values for the calibration curve.

$$\overline{X}_{All} = \frac{\sum_{i=1}^n x_i}{n}$$

Where:

- $\overline{X}_{All}$  = Average of all area count values.
- $x_i$  = Individual area count values.
- $i$  = Iteration value.
- $n$  = Number of injections.

$\overline{X}_{All}$	=	0.2065
$x_1$	=	0.0413
$x_2$	=	0.0422
$n$	=	38

### Sample Calculations

#### Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

Calibration Point No: Cal 02  
 Sample No: 28959-003  
 Sample Location: U1 SDA Inlet

#### 7. Determination of slope (least-squares regression) value for calibration curve.

$$m = \frac{\sum_{i=1}^n (x_i - \bar{x})(y_i - \bar{y})}{\sum_{i=1}^n (x_i - \bar{x})^2}$$

Where:

- m = Slope of least-squares regression curve.
- $x_i$  = Individual area count values for each individual injection.
- $\bar{x}$  = Average of all area count values =  $\bar{X}_{All}$
- $y_i$  = Actual area concentration values for each individual injection.
- $\bar{y}$  = Average of all concentration values =  $\bar{Y}_{All}$
- i = Iteration value.
- n = Number of injections.

m	=	4.65230
$x_1$	=	0.0413
$x_2$	=	0.0422
$\bar{x}$	=	0.2065
$y_1$	=	0.0000
$y_2$	=	0.0406
$\bar{y}$	=	0.8680
n	=	38

#### 8. Determination of y-intercept (least-squares regression) value for calibration curve.

$$b = \bar{y} - m \bar{x}$$

Where:

- b = Y-axis intercept.
- $\bar{x}$  = Average of all area count values =  $\bar{X}_{All}$
- $\bar{y}$  = Average of all concentration values =  $\bar{Y}_{All}$

b	=	0.00637
m	=	4.65230
$\bar{x}$	=	0.2065
$\bar{y}$	=	0.8680

**Sample Calculations**  
Ion Chromatography Analysis

Customer: Palatine Source Testing	Lab Project No: 28959	Analyst: Eric Ewing
Plant: Wheelabrator South Broward	Customer Reference No: 12218	Received: 4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A	Analyte: Chloride

Calibration Point No: Cal 02  
Sample No: 28959-003  
Sample Location: U1 SDA Inlet

9. Determination of coefficient of correlation (least-squares regression) value for calibration curve.

$$r = \frac{\sum_{i=1}^n (x_i - \bar{x})(y_i - \bar{y})}{\sqrt{\sum_{i=1}^n (x_i - \bar{x})^2 \sum_{i=1}^n (y_i - \bar{y})^2}}$$

Where:

- $r^2$  = Square of the Pearson product moment correlation coefficient through data points in known y's and known x's.
- $r$  = Pearson product moment correlation coefficient through data points in known y's and known x's.
- $x_i$  = Individual area count values for each individual injection.
- $y_i$  = Actual area concentration values for each individual injection.
- $\bar{x}$  = Average of all area count values =  $\bar{X}_{All}$
- $\bar{y}$  = Average of all concentration values =  $\bar{Y}_{All}$
- $l$  = Iteration value.
- $n$  = Number of injections.

- $r^2$  = 0.99997
- $r$  = 0.99998
- $x_1$  = 0.0413
- $x_2$  = 0.0422
- $\bar{x}$  = 0.2065
- $y_1$  = 0.0000
- $y_2$  = 0.0406
- $\bar{y}$  = 0.8680
- $n$  = 38



**Sample Calculations**  
Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

Calibration Point No: Cal 02  
Sample No: 28959-003  
Sample Location: U1 SDA Inlet

10. Determination of average sample area counts from duplicate injections.

$$Avg_{Sample} = \frac{(Area_{Trial1} + Area_{Trial2})}{2}$$

Where:

Avg<sub>Sample</sub> = Average of duplicate injection area counts  
Area<sub>Trial2</sub> = Area count for injection Trial 2  
Area<sub>Trial1</sub> = Area count for injection Trial 1  
2 = Constant (number of injections)

Avg<sub>Inj</sub> = 0.2545  
Area<sub>Trial2</sub> = 0.2592  
Area<sub>Trial1</sub> = 0.2497

11. Difference between duplicate injections for the sample.

$$\Delta_{Injection} = |Area_{Trial2} - Area_{Trial1}|$$

Where:

$\Delta_{Injection}$  = Area count difference between duplicate injections  
Area<sub>Trial2</sub> = Area count for injection Trial 2  
Area<sub>Trial1</sub> = Area count for injection Trial 1

$\Delta_{Injection}$  = 0.0095  
Area<sub>Trial2</sub> = 0.2592  
Area<sub>Trial1</sub> = 0.2497

### Sample Calculations Ion Chromatography Analysis

Customer: Palatine Source Testing	Lab Project No: 28959	Analyst: Eric Ewing
Plant: Wheelabrator South Broward	Customer Reference No: 12218	Received: 4/1/13
Applicable Analytical Method: U.S. EPA Method 26A	Analyte: Chloride	

Calibration Point No: Cal 02  
Sample No: 28959-003  
Sample Location: U1 SDA Inlet

#### 12. Difference between individual injection and average area count for the sample.

$$\Delta_{Injection} = \frac{|Area_{Trial2} - Avg_{Inj}|}{Avg_{Inj}} 100$$

Where:

- $\Delta_{Injection}$  = Difference between individual injection and average area count (%).
- $Avg_{Inj}$  = Average of duplicate injection area counts
- $Area_{Trial2}$  = Area count for injection Trial 2
- 100 = Constant (conversion factor for percentage)

$$\begin{aligned} \Delta_{Injection} &= 1.9\% \\ Avg_{Inj} &= 0.2545 \\ Area_{Trial2} &= 0.2592 \end{aligned}$$

Note: EPA Method 26 requires  $\Delta_{Injection}$  to be less than 5%.

#### 13. Determination of sample concentration from least-squares regression curve (mg/L).

$$C_{Reg} = DF [m(Avg_{Inj}) + b]$$

Where:

- $C_{Reg}$  = Sample concentration determined using the regression curve (mg/L)
- DF = Sample dilution factor
- $Avg_{Inj}$  = Average of duplicate injection area counts.
- m = Slope of least-squares regression curve.
- b = Y-intercept of least-squares regression curve.

$$\begin{aligned} C_{Reg} &= 1190.15 \\ DF &= 1000 \\ Avg_{Inj} &= 0.2545 \\ m &= 4.6523 \\ b &= 0.0064 \end{aligned}$$

### Sample Calculations

#### Ion Chromatography Analysis

Customer: Palatine Source Testing	Lab Project No: 28959	Analyst: Eric Ewing
Plant: Wheelabrator South Broward	Customer Reference No: 12218	Received: 4/1/13
Applicable Analytical Method: U.S. EPA Method 26A		Analyte: Chloride

Calibration Point No: Cal 02

Sample No: 28959-003

Sample Location: U1 SDA Inlet

## 14. Determination of total amount of analyte in sample (total mg).

$$M_{Analyte} = \frac{(C_{Reg})(V_{Soln})}{1000}$$

Where:

- $M_{Analyte}$  = Amount of analyte in sample (total mg)  
 $C_{Reg}$  = Sample concentration determined using the response factor (mg/L)  
 $V_{Soln}$  = Sample volume (ml)  
 1000 = Conversion constant (ml to L)

$$\begin{aligned}
 M_{Analyte} &= 728.37 \\
 C_{Reg} &= 1190.1458 \\
 V_{Soln} &= 612.0
 \end{aligned}$$

## 15. Determination of Detection Limits.

## 15a. Determination of average spike result.

$$AvgM_{f_i} = \frac{\sum_{i=1}^n M_{f_i}}{n}$$

Where:

- $AvgM_{f_i}$  = Average of spike result (mg/L)  
 $M_{f_i}$  = Net results recorded for each iteration (mg/L)  
 $n$  = Number of iterations.  
 $i$  = Placeholder for iteration.

$$\begin{aligned}
 AvgM_{f_i} &= 0.044 \\
 M_{f_1} &= 0.049 & M_{f_5} &= 0.043 \\
 M_{f_2} &= 0.049 & M_{f_6} &= 0.042 \\
 M_{f_3} &= 0.041 & M_{f_7} &= 0.043 \\
 M_{f_4} &= 0.043 & M_{f_8} &= 0.043 \\
 n &= 8
 \end{aligned}$$

**Sample Calculations**  
Ion Chromatography Analysis

Customer: Palatine Source Testing	Lab Project No: 28959	Analyst: Eric Ewing
Plant: Wheelabrator South Broward	Customer Reference No: 12218	Received: 4/1/13
Applicable Analytical Method: U.S. EPA Method 26A		Analyte: Chloride

Calibration Point No: Cal 02  
Sample No: 28959-003  
Sample Location: U1 SDA Inlet

15b. Determination of standard deviation of spike result.

$$\sigma_{f-i} = \sqrt{\frac{\sum_{i=1}^n (M_{f-i} - AvgM_{f-i})^2}{(n-1)}}$$

Where:

- $\sigma_{f-i}$  = Standard deviation of spike result.
- $AvgM_{f-i}$  = Average spike result (mg/L)
- $M_{f-i}$  = Concentration recorded for each iteration (mg/L)
- $n$  = Number of iterations.
- $i$  = Placeholder for iteration.

$\sigma_{f-i}$	=	0.0031		
$AvgM_{f-i}$	=	0.044		
$M_{f-1}$	=	0.049	$M_{f-5}$	= 0.043
$M_{f-2}$	=	0.049	$M_{f-6}$	= 0.042
$M_{f-3}$	=	0.041	$M_{f-7}$	= 0.043
$M_{f-4}$	=	0.043	$M_{f-8}$	= 0.043
$n$	=	8		

15c. Determination of variance of spike result.

$$V_{f-i} = (\sigma_{f-i})^2$$

Where:

- $V_{f-i}$  = Variance of spike result.
- $\sigma_{f-i}$  = Standard deviation of spike result.

$V_{f-i}$	=	9.49E-06
$\sigma_{f-i}$	=	0.0031

**Sample Calculations**  
Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

Calibration Point No: Cal 02  
Sample No: 28959-003  
Sample Location: U1 SDA Inlet

15d. Determination of RMS deviation of spike result.

$$RMS_{f-i} = 100 \frac{\sigma_{f-i}}{AvgM_{f-i}}$$

Where:

- $RMS_{f-i}$  = RMS deviation of spike results (%).  
 $\sigma_{f-i}$  = Standard deviation of spike result.  
 $AvgM_{f-i}$  = Average spike result (mg/L)  
 100 = Conversion constant (fraction to percent)

$RMS_{f-i}$  = 0.0698  
 $\sigma_{f-i}$  = 0.0031  
 $AvgM_{f-i}$  = 0.0441

15e. Determination of average spike recovery.

$$R_f = 100 \frac{AvgM_{f-i}}{RA}$$

Where:

- $R_f$  = Average spike recovery (%)  
 $AvgM_{f-i}$  = Average spike result (mg/L)  
 $RA$  = Spike concentration added (mg/L)  
 100 = Conversion constant (fraction to percent)

$R_f$  = 108.7%  
 $AvgM_{f-i}$  = 0.04411  
 $RA$  = 0.04058

**Sample Calculations**  
Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

Calibration Point No: Cal 02  
Sample No: 28959-003  
Sample Location: U1 SDA Inlet

15f. Determination of  $t_{(n-1, 0.99)}$ .

Value taken from the following Table:

n	$t_{(n-1, 0.99)}$
7	3.143
8	2.998
9	2.896
10	2.821
11	2.764
16	2.602
21	2.528

Where:

$t_{(n-1, 0.99)}$  = Students' t value appropriate for a 99% confidence level and a standard deviation estimate with n-1 degrees of freedom.

n = Number of iterations.

$t_{(n-1, 0.99)}$  = 2.998

n = 8

15g. Determination of Method Detection Limit (MDL).

$$MDL = \sigma_{f, i} t_{(n-1, 0.99)}$$

Where:

MDL = Method detection limit (mg/L)

$t_{(n-1, 0.99)}$  = Students' t value appropriate for a 99% confidence level and a standard deviation estimate with n-1 degrees of freedom.

$\sigma_{f, i}$  = Standard deviation of spike result.

MDL = 0.009

$t_{(n-1, 0.99)}$  = 2.998

$\sigma_{f, i}$  = 0.0031

*CleanAir*

PALATINE SOURCE TESTING  
WHEELABRATOR SOUTH BROWARD

Customer Reference No: 12218  
Laboratory Services Project No: 28960

**RAW DATA**

ii

CHROMATOGRAPHIC DATA REDUCTION  
Ion Chromatography Analysis

Customer: Palatine Source Testing	Lab Project No: 28959	Analyst: Eric Ewing
Plant: Wheelabrator South Broward	Customer Reference No: 12218	Received: 4/1/13
Applicable Analytical Method: U.S. EPA Method 26A	Analyte: Chloride	

MDL= 0.009 mg/L	Average Flow Rate
LOQ= 0.041 mg/L	0.80 mL/min

Sample Location	Sample Identification Number	Sample Identification	Date of Injection	Area Counts Trial 1	Area Counts Trial 2	Area Count Average	DF (Analysis Dilution Factor)	V <sub>inj</sub> (Total Sample Volume, mL)	C <sub>reg</sub> (Concentration, mg/L from Reg Curve)	M <sub>anlyte</sub> Total Amount of Analyte (mg)
Reagent Blank	28959-001	DI H2O RB	04/02/13	0.0000	0.0000	0.0000	1	300.0	<	<0.012
Reagent Blank	28959-002	0.1N H2SO4 RB	04/03/13	0.0000	0.0000	0.0000	1	340.0	<	<0.014
U1 SDA Inlet	28959-003	Imp C&R R1	04/03/13	0.2497	0.2592	0.2545	1000	612.0	1,190.15	728.37
U1 SDA Inlet	28959-004	Imp C&R R2	04/03/13	0.2112	0.2102	0.2107	1000	644.0	986.61	635.38
U1 SDA Inlet	28959-005	Imp C&R R3	04/03/13	0.2041	0.2057	0.2049	1000	645.0	959.62	618.96
U1 FF Outlet	28959-006	Imp C&R R1	04/03/13	0.0231	0.0223	0.0227	10	773.0	1.12	0.87
U1 FF Outlet	28959-007	Imp C&R R2	04/03/13	0.0256	0.0248	0.0252	10	696.0	1.24	0.86
U1 FF Outlet	28959-008	Imp C&R R3	04/03/13	0.0794	0.0831	0.0813	10	745.0	3.84	2.86
U2 SDA Inlet	28959-009	Imp C&R R1	04/03/13	0.2531	0.2534	0.2533	1000	673.0	1,184.56	797.21
U2 SDA Inlet	28959-010	Imp C&R R2	04/03/13	0.2253	0.2213	0.2233	1000	699.0	1,045.23	727.48
U2 FF Outlet	28959-011	Imp C&R R1	04/03/13	0.1519	0.1546	0.1533	20	689.0	14.39	9.91
U2 FF Outlet	28959-012	Imp C&R R2	04/03/13	0.1550	0.1543	0.1547	20	647.0	14.52	9.39
U2 FF Outlet	28959-013	Imp C&R R3	04/04/13	0.1419	0.1409	0.1414	20	692.0	13.28	9.19
U3 SDA Inlet	28959-014	Imp C&R R1	04/03/13	0.2164	0.2210	0.2187	1000	600.0	1,023.83	614.30
U3 SDA Inlet	28959-015	Imp C&R R2	04/03/13	0.2085	0.2070	0.2078	1000	643.0	972.88	625.56
U3 SDA Inlet	28959-016	Imp C&R R3	04/03/13	0.2016	0.2002	0.2009	1000	646.3	941.02	608.18
U3 FF Outlet	28959-017	Imp C&R R1	04/04/13	0.1517	0.1493	0.1505	25	709.0	17.66	12.52
U3 FF Outlet	28959-018	Imp C&R R2	04/04/13	0.1473	0.1509	0.1491	25	734.0	17.50	12.85
U3 FF Outlet	28959-019	Imp C&R R3	04/04/13	0.1691	0.1669	0.1680	25	678.0	19.70	13.36



**CleanAir**

PALATINE SOURCE TESTING  
WHEELABRATOR SOUTH BROWARD

Customer Reference No: 12218  
Laboratory Services Project No: 28960

**QUALITY ASSURANCE RECORDS**

iii

CHROMATOGRAPHIC DATA REDUCTION  
Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

QUALITY CONTROL CHECKS

Sample Location	Sample Identification Number	Sample Identification	Date of Injection	Area Counts Trial 1	Area Counts Trial 2	Area Count Average	Area Count Duplicate Difference	Duplicate Relative Difference (%)	Is Duplicate Difference < 5%?
Reagent Blank	28959-001	DI H2O RB	04/02/13	0.0000	0.0000	0.0000	na	na	Yes
Reagent Blank	28959-002	0.1N H2SO4 RB	04/03/13	0.0000	0.0000	0.0000	na	na	Yes
U1 SDA Inlet	28959-003	Imp C&R R1	04/03/13	0.2497	0.2592	0.2545	0.0095	3.7%	Yes
U1 SDA Inlet	28959-004	Imp C&R R2	04/03/13	0.2112	0.2102	0.2107	0.0010	0.5%	Yes
U1 SDA Inlet	28959-005	Imp C&R R3	04/03/13	0.2041	0.2057	0.2049	0.0016	0.8%	Yes
U1 FF Outlet	28959-006	Imp C&R R1	04/03/13	0.0231	0.0223	0.0227	0.0008	3.5%	Yes
U1 FF Outlet	28959-007	Imp C&R R2	04/03/13	0.0256	0.0248	0.0252	0.0008	3.2%	Yes
U1 FF Outlet	28959-008	Imp C&R R3	04/03/13	0.0794	0.0831	0.0813	0.0037	4.6%	Yes
U2 SDA Inlet	28959-009	Imp C&R R1	04/03/13	0.2531	0.2534	0.2533	0.0003	0.1%	Yes
U2 SDA Inlet	28959-010	Imp C&R R2	04/03/13	0.2253	0.2213	0.2233	0.0040	1.8%	Yes
U2 FF Outlet	28959-011	Imp C&R R1	04/03/13	0.1519	0.1546	0.1533	0.0027	1.8%	Yes
U2 FF Outlet	28959-012	Imp C&R R2	04/03/13	0.1550	0.1543	0.1547	0.0007	0.5%	Yes
U2 FF Outlet	28959-013	Imp C&R R3	04/04/13	0.1419	0.1409	0.1414	0.0010	0.7%	Yes
U3 SDA Inlet	28959-014	Imp C&R R1	04/03/13	0.2164	0.2210	0.2187	0.0046	2.1%	Yes
U3 SDA Inlet	28959-015	Imp C&R R2	04/03/13	0.2085	0.2070	0.2078	0.0015	0.7%	Yes
U3 SDA Inlet	28959-016	Imp C&R R3	04/03/13	0.2016	0.2002	0.2009	0.0014	0.7%	Yes
U3 FF Outlet	28959-017	Imp C&R R1	04/04/13	0.1517	0.1493	0.1505	0.0024	1.6%	Yes
U3 FF Outlet	28959-018	Imp C&R R2	04/04/13	0.1473	0.1509	0.1491	0.0036	2.4%	Yes
U3 FF Outlet	28959-019	Imp C&R R3	04/04/13	0.1691	0.1669	0.1680	0.0022	1.3%	Yes

CHROMATOGRAPHIC DATA REDUCTION

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U. S. EPA Method 26A			Analyte:	Chloride

CCV Concentration: 0.81 mg/L  
 QC Concentration: 1.03 mg/L

MDL=	0.009 mg/L
LOQ=	0.041 mg/L

QUALITY CONTROL CHECKS (CONT)

Sample Location	Sample Identification Number	Sample Identification	Date of Injection	Area Counts Trial 1	Area Counts Trial 2	Area Count Average	Area Count Duplicate Difference	Duplicate Relative Difference (%)	C <sub>Reg</sub> (Concentration, mg/L from Reg Curve)	Percent Difference from Actual Value (%)	Is Percent Difference from Actual Value <10%?
CleanAir	28959-1000	QC	04/01/13	0.2235	0.2222	0.2229	0.0013	0.6%	1.04	1.59%	Yes
CleanAir	28959-00	CCB	04/02/13	0.0000	0.0000	0.0000	na	na	<	<	Yes
CleanAir	28959-1001	CCV	04/02/13	0.1746	0.1774	0.1760	0.0028	1.6%	0.83	1.68%	Yes
CleanAir	28959-1002	QC	04/02/13	0.2219	0.2231	0.2225	0.0012	0.5%	1.04	1.43%	Yes
CleanAir	28959-00	CCB	04/02/13	0.0000	0.0000	0.0000	na	na	<	<	Yes
CleanAir	28959-1003	CCV	04/02/13	0.1745	0.1765	0.1755	0.0020	1.1%	0.82	1.39%	Yes
CleanAir	28959-1004	QC	04/03/13	0.2169	0.2215	0.2192	0.0046	2.1%	1.03	0.07%	Yes
CleanAir	28959-00	CCB	04/04/13	0.0000	0.0000	0.0000	na	na	<	<	Yes
CleanAir	28959-1005	CCV	04/04/13	0.1725	0.1733	0.1729	0.0008	0.5%	0.81	0.10%	Yes
CleanAir	28959-1006	QC	04/04/13	0.2141	0.2173	0.2157	0.0032	1.5%	1.01	1.65%	Yes
CleanAir	28959-00	CCB	04/04/13	0.0000	0.0000	0.0000	na	na	<	<	Yes
CleanAir	28959-1007	CCV	04/04/13	0.1711	0.1742	0.1727	0.0031	1.8%	0.81	0.24%	Yes
CleanAir	28959-1008	QC	04/05/13	0.2191	0.2208	0.2200	0.0017	0.8%	1.03	0.27%	Yes
CleanAir	28959-00	CCB	04/05/13	0.0000	0.0000	0.0000	na	na	<	<	Yes
CleanAir	28959-1009	CCV	04/05/13	0.1689	0.1690	0.1690	0.0021	1.3%	0.79	2.93%	Yes

Sample Duplicate Analysis Area Count Check

									Precision	Is Precision within ±5% Tolerance?
U2 FF Outlet	28959-011	Imp C&R R1	04/03/13	0.1519	0.1546	0.1533	0.0027	1.8%		Yes
U2 FF Outlet	28959-011	Imp C&R R1	04/05/13	0.1514	0.1560	0.1537	0.0046	3.0%	0.3%	Yes
U3 FF Outlet	28959-019	Imp C&R R3	04/04/13	0.1691	0.1669	0.1680	0.0022	1.3%		Yes
U3 FF Outlet	28959-019	Imp C&R R3	04/05/13	0.1635	0.1689	0.1662	0.0054	3.2%	1.1%	Yes

Matrix Spike Recoveries

									Precision	Spike Recovery	Is Spike Recovery Between 90-110%
Matrix Spike	28959-006	Imp C&R R1	04/05/13	0.1576	0.1526	0.1551	0.0050	3.2%		105.5%	Yes
Matrix Spike	28959-006	Imp C&R R1	04/05/13	0.1498	0.1562	0.1530	0.0064	4.2%	1.4%	104.1%	Yes
Matrix Spike	28959-008	Imp C&R R3	04/05/13	0.1697	0.1783	0.1740	0.0086	4.9%		98.8%	Yes

**CleanAir**

**PALATINE SOURCE TESTING  
WHEELABRATOR SOUTH BROWARD**

Customer Reference No: 12218  
Laboratory Services Project No: 28960

**CHAIN-OF-CUSTODY DOCUMENTATION**

iv

Lab Project No.: 28960

Date Received: 4/1/2013

CleanAir No.: 12218

66

Customer : 66

Contact : Scott Brown

Phone :

Fax :

Email : sbrown@cleanair.com

### Requested Analysis

Due	Analyst	Status	Sample Type	Container	Method
4/15/201	EE	In Queue	1-19 Impinger C&R	Nalgene	US EPA Method 26A Chloride

Printed 2013/04/01 11:19:33

CLIENT Wheelabrator  
 PLANT South Broward  
 PROJECT MANAGER S. Brown

PROJECT 12218SB

DEPT. 66

66-12218SB-8

ANALYTICAL METHOD	CONTAINER NUMBER	SAMPLE FRACTION
USEPA M-26	SEE BELOW (IF APPLICABLE)	REAGENT BLANKS



800-627-0033 (phone)  
847-991-3385 (fax)

NUMBER OF CONTAINERS

CONTAINER SEALED?  
LIQUID LEVEL MARKED?

ANALYSIS REQUESTED

Chloride  
Fluoride  
Bromide  
Archive

FORWARDING LAB

CleanAir Analytical Services  
500 West Wood Street  
Palatine, IL 60067

800-627-0033 (phone)  
847-991-3385 (fax)

ADDITIONAL INFORMATION

28960

LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	NUMBER OF CONTAINERS	CONTAINER SEALED? LIQUID LEVEL MARKED?	ANALYSIS REQUESTED	ADDITIONAL INFORMATION
-001	3/25 <sup>200</sup>	Reagent Blank	All	DI Water (~200 mL), 250 mL HDPE	1	X		Please Report North
-002	3/25 <sup>100</sup>	Reagent Blank	All	0.1 N H <sub>2</sub> SO <sub>4</sub> (~200 mL), 1000 mL HDPE	1	X		and South Broward Separately

Relinquished By: (signature) S. Brown	Date / Time 3/27/2013 17:00	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by: S. Brown Signature <u>S. Brown</u> Date 3/27/2013
Received By: (signature) <u>[Signature]</u>	Date / Time 4/1/13 1105	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	

CLIENT Wheelabrator  
 PLANT South Broward  
 PROJECT MANAGER S. Brown

PROJECT 12218SB  
 DEPT. 66

66-12218SB-7

**CleanAir**  
 ENGINEERING  
 500 West Wood Street  
 Palatine, IL 60067  
 800-627-0033 (phone)  
 847-991-3385 (fax)


ANALYTICAL METHOD	CONTAINER NUMBER	SAMPLE FRACTION
USEPA M-26	2	ALKALINE IMPINGER CATCH AND RINSE 1000 mL HDPE

28960

LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX
-006	3/25	Unit 1 FF Outlet	1	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-007	3/25	Unit 1 FF Outlet	2	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-008	3/25	Unit 1 FF Outlet	3	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-003	3/25	Unit 1 SDA Inlet	1	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-004	3/25	Unit 1 SDA Inlet	2	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-005	3/25	Unit 1 SDA Inlet	3	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-011	3/27	Unit 2 FF Outlet	1	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-012	3/27	Unit 2 FF Outlet	2	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-013	3/27	Unit 2 FF Outlet	3	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-009	3/27	Unit 2 SDA Inlet	1	Acidic Impinger Catch and Rinse, 1000 mL HDPE
-010	3/27	Unit 2 SDA Inlet	2	Acidic Impinger Catch and Rinse, 1000 mL HDPE

NUMBER OF CONTAINERS	CONTAINER SEALED? LIQUID LEVEL MARKED?	ANALYSIS REQUESTED			FORWARDING LAB CleanAir Analytical Services 500 West Wood Street Palatine, IL 60067 800-627-0033 (phone) 847-991-3385 (fax)  ADDITIONAL INFORMATION
		Chloride	Bromide	Archive	
1	773	X			Please Report North
1	697	X			and South Broward Separately
1	745	X			
1	612	X			
1	644	X			
1	645	X			
1	689	X			
1	647	X			
1	692	X			
1	673	X			
1	696	X			

Relinquished By: (signature) S. Brown	Date / Time 3/27/2013 17:00	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by: S. Brown
Received By: (signature) <i>[Signature]</i>	Date / Time 3/27/13 11:05	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Signature <i>[Signature]</i> Date 3/27/2013

CLIENT <u>Wheelabrator</u>		PROJECT <u>12218SB</u>		66-12218SB-6									
PLANT <u>South Broward</u>		DEPT. <u>66</u>											
PROJECT MANAGER <u>S. Brown</u>		 500 West Wood Street Palatine, IL 60067 800-627-0033 (phone) 847-991-3385 (fax)		NUMBER OF CONTAINERS	CONTAINER SEALED? LIQUID LEVEL MARKED?								
ANALYTICAL METHOD	CONTAINER NUMBER					ANALYSIS REQUESTED							
<u>USEPA M-26</u>	<u>1</u>					<table border="1"> <tr> <td>Chloride</td> <td>Fluoride</td> <td>Bromide</td> <td>Archive</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> </tr> </table>				Chloride	Fluoride	Bromide	Archive
Chloride	Fluoride	Bromide	Archive										
SAMPLE FRACTION		FORWARDING LAB											
<u>ACIDIC IMPINGER CATCH AND RINSE</u>		CleanAir Analytical Services											
<u>1000 mL HDPE</u>		500 West Wood Street Palatine, IL 60067											
<u>28960</u>		800-627-0033 (phone) 847-991-3385 (fax)											
LAB ID NUMBER	DATE (2013)	TEST LOCATION	RUN NUMBER	SAMPLE MATRIX	ADDITIONAL INFORMATION								
					Please Report North								
					and South Broward Separately								
<u>-017</u>	<u>3/26</u>	<u>Unit 3 FF Outlet</u>	<u>1</u>	<u>Acidic Impinger Catch and Rinse, 1000 mL HDPE</u>	<u>1</u> <u>709</u> X								
<u>-018</u>	<u>3/26</u>	<u>Unit 3 FF Outlet</u>	<u>2</u>	<u>Acidic Impinger Catch and Rinse, 1000 mL HDPE</u>	<u>1</u> <u>714</u> X								
<u>-019</u>	<u>3/26</u>	<u>Unit 3 FF Outlet</u>	<u>3</u>	<u>Acidic Impinger Catch and Rinse, 1000 mL HDPE</u>	<u>1</u> <u>678</u> X								
<u>-014</u>	<u>3/26</u>	<u>Unit 3 SDA Inlet</u>	<u>1</u>	<u>Acidic Impinger Catch and Rinse, 1000 mL HDPE</u>	<u>1</u> <u>620</u> X								
<u>-015</u>	<u>3/26</u>	<u>Unit 3 SDA Inlet</u>	<u>2</u>	<u>Acidic Impinger Catch and Rinse, 1000 mL HDPE</u>	<u>1</u> <u>643</u> X								
<u>-016</u>	<u>3/26</u>	<u>Unit 3 SDA Inlet</u>	<u>3</u>	<u>Acidic Impinger Catch and Rinse, 1000 mL HDPE</u>	<u>1</u> <u>6463</u> X								
Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	This form completed by:							
<u>S. Brown</u>	<u>3/27/2013 17:00</u>					<u>S. Brown</u>							
Received By: (signature)	Date / Time	Received By: (signature)	Date / Time	Relinquished By: (signature)	Date / Time	Signature Date							
<u>[Signature]</u>	<u>4/1/13 1105</u>					<u>[Signature]</u> <u>3/27/2013</u>							



**CleanAir**

PALATINE SOURCE TESTING  
WHEELABRATOR SOUTH BROWARD

Customer Reference No: 12218  
Laboratory Services Project No: 28960

**DETECTION LIMIT DETERMINATION DATA**

v

**Determination of Method Detection Limit**  
Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

		Non-Iterative Study	
MDL Reference	40 CFR 136, Appendix B	No. of Replicates	$t_{(n-1,0.99)}$
CleanAir Reference	SOP EPA5-11	7	3.143
		8	2.998
Matrix	Deionized Water	9	2.896
		10	2.821
		11	2.764
Analyte	Chloride	16	2.602
Spike Concentration	0.0406 mg/L	21	2.528
Slope	4.6523		
Intercept	0.0064		
Coefficient of Corr.	0.99997		

Spike Aliquots	Spike Result (Area Count)	Measured Concentration (mg/L)
1	0.0091	0.049
2	0.0092	0.049
3	0.0074	0.041
4	0.0079	0.043
5	0.0078	0.043
6	0.0077	0.042
7	0.0079	0.043
8	0.0079	0.043

Average Spike Concentration:	0.044	Is the spike level higher than the MDL?	Yes
Recovery ( $R_d$ ):	108.71%	Is the spike level less than ten times the MDL?	Yes
Standard Deviation ( $S_d$ ):	0.00308	Is the Avg Recovery between 90% < $R_d$ < 110%?	Yes
RMS Deviation:	7.0%		
$t_{(n-1,0.99)}$ :	2.998		
MDL:	0.009		
LOQ:	0.041		

**CleanAir**

PALATINE SOURCE TESTING  
WHEELABRATOR SOUTH BROWARD

Customer Reference No: 12218  
Laboratory Services Project No: 28960

**EQUIPMENT CALIBRATION RECORDS**

**vi**

CHROMATOGRAPHIC DATA REDUCTION  
Ion Chromatography Analysis

Customer:	Positive Source Testing, Lab Project No:	28958	Analyst:	Eric Ewing	
Plant:	Wmababanz South Broward	Customer Reference No:	12218	Received:	4/11/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

Stock Standard: 1014.41 mg/L  
Working Stock Conc.: 10.1441 mg/L  
QC Standard: 205.37 mg/L

Analyte:

Calibration ID	Date of Injection	Chloride Standards Calibration Data 1						
		Cal 01	Cal 02	Cal 03	Cal 04	Cal 05	Cal 06	Cal 07
Cal 1 Trial 1	03/28/2013	0.0000	0.0074	0.0413	0.0811	0.2698	0.3484	0.5381
Cal 1 Trial 2		0.0000	0.0079	0.0422	0.0842	0.2894	0.3433	0.5381
Cal 2 Trial 1	04/01/2013			0.0428				
Cal 2 Trial 2				0.0442				
Cal 3 Trial 1	04/02/2013				0.0839			
Cal 3 Trial 2					0.0883			
Cal 4 Trial 1	04/03/2013					0.2882		
Cal 4 Trial 2						0.2731		
Cal 5 Trial 1	04/04/2013						0.3543	0.5440
Cal 5 Trial 2							0.3513	0.5489
Cal 6 Trial 1	04/05/2013			0.0436				
Cal 6 Trial 2				0.0421				
Cal 7 Trial 1	04/05/2013		0.0078	0.0434	0.0833	0.2705	0.3484	0.5448
Cal 7 Trial 2			0.0077	0.0407	0.0840	0.2700	0.3481	0.5525

n	2	4	8	8	8	8	
Average Area Counts	0.0000	0.0072	0.0424	0.0839	0.2701	0.3483	0.5440
Standard Deviation	0.0000	0.0002	0.0012	0.0017	0.0018	0.0039	0.0002
%RSD	0.00	2.81	2.79	2.00	0.80	1.13	1.14
Minimum	0.0000	0.0074	0.0407	0.0811	0.2682	0.3433	0.5301
Maximum	0.0000	0.0079	0.0442	0.0893	0.2731	0.3543	0.5525


EPA Method 26 Quality Control Parameters

Average Minus Minimum Value (Rel. %)	3.90%	4.26%	3.22%	0.73%	1.44%	1.46%
Is Minimum Within 5% of Average Value?	Yes	Yes	Yes	Yes	Yes	Yes
Maximum Minus Average Value (Rel. %)	2.80%	3.97%	2.98%	1.09%	1.72%	1.58%
Is Maximum Within 5% of Average Value?	Yes	Yes	Yes	Yes	Yes	Yes

Measured Area Counts (Counts)	Actual Concentration (mg/L)	Regression Concentration (mg/L)	Quality Control Checks			
			Difference (Count)	% of Scale 1	Difference (mg/L)	% of Scale 2
0.0000	0.000	0.008	-0.25%	Yes	0.00%	Yes
0.0077	0.041	0.042	-0.06%	Yes	-3.98%	Yes
0.0425	0.203	0.204	-0.05%	Yes	-0.82%	Yes
0.0838	0.408	0.388	0.50%	Yes	2.35%	Yes
0.2702	1.288	1.283	0.19%	Yes	0.37%	Yes
0.3483	1.823	1.827	-0.15%	Yes	-0.23%	Yes
0.5440	2.536	2.537	-0.05%	Yes	-0.05%	Yes

Regression Constants  
Slope m = 4.6323  
Intercept b = 0.0084  
Coeff. R<sup>2</sup> = 0.99997

Is Coefficient of Regression > 0.9992  
Yes



† Lot numbers for the individual calibration standards are listed in the Standard and Reagent Traceability section in the Case Narrative.

*CleanAir*

PALATINE SOURCE TESTING  
WHEELABRATOR SOUTH BROWARD

Customer Reference No: 12218  
Laboratory Services Project No: 28960

**STANDARD PREPARATION RECORDS**

vii

**Stock Solution Standard Mixing Recipe (Anions)**  
Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

Order of Elution	8	9	10	11	12	13	14	15
<b>Analyte</b>	Fluoride	Chloride	Nitrite	Bromide	Nitrate	Phosphate	Sulfate	Iodide
Analyte Weight (g/g-mole)	19.00	35.45	46.01	79.90	62.00	94.97	96.06	126.91
Solid Formula	NaF	NaCl	NaNO <sub>2</sub>	NaBr	NaNO <sub>3</sub>	Na <sub>2</sub> HPO <sub>4</sub>	Na <sub>2</sub> SO <sub>4</sub>	NaI
Number of Ions/Formula	1	1	1	1	1	1	1	1
Formula Weight (g/g-mole)	41.99	58.44	69.00	102.89	84.99	141.96	142.04	149.89
% Analyte in Solid	45.25%	60.66%	66.68%	77.66%	72.95%	66.90%	67.63%	84.66%

Recommended Analyte Concentration (mg/L)	500	1007.21	2000	3000	3000	5000	5000	7000
--	-----	---------	------	------	------	------	------	------

Amount of Solid Required to Achieve the Above Stock Solution Concentration In The Listed Volumetric Flask:								
500 ml	0.5525	0.8302	1.4997	1.9316	2.0562	3.7369	3.8967	4.1341

Size of Flask	500 ml ▼							
Amount of Solid Used	1.10546 g	0.83611 g		1.93183 g			3.69908 g	
Actual Concentration (mg/L)	1000.37	1014.41		3000.39			5003.26	

**Concentration in the Five Cal Flasks (mg/L)**

Stock (1 liter Flask) Solution Concentrations								
10 ml Original Solution Used	10.0037	10.1441		30.0039			50.0326	Cal ID
Dilution Flask Size	Aliquot Stock							
500	2	0.0400	0.0406	0.1200		0.2001		Cal 01
250	5	0.2001	0.2029	0.6001		1.0007		Cal 02
250	10	0.4001	0.4058	1.2002		2.0013		Cal 03
250	20	0.8003	0.8115	2.4003		4.0026		CCV
200	25	1.2505	1.2680	3.7505		6.2541		Cal 04
250	40	1.6006	1.6231	4.8006		8.0052		Cal 05
200	50	2.5009	2.5360	7.5010		12.5082		Cal 06

**QC Standard Mixing Recipe (Anions)**  
Ion Chromatography Analysis

Customer:	Palatine Source Testing	Lab Project No:	28959	Analyst:	Eric Ewing
Plant:	Wheelabrator South Broward	Customer Reference No:	12218	Received:	4/1/13
Applicable Analytical Method:	U.S. EPA Method 26A			Analyte:	Chloride

Order of Elution	8	9	10	11	12	13	14	15
Analyte	Fluoride	Chloride	Nitrite	Bromide	Nitrate	Phosphate	Sulfate	Iodide
Analyte Weight (g/g-mole)	19.00	35.45	46.01	79.90	62.00	94.97	96.06	126.91
Solid Formula	NaF	NaCl	NaNO <sub>2</sub>	NaBr	NaNO <sub>3</sub>	Na <sub>2</sub> HPO <sub>4</sub>	Na <sub>2</sub> SO <sub>4</sub>	NaI
Number of ions/Formula	1	1	1	1	1	1	1	1
Formula Weight (g/g-mole)	41.99	58.44	69.00	102.89	84.99	141.96	142.04	149.89
% Analyte in Solid	45.25%	60.66%	66.68%	77.66%	72.95%	66.90%	67.63%	84.66%

Recommended Analyte Concentration (mg/L)	140	200	200	400	300	300	300	500
--	-----	-----	-----	-----	-----	-----	-----	-----

Amount of Solid Required to Achieve the Above Stock Solution Concentration In The Listed Volumetric Flask:

500 ml	0.1547	0.1848	0.1500	0.2575	0.2056	0.2242	0.2218	0.2953
--------	--------	--------	--------	--------	--------	--------	--------	--------

Size of Flask: 500 ml

Amount of Solid Used	0.17828 g	0.16927 g		0.27110 g			0.23242 g	
Actual Concentration (mg/L)	161.33	205.37		421.05			314.36	

**Concentration in the QC Flask (mg/L)**

Dilution Flask Size	Aliquot Stock					Cal. ID
1000	5	0.8067	1.0268	2.1053	1.5718	QC

**CleanAir**

PALATINE SOURCE TESTING  
WHEELABRATOR SOUTH BROWARD

Customer Reference No: 12218  
Laboratory Services Project No: 28960

**BATCH LOG SHEETS**

viii



AS40 Log Sheet

Customer Project No:	12218	Analyte(s):	Chloride	Standard Lot#	03201302-64-00000-01
Lab Project No:	28959, 28960			QC Standard Lot#	03201302-64-00000-02
Dates:	3/29/13 - 4/5/13			Working Stock Lot#	03201302-64-00000-03
Analyst:	E. Ewing				

Inj Type: Loop

Inj Mode: Cnst

Inj / Vial: 2

Serial Dilution Data

Microlab 600 Dilution Data

Cartridge I 1B 3/29/2013

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Blank		1						
2		Cal 01 03201302-64-00000-04		1						
3		Cal 01 03201302-64-00000-04		1						
4		Cal 02 03201302-64-00000-05		1						
5		Cal 03 03201302-64-00000-06		1						
6		Cal 04 03201302-64-00000-07		1						

Cartridge I 2B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Cal 05 03201302-64-00000-08		1						
2		Cal 06 03201302-64-00000-09		1						
3		Blank		1						
4										
5										
6										

Cartridge I 1B 4/1/2013

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Blank		1						
2		Cal 02 03201302-64-00000-05		1						
3		Blank		1						
4		QC 03201302-64-00000-11		1						
5		Blank		1						
6	28959-001	Reagent Blank DI H2O RB	360	1						

Cartridge I 2B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28959-002	Reagent Blank 0.1N H2SO4 RB	600	1						
2	28959-003	U1 SDA Inlet Imp C&R R1	689	1000					30	30,000
3	28959-004	U1 SDA Inlet Imp C&R R2	675	1000					30	30,000
4	28959-005	U1 SDA Inlet Imp C&R R3	714	1000					30	30,000
5	28959-009	U2 SDA Inlet Imp C&R R1	613	1000					30	30,000
6	28959-010	U2 SDA Inlet Imp C&R R2	631	1000					30	30,000

AS40 Log Sheet

Customer Project No:	12218	Analyte(s):	Chloride	Standard Lot#	03201302-64-00000-01
Lab Project No:	28959, 28960			QC Standard Lot#	03201302-64-00000-02
Dates:	3/29/13 - 4/5/13			Working Stock Lot#	03201302-64-00000-03
Analyst:	E. Ewing				

Inj Type: Loop

Inj Mode: Cnst

Inj / Vial: 2

Serial Dilution Data

Microlab 600  
Dilution Data

Cartridge I 3B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28959-011	U2 SDA Inlet Imp C&R R3	668	1000					30	30,000
2	28959-015	U3 SDA Inlet Imp C&R R1	637	1000					30	30,000
3	28959-016	U3 SDA Inlet Imp C&R R2	624	1000					30	30,000
4		Blank		1						
5		CCV 03201302-64-00000-10		1						
6		Blank		1						

Cartridge I 4B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28959-017	U3 SDA Inlet Imp C&R R3	704	1000					30	30,000
2	28959-006	U1 FF Outlet Imp C&R R1	653	1						
3	28959-007	U1 FF Outlet Imp C&R R2	659	1						
4	28959-008	U1 FF Outlet Imp C&R R3	660	1						
5	28959-012	U2 FF Outlet Imp C&R R1	780	1						
6	28959-013	U2 FF Outlet Imp C&R R2	735	1						

Cartridge I 5B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28959-014	U2 FF Outlet Imp C&R R3	837	1						
2	28959-018	U3 FF Outlet Imp C&R R1	750	1						
3	28959-019	U3 FF Outlet Imp C&R R2	690	1						
4	28959-020	U3 FF Outlet Imp C&R R3	726	1						
5		Blank		1						
6		QC 03201302-64-00000-11		1						

Cartridge I 6B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Blank		1						
2	28960-001	Reagent Blank DI H2O RB	300	1						
3	28960-006	U1 FF Outlet Imp C&R R1	773	1						
4	28960-007	U1 FF Outlet Imp C&R R2	695	1						
5	28960-008	U1 FF Outlet Imp C&R R3	745	1						
6	28960-011	U2 FF Outlet Imp C&R R1	689	1						

AS40 Log Sheet

Customer Project No:	12218	Analyte(s):	Chloride	Standard Lot#	03201302-64-00000-01
Lab Project No:	28959, 28960			QC Standard Lot#	03201302-64-00000-02
Dates:	3/29/13 - 4/5/13			Working Stock Lot#	03201302-64-00000-03
Analyst:	E. Ewing				

Inj Type: Loop

Inj Mode: Cnst

Inj / Vial: 2

Serial Dilution Data

Microlab 600 Dilution Data

Cartridge I 7B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28960-012	U2 FF Outlet Imp C&R R2	647	1						
2	28960-013	U2 FF Outlet Imp C&R R3	692	1						
3	28960-017	U3 FF Outlet Imp C&R R1	709	1						
4	28960-018	U3 FF Outlet Imp C&R R2	734	1						
5	28960-019	U3 FF Outlet Imp C&R R3	678	1						
6		Blank		1						

Cartridge I 8B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		CCV 03201302-64-00000-10		1						
2		Blank		1						
3		Cal 03 03201302-64-00000-06		1						
4		Blank		1						
5										
6										

Cartridge I 1B 4/3/2013

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Blank		1						
2		Cal 04 03201302-64-00000-07		1						
3		Blank		1						
4		CCV 03201302-64-00000-10		1						
5		Blank		1						
6	28960-002	Reagent Blank 0.1N H2SO4 RB	340	1						

Cartridge I 2B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28960-003	U1 SDA Inlet Imp C&R R1	612	1000					30	30,000
2	28960-004	U1 SDA Inlet Imp C&R R2	644	1000					30	30,000
3	28960-005	U1 SDA Inlet Imp C&R R3	645	1000					30	30,000
4	28960-009	U2 SDA Inlet Imp C&R R1	673	1000					30	30,000
5	28960-010	U2 SDA Inlet Imp C&R R2	696	1000					30	30,000
6	28960-014	U3 SDA Inlet Imp C&R R1	600	1000					30	30,000

AS40 Log Sheet

Customer Project No:	12218	Analyte(s):	Chloride	Standard Lot#	03201302-64-00000-01
Lab Project No:	28959, 28960			QC Standard Lot#	03201302-64-00000-02
Dates:	3/29/13 - 4/5/13			Working Stock Lot#	03201302-64-00000-03
Analyst:	E. Ewing				

Inj Type: Loop

Inj Mode: Cnst

Inj / Vial: 2

Serial Dilution Data

Microlab 600 Dilution Data

Cartridge I 3B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28960-015	U3 SDA Inlet Imp C&R R2	643	1000					30	30,000
2	28960-016	U3 SDA Inlet Imp C&R R3	646.3	1000					30	30,000
3	28960-006	U1 FF Outlet Imp C&R R1	773	10					600	6,000
4		Blank		1						
5		QC 03201302-64-00000-11		1						
6		Blank		1						

Cartridge I 4B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28960-007	U1 FF Outlet Imp C&R R2	695	10					600	6,000
2	28960-008	U1 FF Outlet Imp C&R R3	745	10					600	6,000
3	28960-011	U2 FF Outlet Imp C&R R1	689	20					300	6,000
4	28960-012	U2 FF Outlet Imp C&R R2	647	20					300	6,000
5	28960-013	U2 FF Outlet Imp C&R R3	692	20					300	6,000
6	28960-017	U3 FF Outlet Imp C&R R1	709	25					240	6,000

Cartridge I 5B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28960-018	U3 FF Outlet Imp C&R R2	734	25					240	6,000
2	28960-019	U3 FF Outlet Imp C&R R3	678	25					240	6,000
3		Blank		1						
4		CCV 03201302-64-00000-10		1						
5		Blank		1						
6		Cal 05 03201302-64-00000-08		1						

Cartridge I 6B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Blank		1						
2										
3										
4										
5										
6										

AS40 Log Sheet

Customer Project No:	12218	Analyte(s):	Chloride	Standard Lot#	03201302-64-00000-01
Lab Project No:	28959, 28960			QC Standard Lot#	03201302-64-00000-02
Dates:	3/29/13 - 4/5/13			Working Stock Lot#	03201302-64-00000-03
Analyst:	E. Ewing				

Inj Type: Loop

Inj Mode: Cnst

Inj / Vial: 2

Serial Dilution Data

Microlab 600 Dilution Data

Cartridge I 1B 4/4/2013

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Blank		1						
2		Cal 06 03201302-64-00000-09		1						
3		Blank		1						
4		QC 03201302-64-00000-11		1						
5		Blank		1						
6	28959-006	U1 FF Outlet Imp C&R R1	653	10					600	6,000

Cartridge I 2B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28959-007	U1 FF Outlet Imp C&R R2	659	10					600	6,000
2	28959-008	U1 FF Outlet Imp C&R R3	660	10					600	6,000
3	28959-012	U2 FF Outlet Imp C&R R1	780	10					600	6,000
4	28959-013	U2 FF Outlet Imp C&R R2	735	10					600	6,000
5	28959-014	U2 FF Outlet Imp C&R R3	837	10					600	6,000
6	28959-018	U3 FF Outlet Imp C&R R1	750	20					300	6,000

Cartridge I 3B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28959-019	U3 FF Outlet Imp C&R R2	690	20					300	6,000
2	28959-020	U3 FF Outlet Imp C&R R3	726	20					300	6,000
3	28959-006	U1 FF Outlet Imp C&R R1	653	10					600	6,000
4		Blank		1						
5		CCV 03201302-64-00000-10		1						
6		Blank		1						

Cartridge I 4B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28959-018	U3 FF Outlet Imp C&R R1	750	20					300	6,000
2	28959-007	Matrix Spike 03201302-64-00000-09	659	10					275	2,750
3	28959-007	Matrix Spike 03201302-64-00000-09	659	10					275	2,750
4	28959-020	Matrix Spike 03201302-64-00000-09	726	20					137.5	2,750
5	28960-011	U2 FF Outlet Imp C&R R1	689	20					300	6,000
6	28960-019	U3 FF Outlet Imp C&R R3	678	25					240	6,000

AS40 Log Sheet

Customer Project No:	12218	Analyte(s):	Chloride	Standard Lot#	03201302-64-00000-01
Lab Project No:	28959, 28960			QC Standard Lot#	03201302-64-00000-02
Dates:	3/29/13 - 4/5/13			Working Stock Lot#	03201302-64-00000-03
Analyst:	E. Ewing				

Inj Type: Loop

Inj Mode: Cnst

Inj / Vial: 2

Serial Dilution Data

Microlab 600 Dilution Data

Cartridge I 5B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1	28960-006	Matrix Spike 03201302-64-00000-07	773	10					275	2,750
2	28960-006	Matrix Spike 03201302-64-00000-07	773	10					275	2,750
3	28960-008	Matrix Spike 03201302-64-00000-07	745	10					275	2,750
4		Blank		1						
5		QC 03201302-64-00000-11		1						
6		Blank		1						

Cartridge I 6B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Cal 02 03201302-64-00000-05		1						
2		Blank		1						
3										
4										
5										
6										

Cartridge I 1B 4/5/2013

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Blank		1						
2		CCV 03201302-64-00000-10		1						
3		Blank		1						
4	28959-012	U2 FF Outlet Imp C&R R1	780	20					300	6,000
5	28959-013	U2 FF Outlet Imp C&R R2	735	20					300	6,000
6	28959-014	U2 FF Outlet Imp C&R R3	837	20					300	6,000

Cartridge I 2B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Blank		1						
2		CCV 03201302-64-00000-10		1						
3		Blank		1						
4		Cal 01 03201302-64-00000-04		1						
5		Cal 01 03201302-64-00000-04		1						
6		Cal 02 03201302-64-00000-05		1						

Cartridge I 3B

Pos	Sample #	Identification	Volume	Dilution Factor	Pipet Serial No.	Pipet Size	Flask Serial No.	Flask Size	Aliquot Size (uL)	Total Volume (uL)
1		Cal 03 03201302-64-00000-06		1						
2		Cal 04 03201302-64-00000-07		1						
3		Cal 05 03201302-64-00000-08		1						
4		Cal 06 03201302-64-00000-09		1						
5		Blank		1						
6										

WHEELABRATOR SOUTH BROWARD, INC.  
FT. LAUDERDALE, FL

Client Reference No: Service Agreement  
CleanAir Project No: 12218-3

**PERTINENT CERTIFICATIONS**

J

*I herby certify that all pages contained within this Appendix have been reviewed and, to the best of my ability, verified as accurate.*

QA/QC Initials: VAR

Date: 5/6/13



**This Page Intentionally Left Blank**





# AeroMet

## Engineering, Inc.

Solutions for a Changing Environment

# Certification of Visible Opacity Reading

## Daniel Luckhard

qualified to conduct EPA Method 9 Tests for visible opacity in accordance with the methods established for such qualification in 40 CFR Part 60 Appendix A.

Certification Date: March 6, 2013

Expiration Date: September 6, 2013

AeroMet Instructor:

Trey Beauchamp

**AEROMET ENGINEERING INC. CERTIFIES THAT**

**Daniel Luckhard**

has qualified as a **CERTIFIED VISIBLE EMISSIONS READER**

per Title 40 Part 60 Appendix A USEPA Method 9

Issued: 3/6/13

Expires: 9/6/13

Questions? Call 573.636.6393

J-3

AeroMet Public School

### GIFT CARD DRAWING

- To see if you have won:
1. Go to [www.aeromet.org](http://www.aeromet.org)
  2. Click on Smoke School
  3. Click on Gift Card Drawing
  4. Look for your location on the list.

The winner (you) will be notified within 7 days of public opening event. You are automatically registered by your pass the certification test.

If you have a question, you must contact AeroMet at 573.636.6393. To see if you have won, visit [www.aeromet.org](http://www.aeromet.org).



**This Page Intentionally Left Blank**