Barbara \ File

-C/2-



RECEIVED

SEP 2 6 2000

DIVISION OF AIR RESOURCES MANAGEMENT

WHEELABRATOR NORTH BROWARD, INC. A WASTE MANAGEMENT COMPANY

2600 N.W. 48th Street Pompano Beach, FL 33073 (954) 971-8701 (954) 971-8703 Fax

CERTIFIED MAIL #239 397 939

October 14, 2000

Mr. Michael Hewett Florida Department of Environmental Protection Twin Towers Office Building 2600 Blair Stone Road Tallahassee, FL 32399-2400

Re:

Wheelabrator North Broward

Compliance with required Construction Completion Date of September 13, 2000 for

Selective Non-Catalytic Reduction (SNCR) System for NOx

Dear Mr. Hewett:

As required by 40 CFR Subpart Cb, construction of the facility SNCR system for NOx was completed on September 13, 2000.

If there are any questions, or if further information is required, please contact this office at (954) 971-8701.

Sincerely,

William Roberts

General Manager

cc:

Chuck Faller

Scott Shannon - MPI

William Roberts

Terri Long - FDEP - West Palm Beach

Matt Killeen Tim Porter

Jeff Turpin - BCOIWM

File: 3.7.3 File: 5.1.3.2

XC: Isadore Goldmin, SED Al Chero, DEP Javiet Mach, Brown County

s:091400

Barbara \ Cile



Department of Environmental Protection

Jeb Bush Governor Twin Towers Office Building 2600 Blair Stone Road Tallahassee, Florida 32399-2400 Certified Mail -- Return Receipt Requested

David B. Struhs Secretary

August 22, 2000

Mr. William Roberts
Regional Manager
Wheelabrator North Broward, Inc.
2600 N.W. 48th Street
Pompano Beach, FL 33073

Re:

DEP File No. 0112120-003-AC, PSD-FL-122C

Modification to Permit No. PSD-FL-122B

Wheelabrator North Broward

Dear Mr. Roberts:

We are in receipt of your request for a minor modification to the referenced facility PSD permit for the construction of two minor source wet scrubbers dated July 24, 2000, and received by the Department on July 27, 2000. However, we must deem your application incomplete due to the following reasons:

- 1. Please submit you application using the proper Department form No. 62-210.900(1). The form is available on the Department's Internet web site: www.dep.state.fl/air.
- 2. Rule 62-4.050(3), F.A.C. requires that all applications for a Department permit must be certified by a professional engineer registered in the State of Florida. This requirement also applies to responses to Department requests for additional information of an engineering nature. Please ensure that the completed application is so certified.

Please also note that we are advising applicants that Rule 62-4.055(1), F.A.C. requires a response to requests for information within 90 days. When we receive the above mentioned items, we will continue processing your application. If you have questions, please contact Tom Cascio at 850/921-9526.

Sincerely,

Scott M. Sheplak, P.E.

Administrator Title V Section

cc: Jarrett Mack, Broward County Isidore Goldman, SE District

"More Protection, Less Process"

on the reverse side?			I also wish to receive the following services (for an extra fee): 1.	ceipt Service.
IN ADDRESS completed of	3. Article Addressed to: Mr. William Roberts Wheelabrator North Broward, Inc. 2600 NW 48 St. Pompano Beach, FL 33073	4b. Service 1 Registere Express I	Type ad	for using Return Re-
RETUR	5. Received By: (Print Name)	Addressee's Address (Ohly if requested and fee is paid)		Thank you
s your	6. Signature: (Addressee or Agent)	និទានការស្លាប់ 		•
=	PS Form 3811. December 1994 10	2595-97-B-0179	Domestic Return Receipt	

P 265 657 774

US Postal Service

US Postal Service
Receipt for Certified Mail
No Insurance Coverage Provided.
Do not use for International Mail (See reverse)
Mr. William Roberts
Wheelabrator North Broward, Inc.
2600 NW 48 St.
Pompano Beach, FL 33073

٦	Certified Fee	J
4	Special Delivery Fee	
_	Restricted Delivery Fee	
April 1995	Return Receipt Showing to Whom & Date Delivered	
	Return Receipt Showing to Whom, Date, & Addressee's Address	
800	TOTAL Postage & Fees	\$
PS Form 3800	Postmark or Date 08-23	-00 59D